MASTER

**Technical Specifications for the
Bulk Shielding Reactor**

OAK RIDGE NATIONAL LABORATORY
OPERATED BY UNION CARBIDE CORPORATION · FOR THE DEPARTMENT OF ENERGY

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

Printed in the United States of America. Available from
National Technical Information Service
U.S. Department of Commerce
5285 Port Royal Road, Springfield, Virginia 22161
Price: Printed Copy \$4.00, Microfiche \$3.00

52

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, contractors, subcontractors, or their employees, makes any warranty, express or implied, nor assumes any legal liability or responsibility for any third party's use or the results of such use of any information, apparatus, product or process disclosed in this report, nor represents that its use by such third party would not infringe privately owned rights.

ORNL/TM-6345

Contract No. W-7405-eng-26

Operations Division

TECHNICAL SPECIFICATIONS

FOR THE

BULK SHIELDING REACTOR

Date Published - June, 1978

OAK RIDGE NATIONAL LABORATORY
Oak Ridge, Tennessee 37830
operated by
UNION CARBIDE CORPORATION
for the
DEPARTMENT OF ENERGY

EB
DISTRIBUTION OF THIS DOCUMENT IS ~~UNLIMITED~~

**THIS PAGE
WAS INTENTIONALLY
LEFT BLANK**

CONTENTS

1. Glossary of Terms	1-1
2. Safety Limits and Limiting Safety System Settings	2-1
2.1 Safety Limits	2-1
2.1.1 Safety Limits for Operation in Mode 1 (Natural Con- vection)	2-1
2.1.2 Safety Limits for Operation in Mode 2 (Forced Con- vection)	2-2
2.2 Limiting Safety System Settings	2-4
3. Limiting Conditions for Operation	3-1
3.1 System Reactivity	3-1
3.1.1 The Reactor Core	3-1
3.2 Core Configuration	3-2
3.3 Reactor Control and Safety System	3-3
3.3.1 Minimum Reactor Instrumentation Requirements	3-3
3.3.2 Mechanical Control System	3-4
3.4 Cooling System	3-5
3.5 Emergency Systems	3-6
3.5.1 Confinement System	3-6
3.5.2 Coolant Leaks	3-8
3.6 Radiation Monitoring Equipment	3-8
3.7 Limitations on Experiments	3-9
4. Surveillance Requirements	4-1
4.1 System Reactivity	4-1
4.1.1 The Reactor Core	4-1
4.2 Core Configuration	4-2
4.3 Reactor Control and Safety System	4-3
4.3.1 Surveillance of Reactor Instrumentation	4-3
4.3.2 Surveillance of Mechanical Control System	4-4
4.4 Primary Cooling System	4-5
4.5 Emergency Systems	4-6
4.5.1 Confinement System	4-6
4.5.2 Coolant Leaks	4-6

	Page
4.6 Radiation Monitoring Equipment	4-7
4.7 Limitations on Experiments	4-8
5. Design Features	5-1
5.1 Reactor Fuel	5-1
5.2 Reactor Building	5-2
5.3 Fuel Storage and Handling	5-3
6. Administrative Controls	6-1
6.1 Organization	6-1
6.2 Personnel Qualification	6-1
6.3 Staff Requirements	6-1
6.4 Facility Modifications	6-1
6.5 Operating Procedures	6-3
6.6 Action To Be Taken in the Event a Safety Limit Is Exceeded . .	6-4
6.7 Action To Be Taken in the Event of an Abnormal Occurrence . .	6-4
6.8 Reporting Requirements	6-4
6.9 Actions To Be Taken in Regard to Potential Degradations of a Reactor Shutdown System	6-5
6.10 Operating Records	6-6
6.11 Review Committees	6-6
6.11.1 Reactor Operations Review Committee	6-6
6.11.2 Reactor Experiment Review Committee	6-7
6.11.3 Criticality Committee	6-7
7. References	7-1

TECHNICAL SPECIFICATIONS
FOR THE
BULK SHIELDING REACTOR

1. GLOSSARY OF TERMS

The following list is a glossary of terms frequently used in the discussions in the Technical Specifications.

- 1.1 Abnormal Occurrence - An abnormal occurrence is any of the following:
- a. Any actual safety system setting less conservative than specified in 2.2, Limiting Safety System Settings.
 - b. Operation in violation of a Limiting Condition for Operation.
 - c. Incidents or conditions which prevented or could have prevented the performance of the intended safety function of an engineered safety feature or the reactor safety system.
 - d. Release of fission products of a magnitude to indicate a failure of the principal physical boundary.
 - e. An uncontrolled or unanticipated change in reactivity.
 - f. An observed inadequacy in the implementation of either administrative or procedural controls, such that the inadequacy has caused the existence or development of an unsafe condition in connection with the operation of the reactor.
 - g. An uncontrolled or unanticipated release of radioactivity.
- 1.2 Calibration - An adjustment of electronic, mechanical, pneumatic, or other sensing systems such as the output of the system responds, with acceptable range and accuracy, to known values of the parameter that the system measures or to known input signals when access to the primary element is limited.
- 1.3 Certified Operator (RO or SRO) - Any individual who has successfully completed the training, examination, and certification for reactor operator (RO) or senior reactor operator (SRO) pursuant to ERDA Manual Chapter 0540 and pursuant to IAD 8401-6.
- 1.4 Channel Calibration - A channel calibration is an adjustment of the channel such that its output responds, with acceptable range and accuracy, to known values of the parameter that the channel measures

or to known input signals when access to the primary element is limited.

- 1.5 Channel Check - A channel check is a qualitative verification of acceptable performance by observation of channel behavior. This verification shall include comparison of the channel with expected values or other independent channels or methods of measuring the same variable.
- 1.6 Channel Test - A channel test is the introduction of an appropriate signal into a channel to verify that it is operable.
- 1.7 Core Configuration - The disposition of reactor core elements within the reactor, including position, number, and fuel mass.
- 1.8 Degradation of the Reactor Shutdown System -
 - a. Class 1 - The actual failure of the reactor shutdown system to initiate the protective action when the reactor variable has exceeded the limiting safety system setting (LSSS) or the premature termination of the protective action. For example: Reactor coolant flow rate decreases to below the LSSS without an automatic trip; the relatching of neutron-absorbing rods prior to achieving the required shutdown margin.
 - b. Class 2 - Failure or malfunction of components, personnel error, or procedural inadequacy which, due to its effect on multiple units, would, by itself, prevent the reactor shutdown system from providing the protective action at the LSSS. For example: In a two-out-of-three system, the drift of the setpoints of two flow channels to values beyond the LSSS; an improper calibration procedure which resulted in several setpoint adjustments being effectively beyond the LSSS.
 - c. Class 3 - Failure or malfunction of one or more components, personnel error, or procedural inadequacy which reduces the capability of the reactor shutdown to the extent that the occurrence of a random single failure would prevent the protective action at the LSSS. For example: In a two-out-of-three system, the drift of a single channel setpoint to a value beyond the LSSS.
 - d. Class 4 - Failure or malfunction of one or more components, personnel error, or procedural inadequacy affecting a limited number

of units such that, although the degree of redundancy may be reduced, the reactor shutdown system retains, even after the application of the single failure criterion, the ability to provide the protective action when required (conditions and LSSS) by the Technical Specifications. For example: In a two-out-of-four system, one undervoltage relay failed to perform during a test.

- 1.9 Engineered Safety Features - Features of a unit, other than reactor trip or those used only for normal operation, that are provided to prevent, limit, or mitigate the release of radioactive material.
- 1.10 Excess Reactivity - Excess reactivity is the excess k_{eff} above unity that would exist if all the shim-safety rods were fully withdrawn.
- 1.11 Experiment - An experiment is any apparatus (other than the reactor components and structure), device, or material placed in the reactor core region, in an experimental facility, or in line with a beam of radiation emanating from the reactor.
- 1.12 Flight Time - Flight time is the time interval between the introduction of a fast scram signal and the actuation of the seat switch of the rod being tested. Flight time measurements are normally made with the rod withdrawn to the upper limit of its travel.
- 1.13 Fuel Element - Fuel elements are core pieces that can be inserted into the BSR grid and that contain a fissionable material for use in the production of energy.
- 1.14 Functional Test - A functional test is a test of a component or system of components to assure that the component or system of components perform as per design when called upon.
- 1.15 Ganged-Rod Position - This is a term used to describe the relationship of shim-safety rod positions. Any number of shim-safety rods are said to be at ganged-rod position if they are withdrawn equidistant from their seats.
- 1.16 Limiting Conditions for Operation - Limiting Conditions for Operation (LCO) are those administratively established constraints required for safe operation of the facility.
- 1.17 Limiting Safety System Settings - Limiting Safety System Settings (LSSS) are those limiting values for settings of the safety channels by which

point protective action must be initiated.

- 1.18 Movable Experiment - A movable experiment is one in which it is intended that the entire experiment or part of it may be moved in or near the core or into and out of the reactor while the reactor is operating.
- 1.19 Nominal Full Power - 2 MW (Administrative Limit).
- 1.20 Operable - A component or system is operable when it is capable of performing its intended function in a normal manner.
- 1.21 Operating - A component or system is operating when it is performing its intended function in a normal manner.
- 1.22 Operating Modes -
 - a. Natural Convection Mode - Operation in which natural convection cooling is adequate; level at 1.2 MW or less.
 - b. Forced Flow Mode - Operation in which forced convection cooling is required; level in excess of 1.2 MW.
- 1.23 Power Operation - Operation at power levels in excess of 200 kW (sometimes referred to as "operation at power").
- 1.24 Reactor Safety System - The reactor safety system is that combination of measuring channels and associated circuitry which forms the automatic protective system of the reactor.
- 1.25 Reactor Secured - That overall condition where all of the following conditions are satisfied:
 - a. Reactor shutdown.
 - b. Electrical power to the control rod circuits is switched off and switch key is in proper custody.
 - c. No work in progress involving in-core components, experiments, or installed control rod drives.
- 1.26 Reactor Shutdown - The reactor is in a shutdown condition when all shim-safety rods are fully inserted or when it is in a reactivity condition equivalent to one where all shim-safety rods are fully inserted.
- 1.27 Release Time - The release time is the time interval between a fast scram signal and the first detectable movement of the magnet armature.
- 1.28 Safety Channel - A safety channel is a combination of detectors, amplifiers and associated circuitry that forms an input to the automatic

protective system and is designed to initiate a reactor shutdown for the primary purpose of protecting the reactor.

- 1.29 Safety Limit - Safety Limits are limits on important process variables which are found to be necessary to reasonably protect the integrity of certain of the physical barriers which guard against the uncontrolled release of radioactivity.
- 1.30 Shim-Safety Rods - Shim-safety rods (control rods) are the neutron-absorbing core components used to control the reactor power by varying their position in the reactor core. Shim-safety rods may or may not contain a fuel section.
- 1.31 Shutdown Margin - The shutdown margin is the amount of reactivity which must be added to a shutdown reactor to make it critical.
- 1.32 Shutdown Mechanisms - The shutdown mechanisms consist of any of the following:
 - a. Scram - Gravity insertion of all shim rods.
 - b. Setback - A reduction of reactor power by the automatic control system.
 - c. Reverse - Motor driven insertion of all shim rods at their normal insertion speed.
- 1.33 Specifications for BSR Fuel Elements and/or BSR Shim Rod Elements - Detailed material and fabrication specifications, quality assurance requirements, and associated engineering drawings approved by ORNL Operations Division management.
- 1.34 Startup Operation - Operation at 200 KW or less.
- 1.35 Time Intervals -
 - a. Biennially - To be performed once each two years at intervals not to exceed 30 months.
 - b. Annually - To be performed once each year at intervals not to exceed 14 months.
 - c. Semiannually - To be performed two times annually at intervals not to exceed 8 months.
 - d. Quarterly - To be performed four times annually at intervals not to exceed 5 months.
 - e. Monthly - To be performed once each month at intervals not to exceed 60 days.

- f. Weekly - To be performed once each week at intervals not to exceed 10 days.
- g. Daily - To be performed once each day at intervals not to exceed 2 days.

- 1.36 Tried Experiment - A tried experiment is either of the following:
- a. An experiment previously approved and performed in this reactor.
 - b. An experiment of similar size, shape, composition, and location as an experiment previously approved and performed in this reactor.

2. SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

2.1 Safety Limits

2.1.1 Safety Limits for Operation in Mode 1 (Natural Convection)

Applicability:

This specification applies to the process variables associated with core thermal and hydraulic performance when operating in the natural convection flow mode. The variable is reactor power.

Objective:

The objective is to establish limits for the critical process variables which, if not exceeded, will provide confidence that the integrity of the fuel-element cladding will not be breached.

Specifications:

When operating in the natural convection mode, the reactor power shall not exceed 3.5 MW.

Bases:

The safety limit set forth in this specification has been established to ensure operation at or below a power level at which there is a wide burnout margin. The critical heat flux for natural convection cooling and 120°F inlet temperatures as interpolated from the experimental data of Gambill and Bundy¹ is about 1.25×10^5 Btu/ft²hr. The maximum heat flux in the BSR has been very conservatively estimated to be 2.51×10^4 Btu/ft²hr/MW (Ref. 2,3). Hence the burnout power level is about 5 MW under natural convection conditions.

The inlet water temperature is normally automatically controlled at 100°F and operation of the reactor is administratively prohibited if the inlet temperature exceeds 120°F. Since the pool contains ~130,000 gal (1.06×10^6 lb) of water, nearly 2 hours operation at 3.5 MW is required to raise the pool water temperature 20°F to the administrative limit. Rapid changes in coolant inlet temperature, therefore, need not be considered since there is adequate time for supervisory action to effect administrative control.

2.1.2 Safety Limits for Operation in Mode 2 (Forced Convection)

Applicability:

This specification applies to the process variables of Reactor Thermal Power and Reactor Primary Coolant Flow.

Objective:

The objective is to establish limits for the critical process variables which, if not exceeded, will provide confidence that the integrity of the fuel-element cladding will not be breached.

Specifications:

When operating in the forced convection mode, the relationship between total reactor primary coolant flow rate and reactor power shall lie to the right of and under curve B of Fig. 2.1.

Bases:

The safety limits set forth in these specifications have been established to guarantee against operation in a region which can cause damage to the fuel cladding.

The parameters which are of importance in determining the critical heat flux for subcooled boiling burnout are coolant velocity and degree of subcooling. Since neither of these can be measured directly, an analysis³ of typical BSR cores was undertaken in order to relate these parameters to the measured variables: flow, power level, and temperature.

Curve A of Fig. 2.1 is a very conservative estimate of the conditions required to produce a critical heat flux somewhere in the core. It is based upon the Gambill minimum critical heat flux correlation⁴ and assumes a coolant inlet temperature of 120°F and a maximum to average heat flux ratio of 3. (The highest observed value of this ratio is 2.23.) The safety limit (curve B of Fig. 2.1) has been established by requiring a 10% margin on power level below the estimated burnout curve. The lower limit on flow is established to prevent operation in the region where a combination of low velocity downward forced convection and upward natural convection could produce flow instabilities.

2.2 Limiting Safety System Settings

Applicability:

These specifications apply to the safety system action set points for the reactor process variables related to the safety limits.

Objective:

The objective of this specification is to provide limiting values of the set points of the safety channels so that automatic protective action, sufficient to provide confidence that the criteria set forth in the safety limits (Section 2.1) are satisfied, will occur when required.

Specifications:

a. For Mode 1, Natural Convection

Reactor Power: The LSSS on the power of the reactor in the natural convection mode shall be 1.75 MW.

b. For Mode 2, Forced Convection

The relationship between the reactor primary coolant flow rate LSSS and the reactor power LSSS shall lie below and to the right of Curve C of Fig. 2.1.

Bases:

The limiting safety system settings were chosen such that when measurement uncertainties and anticipated transient conditions are considered there is confidence that the criteria set forth in the safety limits are at all times satisfied.

The maximum power level LSSS for the natural convection mode has been set at the nucleate boiling level, a factor of about 2.9 below burnout.

For the forced convection flow mode, the LSSS have been chosen to provide a factor of 1.75 between the LSSS and the lowest occurrence of a critical heat flux.³ The specific limitation on flow provided at the lower end is to ensure that the limits are within the range of validity of the calculations.

3. LIMITING CONDITIONS FOR OPERATION

3.1 System Reactivity

Applicability:

These specifications apply to the reactivity condition of the reactor and its associated components.

Objective:

The objective is to ensure that the reactor can be made subcritical and maintained in a subcritical condition whenever required, and to prevent the occurrence of any condition that might add a significant amount of uncontrolled reactivity.

3.1.1 The Reactor Core

Specifications:

- a. Excess Reactivity Loaded in the Core - The core excess reactivity shall be less than or equal to 50% of the reactivity worth of the shim-safety rods when they are withdrawn in the ganged position. In addition, the reactor core will be so arranged that the shutdown margin with the highest worth shim rod withdrawn shall be greater than 0.8% $\Delta k/k$ relative to the cold clean condition. The total mass of fuel in the core will be adjusted to achieve this before criticality for power operation is attained. (Failure to meet these requirements during criticality tests of a new core configuration or for other investigative purposes shall not be regarded as a violation of the specification provided corrective action is taken prior to startup for power operation.)
- b. Reactivity Worth of Experiments - The limitations on reactivity worth of experiments either within the core or sufficiently close to the reactor to produce significant interactions are specified in Section 3.7.
- c. Minimum Distance - The minimum distance between the BSR core and the PCA core shall be maintained at greater than 10 inches by means of mechanical stops.

Bases:

- a. The limitation on excess reactivity is expressed in terms of relative rod worths rather than in absolute terms, because the absolute worths of the shim-safety rods are a function of the specific fuel mass and configuration of the core. The requirements that no one rod can produce criticality guarantees that the rod worths are distributed in a manner that minimizes the consequences of the uncontrolled withdrawal of a single rod.

To ensure that the worths of the shim-safety rods are adequate to meet the requirements of Section 3.1.1, Specification "a," they are calibrated, individually and ganged, whenever a significant change in core configuration is introduced.

Normally the total worth of the shim-safety rod complement is about 11% $\Delta k/k$ so that the shutdown margin is about 5.5% $\Delta k/k$.

- b. Reactor experiments are examined to determine their reactivity effects and also their potential for increasing or decreasing the reactivity of the system; and specific requirements are imposed to ensure that reactor experiments cannot, by failure or misoperation, significantly affect the reactivity balance of the reactor. This is discussed further in Section 3.7.
- c. It has been determined that this distance is adequate to prevent interaction between the two cores.⁵

3.2 Core Configuration

Applicability:

This specification applies to the determination of core configurations which may be used in the reactor.

Objective:

The objective is to ensure that, under all permissible operating conditions, the maximum heat flux in the reactor is sufficiently below the burnout heat flux to provide an adequate margin of safety.

Specifications:

The reactor core configuration shall be such that the maximum power generated in any fuel element, shall not exceed 0.09 MW per MW of reactor power.

Basis:

At normal flow, 1100 gpm, the minimum burnout heat flux in the BSR core has been conservatively estimated to be 1.75×10^5 Btu/ft²hr (Ref. 3). This specification which utilizes an axial hot spot factor of 1.5 provides a margin of 2.73 between the normal power level of 2 MW and the burnout power level. Should the flow be reduced to the LSSS of 700 gpm the margin would become 1.75. Should both the power level and the flow reach their respective LSSS values simultaneously, a margin of 1.13 would remain. In the natural convection mode with the power level at the LSSS the margin is 2.85.

3.3 Reactor Control and Safety System

Applicability:

This specification applies to the safety, control, and surveillance instrumentation and to the mechanical components of these systems which are required for startup and operation.

Objective:

The objective is to ensure that an adequate complement of safety, control, and surveillance instrumentation together with the requisite mechanical components are available during startup and operation.

Specifications:

3.3.1 Minimum Reactor Instrumentation Requirements

The minimum complement of reactor safety and measuring instrumentation required for startup and operation is specified in Table 3.1.

Table 3.1. Minimum Instrumentation Required
for Reactor Operation

Description	Number Required	
	Mode 1	Mode 2
	Natural Convection	Forced Convection
<u>Safety or Protective Channels</u>		
Safety level channels	2	2
Log N channels	1 ^a	1 ^a
ΔT channels	None	1 ^b
Primary coolant flow channels ^c	None	2
Manual Scram	1	1
<u>Measuring Channels</u>		
Fission chamber channel	1 ^a	1 ^a
Flapper valve position channels	1	1
Pool water level channels	1	1

^aStartup only, not needed with the reactor at power.

^b ΔT channels serve as backup instrumentations for the reactor safety level channels and therefore do not need to be redundant.

^cFlow channels may utilize core ΔP instrumentation.

3.3.2 Mechanical Control System

- Number of Shim-Safety Rods - The reactor shall not be operated with less than four shim safety rods.
- Maximum Release Time - The release time of the shim-safety rods shall be less than 30 ms.
- Maximum Flight Time - The maximum flight time shall be 800 ms or less.
- Maximum Rate of Reactivity Addition - The maximum rate of positive reactivity addition (by movement of the shim-safety rods) shall be limited to 0.10% $\Delta k/k$ per second.
- Maximum Reactivity Available to the Servo System - The maximum reactivity available to the servo control system shall be limited to 0.75% $\Delta k/k$.

Bases:

The reactor control and safety system is designed to prevent the only credible cause for a massive release of fission products from the BSR fuel, namely, overheating to an extent sufficient to cause melting and destruction of the integrity of the fuel cladding. Such a condition could be brought about either by an increase in power beyond the capacity for heat removal, a decrease in the heat transfer capability of the system, or a combination of both.

The requirement that the above listed minimum instrumentation be operable and that the associated mechanical components be operable is sufficient to guarantee against these conditions.

The release and flight times prescribed are those which could reasonably be expected when the shim-safety rods are free to fall within their guides and thus ensure that the rods are unrestricted and free to fall when called upon to do so.

Based upon Spert data cited in the BSR Safety Analysis report² restriction of the reactivity addition rate to 0.1% $\Delta k/k$ per second guarantees that during a startup runaway the maximum fuel surface temperature would not exceed 320°F which is well below the melting point.

During normal operation the reactor is operated by means of a servo system which provides automatic shimming to compensate for small positive and negative reactivity changes. The BSR has a delayed neutron fraction equivalent to $\sim 0.81\%$ $\Delta k/k$, and the positive reactivity which is available to the servo is maintained at less than this value to prevent the possibility of prompt criticality as a result of servo action.

3.4 Cooling System

Applicability:

These specifications apply to the conditions which must exist in order for the reactor pool to supply cooling water to the reactor and provide adequate shielding for the reactor core.

Objective:

The objective is to ensure an adequate supply of cooling water to provide heat removal, shielding, and moderation to the reactor.

Specifications:

- a. Coolant Flow - When operating in the Forced Convection Mode the head of the water in the pool shall be sufficient to maintain the flows required by the LSSS specified in Section 2.1.2.
- b. Coolant Temperature - During reactor operation the bulk coolant temperature shall not exceed 120°F.
- c. Shielding - The height of the water in the pool shall be maintained at a level sufficient to protect against radiation exposures in excess of the limits specified in ERDAM 0524.
- d. Radioactivity Level - The radioactivity in the cooling water shall be maintained at a level low enough to provide protection against radiation exposures in excess of those specified in ERDAM 0524.

Bases:

- a. Forced convection flow through the BSR core is provided by a syphon system which takes water from the reactor core and leads it to a decay tank located at a lower elevation. The coolant is then pumped through a heat exchanger and returned to the pool. The coolant flow rate available depends upon the head provided by the depth of the water in the pool, and this must be adequate to satisfy the LSSS flow requirements.
- b. The critical heat flux calculations and resulting safety limit and LSSS values were determined using an inlet temperature of 120°F. Thus, if this value is not exceeded, these limits remain conservative with respect to the inlet temperature.
- c,d. Normally the radiation levels in the occupied areas near the reactor pool are considerably less than those specified by ERDAM-0524; however, in order to allow for abnormal operations and experimental operations, the legislated limits are specified.

3.5 Emergency Systems

3.5.1 Confinement SystemApplicability:

This specification applies to the operating status of the reactor building and the associated exhaust system.

Objective:

The objective is to ensure containment integrity when it is needed.

Specification:

The BSR shall not be operated unless the building confinement system is operable. The minimum requirements are:

- a. Flow through the exhaust duct must be in the normal range, i.e., between 3,025 cfm and 5,500 cfm.
- b. The filter bank for the exhaust system shall be operable and the filters therein shall meet removal efficiency specifications, i.e., particulate filters shall show an efficiency of 99.5% for removal of particles $\geq 0.3 \mu$ in size, and the iodine absorbers shall show an efficiency of $\geq 97\%$ for removal of elemental iodine.
- c. All building doors and any other openings in the building must be properly closed, equipped with automatic closers, or be under the direct control of qualified operators.
- d. Automatic activation of the containment mode of the confinement system shall occur when the general radiation background in the vicinity of the containment system monitor exceeds 150 mR/hr.

Basis:

The BSR containment system, in principle, is described on page 34 of the description and safety analysis report.² The restrictions imposed by Specification 3.5.1 will ensure that the requirements for containment are met when needed at any time when the reactor is operating.

Since the establishment of a negative pressure differential is related to the exhaust rate, the requirements on exhaust rate have been selected to guarantee an adequate negative pressure.

The filter efficiencies are based upon the highest values that can be practically achieved with commercial equipment. Many years of experience have shown that these values are more than adequate to reduce the normal effluents to trivial levels, and under the conditions of the maximum hypothetical accident they provide a reduction in the iodine release to well below the maximum permitted by guidelines of 10CFR100.

3.5.2 Coolant Leaks

Applicability:

This specification applies to leaks from the pool or primary water cooling system.

Objective:

The purpose of this specification is to ensure that the loss of water from the pool is within acceptable limits.

Specification:

The reactor shall not be operated with a leak or leaks in the pool or primary coolant system which exceed 30 gallons per minute.

Basis:

It has been determined⁶ that should the design basis accident occur while the reactor coolant system is leaking at a rate of 30 gpm, even under the most pessimistic assumptions the consequences would not result in any significant hazard to the public.

3.6 Radiation Monitoring Equipment

Applicability:

This specification applies to the monitoring of radiation levels and airborne activity in the reactor building.

Objective:

The objective is to ensure that a sufficient number and variety of operable instruments to adequately monitor radiation levels throughout the building are available.

Specifications:

The reactor shall not be operated unless the following minimum requirements for operable area radiation monitors are met or backup measures approved by the reactor supervisor or his designated alternate are provided:

- a. At least two operable constant air monitors shall be located at appropriate points within the reactor building.
- b. At least two operable monitrons shall be located at appropriate points within the building.
- c. Readouts from the required equipment shall be displayed in the reactor control room and at the remote control console.

d. At least one β, γ stack monitor is operable.

Basis:

The minimum required number of radiation monitors in the building provides protection and warning of elevated levels of radiation so that there will be sufficient time to evacuate the building or portions of the building and to take necessary steps to prevent the spread of radioactivity to the surroundings.

Remote indication in the control room and at the remote control console provides continuously available information concerning the radioactivity levels within the building.

3.7 Limitations on Experiments

Applicability:

These specifications apply to all experiments installed in the BSR.

Objective:

The objective of these specifications is to establish general limits for BSR experiments that will protect the reactor from damage and shall limit radiation exposure to both on-site and off-site personnel to as low as practicable levels.

Specifications:

The following limitations apply to all in-reactor experiments:

a. Reactivity - The following limits apply to individual experiments:

- (1) Experiments which can cause a positive reactivity change greater than $0.5\% \Delta k/k$ and which are movable experiments shall be equipped with a mechanical insertion-and-removal system having the same reliability as the reactor control-system drives. The reactivity insertion rate by these mechanisms shall not exceed $0.01\% \Delta k/k \text{ s}^{-1}$.
- (2) Experiments which can cause a positive reactivity change greater than $0.5\% \Delta k/k$ due to motion but which need not be moved while the reactor is critical shall be so firmly supported that no credible circumstance can cause them to be moved while the reactor is critical.
- (3) Experiments which can cause a positive reactivity change greater than $0.5\% \Delta k/k$ due to being damaged by temperature

or pressure shall be instrumented to cause an appropriate reactor power or reactivity reduction if such temperature or pressure is approached. This is in addition to the safeguards built into the experiment to control the temperature and/or pressure.

- (4) The combined reactivity worth of all experiments which can add positive reactivity to the core due to a common-mode failure shall be $\leq 50\%$ of the shutdown margin of the shim-safety rod control system.

- b. Hydraulic Stability - All in-core experiments shall be designed to withstand the hydraulic forces and each assembly shall be staked, welded, or adequately held to avoid loss into the reactor.
- c. Temperature - Heat developed in any experiments by gamma absorption, fissions, electric heaters, etc., shall be dissipated by an adequate coolant flow. Under normal conditions, the temperature of the outer container shall not exceed the saturation temperature of the reactor coolant.
- d. Explosives - No explosives or mixtures of material that under credible circumstances can detonate shall be irradiated in the reactor.
- e. Pressure Containment - Where failure of pressure-containing walls of an experiment can cause a hazard to personnel or to the reactor, the container shall meet the intent of applicable pressure vessel codes. The design for each such container shall be reviewed by a competent engineer and written approval obtained from the Operations Division and the Reactor Experiment Review Committee (RERC).

Bases:

- a. Reactivity
 - (1), (2), and (3) The upper limit of $0.5\% \Delta k/k$ for a reactivity change by an experiment ensures that such change will not result in prompt criticality. It also ensures that the servo system can immediately compensate for such change. The limit of $0.01\% \Delta k/k \text{ s}^{-1}$ for an intentional, controlled reactivity insertion rate ensures adequate compensation by the servo system.

- (4) The restriction on the combined reactivity worth of all experiments guarantees that the shutdown margin is always adequate to make the reactor subcritical.
- b. Hydraulic Stability - The reactor components must be protected from damage that might result from the movement of an experiment in an uncontrolled manner due to hydraulic forces. The requirements of 3.7 (b) will ensure this.
 - c. Temperature - As with reactor components, the surfaces of experiment rigs are maintained below the saturation temperature of the reactor coolant to avoid steam blanketing and possible burnout.
 - d. Explosives - The irradiation of explosives is avoided to protect reactor components from possible damage.
 - e. Pressure Containment - Depending on location, failure of pressure-containing walls could affect reactivity or damage adjacent reactor components. Failure of pressure-containing walls external to the reactor may endanger personnel directly by impact injury or release of radioactive gases. The use of applicable pressure vessel codes insures that adequate safety margins are maintained.

4. SURVEILLANCE REQUIREMENTS

The surveillance requirements in this section apply to continuous system and facility operation. During periods of extended shutdown (periods of time greater than the minimum frequency listed), the stated requirements may be suspended. However, in this case, the requisite surveillance must be performed before the system is again considered operable.

4.1 System Reactivity

Applicability:

These specifications apply to the surveillance requirements for system reactivity.

Objective:

The objective is to ensure compliance with the specifications in Section 3.1 relative to system reactivity.

4.1.1 The Reactor Core

Specifications:

- a. Prior to the startup following significant changes to the reactor configuration or loading, including experiment and reflector changes, or annually, whichever of the above shall occur first, the ganged-rod position that represents 50% of the shim-safety rod worth shall be determined. If the reactor reaches criticality with the rods withdrawn to a lesser extent than this, the reactor shall be shut down and the situation corrected.

Prior to the startup following significant changes to the reactor configuration or loading, including experiment and reflector changes, or annually, whichever of the above shall occur first, each shim-safety rod shall be withdrawn to its upper limit to ensure that the reactor is sufficiently subcritical with each rod withdrawn while the others are fully inserted. (This check is normally accomplished in conjunction with the flight time measurements.) Should the test fail, the reactor shall be shut down and the situation corrected. The shim-safety rods shall be calibrated for

reactivity worth whenever a significant change in core loading is made or prior to operation following installation of a new rod.

- b. When required, calculations shall be performed to ensure that the requirements of Section 3.1.1, Specification "b" are met. Where uncertainty exists, experiments to determine the worth of experiments shall be performed. Additional specifications concerning experiments are listed in Section 4.7.

Basis:

These surveillance requirements for reactivity limitations are based upon more than 20 years of experience with the BSR which indicates that adherence to the required checks at the specified frequency is adequate to guarantee compliance with Section 3.1.1.

4.2 Core Configuration

Applicability:

The specifications apply to the procedures for determining permissible core configurations.

Objective:

The objective is to ensure compliance with the specifications in Section 3.2 relative to reactor core configurations.

Specification:

All fuel loadings shall be specified by a qualified member of the Technical Staff and, prior to power operation, all reactor core configurations shall be examined by the Operations Division Technical Staff either by comparison with previously analyzed cores or by calculation and/or experiment to verify that the criterion set forth in Section 3.2 is satisfied.

Basis:

Methods³ have been developed to estimate the maximum heat flux in the reactor fuel elements. Moreover, data on the operating power level and maximum heat flux in a large number of representative core configurations operated in the past are available for comparison.

4.3 Reactor Control and Safety System

Applicability:

This specification applies to the surveillance requirements for the safety and measuring instrumentation and for the mechanical components of the control systems required for startup and operation.

Objective:

The objective is to ensure the continued operability of the control and safety systems.

4.3.1 Surveillance of Reactor Instrumentation

Specifications

a. Testing

- (1) The safety-level channels, the Log-N channel, and the fission chamber channel shall be tested:
 - (a) Prior to each startup following refueling or other changes in the reactor core configuration or a start-up following an extended shutdown (>8 hours).
 - (b) Prior to startup after any change or maintenance involving any component of these channels.

b. Calibration

- (1) The safety level, Log-N, and fission chamber channels shall be calibrated quarterly or following major maintenance.
- (2) The ΔT and primary coolant flow channels shall be calibrated annually or following major maintenance.
- (3) The flapper valve position channels shall be subjected to a functional test quarterly or following major maintenance.
- (4) The pool water level channels shall be calibrated annually or following major maintenance.

c. Channel Checks

- (1) A channel check of those safety or protective channels required during operation shall be made prior to each startup following refueling or other changes in the reactor configuration or a startup following an extended shutdown (>8 hours).

4.3.2 Surveillance of Mechanical Control System

Specifications:

- a. The shim-safety rods shall be visually and dimensionally inspected biennially.
- b. The release time and flight time for each shim-safety rod shall be measured quarterly or any time that the shim-safety rod is moved to a new position, or following maintenance to a shim-safety rod or its related drive mechanisms.
- c. The maximum rate of reactivity addition by the shim-safety rods shall be determined following a significant increase in total worth of the shim-safety rods, whenever there is a significant change in core configuration, or annually.
- d. A measurement of the positive reactivity assigned to the servo-control system shall be made following a significant increase in the worth of the control rod as determined from shim-safety rod worth measurements or annually.

Bases:

The specified channel checks, tests, and calibrations will provide assurance that the various measuring channels are operating properly with reliable and correct output signals. The time intervals between checks, tests, and calibrations are based on over 20 years of experience with similar instrumentation in the BSR and other ORNL reactors.

Six years of experience with the 1.5% natural boron-stainless steel shim-safety rods has revealed no significant corrosion, cracking, growth, or other changes. Movement of, or maintenance to, the shim-safety rod or related drive parts could result in changes which could produce improper release or scram times, thus necessitating a measurement following any such activity. In the absence of maintenance or changes, our records show that release time and scram time change very little over a period of years.

Shim-safety rod calibration data have been gathered on a number of occasions during the lifetime of the rods, as well as following each significant change in core configuration. The data indicate that during the lifetime of a typical rod the composite reactivity

worth of all the shim-safety rods experiences no significant change. Therefore, recalibration following significant changes in core configuration provides adequate information to predict the shutdown margin.

4.4 Primary Cooling System

Applicability:

This specification applies to the surveillance requirements of the primary coolant system.

Objective:

The objective is to ensure the continuing integrity of the primary cooling system and to ensure compliance with the specifications set forth in Section 3.4.

Specifications:

- a. When the reactor is operating the height of the water above the reactor shall be checked once per shift.
- b. The temperature of the pool water shall be checked
 - (1) at intervals not to exceed three hours when operating in the natural convection mode,
 - (2) once per shift when operating in the forced convection mode.
- c. See "a" above.
- d. The radioactivity of the water is continuously monitored by an instrument which provides an alarm in the control room. During operation an independent check of the radioactivity of the pool water shall be made daily.

Basis:

Because of the large volume of water (~130,000 gallons) in the reactor pool, it would require an extremely large leak to lower the water level rapidly (~55 gpm per ft/hr). The forced convection system is a syphon device equipped with a syphon break so that rupture of the primary coolant line cannot drain the pool. Moreover, the pool water level is constantly monitored and displayed in the control room by the pool water level channel (see Section 3.3.1), hence the surveillance required is adequate.

Even at 2 MW operation with no secondary cooling, the pool water temperature cannot rise at a rate in excess of 6°F per hour. Thus the surveillance is adequate.

Continuous monitoring of the pool water radioactivity and the daily check is supplemented by the complement of radiation protection instruments in the building. Hence the surveillance is adequate to fulfill the requirements of Section 3.4.

4.5 Emergency Systems

4.5.1 Confinement System

Applicability

This specification applies to the surveillance requirements for the confinement system.

Objective

The objective of this specification is to ensure continued reliability of the confinement and the containment actuation systems.

Specifications

- a. The complete confinement closure system, including all instruments and indicators, shall be subjected to a thorough functional test quarterly.
- b. A test to confirm in-leakage to the building in the containment mode shall be conducted quarterly.
- c. The efficiency of the absolute filters and charcoal absorbers in the building containment system shall be measured semi-annually or after major maintenance or filter replacement.

Basis

Seven years of test records for the BSR containment system has shown that the closure system test frequency is proper. Also the records show that the efficiency of the absolute filters and charcoal absorbers changes very slowly and that their test frequency is adequate.

4.5.2 Coolant Leaks

Applicability

This specification applies to the surveillance requirements necessary to evaluate leaks from the primary cooling system.

Objective:

The objective is to ensure that leaks from the primary coolant system in excess of those specified in Section 3.5.2 are detected.

Specifications:

Based upon the surveillance requirements of Section 4.4.a., unexplained water losses from the primary coolant system shall be determined once per shift.

Basis:

This specification ensures that immediate attention will be brought to the fact that water losses are occurring and will provide for the implementation of the requirements of specification 3.5.2.

4.6 Radiation Monitoring Equipment

Applicability:

This specification applies to the surveillance requirements for the area radiation monitoring equipment.

Objective:

The objective is to ensure that the radiation monitoring equipment is operable.

Specifications:

- a. A calibration and a test of the radiation monitoring equipment for operability shall be conducted at least semiannually and after major maintenance.
- b. The stack monitor shall be calibrated at least semiannually, or following maintenance or change involving components of the system.

Bases:

Area radiation monitors are simple radiation detection devices and experience has indicated that they operate quite reliably for long periods of time. Nevertheless, their failure at any time cannot be discounted or predicted. Therefore, all the radiation monitors in the plant-wide radiation detection system are continuously monitored electronically to detect the most common types of failures expected. These devices are primarily used to detect the presence of radiation where none had previously existed. Their alarm point is set at a small value above background and absolute

accuracy is not essential. Hence, the semiannual test for operability combined with the continual electronic monitoring is considered adequate to ensure that the equipment remains in proper operation.

4.7 Limitations on Experiments

Applicability:

This specification applies to the surveillance requirements for experiment limitations.

Objective:

The objective is to ensure compliance with the specifications set forth in Section 3.7 regarding limitations on experiments.

Specifications:

- a. The Technical Assistance Department of the Operations Division shall review and examine all experiments proposed for insertion into the reactor for safety, potential hazards, and compatibility with the operation of the reactor and other experiments.
- b. New or unusual experiments shall be submitted with recommendations of the Technical Assistance Department to the Reactor Experiment Review Committee (RERC) for review in accordance with the provisions of Section 6.11 of these Technical Specifications.
- c. Tried experiments may be approved by the Technical Assistance Department without further review by the RERC.

Bases:

Review of experiments in accordance with the above specifications adequately ensures compliance with the specifications set forth in Section 3.7.

5. DESIGN FEATURES

5.1 Reactor Fuel

Applicability:

This specification applies to the fuel elements used in the reactor core.

Objective:

The objective is to ensure that the fuel elements are of such design and are fabricated in such a manner as to permit their use with a high degree of confidence in their reliability with respect to their physical and nuclear characteristics.

Specifications:a. Reactor Fuel Elements

- (1) The fuel elements for the reactor consist of "MTR" plate-type elements with cores containing uranium highly enriched in ^{235}U . The material requirements shall be as follows:
 - (a) Fuel plate U-Al alloy, U_3O_8 -Al cermet, or U-Al_x intermetallic, Al cladding
 - (b) ^{235}U enrichment: up to 97%
 - (c) Number of plates per element: 10-25
 - (d) Nominal weight of ^{235}U per element: ≤ 350 g
- (2) Fuel element design and core loading shall be correlated by experiment and calculation to ensure that the maximum operating heat flux will always be below the critical heat flux by a factor of at least 1.6 (see Reference 3).
- (3) All fuel elements fabricated for normal use as reactor fuel shall conform to the ORNL "Specifications for BSR Fuel Elements," and in addition vendors shall develop and implement a quality assurance program equivalent to RDT F2-4T. For internal fabrication the quality assurance program should be equivalent to RDT F2-2T.
- (4) Before awarding a contract to fabricate fuel elements, an ORNL site inspection team shall evaluate the prospective vendor's operation and make a positive determination that the vendor is capable of producing elements which have an

acceptably low probability of failure in the reactor.

b. Control-Rod Element

- (1) The control-rod elements consist of a partial fuel element containing MTR fuel plates similar to those used in the fuel elements with a central aluminum housing and guide for the control rod. The material requirements shall be as follows:
 - (a) Fuel plates: U-Al alloy, U_3O_8 -Al cermet, or $U-Al_x$ intermetallic, Al cladding
 - (b) ^{235}U enrichment: $\leq 97\%$
 - (c) Number of plates: 8-20
 - (d) Nominal weight of ^{235}U per element: ≤ 250 grams
- (2) Same as Section 5.1 Specification "a.(2)."
- (3) Same as Section 5.1, Specification "a.(3)" except "Specifications for BSR Control Rod Elements."
- (4) Same as Section 5.1, Specification "a. (4)."

Basis:

Calculations during the design and experience during operation of the reactor indicate that fuel control rod elements and control rods having these characteristics meet the criteria for reliability and performance.

5.2 Reactor Building

Applicability:

This specification applies to the building that houses the reactor.

Objective:

The objective is to ensure that provisions are made to restrict the amount of airborne radioactivity released to the atmosphere.

Specifications:

The reactor is housed in a building designed to be maintained at negative pressure with respect to the outside ambient pressure.

Bases:

The confinement system is designed to exhaust air from the reactor building at a rate to ensure leakage into the building and to maintain a slight negative pressure within the building with respect to outside ambient pressure. The air exhausted from the reactor building when in the containment mode passes through a series of filters described in Section

3.5.1 before being discharged through a stack to the atmosphere. The confinement system is in operation during all modes of reactor operation and during in-pool movement of irradiated fuel.

5.3 Fuel Storage and Handling

Applicability:

This specification applies to storage facilities for new and irradiated fuel.

Objective:

The objective is to store fuel in such a manner as to ensure subcritical conditions and ensure adequate cooling and shielding for irradiated fuel.

Specifications:

a. For Storage and Handling Outside the Reactor

- (1) Fuel elements and/or shim-safety rods shall be stored in storage facilities which have been reviewed, approved, and declared critically safe by ORNL's Criticality Committee.
The criterion used is that k_{eff} shall not exceed 0.95.
- (2) The transfer of fuel elements and/or shim-safety rods between approved storage facilities shall be only by authorization of the reactor supervisor or his authorized representative.
- (3) Irradiated fuel shall be stored in a manner which will provide natural convection cooling and adequate shielding.

b. For Handling Within the Reactor

- (1) All transfers shall be authorized by the reactor supervisor or his authorized representative.
- (2) All transfers shall be by written request which provides for identification of all fuel elements handled.

Bases:

All fuel units used in the BSR are fabricated according to specifications that have been developed to ensure dimensional control to guarantee that the elements will fit into a fixed, nonadjustable grid, to ensure that the fuel content is within rigid limits, to ensure that the cladding will safely contain fission products for the life of the elements, and to guarantee structural integrity of the assembled elements.

Stored fuel elements shall be maintained in a geometry that will prevent criticality. The methods of preventing and/or handling criticality hazards outside of the reactor core must be approved by the ORNL Criticality Committee, and this approval is documented in completed Nuclear Safety Requests. Critical experiments have been performed and these data are used in evaluating requests.

The handling of all fuel elements to, from, and/or within the reactor will result in approved core configurations. These core configurations are based on data from boiling experiments, previous fuel loadings, and empirical calculations. All fuel loadings are prepared by technical personnel based on these evaluations.

6. ADMINISTRATIVE CONTROLS

6.1 Organization

The Oak Ridge National Laboratory, which is owned by the Department of Energy and operated under contract by the Nuclear Division of Union Carbide Corporation, shall be responsible for operation and supervision of the facility. The Operations Division shall be directly responsible for the operation of the facility. The relationship of the reactor to the Laboratory's structure is shown in Figure 6.1.

6.2 Personnel Qualification

- a. The reactor shall be operated by personnel examined and qualified under the general provisions of ERDA Manual Chapter 0540, ERDAM Appendix 8401-II, and IAD 8401-6 and approved by the Operations Division Director.
- b. Jobs requiring an operator or a senior operator qualification are indicated in Figure 6.1 (Organizational Chart).

6.3 Staff Requirements

- a. The minimum personnel on duty during reactor operation shall be:
 - (1) One qualified senior operator; and
 - (2) One qualified operator.
- b. The control room or the remote control panel shall be attended by at least one qualified operator at all times during reactor operation.
- c. At least one qualified senior operator shall be present in the control room during reactor startup.

6.4 Facility Modifications

- a. It shall be the responsibility of the Division Director to ensure that changes in technical specifications or modifications to the plant protection system, reactivity control systems, or engineered safety features, or changes that involve a safety question not reviewed in the safety analysis report shall receive prior review and authorization by the RORC and/or DOE in accordance with the requirements of ORNL Standard Practice Procedure 18-B and ORO Manual Chapter 0540.
- b. Certain mechanical and instrumentation and control design changes may

6-2

Figure 6.1 Organizational Chart

¹ Shall be certified senior reactor operator..

² Shall be certified reactor operator.

be made by the contractor provided the effect of the change does not involve a change in a technical specification or an unreviewed safety question. Formal procedures shall be established for documenting important mechanical and instrumentation and control design changes.

6.5 Operating Procedures

- a. The reactor shall be operated in accordance with documented operating procedures. In no instance shall the operating procedures designate authorization to operate the reactor outside the bounds of any specifications listed in this document. The procedures shall be adequate to ensure safe operation of the reactor but should not preclude the use of independent judgment and action should the situation require such. Detailed written procedures shall be provided for, but not limited to, the following:
 - (1) Emergency and abnormal conditions including evacuations.
 - (2) Reactor startup, operation, and shutdown.
 - (3) Installation and removal of fuel elements, control rods, and all non-permanent reactor components.
 - (4) Routine maintenance of control rod drives and reactor safety systems.
- b. A standard method shall be used to change operating procedures as necessary to ensure that all persons concerned are notified of the change and that a permanent record is made. Permanent procedure changes shall require the approval of at least two of the following senior staff members:
 - (1) Operations Division Director
 - (2) Reactor Operations Department Head
 - (3) BSR Supervisor
 - (4) Assistant Reactor Supervisor
 - (5) Day SupervisorTemporary procedure changes that do not alter their original intent shall be made, when required, by issuing special operating instructions. Such special operating instructions shall be approved by at least two of the senior staff members listed above.

- c. Radiation control procedures shall be maintained and made available to all Operations personnel.

6.6 Action To Be Taken in the Event a Safety Limit Is Exceeded

In the event a safety limit is exceeded:

- a. The reactor shall be shut down and reactor operation shall not be resumed until authorized by DOE.
- b. An immediate report shall be made to the Director of the Office of Laboratory and Personnel Protection.
- c. A report shall be made to DOE no later than the next work day.
- d. A report shall be made which shall include an analysis of the causes and the extent of possible resultant damage, the effectiveness of corrective action, and recommendations for measures to prevent or reduce the probability of recurrence. This report shall be sent to the Reactor Operations Review Committee (RORC) and a similar report submitted to DOE when authorization to resume operation of the reactor is sought.

6.7 Action To Be Taken in the Event of an Abnormal Occurrence

In the event of an abnormal occurrence, as defined in Section 1, the following action shall be taken:

- a. The reactor supervisor and other appropriate management personnel shall be notified and corrective action taken.
- b. A report shall be made that shall include an analysis of the cause of the occurrence, efficacy of corrective action, and recommendations for measures to prevent or reduce the probability of recurrence in accordance with ERDA Manual Chapter 0502.
- c. When required, a report shall be submitted to DOE.

6.8 Reporting Requirements

- a. A report shall be made no later than the next work day to the Safety and Environmental Control Division, DOE, Oak Ridge Operations, of the following conditions:
 - (1) Any release of radioactivity to the environment above the permissible limits specified in ERDA Manual Chapter 0524.

- (2) Any violation of a safety limit (Section 2.1).
 - (3) Any exposures to personnel in controlled and uncontrolled areas that exceed the standards in ERDA Manual Chapter 0524.
- b. A report shall be made within three work days to DOE-ORO of any violation of the Technical Specifications.

6.9 Actions To Be Taken in Regard to Potential
Degradations of a Reactor Shutdown System

- a. Immediate remedial actions required:
- (1) Upon experiencing a Class 1 degradation of the reactor shutdown system, the BSR shall immediately shut down by manual scram or other emergency backup means that may be necessary.
 - (2) Upon the discovery of a Class 2 degradation of the reactor shutdown system, the BSR shall immediately be shut down in an orderly (non-emergency) manner, except when the situation warrants more urgent shutdown action.
 - (3) Upon the discovery of a Class 3 degradation of the reactor shutdown system, ORNL shall take the applicable course of action below:
 - (a) For coincidence logic system, the degraded unit shall be promptly placed (or kept) in the tripped state until operability is restored, except for the brief time necessary to determine the operability of the redundant channels. If the action above would result in an automatic scram, this requirement should be satisfied instead by the prompt initiation of an orderly shutdown.
 - (b) For one-out-of-two or -three systems, where a bypass of a channel for short time periods is authorized in order to permit testing or repair, the bypassed condition may be retained. If operability cannot be regained by the end of the period authorized for bypass, the reactor shall be immediately shut down in an orderly manner, except when the situation warrants more urgent shutdown action.
 - (4) Upon the discovery of a Class 4 degradation of the reactor shutdown system, ORNL shall ascertain the cause of the degradation and implement appropriate corrective action designed to correct

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

sible for periodically conducting an independent safety review of the reactor facility. The members of the RORC shall be appointed by the Director of the Laboratory and shall not be directly involved in the operation of the reactor. The committee members shall collectively possess expertise in all areas of reactor operations and safety.

The RORC shall meet with the operating personnel as frequently as it deems necessary to keep informed of any operational problems or potential hazards. The committee shall conduct at least one formal review each year, and the minutes of this review shall be reported in writing to the Director of the Laboratory. In compliance with the requirements of IAD 8401-7, the RORC shall review any proposed modifications that have safety significance. A detailed description of the committee's function and method of review is presented in Reference 7.

6.11.2 Reactor Experiment Review Committee

There shall be a Reactor Experiment Review Committee (RERC) responsible for reviewing any new or unusual experiments proposed for insertion into the reactor. The RERC shall review proposed experiments in such detail as to ensure that no credible failure or malfunction of the experiment could create a positive change in reactivity greater than the reactor safety system was designed to accommodate. The committee shall review experiments from the standpoint of personnel and equipment safety and the continuity of reactor operations. The committee shall, as it deems necessary, place limits upon any material, systems, components, effluents, or operations that may present a hazard to personnel or to the reactor. The committee shall, in executing its responsibility, make recommendations or establish conditions on design, construction, and operation of an experiment. A detailed description of the committee's functions and method of review is presented in Reference 7.

6.11.3 Criticality Committee

There shall be a Criticality Committee responsible for the review and approval of operations which involve handling, storage, transportation, and disposal of significant quantities of fissile material. The committee shall on request serve as a consulting group and provide assistance in problems involving criticality. The committee shall conduct an annual review of all areas containing significant amounts of fissile material to

ensure that approved procedures are being followed. A detailed description of the committee's functions and method of review is presented in Reference 7.

7. REFERENCES

1. W. R. Gambill, R. D. Bundy, *Burnout Heat Fluxes for Low-Pressure Water in Natural Circulation*, ORNL-3026 (Dec. 1960).
2. L. E. Stanford, T. P. Hamrick, F. T. Binford, *Description and Safety Analysis of Significant Change of the BSR for 2-MW Operation*, ORNL/TM-2231 (May 1968).
3. F. T. Binford, "Burnout Conditions in BSR Cores Under Forced Convection Flow," Supplement No. 1 to *Description and Safety Analysis of Significant Change of the BSR for 2-MW Operation*, ORNL/TM-2231 (March 1968).
4. W. R. Gambill, *Design Curves for Burnout Heat Flux in Forced-Convection Subcooled Light Water Systems*, ORNL/TM-2421 (Nov. 1968).
5. E. P. Blizard, *Neutron Physics Division Annual Progress Report for Period Ending Sept. 1, 1960*, ORNL-3016, pp 18-26.
6. Internal Correspondence from F. T. Binford to J. A. Cox, "Significance of Operating with a Leak in the ORR Primary Coolant System" (September 4, 1973).
7. Internal Correspondence from D. M. Davis to Distribution, "The Safety Program of the Oak Ridge National Laboratory" (May 7, 1975).

DISTRIBUTION

- 1-2. F. T. Binford
- 3. F. R. Bruce
- 4-5. G. H. Burger
- 6. C. D. Cagle
- 7. W. R. Casto
- 8. G. H. Coleman
- 9. J. A. Conlin
- 10. B. L. Corbett
- 11-60. J. A. Cox
- 61. W. H. Culbert
- 62. D. T. Dice
- 63. S. J. Ditto
- 64. W. A. Duggins
- 65. R. H. Guymon
- 66. T. P. Hamrick
- 67. L. B. Holland
- 68-73. S. S. Hurt, III
- 74. J. D. Jenkins
- 75. L. P. Jernigan, Jr.
- 76. E. B. Johnson
- 77. F. B. K. Kam
- 78. E. M. King
- 79. E. Lamb
- 80. E. D. Lance
- 81. L. C. Lasher
- 82. D. L. Laughlin
- 83-87. R. V. McCord
- 88. F. H. Neill
- 89. T. B. Nixon
- 90. L. C. Oakes
- 91. H. Postma
- 92. M. E. Ramsey
- 93. W. H. Sides
- 94. T. M. Sims
- 95. M. J. Skinner
- 96. J. H. Swanks
- 97. J. R. Thomas
- 98. K. W. West
- 99-100. Central Research Library
- 101. Document Reference Section
- 102. Nuclear Safety Information Center
- 103-104. Laboratory Records Department
- 105. Laboratory Records, ORNL-RC
- 106-110. Research and Technical Support Division, DOE, Oak Ridge, TN
- 111-137. Technical Information Center, DOE, Oak Ridge, TN

OAK RIDGE NATIONAL LABORATORY

OPERATED BY
UNION CARBIDE CORPORATION
NUCLEAR DIVISION

POST OFFICE BOX X
OAK RIDGE, TENNESSEE 37830

July 12, 1978

To: Recipients of Subject Report

Report No. ORNL/TM-6345 Classification Unclassified
Author(s): - - -
Subject: Technical Specifications for the Bulk Shielding Reactor.

Please correct your copy(ies) of subject document by affixing the attached Page 6-5. It has been prepared on self-adhesive stock for your convenience, just peel of backing and paste in your report.

A handwritten signature in cursive script, reading "J L Langford".
J. L. Langford, Supervisor
Laboratory Records Department
Information Division

JLL:we

Attachment

cc: Master File ORNL/TM-6345-RC