Energy

FOSSIL

150
10/3/84

MR ①

DR-0449-9

DOE/OR/03054-37-Annex-Vol.A
(DE84015193)

FINAL TECHNICAL REPORT:
SRC BURN TEST IN 700-hp OIL-DESIGNED BOILER

Southern Research Institute Report

September 1983

Work Performed Under Contract No. AC05-78OR03054

Southern Research Institute
Birmingham, Alabama

and

International Coal Refining Company
Allentown, Pennsylvania

Technical Information Center
Office of Scientific and Technical Information
United States Department of Energy

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available from the National Technical Information Service, U. S. Department of Commerce, Springfield, Virginia 22161.

Price: Printed Copy A12
Microfiche A01

Codes are used for pricing all publications. The code is determined by the number of pages in the publication. Information pertaining to the pricing codes can be found in the current issues of the following publications, which are generally available in most libraries: *Energy Research Abstracts (ERA)*; *Government Reports Announcements and Index (GRA and I)*; *Scientific and Technical Abstract Reports (STAR)*; and publication NTIS-PR-360 available from NTIS at the above address.

FINAL TECHNICAL REPORT:
SRC BURN TEST IN 700-hp OIL-DESIGNED BOILER

Annex Volume A: Southern Research Institute Report

September 1983

Southern Research Institute
Birmingham, Alabama

and

International Coal Refining Company
Allentown, Pennsylvania

MASTER

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

ABSTRACT

Combustion tests were performed using three forms of Solvent Refined Coal (SRC) as the fuel for a 700 hp oil-designed water-tube boiler at the U.S. Department of Energy (DOE) Pittsburgh Energy Technology Center (PETC). This report contains the results from a program of measurements and analyses performed by Southern Research Institute (SoRI) under contract to the International Coal Refining Company (ICRC). The major objectives of the work performed by Southern Research Institute were: (1) to characterize the particulate matter resulting from the combustion of Solvent Refined Coal (SRC) and its fuel forms, and (2) to develop estimates of the specific collection areas required for varying levels of collection of fly ash from SRC combustion in electrostatic precipitators. The report contains physical and chemical characterizations of particles collected during the combustion experiments, and a discussion of electrostatic precipitation of SRC fly ash based on performance measurements with a small-scale precipitator and on simulations using a mathematical model.

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

INDEX

	<u>Page</u>
Abstract.....	iii
Summary.....	xvii
I. Introduction.....	1
A. Sampling objectives and locations.....	2
B. Test program.....	5
II. Measurement Techniques.....	7
A. Particle size distributions.....	7
1. Cascade impactor measurements.....	9
2. Five-stage cyclone measurements.....	16
3. Ultrafine particle size measurements.....	17
4. Large particle measurements.....	19
B. In-situ resistivity measurements.....	25
C. SO ₂ and SO ₃ measurements.....	29
D. Secondary voltage and waveform measurements.....	30
III. Results.....	32
A. Particle size distribution.....	32
1. Impactors.....	32
2. Five-stage series cyclones.....	77
3. Ultrafine sampling system.....	85
4. Large particle sizing.....	91
B. Resistivity.....	94
C. Gas analysis.....	94
D. Chemical analysis.....	95
1. Fuel.....	95
2. Collected ash.....	101
E. Scanning electron microscope photographs.....	105
F. Pilot precipitator operations.....	133
IV. Mathematical Modeling.....	154
A. Description of the ESP MODEL.....	154
B. Mathematical modeling of the PETC pilot-scale precipitator.....	157
C. Estimates of full-scale ESP performance with boilers firing SRC fuels.....	165
V. Alternate Control Consideration.....	181
VI. References.....	183
Appendix A - Preliminary Data	184
Appendix B - Coal Analyses and Five-Stage Series Cyclone Data.....	219

TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
1.	Sampling Location Utilization.....	4
2.	WFI Sciences Test Numbering System, No. 6 Fuel Oil Firing (August 26 through September 3, 1982)..	33
3.	WFI Sciences Test Numbering System, SRC Fuel Firing (October 29 through November 14, 1982).....	34
4.	WFI Sciences Test Numbering System, SRC Fuel Firing (November 15 through November 19, 1982)....	35
5.	WFI Sciences Test Numbering System, SRC Residual Fuel Oil Firing (December 8 through December 17, 1982).....	36
6.	WFI Sciences Test Numbering System, SRC-Water Slurry Firing (January 5 through January 14, 1983).....	37
7.	SORI's Test Numbering System, No. 6 Fuel Oil Test (August 24 through September 3, 1982).....	38
8.	SORI's Test Numbering System, SRC Fuel Test (October 20 through November 19, 1982).....	41
9.	SORI's Test Numbering System, SRC Residual Fuel Oil Test (December 6 through December 17, 1982)...	45
10.	SORI's Test Numbering System, SRC-Water Slurry Test (January 5 through January 14, 1983).....	48
11.	Results of No. 6 Fuel Oil Steady-State Test; Method 17 and Impactor Data.....	51
12.	Results of SRC Fuel Steady-State Test; Method 17 and Impactor Data.....	52
13.	Results of SRC Residual Fuel Oil Steady-State Test; Method 17 and Impactor Data.....	53
14.	Results of SRC-Water Slurry Steady-State Test; Method 17 and Impactor Data.....	54

TABLES (Cont'd)

<u>Table</u>	<u>Title</u>	<u>Page</u>
15.	Inlet Impactor Cumulative Mass Loadings at Indicated Sizes for Steady-State Test Weeks.....	76
16.	Inlet Mass Loadings, Cyclone and Impactor Comparisons.....	84
17.	No. 6 Fuel Oil Test, SO ₂ and SO ₃ Measurements.....	96
18.	SRC Fuel Test, SO ₂ and SO ₃ Measurements.....	97
19.	SRC Residual Fuel Oil Test, SO ₂ and SO ₃ Measurements.....	98
20.	SRC-Water Slurry Test, SO ₂ and SO ₃ Measurements....	99
21.	No. 6 Fuel Oil Analysis, Dry Basis.....	100
22.	Analysis of SRC Fuels, Wet Basis.....	100
23.	Total Organic Analysis for SRC Ashes.....	102
24.	Chemical Analysis of No. 6 Fuel Oil Ashes.....	104
25.	Chemical Analysis of SRC Fuel Ashes.....	106
26.	Chemical Analysis of SRC Residual Fuel Oil Ashes...	108
27.	Chemical Analysis of SRC-Water Slurry Ashes.....	110
28.	ESP Average Operating Conditions During Steady-State Test Weeks.....	134
29.	Percent Penetration Comparison for Four Fuels.....	163
30.	Percent Penetration Error Comparison.....	164
31.	Mechanical Parameters and Gas Flow Parameters Used in the ESP Model to Estimate Full-Scale Precipitator Collection Efficiency. The Parameters Apply to Each Separately-Energized Electrical Section in the Direction of Gas Flow.....	167

TABLES (Cont'd)

<u>Table</u>	<u>Title</u>	<u>Page</u>
32.	Electrical Operating Points Used in the ESP Model to Estimate Full-Scale Precipitator Collection Efficiency.....	169
33.	Results of ESP Model Computations of Percent Mass Penetration in a Full-Scale ESP. The Computations are Performed for Both Nominal and Degraded Electrical Parameters and for Two Different Sets of Non-Ideal Gas Flow Parameters. The Computations do not Include an Estimate of the Increased Penetration Due to Rapping Reentrainment.....	172
34.	Estimates of Collection Efficiency and Minimum SCA for Precipitators Collecting Ash from Five Different Fuels, for a Specified Inlet Mass Loading and a Range of Outlet Mass Loadings. The Estimated SCA Values are Based on ESP Model Computations of Collection Efficiency which do not Include the Effect of Rapping Reentrainment, Except in the Comparison Case of Medium-Sulfur Bituminous Coal. None of the Estimated SCA Values Include Engineering Design Margins.....	175

FIGURES

<u>Figure</u>	<u>Title</u>	<u>Page</u>
1.	Pilot ESP and sampling locations during SRC Test Firing Program.....	3
2.	Operation principle and typical performance for a cascade impactor.....	11
3.	Modified Brink Model BMS-11 Cascade Impactor.....	13
4.	University of Washington Mark III source test cascade impactor.....	14
5.	The Five-Stage Series Cyclone System.....	18
6.	SoRI Ultrafine Particle Sample Extraction-Dilution System (SEDS).....	20
7.	Flow schematic and electronic block diagram of the Electrical Aerosol Size Analyzer.....	21
8.	Large Particle Diluter.....	23
9.	Diagram of the SoRI large particle sampling system (LPSS).....	24
10.	Point-to-plane resistivity probe.....	26
11.	Typical voltage-current relationships for point-to-plane resistivity probe.....	28
12.	Schematic diagram of apparatus for collection of SO ₃ and SO ₂	31
13.	Cumulative mass loading versus particle diameter for No. 6 fuel oil; August 30 - September 3, 1982; ESP inlet and outlet.....	56
14.	Cumulative percent versus particle diameter for No. 6 fuel oil; August 30 - September 3, 1982; ESP inlet and outlet.....	57

FIGURES (Cont'd)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
15.	dM/dlogD versus particle diameter for No. 6 fuel oil; August 30 - September 3, 1982; ESP inlet and outlet.....	58
16.	dN/dlogD versus particle diameter for No. 6 fuel oil; August 30 - September 3, 1982; ESP inlet and outlet.....	59
17.	Fractional efficiency curve for No. 6 fuel oil; August 30 - September 3, 1982.....	60
18.	Cumulative mass loading versus particle diameter for SRC Fuel; November 18 - 19, 1982; ESP inlet and outlet.....	62
19.	Cumulative percent versus particle diameter for SRC Fuel; November 18 - 19, 1982; ESP inlet and outlet.....	63
20.	dM/dlogD versus particle diameter for SRC Fuel; November 18 - 19, 1982; ESP inlet and outlet.....	64
21.	dN/dlogD versus particle diameter for SRC Fuel; November 18 - 19, 1982; ESP inlet and outlet.	65
22.	Fractional efficiency curve for SRC Fuel; November 15 - 19, 1982.....	66
23.	Cumulative mass loading versus particle diameter for SRC Residual Fuel Oil; December 13 - 17, 1982; ESP inlet and outlet.....	67
24.	Cumulative percent versus particle diameter for SRC Residual Fuel Oil; December 13 - 17, 1982; ESP inlet and outlet.....	68
25.	dM/dlogD versus particle diameter for SRC Residual Fuel Oil; December 13 - 17, 1982; ESP inlet and outlet.....	69

FIGURES (Cont'd)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
26.	dN/dlogD versus particle diameter for SRC Residual Fuel Oil; December 13 - 17, 1982; ESP inlet and outlet.....	70
27.	Fractional efficiency curve for SRC Residual Fuel Oil; December 13 - 17, 1982.....	71
28.	Cumulative mass loading versus particle diameter for SRC-Water Slurry; January 11 - 14, 1983; ESP inlet.....	72
29.	Cumulative percent versus particle diameter for SRC-Water Slurry; January 11 - 14, 1983; ESP inlet.....	73
30.	dM/dlogD versus particle diameter for SRC-Water Slurry; January 11 - 14, 1983; ESP inlet.....	74
31.	dN/dlogD versus particle diameter for SRC-Water Slurry; January 11 - 14, 1983; ESP inlet.....	75
32.	Cumulative mass loading versus particle diameter for Five-Stage Series Cyclones.....	78
33.	Cumulative mass percent less than indicated size for Five-Stage Series Cyclones.....	79
34.	Cumulative mass percent less than indicated size; inlet impactors and cyclones; No. 6 fuel oil.....	80
35.	Cumulative mass percent less than indicated sizes inlet impactors and cyclones; SRC Fuel.....	81
36.	Cumulative mass percent less than indicated size; inlet impactors and cyclones; SRC Residual Fuel Oil.....	82
37.	Cumulative mass percent less than indicated size; inlet impactors and cyclones; SRC-Water Slurry.....	83
38.	Differential particle-size distribution, inlet and outlet, No. 6 fuel oil test.....	86

FIGURES (Cont'd)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
39.	Differential particle-size distribution, inlet and outlet, SRC Fuel test.....	87
40.	Differential particle-size distribution, inlet and outlet, SRC Residual Fuel Oil test.....	88
41.	Differential particle-size distribution, inlet SRC-Water Slurry test.....	89
42.	Fractional efficiency for PETC Test Series.....	90
43.	Relative concentration per particle size bands versus time from LPSS during SRC Fuel test; ESP outlet, 1.94-9.3 μm	92
44.	Relative concentration per particle size bands versus time from LPSS during SRC Fuel test; ESP outlet, 9.27-35 μm	93
45.	Five-Stage Cyclone Samples: Cyclone Stage 1: PETC-SRC Test Program.....	112
46.	Five-Stage Cyclone Samples: Cyclone Stage 2: PETC-SRC Test Program.....	113
47.	Five-Stage Cyclone Samples: Cyclone Stage 3: PETC-SRC Test Program.....	114
48.	Five-Stage Cyclone Samples: Cyclone Stage 4: PETC-SRC Test Program.....	115
49.	Five-Stage Cyclone Samples: Cyclone Stage 5: PETC-SRC Test Program.....	116
50.	Inlet Impactor Precollector Samples: PETC-SRC Test Program.....	117
51.	Inlet Impactor Stage 1 Samples: PETC-SRC Test Program.....	118
52.	Inlet Impactor Stage 2 Samples: PETC-SRC Test Program.....	119

FIGURES (Cont'd)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
53.	Inlet Impactor Stage 3 Samples: PETC-SRC Test Program.....	120
54.	Inlet Impactor Stage 4 Samples: PETC-SRC Test Program.....	121
55.	Inlet Impactor Stage 5 Samples: PETC-SRC Test Program.....	122
56.	Inlet Impactor Stage 6 Samples: PETC-SRC Test Program.....	123
57.	Inlet Impactor Stage 7 Samples: PETC-SRC Test Program.....	124
58.	Inlet Impactor Backup Filter Samples: PETC-SRC Test Program.....	125
59.	Outlet Impactor Samples: PETC-SRC Test Program. A - Precollector Sample; B - Precollector Sample; C - Stage 1 Sample; D - Stage 2 Sample.....	126
60.	Outlet Impactor Stage 3 Samples: PETC-SRC Test Program.....	127
61.	Outlet Impactor Stage 4 Samples: PETC-SRC Test Program.....	128
62.	Outlet Impactor Stage 5 Samples: PETC-SRC Test Program.....	129
63.	Outlet Impactor Stage 6 Samples: PETC-SRC Test Program.....	130
64.	Outlet Impactor Stage 7 Samples: PETC-SRC Test Program.....	131
65.	Outlet Impactor Backup Filter Samples: PETC-SRC Test Program.....	132
66.	Voltage current curve, PETC-ICRC No. 6 fuel oil test, T-R No. 1, 9/3/82.....	135
67.	Voltage current curve, PETC-ICRC No. 6 fuel oil test, T-R No. 2, 9/3/82.....	136

FIGURES (Cont'd)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
68.	Voltage current curve, PETC-ICRC No. 6 fuel oil test, T-R No. 3, 9/3/82.....	137
69.	Precipitator secondary voltage waveform, Pittsburgh Energy Technology Center, T-R No. 1, 9/3/82.....	138
70.	Precipitator secondary voltage waveform, Pittsburgh Energy Technology Center, T-R No. 2, 9/3/82.....	139
71.	Precipitator secondary voltage waveform, Pittsburgh Energy Technology Center, T-R No. 3, 9/3/82.....	140
72.	Voltage current curve, PETC-ICRC SRC Fuel test, T-R No. 1, 11/19/82.....	141
73.	Voltage current curve, PETC-ICRC SRC Fuel test, T-R No. 2, 11/19/82.....	142
74.	Voltage current curve, PETC-ICRC SRC Fuel test, T-R No. 3, 11/19/82.....	143
75.	Voltage current curve, PETC-ICRC SRC Residual Fuel Oil test, T-R No. 1, 12/17/82.....	145
76.	Voltage current curve, PETC-ICRC SRC Residual Fuel Oil test, T-R No. 2, 12/17/82.....	146
77.	Voltage current curve, PETC-ICRC SRC Residual Fuel Oil test, T-R No. 3, 12/17/82.....	147
78.	Precipitator secondary waveform, PETC-ICRC SRC Residual Fuel Oil test, T-R No. 1, 12/17/82.....	148
79.	Precipitator secondary waveform, PETC-ICRC SRC Residual Fuel Oil test, T-R No. 2, 12/17/82.....	149
80.	Precipitator secondary waveform, PETC-ICRC SRC Residual Fuel Oil test, T-R No. 3, 12/17/82.....	150
81.	Voltage current curve, PETC-ICRC SRC-Water Slurry test, T-R No. 1, 1/11/83.....	151

FIGURES (Cont'd)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
82.	Voltage current curve, PETC-ICRC SRC-Water Slurry test, T-R No. 2, 1/11/83.....	152
83.	Voltage current curve, PETC-ICRC SRC-Water Slurry test, T-R No. 3, 1/11/83.....	153
84.	Measured particle size distribution of fuel oil ash.....	159
85.	Measured particle size distribution of ashes from three SRC fuels.....	160
86.	Measured and computed performance of the PETC pilot-scale ESP. ESP MODEL computations use measured electrical and aerosol data, 10% gas sneackage and three different values of σ_{gas} . The measured value of collection efficiency is taken from impactor data. The error bars indicate the range of scatter in mass train data.....	161
87.	Ash particle size distribution used in the ESP MODEL to estimate full-scale precipitator collection efficiency.....	170
88.	Estimates of full-scale ESP collection efficiency for ash from No. 6 fuel oil and three SRC fuels. The same estimates of electrical operating points are used for each of the three solid curves. (The three dashed curves show estimates of performance with degraded electrical conditions due to contamination of the high voltage insulators.) Differences in the three curves reflect measured differences in the ash particle size distributions. The estimates do not include the effect of rapping reentrainment.....	174
89.	Estimates of minimum SCA for a specified inlet mass loading and a range of outlet mass loadings. The estimated SCA values are based on ESP MODEL computations of collection efficiency which do not include the effect of rapping reentrainment, except in the comparison case of medium-sulfur bituminous coal. None of the estimated SCA values include engineering design margins.....	176
90.	Computed examples of degradation in precipitator performance due to rapping reentrainment.....	177

THIS PAGE
WAS INTENTIONALLY
LEFT BLANK

SUMMARY

This report describes the results of a measurement and analysis program conducted by Southern Research Institute (SoRI), under contract with the International Coal Refining Company (ICRC), during combustion trials of various fuel forms of Solvent Refined Coal (SRC). These trials were conducted in a 700-hp water-tube boiler, designed for oil firing, at the U.S. Department of Energy's (DOE) Pittsburgh Energy Technology Center (PETC). SoRI's major objectives during the combustion trials were: (1) characterization of the particulate matter resulting from the combustion of various fuels and (2) development of estimates of the specific collection area in electrostatic precipitators required for varying levels of collection efficiency of fly ash from SRC combustion.

The fuels which were fired in DOE's facility included: (1) a No. 6 fuel oil, (2) SRC Fuel, a pulverized solid, (3) SRC Residual Fuel Oil consisting of 55% SRC Fuel and 45% SRC process solvents, and (4) SRC-Water Slurry consisting of 66% SRC Fuel mixed with 34% water and containing 0.5 wt. % of a commercial surfactant (Lomar D). In order to accomplish the first objective of this work, SoRI determined the size distribution, chemical composition, electrical resistivity, particle density and physical shape of the particulate or fly ash generated by combustion of each of the fuels. The second objective was accomplished through the use of performance measurements with a pilot-scale electrostatic precipitator (ESP) and through simulations with a mathematical model of electrostatic precipitation developed by SoRI under the sponsorship of the U.S. Environmental Protection Agency. SoRI also determined the sulfur dioxide and sulfur trioxide concentrations of the flue gases, monitored the operating voltage and

current in the ESP and monitored the operating parameters of the 700-hp boiler during each test series.

Table S-1 provides a partial summary of the data obtained during the SoRI measurement program. Proximate analysis of each fuel indicated a low ash content which is reflected in the ESP inlet mass loadings. The ash content from the proximate analysis of the SRC Fuel was essentially the same as the No. 6 fuel oil but due to the firing characteristics of the pulverized solid the inlet mass loading was considerably higher. The higher inlet mass loadings obtained with the SRC-Water Slurry are due to the ash from the Lomar D additive. The No. 6 fuel oil ash had a higher concentration of very fine particles, as the mass median diameter of 0.25 μm indicates, and this accounts for the reduced collection efficiency measured from the No. 6 fuel oil compared to the collection efficiency of the other ashes. The differences in loss on ignition (LOI) and carbon content of the particulate are mainly due to sulfuric acid uptake on the particulate.

The operational data gathered from the pilot ESP were used as input data to SoRI's ESP MODEL. The computed efficiencies were compared with the measured efficiencies and the agreement was good in all cases. Figure S-1 presents the ESP MODEL estimates of full-scale ESP collection efficiency for ash from fuel oil and three SRC fuels. The same estimates of electrical operating points were used for each of the three curves. The differences in the curves reflect measurement differences in the ash particle size distributions. The estimates in Figure S-1 do not include any effect of rapping reentrainment which would result in lower collection efficiencies.

By using the inlet mass loadings in Table S-1 and the estimates of collection efficiency in Figure S-1, estimates of outlet mass loadings can be calculated and plotted versus specific collection

Table S-1

Partial Summary of Particulate Characterization,
SRC Test Program

	<u>No. 6 Fuel Oil</u>	<u>SRC Fuel</u>	<u>SRC Residual Fuel Oil</u>	<u>SRC Water Slurry</u>
ESP Inlet Mass Loadings, lbs/10 ⁶ Btu				
Method 17	0.0492	0.8862	0.1968	0.9534
Impactors	0.0359	0.7971	0.1782	0.9778
ESP Efficiency, % ¹				
Method 17	92.70	99.06	99.46	99.20
Impactors	98.26	99.50	99.50	-
ESP Specific Collection Area, m ² /(m ³ /sec)	46.5	45.7	46.7	43.7
Particle Density, gm/cc	3.00	2.00	2.00	2.44
Inlet Mass Median Diameter, μ m	0.25	21.8	10.3	17.8
Carbon Content of Inlet Particulate, %	13	23	34	51
Loss on Ignition of Inlet Particulate, % ²	28	71	85	69

1. Based on gr/dscf

2. LOI determination done at 750°C

Figure S-1. Estimates of full-scale ESP collection efficiency for ash from No. 6 Fuel Oil and three SRC fuels. The same estimates of electrical operating points are used for each of the three solid curves. Differences in the three curves reflect measured differences in the ash particle size distributions. The estimates do not include the effect of rapping reentrainment.

area as in Figure S-2. The data in Figure S-2 do not include the effect of rapping reentrainment on collection efficiency. If one could assume that rapping reentrainment losses for SRC fuels could be maintained at a maximum of 50% of the outlet emissions, then an ESP operating at an SCA of $150 \text{ ft}^2/\text{kacfm}$ could maintain outlet emissions of $0.1 \text{ lbs}/10^6 \text{ Btu}$.

Although there were complications in operating the pilot-scale ESP due to the high carbon content of the SRC ashes, the PETC pilot-scale ESP performed very well in collecting ashes from SRC fuels. Both measurements and mathematical modeling demonstrate that there are no fundamental problems that would prohibit the use of electrostatic precipitators for cleaning the flue gas from a full-scale utility boiler firing SRC fuels.

Figure S-2. Estimates of minimum SCA for a specified inlet mass loading (Table S-1) and a range of outlet mass loadings. The estimated SCA values are based on ESP MODEL computations of collection efficiency which do not include the effect of rapping reentrainment. None of the estimated SCA values include engineering design margins.

I. INTRODUCTION

The International Coal Refining Company (ICRC) has conducted a series of pilot-scale combustion trials with various physical forms of a fuel known as Solvent Refined Coal (SRC). These fuels included: (1) SRC Fuel, a pulverized solid; (2) SRC Residual Fuel Oil, 55% SRC Fuel and 45% SRC Process Solvents; and (3) SRC-Water Slurry, 66% SRC Fuel mixed with 34% water and containing 0.5 wt. % Lomar D additive. These experiments were performed using a 700 horsepower, oil-designed water-tube boiler at the U.S. Department of Energy's (DOE) Pittsburgh Energy Technology Center (PETC). This report contains the results from a program of measurements and analyses performed by Southern Research Institute (SoRI) under contract with ICRC. The major tasks performed by SoRI were: (1) characterization of particulate resulting from combustion of No. 6 fuel oil, (2) characterization of particulate resulting from combustion of SRC fuels, and (3) development of the estimated specific collection areas required for electrostatic precipitation of the fly ash which results from combustion of the various forms of SRC. This latter objective was accomplished through the use of performance measurements with a pilot-scale precipitator, and with simulations using a mathematical model of electrostatic precipitation developed by SoRI under the sponsorship of the U.S. Environmental Protection Agency.

The particulate characterization program included, in addition to the work performed by SoRI, participation by representatives of Wheelabrator-Frye, Inc. (WFI), Wheelabrator-Frye, Inc. Sciences (WFI Sciences), and Southern Company Services (SCS). WFI supplied and operated the pilot-scale precipitator, WFI Sciences provided sampling support with mass train measurements and operated a small-scale fabric filter test device, and SCS monitored the boiler system operation and coordinated the testing efforts. The

particulate characterization measurements performed by SoRI included: (1) particle sizing determinations using inertial, optical, and mobility-based techniques, (2) analysis of flue gas for sulfur dioxide and sulfur trioxide, (3) in-situ resistivity measurements, and (4) observation of boiler and precipitator operation during the test periods.

A. Sampling Objectives and Locations

Figure 1 presents the location of the sampling stations which were used to obtain samples of the boiler effluent. Sampling location 1 was on the hot gas side of the flue gas cooler and was used by SoRI, WFI Sciences and DOE's contractor, General Electric Company-Management and Technical Services Company (GE-MATSCO), for obtaining samples at the boiler outlet. GE-MATSCO and WFI Sciences employees obtained particulate loading data for use in boiler efficiency calculations. SoRI used this location to obtain SO_2 and SO_3 concentrations in the flue gas for the various fuels.

The inlet duct to the ESP, which handled approximately one half of the boiler gases, includes sampling locations 2 and 3. Sampling location 2 was utilized by WFI Sciences to obtain flue gas for the small-scale fabric filter test device. Sampling location 3 was used by SoRI and WFI Sciences to obtain particle size, resistivity, gas analyses and particulate concentration data. Table 1 presents the location of the measurement, the type of measurement and the responsible contractor for both the ESP inlet and outlet sampling locations. Sampling location 4 in Figure 1 was at the ESP outlet duct, at which particle size, gas analyses and particle concentration data were also obtained.

Sampling location 5 was located at the outlet of the pulse jet baghouse, which received the total flow from the boiler when the ESP was not operational. During the test program while the ESP

Figure 1. Pilot ESP and sampling locations during SRC Test Firing Program.

Table 1
SAMPLING LOCATION UTILIZATION

<u>Location</u>	<u>Measurement</u>	<u>Equipment</u>	<u>Contractor</u>
Sampling Location 3			
Port a	Particle Sizing	Impactors	SoRI
Port b	Particle Sizing	Impactors	SoRI
Port c	Particle Sizing	5-Stage Cyclone	SoRI
Port d	Resistivity	Point-to-Plane Resistivity Probe	SoRI
Port e	SO ₂ -SO ₃	Cheney-Homolya System	SoRI
Port f	Particle Concentration & Gas Analyses	EPA Method 17	WFI Sciences
Port g	Particle Sizing	Ultrafine Particle Sizing System	SoRI
Sampling Location 4			
Port a	Particle Sizing	Impactors	SoRI
Port b	Particle Concentration & Gas Analyses	EPA Method 17	WFI Sciences
Port c	SO ₂ -SO ₃	Cheney-Homolya System	SoRI
Port d&e	Particle Sizing	Large Particle Sizing System	SoRI
Port f	Particle Sizing	Ultrafine Particle Sizing System	SoRI

was operating, the pulse jet baghouse handled only approximately one half the boiler flue gases. WFI Sciences also performed mass concentration measurements at sampling location 5.

B. Test Program

As has previously been stated, the test program at DOE's PETC facility was designed to obtain data which would allow the characterization of the particulate resulting from the firing of various SRC-fuel forms. A second major objective was to obtain performance data from the pilot electrostatic precipitator and from the fabric filter test device to aid in developing design parameters for full-scale control devices.

No. 6 fuel oil was used as a baseline fuel for the boiler and ESP and was followed by various other fuel forms of SRC which included: pulverized SRC Fuel, SRC Residual Fuel Oil, and SRC-Water Slurry. The test program for each fuel included a parametric and steady-state test week. The parametric test week was used to check sampling equipment, precipitator operations, and to develop modifications to sampling procedures if necessary. The data obtained during these parametric test weeks were not necessarily valid or useful for computer modeling, since the primary purpose was to establish operating conditions and sampling procedures for the steady-state test weeks. These preliminary data from the various measurement systems have been included in appendix A of this report for completeness. However, these data should not be considered in the evaluation of particulate properties or in the analysis of the pilot precipitator performance.

During the steady-state weeks, SoRI conducted the following measurements at the inlet sampling location (location 3): particle size measurements with cascade impactors, a five-stage

series cyclone, and an ultrafine particle sizing system; in situ resistivity measurements; and SO_2 - SO_3 measurements. The following measurements were conducted at the ESP outlet (sampling location 4) during the steady-state weeks while No. 6 fuel oil, SRC Fuel and SRC-Residual Fuel Oil were fired in the 700 hp boiler: particle size measurements with cascade impactors, an ultrafine particle sampling system and a large particle sizing system; and SO_2 - SO_3 measurements.

Sulfur oxide measurements were also conducted by SoRI at sampling location 1 (boiler outlet duct), during each steady-state week. The electrical operating conditions of the pilot ESP and the boilers operating parameters were also monitored during each test series.

WFI Sciences conducted EPA Method 17 for determinations of particulate concentrations in the flue gases at locations 3 and 4 during each steady-state week and operated their fabric filter field comparator at sampling location 2 during the steady-state periods. WFI Sciences conducted EPA Method 5 for determining particulate emissions at the boiler outlet (sampling location 1) and the pulse jet baghouse outlet (sampling location 5) for each test series except the No. 6 fuel oil test series. WFI Sciences' results are reported elsewhere. However, the data obtained at sampling locations 3 and 4 are included in this report to compare mass loadings obtained with cascade impactors which were operated during the same relative time periods.

II. MEASUREMENT TECHNIQUES

A. Particle Size Distributions

The particulate matter suspended in industrial gas streams may be in the form of nearly perfect spheres, regular crystalline forms other than spheres, irregular or random shapes, or as agglomerates made up from combinations of these. It is possible to discuss particle size in terms of the volume, surface area, projected area, projected perimeter, linear dimensions, light scattering properties, or in terms of drag forces in a liquid or gas (mobility). Particle sizing work is frequently done on a statistical basis where large numbers of particles, rather than individuals, are sampled. For this reason the particles are normally assumed to be spherical. This convention also makes transformation from one basis to another more convenient.

Experimental measurements of particle size normally cannot be made with a single instrument if the size range of interest extends over much more than a decimal order of magnitude. Presentations of size distributions covering broad ranges of sizes then must include data points which may have been obtained using different physical mechanisms. Normally the data points are converted by calculation to the same basis and put into tabular form or fitted with a histogram or smooth curve to represent the particle size distribution. Frequently used bases for particle size distributions are the relative number, volume, surface area, or mass of particles within a size range. The size range might be specified in terms of aerodynamic, Stokes, or equivalent Polystyrene Latex (PSL) bead diameter. There is no standard equation for statistical distributions which can be universally applied to describe the results given by experimental particle size measurements. For industrial sources the best procedure is to plot the experimental points in a convenient format and to

examine the distribution in different size ranges separately, rather than trying to characterize the entire distribution by two or three parameters.

An ideal particle size measurement device for sizing particulate generated by various processes would be located in-situ and give real time readout of particle size distributions and particle number concentration over the size range from 0.01 μm to 100 μm diameter. At the present time, however, particle size distribution measurements are made using several instruments which operate over limited size ranges and do not yield instantaneous data.

Particle sizing methods used in making field measurements may involve instruments which are operated in-stack, or out-of-stack where the samples are taken using probes. For in-stack sampling, the sample aerosol flow rate is usually adjusted to maintain near isokinetic sampling conditions in order to avoid concentration errors which result from under or oversampling of large particles (dia. > 3 μm) which have too high an inertia to follow the gas flow streams in the vicinity of the sampling nozzle. Since many particulate sizing devices have size fractionation points that are flow rate dependent, the necessity for isokinetic sampling in the case of large particles can result in undesirable compromises in obtaining data -- either in the number of points sampled or in the validity or precision of the data for large particles.

Choices of particulate measurement devices or methods for individual applications are dependent on the availability of suitable techniques which permit the required temporal and/or spatial resolution or integration. In certain instances the properties of the particulate are subject to large changes in not only size distribution and concentration, but also in chemical composition. Different methods of sampling devices are generally

required to obtain data for long term process averages as opposed to the isolation of certain portions of the process in order to determine the cause of a particular type of emission.

Interferences exist which can affect most sampling methods. Two commonly occurring problems are the condensation of vapor phase components from the gas stream and reactions of gas, liquid, or solid phase materials with various portions of the sampling systems. An example of the latter is the formation of sulfates in appreciable (1 to 5 milligram) quantities on several of the commonly used glass fiber filter media by reactions involving SO_x and trace constituents of the filter media. Sulfuric acid condensation in cascade impactors and in the probes used for extractive sampling is an example of the former.

If extractive sampling is used and the sample is conveyed through lengthy probes and transport lines, as is the case with several particle sizing methods, special attention must be given toward recognition, minimization, and compensation for losses by various mechanisms in the transport lines. The degree of such losses can be quite large for certain particle sizes.

During the test program at PETC various methods for measuring particle size distributions were used which included inertial methods (cascade impactors and cyclones), optical methods (Climet and Royco optical particle counters), and an electrical mobility method (Electrical Aerosol Analyzer).

1. Cascade Impactor Measurements

Inertial cascade impactors are commonly used to perform particle size distribution measurements because they are sufficiently rugged and compact for in-situ sampling, and traversing the process stream is a practical operation. In-situ sampling is

preferred since the complete size distribution may be seriously distorted if a probe is used for sample extraction. Cascade impactors are capable of measuring particle size distributions for diameters approximately between 0.5 and 10.0 μm .

The mechanisms by which a cascade impactor classifies particulate is illustrated in Figure 2. In each stage of an impactor, the gas stream passes through an orifice and forms a jet which is directed toward an impaction plate. For each stage there is a characteristic particle diameter which has a 50% probability of impaction resulting in collection. This characteristic diameter is referred to as the D_{50} of the stage. The schematic diagram in Figure 2 shows a single jet for illustrative purposes, but commercial impactors may have from one to several hundred jets in a stage. Typical impactors consist of from 5 to 10 stages. Particle collection efficiency of a given impactor jet-plate combination is determined by factors such as particle shape and density, viscosity of the gas, and the design of the impactor stage. The type of impaction surface (glass fiber, grease, metal, etc.) will also influence stage collection characteristics.

The selection of the proper impactor for a given test situation is primarily dependent upon the mass loading of the gas stream and its effect on sampling time. There are three major criteria to be met in the selection process:

- (1) The sampling period must be of sufficient duration to provide a reasonable averaging of transient conditions in the stack.
- (2) The loading of a given impactor stage must be low enough to prevent reentrainment.
- (3) The sampling rate through the impactor must be sufficiently low to prevent scouring of impacted particles by high gas velocities.

A. TYPICAL IMPACTOR JET AND COLLECTION PLATE

B. GENERALIZED STAGE COLLECTION EFFICIENCY CURVE

4266-67

Figure 2. Operation principle and typical performance for a cascade impactor.

For these reasons, an impactor with a comparatively low sample rate must be used in a gas stream with a high mass loading. Conversely, in a low mass loading situation such as a control device outlet, a high sampling rate device must be used if a significant amount of particulate is to be gathered in a reasonable amount of time. A cascade impactor can normally yield useful information over a range of sample rates differing by a factor of 2 or 3. Since high efficiency control devices will cause the outlet mass loading to differ from the inlet by factors of 10 to 100, both high and low flow rate impactors are usually required for control device characterization. Figures 3 and 4 are drawings of the impactors used during this program. Brink impactors were used at the ESP inlet sampling location (sampling location 3) during the preliminary weeks and on the first day of steady-state test while No. 6 fuel oil was fired. Due to particle reentrainment problems which resulted from the high concentration of fine particulate while No. 6 fuel oil was fired and reentrainment problems within the impactors during pulverized SRC Fuel firing, University of Washington Mark III cascade impactors were used at the ESP inlet and outlet sampling locations for all test series after the first day of steady-state test with No. 6 fuel oil and after the third day of steady-state test with SRC Fuel.

Impactor stages are generally too heavy for the tare capacity of field-usable precision balances. For this reason, the particles are captured on substrates which are low in mass, such as metal foils or glass fibers. For glassy materials such as coal fly ash, metal foils must be covered with grease to reduce reentrainment due to particle bounce. However, greases tend to evaporate at temperatures of 350°C, and glass materials must be used. These substrates must be handled carefully to prevent fiber loss after weighing, and special precautions must be taken when using glass fiber substrates in streams containing sulfur dioxide.

620-92

Figure 3. Modified Brink Model BMS-11 Cascade Impactor.

620-95A

Figure 4. University of Washington Mark III source test cascade impactor.

Southern Research Institute has performed extensive studies under EPA Contract No. 68-02-2131 to determine the magnitude and cause of substrate weight gains, and to recommend solutions to the problem. It has been found that with careful handling of glass fiber substrates, weight losses could be kept below 0.2 mg per substrate. For substrates used in Andersen and University of Washington impactors 2 mg is a typical mass collected on the latter stages of these impactors. It was also found that weight gains which resulted from sulfate formation within the filter mat could be reduced to acceptable limits by using Reeve Angel 934AH glass fiber material and conditioning the material via a sulfuric acid wash followed by an alcohol and water wash and finally by baking and desiccation. Of the various filter materials studied, only the Reeve Angel 934AH was found to be suitable in all respects for use as cascade impactor substrates. During steady-state testing, "blank" impactor runs were made in order to determine substrate weight gains.

Following sampling and determination of stage weights, data reduction procedures as outlined below were followed.

- (1) Stage weights are corrected for "blank" weight gains.
- (2) Cut points for the individual stages for each impactor are calculated based on calibration studies conducted in the laboratory using polystyrene latex beads for sizes smaller than 2.0 μm diameter and ammonium fluorescein particles for particle diameters from 2 to 8 μm diameter. Glass fiber substrates were in place for the calibration studies.
- (3) Impactor runs are arranged in groups in an appropriate manner.
- (4) The data are then used as input to a computer program which calculates the size distribution.

A detailed description of the data reduction program is available in the EPA publication, A Computer-Based Cascade Impactor Data Reduction System.¹ A brief outline of the operations performed by the program is given below.

- (1) Individual impactor runs are fit with a series of segmented polynomials (spline fit) which are continuous at the points of overlap in the first derivative with respect to particle size.
- (2) The "spline fits" for all runs are arranged in the groups desired.
- (3) The polynomials are differentiated to obtain values of $dM/d\text{LOGD}$ (the differential of the cumulative mass curve) at fixed particle sizes. All particle diameters are "Stokes diameter," defined as the diameter of a sphere having the same density which exhibits aerodynamic behavior identical to the particle of interest. Average density values are used which are obtained from helium pycnometer determinations.
- (4) Average values of $dM/d\text{LOGD}$ are calculated for the fixed particle sizes from the members of each group, and an outlier analysis is performed. If the analysis results in certain values being discarded, a new average is computed without the outliers. Fifty percent confidence intervals are then computed.
- (5) The functions determined by the averaged $dM/d\text{LOGD}$ values are integrated to obtain corresponding cumulative distributions.
- (6) The program then plots the size distributions in the desired format.

2. Five-Stage Cyclone Measurements

A five-stage cyclone of SORI design was used at the ESP inlet sampling location to obtain inlet size distribution measurements and larger size-fractionated samples for chemical analyses. The cyclone system offered two advantages over impactors: 1) large samples could be acquired since the collection cups hold up to about 1 g of dust compared to a maximum loading of about 10 mg

for an impactor stage, and 2) particle bounce is not as severe a problem in cyclones as it may be in impactors. One major disadvantage the cyclones have is that the existing theories do not accurately predict cyclone performance. Figure 5 presents the 5-stage cyclone system which was used during the testing at PETC. The cyclone system at 4.72×10^{-4} m³/sec (1 acfm) and 20°C has cut-points, or D₅₀'s of 7.5, 2.6, 1.3, 0.6 and 0.3 µm.

3. Ultrafine Particle Size Measurements

There are two physical properties of ultrafine particles (diameter < 0.5 µm) which are size dependent and which can be predicted with sufficient accuracy under controlled conditions to be used to measure particle size. These properties are the particle diffusivity and electrical mobility. Although ultrafine particle size distribution measurements are still in a developmental stage, instruments are available which can be used for this purpose, and a number of field measurements have been made. A practical limitation on the lower size limit for this type of measurement is the loss of particles by diffusion in the sampling lines and instrumentation. These losses are excessive for particle sizes below about 0.01 µm where the samples are extracted from a duct and diluted to concentrations within the capability of the sizing devices.

An Ultrafine Particle Sampling System (LPSS) developed by SoRI² was used during the test program at PETC at the ESP inlet and outlet sampling locations. The system used at PETC requires extractive sampling and conditioning of the flue gases and consists of a Sample Extraction Dilution System² (SEDS), a Climet Model 208 optical particle counter with a Canberra Model 3100 multichannel analyzer, and a TSI Model 3030 Electrical Aerosol Size Analyzer (EASA).

4181-94

Figure 5. The Five-Stage Series Cyclone System.

The Sample Extraction Dilution System shown in Figure 6 extracts a continuous flue gas sample from the duct, conditions it to prevent the formation of an interference condensation fume, and dilutes it to temperatures and concentrations allowable for use in the Optical Particle Counter and EASA. The conditioned sample provided for sizing has a lower size limit of $0.01\text{ }\mu\text{m}$ and an upper size limit of $2.0\text{ }\mu\text{m}$. These limits are due to particulate transport losses within the SEDS system itself rather than to the operating ranges of the sizing instrument used with the system.

Real time concentration information in the $0.3\text{ }\mu\text{m}$ to $2.0\text{ }\mu\text{m}$ size range can be obtained with the Climet Optical Particle Counter in conjunction with the Sample Extraction Dilution System. This real time analog data allows one to observe emission fluctuations as well as obtain an integrated time average.

In the Optical Particle Counter individual particles pass through a small viewing volume where they scatter a light beam. This scattered light is detected by a photodetector. The amplitude of the scattered pulse determines the size of the particle and the presence of a pulse indicates the presence of a particle. Pulse height analysis is then performed on the signal from the optical particle counter to obtain the desired sizing information.

Figure 7 presents a schematic of the TSI Electrical Aerosol Sizing Analyzer (EASA) which operates on an electrical mobility principle^{3,4} where the particle charge is known and the particle size is determined from the mobility and, when used with the SEDS system, covers the size range from $0.01\text{ }\mu\text{m}$ to $1.0\text{ }\mu\text{m}$.

4. Large Particle Measurements

A Large Particle Sampling System (LPSS) designed by SORI was operated at the ESP outlet sampling location during the test program at PETC. The LPSS consists of a diluter, an Optical Particle Analyzer and a Data Acquisition System.

620-98

Figure 6. SoRI Ultrafine Particle Sample Extraction-Dilution System (SEDS).

3540-063

Figure 7. Flow schematic and electronic block diagram of the Electrical Aerosol Size Analyzer.

Due to instrumental limitations on the total concentration of particles in the sample gas stream arriving at the sensor, Optical Particle Counters require that the particulate sample from the flue be diluted before measurement. Because of the very steep gradient in the particle size distribution (especially on a number basis) found at the exit of a precipitator on a power boiler, the large particle diluter is made as a size selective device which, under ideal conditions, dilutes small particles in the sample gas stream by fairly large factors while passing a relatively undiluted stream of the lower concentration, large particles directly to the optical particle sensor. Figure 8 illustrates the operating system for the large particle diluter.

The geometry of the diluter (Figure 8) is such that the large particles, having high inertia, tend to pass directly from the inlet to the sample exit of the diluter while small particles (having relatively low inertia) are mixed to varying degrees, depending on their sizes, with the dilution air. This procedure produces a substantial reduction in concentration of small particles and condensable vapors in the sample stream while maintaining the concentration of the less numerous large particles. Under sampling conditions where additional dilution is required, a small diluter is appended and the resulting dilution is sufficiently large so that the Optical Particle Counter can still be used.

A Royco Model 225 Optical Particle Counter was used with the LPSS and is shown in Figure 9 along with the Data Acquisition System. The Data Acquisition System consists of a nine-track magnetic tape recorder housed in a weather-proof enclosure and a second weather-proof enclosure which contains a control panel, a Tectronics T922R oscilloscope, analog inputs, interface circuits, and a DEC LSI/03 computer.

5034-72

Figure 8. Large Particle Diluter.

4181 B5

Figure 9: Diagram of the SoRI large particle sampling system (LPSS).

B. In-Situ Resistivity Measurements

SoRI's in-situ point-to-plane resistivity probe was operated at the ESP inlet sampling location during each steady-state test series at PETC.

The point-to-plane probe for measuring resistivity has been in use since the early 1940's in this country. One model of this device is shown in Figure 10. The probe is inserted directly into the dust-laden gas stream and allowed to come to thermal equilibrium. The particulate sample is deposited electrically onto the measurement cell through the electrostatic action of the corona point and plate electrode system such that a corona is formed in the vicinity of the point. The dust particles are charged by the ions and perhaps by free electrons from this corona in a manner analogous to that occurring in an electrostatic precipitator.

The dust layer is formed through the interaction of the charged particulate with the electrostatic field adjacent to the collection plate. Thus, this device is intended to simulate the behavior of a full-scale electrostatic precipitator and to provide a realistic value for the resistivity of the dust that should be comparable to that in the actual ESP.

In the point-to-plane technique, two methods of making measurements on the same sample may be used. The first is the "V-I" method. In this method, a voltage-current curve is obtained before the electrostatic deposition of the dust, while the collecting disc is clean. A second voltage-current curve is obtained after the dust layer has been collected. After the layer has been collected and the clean and dirty voltage-current curve is obtained, the second method of making a measurement may be used. In the second method, the parallel disc or "spark method," a disc the same size as the collecting disc is lowered on the collected sample. Increasing voltages are then applied to the

(b)

620-433

Figure 10. Point-to-plane resistivity probe.

dust layer and the current obtained is recorded until the dust layer breaks down electrically and sparkover occurs. The geometry of the dust sample, together with the applied voltage and current, provide sufficient information for the determination of the dust resistivity.

In the point-to-plane method, the voltage drop across the dust layer is determined by the shift in the voltage-vs-current characteristics along the voltage axis as shown in Figure 11. The situation shown is for resistivity values ranging from 10^9 to 10^{11} ohm·cm.

If the parallel disc method is used, dust resistance is determined from the voltage measured just prior to sparkover. In both methods the resistivity is calculated as the ratio of the electric field to the current density.

The practice of measuring the resistivity with increasing voltage has evolved because the dust layer behaves as a nonlinear resistor. As the applied voltage is increased, the current increases greater than that attributable to the increase in voltage. Therefore, as described in the A.S.M.E. Power Test Code Number 28 procedure, the value just prior to sparkover is reported as the resistivity.

There is considerable justification for using the value of resistivity prior to electrical breakdown as the resistivity, since it is precisely at electrical breakdown that the resistivity causes problems within the ESP. The electrical breakdown in the dust layer in the operating ESP either initiates electrical sparkover or reverse ionization (back corona) when high ash resistivity is the factor limiting ESP behavior. If neither of these events occur, the dust layer merely represents an additional voltage drop to the ESP power supply.

3540-219

Figure 11. Typical voltage-current relationships for point-to-plane resistivity probe.

Even though there are many similarities between the operation of the point-to-plane device and a full-scale ESP, several problems also exist. The first problem encountered is the determination of the thickness of the dust layer. Some devices make use of a thickness measurement system built into the probe. In other devices, the instrument is withdrawn from the duct and the thickness of the dust layer is estimated visually by inspecting the dust between the discs. However, the dust layer is almost always disturbed by the air flow through the sampling port and extreme care is required to preserve the layer intact. The device which SoRI used for measurements includes a dial indicator which is used to determine the thickness of the dust layer before the probe is removed from the flue.

C. SO₂ and SO₃ Measurements

Measurements of gas phase sulfur dioxide and sulfur trioxide were obtained at sampling locations 1, 3 and 4 for each fuel fired in the 700 hp boiler except for the SRC-Water Slurry test series when SO₂-SO₃ measurements were not obtained at sampling location 4.

The Cheney-Homolya SO_x sampling train⁵ was used to sample for SO₂ and SO₃ and consists of a heated quartz probe followed by an out of stack heated quartz filter followed by a controlled temperature condenser for selectively retaining condensed SO₃ (H₂SO₄) and a series of hydrogen peroxide bubblers for absorbing SO₂. The heated filter removes any sulfate-bearing particles that might interfere with determination of the gas phase SO₃ (H₂SO₄) while preventing the loss of SO₃ (H₂SO₄) vapor on the filter. The filter is maintained at a temperature of about 250°C and the condenser at about 60°C. The recovered condensate and peroxide solution are titrated by the barium-thorin procedure described in EPA Method 6.

Figure 12 presents a diagram of the sampling train used at PETC for all SO_2 and SO_3 measurements.

D. Secondary Voltage and Waveform Measurements

The voltage output of the transformer rectifier sets of the pilot ESP were monitored with calibrated voltage dividers which were installed in the high voltage bus ducts on the ESP. Voltage waveforms of corona start and maximum voltage output from the TR's were recorded with a Nicolet Digital Storage Oscilloscope. The voltage divider readings were used by WFI to correct their meter readings for their tabulations of operating voltages for each test series.

620-100

Figure 12. Schematic diagram of apparatus for collection of SO₃ and SO₂.

III. RESULTS

During the test programs at PETC each sampling contractor used their own test number nomenclature. The test numbers used by each contractor are traceable to a date and time of day each measurement or test was performed. The tables for test numbers include date, time and sample location for each measurement system during each phase of testing when data were obtained. Tables 2 through 6 present WFI Sciences test numbering system while Tables 7 through 10, present those used by SoRI. WFI Sciences and SoRI test numbering systems have been included since references are made to test numbers or sample filters elsewhere in this report.

The results obtained during the steady-state weeks of testing are those which are discussed in this report and include data obtained on the following days under the indicated conditions:

<u>Fuel</u>	<u>Steady-State Data</u>
No. 6 Fuel Oil	Aug. 30 through Sept. 3, 1982
SRC Fuel	Nov. 15 through Nov. 19, 1982
SRC Residual Fuel Oil	Dec. 13 through Dec. 17, 1982
SRC-Water Slurry	Jan. 11 through Jan. 14, 1983

A. Particle Size Distribution

1. Impactors

Cascade impactors were operated at sampling locations 3 and 4 with the exception of outlet sampling with impactors during the SRC-Water Slurry Test Series. Table 11 presents the daily average mass loadings calculated from the impactors along with WFI Sciences Method 17 data from the No. 6 fuel oil steady-state test. Tables 12, 13 and 14 present the impactor and mass train steady-

Table 2

WPI Sciences Test Numbering System
No. 6 Fuel Oil Firing
(August 26 through September 3, 1982)

Test date	ESP inlet		ESP outlet		Boiler outlet		Pulse jet outlet		Field comparator	
	Test No.	Time	Test No.	Time	Test No.	Time	Test No.	Time	Test No.	Time
8-26-82	EI-1	10:55-13:10	EO-1	10:55-13:10	N.A.	—	N.A.	—	1=1-5	9:03-15:22
	EI-2	13:46-15:55	EO-2	13:46-15:12						
8-27-82	EI-3	10:00-12:06	EO-3	10:00-12:06					2=1-4	9:42-14:25
	EI-4	12:42-12:49	EO-4	12:42-14:49						
8-30-82	EI-5	9:16-11:26	EO-5	9:16-11:26					3=1-5	9:21-15:05
	EI-6	12:45-14:53	EO-6	12:45-14:53						
8-31-82	EI-7	8:30-10:38	EO-7	8:30-10:38					4=1-5	8:45-17:26
	EI-8	14:10-14:27	EO-8	14:10-14:26						
	EI-9	15:54-18:00	EO-9	15:54-18:00						
9-1-82	EI-10	8:30-10:38	EO-10	8:30-10:38					5=1-4	8:40-17:33
	EI-11	12:32-17:38	EO-11	12:32-13:32						
9-2-82	EI-12	8:34-10:41	EO-12	8:34-10:41					5=5-8	8:33-13:57
	EI-13	12:33-14:44	EO-13	12:33-14:44						
9-3-82	EI-14	7:10-9:17	EO-14	7:10-9:17					6=1-7	6:01-13:48
	EI-15	10:36-12:49	EO-15	10:36-12:49						

Table 3

WFI Sciences Test Numbering System
 SRC Fuel Firing
 (October 29 through November 14, 1982)

Test date	ESP inlet		ESP outlet		Boiler outlet		Pulse jet outlet		Field comparator	
	Test No.	Time	Test No.	Time	Test No.	Time	Test No.	Time	Test No.	Time
10-25-82									1	11:40-12:45
									2	12:45-13:30
10-29-82	EI-1	11:11-13:12	EO-1	11:13-13:24	BO-1	11:21-13:13			3	18:35-19:45
	EI-2	18:42-20:09	EO-2	18:40-20:08	BO-2	13:43-20:12			4	19:45-20:05
11-1-82	EI-3	13:35-15:57	EO-3	13:31-15:58	BO-3	13:50-15:56			5-10	11:30-20:00
	EI-4	17:21-19:46	EO-4	17:22-19:58	BO-4	17:31-20:06				
11-3-82	EI-5	15:47-17:12	EO-5	15:48-17:19	BO-5	15:58-17:31			11-12	16:00-17:30
11-4-82	EI-6	11:47-13:52	EO-6	11:46-13:51	BO-6	11:51-13:55	PJ-1	11:15-14:00	13-14	11:50-14:00
11-5-82									15	18:30-19:39
11-8-82							PJ-2	11:45-11:55	16	11:30-15:51
11-10-82							PJ-3	10:58-13:42	17-19	10:58-13:45
11-11-82							PJ-4	13:17-14:26	20-22	12:58-16:50
11-12-82							PJ-5	15:10-16:40	23-24	15:00-16:25

Table 4

WFI Sciences Test Numbering System
SRC Fuel Firing
(November 15 through November 19, 1982)

Test date	ESP inlet		ESP outlet		Boiler outlet		Pulse jet outlet		Field comparator	
	Test No.	Time	Test No.	Time	Test No.	Time	Test No.	Time	Test No.	Time
11-15-82	EI-7	9:27-11:33	EO-7	9:28-11:34	BO-7	8:58-11:01	PJ-6	8:20-13:48	26-29	10:00-19:47
	EI-8	17:56-19:49	EO-8	17:55-19:58	BO-8	18:00-19:54				
11-16-82	EI-9	8:44-11:10	EO-9	8:43-11:09	BO-9	9:03-11:07	PJ-7	8:45-20:22	30-35	8:35-20:40
	EI-10	16:35-16:57	EO-10	16:34-16:56	BO-10	16:38-17:03				
	EI-11	18:42-20:48	EO-11	18:41-20:47	BO-11	18:43-19:26				
11-17-82	EI-12	8:40-10:45	EO-12	8:39-10:44	BO-12	8:50-10:54	PJ-8	8:42-16:47	36-40	8:40-16:50
	EI-13	14:34-16:40	EO-13	14:34-16:39	BO-13	14:44-16:51				
11-18-82	EI-14	14:18-16:23	EO-14	14:17-16:22	BO-14	14:22-16:25	PJ-9	14:19-18:31	41-45	15:15-18:50
	EI-15	17:02-19:06	EO-15	17:01-19:05	BO-15	17:02-19:07				
11-19-82	EI-16	9:00-11:05	EO-16	8:59-11:04	BO-16	8:37-10:34	PJ-10	8:18-16:51	46-54	9:00-17:40
	EI-17	11:42-11:57	EO-17	11:41-11:55	BO-17	11:53-12:01				
	EI-18	12:42-14:59	EO-18	12:41-14:58	BO-18	12:41-14:47				
	EI-19	15:37-17:33	EO-19	15:36-17:32	BO-19	15:46-17:52				

Table 5

WFI Sciences Test Numbering System
 SRC Residual Fuel Oil Firing
 (December 8 through December 17, 1982)

Test date	ESP inlet		ESP outlet		Boiler outlet		Pulse jet outlet		Field comparator	
	Test No.	Time	Test No.	Time	Test No.	Time	Test No.	Time	Test No.	Time
12-8-82	EI-20	10:07-12:16	EO-20	10:07-12:16	BO-20	10:22-12:31			55-58	11:49-17:25
	EI-21	14:57-17:05	EO-21	14:56-17:05	BO-21	14:58-17:04				
12-9-82	EI-22	9:15-11:24	EO-22	9:14-11:23	BO-22	9:00-11:07			59-64	9:02-16:21
	EI-23	13:33-15:39	EO-23	13:33-15:38	BO-23	13:23-15:30				
12-10-82	EI-24	11:44-13:51	EO-24	11:43-13:50	BO-24	11:49-13:56			65-70	11:47-18:10
	EI-25	16:00-18:04	EO-25	15:58-18:03	BO-25	14:27-17:19				
12-13-82	EI-26	11:10-13:19	EO-26	11:10-13:19	BO-26	11:06-13:14	PJ-11	11:15-13:19	71-74	11:15-16:20
	EI-27	14:10-16:18	EO-27	14:11-16:18	BO-27	14:13-16:23	PJ-12	14:13-16:15		
12-14-82	EI-28	9:56-12:33	EO-28	9:56-12:03	BO-28	9:00-11:39	PJ-13	9:26-13:55	75-83	9:00-18:00
	EI-29	13:02-15:12	EO-29	13:02-15:12	BO-29	12:00-14:07				
	EI-30	15:55-18:00	EO-30	15:55-18:00	BO-30	15:30-17:40				
12-15-82	EI-31	8:58-11:04	EO-31	8:45-10:52	BO-31	8:58-11:04	PJ-14	9:07-13:32	84-92	8:55-18:00
	EI-32	11:34-13:41	EO-32	11:30-13:38	BO-32	11:34-13:41				
	EI-33	14:15-16:22	EO-33	14:04-15:16	BO-33	14:15-16:22				
					BO-34	17:10-18:14				
12-16-82	EI-34	8:40-10:47	EO-34	8:40-10:45	BO-35	8:34-10:40	PJ-15	8:25-13:19	93-100	8:40-17:30
	EI-35	11:29-13:34	EO-35	11:28-13:34	BO-36	11:15-13:20				
					BO-37	16:00-18:05				
12-17-82	EI-36	9:06-11:12	EO-36	9:08-11:14	BO-38	9:21-11:28	PJ-16	9:35-13:57	101-108	9:20-17:01
	EI-37	11:39-13:44	EO-37	11:40-13:45	BO-39	11:52-13:57				
	EI-38	14:26-16:32	EO-38	14:28-16:32	BO-40	14:33-16:38				

Table 6

WFI Sciences Test Numbering System
 SRC-Water Slurry Firing
 (January 5 through January 14, 1983)

Test date	ESP inlet		ESP outlet		Boiler outlet		Pulse jet outlet		Field comparator	
	Test No.	Time	Test No.	Time	Test No.	Time	Test No.	Time	Test No.	Time
1-5-83	EI-39	10:25-11:31	EO-39	10:00-11:11	BO-41	10:24-12:34			109-112	9:57-13:06
1-6-83	EI-40	8:42-10:49	EO-40	8:40-9:46	BO-42	8:39-10:49			112	8:18-18:22
	EI-41	11:27-12:27	EO-41	11:27-12:27						
1-7-83	EI-42	9:00-10:25	EO-42	9:00-10:24	BO-43	9:01-10:31			113-120	8:39-17:04
	EI-43	11:15-12:40	EO-43	11:15-12:40	BO-44	11:16-12:45				
	EI-44	15:30-16:30	EO-44	15:30-16:30	BO-45	15:31-16:46				
1-10-83	EI-45	8:50-10:55	EO-45		BO-46	8:50-10:59			121-126	8:41-16:14
	EI-46	12:53-14:55	EO-46		BO-47	12:53-15:27				
1-11-83	EI-47	8:45-10:53	EO-47	8:45-10:50	BO-48	8:48-10:54	PJ-17	11:30-16:15	127-132	8:40-16:04
	EI-48	11:30-13:35	EO-48	11:30-13:32	BO-49	11:31-13:38				
	EI-49	14:15-16:20	EO-49	14:15-16:18						
1-12-83	EI-50	8:50-10:55	EO-50	8:50-10:57	BO-50	8:57-11:02	PJ-18	8:56-14:06	133-136	9:22-15:06
	EI-51	12:03-14:08	EO-51	12:04-14:10	BO-51	12:10-14:15				
	EI-52	14:37-16:42	EO-52	14:38-16:43						
1-13-83	EI-53	7:51-10:06	EO-53	7:52-9:58	BO-52	8:07-10:13	PJ-19	7:54-12:42		
	EI-54	10:40-12:20	EO-54	10:41-12:22	BO-53	10:45-12:51				
	EI-55	12:47-14:14	EO-55	12:49-14:14						
1-14-83	EI-56	8:20-10:25	EO-56	8:21-10:26	BO-54	8:22-10:28				
	EI-57	11:25-13:04	EO-57	11:25-13:07	BO-55	11:13-13:20				
	EI-58	13:31-14:57	EO-58	13:34-14:59						

Table 7

SoRI's Test Numbering System
No. 6 Fuel Oil Test
(August 24 through September 3, 1982)

	<u>SoRI Run ID</u>	<u>Date</u>	<u>Start Time</u>	<u>Finish Time</u>	<u>Test Duration (min)</u>
Inlet Impactors					
P	PETCI-1	8/24/82	09:01	10:22	81
P,B	PETCI-2	8/24/82	13:30	15:30	120
	PETCI-3	8/30/82	09:17	11:06	80
	PETCI-4	8/30/82	12:34	13:56	80
B	PETCI-5	8/30/82	09:25	10:45	80
	PETCI-6	8/31/82	08:32	10:16	64
A	PETCI-7	8/31/82	14:07	14:26	19
B	PETCI-8	8/31/82	08:34	09:39	64
	PETCI-9	8/31/82	15:51	17:37	64
	PETCI-10	9/1/82	08:30	10:09	64
	PETCI-11	9/1/82	12:31	16:48	64
B	PETCI-12	9/1/82	08:33	09:41	68
	PETCI-13	9/2/82	08:30	10:32	64
	PETCI-14	9/2/82	12:35	14:44	64
B	PETCI-15	9/2/82	08:32	09:36	64
	PETCI-16	9/3/82	07:07	08:51	64
	PETCI-17	9/3/82	10:32	12:22	64
B	PETCI-18	9/3/82	07:09	08:13	64
Outlet Impactors					
P	PETCO-1	8/26/82	09:07	15:30	389
P,B	PETCO-2	8/27/82	07:56	14:57	421
	PETCO-3	8/30-31/82	09:15(8/30)	15:57(8/31)	480
B	PETCO-4	8/30/82	09:16	16:00	480
	PETCO-5	9/1-3/82	08:00(9/1)	13:44(9/3)	480
B	PETCO-6	9/1,9/3/82	08:00(9/1)	13:44(9/3)	480

A = Aborted run; B = blank; P = preliminary.

Table 7 (Continued)

SoRI's Test Numbering System
No. 6 Fuel Oil Test
(August 24 through September 3, 1982)

	<u>SoRI Run ID</u>	<u>Date</u>	<u>Start Time</u>	<u>Finish Time</u>	<u>Test Duration (min)</u>
	Cyclone				
P	PETCI-1C	8/24/82	13:51	15:11	81
	PETCI-2C	8/30/82	09:20	17:20	480
	PETCI-3C	8/31/82	08:30	16:30	480
	PETCI-4C	9/1/82	08:30	16:30	480
	PETCI-5C	9/2-3/82	08:21 (9/2)	11:46 (9/3)	480
	Resistivity				
P	PETCI-1R	8/24/82	09:32	13:30	238
P	PETCI-2R	8/27/82	09:33	13:30	237
	PETCI-3R	8/30/82	09:35	12:31	176
	PETCI-4R	8/31/82	08:04	11:30	206
	PETCI-5R	8/31/82	16:03	18:07	124
	PETCI-6R	9/1/82	11:53	12:53	60
	PETCI-7R	9/2/82	08:08	11:45	217
	PETCI-8R	9/2/82	12:37	15:30	173
	PETCI-9R	9/3/82	05:59	09:45	226
	PETCI-10R	9/3/82	10:34	11:05	31
	Ultrafine Inlet EAA				
P	PETCI-1U	8/24/82	10:45	14:20	215
P	PETCI-2U	8/26/82	08:55	11:15	140
P	PETCI-3U	8/27/82	13:50	15:16	86
	PETCI-4U	8/30/82	09:19	10:39	80
	PETCI-5U	8/30/82	14:25	17:30	185
	PETCI-6U	8/31/82	08:55	12:05	190
	PETCI-7U	9/1/82	09:50	17:35	465

P = Preliminary; S = shorted out.

Table 7 (Continued)

SoRI's Test Numbering System
No. 6 Fuel Oil Test
(August 24 through September 3, 1982)

	<u>SoRI Run ID</u>	<u>Date</u>	<u>Start Time</u>	<u>Finish Time</u>	<u>Test Duration (min)</u>
Ultrafine Outlet EAA					
P	PETCO-1U	8/27/82	09:47	11:30	103
	PETCO-2U	8/30/82	12:30	15:50	200
	PETCO-3U	9/2/82	09:05	16:30	445
	PETCO-4U	9/3/82	07:19	12:15	296
Ultrafine Inlet Optical					
P	PETCI-1P	8/24/82	10:45	14:20	215
P	PETCI-2P	8/26/82	08:55	11:15	140
P	PETCI-3P	8/27/82	13:50	15:16	86
	PETCI-4P	8/30/82	09:19	10:39	80
	PETCI-5P	8/30/82	14:25	17:30	185
	PETCI-6P	8/31/82	08:55	12:05	190
	PETCI-7P	9/1/82	09:50	17:35	465
Ultrafine Outlet Optical					
P	PETCO-1P	8/27/82	09:47	11:30	103
	PETCO-2P	8/30/82	12:30	15:50	200
	PETCO-3P	9/2/82	09:05	16:30	440
	PETCO-4P	9/3/82	07:19	12:15	296

P = Preliminary.

Table 8

SoRI's Test Numbering System
SRC Fuel Test
(October 20 through November 19, 1982)

	<u>SoRI Run ID</u>	<u>Date</u>	<u>Start Time</u>	<u>Finish Time</u>	<u>Test Duration (min)</u>
		Inlet Impactors			
P	PETCI-19	10/20/82	11:55	13:11	62
P	PETCI-20	10/21/82	10:15	10:23	8
P	PETCI-21	10/25/82	14:00	15:03	63
P	PETCI-22	10/28/82	11:50	12:50	30
P	PETCI-23	10/29/82	13:06	13:16	10
P	PETCI-24	11/1/82	13:50	15:68	56
P	PETCI-25	11/1/82	17:08	17:48	40
P	PETCI-26	11/3/82	15:23	16:03	40
P	PETCI-27	11/4/82	11:42	12:22	40
P	PETCI-28	11/15/82	09:31	10:11	40
P	PETCI-29	11/15/82	10:54	10:34	40
P	PETCI-30	11/15/82	17:52	18:32	40
P,B	PETCI-31	11/15/82	19:01	19:41	40
P	PETCI-32	11/16/82	08:41	09:21	40
P	PETCI-33	11/16/82	10:16	10:56	40
P,A	PETCI-34	11/16/82	16:33	17:13	40
P	PETCI-35	11/16/82	18:36	19:04	40
P,B	PETCI-36	11/16/82	19:49	20:17	28
P,A	PETCI-37	11/17/82	08:55	09:35	40
P	PETCI-38	11/17/82	10:00	10:40	40
P	PETCI-39	11/17/82	14:42	15:10	28
P,B	PETCI-40	11/17/82	15:43	16:11	28
P	PETCI-41	11/18/82	14:32	14:40	8
	PETCI-42	11/18/82	15:37	15:43	6
	PETCI-43	11/18/82	17:03	17:09	6
B	PETCI-44	11/18/82	18:28	18:34	6
	PETCI-45	11/19/82	08:58	09:04	6
	PETCI-46	11/19/82	10:32	10:38	6
	PETCI-47	11/19/82	12:40	12:46	6
	PETCI-48	11/19/82	14:23	14:29	6
	PETCI-49	11/19/82	15:36	15:42	6
B	PETCI-50	11/19/82	17:06	17:12	6

A - Aborted Run
B - Blank
P - Preliminary

Table 8 (Cont'd)

SoRI's Test Numbering System
SRC Fuel Test
(October 20 through November 19, 1982)

	<u>SoRI Run ID</u>	<u>Date</u>	<u>Start Time</u>	<u>Finish Time</u>	<u>Test Duration (min)</u>
Outlet Impactors					
P	PETCO-7	10/28/82	10:52	11:23	30
P,B	PETCO-8	10/29/82	18:28	18:58	30
P	PETCO-9	11/1/82	13:43	15:43	120
P,B	PETCO-10	11/1/82	17:11	19:11	120
P	PETCO-11	11/4/82	11:46	13:06	60
	PETCO-12	11/15/82	09:35	11:35	120
A	PETCO-13	11/16/82	08:35	16:55	142
	PETCO-14	11/16/82	18:38	22:38	240
	PETCO-15	11/7-18/82	14:37(11/17)	19:06(11/18)	240
	PETCO-16	11/19/82	09:03	17:41	480
Cyclones					
P	PETCI-6C	10/29/82	18:30	19:21	51
P	PETCI-7C	11/1/82	14:15	16:00	105
P	PETCI-8C	11/3/82	15:30	17:18	105
P	PETCI-9C	11/4/82	11:55	13:55	120
	PETCI-10C	11/15/82	09:35	11:35	120
	PETCI-11C	11/16/82	08:45	10:15	90
	PETCI-12C	11/17/82	08:38	10:08	90
	PETCI-13C	11/18/82	14:27	15:57	90
	PETCI-14C	11/19/82	09:00	10:30	90
Resistivity					
P	PETCI-11R	10/21/82	13:00	13:55	55
	PETCI-12R	11/1/82	16:50		
	PETCI-13R	11/3/82	15:44	16:45	181
	PETCI-14R	11/15/82	18:24	19:20	56
	PETCI-15R	11/16/82	18:45	19:30	45
	PETCI-16R	11/17/82	14:50	16:20	90
	PEqCI-17C	11/18/82	17:15	18:40	85
A	PETCI-18R	11/18/82	16:40	16:50	10

A - Aborted Run
 B - Blank
 P - Preliminary
 S - Shorted Out

Table 8 (Cont'd)

SoRI's Test Numbering System
SRC Fuel Test
(October 20 through November 19, 1982)

	<u>SoRI Run ID</u>	<u>Date</u>	<u>Start Time</u>	<u>Finish Time</u>	<u>Test Duration (min)</u>
Ultrafine Inlet EAA					
P	PETCI-8U	10/29/82	11:50	13:20	90
P	PETCI-9U	10/29/82	18:30	20:00	90
P	PETCI-10U	11/1/82	14:00	15:34	94
P	PETCI-11U	11/1/82	17:10	18:45	95
P	PETCI-12U	11/3/82	15:25	16:38	73
P	PETCI-13U	11/4/82	11:45	13:03	78
	PETCI-14U	11/15/82	18:00	19:40	100
	PETCI-15U	11/16/82	10:01	11:30	89
	PETCI-16U	11/17/82	14:38	16:38	120
	PETCI-17U	11/18/82	14:15	15:24	69
	PETCI-18U	11/19/82	12:47	17:00	253
Ultrafine Outlet EAA					
	PETCO-5U	11/17/82	09:35	11:00	85
	PETCO-6U	11/18/82	15:35	16:22	47
	PETCO-7U	11/18/82	16:44	19:00	136
	PETCO-8U	11/19/82	08:30	11:00	150
Ultrafine Inlet Optical					
P	PETCI-8P	10/29/82	11:50	13:20	90
P	PETCI-9P	10/29/82	18:30	20:00	90
P	PETCI-10P	11/1/82	14:00	15:34	94
P	PETCI-11P	11/1/82	17:10	18:45	95
P	PETCI-12P	11/3/82	15:25	16:38	73
P	PETCI-13P	11/4/82	11:45	13:03	78
P	PETCI-14P	11/15/82	18:00	19:40	100
	PETCI-15P	11/16/82	10:01	11:30	89
	PETCI-16P	11/16/82	18:00	19:42	102
	PETCI-17P	11/17/82	14:38	16:38	120
	PETCI-18P	11/18/82	14:15	15:24	69
	PETCI-19P	11/19/82	12:47	17:00	253

P - Preliminary

Table 8 (Cont'd)

SoRI's Test Numbering System
 SRC Fuel Test
 (October 20 through November 19, 1982)

<u>SoRI Run ID</u>	<u>Date</u>	<u>Start Time</u>	<u>Finish Time</u>	<u>Test Duration (min)</u>
Ultrafine Outlet Optical				
PETCO-5P	11/16/82	19:42	21:00	78
PETCO-6P	11/17/82	09:35	11:00	85
PETCO-7P	11/18/82	15:35	16:22	47
PETCO-8P	11/18/82	16:44	19:00	136
PETCO-9P	11/19/82	08:30	11:00	150

Table 9

SoRI's Test Numbering System
 SRC Residual Fuel Oil Test
 (December 6 through December 17, 1982)

	<u>SoRI Run ID</u>	<u>Date</u>	<u>Start Time</u>	<u>Finish Time</u>	<u>Test Duration (min)</u>
	Inlet Impactors				
P,A	PETCI-51	12/6/82			6
P	PETCI-52	12/6/82	15:35	15:47	12
P	PETCI-53	12/7/82	09:56	10:10	12
P	PETCI-54	12/7/82	15:12	15:18	6
P	PETCI-55	12/9/82	09:35	09:52	12
P	PETCI-56	12/10/82	11:43	12:00	12
	PETCI-57	12/13/82	11:15	11:27	12
	PETCI-58	12/13/82	12:43	12:55	12
	PETCI-59	12/13/82	14:10	14:22	12
B	PETCI-60	12/13/82	15:44	15:56	12
	PETCI-61	12/14/82	09:23	09:35	12
	PETCI-62	12/14/82	11:33	11:42	12
	PETCI-63	12/14/82	13:00	13:12	12
B	PETCI-64	12/14/82	15:44	15:56	12
	PETCI-65	12/14/82	14:41	14:53	12
A	PETCI-66	12/15/82	08:56	09:08	12
	PETCI-67	12/15/82	10:25	10:37	12
	PETCI-68	12/15/82	11:40	11:52	12
	PETCI-69	12/15/82	13:10	13:22	12
B	PETCI-70	12/15/82	14:20	14:32	12
	PETCI-71	12/16/82	08:51	09:03	12
	PETCI-72	12/16/82	10:17	10:29	12
	PETCI-73	12/16/82	11:43	11:55	12
	PETCI-74	12/16/82	13:16	13:28	12
	PETCI-75	12/17/82	09:19	09:29	10
	PETCI-76	12/17/82	10:40	10:50	10
	PETCI-77	12/17/82	12:02	12:12	10
	PETCI-78	12/17/82	13:15	13:25	10
	PETCI-79	12/17/82	14:52	15:02	10
	PETCI-80	12/17/82	16:05	16:15	10

A - Aborted Run
 B - Blank
 P - Preliminary

Table 9 (Cont'd)

SoRI's Test Numbering System
SRC Residual Fuel Oil
(December 6 through December 17, 1982)

	<u>SoRI Run ID</u>	<u>Date</u>	<u>Start Time</u>	<u>Finish Time</u>	<u>Test Duration (min)</u>
	Outlet Impactor				
	PETCO-17	12/13-14/82	11:17(12/13)	15:30(12/14)	577
	PETCO-18	12/15-16/82	08:52(12/15)	13:34(12/16)	518
	PETCO-19	12/17/82	09:07	16:30	367
	Cyclones				
P	PETCI-15C	12/8/82	10:09	12:11	120
	PETCI-16C	12/13/82	11:10	13:15	125
	PETCI-17C	12/14/82	09:23	11:58	155
	PETCI-18C	12/15/82	09:02	12:07	185
	PETCI-19C	12/16/82	08:51	12:21	210
	PETCI-20C	12/17/82	09:20	12:30	190
	Resistivity				
P	PETCI-20R	12/9/82	09:30	11:00	90
P	PETCI-21R	12/10/82	11:43	13:20	37
	PETCI-22R	12/13/82	14:35	16:00	85
	PETCI-23R	12/14/82	09:42	15:15	333
	Ultrafine Inlet EAA				
P	PETCI-19U	12/8/82	10:12	11:30	78
P	PETCI-20U	12/9/82	09:32	10:30	58
P	PETCI-21U	12/10/82	13:55	14:55	60
	PETCI-22U	12/15/82	11:15	12:30	75
	PETCI-23U	12/16/82	12:15	13:30	75
	PETCI-24U	12/17/82	09:40	11:00	80

P - Preliminary
S - Shorted Out

Table 9 (Cont'd)

SoRI's Test Numbering System
SRC Residual Fuel Oil Test
(December 6 through December 17, 1982)

	<u>SoRI Run ID</u>	<u>Date</u>	<u>Start Time</u>	<u>Finish Time</u>	<u>Test Duration (min)</u>
	Ultrafine Outlet EAA				
P	PETCO-9U	12/9/82	11:10	12:10	60
P	PETCO-10U	12/10/82	12:08	13:10	62
	PETCO-11U	12/5/82	13:00	14:00	60
	PETCO-12U	12/16/82	09:10	10:15	65
	PETCO-13U	12/17/82	12:05	15:00	175
	Ultrafine Inlet Optical				
P	PETCI-20P	12/8/82	10:12	11:30	78
P	PETCI-21P	12/9/82	09:32	10:30	58
P	PETCI-22P	12/10/82	13:55	14:55	60
	PETCI-23P	12/15/82	11:15	12:30	75
	PETCI-24P	12/16/82	12:15	13:30	75
	PETCI-25P	12/17/82	09:40	11:00	80
	Ultrafine Outlet Optical				
P	PETCO-10P	12/9/82	11:10	12:10	60
P	PETCO-11P	12/10/82	12:08	13:10	62
	PETCO-12P	12/15/82	13:00	14:00	60
	PETCO-13P	12/16/82	09:10	10:15	65
	PETCO-14P	12/17/82	12:05	15:00	175

P - Preliminary

Table 10

SoRI's Test Numbering System
SRC-Water Slurry Test
(January 5 through January 14, 1983)

	<u>SoRI Run ID</u>	<u>Date</u>	<u>Start Time</u>	<u>Finish Time</u>	<u>Test Duration (min)</u>
	Inlet Impactors				
P	PETCI-81	1/5/83	10:10	10:20	6
P,B	PETCI-82	1/6/83	09:00	09:10	6
P	PETCI-83	1/6/83	10:19	10:30	6
P,H	PETCI-84	1/10/83	09:10	09:16	6
P,H	PETCI-85	1/10/83	11:15	11:21	6
P,H	PETCI-86	1/10/83	12:54	13:00	6
P,H,B	PETCI-87	1/10/83	15:20	15:26	6
P,H	PETCI-88	1/10/83	14:27	14:33	6
	PETCI-89	1/11/83	08:59	09:05	6
	PETCI-90	1/11/83	10:18	10:24	6
	PETCI-91	1/11/83	11:55	12:01	6
	PETCI-92	1/11/83	13:06	13:12	6
B	PETCI-93	1/11/83	13:50	13:56	6
	PETCI-94	1/12/83	09:34	09:40	6
	PETCI-95	1/12/83	10:21	10:27	6
	PETCI-96	1/12/83	11:55	12:01	6
	PETCI-97	1/12/83	12:35	12:41	6
B	PETCI-98	1/12/83	13:45	13:51	6
	PETCI-99	1/13/83	08:25	08:31	6
	PETCI-101	1/13/83	09:37	09:43	6
	PETCI-102	1/13/83	11:02	11:08	6
	PETCI-103	1/13/83	11:57	12:03	6
B	PETCI-104	1/13/83	13:06	13:12	6
	PETCI-105	1/14/83	08:51	08:57	6
	PETCI-106	1/14/83	09:48	09:54	6
	PETCI-107	1/14/83	11:26	11:32	6
	PETCI-108	1/14/83	12:43	12:49	6
B	PETCI-109	1/14/83	13:36	13:42	6

B = Blank; H = high O₂; P = preliminary.

Table 10 (Continued)

SoRI's Test Numbering System
 SRC-Water Slurry Test
 (January 5 through January 14, 1983)

	<u>SoRI Run ID</u>	<u>Date</u>	<u>Start Time</u>	<u>Finish Time</u>	<u>Test Duration (min)</u>
Cyclone					
P	PETCI-21C	1/7/83	09:00	10:05	60
	PETCI-22C	1/11/83	08:55	10:25	90
	PETCI-23C	1/12/83	09:34	11:04	90
	PETCI-24C	1/13/83	08:25	09:55	90
	PETCI-25C	1/14/83	08:50	10:20	90
P,H	PETCI-26C	1/10/83	09:11	10:41	90
Resistivity					
P	PETCI-24R	1/7/83	10:58	11:58	60
H	PETCI-25R	1/10/83	13:02	13:17	15
	PETCI-26R	1/11/83	13:05	14:00	55
	PETCI-27R	1/12/83	12:45	13:45	60
	PETCI-28R	1/13/83	12:12	13:13	60
A	PETCI-29R	1/14/83	12:24	-	-

A = Aborted run; H = high O₂; P = preliminary; S = shorted.

Table 10 (Continued)

SoRI's Test Numbering System
SRC-Water Slurry Test
(January 5 through January 14, 1983)

	<u>SoRI Run ID</u>	<u>Date</u>	<u>Start Time</u>	<u>Finish Time</u>	<u>Test Duration (min)</u>
Ultrafine Inlet EAA					
P	PETCI-19U	1/5/83	10:30	12:30	120
P	PETCI-20U	1/6/83	09:44	15:00	316
P	PETCI-21U	1/7/83	09:35	12:51	196
P	PETCI-22U	1/7/83	15:12	15:40	28
P, H	PETCI-23U	1/10/83	09:50	11:10	140
P, H	PETCI-24U	1/10/83	12:50	14:20	90
	PETCI-25U	1/11/83	09:20	10:25	65
	PETCI-26U	1/11/83	12:36	13:50	74
	PETCI-27U	1/12/83	10:05	11:05	60
	PETCI-28U	1/12/83	12:15	13:30	75
	PETCI-29U	1/14/83	09:37	10:35	58
Ultrafine Inlet Optical					
P	PETCI-20P	1/5/83	10:30	12:30	120
P	PETCI-21P	1/6/83	09:44	15:00	316
P	PETCI-22P	1/7/83	09:35	12:51	196
P	PETCI-23P	1/10/83	09:50	11:10	80
P	PETCI-24P	1/10/83	12:50	14:20	90
	PETCI-25P	1/11/83	09:20	10:25	65
	PETCI-26P	1/11/83	12:36	13:50	74
	PETCI-27P	1/12/83	10:05	11:05	60
	PETCI-28P	1/12/83	12:15	13:30	75
	PETCI-29P	1/14/83	09:37	10:35	58

P = preliminary; H = high O₂.

Table 11

Results of No. 6 Fuel Oil Steady-State Test; Method 17 and Impactor Data

	Date					Test
	8-30-82	8-31-82	9-1-82	9-2-82	9-3-82	average
ESP Inlet						
Temperature, °F	340	356	366	359	368	358
°C	171	180	185	181	186	181
Volume flow, acfm	5125	5091	5057	5098	5390	5152
ds ³ /sec	1.30	1.26	1.25	1.25	1.31	1.27
Mass loading						
Mass trains, gr/dscf	0.0292	0.0283	0.0320	0.0374	0.0308	0.0315
gr/dsm ³	0.0668	0.0649	0.0731	0.0856	0.0705	0.0722
lb/10 ⁶ Btu	0.0451	0.0445	0.0499	0.0583	0.0484	0.0492
g/10 ⁶ cal	0.0812	0.0801	0.0898	0.1049	0.0871	0.0886
Impactors, gr/dscf	0.0219	0.0235	0.0240	0.0226	0.0227	0.0230
gr/dsm ³	0.0501	0.0538	0.0549	0.0517	0.0520	0.0526
lb/10 ⁶ Btu	0.0339	0.0369	0.0374	0.0352	0.0357	0.0359
g/10 ⁶ cal	0.0610	0.0664	0.0673	0.0633	0.0642	0.0647
ESP Outlet						
Temperature, °F	290	299	307	303	309	302
°C	143	148	152	150	153	149
Volume flow, acfm	4834	4800	4883	4853	4934	4860
ds ³ /sec	1.40	1.36	1.35	1.35	1.37	1.37
Mass loading						
Mass trains, gr/dscf	0.0026	0.0021	0.0026	0.0020	0.0021	0.0023
gr/dsm ³	0.0061	0.0049	0.0059	0.0046	0.0048	0.0053
lb/10 ⁶ Btu	0.0044	0.0036	0.0045	0.0035	0.0037	0.0040
g/10 ⁶ cal	0.0079	0.0065	0.0081	0.0063	0.0067	0.0072
Impactors, gr/dscf	-----0.0005-----	-----0.0004-----	-----0.0004-----	-----0.0004-----	-----0.0004-----	0.0004
gr/dsm ³	-----0.0011-----	-----0.0009-----	-----0.0009-----	-----0.0009-----	-----0.0009-----	0.0009
lb/10 ⁶ Btu	-----0.0008-----	-----0.0006-----	-----0.0006-----	-----0.0006-----	-----0.0006-----	0.0007
g/10 ⁶ cal	-----0.0014-----	-----0.0011-----	-----0.0011-----	-----0.0011-----	-----0.0011-----	0.0013
Efficiency, %						
Mass trains	91.10	92.58	91.88	94.65	93.18	92.70
Impactors	-----97.80-----	-----98.27-----	-----98.27-----	-----98.27-----	-----98.27-----	98.26
SCA, ft ² /1000 acfm	237	239	241	239	226	236
m ² /(m ³ /sec)	46.7	47.0	47.4	44.4	47.0	46.5

Table 12

Results of SRC Fuel Steady-State Test; Method 17 and Impactor Data

	Date					Test
	11-15-82	11-16-82	11-17-82	11-18-82	11-19-82	average
ESP Inlet						
Temperature, °F	301	296	300	303	300	301
°C	149	147	148	150	149	149
Volume flow, acfm	5366	5063	5137	5242	5404	5245
ds ³ /sec	1.58	1.53	1.54	1.52	1.56	1.52
Mass loading						
Mass trains, gr/dscf	0.4597	0.4192	0.4569	0.3846	0.4278	0.4248
gr/dsm ³	1.025	0.9594	1.046	0.8802	0.9784	0.9722
lb/10 ⁶ Btu	0.9318	0.9145	0.9462	0.8327	0.8610	0.8862
g/10 ⁶ cal	1.6772	1.6461	1.7032	1.4989	1.5498	1.5952
Impactors, gr/dscf	0.4247 ^a	0.2019 ^a	0.3871 ^a	0.4074	0.3720	0.3821
gr/dsm ³	0.9720 ^a	0.4621 ^a	0.8860 ^a	0.9324	0.8514	0.8745
lb/10 ⁶ Btu	0.8608 ^a	0.4405 ^a	0.8017 ^a	0.8820	0.7487	0.7971
g/10 ⁶ cal	1.5494 ^a	0.7929 ^a	1.4431 ^a	1.5876	1.3477	1.4348
ESP Outlet						
Temperature, °F	229	227	235	243	236	234
°C	109	108	113	117	114	112
Volume flow, acfm	6048	6049	6117	6251	6161	6129
ds ³ /sec	2.06	2.06	2.04	2.06	2.06	2.06
Mass loading						
Mass trains, gr/dscf	0.0061	0.0100	0.0023	0.0016	0.0025	0.0040
gr/dsm ³	0.0138	0.0229	0.0053	0.0037	0.0057	0.0092
lb/10 ⁶ Btu	0.0153	0.0304	0.0063	0.0043	0.0063	0.0105
g/10 ⁶ cal	0.0275	0.0547	0.0113	0.0077	0.0113	0.0189
Impactors, gr/dscf	0.0026	0.0031	-----0.0014-----		0.0005	0.0019
gr/dsm ³	0.0060	0.0071	-----0.0032-----		0.0011	0.0043
lb/10 ⁶ Btu	0.0346	0.0095	-----0.0037-----		0.0014	0.0050
g/10 ⁶ cal	0.0623	0.0171	-----0.0067-----		0.0025	0.0090
Efficiency, %						
Mass trains	98.67	97.61	99.50	99.58	99.42	99.06
Impactors	—	—	—	99.66	99.87	99.50
SCA, ft ² /1000 acfm	227	239	237	232	223	232
m ² /(m ³ /sec)	44.7	47.0	46.6	45.7	43.9	45.7

a. Data from Brink impactors and not used in averages.

Table 13

Results of SRC Residual Fuel Oil Steady-State Test; Method 17 and Impactor Data

	Date					Test
	12-13-82	12-14-82	12-15-82	12-16-82	12-17-82	average
ESP Inlet						
Temperature, °F	300	301	295	300	300	299
°C	149	149	147	149	149	148
Volume flow, acfm	5091	5249	4983	5105	7034	5107 ^a
ds ³ /sec	1.43	1.45	1.42	1.40	1.97	1.42 ^a
Mass loading						
Mass trains, gr/dscf	0.745	0.1246	0.0982	0.1282	0.1197	0.1112
gr/dsm ³	0.170	0.285	0.225	0.293	0.274	0.2545
lb/10 ⁶ Btu	0.1352	0.2320	0.1805	0.2136	0.2018	0.1968
g/10 ⁶ cal	0.2434	0.4176	0.3249	0.3845	0.3632	0.3542
Impactors, gr/dscf	0.770	0.1157	0.0903	0.1144	0.0985	0.1007
gr/dsm ³	0.1762	0.2648	0.2067	0.2618	0.2254	0.2305
lb/10 ⁶ Btu	0.1397	0.2155	0.1660	0.1906	0.1660	0.1782
g/10 ⁶ cal	0.2515	0.3878	0.2987	0.3430	0.2989	0.3207
ESP Outlet						
Temperature, °F	229	239	240	240	254	237
°C	110	115	116	116	123	114
Volume flow, acfm	5623	5669	5722	5644	7576	5665
ds ³ /sec	1.84	1.81	1.83	1.79	2.37	1.80
Mass loading						
Mass trains, gr/dscf	0.0006	0.0009	0.0006	0.0002	0.0041	0.0006 ^a
gr/dsm ³	0.0014	0.0021	0.0014	0.0005	0.0094	0.0014 ^a
lb/10 ⁶ Btu	0.0012	0.0019	0.0012	0.0004	0.0077	0.0012 ^b
g/10 ⁶ cal	0.0022	0.0034	0.0022	0.0007	0.0139	0.0022 ^b
Impactors, gr/dscf	-----0.0003-----		-----0.0008-----		0.0012	0.0005 ^a
gr/dsm ³	-----0.0007-----		-----0.0018-----		0.0027	0.0011 ^a
lb/10 ⁶ Btu	-----0.0005-----		-----0.0015-----		0.0028	0.0010 ^b
g/10 ⁶ cal	-----0.0009-----		-----0.0027-----		0.0050	0.0019 ^b
Efficiency, %						
Mass trains	99.19	99.28	99.39	99.84	96.57	99.46
Impactors	-----99.69-----		-----99.22-----		98.78	99.50 ^a
SCA, ft ² /1000 acfm	239	232	239	238	173	237 ^a
m ² /(m ³ /sec)	47.0	45.7	47.0	46.8	34.0	46.7 ^a

a. The data for December 17 are not included in the average.

b. Does not include data when TR Set 1 was out of service.

Table 14

Results of SRC-Water Slurry Steady-State Test; Method 17 and Impactor Data

	Date						Test
	1-11-83	1-12-83	1-13-83		1-14-83		average
ESP Inlet							
Temperature, °F	303	301	-----300-----		-----300-----		301
°C	151	149	-----149-----		-----149-----		149
Volume flow, acfm	5581	5220	5591	5645	5338	5571	5478
ds _m ³ /sec	1.49	1.45	1.52	1.51	1.43	1.48	1.48
Mass loading							
Mass trains, gr/dscf	0.6139	0.4934	0.4931	0.5531	0.5396	0.5850	0.5476
gr/dsm ³	1.405	1.129	1.129	1.266	1.235	1.339	1.253
lb/10 ⁶ Btu	1.0754	0.8539	0.8531	0.9572	0.9452	1.0248	0.9534
q/10 ⁶ cal	1.9357	1.5370	1.5356	1.7230	1.7014	1.8446	1.7161
Impactors, gr/dscf	0.6357	0.5029	-----0.5815-----		-----0.5265-----		0.5616
gr/dsm ³	1.455	1.151	-----1.331-----		-----1.205-----		1.285
lb/10 ⁶ Btu	1.1216	0.8703	-----1.0064-----		-----0.9223-----		0.9778
q/10 ⁶ cal	2.0189	1.5666	-----1.8115-----		-----1.6602-----		1.7600
ESP Outlet							
Temperature, °F	240	237	-----240-----		-----240-----		239
°C	16	114	-----116-----		-----116-----		115
Volume flow, acfm	5974	5701	5741	5740	5686	5548	5753
ds _m ³ /sec	1.84	1.81	1.80	1.76	1.77	1.72	1.80
Mass loading							
Mass trains, gr/dscf	0.0022	0.0062	0.0035	0.0121 ^a	0.0072	0.0126 ^a	0.0044 ^b
gr/dsm ³	0.0051	0.0142	0.0080	0.0277 ^a	0.0165	0.0288 ^a	0.0100 ^b
lb/10 ⁶ Btu	0.0052	0.0129	0.0075	0.0259	0.0152	0.0266	0.0095
q/10 ⁶ cal	0.0094	0.0232	0.0135	0.0466	0.0274	0.0479	0.0171
Impactors, gr/dscf	--	--	--	--	--	--	--
gr/dsm ³	--	--	--	--	--	--	--
lb/10 ⁶ Btu	--	--	--	--	--	--	--
q/10 ⁶ cal	--	--	--	--	--	--	--
Efficiency, %							
Mass trains	99.64	98.74	99.29	97.81	98.67	97.85	99.20 ^b
Impactors	--	--	--	--	--	--	--
SCA, ft ² /1000 acfm	218	233	218	144 ^a	228	146 ^a	222 ^b
m ² /(m ³ /sec)	42.9	45.9	42.9	28.3	44.9	28.7	43.7 ^b

a. TR Set 1 was out of operation.

b. Does not include data when TR Set 1 was out of service.

state data from the SRC Fuel, SRC Residual Fuel Oil and SRC-Water Slurry tests, respectively.

Due to the requirement of sampling at an average isokinetic rate with the impactors, the calculated loadings from mass trains, which sample isokinetically at each sample point, as compared with those calculated from impactors, often do not agree exactly but usually are within $\pm 25\%$. In situations where the loadings which are compared are very low, the difference in the types of measurements, mass train vs. impactor, have been quite large, as at PETC. The reason for this difference is usually attributed to the large particles which would be representatively collected with mass trains and not impactors. The differences noticed between the outlet ESP loadings during the No. 6 fuel oil test are very large (greater than a factor of 5) and may have been due to gas phase reactions with the flue gas and filtering media used by WFI Sciences and/or nozzle scrappings. After the No. 6 fuel oil test, WFI Sciences used filter media supplied by SoRI for the outlet mass train sampling. The filtering media used was Reeve-Angel 934-AH filter paper which had been conditioned by SoRI using an acid washing procedure described in "Procedures for Cascade Impactor Calibration and Operation in Process Streams," by D. B. Harris, U.S. Environmental Protection Agency, Report No. EPA-600/2-77-004, January 1977.

The data obtained at the ESP inlet and outlet sampling location with cascade impactors during the No. 6 fuel oil tests are presented graphically in Figures 13, 14, 15 and 16 as cumulative mass loading, cumulative percent, $dM/d\log D$ (differential mass) and $dN/d\log D$ (differential number) vs. particle size, respectively. Figure 17 presents the fractional collection efficiency measured across the ESP while No. 6 fuel oil was fired in the boiler.

PITTSBURGH ENERGY TECH. CENTER OIL STEADY STATE INLET AUG-SEPT

5034-1

Figure 13. Cumulative mass loading versus particle diameter for No. 6 fuel oil; August 30 – September 3, 1982; ESP inlet and outlet.

PITTSBURGH ENERGY TECH. CENTER OIL STEADY STATE INLET AUG-SEPT

5034-2

Figure 14. Cumulative percent versus particle diameter for No. 6 fuel oil; August 30 – September 3, 1982; ESP inlet and outlet.

PITTSBURGH ENERGY TECH. CENTER OIL STEADY STATE INLET AUG-SEPT

5034-3

Figure 15. $dM/dlogD$ versus particle diameter for No. 6 fuel oil; August 30 – September 3, 1982; ESP inlet and outlet.

PITTSBURGH ENERGY TECH. CENTER OIL STEADY STATE INLET AUG-SEPT

5034-4

Figure 16. $dN/dlogD$ versus particle diameter for No. 6 fuel oil; August 30 – September 3, 1982; ESP inlet and outlet.

PITTSBURGH ENERGY TECH. CENTER OIL STD. STA. FRACTIONAL EFFICIENCY

Figure 17. Fractional efficiency curve for No. 6 fuel oil; August 30 – September 3, 1982.

The impactor data for the pulverized SRC steady-state test are presented in Figures 18 through 22; those from the SRC Residual Fuel Oil test in Figures 23 through 27; and those from the SRC-Water Slurry test in Figures 28 through 31.

Ash collected in the ESP was used for particle density determinations with a helium pycnometer for inclusion in the Cascade Impactor Data Reduction Program. The density of the collected ashes were as follows: 3.00 gm/cc for No. 6 fuel oil ash, 2.00 gm/cc for SRC Fuel and SRC Residual Fuel Oil ashes; and 2.44 gm/cc for SRC-Water Slurry ash. The SRC-Water Slurry ash contained higher amounts of sodium due to the surfactant LOMAR D, which was added to the fuel. The higher ESP inlet mass loading measured during the SRC-Water Slurry Test Series are the result of the LOMAR D. Table 15 presents the cumulative mass loading at the indicated size for each of the inlet data sets.

During the SRC-Water Slurry Test Program it was observed that the ash collected in the latter stages of the inlet impactors was a light buff color rather than the black color of the previous ashes. This ash had a high sodium content and indicated a high concentration of LOMAR D or LOMAR D ash.

The impactor fractional efficiency graphs indicate that the SRC Residual Fuel Oil ashes had the highest collection efficiency of particles above 5 microns but the lowest below one micron. The oil ash data indicated the lowest collection efficiency for particles above 5 μm which is most likely due to entrainment or sluffing of agglomerated particles in the ESP or ductwork, since the oil ash had the fewest number of particles above 5 μm . Of the SRC ashes produced, the ash from the SRC Residual Fuel Oil test had the smallest mass median diameter, 10.3 μm , and the lowest mass loading $\sim 0.18 \text{ lbs}/10^6 \text{ BTU}$.

5034-10

Figure 18. Cumulative mass loading versus particle diameter for SRC Fuel; November 18 – 19, 1982; ESP inlet and outlet.

5034-11

Figure 19. Cumulative percent versus particle diameter for SRC Fuel; November 18-19, 1982; ESP inlet and outlet.

5034-12

Figure 20. $dM/d\log D$ versus particle diameter for SRC Fuel; November 18 – 19, 1982; ESP inlet and outlet.

5034-13

Figure 21. $dN/dlogD$ versus particle diameter for SRC Fuel; November 18 – 19, 1982; ESP inlet and outlet.

PITTSBURGH ENERGY TECH. CENTER SRC STD. STA. FRACTIONAL EFFICIENCY

5034-18

Figure 22. Fractional efficiency curve for SRC Fuel; November 15 - 19, 1982.

5034-19

Figure 23. Cumulative mass loading versus particle diameter for SRC Residual Fuel Oil; December 13 - 17, 1982; ESP inlet and outlet.

PITTSBURGH ENERGY TECH CENTER RESIDUAL OIL INLET 12/13-17/82

5034-20

Figure 24. Cumulative percent versus particle diameter for SRC Residual Fuel Oil; December 13 - 17, 1982; ESP inlet and outlet.

PITTSBURGH ENERGY TECH CENTER RESIDUAL OIL INLET 12/13-17/82

5034-21

Figure 25. $dM/d\log D$ versus particle diameter for SRC Residual Fuel Oil; December 13 – 17, 1982; ESP inlet and outlet.

6034-22

Figure 26. $dN/dlogD$ versus particle diameter for SRC Residual Fuel Oil; December 13 – 17, 1982; ESP inlet and outlet.

PITTSBURGH ENERGY TECH. CENTER RESID OIL FRACTIONAL EFFICIENCY

Figure 27. Fraction efficiency curve for SRC Residual Fuel Oil; December 13 - 17, 1982.

PITTSBURGH ENERGY TECH CENTER SRC/WATER SLURRY INLET 1/11-14/83

Figure 28. Cumulative mass loading versus particle diameter for SRC-Water Slurry; January 11 – 14, 1983; ESP inlet.

PITTSBURGH ENERGY TECH CENTER SRC/WATER SLURRY INLET 1/11-14/83

5084-29

Figure 29. Cumulative percent versus particle diameter for SRC-Water Slurry; January 11 – 14, 1983; ESP inlet.

5034-31

Figure 30. $dM/d\log D$ versus particle diameter for SRC-Water Slurry; January 11 - 14, 1983; ESP inlet.

5034-30

Figure 31. $dN/d\log D$ versus particle diameter for SRC-Water Slurry; January 11 - 14, 1983; ESP inlet.

Table 15

Inlet Impactor Cumulative Mass Loadings at Indicated Sizes
For Steady-State Test Weeks

	Fuel			
	No. 6 fuel oil	SRC Fuel	SRC Residual Fuel Oil	SRC-Water Slurry
Total loading,				
gr/dscf	0.0230	0.3821	0.1007	0.5616
lb/10 ⁶ Btu	0.0359	0.7971	0.1782	0.9778
Particulate loading				
less than:				
8 μ m				
gr/dscf	0.0222	0.0592	0.0403	0.1516
lb/10 ⁶ Btu	0.0347	0.1235	0.0713	0.2640
5 μ m				
gr/dscf	0.0215	0.0344	0.0232	0.1039
lb/10 ⁶ Btu	0.0336	0.0718	0.0411	0.1809
2 μ m				
gr/dscf	0.0196	0.0218	0.0131	0.0753
lb/10 ⁶ Btu	0.0306	0.0455	0.0232	0.1311
1 μ m				
gr/dscf	0.0170	0.0164	0.008	0.0618
lb/10 ⁶ Btu	0.0266	0.0342	0.0142	0.1076
0.5 μ m				
gr/dscf	0.0138	0.0132	0.0056	0.0542
lb/10 ⁶ Btu	0.0216	0.0275	0.0099	0.0944
0.25 μ m				
gr/dscf	0.0115	0.0107	0.0047	0.0420
lb/10 ⁶ Btu	0.0180	0.0223	0.0083	0.0656
Inlet mass median diameter, μ m	0.25	21.8	10.3	17.8

2. Five-Stage Series Cyclones

The five-stage series cyclones were operated at the ESP inlet sampling location during each test series. Tables including the individual runs and calculated stage D_{50} 's and loadings are contained in Appendix B. The D_{50} , effective stage cut diameter, is assumed to be equal to the particle diameter for which the stage collection efficiency is 50%. The cyclones, during the No. 6 fuel oil test, had to be operated without a backup filter in order that samples of the particulate above $\sim 0.2 \mu\text{m}$ could be obtained. When the cyclones were operated with a backup filter during the No. 6 fuel oil test, the system pressure drop was too great to maintain an isokinetic flow-rate through the cyclones. The cyclone data from the No. 6 fuel oil test was compared on a daily basis with the impactor data and fit to the impactor loadings by assuming the differences were due to that particulate below the last stage cyclone D_{50} .

Figure 32 presents the cumulative mass loading vs. particle diameter for each of the cyclone data sets and the "corrected" cumulative curve for the No. 6 fuel oil data set. Figure 33 presents these data on a cumulative mass percent less than indicated size. Each data set from the cyclones was compared on a cumulative mass percent basis with the impactors and Figures 34 through 37 present these comparisons. The fair agreement obtained between the cyclone and impactor distributions is considered to be reasonable.

Table 16 presents the total mass loadings from the cyclones and impactors. The comparisons are very good considering the run times were considerably different:

5031 33

Figure 32. Cumulative mass loading versus particle diameter for Five-Stage Series Cyclones.

Figure 33. Cumulative mass percent less than indicated size for Five-Stage Series Cyclones.

5034-43

Figure 34. Cumulative mass percent less than indicated size; inlet impactors and cyclones; No. 6 fuel oil.

5034-35

Figure 35. Cumulative mass percent less than indicated sizes inlet impactors and cyclones; SRC Fuel.

6034-36

Figure 36. Cumulative mass percent less than indicated size; inlet impactors and cyclones; SRC Residual Fuel Oil.

5034-38

Figure 37. Cumulative mass percent less than indicated size; inlet impactors and cyclones; SRC-Water Slurry.

Table 16
Inlet Mass Loadings
Cyclone and Impactor Comparisons

	Cyclone		Impactor	
	<u>qr/SCF</u>	<u>lbs/10⁶ Btu</u>	<u>qr/SCF</u>	<u>lbs/10⁶ Btu</u>
No. 6 Fuel Oil*	0.0230	0.0359	0.0230	0.0359
SRC Fuel	0.4230	0.8824	0.3821	0.7971
SRC Residual Fuel Oil	0.1155	0.2044	0.1007	0.1782
SRC-Water Slurry	0.4205	0.7321	0.5616	0.9778

*Cyclone total loading assigned that of impactors.

	Run Time, Minutes	
	<u>Impactors</u>	<u>Cyclones</u>
No. 6 Fuel Oil	64	430
SRC Fuel	6	90
SRC Residual Fuel Oil	12	160
SRC-Water Slurry	6	90

The cyclone data in Table 16 show that the pulverized SRC Fuel and SRC-Water Slurry fuels produce close to the same mass loading, whereas the SRC Residual Fuel Oil fuel produced only about one third as much total mass loading as the other SRC fuels. Figures 32 and 33 show that although the SRC Residual Fuel Oil produced one third the total mass loading, as the SRC Fuel and SRC-Water Slurry fuels, it produced 100 percent more 11 μ m particulate, on a cumulative percentage basis, than the SRC Fuel and 40 percent more 11 μ m particulate than the SRC-Water Slurry fuel.

3. Ultrafine Sampling System

The UFSS obtained data at the inlet and outlet sampling locations during each test series with the exception of outlet data during the SRC-Water Slurry test. These results are presented as differential size distributions in Figures 38 through 41. The impactor data are also plotted with Electrical Aerosol Analyzer (EAA) and Climet Optical Particle Counter data. The EAA and the impactor data agree fairly well in their overlap regions considering the differences in the sizing techniques. However, the optical data compare poorly with the impactor data. Possible reasons for these differences include line losses and losses in the dilution system. Figure 42 presents the fractional efficiency data for the UFSS and impactors where available. These data from the EAA were used along with the impactor size distribution to provide a size distribution for the mathematical model of electrostatic precipitation.

5034-40

Figure 38. Differential particle-size distribution, inlet and outlet, No. 6 fuel oil test.

Figure 39. Differential particle-size distribution, inlet and outlet, SRC Fuel test.

5034-41

Figure 40. Differential particle-size distribution, inlet and outlet, SRC Residual Fuel Oil test.

5034-89

Figure 41. Differential particle-size distribution, inlet SRC-Water Slurry test.

Figure 42. Fractional efficiency for PETC Test Series.

4. Large Particle Sizing

The Large Particle Sizing System (LPSS) was included in the test program at PETC to try and quantify any differences that might exist in the rapping emissions of the various ashes produced from the 700 horsepower boiler. In order to evaluate the particulate and ESP performance characteristics at PETC, time did not allow data to be gathered under full-scale rapping sequences. The plan for gathering data on rapping was that the LPSS would gather data at the outlet during raps which occurred after approximately two hours of ESP steady-state operation without rapping. This two hour period of ESP operation without rapping was established in order that the other sampling systems (mass train and impactor) could obtain data to evaluate the ESP performance and particulate generated by the fuel used.

After the period of non-rapping, when the mass trains and impactors were not sampling, the plate rappers, which were 8 lb. hammers, were activated for one minute each, beginning with the third or outlet field and then continuing to the second field plate rappers after the third field plate rappers had been turned off and then to the first field plate rappers. Once the first field plate rappers had been turned off then the wire vibrators were activated for fifteen seconds each beginning with the third field and continuing to the first field.

The LPSS developed electronic problems during the preliminary week of the No. 6 fuel oil test and a problem with the dilution system occurred during the SRC Residual Fuel Oil test. Due to the problems encountered with the LPSS, data were only obtained during the SRC Fuel test series.

Figures 43 and 44 present samples of the data produced with the LPSS on a relative concentration per particle size band basis

Figure 43. Relative concentration per particle size bands versus time from LPSS during SRC Fuel test; ESP outlet, 1.94-9.3 μm .

Figure 44. Relative concentration per particle size bands versus time from LPSS during SRC Fuel test; ESP outlet, 9.27-35 μm .

versus time. The data for each size band has been normalized to the maximum concentration in that size band during the sampling period (one plate rap and one vibrator sequence). Comparisons of absolute concentrations for different sizes were not possible due to non-linear dilution, particle counting coincidence losses and probe losses.

B. Resistivity

Southern Research Institute's point-to-plane in-situ resistivity probe was operated at the ESP inlet sampling location during each test series. When fly ash, with a high carbon content, is collected in the resistivity probe, it is usually impossible to obtain a meaningful number for ash resistivity. During the test at PETC, all of the fuels produced very high carbon content particulate. The only fuel which produced an ash where reasonable data were obtained with the resistivity probe was the No. 6 fuel oil. The data from the resistivity measurements suggested that the ash which the probe collected during the No. 6 fuel oil test had a resistivity of about 1×10^9 ohm·cm at $\sim 350^\circ\text{F}$.

All the other measurements on the three other SRC fuels indicated that the resistivity of the particulate collected in the resistivity probe was less than 10^9 ohm·cm. The particulate produced from the SRC fuels contained high percentages of carbon and contributed to electrical grounds, within the collection area of the probe, due to its low resistance.

C. Gas Analysis

WFI Sciences gas analysis data for O_2 , CO_2 , and H_2O were used for the impactor and cyclone data reduction. SORI obtained sulfur dioxide and sulfur trioxide data at sampling locations 1, 3 and 4

for each fuel with the exception of location 4 during the SRC-Water Slurry test.

Tables 17 through 20 present the SO_2 and SO_3 data from the indicated fuels. The lower concentrations of SO_3 and SO_2 data at the ESP outlets vs. those at the inlet are probably due to inleakage of the insulator purge system, which caused dilution and cooling of the flue gas and therefore condensation of H_2SO_4 . The SO_3 data do not indicate much, if any, uptake of SO_3 on the particulate from the gas cooler inlet to the ESP inlet. There may be some indication of H_2SO_4 uptake on the ash during the SRC Residual Fuel Oil test from the gas cooler inlet to the ESP inlet. However, there is also an indication of higher SO_2 during 12/16/82 where sampling was done at the flue gas cooler inlet, which indicates there may have been a slight change in sulfur content of the fuel supply.

The absence of SO_3 , and the higher SO_2 values, during the SRC-Water Slurry test series, may be due to the high sodium Lomar D additive which was added to the SRC-Water Slurry fuel.

D. Chemical Analysis

1. Fuel

Samples of each fuel as fired were obtained and sent to local laboratories for analysis. The analysis of the No. 6 fuel oil samples from Commercial Testing and Engineering Co. (CT&E) are presented as Table 21. There was some concern expressed that the BTU/lb values CT&E obtained were in error. However, when asked to repeat the analysis on the unused sample portion, it was discovered that CT&E no longer had the sample. Analysis by others on the No. 6 fuel oil are contained in the PETC report pertaining to these test series.

Table 17. No. 6 Fuel Oil Test,
SO₂ and SO₃ Measurements

<u>Date</u>	<u>Location</u>	<u>Time</u>	<u>Flue Gas</u> <u>°F</u>	<u>ppm v/v^a</u>	
				<u>H₂SO₄</u>	<u>SO₂</u>
8/30/82	ESP Inlet	1117-1151	330	1.2	395
		1318-1351	337	1.5	395
		1415-1445	342	1.2	375
		1540-1604	344	1.5	410
8/31/82	ESP Inlet	0828-0853	338	1.8	395
		0940-1010	340	1.6	355
		1152-1218	342+338 ^b	1.3	350
		1548-1614	358	1.0	310
		1700-1725	362	1.2	320
9/1/82	Gas Cooler Inlet	0845-0905	548	0.90	325
		0930-0952	548	1.0	325
		1200-1225	563	0.80	290
		1247-1306	565	1.2	300
		1627-1649	586+579 ^b	1.5	310
		1704-1721	583+497 ^b	1.4	295
9/2/82	ESP Outlet	0902-0923	299	0.26	275
		0955-1021	299	0.22	250
		1210-1233	302	0.27	280
		1317-1336	306	0.35	270
		1455-1515	308	0.44	285
9/3/82	ESP Outlet	0707-0728	303	0.19	290
		0815-0838	301	0.23	290
		0934-0956	305	0.30	295
		1038-1100	309	0.35	295
		1148-1214	313	0.37	285
		1330-1352	321	0.41	300

a. Volume per volume basis.

b. Flue gas temperatures varied during run.

Table 18. SRC Fuel Test,
SO₂ and SO₃ Measurements

<u>Date</u>	<u>Location</u>	<u>Time</u>	<u>Flue Gas °F</u>	<u>ppm v/v^a</u>	
				<u>H₂SO₄</u>	<u>SO₂</u>
11/15/82	ESP Inlet	0940-1005	293	1.4	410
		1030-1056	292	1.9	430
		1754-1820	293	2.8	450
		1900-1926	295	3.8	445
11/16/82	ESP Inlet	0851-0910	292	2.0	460
		0928-0948	292	2.5	450
		1014-1037	292	2.7	415
		1633-1657	294	3.0	440
		1845-1908	293	3.5	425
		1950-2015	290	2.8	445
11/17/82	ESP Inlet	0843-0905	290	2.0	425
		0945-1007	291	2.5	425
	Gas Cooler Inlet	1436-1458	505+510 ^b	3.4	445
		1548-1612	510	3.4	445
11/18/82	Gas Cooler Inlet	1427-1448	515	3.3	455
		1526-1548	517	3.1	435
		1657-1718	520+525 ^b	3.8	440
		1806-1830	527	3.2	425
11/19/82	ESP Outlet	0858-0930	234	0.31	320
		1010-1038	236	0.19	315
		1247-1315	240	0.16	340
		1415-1440	242	0.15	335
		1650-1715	242	0.16	330

a. Volume per volume basis.

b. Flue gas temperatures varied during run.

Table 19. SRC Residual Fuel Oil Test,
SO₂ and SO₃ Measurements

<u>Date</u>	<u>Location</u>	<u>Time</u>	<u>Flue Gas</u> °F	ppm v/v ^a	
				<u>H₂SO₄</u>	<u>SO₂</u>
12/13/82	ESP Inlet	1100-1122	296	0.58	315
		1220-1245	294	0.66	330
		1418-1442	295	0.71	335
		1527-1550	298	0.77	335
12/14/82	ESP Inlet	0918-0940	290	0.68	320
		1002-1024	290	0.49	295
		1103-1124	292	0.59	295
		1300-1324	292	0.62	305
		1426-1450	295	0.62	305
12/15/82	ESP Inlet	0857-0920	292+304+287 ^b	0.84	285
		1003-1024	285+297 ^b	0.76	285
		1202-1226	297+291 ^b	0.70	305
		1253-1316	292	0.62	285
		1432-1455	293	0.72	295
12/16/82	Gas Cooler Inlet	0842-0904	470	0.91	325
		0938-1002	472	1.1	330
		1115-1138	474	1.4	330
		1225-1247	476	1.4	330
		1348-1412	474	1.5	340
12/17/82	ESP Outlet	0915-0943	254	0.29	290
		1014-1040	257	0.25	285
		1200-1225	256	0.27	280
		1243-1307	254	0.28	275
		1424-1450	256	0.26	290
		1530-1556	256	0.26	290

a. Volume per volume basis.

b. Flue gas temperatures varied during run.

Table 20. SRC-Water Slurry Test,
SO₂ and SO₃ Measurements

<u>Date</u>	<u>Location</u>	<u>Time</u>	<u>Flue Gas</u> <u>°F</u>	<u>ppm v/v^a</u>	
				<u>H₂SO₄</u>	<u>SO₂</u>
1/11/83	ESP Inlet	0903-0929	292	<0.1	570
		1006-1033	294	<0.1	560
		1147-1215	292	<0.1	575
		1247-1313	296	<0.1	565
1/12/83	ESP Inlet	0926-0950	291	<0.1	555
		1009-1032	293	<0.1	530
		1207-1232	294	<0.1	555
		1311-1338	289	<0.1	555
1/13/83	Gas Cooler Inlet	0815-0843	484	<0.1	535
		0911-0939	488	<0.1	545
		1056-1122	490	<0.1	555
		1156-1222	493	<0.1	535
1/14/83	ESP Inlet	0837-0901	292	<0.1	520
		0925-0954	291	<0.1	505
		1115-1140	292	<0.1	525
		1225-1250	294	<0.1	500

a. Volume per volume basis.

Table 21. No. 6 Fuel Oil Analysis,
Dry Basis

Date	8/30/82	9/2/82
% Carbon	84.31	84.20
% Hydrogen	11.00	11.23
% Nitrogen	0.34	0.43
% Chlorine	0.03	0.02
% Sulfur	1.20	0.85
% Ash	0.16	0.16
% Oxygen (by difference)	2.96	3.11
% Fixed Carbon	5.34	4.10
% Volatile	94.50	95.74
Btu/lb.	21743	21865

Table 22. Analysis of SRC Fuels
Wet Basis

Fuel	SRC Fuel	SRC Residual Fuel Oil	SRC-Water Slurry
Date	11/17/82	12/15/82	1/11/83
% Moisture	0.42	-	47.51
% Hydrogen	6.28	6.17	2.64
% Nitrogen	1.89	1.23	0.97
% Sulfur	1.19	1.22	0.66
% Ash	0.17	0.03	0.36
% Fixed Carbon	49.58	39.88	25.79
% Volatile	49.83	60.09	26.34
Btu/lb.	15414	16652	8253

Samples of the other fuels are presented as Table 22. The reports from the independent laboratories are included in Appendix B of this report.

2. Collected Ash

Various samples of ash which were collected at different points along the flue gas duct by SoRI, WFI Sciences and WFI personnel were analyzed at SoRI. These analyses included: loss on ignition (LOI) determinations; carbon, hydrogen and nitrogen (CHN) determinations; elemental analysis; and total organic analysis.

Loss on ignition (LOI) of the ash samples was determined in accordance with ASTM specifications at 750°C. The carbon, hydrogen and nitrogen content of ash samples was obtained using a Perkin Elmer Model 240 CHN analyzer. Typical sample weights are 1.5 to 3.0 mg for CHN analyses.

Total organic analyses were performed on one ESP inlet mass train filter and one baghouse (Pulse Jet) ash sample from each of the SRC tests. Each sample was extracted for 24 hours with 150 ml of methylene chloride in a Soxhlet extractor. The methylene chloride was then concentrated as a final volume of 10 ml in a Kuderna-Danish evaporator. A 9 ml aliquot was evaporated to dryness to obtain a residue weight. The remaining 1 ml was retained for a gas chromatographic analysis. As shown in Table 23 the total organic content of the ashes was negligible. Furthermore, what little residue was extracted appeared to be inorganic rather than organic in composition. An infrared scan of the residues gave spectra suggesting a complex silicate.

Elemental analysis of ash samples was performed on ignited ash samples for their major components according to standard procedures used by SoRI. Three methods of attack were used to

Table 23. Total Organic Analysis for SRC Ashes

<u>Sample</u>	<u>wt % Extractable Residue</u>
ESP Inlet Mass Train Filters	
- EI-16; 11/19/82 - SRC Fuel	0.86
EI-31; 12/15/82 - SRC Residual Fuel Oil	0.59
EI-50; 1/12/83 - SRC-Water Slurry Fuel	0.13
Baghouse Ash	
SRC Fuel	0.37
SRC Residual Fuel Oil	0.25
SRC-Water Slurry	0.18

bring the ashes into solution: (1) a sodium carbonate fusion for SO_3 , (2) a sodium hydroxide fusion for Al_2O_3 and SiO_2 , and (3) a sulfuric, hydrofluoric and nitric acid digestion for the remaining elements. The SO_3 analysis was by ion chromatography, the P_2O_5 and SiO_2 by colorimetry and the other elements by atomic absorption, or emission spectroscopy. Al_2O_3 is generally determined by colorimetry; however, this procedure could not be used for these samples because of interference from the high levels of titanium. Rather than trying to remove this interference, an atomic adsorption procedure for this analysis was evaluated. This procedure compared favorably with the colorimetric procedure with a National Bureau of Standards (NBS) ash and several "normal" ashes. Several SRC samples were then analyzed by the method of standard additions to insure that no interference problems existed with these samples. Since none were observed, the atomic absorption analysis for all SRC ashes was used.

Table 24 presents the chemical analysis data from the ashes obtained while No. 6 fuel oil was fired. During the elemental analysis work-up of the No. 6 fuel and ashes, samples were observed with a Scanning Electron Microscope with an X-ray Emission Spectrometer (XES) on ESP third field ashes which were ignited and unignited. The XES indicated a significant decrease in the sulfur content of the ash after ignition. Since enough ash from the third field was not available for soluble SO_4 = determinations, a sample of the second field ESP ash was analyzed. This unignited ash sample contained 20.6 wt% SO_4 = whereas the ignited ash contained 10.7 wt% SO_3 , equivalent to 12.8 wt% in SO_4 =. It appears that the unignited ash contained about 8 wt% of H_2SO_4 and this would account for some of the discrepancy between the LOI (23.6 wt%) and carbon content (9.3 wt%), (Table 24), of this sample and, presumably, the other samples as well.

Table 24. Chemical Analysis of No. 6
Fuel Oil Ashes

LOI and CHN Determinations

<u>Sample</u>	<u>wt. %</u>			
	<u>LOI</u>	<u>C</u>	<u>H</u>	<u>N</u>
8/30-9/1/82 Cyclone composite #2-4				
Stage 1	-	8.6	0.84	0.20
2	-	6.6	0.63	0.24
3	-	5.8	0.67	<0.1
4	-	3.8	0.90	<0.1
5	-	3.4	1.8	<0.1
9/2-9/3/82 Cyclone #5	15.8	-	-	-
Composite of all stages				
9/1 ESP 1st field leading edge	27.7	13.4	0.66	<0.1
ESP 2nd field leading edge	23.6	9.3	0.59	<0.1
ESP 3rd field leading edge	30.3	11.5	0.79	<0.1

Elemental Analysis

<u>Element, as oxide</u>	<u>wt. %</u>			
	<u>ESP 1st Field</u>	<u>ESP 2nd Field</u>	<u>ESP 3rd Field</u>	<u>Cyclone #5¹ Composite</u>
Li ₂ O	0.03	0.03	0.03	0.02
Na ₂ O	5.1	6.6	2.9	4.3
K ₂ O	0.90	0.63	1.4	0.48
CaO	9.1	9.8	5.9	12.6
MgO	2.2	2.4	1.4	2.3
Fe ₂ O ₃	31.3	25.9	37.5	27.9
TiO ₂	0.6	0.4	1.0	0.8
V ₂ O ₅	2.6	3.5	1.6	2.3
ZnO	3.4	3.9	1.7	2.6
Al ₂ O ₃	10.2	7.3	11.9	9.7
SiO ₂	16.5	10.8	19.3	13.6
P ₂ O ₅	11.5	15.1	8.2	11.6
SO ₃	6.9	10.7	3.3	9.2

1. All stages composited into a single sample for analysis.

Table 25 contains the chemical analysis of the ashes collected during the pulverized SRC Fuel test and Tables 26 and 27 contain these data for the SRC Residual Fuel Oil and SRC-Water Slurry tests, respectively. The coarse fraction of ash in Table 26 was obtained from the 55 gal. drum which was used to store the ESP hopper ash after it had been removed from the hoppers by vacuum. The finer fraction was obtained from the vacuum cleaner which was in series with the 55 gal. drum.

E. Scanning Electron Microscope Photographs

Selected samples of ashes obtained with the five-stage series cyclone and impactors were submitted for Scanning Electron Microscope (SEM) photographs. Figures 45 through 65 present the photographs which were taken to compare the calculated size of the particulate with that which was collected on the indicated stages, as well as to look at the physical appearance of the particulate. In general the larger particulate from all the SRC fuels appears to be hollow spheres which is indicative of carbon. For the SRC ashes it appears that past the third stage of the impactors (inlet) $< \sim 4 \mu\text{m}$, to the sixth stage, $\sim 1.2 \mu\text{m}$, the majority of the particulate collected is angular.

The photographs where the particulate appears to be stuck together with glue (e.g. Figure 57) can be explained by the presence of grease which was used to coat the collection stages of the University of Washington cascade impactors to reduce reentrainment and/or particle bounce. Some of the photographs exhibit probable reentrainment since some particles in the field of view are obviously larger than the calculated stage D_{50} . One obvious example can be seen on the backup filter from the SRC Residual Fuel Oil test series, Figure 58.

Table 25. Chemical Analysis of SRC Fuel Ashes

LOI and CHN Determinations		wt. %			
Sample		LOI	C	H	N
11/15/82 Cyclone, Stage	1		91.6	0.55	1.5
	2		77.0	0.48	1.1
	3		59.6	0.63	1.0
	4		39.0	0.58	1.0
	5		23.1	0.98	0.50
11/16/82 Cyclone Composite			20.6	0.17	0.33
11/17/82 Cyclone, Stage	1		91.5	0.53	1.4
	2		42.5	0.42	0.90
	3		45.7	0.58	0.49
	4		42.8	0.75	0.53
	5		27.4	1.1	0.69
11/18/82 Cyclone, Stage	1		74.4	0.42	1.2
	2		69.5	0.42	0.58
	3		47.7	0.48	0.49
	4		26.6	0.62	0.29
	5		11.0	1.2	0.13
11/19/82 Cyclone, Stage	1		9.7	0.13	0.22
	2		51.9	0.30	0.32
	3		43.3	0.41	0.38
	4		21.9	0.58	0.31
	5		9.0	0.92	0.18
SRC Fuel ESP Ash, Field	1	87.6	27.7	0.68	0.22
	2	77.8	83.1	0.85	1.2
	3	86.9	76.9	0.87	1.1
SRC Fuel Baghouse Ash		86.9	15.7	0.30	0.41
SRC Fuel Composite of Mass Train Filters - EI-14, 15, 18 and 19		71.0	23.3	0.32	0.86

Table 25. Chemical Analysis of SRC Fuel Ashes (Cont'd)

Elemental Analyses	wt. %					
	ESP Field 1	ESP Field 2	ESP Field 3	Bag- House	Mass ¹ Train Composite	Cyclone ² Composite
Li ₂ O	0.02	0.02	0.02	0.01	0.01	0.01
Na ₂ O	11.1	8.3	5.0	10.3	10.8	5.2
K ₂ O	1.0	0.98	1.2	0.96	1.0	0.62
CaO	3.9	2.8	3.9	3.1	3.0	3.3
MgO	1.0	0.73	0.82	0.83	0.79	0.87
Fe ₂ O ₃	21.2	40.6	31.7	17.8	16.1	24.1
V ₂ O ₅	-	-	-	1.1	-	1.2
ZnO	-	-	-	0.19	-	0.22
TiO ₂	12.5	10.7	10.3	16.0	20.4	19.2
Al ₂ O ₃	13.4	9.2	13.7	14.3	13.7	14.2
SiO ₂	23.8	15.0	22.8	22.1	21.5	21.6
P ₂ O ₅	0.60	0.90	1.2	0.39	0.28	0.47
SO ₃	10.7	7.4	8.5	12.8	6.8	8.8
TOTAL	99.2	96.6	99.1	99.8	94.4	99.8

1. Composite of EI-14, 15, 18 and 19 mass train runs.

2. Composite of all cyclone stages of 11/15, 16, 17, 18 and 19/82 - LOI = 92.7 wt. %.

Table 26. Chemical Analysis of SRC Residual Fuel Oil Ashes

LOI and CHN Determinations		wt. %			
<u>Sample</u>		<u>LOI</u>	<u>C</u>	<u>H</u>	<u>N</u>
12/13/82 Cyclone, Stage	1		36.1	0.29	0.29
	2		75.4	0.35	0.52
	3		34.1	0.37	0.58
	4		25.4	0.57	0.16
	5		15.4	1.4	0.00
12/14/82 Cyclone, Stage	1		27.1	0.09	0.37
	2		26.3	0.17	0.34
	3		45.7	0.32	0.50
	4		35.1	0.50	0.42
	5		17.1	1.5	0.65
12/15/82 Cyclone, Stage	1		18.0	0.12	0.15
	2		46.4	0.29	0.48
	3		36.3	0.48	0.58
	4		63.8	0.72	0.95
	5		9.5	0.88	0.38
12/16/82 Cyclone, Stage	1		22.3	0.09	0.31
	2		96.6	0.44	1.1
	3		32.6	0.40	0.39
	4		31.1	0.70	0.60
	5		11.8	0.92	0.38
12/17/82 Cyclone, Stage	1		89.5	0.33	1.3
	2		39.8	0.25	0.50
	3		38.1	0.36	0.47
	4		48.8	0.53	0.51
	5		11.9	0.82	0.36
SRC Residual Fuel Oil Ash - ESP					
Coarse Fraction Field 1		61.7	65.3	0.69	0.57
Fine Fraction Field 1		84.2	53.7	0.55	0.63
Coarse Fraction Field 2		82.5	55.5	0.43	0.65
Fine Fraction Field 2		85.4	63.0	0.69	1.0
SRC Residual Fuel Oil Baghouse Ash		86.7	32.8	0.30	0.52
All Mass Train Composites		84.5	33.8	0.28	0.78

Table 26. Chemical Analysis of SRC Residual Fuel Oil Ashes (Cont'd)

Elemental Analyses	wt. %						
	ESP Field 1		ESP Field 2		Baghouse	Mass Train Composites	Cyclone ² Composites
Element as Oxide	Coarse	Fine	Coarse	Fine			
Li ₂ O	0.02	0.02	0.02	0.02	0.01	0.02	0.02
Na ₂ O	3.7	7.2	9.1	7.8	4.4	8.4	6.1
K ₂ O	0.63	0.79	0.82	0.87	0.54	0.78	0.62
CaO	1.5	2.2	2.6	2.8	2.1	2.1	2.5
MgO	0.52	0.77	0.83	0.99	0.62	0.83	0.98
Fe ₂ O ₃	60.8	35.5	25.0	26.8	46.7	17.4	17.2
V ₂ O ₅	-	-	-	-	0.87	-	1.4
ZnO	-	-	-	-	0.21	-	0.12
TiO ₂	8.4	13.4	23.4	16.3	12.3	20.5	25.4
Al ₂ O ₃	7.6	12.5	13.4	13.5	11.1	15.6	17.0
SiO ₂	10.8	17.9	15.7	19.3	15.0	16.8	22.1
P ₂ O ₅	0.64	0.62	0.62	0.63	0.71	0.44	0.38
SO ₃	6.0	8.5	8.1	10.2	4.0	11.4	6.1
TOTAL	100.6	99.4	99.6	99.2	98.6	94.3	99.9

1. Composite of all inlet mass train thimble samples.

2. Composite of all cyclone stages for all runs. LOI = 88.6 wt. %.

Table 27. Chemical Analysis of SRC-Water Slurry Ashes

LOI and CHN Determinations		wt. %			
Sample		LOI	C	H	N
1/11/83 Cyclone, Stage	1	-	31.9	0.26	0.60
	2		74.9	0.45	0.90
	3		28.9	0.32	0.25
	4		17.8	0.28	0.00
	5		3.4	0.12	0.36
1/12/83 Cyclone, Stage	1		30.3	0.23	0.50
	2		43.9	0.32	0.57
	3		29.1	0.26	0.38
	4		16.3	0.40	0.12
	5		1.6	0.07	0.00
1/13/83 Cyclone, Stage	1		24.7	0.22	0.61
	2		51.4	0.32	0.97
	3		33.5	0.29	0.62
	4		17.7	0.26	0.12
	5		0.97	0.06	0.00
1/14/83 Cyclone, Stage	1		13.7	0.11	0.12
	2		92.4	0.46	1.3
	3		32.2	0.24	0.21
	4		15.8	0.19	0.12
	5		1.4	0.05	0.01
SRC-Water Slurry Baghouse		72.3	67.5	0.47	1.4
Mass Trains - ET-47, 49, 51, 52, 53, 54 and 57 Thimbles		69.1	50.8	0.40	1.1
ESP Ash					
Leading Edge Field 1		82.5	15.4	0.38	0.34
Trailing Edge Field 2		58.5	53.6	0.61	0.85
Leading Edge Field 3		54.5	44.6	1.3	0.54

Table 27. Chemical Analysis of SRC-Water Slurry Ashes (Cont'd)

Elemental Analyses	wt. %					
	ESP Field 1	ESP Field 2	ESP Field 3	Baq- House	Mass ¹ Train Composite	Cyclone ² Composite
Li ₂ O	0.02	0.01	0.02	0.02	0.02	0.02
Na ₂ O	13.5	21.6	24.4	25.3	21.9	16.9
K ₂ O	0.86	0.74	0.81	0.75	0.95	0.80
CaO	3.6	2.3	2.0	2.4	2.9	3.7
MgO	0.62	0.47	0.41	0.48	0.52	0.69
Fe ₂ O ₃	26.9	23.3	17.8	8.9	9.8	12.5
TiO ₂	5.9	5.5	6.4	7.5	6.5	7.1
V ₂ O ₅	-	-	-	0.48	-	0.41
ZnO	-	-	-	0.07	-	0.07
Al ₂ O ₃	10.9	8.0	6.6	8.0	9.6	10.8
SiO ₂	25.7	14.3	11.6	15.2	20.0	26.4
P ₂ O ₅	0.30	0.29	0.26	0.17	0.17	0.20
SO ₃	12.9	24.4	28.6	29.8	27.0	21.6
TOTAL	101.2	100.9	98.9	99.1	99.4	101.2

1. Composite of mass train thimbles EI-47, 49, 51, 52, 53, 54 and 57.

2. Composite of all cyclone stages on 1/11, 12, 13 and 14/83.
LOI = 72.9%.

Figure 45. Five-Stage Cyclone Samples: Cyclone Stage 1: PETC-SRC Test Program.

Figure 46. Five-Stage Cyclone Samples: Cyclone Stage 2: PETC-SRC Test Program.

Figure 47. Five-Stage Cyclone Samples: Cyclone Stage 3: PETC-SRC Test Program.

Figure 48. Five-Stage Cyclone Samples: Cyclone Stage 4: PETC-SRC Test Program.

5034-56

Figure 49. Five-Stage Cyclone Samples: Cyclone Stage 5: PETC-SRC Test Program.

NO ASH

NO. 6 FUEL OIL
9/1/82

$D_{50} =$

SRC FUEL
11/18/82

$D_{50} = > 12 \mu\text{m}$

SRC RESIDUAL FUEL OIL
12/15/82

$D_{50} = > 11 \mu\text{m}$

SRC-WATER SLURRY
1/11/83

$D_{50} = > 10 \mu\text{m}$

5024-57

Figure 50. Inlet Impactor Precollector Samples: PETC-SRC Test Program.

NO ASH

NO. 6 FUEL OIL
9/1/82

$D_{50} =$

SRC FUEL
11/18/82

$D_{50} = 11.58 \mu\text{m}$

SRC RESIDUAL FUEL OIL
12/15/82

$D_{50} = 11.52 \mu\text{m}$

SRC-WATER SLURRY
1/11/83

$D_{50} = 10.08 \mu\text{m}$

5034-58

Figure 51. Inlet Impactor Stage 1 Samples: PETC-SRC Test Program.

NO ASH

NO. 6 FUEL OIL
9/1/82

$D_{50} =$

SRC FUEL
11/18/82

$D_{50} \approx 5.12 \mu\text{m}$

SRC RESIDUAL FUEL OIL
12/15/82

$D_{50} \approx 5.10 \mu\text{m}$

SRC-WATER SLURRY
1/11/83

$D_{50} \approx 4.45 \mu\text{m}$

5034-59

Figure 52. Inlet Impactor Stage 2 Samples: PETC-SRC Test Program.

Figure 53. Inlet Impactor Stage 3 Samples: PETC-SRC Test Program.

NO. 6 FUEL OIL
9/1/82

$D_{50} = 1.62 \mu\text{m}$

SRC FUEL
11/18/82

$D_{50} = 2.35 \mu\text{m}$

SRC RESIDUAL FUEL OIL
12/15/82

$D_{50} = 2.54 \mu\text{m}$

SRC-WATER SLURRY
1/11/83

$D_{50} = 2.21 \mu\text{m}$

5034-61

Figure 54. Inlet Impactor Stage 4 Samples: PETC-SRC Test Program.

NO. 6 FUEL OIL
9/1/82

$D_{50} = 0.87 \mu\text{m}$

SRC FUEL
11/18/82

$D_{50} = 1.37 \mu\text{m}$

SRC RESIDUAL FUEL OIL
12/15/82

$D_{50} = 1.42 \mu\text{m}$

SRC-WATER SLURRY
1/11/83

$D_{50} = 1.22 \mu\text{m}$

5034-62

Figure 55. Inlet Impactor Stage 5 Samples: PETC-SRC Test Program.

Figure 56. Inlet Impactor Stage 6 Samples: PETC-SRC Test Program.

NO. 6 FUEL OIL
9/1/82

$D_{50} = 0.19 \mu\text{m}$

SRC FUEL
11/18/82

$D_{50} = 0.33 \mu\text{m}$

SRC RESIDUAL FUEL OIL
12/15/82

$D_{50} = 0.39 \mu\text{m}$

SRC-WATER SLURRY
1/11/83

$D_{50} = 0.32 \mu\text{m}$

5034-64

Figure 57. Inlet Impactor Stage 7 Samples: PETC-SRC Test Program.

NO FILTER

NO. 6 FUEL OIL
9/1/82

$D_{50} = < 0.19 \mu\text{m}$

SRC FUEL
11/18/82

$D_{50} = < 0.33 \mu\text{m}$

SRC RESIDUAL FUEL OIL
12/15/82

$D_{50} = < 0.39 \mu\text{m}$

SRC-WATER SLURRY
1/11/83

$D_{50} = < 0.32 \mu\text{m}$

5034-65

Figure 58. Inlet Impactor Backup Filter Samples: PETC-SRC Test Program.

Figure 59. Outlet Impactor Samples: PETC-SRC Test Program. A - Precollector Sample; B - Precollector Sample; C - Stage 1 Sample; D - Stage 2 Sample.

5034-67

Figure 60. Outlet Impactor Stage 3 Samples: PETC-SRC Test Program.

5034-68

Figure 61. Outlet Impactor Stage 4 Samples: PETC-SRC Test Program.

NO. 6 FUEL OIL
8/30/82

$D_{50} = 0.93 \mu\text{m}$

SRC FUEL
11/19/82

$D_{50} = 1.37 \mu\text{m}$

SRC RESIDUAL FUEL OIL
12/15/82

$D_{50} = 1.31 \mu\text{m}$

5034-69

Figure 62. Outlet Impactor Stage 5 Samples: PETC-SRC Test Program.

5034-69

Figure 63. Outlet Impactor Stage 6 Samples: PETC-SRC Test Program.

5034-70

Figure 64. Outlet Impactor Stage 7 Samples: PETC-SRC Test Program.

Figure 65. Outlet Impactor Backup Filter Samples: PETC-SRC Test Program.

The SEM photographs are generally representative of the particulate collected. In some cases, such as in Figure 58 - SRC Residual Fuel Oil, the operator took photographs of obviously interesting objects.

F. Pilot Precipitator Operations

The pilot ESP was monitored by WFI personnel during all tests. The ESP performed very well with the exception of insulator fouling problems which occurred during the SRC fuels. On occasion after a test day was completed the insulators had to be manually cleaned in order that the secondary voltages could be maintained for the following day's test program. The ESP operating conditions are reported in WFI's report, but Table 28 presents the average operating conditions of the ESP for the different test series.

Figures 66 through 68 present voltage current curves from transformer rectifiers 1 through 3 respectively. Figures 69 through 71 present secondary voltage waveforms obtained with calibrated voltage dividers on a Nicolet digital storage oscilloscope. The waveform figures contain corona start (voltage at noticeable current flow) and maximum voltage before sparking or maximum T-R voltage. The secondary voltage data from the No. 6 fuel oil test indicated no electrical problems for the ESP. The V-I curves indicate that the ESP could have been operated at a much higher current density than the selected operating points. However, the operating points were established at ~ 10 mA secondary current to be representative of operating conditions for a full-scale unit.

Figures 72 through 74 present the V-I curves for the pulverized SRC Fuel test series. They also indicated no operational problems with the ESP power supplies.

Table 28. ESP Average Operating Conditions During Steady-State Test Weeks

CONDITION	No. 6 Fuel Oil	SRC Fuel	SRC Residual Fuel Oil	SRC- Water Slurry ¹
DATE	<u>8/30-9/3/82</u>	<u>11/15-19/82</u>	<u>12/13-17/82</u>	<u>1/10-14/83</u>
First Field -				
Operating Secondary Voltage, kV	47.5	35.2	24.9	37.1
Operating Secondary Current, mA	9.8	5.3	4.6	4.3
Current Density, nA/cm ²	26.1	14.1	12.2	11.4
Second Field -				
Operating Secondary Voltage, kV	41.6	40.5	38.0	45.1
Operating Secondary Current, mA	10.0	9.4	5.0	6.1
Current Density, nA/cm ²	26.6	25.0	13.3	16.2
Third Field -				
Operating Secondary Voltage, kV	40.0	43.2	33.8	37.7
Operating Secondary Current, mA	10.0	9.9	5.0	8.5
Current Density, nA/cm ²	26.6	26.4	13.3	22.6

1. Does not include data from test 9-12 of SRC-Water Slurry Test Series.

VOLTAGE CURRENT CURVE

PETC - ICRC #6 FUEL OIL TEST

T-R# 1

9/3/82

Figure 66. Voltage current curve, PETC-ICRC No. 6 fuel oil test, T-R No. 1, 9/3/82.

VOLTAGE CURRENT CURVE

PETC - ICRC #6 FUEL OIL TEST

T-R# 2

9/3/82

Figure 67. Voltage current curve, PETC-ICRC No. 6 fuel oil test, T-R No. 2, 9/3/82.

VOLTAGE CURRENT CURVE

PETC - ICRC #6 FUEL OIL TEST

T-R# 3

9/3/82

Figure 68. Voltage current curve, PETC-ICRC No. 6 fuel oil test, T-R No. 3, 9/3/82.

PRECIPITATOR SECONDARY VOLTAGE WAVEFORM

PITTSBURGH ENERGY TECHNOLOGY CENTER

TR# 1

9/3/82

Figure 69. Precipitator secondary voltage waveform, Pittsburgh Energy Technology Center, TR# 1, 9/3/82.

PRECIPITATOR SECONDARY VOLTAGE WAVEFORM

PITTSBURGH ENERGY TECHNOLOGY CENTER

TR# 2

9/3/82

Figure 70. Precipitator secondary voltage waveform, Pittsburgh Energy Technology Center, T-R No. 2, 9/3/82.

PRECIPITATOR SECONDARY VOLTAGE WAVEFORM

PITTSBURGH ENERGY TECHNOLOGY CENTER

TR# 3

9/3/82

Figure 71. Precipitator secondary voltage waveform, Pittsburgh Energy Technology Center, T-R No. 3, 9/3/82.

VOLTAGE CURRENT CURVE

PETC - ICRC PULV SRC TEST

T-R# 1

11/19/82

Figure 72. Voltage current curve, PETC-ICRC SRC Fuel test, T-R No. 1, 11/19/82.

VOLTAGE CURRENT CURVE

PETC - ICRC PULV SRC TEST

T-R# 2

11/19/82

Figure 73. Voltage current curve, PETC-ICRC SRC Fuel Test, T-R No. 2, 11/19/82.

VOLTAGE CURRENT CURVE

PETC - ICRC PULV SRC TEST

T-R# 3

11/19/82

Figure 74. Voltage current curve, PETC-ICRC SRC Fuel test, T-R No. 3, 11/19/82.

Figures 75 through 77 are the V-I curves obtained while SRC-Residual Fuel Oil was fired. Figure 75 indicates that some electrical problem existed in T-R# 1 due to the low attainable secondary voltage. From Figure 78, which is the waveform plot for T-R# 1, it is apparent that the secondary voltage didn't rise much farther than indicated corona start. This was due to tracking of the secondary voltage along the insulator to ground due to buildup on the insulators. Figures 79 and 80 present the waveforms for corona start and maximum attainable voltage for T-R's 2 and 3 respectively, during the SRC Residual Fuel Oil test.

Figures 81 through 83 present the V-I curves from the SRC-Water Slurry test for T-R's 1, 2 and 3 respectively and demonstrate that the ESP could have been operated at higher current densities than the test averages. During the SRC-Water Slurry test series the insulator fouling problem was very evident since some of the two-hour test could not be finished without the voltage falling off considerably.

All in all, the ESP had little difficulty in collecting the high carbon content ash and if the insulators could have been kept clean, could have been operated at practically any efficiency desired.

VOLTAGE CURRENT CURVE

PETC - ICRC RESIDUAL OIL TEST

T-R# 1

12/17/82

Figure 75. Voltage current curve, PETC-ICRC SRC Residual Fuel Oil test, T-R No. 1, 12/17/82.

VOLTAGE CURRENT CURVE

PETC - ICRC RESIDUAL OIL TEST

T-R# 2

12/17/82

Figure 76. Voltage current curve, PETC-ICRC SRC Residual Fuel Oil test, T-R No. 2, 12/17/82.

VOLTAGE CURRENT CURVE

PETC - ICRC RESIDUAL OIL TEST

T-R# 3

12/17/82

Figure 77. Voltage current curve, PETC-ICRC SRC Residual Fuel Oil test, T-R No. 3, 12/17/82.

PRECIPITATOR SECONDARY WAVEFORM

PETC - ICRC RESIDUAL OIL TEST

TR# 1

12/17/82

Figure 78. Precipitator secondary waveform, PETC-ICRC SRC Residual Fuel Oil test,
T-R No. 1, 12/17/82.

PRECIPITATOR SECONDARY WAVEFORM

PETC - ICRC RESIDUAL OIL TEST

TR# 2

12/17/82

Figure 79. Precipitator secondary waveform, PETC-ICI C Residual Fuel Oil test,
T-R No. 2, 12/17/82.

PRECIPITATOR SECONDARY WAVEFORM

PETC - ICRC RESIDUAL OIL TEST

TR# 3

12/17/82

Figure 8G. Precipitator secondary waveform, PETC-ICRC SRC Residual Fuel Oil test,
T-R No. 3, 12/17/82.

VOLTAGE CURRENT CURVE

PETC - ICRC SRC-WATER TEST

T-R# 1

1/11/83

Figure 81. Voltage current curve, PETC-ICRC SRC-Water Slurry test, T-R No. 1, 1/11/83.

VOLTAGE CURRENT CURVE

PETC - ICRC SRC-WATER TEST

T-R# 2

1/11/83

Figure 82. Voltage current curve, PETC-ICRC SRC-Water Slurry test, T-R No. 2, 1/11/83.

VOLTAGE CURRENT CURVE

PETC - ICRC SRC-WATER TEST

T-R# 3

1/11/83

Figure 83. Voltage current curve, PETC-ICRC SRC-Water Slurry test, T-R No. 3, 1/11/83.

IV. MATHEMATICAL MODELING

The purpose of this chapter is to estimate the performance of a full-scale precipitator collecting fly ash from a utility boiler that is firing some form of Solvent Refined Coal. This projection requires a method of extrapolation beyond the data base obtained from testing the PETC pilot-scale precipitator. The most reliable method of extrapolation uses a detailed mathematical simulation of the entire precipitation process, performed by a computer model which has been developed under the sponsorship of the U.S. Environmental Protection Agency. Previous work has demonstrated that the ESP MODEL performs a good mathematical simulation of the electrostatic precipitation process in full-scale precipitators collecting fly ash particles from combustion of pulverized coal⁸.

The principal source of uncertainty in the mathematical modeling discussed in this chapter is the degree of degradation of performance of a full-scale precipitator due to rapping reentrainment of collected particulate matter. Nevertheless, the results of mathematical modeling support the PETC test results in demonstrating that there are no fundamental problems that would prohibit the use of electrostatic precipitators for cleaning the flue gas from a utility boiler that is firing some form of Solvent Refined Coal.

A. Description of the ESP MODEL

The ESP MODEL is documented in detail in two companion volumes published as EPA Report 600/7-78-111a,b⁶. The mathematical structure of the computer algorithm is described briefly in this introductory section because it is the basis of the mathematical modeling of the PETC pilot-scale precipitator and of the full-scale precipitator performance projections.

Each separately-energized electrical section of one gas passage of a wire-plate precipitator is subdivided into small computational length increments, within each of which the electrical conditions (including the particulate space charge density) are approximately uniform. The inlet aerosol particle size distribution is subdivided into small bands, within each of which the particle size is approximately uniform. The ideal collection efficiency for each particle size, in each computational length increment, is calculated using the Deutsch-Anderson equation⁹. This equation is based on the probability of particle transport into a boundary layer of laminar gas flow near the collecting plate (where particle collection is assured) assuming a uniform particle distribution over any cross-sectional plane of the precipitator due to fully-developed small-scale turbulence in the gas flow. That assumption is approximately valid for the fine particles that are of principal importance in a mathematical simulation of electrostatic precipitation.

In the boundary layer of laminar gas flow, each charged particle has a component of velocity directed toward the collecting plate that is called the particle migration velocity. This velocity appears in the Deutsch-Anderson equation as a single parameter which incorporates the combined effects of all the electrical mechanisms of particle charging and collecting. The bulk of the time required to execute the ESP MODEL is used in computing the particle charge and the collecting electric field that are needed to compute the particle migration velocity, for each particle size in each computational length increment. The overall collection efficiency for ideal gas flow, for each particle size, is obtained by summing over the computation length increments. That collection efficiency can be translated into an overall effective precipitation rate parameter. Corrections for non-ideal gas flow in a precipitator (gas sneakage past the electrified fields and non-uniform gas flow distribution) are performed by calculating an empirical reduction in the overall effective precipitation rate parameter for each particle size.

The ESP MODEL performs a self-consistent computation of the inter-electrode space charge distribution in each computational length increment, including approximately both ionic space charge and suspended particulate space charge. The algorithm solves simultaneously Poisson's equation and the current continuity equation in the interelectrode space, using the mathematical boundary conditions of operating voltage and current density specified as input data. The result of this computation is the value of collecting electric field, in wire-plate precipitator geometry. The ESP MODEL is not sensitive to the geometrical details of different types of corona electrodes and different collecting plate baffles.

The charge acquired by suspended particles in each computational length increment is computed using a unipolar ionic charging theory⁷. The algorithm sums the time-rates-of-charging for field charging, charging by thermal diffusion of ions, and field-enhanced thermal diffusion charging. The algorithm computes a fourth-order Runge-Kutta numerical solution to the differential equation for the charging rate. The charge acquired by aerosol particles depends on the particle size, the density of unipolar ions, the exposure time (the ratio of the computational length increment to the gas velocity) and the average electric field in the interelectrode space.

The degrading effects of gas sneakage and non-rapping reentrainment in a precipitator are represented by a decimal fraction S (typically 0.05 to 0.10) specified by the user. Non-uniformity in the gas flow distribution is represented by the normalized standard deviation σ_{gas} (typically 0.15 to 0.25) of a matrix of gas velocity measurements over the face of the precipitator. Both of these non-ideal parameters enter into the calculation of correction factors

that are applied to the overall effective precipitation rate parameter for each particle size. Finally, the computed collection efficiency for each particle size is corrected for rapping reentrainment of collected particles. However, both measurements and modeling of the PETC pilot-scale precipitator were performed without performance degradation due to rapping reentrainment.

B. Mathematical Modeling of the PETC Pilot-Scale Precipitator

The ESP MODEL was used first to simulate the performance of the PETC pilot-scale precipitator. As with all mathematical modeling, the accuracy of the computation is limited by the accuracy of the input data. In this application, there were large uncertainties in several of the data. The electrical operating conditions used in the simulation were averages of the operating conditions measured throughout each test and were different for each fuel. For the No. 6 fuel oil test, the ESP was capable of operating at high voltage and current levels. However, the operating points were reduced to more conservative values of voltage and current. In subsequent tests with other fuels, the operating points showed varying degrees of degradation due to current tracking across the surface of the high voltage insulators. The high voltage also tended to fluctuate during the tests. These fluctuations were small in the No. 6 fuel oil test, which was performed first, but were much bigger during the later tests -- up to 10 kV during one of the SRC Residual Fuel Oil tests, with 3 to 5 kV being typical. For all cases, the electrical operating points were not limited by the electrical resistivity of the collected ash layer. (The higher values of operating voltage and current that can be attained with low-resistivity ash layers yield increased precipitator collection efficiency, but also increased electrical power consumption.) Table 28 shows the electrical operating points used in the simulation of precipitator performance with each of the four fuels.

The mechanical parameters used in the simulation were based on measurements of the PETC pilot-scale precipitator. The WFI collecting plates were spaced an average of 5 inches from the wires. These plates had a step height of 1.4 inches. Since the aerosol particle charging and collecting is limited by the maximum electric field in the precipitator, the wire-to-plate distance used in the simulation was the distance from the wire to the closest part of the plate, 4.3 inches. The details of collecting plate geometry are not considered in the ESP MODEL computation of collection efficiency. However, the good agreement between measured and computed collection efficiencies, shown in Figure 86, indicates that the WFI collecting plate geometry had no unusual effect on particle collection. The effect on rapping reentrainment was not tested.

The inlet mass loadings and particle size distributions used in the four simulations were taken from impactor and UPSS data. Since the four fuels tested were very low in ash, the mass loadings were very light compared to loadings found in fly ash precipitators serving pulverized-coal-fired utility boilers. As a result, no corona quenching should have occurred in the inlet electrical section. The particle size distributions of the four fuels are shown in Figures 84 and 85. Note that the particle size scale is different in the two figures. The No. 6 fuel oil ash has a much higher concentration of very fine particles than the other ashes. This is typical of No. 6 fuel oil and accounts for the reduced precipitator collection efficiency for ash from firing No. 6 fuel oil.

Following the ideal efficiency computation, the efficiency is corrected for gas sneakeage and non-rapping reentrainment and for gas velocity variations. The measured gas flow was very non-uniform, especially at the precipitator inlet. The inlet value of σ_{gas} was 57% and the outlet value was 18%. This is based on WFI data dated 2/4/83. The data were taken on a dirty precipitator after the completion of the testing program. The egg crate flow straightener

Figure 84. Measured particle size distribution of fuel oil ash.

Figure 85. Measured particle size distribution of ashes from three SRC fuels.

Figure 86. Measured and computed performance of the PETC pilot-scale ESP. ESP MODEL computations use measured electrical and aerosol data, 10% gas sneackage and three different values of σ_{gas} . The measured value of collection efficiency is taken from impactor data. The error bars indicate the range of scatter in mass train data.

was partially plugged when these measurements were taken (20-25% plugged on the top half and 75-80% blocked on the bottom half, according to WFI estimates.) These data left a large uncertainty as to a representative value of σ_{gas} to be used in the mathematical modeling. The sneakage fraction S was not measured. Consequently, the ESP MODEL was run for a matrix of S and σ_{gas} values for each fuel. Table 29 shows the penetrations obtained for each case. Table 30 shows the percent error for each of the penetrations in Table 29 compared to the measured value. Negative values indicate that the calculated penetration is greater than the measured value. With the exception of SRC Residual Fuel Oil, the best agreement occurs for a sneakage value of 0.10. This is a reasonable value for a well-baffled pilot-scale precipitator. The best agreement does not occur for a single value of σ_{gas} but covers the range of 0.2 to 0.4 for all fuels except SRC Residual Fuel Oil. The average value of $\sigma_{\text{gas}} = 0.3$ gives an average error of 15%, with $S = 0.10$. The ESP MODEL consistently underpredicts the efficiency for SRC Residual Fuel Oil. No rapping reentrainment correction was performed since no rapping data were measured during the test series.

The results of the mathematical simulation are shown in Figure 86. In this figure, the measured collection efficiency is plotted against the computed value for $S = 0.10$ and $\sigma_{\text{gas}} = 0.2, 0.3$, and 0.4. Perfect agreement between measured and computed values is indicated by the diagonal dashed line. The relationship between particle size distribution and collection efficiency is reflected in this figure, with SRC Fuel ash having the greatest fraction of large particles and the highest collection efficiency, and with No. 6 fuel oil ash having a preponderance of fine particles and the lowest collection efficiency. The poor agreement for SRC Residual Fuel Oil is probably due to large fluctuations in the electrical operating points during the testing. An increase of a few kV in the average operating voltage used in the computations would bring the computed

Table 29

PERCENT PENETRATION COMPARISON FOR FOUR FUELS

NO. 6 FUEL OIL					
Measured penetration = 1.91					
S	σ_{gas}				
	.0	.2	.3	.4	.6
.00	.81	1.1	1.3	1.7	2.7
.05		1.5	1.8	2.3	3.6
.10		2.0	2.4	3.0	4.7
.15		2.7	3.3	4.0	6.0

SRC-WATER SLURRY					
Measured penetration = 1.18					
S	σ_{gas}				
	.0	.2	.3	.4	.6
.00	.48	.58	.67	.79	1.1
.05		.74	.87	1.0	1.5
.10		.97	1.2	1.4	2.1
.15		1.3	1.6	1.9	2.9

SRC RESIDUAL FUEL OIL					
Measured penetration = 0.85					
S	σ_{gas}				
	.0	.2	.3	.4	.6
.00	.87	1.1	1.3	1.5	2.2
.05		1.4	1.7	2.0	3.0
.10		1.9	2.2	2.7	4.2
.15		2.5	3.0	3.7	5.7

SRC FUEL					
Measured penetration = 0.50					
S	σ_{gas}				
	.0	.2	.3	.4	.6
.00	.13	.17	.20	.25	.39
.05		.23	.28	.36	.58
.10		.33	.41	.52	.85
.15		.43	.59	.75	1.2

Table 30

PERCENT PENETRATION ERROR COMPARISON

NO. 6 FUEL OIL					
S	σ_{gas}				
	.0	.2	.3	.4	.6
.00	58	42	31	11	41
.05		21	6	-20	-88
.10		-5	-25	-57	-140
.15		-41	-72	-110	-210

SRC-WATER SLURRY					
S	σ_{gas}				
	.0	.2	.3	.4	.6
.00	59	51	43	33	7
.05		37	26	15	-27
.10		18	-2	-18	-78
.15		-10	-36	-61	-150

SRC RESIDUAL FUEL OIL					
S	σ_{gas}				
	.0	.2	.3	.4	.6
.00	-2	-29	-52	-76	-160
.05		-64	-100	-140	-250
.10		-120	-160	-220	-390
.15		-190	-250	-330	-570

SRC FUEL					
S	σ_{gas}				
	.0	.2	.3	.4	.6
.00	74	66	60	50	22
.05		54	44	28	-16
.10		34	18	-4	-70
.15		14	-18	-50	-140

efficiency in line with the measured efficiency. The measured values of collection efficiency shown in Figure 86 are taken from impactor measurements, but the horizontal error bars indicate the scatter in mass train measurements. The level of agreement between computed and measured collection efficiency, shown in Figure 86, is considered to be good, based on previous experience in modeling full-scale utility fly ash precipitators⁸.

C. Estimates of Full-Scale ESP Performance with Boilers Firing SRC Fuels

The ESP MODEL can be used during a design process to estimate the performance of a full-scale precipitator. Performance estimates are described in this section for full-scale precipitators collecting ash from firing the four fuels tested at PETC and, for comparison, fly ash from firing a medium-sulfur (2%) eastern bituminous coal. The ESP MODEL computations of collection efficiency may be helpful not only in estimating the size of a new precipitator but also in estimating the adequacy of an existing precipitator when converting from No. 6 fuel oil firing to SRC Fuel firing.

Limitations of the Performance Estimation Procedure

There are a number of uncertainties in the values of input data for the ESP MODEL which could compromise the estimates of full-scale precipitator performance with ash from SRC fuels. In a full-scale precipitator, particular attention must be given to the matter of purging high voltage insulators; although the unknown quantity of purge air required should be a small fraction of the total gas flow. The ESP MODEL is not sensitive to differences in precipitator performance due to differences in electrode geometry. Neglect of the details of the electrode geometry of the PETC pilot-scale precipitator did not cause any observable discrepancy

between computations and measurements performed without electrode rapping. However, the amount of precipitator performance degradation due to rapping reentrainment could be affected by the details of electrode geometry. Indeed, the effects of rapping reentrainment appear to be the major source of uncertainty in attempting to make full-scale precipitator performance projections. Numerical examples of precipitator performance degradation due to rapping reentrainment are given below. It should be noted also that the computations reported here are not the same thing as the complete engineering design of a precipitator system. The precipitator performance projections do not address a number of points that are very important in the design process. Such points include: gas flow distribution and baffling, automatic controllers of operating voltage, electrode rappers and vibrators, ash handling and removal, marginal SCA requirements, and general operation and maintenance procedures. The precipitator performance projections take for granted good standard engineering design of a precipitator system and good standard operation and maintenance procedures.

Estimates of Input Data for the ESP MODEL

The mechanical design parameters and the gas flow assumed for the full-scale precipitator performance estimates are shown in Table 31. These parameters apply to each of several electrical bus sections in series. Parallel arrangements of electrical bus sections are used to accommodate the total gas flow. Nine-inch plate spacing is chosen to represent a typical retrofit situation. The gas velocity is fixed at 4 ft/s. This is a typical design value for utility fly ash precipitators. It is probably an upper limit for precipitators collecting ash from SRC fuels because of possible problems with reentrainment of the collected ash--problems associated with the low electrical resistivity of the collected ash. The precipitator performance estimation

Table 31

MECHANICAL PARAMETERS AND GAS FLOW PARAMETERS USED IN THE ESP MODEL TO ESTIMATE FULL-SCALE PRECIPITATOR COLLECTION EFFICIENCY. THE PARAMETERS APPLY TO EACH SEPARATELY-ENERGIZED ELECTRICAL SECTION IN THE DIRECTION OF GAS FLOW.

<u>Precipitator Parameter</u>	<u>SRC Fuels and No. 6 Fuel Oil</u>	<u>Medium-Sulfur Bituminous Coal</u>
Parallel lanes	37	40
Plate spacing	9 in.	9 in.
Plate height	30 ft	30 ft
Plate length	7.2 ft	8.1 ft
Plate area	16,000 ft ²	19,440 ft ²
Wire spacing	7.2 in.	6.5 in.
Gas temperature	350°F	300°F
Volume gas flow*	200 kACFM	216 kACFM
Linear gas velocity	4 ft/s	4 ft/s
SCA (per section)	80 ft ² /kACFM	90 ft ² /kACFM

*The estimated volume gas flow does not include the purge air that may be required for the high voltage insulators.

procedure involves computations of the variations in collection efficiency with variations in SCA. In order to vary SCA in a realistic way by varying the designed number of electrical sections and baffled sections (as opposed to varying the designed gas flow) the increment in collecting plate area and SCA for each electrical section is chosen to be small.

Estimated values of the mass loading and size distribution of ash particles from No. 6 fuel oil and the three SRC fuels are chosen to be the same as those measured at PETC. Values for the coal comparison case are representative values from a data base of measurements at 17 electric utility plants firing pulverized bituminous coal. The precipitator inlet mass loadings are tabulated again later in connection with the presentation of final results in Table 34. The particle size distributions are plotted again in Figure 87, on the same scale for a direct comparison. The log-normal straight line plot for the coal comparison case is a good average representation of measurements in the data base, in the particle size range $0.5 \mu\text{m}$ to $50 \mu\text{m}$. Variations in the assumed values of inlet mass loading of SRC fuel ashes would have negligible effect on the ESP MODEL computation of collection efficiency. On the other hand, the particle size distribution is critical. Precipitator performance, whether measured or computed, is very sensitive to the fine particle fractions of the inlet mass loading. As illustrated above in the data from PETC, a higher concentration of fine particles causes a lower precipitator collection efficiency.

Estimated values of the electrical operating points in each electrical bus section are listed in Table 32. Values for the coal comparison case are values predicted for fly ash of electrical resistivity $1 \times 10^{11} \text{ ohm}\cdot\text{cm}$, based on correlations of electrical operating data from 17 full-scale utility fly ash precipitators. The values for No. 6 fuel oil and the three SRC fuels are

Table 32

ELECTRICAL OPERATING POINTS USED IN THE ESP MODEL
TO ESTIMATE FULL-SCALE PRECIPITATOR COLLECTION EFFICIENCY

SRC Fuels and No. 6 Fuel Oil

Section	Nominal Parameters			Degraded Parameters		
	kV	$\mu\text{A}/\text{ft}^2$	nA/cm^2	kV	$\mu\text{A}/\text{ft}^2$	nA/cm^2
1	45	26.0	28.0	41	9.3	10.0
2	41	27.9	30.0	37	11.1	11.9
3	38	28.8	31.0	35	11.6	12.5
4	37	28.8	31.0	34	12.1	13.0

Medium-Sulfur Bituminous Coal

Section	Nominal Parameters		
	kV	$\mu\text{A}/\text{ft}^2$	nA/cm^2
1	39	8.1	8.7
2	38	11.8	12.7
3	37	14.8	15.9
4	35	19.1	20.6

Figure 87. Ash particle size distribution used in the ESP MODEL to estimate full-scale precipitator collection efficiency.

hypothetical, and are therefore chosen to be the same for each of the four fuels. Since the electrical operating points are not limited by the resistivity of the ash layer on the collecting plate, the nominal parameters shown in Table 32 merely indicate a reasonable limit on the electrical power consumption. Because of the testing experience at PETC with degraded electrical conditions caused by low-resistivity ash deposits on the surface of the high voltage insulators, examples of precipitator performance are computed also for the degraded electrical parameters shown in Table 32. These examples give an indication of the possible consequences of inadequate purging of the high voltage insulators. Computations of precipitator collection efficiency will vary strongly with the specified operating voltage, and less strongly with the specified operating current. However, it should be noted that the PETC test results indicate that SRC fuel ashes may be collected satisfactorily with a fairly wide latitude in electrical operating conditions. The effect of the electrical operating conditions on suppression of rapping reentrainment was not tested at PETC.

The parameters that are used to make approximate corrections for non-ideal gas flow conditions are chosen to be $S = 0.10$ and $\sigma_{\text{gas}} = 0.25$. These parameters are reasonably representative of a retrofit situation where the existing precipitator is in good mechanical condition, with good gas flow distribution and baffling. Precipitator performance is computed also for $S = 0.05$ and $\sigma_{\text{gas}} = 0.15$, as shown in Table 33, as an indication of the improved performance that can be expected from the best design and construction of a new precipitator.

Results of the Performance Estimation Procedure

The ESP MODEL computations of precipitator performance are summarized for all cases in Table 33. The numbers in the left-

Table 33

RESULTS OF ESP MODEL COMPUTATIONS OF PERCENT MASS PENETRATION IN A FULL-SCALE ESP. THE COMPUTATIONS ARE PERFORMED FOR BOTH NOMINAL AND DEGRADED ELECTRICAL PARAMETERS AND FOR TWO DIFFERENT SETS OF NON-IDEAL GAS FLOW PARAMETERS. THE COMPUTATIONS DO NOT INCLUDE AN ESTIMATE OF THE INCREASED PENETRATION DUE TO RAPPING REENTRAINMENT.

	[S = 0.10] [σ _{gas} = 0.25]		[S = 0.05] [σ _{gas} = 0.15]	
	Percent Penetration		Percent Penetration	
No. 6 Fuel Oil				
SCA 80 ft ² /kACFM	32	(46)	28	(43)
160	11	(21)	8.1	(18)
240	3.6	(9.4)	2.4	(7.3)
SRC Residual Fuel Oil				
SCA 80 ft ² /kACFM	17	(24)	11	(17)
160	3.6	(6.4)	1.8	(4.2)
240	0.89	(2.3)	0.43	(1.4)
SRC-Water Slurry (LOMAR-D Surfactant)				
SCA 80 ft ² /kACFM	17	(24)	11	(17)
160	3.3	(6.2)	1.9	(4.3)
240	0.87	(2.3)	0.50	(1.7)
320	0.28	(0.96)	0.15	(0.65)
SRC Fuel				
SCA 80 ft ² /kACFM	13	(17)	6.9	(10)
160	1.7	(3.2)	0.80	(1.9)
240	0.39	(1.0)	0.19	(0.64)
Medium-Sulfur Bituminous Coal				
SCA 180 ft ² /kACFM	3.0		1.6	
270	0.73		0.37	
360	0.22		0.096	

most column are plotted as solid curves in the companion Figure 88. This figure shows precipitator penetration (or collection efficiency) versus SCA, in increments of $80 \text{ ft}^2/\text{kACFM}$ for No. 6 fuel oil and the three SRC fuels. Because the electrical operating conditions are assumed to be the same in each case, the differences between the three curves in Figure 88 reflect simply the differences in particle size distribution, as shown in Figure 87. The computations of collection efficiency for ashes from SRC Residual Fuel Oil and SRC-Water Slurry lie along the same curve in Figure 88 because the two measured particle size distributions are so similar. For each of the three solid curves in Figure 88, a companion dashed curve represents the example computation of precipitator performance with degraded electrical conditions—the second column of numbers, in parentheses, in Table 33.

The computed collection efficiencies ($1.0 - \text{output/input}$) can be translated into estimated values of outlet mass loadings versus SCA. Given values of inlet and outlet mass loadings, the corresponding value of collection efficiency is located on one of the three solid curves in Figure 88 and the corresponding value of SCA is read along the horizontal axis at the bottom of the figure. The results of this procedure are listed in Table 34 and plotted in the companion Figure 89.

Finally, an indication of the possible degradation in precipitator performance due to rapping reentrainment is shown in Figure 90. The lower solid curve for the coal comparison case shows a conventional computation of the reduced collection efficiency due to rapping reentrainment. The computation is based on an empirical correlation of rapping reentrainment tests of several utility fly ash precipitators. The computation represents a loss of roughly 10% of the particulate mass collected in the outlet electrical section. It is fortuitous that the no-rap collection efficiency

Figure 88. Estimates of full-scale ESP collection efficiency for ash from No. 6 Fuel Oil and three SRC fuels. The same estimates of electrical operating points are used for each of the three solid curves. (The three dashed curves show estimates of performance with degraded electrical conditions due to contamination of the high voltage insulators.) Differences in the three curves reflect measured differences in the ash particle size distributions. The estimates do not include the effect of rapping reentrainment.

Table 34

ESTIMATES OF COLLECTION EFFICIENCY AND MINIMUM SCA FOR PRECIPITATORS COLLECTING ASH FROM FIVE DIFFERENT FUELS, FOR A SPECIFIED INLET MASS LOADING AND A RANGE OF OUTLET MASS LOADINGS. THE ESTIMATED SCA VALUES ARE BASED ON ESP MODEL COMPUTATIONS OF COLLECTION EFFICIENCY WHICH DO NOT INCLUDE THE EFFECT OF RAPPING REENTRAINMENT, EXCEPT IN THE COMPARISON CASE OF MEDIUM-SULFUR BITUMINOUS COAL. NONE OF THE ESTIMATED SCA VALUES INCLUDE ENGINEERING DESIGN MARGINS.

	Inlet Loading		a) Outlet Loading, lb/10 ⁶ Btu		
	gr/ACF	lb/10 ⁶ Btu	b) Collection Efficiency, %		
			c) SCA, ft ² /kACFM		
No. 6 Fuel Oil	0.012	0.035	a)	0.01	
			b)	71	
			c)	90	
SRC Residual Fuel Oil	0.059	0.18	a)	0.01	0.03
			b)	94.4	83
			c)	130	80
SRC Fuel	0.23	0.78	a)	0.01	0.03
			b)	98.7	96.2
			c)	170	130
SRC-Water Slurry (LOMAR-D Surfactant)	0.32	0.98	a)	0.01	0.03
			b)	99.0	96.9
			c)	230	165
Medium-Sulfur Bituminous Coal	2.2	5.9	a)	0.01	0.03
			b)	99.83	99.49
			c)	410	320

Figure 89. Estimates of minimum SCA for a specified inlet mass loading (see Table 44) and a range of outlet mass loadings. The estimated SCA values are based on ESP MODEL computations of collection efficiency which do not include the effect of rapping reentrainment, except in the comparison case of medium-sulfur bituminous coal. None of the estimated SCA values include engineering design margins.

Figure 90. Computed examples of degradation in precipitator performance due to rapping reentrainment.

curves for ashes from coal and from SRC-Water Slurry (the same curve as solid curve B on Figure 88) are so close. The effect of the higher electrical operating points for the SRC fuel is approximately offset by the effect of the finer particle size distribution.

The two lower dashed curves showing degradation due to rapping reentrainment of ash from SRC-Water Slurry are estimated by a dynamic rapping simulation. A specified fraction of the collected mass in each electrical section (not just the outlet section) is reentrained into the gas stream, on a specified rapping schedule. The two lower dashed curves for SRC-Water Slurry represent arbitrary assumptions of 20% and 40% mass reentrainment. Electrical sections 1, 2, 3, 4 are rapped on a schedule of 1/2, 2, 8, 24 hours, respectively, regardless of which section is the outlet section for a given total SCA. The reentrained particulate mass is distributed into particle size fractions according to a log-normal distribution with $mmd = 5.0 \text{ } \mu\text{m}$ and $\sigma = 3.5$.

Summary and Recommendations

Because of the various uncertainties in the input data chosen for the ESP MODEL, the estimates of full-scale precipitator performance may be more useful for their relative values than for their absolute values. That is, the results may be interpreted by first comparing the computed precipitator collection efficiency for ashes from the unfamiliar SRC fuels and for ashes from the more familiar No. 6 fuel oil and bituminous coal. Then, the absolute values of precipitator collection efficiency that are computed for the familiar ashes may be compared with the data bases maintained by engineering and manufacturing firms.

The limits of uncertainty in using the ESP MODEL can be narrowed considerably with some test data on the precipitability of ashes from firing SRC fuels in a full-scale utility boiler. For estimating the adequacy of an existing precipitator or designing a new precipitator, additional data in several specific areas would be helpful:

- 1) The possibility of improved carbon burn-out in a full-scale utility boiler is a major source of uncertainty. Small changes in the ash chemistry and morphology could cause order-of-magnitude changes in the electrical resistivity of the ash. If the ash resistivity could be increased to the order of 1×10^{10} ohm·cm, the precipitability would remain good and the following problem area would be alleviated.

- 2) Electrical problems associated with contamination of the high voltage insulators need to be investigated with ash from a full-scale utility boiler. If the ash resistivity remains very low, as in the PETC tests, then the volume of heated purge air required for the high voltage insulators needs to be considered more carefully in precipitator design and costing.

- 3) The rapping reentrainment of ashes from SRC fuels is another major source of uncertainty. Reentrainment from the collecting plates can vary widely with the mechanical design of the plates, the distribution of rapping intensity on the plates, and the gas flow distribution. The behavior of the ash can also be influenced strongly by any precipitated residue from a chemical additive, such as the surfactant used in a water slurry of SRC fuel.

4) At a given level of overall precipitator collection efficiency, the outlet mass loading varies in direct proportion to the inlet mass loading. Therefore, measurements of the mass loading of ashes from firing SRC fuels in a full-scale utility boiler are needed to estimate more closely the necessary SCA. In particular, the relatively high mass loading measured for the SRC-Water Slurry tested at PETC resulted from the particular surfactant (LOMAR-D) used to create the slurry.

For all the uncertainties in full-scale precipitator performance projections, the overriding consideration is that the PETC pilot-scale precipitator performed very well in collecting ashes from SRC fuels. Both measurements and mathematical modeling demonstrate that there are no fundamental problems that would prohibit the use of electrostatic precipitators for cleaning the flue gas from a full-scale utility boiler firing SRC fuels. The requirements for retrofitting an existing precipitator, in the process of converting from No. 6 fuel oil firing to SRC-Water Slurry firing, for example, would depend largely on the size and general condition of the existing precipitator and the mass loading of ash from the new fuel.

V. ALTERNATE CONTROL CONSIDERATION

The replacement of present day fuels with SRC will be predicated by fuel cost. Provided the fuel costs of SRC become competitive with fuels, such as oil or natural gas, economic considerations then hinge around conversion costs and environmental control costs for older units to convert to an SRC Fuel.

Baghouses for control of SRC particulate were to be evaluated by Wheelabrator-Frye, Inc. and their report from this project should be consulted regarding the use of baghouses for controlling emissions of SRC particulate.

The two liquid SRC fuels tested during these test programs appear to be possible substitutes for fuel oil. It appears that those utility boilers which are presently firing oil and have electrostatic precipitators with SCA's of approximately 150 to 200 ft^2/kACFM could maintain outlet emissions below $0.1 \text{ lbs}/10^6 \text{ BTU}$ if their fuel source is changed to a SRC Fuel. Many utility oil-fired boilers are not equipped with ESPs but do have cyclones or multiclones primarily for controlling emissions during soot blowing.

If cyclones were the only particulate control device used to collect SRC ash the data in Table 15 can be used to approximate the outlet emissions which might exist. Cyclones and cyclone theory have been investigated at SoRI under research contracts funded by the Environmental Protection Agency. It has been found that cyclone behavior as well as cyclone theory is not well understood. Manufacturers of commercial cyclones provide performance data for various sized cyclones at differing pressure drops.

One manufacturer produces a cyclone which operates at a "Critical Particle Size" of 6.0 μm and a pressure drop of 6" of water at a capacity of 104 cfm. "Critical Particle Size" is defined by cyclone manufacturers as the smallest particle which can be collected with essentially 100% efficiency. The efficiency curve falls off rapidly below the "Critical Particle Size" and by using Table 15 and assuming that the cyclone conditions stated above would correspond to a cyclone D_{50} of 5 μm , an outlet loading could be estimated for the various particulates evaluated at PETC.

Assuming that the total mass loadings and particle size distribution produced at PETC would be representative of a full-scale boiler, the following outlet loadings would be calculated:

<u>Fuel</u>	<u>Loading, lbs/10⁶ BTU</u>	<u>Cyclone Efficiency, %</u>
No. 6 Fuel Oil	0.0336	6.4
SRC Fuel	0.0718	91
SRC Residual Fuel Oil	0.0411	76.9
SRC-Water Slurry	0.1809	81.5

It should be understood that if cyclones with the above parameters were used at PETC in place of the ESP that 50 of them would have been required to handle the same gas flow and at a pressure drop of 6" of water.

VI. REFERENCES

1. Johnson, J. W., G. I. Clinard, L. G. Felix, and J. D. McCain. A Computer-Based Cascade Impactor Data Reduction System. EPA-600/7-78-042, March 1978.
2. Felix, L. G., R. L. Merritt, J. D. McCain, and J. W. Ragland. Sampling and Dilution System Designs for Measurement of Sub-micron Particle Size and Concentration in Stack Emission Aerosols. TSI Quarterly, Volume VII, Issue 4, Oct.-Dec., 1981.
3. Hewitt, G. W. The Charging of Small Particles for Electrostatic Precipitation. AIEE, 76, 300-306, July, 1957.
4. Liu, B.Y.H., K. T. Whitby, and D. Y. H. Pui. A Portable Electrical Aerosol Analyzer. J. Aerosol Sci., 6: 249-264, 1975.
5. Cheney, J. L. and J. B. Homolya. Sampling Parameters for Sulfate Measurement and Characterization. Environ. Sci. Technol., 13:584-588, 1979.
6. McDonald, J. R. A Mathematical Model of Electrostatic Precipitation (Revision 1): Volume 1. Modeling and Programming. Volume 2. User Manual. EPA-600/7-78-111a,b. U.S. Environmental Protection Agency, Research Triangle Park, NC, 1978. NTIS PB284-614,615. Magnetic tape: NTIS PB286-349/AS.
7. Smith, W. B., and J. R. McDonald. Development of a Theory for the Charging of Particles by Unipolar Ions. J. Aerosol Sci., 7:151-166, 1976.
8. Gooch, J. P., and G. H. Marchant. Electrostatic Precipitator Rapping Reentrainment and Computer Model Studies. RP-792, Electric Power Research Institute, Palo Alto, CA, August, 1978.
9. White, H. J. Industrial Electrostatic Precipitation. Addison-Wesley Publishing Company, Reading, MA, 1963.

APPENDIX A
Preliminary Data

Table A1

Preliminary Cyclone Run
SRC Residual Fuel Oil Test and SRC-Water Slurry Test

	Total	Stage No.					Filter
		1	2	3	4	5	
<u>December 8, 1982--PETCI-15C</u>							
Collected mass, mg	900.8	643.3	122.8	39.7	19.3	6.3	69.4
Stage D ₅₀ , μ m		5.48	2.23	1.43	0.570	0.255	
Cumulative mass %, Φ_{50}		28.6	15.0	10.6	8.4	7.7	
Cumulative mass loading $\langle D_{50}$, gr/acf	0.1036	0.0296	0.0155	0.0109	0.0087	0.0080	
<u>January 7, 1983--PETCI-21C</u>							
Collected mass, mg	1019.1	754.7	71.6	37.3	17.9	5.1	137.5
Stage D ₅₀ , μ m		5.83	2.47	1.62	0.0680	0.331	
Cumulative mass %, Φ_{50}		25.9	18.9	15.7	14.0	13.5	
Cumulative mass loading $\langle D_{50}$, gr/acf	0.3095	0.0803	0.0587	0.0487	0.0433	0.0418	
<u>January 10, 1983--PETCI-26C</u>							
Collected mass, mg	2235.2	1731.3	161.9	40.5	23.8	21.9	255.8
Stage D ₅₀ , μ m		4.87	1.97	1.25	0.490	0.211	
Cumulative mass %, Φ_{50}		22.5	15.3	13.5	12.4	11.4	
Cumulative mass loading $\langle D_{50}$, gr/acf	0.3352	0.0756	0.0513	0.0452	0.0416	0.0384	

Table A2

Preliminary Cyclone Runs
SRC Fuel

	Total	Stage No.					Filter
		1	2	3	4	5	
<u>October 29, 1982--PETCI-6C</u>							
Collected mass, mg	997.4	837.7	91.1	18.1	12.9	2.9	34.7
Stage D ₅₀ , μm		5.70	2.34	1.50	0.609	0.280	
Cumulative mass %, <D ₅₀		16.0	6.9	5.1	3.8	3.5	
Cumulative mass loading <D ₅₀ , gr/acf	0.2845	0.0455	0.0196	0.0144	0.0107	0.0099	
<u>November 1, 1982--PETCI-7C</u>							
Collected mass, mg	1878.0	1571.6	168.1	45.4	25.5	9.6	57.8
Stage D ₅₀ , μm		6.33	2.67	1.75	0.736	0.361	
Cumulative mass %, <D ₅₀		16.3	7.4	4.9	3.6	3.1	
Cumulative mass loading <D ₅₀ , gr/acf	0.3112	0.0508	0.0229	0.0154	0.0112	0.010	
<u>November 3, 1982--PETCI-8C</u>							
Collected mass, mg	1810.7	1538.3	181.4	53.5	32.7	4.8	?
Stage D ₅₀ , μm		5.70	2.35	1.51	0.618	0.291	
Cumulative mass %, <D ₅₀		15.0	5.0	2.1	0.3		
Cumulative mass loading <D ₅₀ , gr/acf	0.2508	0.0377	0.0126	0.0052	0.0007		
<u>November 4, 1982--PETCI-9C</u>							
Collected mass, mg	2369.9	1938.9	232.7	69.2	31.7	10.1	87.3
Stage D ₅₀ , μm		5.71	2.35	1.52	0.619	0.291	
Cumulative mass %, <D ₅₀		18.2	8.4	5.5	4.1	3.7	
Cumulative mass loading <D ₅₀ , gr/acf	0.2877	0.0523	0.0241	0.0157	0.0118	0.0106	
<u>November 13, 1982--PETCI-8C, Adjusted filter to loading of 0.0099 gr/acf</u>							
Collected mass, mg	1882.2	1538.3	181.4	53.5	32.7	4.8	71.5
Stage D ₅₀ , μm		5.70	2.35	1.51	0.618	0.291	
Cumulative mass %, <D ₅₀		18.3	8.6	5.8	4.1	3.8	
Cumulative mass loading <D ₅₀ , gr/acf	0.2607	0.0477	0.0225	0.0151	0.0106	0.0099	

Table A3
Preliminary SO₂ and SO₃ Data
SRC Fuel

Date	Location	Time	Flue Gas (°F)	ppm/v/v ^a	
				H ₂ SO ₄	SO ₂
11-1-81	ESP inlet	1333-1358	293	0.27	445
		1429-1453	293	0.31	470
		1520-1544	292	0.39	475
11-3-82	ESP inlet	1522-1546	315	1.7	455
		1610-1634	309	1.8	425
		1656-1720	307	1.6	425
11-4-82	ESP inlet	1140-1205	293	0.92	455
		1227-1250	294	1.1	450
SCR/Water					
1-10-83	ESP inlet	1002-1025	292	0.12	495
		1110-1135	294	0.11	500
		1300-1327	299	<0.1	475
		1415-1441	296	<0.1	450

PLTCI-1 09101-10122 R/24/82

INLET SAMPLE

CASCADE IMPACTOR NUMBER = Y

IMPACTOR FLOWRATE = .373 ACFM

IMPACTOR TEMPERATURE = 343.0 F = 172.8 C

SAMPLING DURATION = 61.00 MIN

IMPACTOR PRESSURE DROP = 0.210, OF HG

STACK TEMPERATURE = 343.0 F = 172.8 C

ASSUMED PARTICLE DENSITY = 3.00 GM/CC, CH₄

STACK PRESSURE = 28.23 IN. OF HG

MAX. PARTICLE DIAMETER = 25.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO₂ = 12.76

CO = 0.00

H₂ = 72.83

O₂ = 3.01

SO₂ = 0.00

H₂O = 11.40

CALC. MASS LOADING = 1.3398E-02 GR/ACF

2.4301E-02 GR/DNCF

3.0559E+01 MG/ACM

5.5609E+01 MG/DNCFM

IMPACTOR STAGE

S1

S2

S3

S4

S5

S6

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

8.72

3.84

1.79

0.89

0.42

0.20

MASS (MILLIGRAMS)

1.52

2.03

1.39

2.33

2.66

2.23

14.05

MG/DNCFM/STAGE

3.22E+00

4.30E+00

2.95E+00

4.94E+00

5.68E+00

4.73E+00

2.98E+01

CUM. PERCENT OF MASS SMALLER THAN D50

94.21

86.47

81.17

72.28

62.07

53.56

CUM. (MG/ACF) SMALLER THAN D50

2.89E+01

2.65E+01

2.49E+01

2.22E+01

1.90E+01

1.64E+01

CUM. (MG/DNCFM) SMALLER THAN D50

5.24E+01

4.81E+01

4.51E+01

4.02E+01

3.45E+01

2.98E+01

CUM. (GR/ACF) SMALLER THAN D50

1.26E-02

1.16E-02

1.09E-02

9.68E-03

8.32E-03

7.18E-03

CUM. (GR/DNCF) SMALLER THAN D50

2.29E-02

2.10E-02

1.97E-02

1.76E-02

1.51E-02

1.30E-02

GEO. MEAN DIA. (MICROMETERS)

1.48E+01

5.78E+00

2.62E+00

1.26E+00

6.07E-01

2.85E-01

1.38E-01

DN/DLOGD (MG/DNCFM)

7.04E+00

1.21E+01

8.88E+00

1.62E+01

1.73E+01

1.44E+01

9.89E+01

DN/DLOGD (NO. PARTICLES/DNCFM)

1.39E+06

3.97E+07

3.15E+08

5.18E+09

4.92E+10

3.95E+11

2.37E+13

BLANK CORRECTION (MILLIGRAMS)

0.11

0.01

0.01

0.01

0.01

0.01

0.38

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

15.20

6.74

3.19

1.62

0.81

0.42

GEO. MEAN DIA. (MICROMETERS)

2.57E+01

1.01E+01

4.64E+00

2.28E+00

1.15E+00

5.83E-01

2.97E-01

DN/DLOGD (MG/DNCFM)

7.09E+00

1.22E+01

9.06E+00

1.69E+01

1.88E+01

1.66E+01

9.89E+01

DN/DLOGD (NO. PARTICLES/DNCFM)

8.02E+05

2.25E+07

1.74E+08

2.73E+09

2.38E+10

1.60E+11

7.20E+12

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE

0.144

0.144

0.371

0.326

0.299

0.322

0.296

HOLE DIAMETERS BY STAGE (CENTIMETERS)

1.8237

1.8237

0.2483

0.0851

0.0551

0.0345

0.0272

NUMBER OF HOLES PER STAGE

1

1

12

90

110

110

90

PETCO-1 9/26/82 9:07-15:30 PORT NO. 1
 IMPACTOR FLOWRATE = .331 ACFM
 IMPACTOR PRESSURE DROP = 0.21 IN. OF HG
 ASSUMED PARTICLE DENSITY = 3.00 GM/CCU.CM.
 GAS COMPOSITION (PERCENT) CO₂ = 10.75 CO = 0.00 H₂ = 71.44 O₂ = 45.08 SO₂ = 0.00 H₂O = 13.30
 CALC. MASS LOADING = 2.7317E-04 GR/ACF 4.6176E-04 GR/DNCF 6.2510E-01 MG/ACM 1.0565E+00 MG/DNCFM
 IMPACTOR STAGE S1 S2 S3 S4 S5 S6 FILTER
 STAGE INDEX NUMBER 1 2 3 4 5 6 7
 D50 (MICROMETERS) 9.34 4.13 1.89 1.10 0.53 0.26
 MASS (MILLIGRAMS) 0.72 0.56 0.12 0.13 0.15 0.19 0.36
 MG/DNCFM/STAGE 3.39E-01 2.63E-01 5.84E-02 6.31E-02 7.25E-02 9.13E-02 1.69E-01
 CUM. PERCENT OF MASS SMALLER THAN D50 67.91 43.05 37.52 31.55 24.69 16.04
 CUM. (MG/ACM) SMALLER THAN D50 4.25E-01 2.69E-01 2.35E-01 1.97E-01 1.54E-01 1.00E-01
 CUM. (MG/DNCFM) SMALLER THAN D50 7.18E-01 4.55E-01 3.96E-01 3.33E-01 2.61E-01 1.69E-01
 CUM. (GR/ACF) SMALLER THAN D50 1.86E-04 1.18E-04 1.02E-04 8.62E-05 6.74E-05 4.38E-05
 CUM. (GR/DNCF) SMALLER THAN D50 3.14E-04 1.99E-04 1.73E-04 1.46E-04 1.14E-04 7.41E-05
 GEO. MEAN DIA. (MICROMETERS) 1.37E+01 6.21E+00 2.79E+00 1.44E+00 7.61E-01 3.74E-01 1.87E-01
 DM/DLOGD (MG/DNCFM) 1.02E+00 7.41E-01 1.72E-01 2.67E-01 2.27E-01 3.06E-01 5.63E-01
 DN/DLOGD (NO. PARTICLES/DNCFM) 2.56E+05 1.97E+06 5.02E+06 5.70E+07 3.29E+08 3.73E+09 5.46E+10
 BLANK CORRECTION (MILLIGRAMS) -0.12 -0.07 -0.03 -0.03 -0.03 -0.03 0.12
 AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION
 D50 (MICROMETERS) 16.25 7.23 3.35 1.97 0.98 0.53
 GEO. MEAN DIA. (MICROMETERS) 2.37E+01 1.08E+01 4.92E+00 2.57E+00 1.39E+00 7.20E-01 3.73E-01
 DM/DLOGD (MG/DNCFM) 1.03E+00 7.47E-01 1.75E-01 2.75E-01 2.40E-01 3.38E-01 5.63E-01
 DN/DLOGD (NO. PARTICLES/DNCFM) 1.47E+05 1.12E+06 2.80E+06 3.09E+07 1.69E+08 1.73E+09 2.07E+10
 NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.
 SQUARE ROOTS OF PSI BY STAGE 0.144 0.144 0.371 0.341 0.350 0.331 0.365
 HOLE DIAMETERS BY STAGE (CENTIMETERS) 1.8237 1.8237 0.2483 0.0612 0.0532 0.0358 0.0249
 NUMBER OF HOLES PER STAGE 1 1 12 90 110 110 90

PLT1-20 10:15-10 23 10/21/62
 IMPACTOR FLOWRATE = .146 ACFM
 IMPACTOR PRESSURE DROP = 0.21 IN. OF HG
 ASSUMED PARTICLE DENSITY = 2.00 GM/CC, CM.
 GAS COMPOSITION (PERCENT) CO₂ = 13.09
 CALC. MASS LOADING = 3.0341E-01 GR/ACF

INLET SAMPLE
 IMPACTOR TEMPERATURE = 307.0 F = 152.8 C
 STACK TEMPERATURE = 307.0 F = 152.8 C
 STACK PRESSURE = 27.91 IN. OF HG

CASCADE IMPACTOR NUMBER - X
 SAMPLING DURATION = 8.00 MIN
 MAX. PARTICLE DIAMETER = 100.0 MICROMETERS
 CO = 0.00 N₂ = 76.11 O₂ = 4.30 SO₂ = 0.00 H₂O = 6.50
 5.0379E-01 GR/DNCF 6.9430E+02 MG/ACM 1.1528E+03 MG/DNCF

IMPACTOR STAGE	S1	S2	S3	S4	S5	S6	FILTER
STAGE INDEX NUMBER	1	2	3	4	5	6	7
D50 (MICROMETERS)	10.99	4.86	2.22	1.29	0.62	0.31	
MASS (MILLIGRAMS)	33.76	12.75	4.61	1.98	1.03	0.28	0.01
MG/DNCF/STAGE	7.15E+02	2.70E+02	9.77E+01	4.19E+01	2.18E+01	5.93E+00	2.12E-01
CUM. PERCENT OF MASS SMALLER THAN D50	37.96	14.54	6.06	2.43	0.53	0.02	
CUM. (MG/ACF) SMALLER THAN D50	2.64E+02	1.01E+02	4.21E+01	1.68E+01	3.70E+00	1.28E-01	
CUM. (MG/DNCF) SMALLER THAN D50	4.38E+02	1.68E+02	6.99E+01	2.80E+01	6.14E+00	2.12E-01	
CUM. (GR/ACF) SMALLER THAN D50	1.15E-01	4.41E-02	1.84E-02	7.16E-03	1.62E-03	5.58E-05	
CUM. (GR/DNCF) SMALLER THAN D50	1.91E-01	7.32E-02	3.05E-02	1.22E-02	2.68E-03	9.26E-05	
GEO. MEAN DIA. (MICROMETERS)	3.31E+01	1.30E+00	3.28E+00	1.69E+00	8.92E-01	4.37E-01	2.18E-01
DM/DLOGD (MG/DNCF)	7.46E+02	7.62E+02	2.87E+02	1.78E+02	6.82E+01	1.97E+01	7.04E-01
DM/DLOGD (NO. PARTICLES/DNCF)	1.96E+07	1.87E+09	7.75E+09	3.50E+10	9.17E+10	2.26E+11	6.45E+10
BLANK CORRECTION (MILLIGRAMS)	0.00	0.00	0.00	0.00	0.00	0.00	0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)	15.59	6.92	3.19	1.87	0.92	0.48	
GEO. MEAN DIA. (MICROMETERS)	4.70E+01	1.04E+01	4.70E+00	2.44E+00	1.31E+00	6.68E-01	3.42E-01
DM/DLOGD (MG/DNCF)	7.47E+02	7.66E+02	2.91E+02	1.81E+02	7.08E+01	2.12E+01	7.04E-01
DM/DLOGD (NO. PARTICLES/DNCF)	1.38E+07	1.31E+09	5.35E+09	2.37E+10	5.97E+10	1.36E+11	3.36E+10

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 71 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE	0.144	0.144	0.371	0.341	0.350	0.331	0.365
HOLE DIAMETERS BY STAGE (CENTIMETERS)	1.8237	1.8237	0.2483	0.0812	0.0532	0.0358	0.0249
NUMBER OF HOLES PER STAGE	1	1	12	90	110	110	90

PETCI-22 11:50-12:20 10/28/82

INLET SAMPLE

CASCADE IMPACTOR NUMBER = X

IMPACTOR FLOWRATE = .030 ACFM

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 30.00 MIN

IMPACTOR PRESSURE DROP = 0.41 IN. OF HG

STACK TEMPERATURE = 300.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.00 GM/CC

STACK PRESSURE = 28.20 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO2 = 13.09

CO = 0.00

H2 = 76.11

O2 = 4.30

SO2 = 0.00

H2O = 6.50

CALC. MASS LOADING = 5.3122E-01 GR/ACF

8.6502E-01 GR/DNCF

1.2156E+03 MG/ACM

1.9795E+03 MG/DNCF

IMPACTOR STAGE

S0

S1

S2

S3

S4

S5

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

8.53

4.34

2.71

1.88

0.72

0.50

MASS (MILLIGRAMS)

26.34

1.49

0.90

0.53

0.33

0.24

1.15

MG/DNCF/STAGE

1.68E+03

9.52E+01

5.75E+01

3.39E+01

2.11E+01

1.53E+01

7.35E+01

CUM. PERCENT OF MASS SMALLER THAN D50

14.98

10.17

7.26

5.55

4.49

3.71

CUM. (MG/ACF) SMALLER THAN D50

1.82E+02

1.24E+02

8.83E+01

6.75E+01

5.45E+01

4.51E+01

CUM. (MG/DNCF) SMALLER THAN D50

2.96E+02

2.01E+02

1.44E+02

1.10E+02

8.88E+01

7.35E+01

CUM. (GR/ACF) SMALLER THAN D50

7.96E-02

5.40E-02

1.86E-02

2.95E-02

2.38E-02

1.97E-02

CUM. (GR/DNCF) SMALLER THAN D50

1.30E-01

8.80E-02

6.28E-02

4.80E-02

3.88E-02

3.21E-02

GEO. MEAN DIA. (MICROMETERS)

2.92E+01

6.08E+00

3.43E+00

2.26E+00

1.16E+00

5.97E-01

3.51E-01

DM/DLOGD (MG/DNCF)

1.57E+03

3.24E+02

2.81E+02

2.14E+02

5.04E+01

9.54E+01

2.44E+02

DN/DLOGD (NO. PARTICLES/DNCF)

6.04E+07

1.38E+09

6.66E+09

1.77E+10

3.06E+10

4.28E+11

5.39E+12

BLANK CORRECTION (MILLIGRAMS)

0.00

0.00

0.00

0.00

0.00

0.00

0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

12.11

6.19

3.88

2.71

1.06

0.75

GEO. MEAN DIA. (MICROMETERS)

4.14E+01

8.66E+00

4.90E+00

3.24E+00

1.70E+00

8.93E-01

5.30E-01

DM/DLOGD (MG/DNCF)

1.58E+03

3.26E+02

2.84E+02

2.17E+02

5.19E+01

1.01E+02

2.44E+02

DN/DLOGD (NO. PARTICLES/DNCF)

4.25E+07

9.61E+08

4.61E+09

1.21E+10

2.02E+10

2.71E+11

3.14E+12

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE

0.385

0.353

0.356

0.375

0.300

0.309

0.322

HOLE DIAMETERS BY STAGE (CENTIMETERS)

0.3554

0.2422

0.1779

0.1364

0.0884

0.0705

0.0556

NUMBER OF HOLES PER STAGE

1

1

1

1

1

1

1

PETCI-23 13106-13116 10/29/82

IMPACTOR FLOWRATE = .030 ACFM INLET SAMPLE CASCADE IMPACTOR NUMBER = Y

IMPACTOR PRESSURE DROP = 0.41N. OF HG IMPACTOR TEMPERATURE = 300.0 F = 148.9 C SAMPLING DURATION = 56.00 MIN

ASSUMED PARTICLE DENSITY = 2.00 GM/CCM. STACK TEMPERATURE = 300.0 F = 148.9 C

GAS COMPOSITION (PERCENT) CO₂ = 13.09 CO = 0.00 N₂ = 76.11 O₂ = 4.30 SO₂ = 0.00 H₂O = 6.50

CALC. MASS LOADING = 1.1464E-01 GR/ACF STACK PRESSURE = 28.20 IN. OF HG MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

IMPACTOR STAGE 1.866EE-01 GR/DNCF 2.6234E+02 MG/ACM 4.2718E+02 MG/DNCF

IMPACTOR STAGE	S0	S1	S2	S3	S4	S5	FILTER
STAGE INDEX NUMBER	1	2	3	4	5	6	7
D50 (MICROMETERS)	9.34	5.45	2.42	1.81	0.87	0.54	
MASS (MILLIGRAMS)	9.95	0.74	0.48	0.10	0.13	0.09	0.96
MG/DNCF/STAGE	3.41E+02	2.53E+01	1.64E+01	4.45E+00	4.45E+00	3.08E+00	3.29E+01
CUM. PERCENT OF MASS SMALLER THAN D50	20.27	14.34	10.50	9.46	8.61	7.69	
CUM. (MG/ACM) SMALLER THAN D50	5.32E+01	3.76E+01	2.75E+01	2.48E+01	2.21E+01	2.02E+01	
CUM. (MG/DNCF) SMALLER THAN D50	8.66E+01	6.13E+01	4.48E+01	4.04E+01	3.59E+01	3.29E+01	
CUM. (GR/ACF) SMALLER THAN D50	2.32E-02	1.64E-02	1.20E-02	1.06E-02	9.65E-03	8.82E-03	
CUM. (GR/DNCF) SMALLER THAN D50	3.78E-02	2.68E-02	1.96E-02	1.77E-02	1.57E-02	1.44E-02	
GEO. MEAN DIA. (MICROMETERS)	3.06E+01	7.13E+00	3.63E+00	2.09E+00	1.25E+00	6.86E+01	3.84E+01
DN/DLOGD (MG/DNCF)	3.31E+02	1.08E+02	4.66E+01	3.51E+01	1.40E+01	1.52E+01	1.09E+02
DN/DLOGD (NO. PARTICLES/DNCF)	1.11E+07	2.85E+08	9.30E+08	3.67E+09	6.80E+09	4.48E+10	1.84E+12
BLANK CORRECTION (MILLIGRAMS)	0.00	0.00	0.00	0.00	0.00	0.00	0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)	13.26	7.76	3.47	2.60	1.27	0.82	
GEO. MEAN DIA. (MICROMETERS)	4.33E+01	1.01E+01	5.19E+00	3.01E+00	1.82E+00	1.02E+00	5.76E+01
DN/DLOGD (MG/DNCF)	3.31E+02	1.09E+02	4.71E+01	3.50E+01	1.43E+01	1.59E+01	1.09E+02
DN/DLOGD (NO. PARTICLES/DNCF)	7.79E+06	1.99E+08	6.43E+08	2.50E+09	4.53E+09	2.87E+10	1.09E+12

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSE BY STAGE	0.410	0.443	0.331	0.360	0.334	0.323	0.294
HOLE DIAMETERS BY STAGE (CENTIMETERS)	0.3618	0.2414	0.1737	0.1266	0.0918	0.0719	0.0566
NUMBER OF HOLES PER STAGE	1	1	1	1	1	1	1

PETCI-24 13:50-15:38 11/1/82

INLET SAMPLE

CASCADE IMPACTOR NUMBER = X

IMPACTOR FLOWRATE = .031 ACFM

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 56.00 MIN

IMPACTOR PRESSURE DROP = 0.4 IN. OF HG

STACK TEMPERATURE = 300.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.00 GM/CC, CM.

STACK PRESSURE = 28.14 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO2 = 10.83

CU = 0.00

N2 = 75.75

O2 = 6.02

SO2 = 0.00

H2O = 7.40

CALC. MASS LOADING = 2.2704E-01 GR/ACF

3.7410E-01 GR/DNCF

5.1955E+02 MG/ACM

8.5606E+02 MG/DNCF

IMPACTOR STAGE

S0

S1

S2

S3

S4

S5

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

8.40

4.27

2.67

1.85

0.71

0.49

MASS (MILLIGRAMS)

22.89

0.60

0.49

0.37

0.35

0.23

0.61

MG/DNCF/STAGE

7.67E+02

2.01E+01

1.64E+01

1.24E+01

1.17E+01

7.71E+00

2.04E+01

CUM. PERCENT OF MASS SMALLER THAN D50

10.38

8.03

6.11

4.66

3.29

2.39

CUM. (MG/ACM) SMALLER THAN D50

5.39E+01

4.17E+01

3.17E+01

2.42E+01

1.71E+01

1.24E+01

CUM. (MG/DNCF) SMALLER THAN D50

8.88E+01

6.87E+01

5.23E+01

3.99E+01

2.82E+01

2.04E+01

CUM. (GR/ACF) SMALLER THAN D50

2.36E-02

1.82E-02

1.39E-02

1.06E-02

7.47E-03

5.42E-03

CUM. (GR/DNCF) SMALLER THAN D50

3.88E-02

3.00E-02

2.28E-02

1.74E-02

1.23E-02

8.93E-03

GEO. MEAN DIA. (MICROMETERS)

2.90E+01

5.99E+00

3.38E+00

2.22E+00

1.14E+00

5.86E-01

3.44E-01

DM/DLOGD (MG/DNCF)

7.13E+02

6.85E+01

8.03E+01

7.82E+01

2.80E+01

4.77E+01

6.79E+01

DN/DLOGD (NO. PARTICLES/DNCF)

2.80E+07

3.04E+08

1.99E+09

6.80E+09

1.79E+10

2.27E+11

1.60E+12

BLANK CORRECTION (MILLIGRAMS)

0.00

0.00

0.00

0.00

0.00

0.00

0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

11.93

6.09

3.82

2.67

1.05

0.74

GEO. MEAN DIA. (MICROMETERS)

4.11E+01

8.53E+00

4.83E+00

3.19E+00

1.67E+00

8.77E-01

5.20E-01

DM/DLOGD (MG/DNCF)

7.15E+02

6.89E+01

8.11E+01

7.94E+01

2.86E+01

5.05E+01

6.79E+01

DN/DLOGD (NO. PARTICLES/DNCF)

1.97E+07

2.12E+08

1.38E+09

4.65E+09

1.18E+10

1.43E+11

9.23E+11

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG. C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE

0.385

0.353

0.356

0.375

0.300

0.309

0.322

HOLE DIAMETERS BY STAGE (CENTIMETERS)

0.3554

0.2422

0.1779

0.1364

0.0884

0.0705

0.0556

NUMBER OF HOLES PER STAGE

1

1

1

1

1

1

1

PETCI-25 17:08-17:40 11/1/82

INLET SAMPLE

CASCADE IMPACTOR NUMBER = Y

IMPACTOR FLOWRATE = .031 ACFM

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 40.00 MIN

IMPACTOR PRESSURE DROP = 0.41N. OF HG

STACK TEMPERATURE = 300.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.00 GM/CC.CM,

STACK PRESSURE = 27.98 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO2 = 11.78

CO = 0.00

N2 = 78.08

O2 = 5.94

SU2 = 0.00

H2O = 4.20

CALC. MASS LOADING = 2.4580E-01 GR/ACF

3.9371E-01 GR/DNCF

5.6247E+02 MG/ACM

9.0095E+02 MG/DNCF

IMPACTOR STAGE

S0

S1

S2

S3

S4

S5

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

9.22

5.38

2.39

1.78

0.88

0.53

MASS (MILLIGRAMS)

16.89

0.97

0.78

0.44

0.25

0.09

0.33

MG/DNCF/STAGE

7.70E+02

4.42E+01

3.56E+01

2.08E+01

1.14E+01

4.11E+00

1.51E+01

CUM. PERCENT OF MASS SMALLER THAN D50

14.48

9.57

5.62

3.39

2.13

1.67

CUM. (MG/ACM) SMALLER THAN D50

8.15E+01

5.38E+01

3.16E+01

1.91E+01

1.20E+01

9.40E+00

CUM. (MG/DNCF) SMALLER THAN D50

1.30E+02

8.62E+01

5.06E+01

3.06E+01

1.92E+01

1.51E+01

CUM. (GR/ACF) SMALLER THAN D50

3.56E+02

2.35E+02

1.38E+02

8.34E+03

5.23E+03

4.11E+03

CUM. (GR/DNCF) SMALLER THAN D50

5.70E+02

3.77E+02

2.21E+02

1.34E+02

8.37E+03

6.58E+03

GEO. MEAN DIA. (MICROMETERS)

3.04E+01

7.04E+00

3.58E+00

2.06E+00

1.25E+00

6.86E-01

3.77E-01

DN/DLOGD (MG/DNCF)

7.44E+02

1.89E+02

1.01E+02

1.58E+02

3.74E+01

1.88E+01

5.00E+01

DN/DLOGD (NO. PARTICLES/DNCF)

2.54E+07

5.18E+05

2.10E+09

1.72E+10

1.81E+10

5.56E+10

6.91E+11

BLANK CORRECTION (MILLIGRAMS)

0.00

0.00

0.00

0.00

0.00

0.00

0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

13.09

7.65

3.42

2.57

1.30

0.80

GEO. MEAN DIA. (MICROMETERS)

4.30E+01

1.00E+01

5.12E+00

2.96E+00

1.82E+00

1.02E+00

5.67E-01

DN/DLOGD (MG/DNCF)

7.45E+02

1.90E+02

1.02E+02

1.61E+02

3.84E+01

1.97E+01

5.00E+01

DN/DLOGD (NO. PARTICLES/DNCF)

1.79E+07

3.62E+05

1.45E+09

1.18E+10

1.21E+10

3.56E+10

5.24E+11

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 160MM HG.

SQUARE ROOTS OF PSI BY STAGE

0.410

0.443

0.331

0.360

0.344

0.323

0.294

HOLE DIAMETERS BY STAGE (CENTIMETERS)

0.3618

0.2414

0.1737

0.1366

0.0918

0.0719

0.0566

NUMBER OF HOLES PER STAGE

1

1

1

1

1

1

1

PLTCT-26 15123-16103 11/3/82

INLET SAMPLE

CASCADE IMPACTOR NUMBER = D

IMPACTOR FLOWRATE = .030 ACFM

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 40.00 MIN

IMPACTOR PRESSURE DROP = 0.4 IN. OF HG

STACK TEMPERATURE = 300.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.00 GM/CC, CM.

STACK PRESSURE = 28.04 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO2 = 11.37

CO = 0.00

H2 = 74.46

O2 = 5.87

SO2 = 0.00

H2O = 8.30

CALC. MASS LOADING = 2.2400E-01 GR/ACF

3.7537E-01 GR/DNCF

5.1442E+02 MG/ACH

8.5897E+02 MG/DNCF

IMPACTOR STAGE

S0

S1

S2

S3

S4

S5

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

7.56

3.76

2.44

1.82

0.78

0.50

MASS (MILLIGRAMS)

15.02

0.63

0.45

0.49

0.32

0.11

0.46

MG/DNCF/STAGE

7.38E+02

3.10E+01

2.21E+01

2.41E+01

1.57E+01

5.41E+00

2.26E+01

CUM. PERCENT OF MASS SMALLER THAN D50

14.07

10.47

7.89

5.09

3.26

2.63

CUM. (MG/ACH) SMALLER THAN D50

7.24E+01

5.39E+01

4.06E+01

2.62E+01

1.68E+01

1.35E+01

CUM. (MG/DNCF) SMALLER THAN D50

1.21E+02

8.99E+01

6.78E+01

4.37E+01

2.80E+01

2.26E+01

CUM. (GR/ACF) SMALLER THAN D50

3.16E-02

2.35E-02

1.77E-02

1.14E-02

7.33E-03

5.92E-03

CUM. (GR/DNCF) SMALLER THAN D50

5.28E-02

3.93E-02

2.96E-02

1.91E-02

1.22E-02

9.86E-03

GEO. MEAN DIA. (MICROMETERS)

2.75E+01

5.33E+00

3.03E+00

2.10E+00

1.19E+00

6.23E-01

3.53E-01

DM/DLOGD (MG/DNCF)

6.58E+02

1.02E+02

1.17E+02

1.88E+02

4.26E+01

2.83E+01

7.51E+01

DN/DLOGD (NO. PARTICLES/DNCF)

3.02E+07

6.42E+08

4.03E+09

1.93E+10

2.43E+10

1.12E+11

1.62E+12

BLANK CORRECTION (MILLIGRAMS)

0.00

0.00

0.00

0.00

0.00

0.00

0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

10.75

5.37

3.50

2.62

1.14

0.75

GEO. MEAN DIA. (MICROMETERS)

3.90E+01

7.60E+00

4.34E+00

3.03E+00

1.73E+00

9.29E-01

5.34E-01

DM/DLOGD (MG/DNCF)

6.59E+02

1.03E+02

1.19E+02

1.91E+02

4.36E+01

2.99E+01

7.51E+01

DN/DLOGD (NO. PARTICLES/DNCF)

2.13E+07

4.44E+08

2.78E+09

1.32E+10

1.61E+10

7.10E+10

9.44E+11

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE

0.341

0.300

0.322

0.361

0.294

0.290

0.329

HOLE DIAMETERS BY STAGE (CENTIMETERS)

0.3560

0.2461

0.1778

0.1368

0.0937

0.0739

0.0550

NUMBER OF HOLES PER STAGE

1

1

1

1

1

1

1

PETCI-27 11142-12122 11/4/82

INLET SAMPLE

CASCADE IMPACTOR NUMBER = X

IMPACTOR FLOWRATE = .C30 ACFM

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 40.00 MIN

IMPACTOR PRESSURE DROP = 0.41N. OF HG

STACK TEMPERATURE = 300.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.00 GM/CCU.CH.

STACK PRESSURE = .28.01 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO2 = 11.57

CO = 0.00

N2 = 76.98

O2 = 6.26

SO2 = 0.00

H2O = 5.20

CALC. MASS LOADING = 2.5116E-01 GR/ACF

4.0611E-01 GR/UNCF

5.7474E+02 MG/ACM

9.2932E+02 MG/DNCM

IMPACTOR STAGE

S0

S1

S2

S3

S4

S5

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

8.55

4.35

2.72

1.89

0.72

0.50

MASS (MILLIGRAMS)

16.96

0.75

0.34

0.42

0.41

0.19

0.46

MG/DNCM/STAGE

8.07E+02

3.57E+01

1.62E+01

2.00E+01

1.95E+01

9.04E+00

2.19E+01

CUM. PERCENT OF MASS SMALLER THAN D50

13.16

9.32

7.58

5.43

3.33

2.36

CUM. (MG/ACM) SMALLER THAN D50

7.56E+01

5.36E+01

4.36E+01

3.12E+01

1.91E+01

1.35E+01

CUM. (MG/DNCM) SMALLER THAN D50

1.22E+02

8.66E+01

7.04E+01

5.04E+01

3.09E+01

2.19E+01

CUM. (GR/ACF) SMALLER THAN D50

3.31E-02

2.34E-02

1.90E-02

1.36E-02

8.36E-03

5.92E-03

CUM. (GR/DNCF) SMALLER THAN D50

5.34E-02

3.78E-02

3.08E-02

2.20E-02

1.35E-02

9.57E-03

GEO. MEAN DIA. (MICROMETERS)

2.92E+01

6.10E+00

3.44E+00

2.26E+00

1.17E+00

5.98E-01

3.51E-01

DM/DLOGD (MG/DNCM)

7.56E+02

1.22E+02

7.92E+01

1.26E+02

4.66E+01

5.62E+01

7.27E+01

DN/DLOGD (NO. PARTICLES/DNCF)

2.89E+07

5.11E+08

1.86E+09

1.04E+10

2.81E+10

2.51E+11

1.60E+12

BLANK CORRECTION (MILLIGRAMS)

0.00

0.00

0.00

0.00

0.00

0.00

0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

12.15

6.21

3.89

2.72

1.07

0.75

GEO. MEAN DIA. (MICROMETERS)

4.14E+01

8.68E+00

4.92E+00

3.25E+00

1.70E+00

8.94E-01

5.31E-01

DM/DLOGD (MG/DNCM)

7.57E+02

1.22E+02

8.00E+01

1.28E+02

4.80E+01

5.93E+01

7.27E+01

DN/DLOGD (NO. PARTICLES/DNCM)

2.03E+07

3.57E+08

1.29E+09

7.10E+09

1.86E+10

1.59E+11

9.30E+11

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE

0.385

0.353

0.356

0.375

0.300

0.309

0.322

HOLE DIAMETERS BY STAGE (CENTIMETERS)

0.3554

0.2422

0.1779

0.1364

0.0664

0.0705

0.0556

NUMBER OF HOLES PER STAGE

1

1

1

1

1

1

1

PETCI-28 09:31-10:11 11/15/82

INLET SAMPLE

CASCADE IMPACTOR NUMBER = Y

IMPACTOR FLOWRATE = .031 ACFM

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 40.00 MIN

IMPACTOR PRESSURE DROP = 0.41 IN. OF HG.

STACK TEMPERATURE = 300.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.00 GM/CC.M.

STACK PRESSURE = 28.32 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO2 = 11.04

CO = 0.00

H2 = 77.68

O2 = 6.47

SO2 = 0.00

H2O = 4.80

CALC. MASS LOADING = 3.8880E-01 GR/ACF

6.1916E-01 GR/DNCF

8.8970E+02 MG/ACM

1.4169E+03 MG/DNCF

IMPACTOR STAGE

S0

S1

S2

S3

S4

S5

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

9.22

5.38

2.39

1.78

0.85

0.53

MASS (MILLIGRAMS)

29.59

0.44

0.33

0.30

0.14

0.14

0.30

MG/DNCF/STAGE

1.34E+03

2.00E+01

1.50E+01

1.36E+01

6.35E+00

6.35E+00

1.36E+01

CUM. PERCENT OF MASS SMALLER THAN D50

5.28

3.87

2.62

1.86

1.41

0.96

CUM. (MG/ACM) SMALLER THAN D50

4.70E+01

3.45E+01

2.51E+01

1.65E+01

1.25E+01

8.54E+00

CUM. (MG/DNCF) SMALLER THAN D50

7.48E+01

5.49E+01

3.99E+01

2.63E+01

2.00E+01

1.36E+01

CUM. (GR/ACF) SMALLER THAN D50

2.05E-02

1.51E-02

1.10E-02

7.22E-03

5.48E-03

3.73E-03

CUM. (GR/DNCF) SMALLER THAN D50

3.27E-02

2.40E-02

1.74E-02

1.15E-02

8.72E-03

5.95E-03

GEO. MEAN DIA. (MICROMETERS)

3.04E+01

7.04E+00

3.58E+00

2.06E+00

1.23E+00

6.76E-01

3.78E-01

DM/DLOGD (MG/DNCF)

1.30E+03

8.53E+01

4.24E+01

1.07E+02

1.99E+01

3.12E+01

4.52E+01

DN/DLOGD (NO. PARTICLES/DNCF)

4.42E+07

2.33E+08

8.80E+08

1.17E+10

1.01E+10

9.65E+10

8.00E+11

BLANK CORRECTION (MILLIGRAMS)

0.00

0.00

0.00

0.00

0.00

0.00

0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

13.09

7.66

3.43

2.57

1.26

0.80

GEO. MEAN DIA. (MICROMETERS)

4.30E+01

1.00E+01

5.12E+00

2.97E+00

1.80E+00

1.00E+00

5.68E-01

DM/DLOGD (MG/DNCF)

1.30E+03

8.57E+01

4.28E+01

1.09E+02

2.04E+01

3.27E+01

4.52E+01

DN/DLOGD (NO. PARTICLES/DNCF)

3.11E+07

1.63E+08

6.09E+08

7.96E+09

6.73E+09

6.17E+10

4.71E+11

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE

0.410

0.443

0.331

0.360

0.334

0.323

0.294

HOLE DIAMETERS BY STAGE (CENTIMETERS)

0.3618

0.2414

0.1737

0.1366

0.0918

0.0719

0.0566

NUMBER OF HOLES PER STAGE

1

1

1

1

1

1

1

PETCI-29 10154-11134 11/15/82

INLET SAMPLE

CASCADE IMPACTOR NUMBER = D

IMPACTOR FLOWRATE = .031 ACFM

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 40.00 MIN

IMPACTOR PRESSURE DROP = 0.41 IN. OF HG

STACK TEMPERATURE = 100.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.00 GR/CC

STACK PRESSURE = 28.32 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO2 = 11.04

CU = 0.00

N2 = 77.68

O2 = 6.47

SO2 = 0.00

H2O = 4.80

CALC. MASS LOADING = 2.6795E-01 GR/ACF

4.2672E-01 GR/DNCF

6.1316E+02 MG/ACM

9.7647E+02 MG/DNCF

IMPACTOR STAGE

S0

S1

S2

S3

S4

S5

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

7.46

3.71

2.41

1.79

0.76

0.49

MASS (MILLIGRAMS)

15.22

0.85

0.52

0.42

0.36

0.11

4.03

MG/DNCF/STAGE

6.90E+02

3.86E+01

2.36E+01

1.90E+01

1.63E+01

5.90E+00

1.83E+02

CUM. PERCENT OF MASS SMALLER THAN D50

19.31

25.36

22.94

20.99

19.32

18.72

CUM. (MG/ACM) SMALLER THAN D50

1.80E+02

1.55E+02

1.41E+02

1.29E+02

1.18E+02

1.15E+02

CUM. (MG/DNCF) SMALLER THAN D50

2.86E+02

2.48E+02

2.24E+02

2.05E+02

1.89E+02

1.83E+02

CUM. (GR/ACF) SMALLER THAN D50

7.85E-02

6.80E-02

6.15E-02

5.63E-02

5.18E-02

5.02E-02

CUM. (GR/DNCF) SMALLER THAN D50

1.25E-01

1.08E-01

9.79E-02

8.96E-02

8.24E-02

7.99E-02

GEO. MEAN DIA. (MICROMETERS)

2.73E+01

5.26E+00

2.99E+00

2.08E+00

1.17E+00

6.14E-01

3.48E-01

DM/DLOGD (MG/DNCF)

6.12E+02

1.27E+02

1.25E+02

1.49E+02

4.42E+01

3.09E+01

6.07E+02

DN/DLOGD (NO. PARTICLES/DNCF)

2.87E+07

8.33E+08

4.48E+09

1.59E+10

2.63E+10

1.27E+11

1.37E+13

BLANK CORRECTION (MILLIGRAMS)

0.00

0.00

0.00

0.00

0.00

0.00

0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

10.80

5.30

3.45

2.58

1.13

0.74

GEO. MEAN DIA. (MICROMETERS)

3.87E+01

7.50E+00

4.28E+00

2.99E+00

1.71E+00

9.17E-01

5.26E-01

DM/DLOGD (MG/DNCF)

6.14E+02

1.28E+02

1.27E+02

1.51E+02

4.54E+01

3.25E+01

6.07E+02

DN/DLOGD (NO. PARTICLES/DNCF)

2.02E+07

5.80E+08

3.09E+09

1.08E+10

1.74E+10

8.07E+10

7.96E+12

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE

0.341

0.300

0.322

0.368

0.294

0.290

0.329

HOLE DIAMETERS BY STAGE (CENTIMETERS)

0.3560

0.2461

0.1778

0.1368

0.0937

0.0739

0.0550

NUMBER OF HOLES PER STAGE

1

1

1

1

1

1

1

PETCI-30 17:52-18:32 11/15/82

INLET SAMPLE

CASCADE IMPACTOR NUMBER = X

IMPACTOR FLOWRATE = .031 ACFM

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 40.00 MIN

IMPACTOR PRESSURE DROP = 0.41N. OF HG

STACK TEMPERATURE = 300.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.00 GR/CC.M.

STACK PRESSURE = 28.32 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO2 = 11.04

CO = 0.00

H2 = 77.68

O2 = 6.47

SO2 = 0.00

H2O = 4.80

CALC. MASS LOADING = 1.4325E-01 GR/ACF

2.2812E-01 GR/UNCF

3.2780E+02 MG/ACM

5.2202E+02 MG/DNCH

IMPACTOR STAGE

S0

S1

S2

S3

S4

S5

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

8.42

4.28

2.68

1.86

0.71

0.49

MASS (MILLIGRAMS)

9.86

0.42

0.46

0.24

0.16

0.11

0.26

MG/DNCH/STAGE

4.47E+02

1.90E+01

2.09E+01

1.09E+01

7.26E+00

4.99E+00

1.18E+01

CUM. PERCENT OF MASS SMALLER THAN D50

14.34

10.69

6.69

4.60

3.21

2.26

CUM. (MG/ACM) SMALLER THAN D50

4.70E+01

3.50E+01

2.19E+01

1.51E+01

1.05E+01

7.40E+00

CUM. (MG/DNCH) SMALLER THAN D50

7.48E+01

5.58E+01

3.49E+01

2.40E+01

1.68E+01

1.18E+01

CUM. (GR/ACF) SMALLER THAN D50

2.05E-02

1.53E-02

9.58E-03

6.60E-03

4.60E-03

3.24E-03

CUM. (GR/DNCF) SMALLER THAN D50

3.27E-02

2.44E-02

1.53E-02

1.05E-02

7.33E-03

5.15E-03

GEO. MEAN DIA. (MICROMETERS)

2.90E+01

6.01E+00

3.38E+00

2.23E+00

1.15E+00

5.88E-01

3.45E-01

DN/DLOGD (MG/DNCH)

4.16E+02

6.49E+01

1.02E+02

6.87E+01

1.73E+01

3.09E+01

3.92E+01

DN/DLOGD (NO. PARTICLES/DNCH)

1.63E+07

2.86E+08

2.51E+09

5.92E+09

1.10E+10

1.45E+11

9.09E+11

BLANK CORRECTION (MILLIGRAMS)

0.00

0.00

0.00

0.00

0.00

0.00

0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

11.96

6.11

3.83

2.68

1.05

0.74

GEO. MEAN DIA. (MICROMETERS)

4.11E+01

8.55E+00

4.64E+00

3.20E+00

1.67E+00

8.79E-01

5.22E-01

DN/DLOGD (MG/DNCH)

4.17E+02

6.53E+01

1.03E+02

6.97E+01

1.78E+01

3.27E+01

3.92E+01

DN/DLOGD (NO. PARTICLES/DNCH)

1.14E+07

2.00E+08

1.74E+09

4.05E+09

7.25E+09

9.18E+10

5.27E+11

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE

0.345

0.353

0.356

0.375

0.300

0.309

0.322

HOLE DIAMETERS BY STAGE (CENTIMETERS)

0.3554

0.2422

0.1779

0.1364

0.0884

0.0705

0.0556

NUMBER OF HOLES PER STAGE

1

1

1

1

1

1

1

PETCI-32 00141-09121 11/16/82

IMPACTOR FLOWRATE = .031 ACFM

IMPACTOR PRESSURE DROP = 0.4IN. OF HG

ASSUMED PARTICLE DENSITY = 2.00 GM/CC, CH

GAS COMPOSITION (PERCENT) CO2 = 10.50

CALC. MASS LOADING = 1.3902E-01 GR/ACF

IMPACTOR STAGE

STAGE INDEX NUMBER

D50 (MICROMETERS)

MASS (MILLIGRAMS)

MG/DNCH/STAGE

CUM. PERCENT OF MASS SMALLER THAN D50

CUM. (MG/ACH) SMALLER THAN D50

CUM. (MG/DNCH) SMALLER THAN D50

CUM. (GR/ACF) SMALLER THAN D50

CUM. (GR/DNCF) SMALLER THAN D50

GEO. MEAN DIA. (MICROMETERS)

DM/DLOGD (MG/DNCH)

DN/DLOGD (NO. PARTICLES/DNCH)

BLANK CORRECTION (MILLIGRAMS)

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

GEO. MEAN DIA. (MICROMETERS)

DM/DLOGD (MG/DNCH)

DN/DLOGD (NO. PARTICLES/DNCH)

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE

HOLE DIAMETERS BY STAGE (CENTIMETERS)

NUMBER OF HOLES PER STAGE

INLET SAMPLE

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

STACK TEMPERATURE = 300.0 F = 148.9 C

STACK PRESSURE = 28.22 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

CASCADE IMPACTOR NUMBER = X

SAMPLING DURATION = 40.00 MIN

CO = 0.00 H2 = 75.34 G2 = 7.06 SO2 = 0.00 H2O = 7.10

2.2767E-01 GR/DNCF 3.1812E+02 MG/ACH 5.2098E+02 MG/DNCH

	S0	S1	S2	S3	S4	S5	FILTER
	1	2	3	4	5	6	7
D50 (MICROMETERS)	8.41	4.28	2.67	1.65	0.71	0.49	
MASS (MILLIGRAMS)	9.21	0.55	0.37	0.35	0.26	0.12	0.29
MG/DNCH/STAGE	4.31E+02	2.57E+01	1.73E+01	1.63E+01	1.21E+01	5.60E+00	1.35E+01
CUM. PERCENT OF MASS SMALLER THAN D50	17.37	12.44	9.13	6.00	3.67	2.60	
CUM. (MG/ACH) SMALLER THAN D50	5.53E+01	3.96E+01	2.90E+01	1.51E+01	1.17E+01	8.26E+00	
CUM. (MG/DNCH) SMALLER THAN D50	9.05E+01	6.48E+01	4.76E+01	3.12E+01	1.91E+01	1.35E+01	
CUM. (GR/ACF) SMALLER THAN D50	2.41E-02	1.73E-02	1.27E-02	8.34E-03	5.10E-03	3.61E-03	
CUM. (GR/DNCF) SMALLER THAN D50	3.95E-02	2.83E-02	2.08E-02	1.37E-02	8.36E-03	5.91E-03	
GEO. MEAN DIA. (MICROMETERS)	2.90E+01	6.00E+00	3.38E+00	2.23E+00	1.14E+00	5.87E-01	3.44E-01
DM/DLOGD (MG/DNCH)	4.00E+02	8.74E+01	8.44E+01	1.63E+02	2.89E+01	3.47E+01	4.49E+01
DN/DLOGD (NO. PARTICLES/DNCH)	1.57E+07	3.87E+08	2.08E+09	8.91E+09	1.84E+10	1.64E+11	1.05E+12
BLANK CORRECTION (MILLIGRAMS)	0.00	0.00	0.00	0.00	0.00	0.00	0.00

	S0	S1	S2	S3	S4	S5	FILTER
	1	2	3	4	5	6	7
D50 (MICROMETERS)	11.95	6.10	3.83	2.67	1.05	0.74	
GEO. MEAN DIA. (MICROMETERS)	4.11E+01	8.54E+00	4.83E+00	3.20E+00	1.67E+00	8.78E-01	5.21E-01
DM/DLOGD (MG/DNCH)	4.01E+02	8.79E+01	8.53E+01	1.84E+02	2.98E+01	3.67E+01	4.49E+01
DN/DLOGD (NO. PARTICLES/DNCH)	1.10E+07	2.70E+08	1.44E+09	6.08E+09	1.22E+10	1.04E+11	6.08E+11

	S0	S1	S2	S3	S4	S5	FILTER
	1	1	1	1	1	1	1
SQUARE ROOTS OF PSI BY STAGE	0.385	0.353	0.346	0.375	0.300	0.309	0.322
HOLE DIAMETERS BY STAGE (CENTIMETERS)	0.3554	0.2422	0.1779	0.1364	0.0834	0.0705	0.0556

PETCI-33 10:16-10:56 11/16/82

INLET SAMPLE

CASCADE IMPACTOR NUMBER - Y

IMPACTOR FLOWRATE = .031 ACFM

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 40.00 MIN

IMPACTOR PRESSURE DROP = 0.41 IN. OF HG

STACK TEMPERATURE = 300.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.00 GM/CC

STACK PRESSURE = 28.22 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO2 = 10.50

CU = 0.00 N2 = 75.34

O2 = 7.06

SO2 = 0.00

H2O = 7.10

CALC. MASS LOADING = 1.0740E-01 GR/ACF

1.7590E-01 GR/DNCF

2.4578E+02 MG/ACM

4.0252E+02 MG/DNCF

IMPACTOR STAGE

S0

S1

S2

S3

S4

S5

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

9.21

5.37

2.38

1.78

0.85

0.53

MASS (MILLIGRAMS)

6.71

0.51

0.46

0.32

0.26

0.08

0.29

MG/DNCF/STAGE

3.13E+02

2.38E+01

2.15E+01

1.49E+01

1.21E+01

3.73E+00

1.35E+01

CUM. PERCENT OF MASS SMALLER THAN D50

22.25

16.34

11.01

7.30

4.29

3.36

CUM. (MG/ACM) SMALLER THAN D50

5.47E+01

4.02E+01

2.71E+01

1.79E+01

1.05E+01

8.26E+00

CUM. (MG/DNCF) SMALLER THAN D50

8.96E+01

6.58E+01

4.43E+01

2.94E+01

1.73E+01

1.35E+01

CUM. (GR/ACF) SMALLER THAN D50

2.39E-02

1.75E-02

1.18E-02

7.84E-03

4.60E-03

3.61E-03

CUM. (GR/DNCF) SMALLER THAN D50

3.91E-02

2.87E-02

1.94E-02

1.28E-02

7.54E-03

5.91E-03

GEO. MEAN DIA. (MICROMETERS)

3.04E+01

7.04E+00

3.58E+00

2.06E+00

1.23E+00

6.74E-01

3.77E-01

DN/DLOGD (MG/DNCF)

3.02E+02

1.02E+02

6.08E+01

1.18E+02

3.79E+01

1.83E+01

4.49E+01

DN/DLOGD (NO. PARTICLES/DNCF)

1.03E+07

2.79E+08

1.27E+09

1.28E+10

1.94E+10

5.70E+10

8.01E+11

BLANK CORRECTION (MILLIGRAMS)

0.00

0.00

0.00

0.00

0.00

0.00

0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

13.08

7.65

3.42

2.57

1.25

0.80

GEO. MEAN DIA. (MICROMETERS)

4.30E+01

1.06E+01

5.12E+00

2.96E+00

1.79E+00

1.00E+00

5.67E-01

DN/DLOGD (MG/DNCF)

3.03E+02

1.02E+02

6.14E+01

1.19E+02

3.90E+01

1.92E+01

4.49E+01

DN/DLOGD (NO. PARTICLES/DNCF)

7.27E+06

1.95E+08

8.75E+08

8.76E+09

1.29E+10

3.64E+10

4.71E+11

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE

0.410

0.443

0.331

0.360

0.334

0.323

0.294

NOSE DIAMETERS BY STAGE (CENTIMETERS)

0.3618

0.2414

0.1737

0.1366

0.0918

0.0719

0.0566

NUMBER OF HOLES PER STAGE

1

1

1

1

1

1

1

PETCI-35 08155-09135 11/17/82

IMPACTOR FLOWRATE = .032 ACFM

IMPACTOR PRESSURE DROP = 0.41 IN. OF HG

ASSUMED PARTICLE DENSITY = 2.00 GM/CC.CM.

GAS COMPOSITION (PERCENT) CO2 = 10.50

CALC. MASS LOADING = 1.3727E+01 GR/ACF

IMPACTOR STAGE

STAGE INDEX NUMBER

D50 (MICROMETERS)

MASS (MILLIGRAMS)

MG/DNCH/STAGE

CUM. PERCENT OF MASS SMALLER THAN D50

CUM. (MG/ACM) SMALLER THAN D50

CUM. (MG/DNCH) SMALLER THAN D50

CUM. (GR/ACF) SMALLER THAN D50

CUM. (GR/DNCF) SMALLER THAN D50

GEO. MEAN DIA. (MICROMETERS)

DN/LLOGD (MG/DNCH)

DN/ELOGD (NO. PARTICLES/DNCH)

BLANK CORRECTION (MILLIGRAMS)

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

GEO. MEAN DIA. (MICROMETERS)

DN/ELOGD (MG/DNCH)

DN/LLOGD (NO. PARTICLES/DNCH)

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE

HOLE DIAMETERS BY STAGE (CENTIMETERS)

NUMBER OF HOLES PER STAGE

INLET SAMPLE

IMPACTOR TEMPERATURE = 295.0 F = 146.1 C

STACK TEMPERATURE = 295.0 F = 146.1 C

STACK PRESSURE = 28.26 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

CO = 0.00 H2 = 75.34 O2 = 7.06 SO2 = 0.00 H2O = 7.10

2.2332E+01 GR/DNCF 3.1413E+02 MG/ACM 5.1034E+02 MG/DNCH

S0 S1 S2 S3 S4 S5 FILTER

1 2 3 4 5 6 7

0.26 4.20 2.62 1.82 0.69 0.46

6.62 0.36 0.29 0.25 0.14 0.06 0.25

4.24E+02 2.31E+01 1.06E+01 1.60E+01 0.96E+00 3.84E+00 1.60E+01

16.94 12.42 8.78 5.65 3.89 3.14

5.32E+01 3.90E+01 2.76E+01 1.77E+01 1.22E+01 9.85E+00

8.64E+01 6.34E+01 4.48E+01 2.88E+01 1.99E+01 1.60E+01

2.33E+02 1.71E+02 1.21E+02 7.75E+03 5.34E+03 4.31E+03

3.78E+02 2.77E+02 1.96E+02 1.26E+02 8.67E+03 7.00E+03

2.87E+01 5.89E+00 3.32E+00 2.18E+00 1.12E+00 5.75E+01 3.37E+01

3.91E+02 7.85E+01 9.06E+01 1.01E+02 2.14E+01 2.37E+01 5.32E+01

1.57E+07 3.67E+08 2.37E+09 9.24E+09 1.44E+10 1.19E+11 1.32E+12

0.00 0.00 0.00 0.00 0.00 0.00 0.00

11.73 5.99 3.76 2.62 1.03 0.72

4.07E+01 8.38E+00 4.74E+00 3.14E+00 1.64E+00 8.61E+01 5.10E+01

3.92E+02 7.90E+01 9.17E+01 1.02E+02 2.20E+01 2.51E+01 5.32E+01

1.11E+07 2.58E+08 1.64E+09 6.32E+09 9.52E+09 7.52E+10 7.63E+11

0.365 0.353 0.356 0.375 0.300 0.309 0.322

0.3554 0.2422 0.1779 0.1364 0.0864 0.0705 0.0556

1 1 1 1 1 1 1

PETCI-37 08155-09,35 11/17/62

INLET SAMPLE

CASCADE IMPACTOR NUMBER = X

IMPACTOR FLOWRATE = .016 ACFM

IMPACTOR TEMPERATURE = 295.0 F = 146.1 C

SAMPLING DURATION = 40.00 MIN

IMPACTOR PRESSURE DROP = 0.1 IN. OF HG

STACK TEMPERATURE = 295.0 F = 146.1 C

ASSUMED PARTICLE DENSITY = 2.00 GM/CC

STACK PRESSURE = 28.26 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO2 = 11.50

CO = 0.00

N2 = 75.36

O2 = 6.64

SO2 = 0.00

H2O = 6.50

CALC. MASS LOADING = 2.9105E-01 GR/ACF

4.6981E-01 GR/DNCF

6.6601E+02 MG/ACM

1.0751E+03 MG/DNCF

IMPACTOR STAGE

S0

S1

S2

S3

S4

S5

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

11.72

5.99

3.76

2.62

1.03

0.72

MASS (MILLIGRAMS)

5.25

0.29

0.21

0.22

0.20

0.14

5.76

MG/DNCF/STAGE

4.68E+02

2.58E+01

1.87E+01

1.96E+01

1.78E+01

1.25E+01

5.13E+02

CUM. PERCENT OF MASS SMALLER THAN D50

56.50

54.10

52.36

50.54

48.88

47.72

CUM. (MG/ACM) SMALLER THAN D50

3.76E+02

3.60E+02

3.49E+02

3.37E+02

3.26E+02

3.18E+02

CUM. (MG/DNCF) SMALLER THAN D50

6.07E+02

5.82E+02

5.63E+02

5.43E+02

5.26E+02

5.13E+02

CUM. (GR/ACF) SMALLER THAN D50

1.64E-01

1.57E-01

1.52E-01

1.47E-01

1.42E-01

1.39E-01

CUM. (GR/DNCF) SMALLER THAN D50

2.65E-01

2.54E-01

2.46E-01

2.37E-01

2.30E-01

2.24E-01

GEO. MEAN DIA. (MICROMETERS)

3.42E+01

8.38E+00

4.74E+00

3.14E+00

1.64E+00

8.62E-01

5.11E-01

DM/DLOGD (MG/DNCF)

5.02E+02

8.85E+01

9.24E+01

1.25E+02

4.38E+01

8.18E+01

1.70E+03

DN/DLOGD (NO. PARTICLES/DNCF)

1.19E+07

1.44E+08

6.27E+08

3.87E+09

9.46E+09

1.22E+11

1.22E+13

BLANK CORRECTION (MILLIGRAMS)

0.00

0.00

0.00

0.00

0.00

0.00

0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

16.63

8.52

5.36

3.76

1.50

1.07

GEO. MEAN DIA. (MICROMETERS)

4.85E+01

1.19E+01

6.76E+00

4.49E+00

2.37E+00

1.27E+00

7.56E-01

DM/DLOGD (MG/DNCF)

5.03E+02

8.89E+01

9.31E+01

1.27E+02

4.47E+01

8.49E+01

1.70E+03

DN/DLOGD (NO. PARTICLES/DNCF)

8.42E+06

1.01E+08

5.76E+08

2.68E+09

6.37E+09

7.99E+10

7.53E+12

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE

0.385

0.353

0.356

0.375

0.300

0.309

0.322

HOLE DIAMETERS BY STAGE (CENTIMETERS)

0.3554

0.2422

0.1779

0.1364

0.0884

0.0705

0.0556

NUMBER OF HOLES PER STAGE

1

1

1

1

1

1

1

PETC1-41 14:32-14:40 11/18/62

IMPACTOR FLOWRATE = .312 ACFM

IMPACTOR PRESSURE DROP = 0.21 IN. OF HG

ASSUMED PARTICLE DENSITY = 2.00 GM/CC, CM.

GAS COMPOSITION (PERCENT) CO₂ = 15.49

CALC. MASS LOADING = 7.6361E-02 GR/ACF

IMPACTOR STAGE

STAGE INDEX NUMBER

D50 (MICROMETERS)

MASS (MILLIGRAMS)

MG/DNCH/STAGE

CUM. PERCENT OF MASS SMALLER THAN D50

CUM. (MG/ACM) SMALLER THAN D50

CUM. (MG/DNCH) SMALLER THAN D50

CUM. (GR/ACF) SMALLER THAN D50

CUM. (GR/DNCF) SMALLER THAN D50

GEO. MEAN DIA. (MICROMETERS)

DM/DLOGD (MG/DNCH)

DN/DLOGD (NO. PARTICLES/DNCH)

BLANK CORRECTION (MILLIGRAMS)

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

GEO. MEAN DIA. (MICROMETERS)

DM/DLOGD (MG/DNCH)

DN/DLOGD (NO. PARTICLES/DNCH)

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE

HOLE DIAMETERS BY STAGE (CENTIMETERS)

NUMBER OF HOLES PER STAGE

INLET SAMPLE

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

STACK TEMPERATURE = 300.0 F = 148.9 C

STACK PRESSURE = 28.27 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

SAMPLING DURATION = 28.00 MIN

CASCADE IMPACTOR NUMBER - D

	S0	S1	S2	S3	S4	S5	FILTER
1	2	3	4	5	6	7	
11.55	11.55	5.11	2.34	1.37	0.66		
0.00	30.13	7.29	0.97	0.22	0.17		1.04
0.00E+00	1.98E+02	4.80E+01	6.38E+00	1.45E+00	1.12E+00		6.84E+00
100.00	24.35	6.05	3.62	3.06	2.64		
1.61E+02	3.92E+01	9.74E+00	5.82E+00	4.93E+00	4.24E+00		
2.62E+02	6.38E+01	1.59E+01	9.48E+00	8.03E+00	6.91E+00		
7.04E-02	1.71E-02	4.26E-03	2.54E-03	2.16E-03	1.85E-03		
1.15E-01	2.79E-02	6.93E-03	4.14E-03	3.51E-03	3.02E-03		
3.40E+01	1.15E+01	7.68E+00	3.46E+00	1.79E+00	9.49E-01		4.67E-01
0.00E+00	1.80E+08	1.36E+02	1.89E+01	6.17E+00	3.54E+00		2.27E+01
0.00E+00	1.11E+14	2.85E+08	4.34E+08	1.03E+09	3.95E+09		2.13E+11
0.00	0.00	0.00	0.00	0.00	0.00		0.00
16.38	16.38	7.28	3.36	1.98	0.98		
4.81E+01	1.64E+01	1.09E+01	4.95E+00	2.58E+00	1.39E+00		6.92E-01
0.00E+00	2.83E+08	1.36E+02	1.90E+01	6.28E+00	3.66E+00		2.27E+01
0.00E+00	1.23E+14	2.00E+08	3.00E+08	6.98E+08	2.59E+09		1.31E+11
0.144	0.144	0.371	0.341	0.350	0.331		0.365
1.8237	1.8237	0.2483	0.0812	0.0532	0.0358		0.0249
1	1	12	90	110	110		90

PETCO-7 10:52-11:23 10/28/32

OUTLET SAMPLE

CASCADE IMPACTOR NUMBER = X

IMPACTOR FLOWRATE = .487 ACFM

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 30.00 MIN

IMPACTOR PRESSURE DROP = 0.4 IN. OF HG

STACK TEMPERATURE = 300.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.00 GM/CC

STACK PRESSURE = 29.52 IN. OF HG

MAX. PARTICLE DIAMETER = 20.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO2 = 11.42

CO = 0.00

N2 = 77.49

O2 = 6.28

SO2 = 0.00

H2O = 4.80

CALC. MASS LOADING = 9.4802E-02 GR/ACF

1.4084E-01 GR/DNCF

2.1694E+02 MG/ACH

3.3143E+02 MG/DNCH

IMPACTOR STAGE

S1

S2

S3

S4

S5

S6

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

9.25

4.08

1.86

1.08

0.51

0.25

MASS (MILLIGRAMS)

53.22

14.61

5.98

4.75

2.95

2.16

6.08

MG/DNCH/STAGE

1.97E+02

5.40E+01

2.21E+01

1.75E+01

1.09E+01

7.98E+00

2.25E+01

CUM. PERCENT OF MASS SMALLER THAN D50

40.70

24.42

17.76

12.47

9.18

6.77

CUM. (MG/ACH) SMALLER THAN D50

8.83E+01

5.30E+01

3.85E+01

2.70E+01

1.99E+01

1.47E+01

CUM. (MG/DNCH) SMALLER THAN D50

1.35E+02

8.09E+01

5.89E+01

4.13E+01

3.04E+01

2.25E+01

CUM. (GR/ACF) SMALLER THAN D50

3.86E-02

2.32E-02

1.68E-02

1.18E-02

8.70E-03

6.42E-03

CUM. (GR/DNCF) SMALLER THAN D50

5.90E-02

3.54E-02

2.57E-02

1.81E-02

1.33E-02

9.81E-03

GEO. MEAN DIA. (MICROMETERS)

1.36E+01

6.14E+00

2.76E+00

1.41E+00

7.40E-01

3.56E-01

1.76E-01

DM/DLOGD (MG/DNCH)

5.87E+02

1.52E+02

6.47E+01

7.37E+01

3.35E+01

2.58E+01

7.46E+01

DN/DLOGD (NO. PARTICLES/DNCH)

2.23E+08

6.25E+08

2.95E+09

2.48E+10

7.91E+10

5.44E+11

1.30E+13

BLANK CORRECTION (MILLIGRAMS)

0.00

0.00

0.00

0.00

0.00

0.00

0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

13.13

5.82

2.56

1.57

0.77

0.40

GEO. MEAN DIA. (MICROMETERS)

1.93E+01

8.74E+00

3.95E+00

2.05E+00

1.09E+00

5.51E-01

2.80E-01

DM/DLOGD (MG/DNCH)

5.90E+02

1.53E+02

6.55E+01

7.53E+01

3.50E+01

2.79E+01

7.46E+01

DN/DLOGD (NO. PARTICLES/DNCH)

1.57E+08

4.37E+08

2.93E+09

1.67E+10

5.09E+10

3.19E+11

6.48E+12

NORMAL (ENGINEERING STANDARDS) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PST BY STAGE

0.144

0.144

0.371

0.341

0.350

0.331

0.365

HOLE DIAMETERS BY STAGE (CENTIMETERS)

1.8237

1.8237

0.2483

0.3812

0.0532

0.0358

0.0249

NUMBER OF HOLES PER STAGE

1

1

12

90

110

110

90

PETCO-9 13:43-15:43 11/1/82

OUTLET SAMPLE

CASCADE IMPACTOR NUMBER = D

IMPACTOR FLOWRATE = .499 ACFM

IMPACTOR TEMPERATURE = 241.0 F = 116.1 C

SAMPLING DURATION = 120.00 MIN

IMPACTOR PRESSURE DROP = 0.5 IN. OF HG

STACK TEMPERATURE = 241.0 F = 116.1 C

ASSUMED PARTICLE DENSITY = 2.00 GM/CC

STACK PRESSURE = 29.20 IN. OF HG

MAX. PARTICLE DIAMETER = 20.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO2 = 9.08

CO = 0.00 N2 = 76.10

O2 = 8.42 SO2 = 0.00 H2O = 6.40

CALC. MASS LOADING = 1.1623E-03 GR/ACF

1.6941E-03 GR/DNCF

2.6598E+00 MG/ACM

3.8537E+00 MG/DNCF

IMPACTOR STAGE

S1 S2 S3 S4 S5 S6 FILTER

STAGE INDEX NUMBER

1 2 3 4 5 6 7

D50 (MICROMETERS)

8.89 3.94 1.79 1.04 0.49 0.24

MASS (MILLIGRAMS)

1.78 0.98 0.48 0.44 0.29 0.16 0.38

MG/DNCF/STAGE

1.52E+00 8.37E-01 4.10E-01 3.76E-01 2.48E-01 1.37E-01 3.25E-01

CUM. PERCENT OF MASS SMALLER THAN D50

60.53 38.80 28.16 18.40 11.97 8.43

CUM. (MG/ACM) SMALLER THAN D50

1.61E+00 1.03E+00 7.49E-01 4.89E-01 3.18E-01 2.24E-01

CUM. (MG/DNCF) SMALLER THAN D50

2.33E+00 1.50E+00 1.09E+00 7.09E-01 4.61E-01 3.25E-01

CUM. (GR/ACF) SMALLER THAN D50

7.04E-04 4.51E-04 3.27E-04 2.14E-04 1.39E-04 9.79E-05

CUM. (GR/DNCF) SMALLER THAN D50

1.02E-03 6.53E-04 4.74E-04 3.10E-04 2.02E-04 1.42E-04

GEO. MEAN DIA. (MICROMETERS)

1.33E+01 5.91E+00 2.66E+00 1.36E+00 7.15E-01 3.46E-01 1.72E-01

DM/DLOGD (MG/DNCF)

4.32E+00 2.37E+00 1.20E+00 1.58E+00 7.67E-01 4.45E-01 1.08E+00

DN/DLOGD (NO. PARTICLES/DNCF)

1.74E+06 1.09E+07 6.12E+07 5.97E+08 2.01E+09 1.03E+10 2.03E+11

BLANK CORRECTION (MILLIGRAMS)

0.00 0.00 0.00 0.00 0.00 0.00 0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

12.62 5.61 2.58 1.51 0.74 0.38

GEO. MEAN DIA. (MICROMETERS)

1.89E+01 8.41E+00 3.80E+00 1.97E+00 1.06E+00 5.33E-01 2.72E-01

DM/DLOGD (MG/DNCF)

4.34E+00 2.38E+00 1.21E+00 1.62E+00 7.99E-01 4.82E-01 1.08E+00

DN/DLOGD (NO. PARTICLES/DNCF)

1.23E+06 7.63E+06 4.22E+07 4.03E+08 1.30E+09 6.08E+09 1.03E+11

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760 MM HG.

SQUARE ROOTS OF PSI BY STAGE

0.144 0.144 0.371 0.341 0.350 0.331 0.365

HOLE DIAMETERS BY STAGE (CENTIMETERS)

1.8237 1.8237 0.2487 0.0812 0.0532 0.0358 0.0249

NUMBER OF HOLES PER STAGE

1 1 12 90 110 110 90

PETCI-52 15:35-15:47 12/6/82

INLET SAMPLE

CASCADE IMPACTOR NUMBER = Y

IMPACTOR FLOWRATE = .312 ACF

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 12.00 MIN

IMPACTOR PRESSURE DROP = 0.1 IN. OF HG

STACK TEMPERATURE = 300.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.00 GR/CC

STACK PRESSURE = 27.94 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO2 = 12.27

CO = 0.00

N2 = 73.60

O2 = 4.33

SO2 = 0.00

H2O = 9.80

CALC. MASS LOADING = 4.0948E-02 GR/ACF

6.9591E-02 GR/DNCF

9.3474E+01 MG/ACM

1.5925E+02 MG/DNCF

IMPACTOR STAGE

S1

S2

S3

S4

S5

S6

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

11.52

5.09

2.52

1.42

0.72

0.39

MASS (MILLIGRAMS)

2.23

2.79

1.02

0.96

0.59

0.21

2.12

MG/DNCF/STAGE

3.58E+01

4.48E+01

1.54E+01

1.54E+01

9.32E+00

3.37E+00

3.41E+01

CUM. PERCENT OF MASS SMALLER THAN D50

77.50

49.34

39.05

29.36

23.51

21.39

CUM. (MG/ACM) SMALLER THAN D50

7.24E+01

4.61E+01

3.65E+01

2.74E+01

2.20E+01

2.00E+01

CUM. (MG/DNCF) SMALLER THAN D50

1.23E+02

7.86E+01

6.22E+01

4.68E+01

3.74E+01

3.41E+01

CUM. (GR/ACF) SMALLER THAN D50

3.17E-02

2.02E-02

1.80E-02

1.20E-02

9.60E-03

8.74E-03

CUM. (GR/DNCF) SMALLER THAN D50

5.39E-02

3.43E-02

2.72E-02

2.04E-02

1.64E-02

1.49E-02

GEO. MEAN DIA. (MICROMETERS)

3.39E+01

7.66E+00

3.58E+00

1.89E+00

1.01E+00

5.31E-01

2.78E-01

DN/DLOGD (MG/DNCF)

3.82E+01

1.27E+02

5.35E+01

6.21E+01

3.13E+01

1.30E+01

1.13E+02

DN/DLOGD (NO. PARTICLES/DNCF)

9.33E+05

2.69E+08

1.11E+09

8.78E+09

2.92E+10

8.29E+10

5.01E+12

BLANK CORRECTION (MILLIGRAMS)

0.08

0.16

0.08

0.08

0.08

0.08

0.25

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

16.34

7.26

3.61

2.06

1.06

0.60

GEO. MEAN DIA. (MICROMETERS)

4.81E+01

1.09E+01

5.12E+00

2.72E+00

1.48E+00

8.00E-01

4.27E-01

DN/DLOGD (MG/DNCF)

3.82E+01

1.27E+02

5.40E+01

6.32E+01

3.24E+01

1.38E+01

1.13E+02

DN/DLOGD (NO. PARTICLES/DNCF)

6.57E+05

1.88E+08

7.70E+08

5.97E+09

1.92E+10

5.15E+10

2.77E+12

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE

0.144

0.144

0.371

0.342

0.351

0.380

0.358

HOLE DIAMETERS BY STAGE (CENTIMETERS)

1.8237

1.8237

0.2483

0.0850

0.0546

0.0344

0.0276

NUMBER OF HOLES PER STAGE

1

1

12

40

110

110

40

PETCI-53 09:56-10:10 12/7/82

INLET SAMPLE

CASCADE IMPACTOR NUMBER = Y

IMPACTOR FLOWRATE = .312 ACFM

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 12.00 MIN

IMPACTOR PRESSURE DROP = 0.11 IN. OF HG

STACK TEMPERATURE = 300.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.00 GM/CM³

STACK PRESSURE = 27.94 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO₂ = 12.27

CO = 0.00

N₂ = 73.60

O₂ = 4.33

SO₂ = 0.00

H₂O = 9.80

CALC. MASS LOADING = 3.9818E-02 GR/ACF

6.7835E-02 GR/DNCF

9.1116E+01 MG/ACM

1.5523E+02 MG/DNCF

IMPACTOR STAGE

S1

S2

S3

S4

S5

S6

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

11.52

5.09

2.52

1.42

0.72

0.39

MASS (MILLIGRAMS)

1.64

2.89

0.97

0.80

0.49

0.16

2.71

MG/DNCF/STAGE

2.64E+01

4.64E+01

1.56E+01

1.29E+01

7.87E+00

2.57E+00

4.35E+01

CUM. PERCENT OF MASS SMALLER THAN D50

83.02

53.11

43.06

34.78

29.71

28.05

CUM. (MG/ACM) SMALLER THAN D50

7.56E+01

4.84E+01

3.92E+01

3.17E+01

2.71E+01

2.56E+01

CUM. (MG/DNCF) SMALLER THAN D50

1.29E+02

8.24E+01

6.68E+01

5.40E+01

4.61E+01

4.35E+01

CUM. (GR/ACF) SMALLER THAN D50

3.31E-02

2.11E-02

1.71E-02

1.38E-02

1.18E-02

1.12E-02

CUM. (GR/DNCF) SMALLER THAN D50

5.63E-02

3.60E-02

2.92E-02

2.36E-02

2.02E-02

1.90E-02

GEO. MEAN DIA. (MICROMETERS)

3.39E+01

7.66E+00

3.58E+00

1.89E+00

1.01E+00

5.31E-01

2.78E-01

DM/DLOGD (MG/DNCF)

2.81E+01

1.31E+02

5.09E+01

5.18E+01

2.65E+01

9.90E+00

1.45E+02

DN/DLOGD (NO. PARTICLES/DNCF)

6.86E+05

2.79E+08

1.06E+09

7.32E+09

2.47E+10

6.32E+10

6.40E+12

BLANK CORRECTION (MILLIGRAMS)

0.08

0.16

0.08

0.08

0.08

0.08

0.25

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

16.34

7.26

3.61

2.06

1.06

0.60

GEO. MEAN DIA. (MICROMETERS)

4.81E+01

1.09E+01

5.12E+00

2.72E+00

1.48E+00

8.00E-01

4.27E-01

DM/DLOGD (MG/DNCF)

2.81E+01

1.32E+02

5.14E+01

5.27E+01

2.73E+01

1.05E+01

1.45E+02

DN/DLOGD (NO. PARTICLES/DNCF)

4.83E+05

1.95E+08

7.32E+08

4.98E+09

1.62E+10

3.92E+10

3.54E+12

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE

0.144

0.144

0.371

0.342

0.351

0.380

0.358

NOSE DIAMETERS BY STAGE (CENTIMETERS)

1.8237

1.8237

0.2483

0.0850

0.0546

0.0344

0.0276

NUMBER OF HOLES PER STAGE

1

1

12

90

110

110

90

PETCI-54 09:35-09:47 12/9/82

INLET SAMPLE

CASCADE IMPACTOR NUMBER = Y

IMPACTOR FLOWRATE = .312 ACFM

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 12.00 MIN

IMPACTOR PRESSURE DROP = 0.11 IN. OF HG

STACK TEMPERATURE = 300.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.00 GM/CC.CH.

STACK PRESSURE = 27.94 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO₂ = 12.27 CH₄ = 0.00 N₂ = 73.50 O₂ = 4.33 SO₂ = 0.00 H₂O = 9.80

CALC. MASS LOADING = 2.943DE-02 GR/ACF

5.0139E-02 GR/DNCF

6.7347E+01 MG/ACM

1.1473E+02 MG/DNCF

IMPACTOR STAGE	S1	S2	S3	S4	S5	S6	FILTER
STAGE INDEX NUMBER	1	2	3	4	5	6	7
D50 (MICROMETERS)	11.52	5.09	2.52	1.42	0.72	0.39	
MASS (MILLIGRAMS)	2.03	1.95	0.63	0.59	0.35	0.17	1.42
MG/DNCF/STAGE	3.26E+01	3.13E+01	1.01E+01	9.48E+00	5.62E+00	2.73E+00	2.28E+01
CUM. PERCENT OF MASS SMALLER THAN D50	71.57	44.25	35.43	27.17	22.27	19.89	
CUM. (MG/ACM) SMALLER THAN D50	4.82E+01	2.93E+01	2.39E+01	1.83E+01	1.50E+01	1.34E+01	
CUM. (MG/DNCF) SMALLER THAN D50	8.21E+01	5.03E+01	4.07E+01	3.12E+01	2.56E+01	2.28E+01	
CUM. (GR/ACF) SMALLER THAN D50	2.11E-02	1.30E-02	1.04E-02	8.00E-03	6.56E-03	5.85E-03	
CUM. (GR/DNCF) SMALLER THAN D50	3.59E-02	2.22E-02	1.78E-02	1.36E-02	1.12E-02	9.97E-03	
GEO. MEAN DIA. (MICROMETERS)	3.39E+01	7.66E+00	3.58E+00	1.89E+00	1.01E+00	5.31E-01	2.78E-01
DM/DLOGD (MG/DNCF)	3.48E+01	8.85E+01	3.30E+01	3.82E+01	1.89E+01	1.05E+01	7.58E+01
DN/DLOGD (NO. PARTICLES/DNCF)	8.49E+05	1.88E+08	6.87E+08	5.40E+09	1.76E+10	6.71E+10	3.35E+12
BLANK CORRECTION (MILLIGRAMS)	0.08	0.15	0.08	0.08	0.08	0.08	0.25

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)	16.34	7.26	3.61	2.06	1.06	0.60	
GEO. MEAN DIA. (MICROMETERS)	4.81E+01	1.09E+01	5.12E+00	2.72E+00	1.48E+00	8.00E-01	4.27E-01
DM/DLOGD (MG/DNCF)	3.48E+01	8.89E+01	3.34E+01	3.89E+01	1.95E+01	1.12E+01	7.58E+01
DN/DLOGD (NO. PARTICLES/DNCF)	5.98E+05	1.32E+08	4.76E+08	3.67E+09	1.16E+10	4.17E+10	1.86E+12

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE	0.144	0.144	0.371	0.342	0.351	0.360	0.358
HOLE DIAMETERS BY STAGE (CENTIMETERS)	1.8237	1.8237	0.2483	0.0850	0.0546	0.0344	0.0276
NUMBER OF HOLES PER STAGE	1	1	12	90	110	110	90

PETCI-56 11143-11155 12/10/82

INLET SAMPLE

CASCADE IMPACTOR NUMBER = Y

IMPACTOR FLOWRATE = .312 ACFM

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 12.00 MIN

IMPACTOR PRESSURE DROP = 0.11N. OF HG

STACK TEMPERATURE = 300.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.00 GM/CM³

STACK PRESSURE = 28.20 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO₂ = 12.27

CU = 0.00

N₂ = 73.60

O₂ = 4.33

SO₂ = 0.00

H₂O = 9.80

CALC. MASS LOADING = 4.0560E-02 GR/ACF

6.8462E-02 GR/DNCF

9.2814E+01 MG/ACM

1.5666E+02 MG/DNCF

IMPACTOR STAGE

S1

S2

S3

S4

S5

S6

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

11.52

5.10

2.52

1.42

0.72

0.39

MASS (MILLIGRAMS)

3.99

3.61

0.74

0.61

0.41

0.14

0.34

MG/DNCF/STAGE

6.35E+01

5.75E+01

1.18E+01

9.71E+00

6.53E+00

2.23E+00

5.41E+00

CUM. PERCENT OF MASS SMALLER THAN D50

59.45

22.76

15.24

9.04

4.88

3.46

CUM. (MG/ACM) SMALLER THAN D50

5.52E+01

2.11E+01

1.41E+01

8.39E+00

4.53E+00

3.21E+00

CUM. (MG/DNCF) SMALLER THAN D50

9.31E+01

3.57E+01

2.39E+01

1.42E+01

7.64E+00

5.41E+00

CUM. (GR/ACF) SMALLER THAN D50

2.41E-02

9.73E-03

6.18E-03

3.67E-03

1.98E-03

1.40E-03

CUM. (GR/DNCF) SMALLER THAN D50

4.07E-02

1.56E-02

1.04E-02

6.19E-03

3.34E-03

2.37E-03

GEO. MEAN DIA. (MICROMETERS)

3.39E+01

7.66E+00

3.58E+00

1.89E+00

1.01E+00

5.32E-01

2.79E-01

DN/DLOGD (MG/DNCF)

6.77E+01

1.62E+02

3.85E+01

3.91E+01

2.20E+01

8.60E+00

1.80E+01

DN/DLOGD (NO. PARTICLES/DNCF)

1.65E+06

3.45E+08

7.99E+08

5.52E+09

2.04E+10

5.45E+10

7.89E+11

BLANK CORRECTION (MILLIGRAMS)

0.08

0.16

0.08

0.08

0.08

0.08

0.25

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

16.34

7.26

3.61

2.06

1.06

0.61

GEO. MEAN DIA. (MICROMETERS)

4.81E+01

1.09E+01

5.12E+00

2.73E+00

1.48E+00

8.01E-01

4.28E-01

DN/DLOGD (MG/DNCF)

6.78E+01

1.63E+02

3.88E+01

3.98E+01

2.27E+01

9.14E+00

1.80E+01

DN/DLOGD (NO. PARTICLES/DNCF)

1.17E+06

2.41E+08

5.53E+08

3.76E+09

1.34E+10

3.39E+10

4.38E+11

NOMINAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE

0.144

0.144

0.371

0.342

0.351

0.380

0.350

HOLE DIAMETERS BY STAGE (CENTIMETERS)

1.8237

1.8237

0.2483

0.0850

0.0546

0.0344

0.0276

NUMBER OF HOLES PER STAGE

1

1

12

90

110

110

90

PETCI-57 11115-11127 12/13/82

INLET SAMPLE

CASCADE IMPACTOR NUMBER = 0

IMPACTOR FLOWRATE = .012 ACFM

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 12.00 MIN

IMPACTOR PRESSURE DROP = 0.21 IN. OF HG

STACK TEMPERATURE = 300.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.00 GM/CC, CM.

STACK PRESSURE = 28.34 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO2 = 11.80

CO = 0.00 H2 = 74.27

O2 = 4.72 SO2 = 0.00 H2O = 9.20

CALC. MASS LOADING = 3.8459E-02 GR/ACF

0.4235E-02 GR/DNCF

8.8098E+01 MG/ACM

1.4699E+02 MG/DNCF

IMPACTOR STAGE

	S1	S2	S3	S4	S5	S6	FILTER
STAGE INDEX NUMBER	1	2	3	4	5	6	7
D50 (MICROMETERS)	11.53	5.11	2.38	1.36	0.66	0.33	
MASS (MILLIGRAMS)	3.78	3.02	0.80	0.60	0.31	0.09	0.74
MG/DNCF/STAGE	5.95E+01	4.75E+01	1.26E+01	9.44E+00	4.88E+00	1.42E+00	1.16E+01
CUM. PERCENT OF MASS SMALLER THAN D50	59.53	27.19	18.63	12.21	8.89	7.92	
CUM. (MG/ACM) SMALLER THAN D50	5.24E+01	2.40E+01	1.64E+01	1.08E+01	7.83E+00	6.98E+00	
CUM. (MG/DNCF) SMALLER THAN D50	3.75E+01	4.00E+01	2.74E+01	1.79E+01	1.31E+01	1.16E+01	
CUM. (GR/ACF) SMALLER THAN D50	2.29E+02	1.05E+02	7.17E+01	4.70E+01	3.42E+01	3.05E+01	
CUM. (GR/DNCF) SMALLER THAN D50	3.82E+02	1.75E+02	1.20E+02	7.84E+01	5.71E+01	5.09E+01	
GEO. MEAN DIA. (MICROMETERS)	3.40E+01	7.68E+00	3.49E+00	1.80E+00	9.44E+01	4.66E+01	2.35E-01
DM/DLOGD (MG/DNCF)	5.34E+01	1.35E+02	3.79E+01	3.89E+01	1.54E+01	4.79E+00	3.87E+01
DN/DLOGD (NO. PARTICLES/DNCF)	1.55E+06	2.84E+08	8.52E+08	6.38E+09	1.75E+10	4.51E+10	2.86E+12
BLANK CORRECTION (MILLIGRAMS)	0.08	0.16	0.08	0.08	0.08	0.08	0.25

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PST BY STAGE

0.144	0.144	0.371	0.341	0.350	0.331	0.365
-------	-------	-------	-------	-------	-------	-------

NOSE DIAMETERS BY STAGE (CENTIMETERS)

1.8237	1.8237	0.2487	0.0821	0.0532	0.0358	0.0249
--------	--------	--------	--------	--------	--------	--------

NUMBER OF NOSES PER STAGE

1	1	12	90	110	110	90
---	---	----	----	-----	-----	----

PETCT-81 10110-10116 1/5/83

IMPACTOR FLOWRATE = .338 ACFM INLET SAMPLE CASCADE IMPACTOR NUMBER = X

IMPACTOR PRESSURE DROP = 0.21 IN. OF HG IMPACTOR TEMPERATURE = 300.0 F = 148.9 C SAMPLING DURATION = 6.00 MIN

ASSUMED PARTICLE DENSITY = 2.44 GM/CC, CM. STACK TEMPERATURE = 300.0 F = 148.9 C

GAS COMPOSITION (PERCENT) CO₂ = 11.94 CO = 0.00 H₂ = 72.35 O₂ = 3.51 SO₂ = 0.00 H₂O = 12.20

CALC. MASS LOADING = 2.3986E-01 GR/ACF 4.1771E-01 GR/DNCF 5.4887E+02 MG/ACM 9.5586E+02 MG/DNCF

IMPACTOR STAGE	S1	S2	S3	S4	S5	S6	FILTER
STAGE INDEX NUMBER	1	2	3	4	5	6	7
D50 (MICROMETERS)	9.98	4.41	2.01	1.16	0.55	0.27	
MASS (MILLIGRAMS)	20.48	4.31	1.23	0.46	0.38	0.48	4.18
MG/DNCF/STAGE	6.21E+02	1.31E+02	3.73E+01	1.39E+01	1.15E+01	1.46E+01	1.27E+02
CUM. PERCENT OF MASS SMALLER THAN D50	35.03	21.35	17.45	15.99	14.78	13.26	
CUM. (MG/ACM) SMALLER THAN D50	1.92E+02	1.17E+02	9.58E+01	8.78E+01	8.11E+01	7.28E+01	
CUM. (MG/DNCF) SMALLER THAN D50	3.38E+02	2.04E+02	1.67E+02	1.53E+02	1.41E+02	1.27E+02	
CUM. (GR/ACF) SMALLER THAN D50	8.40E-02	5.12E-02	4.19E-02	3.84E-02	3.55E-02	3.18E-02	
CUM. (GR/DNCF) SMALLER THAN D50	1.46E-01	8.92E-02	7.29E-02	6.68E-02	6.18E-02	5.54E-02	
GEO. MEAN DIA. (MICROMETERS)	3.16E+01	6.63E+00	2.98E+00	1.53E+00	8.02E+01	3.88E-01	1.93E-01
DM/DLOGD (MG/DNCF)	6.21E+02	3.68E+02	1.09E+02	5.87E+01	3.56E+01	4.74E+01	4.21E+02
DM/DLOGD (NO. PARTICLES/DNCF)	1.54E+07	9.86E+06	3.25E+09	1.28E+10	5.42E+10	6.36E+11	4.61E+13
BLANK CORRECTION (MILLIGRAMS)	0.00	0.00	0.00	0.00	0.00	0.00	0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)	15.66	6.95	3.21	1.88	0.93	0.49	
GEO. MEAN DIA. (MICROMETERS)	4.95E+01	1.04E+01	4.72E+00	2.46E+00	1.32E+00	6.73E-01	3.45E-01
DM/DLOGD (MG/DNCF)	6.22E+02	3.71E+02	1.11E+02	6.03E+01	3.75E+01	5.22E+01	4.21E+02
DM/DLOGD (NO. PARTICLES/DNCF)	9.82E+06	6.23E+06	2.01E+09	7.76E+09	3.10E+10	3.28E+11	1.96E+13

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE	0.144	0.144	0.371	0.341	0.350	0.331	0.365
NO. DIAPHERS BY STAGE (CENTIMETERS)	1.8237	1.8237	0.2483	0.0812	0.0532	0.0358	0.0249
NUMBER OF HOLES PER STAGE	1	1	12	90	110	110	90

PETCI-83 10:19-01:25 1/6/83

INLET SAMPLE

CASCADE IMPACTOR NUMBER = D

IMPACTOR FLOWRATE = .338 ACFM

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 6.00 MIN

IMPACTOR PRESSURE DROP = 0.21 IN. OF HG

STACK TEMPERATURE = 300.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.44 GM/CCM.

STACK PRESSURE = 27.88 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO2 = 12.40

CO = 0.00

N2 = 72.30

O2 = 3.90

SU2 = 0.00

H2O = 11.40

CALC. MASS LOADING = 3.0834E-01 GR/ACF

5.3595E-01 GR/DNCF

7.0560E-02 MG/ACM

1.2264E+03 MG/DNCF

IMPACTOR STAGE

S1

S2

S3

S4

S5

S6

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

9.99

4.41

2.01

1.16

0.55

0.27

MASS (MILLIGRAMS)

27.83

6.59

0.89

0.64

0.49

0.24

3.84

MG/DNCF/STAGE

8.42E+02

1.99E+02

2.69E+01

1.94E+01

1.48E+01

7.26E+00

1.16E+02

CUM. PERCENT OF MASS SMALLER THAN D50

31.32

15.05

12.86

11.28

10.07

9.48

CUM. (MG/ACM) SMALLER THAN D50

2.21E+02

1.06E+02

9.07E+01

7.96E+01

7.10E+01

6.69E+01

CUM. (MG/DNCF) SMALLER THAN D50

3.84E+02

1.85E+02

1.58E+02

1.38E+02

1.23E+02

1.16E+02

CUM. (GR/ACF) SMALLER THAN D50

9.66E-02

4.64E-02

3.96E-02

3.48E-02

3.10E-02

2.92E-02

CUM. (GR/DNCF) SMALLER THAN D50

1.68E-01

8.07E-02

6.89E-02

6.04E-02

5.40E-02

5.08E-02

GEO. MEAN DIA. (MICROMETERS)

3.16E+01

6.63E+00

2.98E+00

1.53E+00

8.01E-01

3.88E-01

1.92E-01

DN/DLOGD (MG/DNCF)

8.42E+02

5.62E+02

7.90E+01

8.15E+01

4.58E+01

2.36E+01

3.86E+02

DN/DLOGD (NO. PARTICLES/DNCF)

2.09E+07

1.51E+09

2.34E+09

1.78E+10

6.97E+10

3.18E+11

4.25E+13

BLANK CORRECTION (MILLIGRAMS)

0.00

0.00

0.00

0.00

0.00

0.00

0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

15.67

6.96

3.21

1.88

0.93

0.49

GEO. MEAN DIA. (MICROMETERS)

4.95E+01

1.64E+01

4.72E+00

2.46E+00

1.32E+00

6.72E-01

3.45E-01

DN/DLOGD (MG/DNCF)

8.43E+02

5.66E+02

8.02E+01

8.37E+01

4.82E+01

2.60E+01

3.86E+02

DN/DLOGD (NO. PARTICLES/DNCF)

1.33E+07

9.49E+08

1.45E+09

1.08E+10

3.99E+10

1.64E+11

1.80E+13

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BT STAGE

0.144

0.144

0.371

0.341

0.350

0.331

0.365

HOLE DIAMETERS BY STAGE (CENTIMETERS)

1.8237

1.8237

0.2433

0.0812

0.0532

0.0358

0.0249

NUMBER OF HOLES PER STAGE

1

1

12

90

110

110

90

PETCJ-84 1/10/83 9:10-9:16

INLET SAMPLE

CASCADE IMPACTOR NUMBER = X

IMPACTOR FLOWRATE = .312 ACFM

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 6.00 MIN

IMPACTOR PRESSURE DROP = 0.11 IN. OF HG

STACK TEMPERATURE = 300.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.44 GM/CC

STACK PRESSURE = 27.78 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO2 = 9.20

CO = 0.00 N2 = 73.10

O2 = 6.19

SO2 = 0.00

H2O = 11.50

CALC. MASS LOADING = 3.8779E-01 GR/ACF

6.7722E-01 GR/DNCF

8.8739E+02 MG/ACM

1.5497E+03 MG/DNCF

IMPACTOR STAGE

S1

S2

S3

S4

S5

S6

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

10.43

4.61

2.19

1.22

0.73

0.29

MASS (MILLIGRAMS)

35.25

5.92

1.38

0.44

0.37

0.24

3.44

MG/DNCF/STAGE

1.16E+03

1.95E+02

4.55E+01

1.45E+01

1.22E+01

7.91E+00

1.13E+02

CUM. PERCENT OF MASS SMALLER THAN D50

25.06

12.48

9.55

8.61

7.82

7.31

CUM. (MG/ACM) SMALLER THAN D50

2.22E+02

1.11E+02

8.47E+01

7.64E+01

6.94E+01

6.49E+01

CUM. (MG/DNCF) SMALLER THAN D50

3.88E+02

1.93E+02

1.48E+02

1.33E+02

1.21E+02

1.13E+02

CUM. (GR/ACF) SMALLER THAN D50

9.72E-02

4.84E-02

3.70E-02

3.34E-02

3.03E-02

2.84E-02

CUM. (GR/DNCF) SMALLER THAN D50

1.70E-01

8.45E-02

6.46E-02

5.83E-02

5.30E-02

4.95E-02

GEO. MEAN DIA. (MICROMETERS)

3.23E+01

6.93E+00

3.17E+00

1.64E+00

9.44E-01

4.60E-01

2.06E-01

DN/DLOGD (MG/DNCF)

1.18E+03

5.50E+02

1.41E+02

5.76E+01

5.38E+01

1.99E+01

3.76E+02

DN/DLOGD (NO. PARTICLES/DNCF)

2.75E+07

1.29E+09

3.44E+09

1.03E+10

5.01E+10

1.60E+11

3.38E+13

BLANK CORRECTION (MILLIGRAMS)

0.00

0.00

0.00

0.00

0.00

0.00

0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

16.37

7.27

3.49

1.98

1.20

0.52

GEO. MEAN DIA. (MICROMETERS)

5.06E+01

1.09E+01

5.03E+00

2.63E+00

1.54E+00

7.90E-01

3.67E-01

DN/DLOGD (MG/DNCF)

1.19E+03

5.53E+02

1.42E+02

5.90E+01

5.62E+01

2.17E+01

3.76E+02

DN/DLOGD (NO. PARTICLES/DNCF)

1.75E+07

8.15E+08

2.13E+09

6.21E+09

2.92E+10

8.41E+10

1.45E+13

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PST BY STAGE

0.144

0.144

0.371

0.350

0.345

0.354

0.358

HOLE DIAMETERS BY STAGE (CENTIMETERS)

1.8237

1.8237

0.2483

0.0818

0.0539

0.0389

0.0254

NUMBER OF HOLES PER STAGE

1

1

12

40

110

110

90

PETCI-85 1/10/83 11:15-11:21

INLET SAMPLE

CASCADE IMPACTOR NUMBER = D

IMPACTOR FLOWRATE = .312 ACFM

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 6.00 MIN

IMPACTOR PRESSURE DROP = 0.21 IN. CF HG

STACK TEMPERATURE = 300.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.44 GR/CM³

STACK PRESSURE = 27.78 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO₂ = 9.20

CO = 0.00

H₂ = 73.10

O₂ = 6.19

SO₂ = 0.00

H₂O = 11.50

CALC. MASS LOADING = 4.2505E+01 GR/ACF

7.4230E+01 GR/DNCF

9.7264E+02 MG/ACF

1.6986E+03 MG/DNCF

IMPACTOR STAGE

S1

S2

S3

S4

S5

S6

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

10.43

4.61

2.10

1.22

0.64

0.29

MASS (MILLIGRAMS)

37.97

7.21

1.03

0.97

0.56

0.42

3.40

MG/DNCF/STAGE

1.25E+03

2.18E+02

3.39E+01

3.20E+01

1.84E+01

1.38E+01

1.12E+02

CUM. PERCENT OF MASS SMALLER THAN D50

26.36

12.37

10.30

8.49

7.41

6.59

CUM. (MG/ACF) SMALLER THAN D50

2.56E+02

1.20E+02

1.01E+02

8.26E+01

7.21E+01

6.41E+01

CUM. (MG/DNCF) SMALLER THAN D50

4.48E+02

2.10E+02

1.76E+02

1.44E+02

1.26E+02

1.12E+02

CUM. (GR/ACF) SMALLER THAN D50

1.12E+01

5.26E-02

4.41E-02

3.61E-02

3.15E-02

2.80E-02

CUM. (GR/DNCF) SMALLER THAN D50

1.96E-01

9.19E-02

7.70E-02

6.31E-02

5.50E-02

4.89E-02

GEO. MEAN DIA. (MICROMETERS)

3.23E+01

6.93E+00

3.11E+00

1.60E+00

8.85E-01

4.29E-01

2.03E-01

DN/DLOGD (MG/DNCF)

1.27E+03

6.69E+02

9.96E+01

1.35E+02

6.65E+01

3.95E+01

3.72E+02

DN/DLOGD (NO. PARTICLES/DNCF)

2.96E+07

1.57E+09

2.59E+09

2.57E+10

7.51E+10

3.90E+11

3.49E+13

BLANK CORRECTION (MILLIGRAMS)

0.00

0.00

0.00

0.00

0.00

0.00

0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

16.37

7.27

3.35

1.97

1.07

0.51

GEO. MEAN DIA. (MICROMETERS)

5.06E+01

1.09E+01

4.54E+00

2.57E+00

1.45E+00

7.40E-01

3.62E-01

DN/DLOGD (MG/DNCF)

1.28E+03

6.74E+02

1.01E+02

1.38E+02

6.96E+01

4.33E+01

3.72E+02

DN/DLOGD (NO. PARTICLES/DNCF)

1.89E+07

9.92E+08

1.60E+09

1.55E+10

4.35E+10

2.04E+11

1.49E+13

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PSI BY STAGE

0.144

0.144

0.371

0.341

0.350

0.361

0.365

HOLE DIAMETERS BY STAGE (CENTIMETERS)

1.8237

1.8237

0.2483

0.0812

0.0532

0.0358

0.0249

NUMBER OF HOLES PER STAGE

1

1

12

90

110

110

90

PETC1-86 1/10/83 12:54-13:00

INLET SAMPLE

CASCADE IMPACTOR NUMBER - E

IMPACTOR FLOWRATE = .312 ACFM

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

SAMPLING DURATION = 6.00 MIN

IMPACTOR PRESSURE DROP = 0.12 IN. OF HG

STACK TEMPERATURE = 300.0 F = 148.9 C

ASSUMED PARTICLE DENSITY = 2.44 GM/CC, CM.

STACK PRESSURE = 27.78 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

GAS COMPOSITION (PERCENT) CO2 = 9.20

CO = 0.00

N2 = 73.10

O2 = 6.19

SO2 = 0.00

H2O = 11.50

CALC. MASS LOADING = 4.3362E-01 GR/ACF

7.5727E-01 GR/DNCF

9.9228E+02 MG/ACM

1.7329E+03 MG/DNCF

IMPACTOR STAGE

S1

S2

S3

S4

S5

S6

FILTER

STAGE INDEX NUMBER

1

2

3

4

5

6

7

D50 (MICROMETERS)

10.43

4.61

2.14

1.23

0.74

0.28

MASS (MILLIGRAMS)

39.45

6.93

0.79

0.98

0.62

0.39

3.44

MG/DNCF/STAGE

1.30E+03

2.28E+02

2.60E+01

3.23E+01

2.04E+01

1.28E+01

1.13E+02

CUM. PERCENT OF MASS SMALLER THAN D50

25.00

11.83

10.32

8.46

7.26

6.54

CUM. (MG/ACH) SMALLER THAN D50

2.48E+02

1.17E+02

1.02E+02

8.39E+01

7.23E+01

6.43E+01

CUM. (MG/DNCF) SMALLER THAN D50

4.33E+02

2.05E+02

1.79E+02

1.47E+02

1.26E+02

1.13E+02

CUM. (GR/ACF) SMALLER THAN D50

1.08E-01

5.13E-02

4.48E-02

3.67E-02

3.16E-02

2.84E-02

CUM. (GR/DNCF) SMALLER THAN D50

1.89E-01

8.95E-02

7.82E-02

6.41E-02

5.51E-02

4.95E-02

GEO. MEAN DIA. (MICROMETERS)

3.23E+01

6.93E+00

3.14E+00

1.62E+00

9.54E-01

4.57E-01

2.00E-01

DM/DLOGD (MG/DNCF)

1.32E+03

6.43E+02

7.82E+01

1.34E+02

9.31E+01

3.06E+01

3.76E+02

DN/DLOGD (NO. PARTICLES/DNCF)

3.08E+07

1.51E+09

1.98E+09

2.46E+10

8.38E+10

2.51E+11

3.71E+13

BLANK CORRECTION (MILLIGRAMS)

0.00

0.00

0.00

0.00

0.00

0.00

0.00

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

16.37

7.27

3.41

1.99

1.22

0.50

GEO. MEAN DIA. (MICROMETERS)

5.06E+01

1.09E+01

4.98E+00

2.60E+00

1.56E+00

7.86E-01

3.57E-01

DM/DLOGD (MG/DNCF)

1.33E+03

6.48E+02

7.93E+01

1.37E+02

9.71E+01

3.34E+01

3.76E+02

DN/DLOGD (NO. PARTICLES/DNCF)

1.96E+07

9.54E+08

1.23E+09

1.48E+10

4.89E+10

1.31E+11

1.58E+13

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG. C AND 760MM HG

SQUARE ROOTS OF PSI BY STAGE

0.144

0.144

0.371

0.343

0.346

0.360

0.350

HOLE DIAMETERS BY STAGE (CENTIMETERS)

1.8237

1.8237

0.2483

0.0818

0.0539

0.0369

0.0254

NUMBER OF HOLES PER STAGE

1

1

12

90

110

110

90

PETCI-88 1/10/83 14:27-14:33

IMPACTOR FLOWRATE = .312 ACFM

IMPACTOR PRESSURE DROP = 0.1 IN. OF HG

ASSUMED PARTICLE DENSITY = 2.44 GM/CC

GAS COMPOSITION (PERCENT): CO2 = 9.20

CALC. MASS LOADING = 2.6562E-01 GR/ACF

IMPACTOR STAGE

STAGE INDEX NUMBER

D50 (MICROMETERS)

MASS (MILLIGRAMS)

MG/DNOM/STAGE

CUM. PERCENT OF MASS SMALLER THAN D50

CUM. (MG/ACM) SMALLER THAN D50

CUM. (MG/DNOM) SMALLER THAN D50

CUM. (GR/ACF) SMALLER THAN D50

CUM. (GR/DNCF) SMALLER THAN D50

GEO. MEAN DIA. (MICROMETERS)

DM/DLOGD (MG/DNOM)

DN/DLOGD (NO. PARTICLES/DNOM)

BLANK CORRECTION (MILLIGRAMS)

AERODYNAMIC DIAMETERS ARE CALCULATED HERE ACCORDING TO THE TASK GROUP ON LUNG DYNAMICS DEFINITION

D50 (MICROMETERS)

GEO. MEAN DIA. (MICROMETERS)

DM/DLOGD (MG/DNOM)

DN/DLOGD (NO. PARTICLES/DNOM)

NORMAL (ENGINEERING STANDARD) CONDITIONS ARE 21 DEG C AND 760MM HG.

SQUARE ROOTS OF PST BY STAGE

HOLE DIAMETERS BY STAGE (CENTIMETERS)

NUMBER OF HOLES PER STAGE

INLET SAMPLE

IMPACTOR TEMPERATURE = 300.0 F = 148.9 C

STACK TEMPERATURE = 390.0 F = 148.9 C

STACK PRESSURE = 27.78 IN. OF HG

MAX. PARTICLE DIAMETER = 100.0 MICROMETERS

CO = 0.00 H2 = 73.10 O2 = 6.19 SO2 = 0.00 H2O = 11.50

4.6386E-01 GR/DNCF 6.0782E+02 MG/ACM 1.0615E+03 MG/DNOM

	S1	S2	S3	S4	S5	S6	FILTER
	1	2	3	4	5	6	7
D50 (MICROMETERS)	10.43	4.61	2.19	1.22	0.73	0.29	
MASS (MILLIGRAMS)	20.59	5.40	1.57	0.56	0.43	0.34	3.33
MG/DNOM/STAGE	6.78E+02	1.78E+02	5.17E+01	1.84E+01	1.42E+01	1.12E+01	1.10E+02
CUM. PERCENT OF MASS SMALLER THAN D50	36.10	19.34	14.46	12.73	11.39	10.34	
CUM. (MG/ACM) SMALLER THAN D50	2.19E+02	1.18E+02	8.79E+01	7.73E+01	6.92E+01	6.28E+01	
CUM. (MG/DNOM) SMALLER THAN D50	3.83E+02	2.05E+02	1.54E+02	1.35E+02	1.21E+02	1.10E+02	
CUM. (GR/ACF) SMALLER THAN D50	9.59E-02	5.14E-02	3.84E-02	3.38E-02	3.03E-02	2.75E-02	
CUM. (GR/DNCF) SMALLER THAN D50	1.67E-01	8.97E-02	6.71E-02	5.90E-02	5.28E-02	4.79E-02	
GEO. MEAN DIA. (MICROMETERS)	3.23E+01	6.93E+00	3.17E+00	1.64E+00	9.44E-01	4.60E-01	2.06E-01
DM/DLOGD (MG/DNOM)	6.91E+02	5.01E+02	1.60E+02	7.33E+01	6.25E+01	2.82E+01	3.64E+02
DN/DLOGD (NO. PARTICLES/DNOM)	1.61E+07	1.18E+09	3.91E+09	1.31E+10	5.82E+10	2.27E+11	3.27E+13
BLANK CORRECTION (MILLIGRAMS)	0.00	0.00	0.00	0.00	0.00	0.00	0.00

	S1	S2	S3	S4	S5	S6	FILTER
	1	2	3	4	5	6	7
D50 (MICROMETERS)	16.37	7.27	3.49	1.98	1.20	0.52	
GEO. MEAN DIA. (MICROMETERS)	5.06E+01	1.09E+01	5.03E+00	2.63E+00	1.54E+00	7.90E-01	3.67E-01
DM/DLOGD (MG/DNOM)	6.92E+02	5.05E+02	1.62E+02	7.51E+01	6.53E+01	3.07E+01	3.64E+02
DN/DLOGD (NO. PARTICLES/DNOM)	1.02E+07	7.43E+08	2.43E+09	7.93E+09	3.40E+10	1.19E+11	1.41E+13

	S1	S2	S3	S4	S5	S6	FILTER
	1	1	12	90	110	110	90
SQUARE ROOTS OF PST BY STAGE	0.144	0.144	0.371	0.350	0.345	0.354	0.358
HOLE DIAMETERS BY STAGE (CENTIMETERS)	1.8237	1.8237	0.2483	0.6818	0.0539	0.0369	0.0254

APPENDIX B

Coal Analyses and Five-Stage Series Cyclone Data

Table B1

Five-Stage Series Cyclone Runs,
No. 6 Fuel Oil Test

	Total	Stage No.					Filter
		1	2	3	4	5	
<u>August 30, 1982--PETCI-2C</u>							
Collected mass, mg	180.0	45.3	9.9	25.4	54.7	44.7	—
Stage D ₅₀ , μm		4.84	1.96	1.25	0.487	0.209	
Cumulative mass %, <D ₅₀		74.8	69.3	55.2	24.4	—	
Cumulative mass loading <D ₅₀ , gr/acf	0.0052 ¹	0.0039	0.0036	0.0029	0.0013	—	
<u>August 31, 1982--PETCI-3C</u>							
Collected mass, mg	107.0	27.0	6.0	21.3	32.1	20.6	—
Stage D ₅₀ , μm		4.68	1.89	1.20	0.464	0.196	
Cumulative mass %, <D ₅₀		74.8	69.2	49.2	19.3	—	
Cumulative mass loading <D ₅₀ , gr/acf	0.0054 ¹	0.0040	0.0037	0.0027	0.0010	—	
<u>September 1, 1982--PETCI-4C</u>							
Collected mass, mg	42.1	16.0	2.8	11.1	6.7	5.5	—
Stage D ₅₀ , μm		4.99	2.04	1.30	0.514	0.226	
Cumulative mass %, <D ₅₀		62.0	55.3	29.0	13.1	—	
Cumulative mass loading <D ₅₀ , gr/acf	0.0026 ¹	0.0016	0.0014	0.0007	0.0003	—	
<u>September 2, 1982--PETCI-5C</u>							
Collected mass, mg	375.9	92.0	31.4	80.0	99.4	73.1	—
Stage D ₅₀ , μm		4.81	1.94	1.23	0.475	0.200	
Cumulative mass %, <D ₅₀		75.5	67.2	45.9	19.5	—	
Cumulative mass loading <D ₅₀ , gr/acf	0.0106 ¹	0.0080	0.0071	0.0049	0.0021	—	

1. Total mass loading.

Table B2
Five-Stage Series Cyclone Runs,
SRC Fuel

	Total	Stage No.					Filter
		1	2	3	4	5	
<u>November 15, 1982--PETCI-10C²</u>							
Collected mass, mg	2568.6	2223.5	160.7	74.1	22.1	3.1	85.1 ²
Stage D ₅₀ , μ m		5.30	2.16	1.38	0.552	0.248	
Cumulative mass %, <D ₅₀		13.4	7.2	4.3	3.4	3.3	
Cumulative mass loading <D ₅₀ , gr/acf	0.2989 ¹	0.0402	0.0215	0.0128	0.0103	0.0099	
<u>November 16, 1982--PETCI-11C</u>							
Collected mass, mg	1536.3	1280.9	132.9	37.5	15.3	3.7	66.0
Stage D ₅₀ , μ m		5.24	2.14	1.36	0.546	0.246	
Cumulative mass %, <D ₅₀		16.6	8.0	5.5	4.5	4.3	
Cumulative mass loading <D ₅₀ , gr/acf	0.2338 ¹	0.0388	0.0186	0.0129	0.0106	0.0100	
<u>November 17, 1982--PETCI-12C</u>							
Collected mass, mg	1591.5	1309.6	139.7	61.3	14.9	5.8	60.2
Stage D ₅₀ , μ m		5.15	2.08	1.32	0.523	0.238	
Cumulative mass %, <D ₅₀		17.7	8.9	5.1	4.2	3.8	
Cumulative mass loading <D ₅₀ , gr/acf	0.2352 ¹	0.0417	0.0210	0.0010	0.0089		
<u>November 18, 1982--PETCI-13C</u>							
Collected mass, mg	1344.0	1141.5	84.7	34.6	14.4	3.1	65.7
Stage D ₅₀ , μ m		5.29	2.15	1.37	0.546	0.241	
Cumulative mass %, <D ₅₀		15.1	8.8	6.2	5.1	4.9	
Cumulative mass loading <D ₅₀ , gr/acf	0.2084 ¹	0.0314	0.0183	0.0129	0.0107	0.0102	
<u>November 19, 1982--PETCI-14C</u>							
Collected mass, mg	1586.6	1355.6	109.6	28.9	11.6	3.8	67.1
Stage D ₅₀ , μ m		5.29	2.16	1.38	0.558	0.255	
Cumulative mass %, <D ₅₀		13.9	7.0	5.2	4.5	4.2	
Cumulative mass loading <D ₅₀ , gr/acf	0.2451 ¹	0.0341	0.0172	0.0127	0.0109	0.0104	

1. Total mass loading.

2. Corrected for blown backup filter.

Table B3

Five-Stage Series Cyclone Runs,
SRC Residual Fuel Oil Test

	Total	Stage No.					Filter
		1	2	3	4	5	
<u>December 13, 1982--PETCI-16C</u>							
Collected mass, mg	400.2	251.4	55.8	24.0	12.0	3.7	53.3
Stage D ₅₀ , μ m		5.50	2.25	1.44	0.581	0.267	
Cumulative mass %, ϕ_{50}		37.2	23.2	17.2	14.2	13.3	
Cumulative mass loading ϕ_{50} , gr/acf	0.04417 ¹	0.0164	0.0102	0.0076	0.0063	0.0059	
<u>December 14, 1982--PETCI-17C</u>							
Collected mass, mg	755.9	523.2	128.3	37.3	11.0	1.6	54.5
Stage D ₅₀ , μ m		5.52	2.26	1.45	0.590	0.276	
Cumulative mass %, ϕ_{50}		30.8	13.8	8.9	7.4	7.2	
Cumulative mass loading ϕ_{50} , gr/acf	0.0677 ¹	0.0208	0.0093	0.0060	0.0050	0.0049	
<u>December 15, 1982--PETCI-18C</u>							
Collected mass, mg	887.1	636.5	107.7	37.0	16.9	4.7	84.3
Stage D ₅₀ , μ m		5.57	2.28	1.47	0.593	0.274	
Cumulative mass %, ϕ_{50}		28.3	16.1	11.9	10.0	9.5	
Cumulative mass loading ϕ_{50} , gr/acf	0.0678 ¹	0.0192	0.0109	0.0081	0.0068	0.0065	
<u>December 16, 1982--PETCI-19C</u>							
Collected mass, mg	1038.7	754.8	135.2	37.0	14.8	4.4	92.5
Stage D ₅₀ , μ m		5.51	2.25	1.44	0.582	0.268	
Cumulative mass %, ϕ_{50}		27.3	14.3	10.7	9.3	8.9	
Cumulative mass loading ϕ_{50} , gr/acf	0.0685 ¹	0.0187	0.0098	0.0074	0.0064	0.0061	
<u>December 17, 1982--PETCI-20C</u>							
Collected mass, mg	779.9	570.2	84.6	27.3	11.9	2.7	83.2
Stage D ₅₀ , μ m		5.89	2.44	1.58	0.649	0.306	
Cumulative mass %, ϕ_{50}		26.9	16.0	12.5	11.0	10.7	
Cumulative mass loading ϕ_{50} , gr/acf	0.0639 ¹	0.0172	0.0103	0.0030	0.0070	0.0068	

¹ Total mass loading.

Table B4

Five-Stage Series Cyclone Runs,
SRC-Water Slurry Test

	Total	Stage No.					Filter
		1	2	3	4	5	
<u>January 11, 1983—PETCI-22C</u>							
Collected mass, mg	1734.4	1351.3	111.9	41.2	24.1	26.6	179.3
Stage D ₅₀ , μm		4.72	1.90	1.20	0.469	0.201	
Cumulative mass %, <D ₅₀		22.1	15.6	13.3	11.9	10.3	
Cumulative mass loading <D ₅₀ , gr/acf	0.2455 ¹	0.0542	0.0384	0.0326	0.0291	0.0254	
<u>January 12, 1983—PETCI-23C</u>							
Collected mass, mg	1829.0	1424.5	91.1	34.8	20.0	60.2	198.4
Stage D ₅₀ , μm		4.72	1.90	1.20	0.469	0.201	
Cumulative mass %, <D ₅₀		22.1	17.1	15.2	14.1	10.9	
Cumulative mass loading <D ₅₀ , gr/acf	0.2587 ¹	0.0572	0.0443	0.0394	0.0366	0.0281	
<u>January 13, 1983—PETCI-24C</u>							
Collected mass, mg	1674.1	1289.1	90.6	34.9	19.6	42.5	197.4
Stage D ₅₀ , μm		4.72	1.90	1.20	0.470	0.202	
Cumulative mass %, <D ₅₀		22.2	16.7	15.7	14.5	11.9	
Cumulative mass loading <D ₅₀ , gr/acf	0.2372 ¹	0.0546	0.0417	0.0368	0.0340	0.0280	
<u>January 14, 1983—PETCI-25C</u>							
Collected mass, mg	1787.3	1392.8	94.8	35.6	20.9	57.0	186.2
Stage D ₅₀ , μm		4.72	1.90	1.20	0.471	0.202	
Cumulative mass %, <D ₅₀		22.1	16.8	14.8	13.6	10.4	
Cumulative mass loading <D ₅₀ , gr/acf	0.2535 ¹	0.0559	0.0425	0.0375	0.0345	0.0264	

¹ Total mass loading.

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

JTHERN DIVISION MANAGER
JL R. EDMUNDS PLEASE ADDRESS ALL CORRESPONDENCE TO
216 OXMOOR CIRCLE, BIRMINGHAM, AL 35209
OFFICE TEL. (205) 942-3120

► Southern Research Institute
Birmingham, Alabama

10-8-82

Sample identification
by

Southern Research Institute

Kind of sample
reported to usNo. 6 Fuel Oil
Pete 8/30/82700 HP Boiler
P.O. Q2659

Sample taken at

Sample taken by

Southern Research Institute

Analysis made in accordance
with ASTM Specifications.

Date sampled

8-30-82

Date received

9-29-82

Analysis report no. 73-83439

PROXIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>
% Moisture	XXXXXX	XXXXXX
% Ash	XXXXXX	.16
% Volatile	XXXXXX	94.50
% Fixed Carbon	XXXXXX	5.34
		100.00
Btu/lb.	XXXXXX	21743
% Sulfur	XXXXXX	1.20

FUSION TEMPERATURE OF ASH

	<u>Reducing</u>	<u>Oxidizing</u>	
Initial Deformation	N °F	R °F	
Softening (H = W)	O °F	U °F	
Softening (H = 1/2 W)	T °F	N °F	H = Cone Height
Fluid	°F	°F	W = Cone Width

Original Copy Watermarked
For Your Protection

224

Respectfully submitted
COMMERCIAL TESTING & ENGINEERING CO.

DAN N. JACKSON, Manager, Birmingham Laboratory

Charter Member

OVER 40 BRANCH LABORATORIES STRATEGICALLY LOCATED IN PRINCIPAL COAL MINING AREAS,
TIDEWATER AND GREAT LAKES PORTS, AND RIVER LOADING FACILITIES

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES, 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601

AREA CODE 312 726-6434

SOUTHERN DIVISION MANAGER
AUL R. EDMUNDS PLEASE ADDRESS ALL CORRESPONDENCE TO
216 OXMOOR CIRCLE, BIRMINGHAM, AL 35209
OFFICE TEL. (205) 942-3120

► Southern Research Institute
Birmingham, Alabama

10-8-82

Sample identification
by

Southern Research Institute

Kind of sample
reported to usNo. 6 Fuel Oil
Pete 8/30/82700 HP Boiler
P.O. No. Q2659

Sample taken at

Sample taken by

Southern Research Institute

Date sampled

8-30-82

Analysis made in accordance
with ASTM Specifications.

Date received

9-29-82

Analysis report no. 73-83439

ULTIMATE ANALYSIS

	<u>As Received</u>	<u>Dry</u>
% Moisture	XXXXXX	XXXXXX
% Carbon	XXXXXX	84.31
% Hydrogen	XXXXXX	11.00
% Nitrogen	XXXXXX	.34
% Chlorine	XXXXXX	.03
% Sulfur	XXXXXX	1.20
% Ash	XXXXXX	.16
% Oxygen (diff.)	XXXXXX	<u>2.96</u>
		100.00

Original Copy Watermarked
For Your Protection

225

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

DAN N. JACKSON, Manager, Birmingham Laboratory

Charter Member

OVER 40 BRANCH LABORATORIES STRATEGICALLY LOCATED IN PRINCIPAL COAL MINING AREAS,
TIDEWATER AND GREAT LAKES PORTS, AND RIVER LOADING FACILITIES

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

NORTHERN DIVISION MANAGER
JL R. EDMUNDS PLEASE ADDRESS ALL CORRESPONDENCE TO
216 OXMOOR CIRCLE, BIRMINGHAM, AL 35209
OFFICE TEL: (205) 942-3120

► Southern Research Institute
Birmingham, Alabama

10-8-82

Sample identification
by Southern Research Institute

Kind of sample reported to us	No. 6 Fuel Oil Petc 9/2/82	700 HP Boiler P.O. No. Q2659
Sample taken at	-----	
Sample taken by	Southern Research Institute	Analysis made in accordance with ASTM Specification
Date sampled	9-2-82	
Date received	9-29-82	

Analysis report no. 73-83438

PROXIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>
% Moisture	XXXXX	XXXXX
% Ash	XXXXX	.16
% Volatile	XXXXX	95.74
% Fixed Carbon	XXXXX	4.10
		100.00
Btu/lb.	XXXXX	21865
% Sulfur	XXXXX	.85

FUSION TEMPERATURE OF ASH

	<u>Reducing</u>		<u>Oxidizing</u>		
Initial Deformation	N	°F	R	°F	
Softening (H = W)	Q	°F	U	°F	
Softening (H = 1/2 W)	T	°F	N	°F	
Fluid		°F		°F	

H = Cone Height
W = Cone Width

Original Copy Watermarked
For Your Protection

226

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

DAN N. JACKSON, Manager, Birmingham Laboratory

Charter Member

OVER 40 BRANCH LABORATORIES STRATEGICALLY LOCATED IN PRINCIPAL COAL MINING AREAS,
TIDEWATER AND GREAT LAKES PORTS, AND RIVER LOADING FACILITIES

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601

AREA CODE 312 726-8434

SOUTHERN DIVISION MANAGER
L. R. EDMUNDS PLEASE ADDRESS ALL CORRESPONDENCE TO
216 OXMOOR CIRCLE, BIRMINGHAM, AL 35209
OFFICE TEL. (205) 942-3120

► Southern Research Institute
Birmingham, Alabama

10-8-82

Sample identification
by

Southern Research Institute

Kind of sample No. 6 Fuel Oil
reported to us Petc 9/2/82700 HP Boiler
P.O. No. Q2659

Sample taken at -----

Sample taken by Southern Research Institute

Date sampled 9-2-82

Analysis made in accordance
with ASTM Specifications.

Date received 9-29-82

Analysis report no. 73-83438

ULTIMATE ANALYSIS

	<u>As Received</u>	<u>Dry</u>
% Moisture	XXXXX	XXXXX
% Carbon	XXXXX	84.20
% Hydrogen	XXXXX	11.23
% Nitrogen	XXXXX	.43
% Chlorine	XXXXX	.02
% Sulfur	XXXXX	.85
% Ash	XXXXX	.16
% Oxygen (diff.)	XXXXX	<u>3.11</u>
		100.00

Original Copy Watermarked
For Your Protection

227

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

DAN N. JACKSON, Manager, Birmingham Laboratory

Charter Member

OVER 40 BRANCH LABORATORIES STRATEGICALLY LOCATED IN PRINCIPAL COAL MINING AREAS,
TIDEWATER AND GREAT LAKES PORTS, AND RIVER LOADING FACILITIES

Table B9

GUARDIAN SYSTEMS, INC.

2810 - 19TH STREET SOUTH
BIRMINGHAM, ALABAMA 35209
TELEPHONE 205/879-1860

4301 15TH STREET EAST
TUSCALOOSA, ALABAMA 35401
TELEPHONE 205/556-8084

Customer: Southern Research Institute
2000 Ninth Avenue South
Birmingham, Alabama 35255

March 28, 1983

Sample type: PSRC - Sample
11175D

Sample location:

Sample by:

Sample date: Received 11/17/'82

Analysis conducted as specified by ASTM.

LABORATORY ANALYSIS REPORT

Laboratory Sample No. 37981
SHORT PROXIMATE ANALYSIS

	<u>As received</u>	<u>Dry basis</u>
Moisture, %	0.42	
Ash, %	0.17	0.17
Sulfur, %	1.19	1.20
Btu	15,414	15,479
MAF BTU		15,506
Volatile Matter	49.83	50.04
Fixed Carbon	49.58	49.79
Carbon	85.34	85.70
Hydrogen	6.28	6.31
Nitrogen	1.89	1.90

APPROVED BY Robert E. Smith

ALL ANALYSIS CONDUCTED ACCORDING
TO ASTM ANNUAL STANDARDS.

GUARDIAN SYSTEMS, INC.

2610 - 19TH STREET SOUTH
BIRMINGHAM, ALABAMA 35209
TELEPHONE 205/879-1850

4301 15TH STREET EAST
TUSCALOOSA, ALABAMA 35401
TELEPHONE 205/556-8084

Customer: Southern Research Institute
2000 Ninth Avenue South
Birmingham, Alabama 35255

March 28, 1983

Sample type: 121555-
SRC Residual Oil

Sample location:

Sample by:

Sample date: 12/15/'82

Analysis conducted as specified by ASTM.

LABORATORY ANALYSIS REPORT

Laboratory Sample No. 37982
SHORT PROXIMATE ANALYSIS

	<u>As received</u>	<u>Dry basis</u>
Moisture, %		
Ash, %	0.03	
Sulfur, %	1.22	
Btu	16,652	
MAF BTU		16,657
Volatile Matter	60.09	
Fixed Carbon	39.88	
Carbon	85.07	
Hydrogen	6.17	
Nitrogen	1.23	

APPROVED BY James L. Fennell

GUARDIAN SYSTEMS, INC.

2810 - 18TH STREET SOUTH
BIRMINGHAM, ALABAMA 35209
TELEPHONE 205/879-1850

4301 15TH STREET EAST
TUSCALOOSA, ALABAMA 35401
TELEPHONE 205/556-6084

Customer: Southern Research Institute
2000 Ninth Avenue South
Birmingham, Alabama 35255

March 28, 1983

Sample type: 011SS
Water Sample

Sample location:

Sample by:

Sample date: 1/11/'83

Analysis conducted as specified by ASTM

LABORATORY ANALYSIS REPORT

Laboratory Sample No. 37983
SHORT PROXIMATE ANALYSIS

	<u>As received</u>	<u>Dry basis</u>
Moisture, %	47.51	
Ash, %	0.36	0.68
Sulfur, %	0.66	1.25
Btu	8,253	15,723
MAF BTU		15,831
Volatile Matter	26.34	50.18
Fixed Carbon	25.79	49.14
Carbon	32.85	62.58
Hydrogen	2.64	5.03
Nitrogen	0.97	1.85

APPROVED BY Robert E. Fennell

ALL ANALYSIS CONDUCTED ACCORDING
TO ASTM ANNUAL STANDARDS.