DOE/PC/92535--T2

APR 01 1993

RECEIVED
USDOE/PETC

13 MAR 26 AM 10:56

2nd QUARTERLY PROJECT STATUS REPORT

Project Title: Control of Coal Combustion SO₂ and NO_x Emissions by In-Boiler Injection of CMA.

DOE Grant #: DE-FG22-92PC92535

DOE/PC/92535--T2

Principal Investigator: Yiannis A. Levendis

DE93 013611

Co-Investigator: Donald L. Wise

Graduate Student: Judy Steciak

Technical Consultant: Girard Simons

Project Performance Period: 1 January 1993 - 31 March 1993

Project Objectives:

The principal objectives of the proposed research are two-fold: (A) To understand the mechanism and assess the effectiveness of sulfur capture by the chemical calcium magnesium acetate (CMA); and (B) To evaluate the NO_x reduction capabilities of CMA by burning the organic constituents of the chemical (the acetate) and reducing NO to stable N₂. The optimum conditions and the location of CMA introduction in the furnace will be identified.

To achieve these goals water solutions of CMA or dry powders of CMA will be injected into hot air or gases simulating the furnace exhaust (containing CO₂, SO_x, NO_x, H₂O, O₂ etc.) and the composition of gaseous and solid products of the reaction will be monitored. The processes of burning the organic acetate as well as the calcination, sintering and sulfation of the remaining solid will be studied in detail.

The possibility of introducing two different sorbents sequentially will also be examined. For instance, such a scheme may employ injection of the rather inexpensive calcium carbonate initially, followed by the more costly CMA.

The effectiveness of a "homemade" CMA using woody biomass as a low-cost source of acetate will be explored if such a product becomes available during the course of this work.

Finally, CMA will be introduced in the matrix of the coal by an ion exchange or a precipitation technique. Upon subsequent combustion, the composition and physical structure of the remaining ash will be examined, as well as the gas phase SO_x concentration. Both techniques (CMA pretreatment and CMA injection) may also be implemented simultaneously to assess their combined effect on sulfur capture. In these experiments it will be rather

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

MASTER

7-0
B D

important to determine the extent of the physical and chemical structure of the ash in order to develop an understanding of the sulfur capture mechanism.

To achieve these objectives the following project tasks were carried over this 2nd three-month period.

Project Tasks:

Work on four major tasks was conducted over this period:

- (a) The laboratory facilities were relocated in a new space, and they were augmented by the purchase of an on-line SO₂ analyzer.
- (b) A new combustion apparatus was constructed in the same laboratory.
- (c) An existing sulfation model was modified and preliminary results were obtained.

(a) Laboratory relocation - SO₂ Analyzer.

A laboratory move was conducted over the past few months to a new dedicated space. Appropriate ventilation, water and air supplies and high voltage electricity were installed last Summer and Fall. The furnace was installed, as shown in Figure 1, and was interfaced with a paramagnetic O₂ analyzer and a chemiluminescent NO/NO_x analyzer, both manufactured by *Beckman*. These two instruments are shown on the left and far right of Fig. 1, respectively.

A new on-line UV SO₂ analyzer, *Resemount Analytical* model 890, was purchased at \$11,440 (\$9,440 DoE - \$2,000 NU). The instrument has three concentration ranges of sensitivity (5-50, 50-500 and 500-5000 ppm). This instrument was recently interfaced to the exit of the furnace through a separate pump, flowmeters, valves, etc.

(b) Construction of a new high-temperature furnace.

A new high temperature furnace was constructed for single particle/drop combustion for the needs of this work.¹ This furnace is similar to that already existing in our laboratory, shown in Fig. 1. The main difference is that the new furnace has long windows (parallelograms 25 cm long and 2 cm wide) spanning the total length of the radiation cavity, see Fig. 2. This will allow visual or photographic observations of the total particle burnlife from both sides of the furnace. The old furnace was equipped with small circular observations ports (1 cm in diameter) located 2.5 cm below the injector tip. Such observation ports were not very useful because rarely a particle would burn at exactly that height. The construction

¹and for the Coal-Water-Fuel work under DOE Grant #: DE-FG22-89PC89776

Figure 1: *Schematic of the air-tight laminar-flow furnace for emissions monitoring.*

of the new furnace affords observation of entire particle trajectories through the radiation cavity of the furnace, or close-up observations at any height in the furnace. Moreover, the old furnace has now been made completely air-tight, by removing the observation ports and fitting a new alumina tube, and will be used for mass balance and emissions monitoring experiments. The new furnace is not completely air-tight and will be used for single particle experiments.

The casing of the new furnace was manufactured by *ATS* and employs 8 aluminum disilicide heating elements to heat a 25 cm long radiation cavity to a maximum temperature of 1650°C.² The furnace was fitted at both sides with quartz windows equipped with shutters. A high density alumina tube (71 cm long, 7.0 cm i.d.) was purchased from *Coors* with two laser-cut diametrically opposite slots (25 cm long and 1.9 cm wide) and was inserted in the furnace casing with the slots aligned with the furnace windows. The alumina tube was held in place by two *Viton* "o-rings" at its top and bottom ends. The "o-rings" were housed in custom-made water-cooled stainless steel assemblies. Both the furnace casing and the "o-ring" assemblies were held on platforms mounted on a large tubular stand, Fig. 2. A stainless steel water-cooled injector (58 cm long, 1 cm i.d.) was constructed, black-passivated and was mounted at the top of the furnace on a brass flange through a brazed *Cajon* fitting, Figs. 1 and 2. The brass flange also served to introduce air or other gases to the furnace through an aluminum perforated plate - flow straightener. An additional low density, aluminum oxide, honeycomb flow straightener was placed downstream, in the annular space between the injector and the alumina tube, Fig. 1.

The pyrometer optics on platforms were relocated from the old furnace and mounted on the new furnace, Fig. 2. Flow panels for air and other gases as well as water were constructed and mounted on the walls, Fig. 2. The pyrometer and associated data acquisition system were also relocated and interfaced, Fig. 2. Finally, the pyrometer optics were re-aligned and optimized for maximum signal strength.

(c) Theoretical calculations on the SO₂ reduction effectiveness.

The experimental results on the sulfur removal effectiveness of CMA particles have been contrasted to theoretical calculations based on a computationally simple, physics-based

²The furnace and a matching power supply were purchased by Northeastern University at a total cost of ca. \$9,500.

Figure 2: *A photograph of the new single particle furnace facility.*

model (Simons, 1988).^{3 4} This approach of contrasting theory and experiments can greatly enhance our understanding of the data, notably reduce the amount of data that must be taken, and suggest the most important regions of parameter space in which to collect data. The CMA (or CA) transformation may be broken into three distinct steps:

- (i) atomization of the water/CMA (or CA) solution, in the case of wet-spraying method
- (ii) droplet dehydration and formation of the porous oxide sorbent, and
- (iii) sulfation by the porous sorbent

Only the last step was examined in this investigation. The pore structure model employed herein is known as the "pore tree" (Simons, 1988). The sorbent pore structure is described as a set of trees whose trunks are located at the particle surface and the branches in the interior. The distribution of pores of radius r_p is proportional to $(1/r_p)^3$. The transport equations include the effects of bulk diffusion to the particle exterior surface, continuum diffusion within the large pores, and Knudsen diffusion within the small pores. The model corrects for these processes and accounts for first order chemical kinetics at the pore walls. The forward intrinsic rate constant, k_s , was expressed in an Arrhenius form $k_s = 6 \times 10^4 \text{ kg}/(\text{m}^2 \text{ s MPa}) \exp(-17,000/T)$. The reverse reaction rate was also accounted for, with the expression $\dot{k}_s = k_s(1 - p_v/p_s)$, where p_s is the local SO_2 pressure and p_v is the equilibrium vapor pressure given by $p_v = 10^{12}/\sqrt{p_{\text{O}_2}} \text{ MPa} \exp(-52,000/T)$ with p_{O_2} in kPa. This pore structure/pore transport model yields the reactivity as a function of temperature and time, and includes the effects of product deposits, i.e., the increased molar volume of CaSO_4 over that of CaO .

Sulfation modelling used the following initial structural data for the calcite generated by dry-spraying at 1273 K (CASE 1 above): porosity of 66% and the temperature-dependent BET surface area data of Fig. 17. To idealize the sulfation of these calcium-based salts, the

³Simons, G.A. and Garman, A.R. "Small-Pore Closure and the Deactivation of the Limestone Sulfation Reaction." *AIChE J.* **32**, 1491, 1986.

Simons, G.A. Garman, A.R. and Boni, A.A. "The Kinetic Rate of SO_2 Sorption by CaO ." *AIChE J.* **33**, 211, 1987.

Simons, G.A., Ham, D.O., Parker, T.E., Morency, J.R., Moniz, G., Boni, A.A. "Alternative SO_2 Sorbents." Final Report PSI-538 TR-744. Physical Sciences Inc., Andover, MA. (1987).

Simons, G.A. "Parameters Limiting Sulfation by CaO ." *AIChE J.* **34**, 167, 1988.

⁴The model predictions were computed based on physical data (porosity, surface area, etc.) obtained for CaO derived from CMA; they may be also valid for CaO derived from CA. Both of these calcium oxides, derived from acetate compounds of calcium, were highly porous. Since physical data for the less porous calcium oxides derived from either CaCO_3 or Ca(OH)_2 were not obtained in this study, the corresponding experimental results were not compared with theory.

calcine sorbent is considered to react as if the magnesium were inert. Thus,

where m relates to the molar ratio of Mg/Ca. For the degenerate case ($m=0$), the model of Simons and Garman (1986) describes the sulfation of CaO. However, for CMA the molar volumes and densities of the reactants and products must be determined. These parameters alter the rate and extent to which the pores of the calcined CMA are filled with sulfate. These values are listed in Table I and are readily implemented into the model. The intrinsic rate constant was not altered, although subsequent findings may suggest it is appropriate to do so.

TABLE I
SULFATION MODEL PARAMETERS

Material	Molar Volume (cm ³ /mole)	Molar Weight (g/mole)	Density (g/cm ³)
MgO	11.26	40.3	3.58
CaO	16.9	56.1	3.32
CaSO ₄	52.1	136.1	2.61
(CaO · m MgO)	$16.9 + 11.26 m$ (39.4 for $m=2$)	$56.1 + 40.3 m$ (136.7 for $m=2$)	$\frac{3.32+2.38m}{1+0.665m}$ (3.46 for $m=2$)
(CaSO ₄ · m MgO)	$52.1 + 11.26 m$ (74.62 for $m=2$)	$136.1 + 40.3 m$ (216.7 for $m=2$)	$\frac{2.61+0.773m}{1+0.216m}$ (2.902 for $m=2$)

The model parameters in Table I immediately suggest an increased calcium utilization for CMA. Notice that the molar volume during sulfation of CaO increases by a factor of 3.1, thus, plugging the pores and limiting conversion. However, the molar volume during sulfation of (CaO · m MgO) increases by a factor of only 1.9. This permits better utilization of the oxide.

Theoretical results are shown in Fig. 3, where the predicted percent of sulfur removal is plotted versus the sorbent particle diameter, in the range of 2 to 100 μm , furnace gas temperatures in the range of 1023-1323 K, and Ca/S ratios of 1 and 2. Fig. 3(a) is pertinent to CaO, meanwhile Fig. 3(b) corresponds to CMA-derived (CaO · m MgO), with $m=2$ for the CMA compound used herein. As expected, the SO₂ removal effectiveness of both types of sorbents decreases, inversely proportional to the sorbent particle size. Furthermore, the effectiveness improves with increasing temperature in this range. It can be seen, from Fig. 19(b), that the predicted SO₂ removal efficiency of CMA at 1223 K, Ca/S=2 and a particle

diameter of $50\mu\text{m}$ is 43% instead of the measured efficiencies in the range of 80-90%. Keeping in mind that the model approximates the physics of solid particles and not cenospheres, this discrepancy could be explained by the fact that the SO_2 gas penetrates the interior of the cenosphere where reaction also takes place.⁵ Thus, the effective thickness of the particle may be equal to the cenosphere walls, i.e. $4\text{-}10\mu\text{m}$, where the model actually predicts close to 90% sulfur removal. Thus, the CMA-derived sorbent out-performs the calcium carbonate and calcium hydroxide sorbents because of its superior cenospheric structure. To explore this point further, additional sulfation experiments were conducted using three different CMA particle size cuts:

- (a) $125\text{-}150\mu\text{m}$
- (b) $53 - 62\mu\text{m}$ and
- (c) $38 - 45\mu\text{m}$.

All of these batches formed cenospheric particles upon calcination and/or sulfation, the latter occasionally combining together to form large “pop-corn”-like particles with comparable wall thickness. Sorbent particles in all of these size cuts resulted in sulfur removal efficiencies in the low to mid-80% region at $\text{Ca/S}=2$ and 950°C . Thus, as revealed by the theoretical analysis, the wall structure and thickness, rather than the particle size, are the important parameters in assessing the utilization of the cenospheric sorbent particles (CMA and CA). The wall thickness of the cenospheres, produced herein, was in the range of $4\text{-}10\mu\text{m}$ which might have been subjected to mild pore diffusion limitations. In contrast, micron size particles, that were, indeed, produced by nebulization of CMA or CA solutions seem to react in a kinetically control regime, free of pore diffusion limitations. Associated sorbent utilization was measured to be close to 100%, as predicted by the model.

Furthermore, there may be additional advantages of the dolomite-derived CMA over the calcite-derived CA, attributed to its pore structure and shape of the pores, as suggested elsewhere (Cole *et al.*, 1986), but most importantly to the smaller increase of the molar volume of the sulfated product. Thus the likelihood of plugging of pores during sulfation is less in CMA than in CA. Finally, there is a possibility of catalytic action of impurities, like iron, etc. that are present in the commercially available CMA.

The model reproduced the SO_2 removal data obtained at high temperature (above 850°C) for all sorbents but underpredicted somewhat the data at the lowest gas temperature. This effect cannot be attributed to the magnesium since it is not present in three of the sorbents.

⁵The penetration of SO_2 to the interior of the cenosphere may not be complete because of pore diffusion limitations.

Figure 3: Model predictions of SO_2 removal at various particle sizes and temperatures of (a) $\text{CaO} \cdot m\text{MgO}$ and (b) CaO , Ca/S ratios of 1 and 2. The porosity was 60% and BET areas in the neighborhood of $25 \text{ m}^3/\text{g}$, as given in the text. (a) (· · · · ·) 1050°C (b) (· · ·) 950°C (c) (- - -) 850°C . Curves with asterisks (*) denote Ca/S ratio of 1.

However, the model was fully validated (Simons *et al.*, 1987) only in the SO_2 pressure range of 60 Pa to 5 kPa and the present data base is below 56 Pa SO_2 . Since SO_2 goes through several intermediate steps to form CaSO_4 , the rate limiting step at low SO_2 pressure and low temperature may have a lower activation energy and/or reaction order than that determined at high SO_2 pressure. This will be investigated further in a future study as it is important in achieving greater than 80% SO_2 removal in standard combustion systems, i.e., in obtaining less than 600 ppm SO_2 .

PRESENT WORK and FUTURE PLANS During the present, 3rd quarter, work is being conducted on NO_x reduction experiments.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

END

**DATE
FILMED**

6 / 10 / 93