WSRC-TR-90-412, Rev. 1

DEGB LOCA ECS POWER LIMIT RECOMMENDATION FOR THE K-14.1 SUBCYCLE (U)

by F. G. Smith, III

Westinghouse Savannah River Company
Savannah River Site
Aiken, South Carolina 29808

WSRC-TR--90-412-Rev. 1

DE93 004439

Other Authors:

S. E. Aleman
(WSRC)

This paper was prepared in connection with work done under Contract No. DE-AC09-89SR18035 with the U. S. Department of Energy. By acceptance of this paper, the publisher and/or recipient acknowledges the U. S. Government's right to retain a nonexclusive, royalty-free license in and to any copyright covering this paper, along with the right to reproduce and to authorize others to reproduce all or part of the copyrighted paper.

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831; prices available from (615) 576-8401, FTS 626-8401.

Available to the public from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

WSRC-TR-90-412
Revision 1

NRTSC
**NUCLEAR REACTOR TECHNOLOGY
AND SCIENTIFIC COMPUTATIONS**

KEYWORDS: LOCA
ECS (EMERGENCY
COOLING SYSTEM)
ASSEMBLY LIMITS

RETENTION: PERMANENT

**DEGB LOCA ECS Power Limit Recommendation
for the K-14.1 Subcycle (U)**

by

F. G. Smith, III
and
S. E. Aleman

ISSUED: April, 1991

J. P. Faraci

Authorized Derivative Classifier

4/4/91

Date

Westinghouse Savannah River Company
Savannah River Laboratory
Aiken, SC 29808

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

PROJECT: DEGB-LOCA ECS Limits for K-14.1
QA Task Number 91-005-1

DOCUMENT: WSRC-TR-90-412

TITLE: DEGB LOCA ECS POWER LIMIT RECOMMENDATION
FOR THE K-14.1 SUBCYCLE (U)
REVISION NUMBER: 1

APPROVALS

B. J. HARDY, TECHNICAL REVIEWER 4/10/91
DATE

W. M. MASSEY, TECHNICAL REVIEWER 4/8/91
DATE

W. H. HORTON, NES CODE DEVELOPMENT GROUP MANAGER 4/10/91
DATE

A. J. GARRETT, NES MANAGER 4/10/91
DATE

TABLE OF CONTENTS

1. Introduction.....	1
2. Computational Methodology	1
2.1 Basis for Selection of "2 Sigma" Sensitivity Variable Settings.....	3
Inlet Liquid Flow	3
Inlet Oscillations	3
Tube Power Fractions.....	4
Heat Transfer Coefficient.....	4
Wall Friction.....	4
Channel Inlet Void.....	5
Rib Cross-Flow Model.....	5
Interfacial Drag.....	6
Bottom End Fitting Form Loss.....	6
Tube Thickness	6
Axial Heated Length.....	7
2.2 FLOWTRAN-TF Assembly Code Uncertainties.....	7
3. Boundary Conditions.....	7
3.1 Assembly Geometry (Bowling/Eccentricity)	8
3.2 Neutronics Boundary Conditions	9
Tube Power Fraction and Assembly Exposure.....	9
Axial Power Shape	10
Azimuthal Power Tilt.....	10
Moderated Core	10
Deposited Power	10
3.3 RELAP5 System Boundary Conditions.....	17
Inlet Void Fraction.....	17
Inlet Temperature	17
Pressure Drop	18
Tank Level.....	18
3.4 Nominal Boundary Conditions for DEGB LOCA Analysis	21
4. Recommended ECS Power Limit for K-14.1 Subcycle.....	22
4.1 Nominal ECS Mark 22 Power Limit.....	22
4.2 LOCA Sensitivity Analyses About Nominal Conditions	23

4.3	Calculation of Flowzone Effluent Temperature Limits	27
5.	Safety Margins	30
5.1	Twall and OTE Power Limits for the Mark 22 Assembly	30
5.2	Twall and OTE in Rigs FA and FB Compared to Mark 22 Assembly.....	31
5.3	Best Estimate Versus Bounding Value of Inlet Temperature.....	33
5.4	Deposited Decay Power Transient	34
5.5	"Development Margin" Factor.....	34
6.	Conclusion	34
7.	References	35
	Appendix A. Linear Versus Nonlinear Response Surface	36
	Appendix B. Fluid and Metal Characteristics at the Limiting Condition.....	38

1. Introduction

This report documents assembly deposited power limits and the corresponding effluent temperature limits recommended for operating the K-14.1 subcycle to ensure sufficient cooling of reactor assemblies during the ECS phase of a Double Ended Guillotine Break (DEGB) Loss Of Coolant Accident (LOCA). The ECS LOCA effluent temperature limits are computed for each flowzone of the K-14.1 charge. The recommended overall DEGB LOCA ECS power limit is 1515 MW or about 63.1% of the historical full reactor power limit (assumed to be 2400 MW) for Mark 22 assemblies. The design basis accident is a break in the plenum inlet line where the AC pump motors not tripped.

The recommended power limit is based on a FLOWTRAN-TF calculation of the maximum assembly power level that prevents any surface temperature inside the assembly from exceeding the local fluid saturation temperature at any time during the ECS phase of the accident. A sensitivity analysis is applied to reduce the FLOWTRAN-TF nominal estimate of this assembly power level to account for uncertainties in the analysis. The resulting conservative power limit is converted into a corresponding limit on the assembly effluent temperature. After applying additional conservatism to the temperature limit to account for variability in reactor operating conditions, the corresponding average assembly power level is reported as our final estimate of a conservative power limit. This ECS limit is designed to be highly conservative, and the conservatism is demonstrated in this report by quantifying explicit and embedded safety margins.

We first present a summary of the limits computational methodology in Chapter 2. This discussion includes an explanation of the basis for the selection of the sensitivity variable settings. In Chapter 3 we present graphs of the transient boundary conditions used for the calculation of the nominal assembly power limit and discuss some of the other assembly model settings used for the FLOWTRAN-TF calculations. Finally, in Chapter 4 we discuss the application of the sensitivity analysis methodology and show the steps used to calculate the recommended power limit. In Appendix A we present an assessment of the linear response surface statistical method used to perform the uncertainty analysis. In Appendix B we present plots of the predicted fluid and metal conditions within the assembly at the location and time when the limit is set.

2. Computational Methodology

The computational methodology is fully documented in "DEGB LOCA ECS Power Limits Methodology (U), Rev. 1", WSRC-TR-90-411 [1]. To introduce the calculational results, we first summarize the basic procedure used to compute assembly effluent temperature limits as follows:

- Select specific environmental factors such as the river water (actually the system analysis uses the water temperature in the 186 cooling basin) and the polybor temperatures.
- Select the worst case accident based on the minimum nominal assembly flowrate computed using the RELAP5 system analysis. The nominal state is defined such that the dominant contributors (geometric, neutronic, and system boundary conditions) to power level are bounded while the rest are at their best estimate values. Bounding the dominant contributors eliminates the need to perform power limit iterations between the system and assembly models, as well as between the system and neutronics calculations.

- Perform a linear error propagation (star pattern) sensitivity study about the nominal state with FLOWTRAN-TF. The candidate sensitivity variables for the Mark 22 assembly are listed in Table 2-1 [1]. A sensitivity study is performed for each variable at plus and minus "2 sigma" about its nominal setting. Given these sensitivity runs, a conservative linear approximation to the FLOWTRAN-TF computed power limit (i.e. response surface) is created. We note that the terminology "2 sigma" is not used in a rigorous way but is intended to imply an acceptable level of uncertainty.

Table 2-1 Mark-22 assembly sensitivity variable list for $T_{\text{wall}} = T_{\text{sat}}$ limits criterion strategy.

Category	Sensitivity and Bounded Variables	Setting
System:	Inlet Temperature Pressure Drop Inlet Liquid Flow Inlet Flow Oscillations	bounded bounded partially bounded best estimate
Neutronics:	Deposited Power Axial Power Shape Azimuthal Power Shape Assembly Exposure Tube Power Fractions	bounded bounded bounded bounded 2 sigma
Constitutive Relations:	Heat Transfer Coefficient Wall Friction Channel Inlet Void Rib Cross-Flow Model Interfacial Drag Bottom End Fitting Form Loss	2 sigma 2 sigma 2 sigma 2 sigma 2 sigma 2 sigma
Geometry:	Bowing/Eccentricity Wall Temperature Peaking Tube Thickness Axial Heated Length	bounded bounded 2 sigma 2 sigma

- An overall uncertainty allowance for the minimum (within core) power limit is computed assuming that the sensitivity variables are independent random variables. An unconsidered factor (a beta multiplier referred to as our "development margin") is also included at this step to further reduce the power limit to account for any unconsidered factors in the analysis.
- An overall uncertainty allowance for the maximum allowable assembly temperature rise is computed. This calculation incorporates the overall power allowance, as well as uncertainty allowances for the pre-incident maximum assembly flowrate and for in-reactor thermocouple measurements.

- If the environmental factors of basin water and polybor temperatures are not set to bounding values over the life of the cycle, then the maximum allowable assembly temperature rise must be computed over the expected range of these factors.

2.1 Basis for Selection of "2 Sigma" Sensitivity Variable Settings

In this section, we present the basis for selecting the "2 sigma" sensitivity settings for the unbounded variables listed in Table 2-1. In some instances, the "2 sigma" settings are based on a statistical analysis of the associated data base. However, in other cases, the assignment of a sensitivity bound is based on engineering judgement of a sufficiently conservative value that will provide a high degree of confidence that the possible changes in the variable are accounted for.

Inlet Liquid Flow

Inlet liquid flowrate was found to be the dominant sensitivity variable in the calculation of a conservative power limit. Therefore, additional sensitivity runs were made over a range of liquid flowrates. A detailed discussion of these results is presented in Section 4.2 below.

Inlet Oscillations

L-Area test data shows that oscillations occur in the plenum inlet pressure and in the plenum level [2]. Based on an analysis of data taken at several positions across the plenum, these oscillations were found to have the following characteristics in maximum amplitude and frequency:

Table 2-2 Inlet oscillation parameters based on L-Area test data.

Plenum Oscillation	Amplitude (% of Mean)	Frequency (Hertz)
Pressure	5	2.5 - 2.8
Level	15	2.6 - 3.2

The amplitude of the oscillations in plenum level were usually within 7% of the mean and pressure oscillation were within 4%; however, the maximum bounding values listed in Table 2-2 were used in our analysis as "2 sigma" levels. The level oscillations were found to lag the pressure oscillations by approximately 90° in most cases.

FLOWTRAN-TF boundary conditions modeling the inlet oscillations were then constructed using

$$x = \bar{x}[1 + A \sin(\omega t + \phi)] \quad (2-1)$$

where:

- A - Amplitude of oscillation
- t - Time from start of LOCA
- x - Value of oscillatory plenum pressure or plenum level
- $\bar{x}$ - Nominal value of plenum pressure or plenum level
- ω - Oscillation frequency

ϕ - Phase lag

The following combinations of inlet oscillations were tested using the bounding amplitudes and frequencies shown in Table 2-2:

1. Pressure and void oscillations occurring in phase.
2. Pressure and void oscillations with a 90° lag in void.
3. Pressure and void oscillations out of phase (180° lag).
4. Pressure oscillations alone.
5. Void oscillations alone.

Testing the sensitivity of assembly power limits to the range of inlet oscillations described above was felt to provide an evaluation of oscillatory boundary conditions at a high level of confidence compatible with our definition of a "2 sigma" bound. An extensive set of oscillation sensitivity calculations was made for the limits calculations reported in Version 0 of this report. These calculations indicated that a slight ($\sim 3\%$) power increase resulted from adding oscillations to the transient boundary conditions. We do not take credit for this power increase in the calculation of reactor power limits but only use the results to indicate that we do not need to include the oscillations in the boundary conditions. Since the accident scenario did not change for the revised limits calculations reported here and since the thermal-hydraulic boundary conditions were essentially unchanged (with the exception of the inlet temperature transient which does not show oscillations), we have not repeated the oscillation sensitivity calculations with the revised boundary conditions but assume that the impact is negligible based on our previous results.

Tube Power Fractions

Based on neutronic calculations and 300-Area fabrication tolerances, a "2 sigma" level uncertainty of 3.4% in fuel tube power fraction variation has been established [3]. For this sensitivity variable, a 3.4% shift in power fraction from the inner to the outer fuel tube was made.

Heat Transfer Coefficient

As described in Ref. [4], the heat transfer correlations used in FLOWTRAN-TF were derived from an analysis of the Rig-B two-phase heat transfer data. Separate correlations were developed for the annular flow regime and for the churn-turbulent flow regime. The correlations were developed from data over a wide range of liquid flow rates and pressure boundary conditions on the single channel rig. From a statistical analysis of the Rig-B heat transfer data, 95% confidence bounds on the correlations were constructed. The lower limits to these bounds reduced the heat transfer coefficient in the annular flow regime by 44.8% and in the churn-turbulent flow regime by 36.1%. A variation of $\pm 50\%$ was actually used for the "2 sigma" sensitivity variation in the heat transfer coefficient for our uncertainty analysis. This variation is greater than the bounds estimated from the Rig-B data and therefore includes some additional margin in the two-phase heat transfer coefficients to better reflect the actual uncertainty in their true values.

Wall Friction

FLOWTRAN-TF uses single-phase friction factors for the gas and liquid phases based on the Darcy-Weisbach equation to calculate the wall friction for each phase [4]. Code calculations of void fraction using a $\pm 25\%$ variation in wall friction bounded (at

approximately a 95% confidence level) the data taken on the SRS Void Rig for a plenum pressure of -1 psig, a 12" tank level, and liquid flowrates of 5 to 35 gpm [5]. Therefore, frictional drag at the wall was varied by $\pm 25\%$ from its nominal value as a "2 sigma" sensitivity setting. The 25% variation obtained from the data analysis was judged to be sufficiently large to account for any uncertainty in applying the wall drag correlations to two-phase flows.

Channel Inlet Void

FLOWTRAN-TF calculates the inlet void fraction to each of the three primary annular flow channels of the Mark 22 assembly as a function of the void fraction in the cell immediately above the channels. This calculation uses void fraction correlations derived from the annular liquid splits measured in the Babcock and Wilcox (B&W) experimental program [6] on a test rig that is a prototypic model of an actual SRS Mark 22 assembly. Based on an analysis of the B&W experimental data, bounds of $\pm 0.4\alpha(1-\alpha)$ were established as "2 sigma" limits for these correlations. Since, at the point where the ECS limit is trimmed, the flow conditions are relatively constant, we can use FLOWTRAN-TF to calculate a reasonably accurate estimate of channel liquid flow splits based on the inlet void fraction in each flow channel. Estimates of the liquid flow fractions are presented in Table 2-3 to give some idea of the variation in liquid flow tested through the sensitivity analysis. A detailed description of the channel inlet void model is given in Ref. [4] and comparisons of model predictions of measured flow splits to data obtained on the B&W prototypic experimental rig are provided in "FLOWTRAN-TF Code Benchmarking (U)", WSRC-TR-90-414.

Table 2-3 Channel liquid flow fraction for a Mark 22 at ECS conditions.

Case	Inner Channel	Middle Channel	Outer Channel
Nominal	0.44	0.27	0.29
Lower Void to Inner Channel	0.51	0.21	0.28
Higher Void to Inner Channel	0.34	0.30	0.36
Lower Void to Middle Channel	0.42	0.40	0.19
Higher Void to Middle Channel	0.43	0.15	0.43

Rib Cross-Flow Model

Each subchannel in the Mark 22 assembly was used as a fluid computational cell for all of the FLOWTRAN-TF limits calculations. Therefore, the code calculated a subchannel average void fraction. Flow between the fluid cells (across the rib gaps) was modeled by solving the azimuthal momentum equations with form losses at the ribs. For our nominal model, the void fraction at the rib gap (α_{Rib}) was set equal to the cell (subchannel) average void fraction ($\alpha_{\text{Cell Average}}$) calculated by FLOWTRAN-TF. This is illustrated by the 45° line shown in Fig. 2-1. Since water will tend to preferentially flow along the

wetting metal surfaces where the ribs are attached to the tube surfaces, we would expect the void fraction to actually be somewhat lower near the ribs than in the center of each subchannel. This effect would likely be most pronounced at higher cell void fractions. Therefore, to test the sensitivity to the rib cross-flow model, we used the altered model shown in Fig. 2-1 to determine void fraction at the rib gap. This model reduces the void fraction at the ribs at cell average void fractions greater than 0.25.

Figure 2-1 Nominal and sensitivity analysis rib void models.

Interfacial Drag

The interfacial drag was varied by $\pm 50\%$ to test its effect on the power limit. The choice of a 50% variation was based on the judgement that this represented a sufficiently large variation to give a high level of confidence that we had bounded the true interfacial drag.

Bottom End Fitting Form Loss

The form loss coefficient in the bottom end fitting was varied by $\pm 50\%$ to test the sensitivity of the power limit to this parameter. Again, the 50% value was selected to give a high degree of confidence that actual variations were accounted for.

Tube Thickness

Based on allowed tolerances in the 300-Area fabrication process, the inner diameter of the tubes was varied by ± 0.005 inches and the outer diameter by ± 0.008 inches. Two combinations of these tolerances were tested:

1. Increased inner diameter with decreased outer diameter to give the minimum tube thickness.

2. Decreased inner diameter with increased outer diameter to give the maximum tube thickness.

All of the fuel and target tubes in the assembly were varied simultaneously. All of the changes in diameter were applied to the inner or outer cladding thickness and fuel or target core dimensions were assumed to remain unchanged. We note that 300-Area quality assurance measurements on manufactured tubes indicate that the majority of the tubes have inner and outer diameters within ± 0.002 inches of their nominal dimension. In fact the largest variation actually measured in tube diameters was only ± 0.004 inches. Therefore, the use of the manufacturing tolerances in our analysis is taken to be an appropriate estimate of the "2 sigma" variation in thickness.

Axial Heated Length

Based on allowed tolerances in the 300-Area fabrication process, the heated length of the assembly was varied by ± 6.0 inches. As with the tube thickness, we assume that this manufacturing tolerance is an estimate of the "2 sigma" variation in axial heated length and that most tube lengths actually fall well within this tolerance.

2.2 FLOWTRAN-TF Assembly Code Uncertainties

The current benchmarking of the FLOWTRAN-TF code is based on single channel heated tests and multiple channel unheated tests. A significant uncertainty in the assembly analysis is then the application of FLOWTRAN-TF to multi-channel heated Mark 22 ECS limits. This deficiency will be resolved when prototypic experimental data becomes available and the FLOWTRAN-TF code can be benchmarked against it. The FLOWTRAN-TF model of a Mark 22 assembly is designed to simulate the alterations in channel flow splits that result from multi-channel heating effects. Based on $T_{\text{wall}} = T_{\text{sat}}$ and OTE single channel heated tests performed in Rig-FA, where the bypass was valved closed and open (thereby simulating the presence of an alternative flow path), heating effects do not divert significant quantities of channel inlet liquid flows [7]. This experimental evidence suggests that channel flow splits determined from unheated prototypic tests are valid at the heat loads of interest in limits calculations.

Code uncertainties identified by benchmarking against single channel heated and multiple channel unheated tests are accounted for in the uncertainty analysis. Flow oscillations were tested in an experimental rig and found to have little impact on the $T_{\text{wall}} = T_{\text{sat}}$ power limits [8]. FLOWTRAN-TF correctly predicted that flow oscillations would have little effect on ECS limits. All other significant uncertainties in the Mark 22 analysis are accounted for through the uncertainty analysis.

We have conducted some nodalization sensitivity runs with FLOWTRAN-TF. As is usually the case with two-fluid thermal-hydraulics codes, there is some dependence on the number of nodes used. To minimize such dependence, we have used the same axial channel nodalization for the Mark 22 ECS limits runs that was used for benchmarking FLOWTRAN-TF.

3. Boundary Conditions

In this section of the report, we discuss the FLOWTRAN-TF input transients, assembly geometry, and other boundary conditions used to generate the reactor limits. The values assigned to the bounded variables listed in Table 2-1 are also listed in this section.

Neutronics boundary conditions are generated through the LLAP code. RELAP5 calculations supplied the input system transients. We have chosen the most conservative of the six combinations of break location and AC trip as a basis for our assembly limits. This limiting case was a plenum inlet break with the AC pump motors remaining on.

3.1 Assembly Geometry (Bowing/Eccentricity)

The azimuthal power tilt in the reactor will lead to non-uniform heating around the assembly. We expect that this non-uniform azimuthal heat flux will tend to bow the assembly in the direction of the hottest sector. The bowing will in turn shift the internal tubes in the same direction causing eccentric positioning. Therefore, our nominal model of a Mark 22 assembly includes bowing and eccentricity in the geometry.

Bowing of the assembly is illustrated in Fig. 3.1-1. We assume a 2-inch (δ measured at the center of the heated section of the assembly) cosine shaped bow of all four tubes in the direction of the power tilt. As shown in Fig. 3.1-1, the bowing, in effect, alters the local axial and azimuthal gravity vectors in the fluid cells. This will cause diversion of subchannel liquid flow away from the azimuthal regions of higher heat fluxes in the upper portion of the assembly.

Figure 3.1-1 Schematic illustration of rig bowing.

Because of the non-uniform heating, it is not likely that the fuel and target tubes within an assembly remain perfectly concentric under normal operating conditions. As a conservative bounding condition, we assume 100% eccentricity of the inner target and both fuel tubes in the direction of the power tilt. This is illustrated in Fig. 3.1-2 where a representation (not drawn to scale) of the cross-sectional view of a Mark 22 assembly with the tubes eccentrically positioned in the 45° direction is shown. This eccentricity reduces the subchannel flow areas in the regions of higher azimuthal heat flux. Power tilts with corresponding eccentricities at 0° , 22.5° , and 45° were tested (azimuthal angles are oriented

as illustrated in Fig. 3.1-2). The 45° direction was found to give the minimum power limit and was therefore selected as a bounding direction for our nominal assembly model.

Figure 3.1-2 Mark 22 cross-sectional view illustrating channel eccentricity.

3.2 Neutronics Boundary Conditions

The boundary conditions used to determine the assembly power level and a complete set of the various power distribution functions used by the FLOWTRAN-TF code to calculate deposited power at each solid node for a Mark 22 assembly are presented in this section of the report. Further details on the calculation of the neutronic boundary conditions are provided in Ref. [9].

Tube Power Fraction and Assembly Exposure

Power fractions for fission power, wet decay heat, and dry decay heat for the inner fuel tube are shown in Fig. 3.2-1 as a function of percent U-235 burnup. Radial power shapes for start and end of cycle (labeled as SOC and EOC, respectively) for the inner fuel tube are shown in Fig. 3.2-2. Similarly, power fractions for the outer fuel tube are plotted in Fig. 3.2-3 and the radial power shapes shown in Fig. 3.2-4. Power fractions for the inner and outer target tubes are shown in Fig. 3.2-5 and Fig. 3.2-6, respectively. While there was little difference in the power limits obtained using start and end of cycle power shapes and power fractions, the end of cycle power shapes and a corresponding fuel burnup of 41.4%

were found to be slightly limiting conditions and were used to perform the K-14.1 limits calculations. The burnup value of 41.4% is actually appropriate for the entire K-14 cycle which implies that the ECS limits reported here are probably good for the whole cycle. However, little gain is realized by using a subcycle specific burnup since limits calculated at start and end of cycle were almost identical.

Axial Power Shape

Figure 3.2-7 shows the axial power shape [10] used in the FLOWTRAN-TF calculations. This peaked (1.55) cosine shape produced the most conservative flow instability power limit (as calculated by the FLOWTRAN-FI code) for all of the shapes investigated in the reference document. A linear power profile was also tested for ECS conditions and was found to produce a slightly higher power limit. Therefore, the peaked cosine shape was used to bound the axial power profile for all of the limits calculations. An exhaustive examination of all possible power shapes to determine the absolute bounding shape for ECS conditions has not been made. However, the peaked cosine profile that was used will cause a peak in the surface temperature and will probably lead to the lowest ECS power limit based on the $T_{wall} = T_{sat}$ criterion. Note that in plotting Fig. 3.2-7, we have used a normalized axial position where the top of the core is the zero position and the bottom of the core is one.

Azimuthal Power Tilt

The reactor assemblies experience an azimuthal power tilt caused by the positioning of adjacent control rods that can be as large as $\pm 20\%$. Figure 3.2-8 shows an azimuthal power profile with a 20% tilt peaked in three different directions (0° , 22.5° , and 45°). The FLOWTRAN-TF calculations used eight azimuthal cells. The points on the power curves are the cell center locations used with the FLOWTRAN-TF solid nodes. As noted above, all three tilt directions were tested in FLOWTRAN-TF runs and the most limiting case (45°) giving the lowest power limit was selected as the nominal tilt direction. The 20% azimuthal power tilt represents a worst case bounding value in that neutronics calculations show that at least 95% (i.e. a 2 sigma bounding level) of the possible power tilts that can be found within the core are less than this value [11].

Moderated Core

Figure 3.2-9 shows the fraction of the core that is moderated as a function of time into the transient. This input is used in the power calculation to determine whether nodes in the axial mesh are dry or moderated when calculating the appropriate decay heat contribution to total deposited power. The fraction of the core that is moderated is obtained from the tank level transient (shown in Fig. 3.3-5 below) using an active core region ranging from 2 to 14.5 feet above the tank bottom.

Deposited Power

The power transient inputs to FLOWTRAN-TF are shown in Figs. 3.2-10 and 3.2-11 [12]. In Fig. 3.2-10 we plot the relative total deposited power and the contributions from fission, wet decay, and dry decay powers. An expanded view of the lower portion of these power transients is shown in Fig. 3.2-11. We see that the total power rapidly falls to about 15% of the pre-incident value within 10 seconds after initiation of the LOCA as the reactor scrams. Decay heat also builds up relatively quickly reaching a maximum at about 20 seconds after the break and slowly declining thereafter such that the total deposited power remains at about 4% of its pre-incident value well into the transient.

All of the limits calculations were performed with the nominal power transients shown below. The power transients are based on recent neutronic calculations that employed conservative estimates of wet and dry decay heat contributions [9]. The ECS limits are set under dry tank conditions. Note that the nominal fission power contribution was set equal to the conservative fission power contribution consistent with a recent update in Reactor 105 Standards and Specifications. The net difference between nominal and conservative powers was estimated to be approximately 6.1%.

Figure 3.2-1 Mark-22 inner fuel power fractions as a function of burnup.

Figure 3.2-2 Mark-22 inner fuel radial power shape at start and end of cycle.

Figure 3.2-3 Mark-22 outer fuel power fractions as a function of burnup.

Figure 3.2-4 Mark-22 outer fuel radial power shape at start and end of cycle.

Figure 3.2-5 Mark-22 inner target power fractions as a function of burnup.

Figure 3.2-6 Mark-22 outer target power fractions as a function of burnup.

Figure 3.2-7 Mark-22 axial power shape.

Figure 3.2-8 Mark-22 azimuthal power shapes.

Figure 3.2-9 Mark-22 fraction of core moderated.

Figure 3.2-10 Mark-22 deposited power distribution.

Figure 3.2-11 Expanded view of Mark-22 deposited power distribution.

3.3 RELAP5 System Boundary Conditions

In this section of the report, we present the system boundary conditions used for the FLOWTRAN-TF limits calculations.

Inlet Void Fraction

For the limits calculations, FLOWTRAN-TF was run using its option to apply a horizontally stratified plenum boundary condition. With this option, the code uses the inlet void fraction, based on a stratified flow regime, to determine the liquid flow into the assembly by making a weir-flow calculation of liquid flow into the USH inlet slots. Therefore, to set the minimum assembly flow, the corresponding inlet void fraction must be specified from a determination of the liquid height in the plenum. Figure 3.3-1 shows the inlet void fraction transients used to generate minimum assembly flows of from 10 to 50 gpm. As discussed in Ref. [1], the 30 gpm flow represents a conservative estimate of the minimum assembly flow and is used as the nominal value for the ECS limits calculations. The basic RELAP5 system calculations are discussed in Ref. [13].

In Fig. 3.3-1, we also show the inlet void fraction transient calculated by the RELAP5 system model. The adjusted transients follow the RELAP5 output up to a time of about 55 seconds into the transient. At this point, we simply take a linear increase in void fraction up to the value required to produce the desired assembly flow rate at approximately 95 seconds. Beyond 95 seconds, we assume that the void fraction remains constant. As shown in Fig. 3.3-1, the RELAP5 transient actually shows significant oscillations in the void fraction between about 60 and 120 seconds after the start of the accident. We believe that these oscillations are largely artifacts of the RELAP5 numerics and do not represent a true simulation of the plenum inlet void fraction; therefore, we have constructed smooth curves to represent the inlet void fraction transients. Nevertheless, we have constructed our nominal transient at 30 gpm minimum assembly flow such that the inlet void fraction is approximately equal to or greater than the RELAP5 predicted void fraction at all times throughout the transient. This procedure produces the 95 second ending time for the void ramp that was then used with the other transients for consistency.

Inlet Temperature

Figure 3.3-2 shows the RELAP5 calculated transient for assembly inlet temperature and the corresponding conservative upper bound used in the actual limits calculations. The system calculations (RELAP5 curve shown in Fig. 3.3-2) were performed assuming a reactor power of 1200 MW which is approximately 50% of historical full power operation, a basin water temperature of 28 °C, and a polybor temperature of 40 °C. Technical specifications actually allow for a 30 °C maximum basin water temperature, therefore we have increase the intermediate region of the RELAP5 computed temperature transient by 2 °C to account for this possible increase in cooling water temperature. The polybor exhaustion time has also been shifted from 115 seconds to 125 seconds to bound the uncertainty in the polybor volume. These adjustments produce the nominal curve in Fig. 3.3-2 which represents the conservative estimate of the inlet fluid temperature used in the power limits calculations. The inlet temperature declines in the initial portion of the transient as reactor power decreases. However, the temperature levels off at about 60 seconds into the transient when hot polybor enters the system. The sharp decline in the inlet temperature at about 125 seconds occurs when the hot polybor is exhausted and the coolant water rapidly changes to cold basin water which is assumed to be at 30 °C. We note that the basin water and

polybor temperatures are set to their maximum values in the analysis so that the inlet temperature transient is very conservative.

Pressure Drop

The plenum pressure transient computed by the RELAP5 system model and the conservative bounding curve used as input to FLOWTRAN-TF are shown in Fig. 3.3-3. In this report, we consistently use the term plenum pressure to mean the pressure at the center of the FLOWTRAN-TF plenum cell and the term tank bottom pressure to mean the pressure at the center of the FLOWTRAN-TF tank bottom cell. Since these cell centers do not coincide with the corresponding system model cells the calculated system pressures have been corrected to the FLOWTRAN-TF cell locations. The plenum pressure falls almost instantaneously from its pre-incident level of about 90 psi to around 38 psi. During the ECS phase of the transient, the pressure gradually declines to an equilibrium value of about 16 psi. The nominal pressure curve was obtained by reducing the plenum pressure calculated by RELAP5 by approximately 1.3 psi at 60 seconds into the transient and beyond. This yields a relatively constant pressure difference across the assembly of -0.5 psi ($P_{\text{plenum}} - P_{\text{tank bottom}}$) from about 70 seconds into the transient and beyond. It is within this time segment that the power limit is set and, as shown in Section 4.2, imposing this overall pressure difference produces a conservative lower bound to the power limit. We note that the RELAP5 system model uses six azimuthal sectors and three rings to model the reactor tank and plenum. The assembly pressure boundary conditions are taken from sector five (the break sector) and ring two.

Figure 3.3-4 shows the LOCA transient for the tank bottom pressure calculated by RELAP5 and adjusted to match the pressure at the center of the corresponding FLOWTRAN-TF cell. This transient is used directly as FLOWTRAN-TF input without modification. Conservatism is applied to the assembly pressure transient by adjusting the plenum pressure, as shown in Fig. 3.3-3, to give a bounding overall pressure gradient.

Tank Level

In Fig. 3.3-5 we show the RELAP5 tank level transient for the DEGB LOCA. This input data to FLOWTRAN-TF is taken unmodified from the RELAP5 system calculation. The tank level transient is used to determine the fraction of the core that is moderated (see Fig. 3.2-9) and therefore only affects the power distribution calculation in FLOWTRAN-TF. Since the minimum assembly flow has been reduced from the nominal value calculated by RELAP5, the tank level transient is to some extent inconsistent with the other boundary conditions. At a lower core flow, that would be compatible with the adjusted assembly boundary conditions, the tank level would be a few inches lower. However, at the point where the ECS limit is set, the tank level is below the active core and a lower tank level would have no impact on the power distribution calculations. Therefore, modifying the tank level transient to more closely reflect the other boundary conditions would only impact the ECS effluent temperature limit if metal temperatures late in the transient were strongly influenced by the power distribution during the initial portion of the accident transient. By the time ECS limits are set, the influence of conditions early in the transient is not strong and a modified tank level transient would therefore not significantly impact the resulting limit.

Figure 3.3-1 Plenum inlet void fraction transients.

Figure 3.3-2 Plenum inlet temperature transient.

Figure 3.3-3 Plenum pressure transient.

Figure 3.3-4 Tank bottom pressure transient from RELAP5.

Figure 3.3-5 Tank level transient from RELAP5.

3.4 Nominal Boundary Conditions for DEGB LOCA Analysis

In summary, the following nominal neutronic and thermal-hydraulic boundary conditions are supplied as input to FLOWTRAN-TF for the ECS phase calculations of DEGB LOCA power limits:

- Neutronic Boundary Condition Input:
 - A deposited assembly power transient which is predominantly decay heat and is conservatively bounded.
 - An axial power profile which is bounded with a 1.55 chopped cosine shape.
 - An azimuthal power tilt which is bounded with a 20% tilt from centerline to fuel tubes.
 - Fuel tube power fractions which are varied over the expected subcycle burnup range (conditions at the end of the subcycle produced the most conservative power limit).
 - Radial power profiles which are fixed (their variation has an insignificant impact).
- Thermal-hydraulic Boundary Condition Input:

- Inlet void fraction (equivalent to plenum height) which translates into a given liquid flowrate based on the horizontal stratified model. For our nominal conditions, the post-incident liquid flowrate becomes 30 gpm to the worst case assembly.
- Inlet fluid temperature is bounded to account for various uncertainties and to reduce the necessity to perform iterative system-assembly limit runs. In the next section, results will be presented to indicate the embedded margin associated with the use of a best estimate inlet temperature versus the bounded value employed as our nominal setting.
- Overall assembly pressure drop is set to the value which minimizes the computed T_{wall} power limit. The tank bottom pressure (tank height) is set to the RELAP5 result and the plenum pressure is adjusted.
- Gas humidity is set equal to the RELAP5 result. Its variation has an insignificant impact on the power limit.

The above boundary conditions define our nominal state along with:

- A 100% eccentricity of all four tubes in the direction of the power tilt.
- A 2-inch cosine bow of all four tubes in the direction of the power tilt.
- An wall temperature peaking factor of 5 °C that is added to the computed local surface temperatures to account for azimuthal variations in local surface conditions. The choice of 5 °C is based on FLOWTRAN-TF assessments to Rig-FB azimuthal temperature profiles. This factor effectively sets the limit when wall temperatures are 5 °C below saturation. This is the wall temperature peaking factor listed as a bounded sensitivity variable in Table 2-1.

4. Recommended ECS Power Limit for K-14.1 Subcycle

In this section, the recommended DEGB LOCA ECS power limit will be presented. The method used to calculate the ECS power limit is fully discussed in "DEGB LOCA ECS Limits Methodology (U), Rev. 1", WSRC-TR-90-411. All of the ECS limits calculations presented in this section are based on the version of FLOWTRAN-TF code that exists in the SRL VAX CMS directory SRLUSER2:[LOCA.FLOWTRAN.TWO-FLUID] as class FLOWTRAN-TF.04. This directory is controlled to allow access only by members of the NES Code Development Group.

4.1 Nominal ECS Mark 22 Power Limit

Using the set of nominal boundary conditions described in Section 3.4, FLOWTRAN-TF calculates a nominal ECS power limit of 6.83 MW for a Mark 22 assembly. The design basis LOCA is a DEGB in the plenum inlet line with the AC pump motors not tripped. This power represents approximately 115% of historical full power operating levels for a Mark 22 assembly. This nominal power limit is converted into a conservative power limit using the sensitivity analysis presented in Section 4.2. The resulting conservative power limit is then converted into a conservative effluent temperature limits for each flowzone in the reactor as shown in Section 4.3. Finally, the flowzone assembly power limits corresponding to the conservative temperature limits are calculated and the minimum overall reactor power determined which is reported as the recommended operating power level.

4.2 LOCA Sensitivity Analyses About Nominal Conditions

Sensitivity analyses have been performed using the current version of FLOWTRAN-TF. These sensitivity runs consisted primarily of varying only one selected sensitivity variable, while maintaining the rest at their nominal values. This approach yields the necessary information required to perform a linear propagation of errors (star pattern) response surface analysis. FLOWTRAN-TF was then used to determine the pre-incident power level which trims the T_{wall} equals T_{sat} criterion at some limiting surface location and at some point in time during the LOCA transient. During these calculations, the criterion of T_{fluid} equals T_{sat} was also checked; however, as expected, this criterion was never reached prior to the T_{wall} equals T_{sat} criterion. These calculations were carried out over the time interval of 0 to 200 seconds into a DEGB LOCA. Calculations beyond 200 seconds were unnecessary since, in all of the computed results, the limit was reached prior to 200 seconds and generally occurred near the point where the hot polybor was exhausted (around 110 to 140 seconds into the transient). The recommended power limit presented in this report applies only to the period following the DEGB up to the point where the ECS systems are throttled.

The sensitivity variables considered were listed previously in Table 2-1 of Section 2 for the Mark 22 assembly. The resulting T_{wall} power levels, necessary to create a linear response surface based on the star pattern sensitivity study, are tabulated in Table 4-1. At the bottom of Table 4-1 the overall uncertainty allowance, a root-sum-square "2 sigma" value, in the assembly power limit is given as 35.3%. A discussion of non-linear effects is presented in Appendix A.

Table 4-1 Summary of sensitivity results obtained for the linear error propagation (star pattern) analyses about the nominal state.

Sensitivity Variable	Power (MW)	Percent Reduction in Power
Nominal	6.83	-
Inlet Liquid Flow	4.91	28.1
Tube Power Fractions	6.79	0.6
Heat Transfer Coefficient	5.82	14.8
Wall Friction	>6.83	0
Channel Inlet Void	6.05	11.4
Rib Cross-Flow Model	6.56	4.0
Interfacial Drag	>6.83	0
BEF Form Loss	>6.83	0
Tube Thickness	6.20	9.2
Axial Heated Length	6.70	1.9
$2\sigma_P = 35.3\%$		

Those sensitivity variables listed in Table 2-1 which were not bounded are shown in Table 4-1 along with their corresponding impact on the T_{wall} power level. These sensitivity variables were ranged plus and minus "2 sigma" about their nominal value, where the term "2 sigma" is used to imply a high level of confidence that the variation represents a conservative bound. As shown in Section 2.1, some of these "2 sigma" settings were based on available variance information while others were based on engineering judgement. Note that for three sensitivity variables, the impact was positive in both directions. These are identified in Table 4-1 as zero contributors to the overall power uncertainty allowance.

The impact, as a percent power change, from a "2 sigma" variation in the sensitivity variable is computed by:

$$\% \text{ Reduction in Power} \equiv \left[\frac{P_{\text{nominal}} - P}{P_{\text{nominal}}} \right] \quad \text{where } P_{\text{nominal}} \approx 6.83 \text{ MW}$$

Since the dominant sensitivity variable is the minimum post-incident inlet liquid flowrate, additional sensitivity runs were made over a wide range of flowrates. These results are listed in Table 4-2 for the T_{wall} criteria. The inlet void fraction boundary conditions shown in Fig. 3.3-1 were used to calculate these results. Since the flowrate was not specified directly, the values listed in the table are the actual minimum assembly flows generated by the void fraction transients shown in Fig. 3.3-1 and are only approximately equal to the nominal flowrates shown in the figure legend. To better determine the impact of inlet liquid flowrate on $T_{wall} = T_{sat}$ power limits, the results given in Table 4-2 are converted to differences and three of the entries (chosen to give a conservative estimate of the power reduction) are plotted in Fig. 4-1. The computed impact of a "2 sigma" variation on percent power change was determined from a quadratic fit to the data and is also shown in Fig. 4-1. Based on the uncertainty in the minimum post-incident flowrate (estimated in Ref. [1] to be 6.29 gpm about the 30 gpm nominal bound) we then obtain:

$$\begin{aligned} 2\sigma_{\Delta Q} &\approx [2.87 + 0.253\Delta Q_f]\Delta Q_f \\ &\approx 28.1\% \quad \text{where } \Delta Q_f \approx 6.29 \text{ gpm} \end{aligned}$$

The 28.1% value for the impact on power due to the inlet flowrate uncertainty is entered in Table 4-1.

We note that the error curve shown in Figure 4-1 is concave upward. Therefore, assuming a linear estimate for the error based on the 2-sigma value gives conservative estimates for the error between zero and 2-sigma and somewhat nonconservative estimates for large error values. The linear error assumption is shown by the straight line on Figure 4-1.

Table 4-2 Effect of minimum assembly flow on nominal T_{wall} power limit.

Q_f (gpm)	Nominal T_{wall} Power (MW)	Nominal T_{wall} Power (Percent)	ΔQ_f (gpm)	% Power Reduction ($2\sigma\Delta Q$)
13.14	2.69	45.3	16.76	60.6
21.19	3.81	64.1	8.71	44.2
24.56	5.29	89.1	5.34	22.5
29.90	6.83	115.0	0	0
39.73	12.17	204.9	-9.83	-78.2
50.40	14.89	250.7	-20.50	-118.0

Figure 4-1 Impact of minimum flow uncertainty on power limit.

The sensitivity to assembly pressure drop has been omitted from Table 4-1 since the nominal pressure drop is defined to be the value which minimizes the computed T_{wall} power limit. Sensitivity runs to determine the effect of assembly pressure drop on nominal and conservative estimate (CE) power limits are given Table 4-3 and are plotted in Fig. 4-2.

The overall assembly pressure drop is defined as the plenum pressure minus the tank bottom pressure.

Table 4-3 Impact of overall assembly pressure drop on the power limit.

ΔP psi	Twall - Nominal		Twall - CE	
	MW	%	MW	%
-1.0	8.10	136.4	4.45	74.9
-0.75	8.12	136.7	4.46	75.1
-0.50	6.83	115.0	3.75	63.1
-0.25	8.32	140.1	4.57	76.9
0	9.13	153.7	5.01	84.3
0.5	9.54	160.6	5.24	88.2
1.0	9.75	164.1	5.35	90.1

Figure 4-2 Mark 22 LOCA ECS power limits as a function of pressure drop across the entire assembly at a post-incident minimum assembly flow of 30 gpm.

Figure 4-2 shows the nominal pressure drop assumed for the limits calculations, and gives an impression of the conservatism added to the calculations by that assumption. As Fig. 4-2 indicates, the nominal setting for overall assembly pressure drop was set to -0.5 psi and all of the sensitivity results given in Tables 4-1 and 4-2 were computed using this value of the pressure drop. This pressure drop is measured from the centers of the FLOWTRAN-TF plenum and tank bottom fluid cells.

4.3 Calculation of Flowzone Effluent Temperature Limits

The nominal T_{wall} power limit for the ECS phase of a DEGB LOCA is given in Table 4-1 which also shows the computed uncertainty value. Based on the methodology developed in Ref. [1], we will show the steps required to compute the Conservative Estimate (CE) of the power limit (i.e. the recommended DEGB LOCA ECS Power Limit) and the corresponding effluent temperature limit from the nominal power limit. This calculation will be done for each flowzone in the K-14.1 charge.

In order to compute a conservative estimate for the power limit, the following quantities are specified independent of reactor flowzone:

FLOWTRAN-TF Nominal T_{wall} Power	$P_{TF}^* = 6.83 \text{ MW}$
"Development Margin" Factor	$\beta^* = 0.90$
Moderator Heat Loss Term	$\gamma = 0.01$
Conversion Factor ($^{\circ}\text{C-gpm/MW}$)	$c = 3455 \text{ (at } 46^{\circ}\text{C)}$
Two-sigma Uncertainty in Power Limit	$2\hat{\sigma}_p = 35.3\%$
Two-sigma Uncertainty in Assembly Hardware	$2\hat{\sigma}_{HW} = 2.0\%$

The conversion constant c has been evaluated at 46°C which is an estimate of the average pre-incident coolant temperature throughout the reactor core. The data given in Table 4-4 has been determined for each flowzone from TRAC calculated plenum pressures and the plenum pressure gradient facemap [14].

Table 4-4 Flowzone specific data based on plenum pressure.

Flowzone	F_Z^* (gpm)	$2\hat{\sigma}_{PC}$ (%)	$2\hat{\sigma}_{PG}$ (psi, %)	
1	337.9	2.94	1.98	1.75
2	346.3	2.81	3.20	2.69
3	363.1	2.56	4.76	3.65
4	342.9	2.68	6.90	5.55
5	361.0	2.43	9.64	7.02
6	364.6	2.39	9.64	6.89

where:

- F_Z^* = Nominal Maximum Pre-incident Assembly Flow
- $2\hat{\sigma}_{PC}$ = Two-sigma Uncertainty in Centerline Plenum Pressure
(based on a centerline pressure uncertainty of 3.34 psi)

$2\hat{\sigma}_{PG}$ = Two-sigma Uncertainty in Local Pressure Gradient

Then, using Eq. (7-16) from Ref. [1] with a single unconsidered factor to represent model development margin, the nominal assembly temperature rise at its limit is computed from:

$$\Delta\tilde{T}_a^* = \frac{c(1-\gamma)}{F_Z^*} \beta^* P_{TF}^* \quad (4-1)$$

Given the nominal temperature rise, the relative thermocouple measurement uncertainties are computed with Eqs. (7-13) and (7-14) of Ref. [1] as:

$$2\hat{\sigma}_{T_{in}} = \frac{2\sigma_{in}}{\Delta\tilde{T}_a^*} \quad \text{and} \quad 2\hat{\sigma}_{T_{eff}} = \frac{2\sigma_{eff}}{\Delta\tilde{T}_a^*} \quad (4-2)$$

In writing Eq. (4-2), we have adopted the notation 2σ for the uncertainty variables to indicate our "2 sigma" high level of confidence in the uncertainty. For the 2-sigma uncertainty in plenum inlet temperature we use 1.92 °C and for the effluent temperature we use 1.76 °C [3]. With these computed terms, the uncertainty in pre-incident assembly flow is calculated by applying Eq. (7-15) of Ref. [1] as:

$$2\hat{\sigma}_F = \sqrt{(2\hat{\sigma}_{HW})^2 + (2\hat{\sigma}_{PC})^2 + (2\hat{\sigma}_{PG})^2} \quad (4-3)$$

Finally, the overall uncertainty allowance in the assembly temperature rise, from Eq. (7-9) of Ref. [1], (with $\hat{\sigma}_p = 0$) is computed as:

$$2\hat{\sigma}_{\Delta T} = \sqrt{(2\hat{\sigma}_p)^2 + (2\hat{\sigma}_F)^2 + (2\hat{\sigma}_{T_{in}})^2 + (2\hat{\sigma}_{T_{eff}})^2} \quad (4-4)$$

The terms computed by applying Eqs. (4-1) through (4-4) are listed in Table 4-5.

Table 4-5 Flowzone specific nominal temperature rise and uncertainty factors.

Flowzone	$\Delta\tilde{T}_a^*$ (°C)	$2\hat{\sigma}_{T_{in}}$ (%)	$2\hat{\sigma}_{T_{eff}}$ (%)	$2\hat{\sigma}_F$ (%)	$2\hat{\sigma}_{\Delta T}$ (%)
1	62.22	3.09	2.83	3.96	35.77
2	60.71	3.16	2.90	4.37	35.83
3	57.91	3.32	3.04	4.89	35.92
4	61.32	3.13	2.87	6.48	36.14
5	58.24	3.30	3.02	7.69	36.40
6	57.67	3.33	3.05	7.56	36.38

A conservative estimate limit for the allowable temperature rise across an assembly in each flowzone is then computed by Eq. (7-17) in Ref. [1] to be:

$$\Delta T_{CE} = \left[1 - \frac{2\hat{\sigma}_{\Delta T}}{100} \right] \Delta \bar{T}_a^* \quad (4-5)$$

This temperature rise is the maximum rise allowed for all assemblies within the flowzone. Therefore, a conservative estimate of the maximum flowzone deposited assembly power is then computed by:

$$P_Z^{CE} = \frac{\langle F_Z \rangle}{c(1 - \gamma)} \Delta T_{CE} \quad (4-6)$$

where $\langle F_Z \rangle$ is the average liquid flowrate in the flowzone. Calculated values of the conservative temperature rise and the conservative assembly power are presented in Table 4-6 for each flowzone.

Table 4-6 Flowzone specific conservative temperature increases.

Flowzone	ΔT_{CE} (°C)	$\langle F_Z \rangle$ (gpm)	P_Z^{CE} (MW)
1	39.96	333.7	3.90
2	38.96	335.5	3.82
3	37.11	345.3	3.75
4	39.16	337.2	3.86
5	37.04	350.4	3.79
6	36.69	350.3	3.76

Historically, full reactor power on an annual averaged basis is estimated to be 2400 MW. A corresponding estimate of the ECS recommended reactor power level on an annual averaged basis can then be computed using the minimum flowzone power in Table 4-6 and the methodology in Ref. [15]. For flowzone 3, which is the limiting flowzone for the ECS power recommendation, we obtain a reactor power of 1515 MW. This power level is 63.1% of the historical value.

The ECS power limits are independent of basin water (or river water) temperature and polybor temperature since fixed (bounding) values were used in the analysis. Future limits calculations could determine the assembly ECS power limits as a function of basin water temperature which would produce higher reactor powers at lower cooling water temperatures. However, at present, since the ECS power limit based on the maximum basin water temperature is uniformly above the flow instability power limits calculated over a range of river water temperatures, no power gain can be realized by determining ECS limits as a function of basin water temperature. The operating limits given in Table 4-6 are applicable for river water temperatures below 43 °C.

Based upon the calculations presented above, the recommended DEGB LOCA ECS reactor power limit is 1515 MW which is approximately 63.1% of full power on an annual average basis. This is a conservative estimate that includes a 10% "development margin" factor. The other conservative estimate power limits given in Tables 4-2 and 4-3 were computed in

a similar fashion (using flowzone 3), except that the nominal FLOWTRAN-TF computed power limit varied for each case.

5. Safety Margins

As discussed above, we have made conservative assumptions in a number of areas to calculate the ECS power limits and have included an uncertainty margin that is conservative to the best of our judgement. However, since heated prototypic Mark 22 test data are not yet available, the true degree of conservatism in our recommended power limit cannot be accurately quantified at this time. Some indications as to the degree of conservatism embedded within the conservative estimate of the DEGB LOCA ECS power limits for a Mark 22 assembly can be derived from the following discussion which depends on both calculated results and comparison to experimental data from the heated single channel rigs FA and FB [7,16-21]. The use of a linear response surface also appears to introduce additional conservatism into the calculation of an assembly power limit. The calculational evidence for this is presented in Appendix A.

5.1 T_{wall} and OTE Power Limits for the Mark 22 Assembly

To estimate the conservatism inherent in using the T_{wall} equal T_{sat} criterion, a series of FLOWTRAN-TF calculations were performed allowing the maximum metal surface temperature to rise to some predetermined value. A summary of these limits calculations is given in Fig. 5-1. Since FLOWTRAN-TF indicates that fairly high metal temperatures can be sustained for indefinite periods, a curve predicting the Onset of Thermal Excursion (OTE) or a maximum surface metal temperature of 150 °C is shown. In order to have metal temperatures in the range of 150 °C one or more of the neighboring subchannels on both sides of a fuel tube would have to be highly voided and have very low surface heat transfer capability. Local subchannel flooding did not appear to trigger significant thermal excursions; however, the FLOWTRAN-TF code was not able to continue computations after a single fluid cell became very highly voided even if metal temperatures were well below 150 °C. At both high and low flows this cell void restriction produced the OTE limit while for the middle range of flows (25 to 40 gpm) the 150 °C limit applied. It is believed that true unbounded thermal excursions require high enough power levels to cause large scale flooding on a multi-channel basis. At lower power levels two-sided cooling conduction in the azimuthal and radial directions in aluminum metal diminishes local flooding and dryout disturbances.

The nominal T_{wall} power limit curve is well below the region of OTE for all flowrates. This trend is consistent with the single channel heated experiments [16-21], as well as their FLOWTRAN-TF benchmarking results. As illustrated in Fig. 5-1, the increase in power between the nominal T_{wall} power limit and the OTE power limit curves ranges from approximately 13% (at 40 gpm) to 52% (at 20 gpm).

As mentioned in the previous section, the conservative estimate power limit calculation was performed at a nominal minimum post-incident assembly flow of 30 gpm. The power limit is 63.1% of the annual averaged historical power level of 2400 MW, which includes a 10% reduction for "development margin". Figure 5-1 shows how large the difference is between the nominal and recommended conservative estimate T_{wall} power (i.e. the recommended power is approximately half the nominal T_{wall} power). Much of the reduction from the nominal to the conservative T_{wall} power is caused by the sensitivity of the computed limit to total liquid flow. Figure 4-1 shows this sensitivity and the fact that it is nonlinear. Some of the implications of this nonlinearity are discussed below.

Figure 5-1 Mark 22 LOCA ECS power limits for $T_{wall} = T_{sat}$ and OTE (150 °C) criteria as a function of post-incident minimum liquid flowrate.

5.2 T_{wall} and OTE in Rigs FA and FB Compared to Mark 22 Assembly

Further indication of the conservatism in the recommended Mark 22 DEGB LOCA ECS limit can be derived from a comparison of the R values for the Mark 22 flow channels to data from the different single channel test rigs. The R values are the saturation ratios defined as

$$R = \frac{Q_{crit}}{Q_{sat}} \quad (5-1)$$

That is, the R value is the ratio of the heat input that brings the rig to the criterion limit to the heat required to bring the entire fluid flow to saturation at the exit. For comparison purposes, the channel saturation ratios (R_{chn}) for the inner, middle, and outer channels of the Mark 22 assembly were computed based on LOCA calculations at the nominal pre-incident power of 6.83 MW and at the conservative pre-incident power of 3.75 MW. The channel R_{chn} values were calculated at the point in time where the T_{wall} criterion was trimmed. These R_{chn} values tend to reach their maximum value at the criterion trim times.

As illustrated in Fig. 5-2, the calculated nominal Rchn values based on the T_{wall} criterion for the three Mark 22 flow channels fall well below all of the OTE test data. The test data cover all of the conditions of liquid flow and assembly pressure difference considered as possible to occur during the ECS phase of a DEGB LOCA. The conservative estimate Rchn values are far below the data, and indicate how far from bulk boiling, on a channel average basis, the fluid in these channels would be when the limit is reached.

Figure 5-2 Comparison of R values for the Mark 22 ECS LOCA limits with Rig FA and Rig FB OTE R values.

In Fig. 5-3, the same calculated Rchn values for the three Mark 22 flow channels are compared to data taken on Rigs FA and FB with the maximum wall temperature limited to equal the fluid saturation temperature. We see that the calculated nominal Rchn values are slightly below the observed R values (due to increased heat flux peaking present in the Mark 22 assembly), whereas the conservative values are far below the data. The implication is that, based on the heated single channel data shown in Figs. 5-2 and 5-3, the margin between OTE and the conservative estimate of T_{wall} is very large (a factor of two to three). We expect that multiple flow channels and two-sided cooling will be beneficial and, therefore, that more prototypic data will indicate that the current ECS limit is even more conservative than is demonstrated here.

The comparisons demonstrated in Figs. 5-2 and 5-3 indicate that our bounding analysis using a hypothetical worst-case assembly produces an acceptably conservative power limit. The calculated Mark 22 power limit produces single channel saturation ratios that fall below the scatter in the experimental T_{wall} and OTE data.

Figure 5-3 Comparison of R values for the Mark 22 ECS LOCA limits with Rig FA and Rig FB T_{wall} criterion R values.

5.3 Best Estimate Versus Bounding Value of Inlet Temperature

The nominal setting used as a boundary condition for the inlet fluid temperature in FLOWTRAN-TF was based on bounding assumptions [1]. The inlet temperature from RELAP5 was adjusted upward and shifted later in time for setting our nominal value. The use of a bounding inlet temperature transient removes the necessity to perform iterative analyses between the system and assembly calculations. Alternatively, the best estimate inlet fluid temperature corresponds to using:

- Approximately the nominal reactor power level computed by FLOWTRAN-TF.
- Annual averaged river (basin) water and polybor temperatures.
- Best estimate of the hot polybor inventory.

FLOWTRAN-TF T_{wall} power limit calculations were performed where the basic nominal case was altered only by replacing the bounding nominal inlet temperature transient with the best estimate value. The best estimate temperature transient is shown in Fig. 4-2 in Ref. [1]. The resulting power limit and a comparison with the basic nominal case study are listed below:

Inlet Temperature Transient	Nominal T _{wall} Power Limit (MW)	Percent of Full Power
Bounded	6.83	115%
Best Estimate	9.00	152%

The results of employing a best estimate inlet temperature transient then indicate that there is approximately a 37% embedded margin in the recommended power limit.

5.4 Deposited Decay Power Transient

In performing our bounding analyses, a conservative deposited decay power transient was selected as the nominal setting. The estimate was based on the accident scenario that yielded the highest decay power transient, with a conservative approach to the computation of this decay power. It is estimated that the deposited power transient is 4 to 7% higher than its corresponding best estimate value over the time region of major interest in setting the DEGB LOCA power limit. This 4 to 7% bias in decay power transient translates almost directly into a 4 to 7% embedded margin in the recommended power limit.

5.5 "Development Margin" Factor

Several experimental and computational efforts are in progress to better understand air-water behavior in SRS Reactors and the Mark 22 assemblies. To cover any negative impacts of new technical data that may appear, a 10% bias was included in the recommended power limit. This bias is referred to as a "development margin" and is a multiplier on the power limit of the form:

$$P_{TF} = \beta P_{TF}^*, \quad \text{where } \beta = 0.9$$

This bias reduces the recommended power limit by approximately 7.0% of full power.

6. Conclusion

The conservative estimate of the DEGB LOCA ECS power level is 1515 MW or 63.1% of historical full reactor power on an annual average basis. This limit is based on code assessments to the most recent data bases and has been intentionally developed to be conservative. We note that the ECS power limit is greater than the recommended restart power level. Within the ECS methodology, there are embedded safety margins both in the criterion definition and in the bounds applied to important parameters. A brief summary of the recognized safety margins is:

- T_{wall} versus OTE Criterion - 20-40% of full power
- Bounded versus Best Estimate Inlet Temperature - 37% of full power
- Bounded versus Best Estimate Decay Power - 4-7% of full power
- "Development Margin" Factor - 7.0% of full power

- Linear Versus Nonlinear Response Surface - Favorable (not quantified)

The "development margin" is included to encompass any margin decreases which may be discovered as pertinent issues are evaluated prior to the incorporation of embedded margins in the base power level recommendation. The purpose of the "development margin" is to minimize the potential for changes in the base ECS power level prior to reactor restart and operation of the first restart cycle. Specific recommendations of effluent temperature limits for each flowzone of the K-14.1 charge are given in Table 4-6.

7. References

1. F. G. Smith, III "DEGB LOCA ECS Limits Methodology (U), Rev. 1" WSRC-TR-90-411, April, 1991.
2. J. C. Whitehouse, "Transmittal of Phase 1 Data", NES-ETH-900281, September 19, 1990.
3. B. J. Hardy, "Addendum to: A Probabilistic Method for Determining Effluent Temperature Limits for Flow Instability for SRS Reactors (U)," WSRC-TM-90-5, Addendum 1, February, 1991.
4. G. P. Flach, S. E. Aleman, L. L. Hamm, S. Y. Lee, F. G. Smith, III, and V. Van Brunt, "FLOWTRAN-TF Code Description (U)," WSRC-TR-90-413, November, 1990.
5. G. P. Flach, "FLOWTRAN-TF Wall Drag Model Uncertainty," NES-CDG-910048, April 2, 1991.
6. Babcock & Wilcox, Alliance Research Center, "Annular Flow Distribution Test: Interim Report," WSRC-TR-90-149, June, 1990.
7. J. A. Steimke, "Status of Heat Transfer Rig FA (U)," WSRC-TR-90-44, January, 1990.
8. J. L. Steimke, "Rig FA Data with Oscillating Flow of Water and with Positive Pressure Drop," NES-ETH-900157, (not issued).
9. M. D. DeHart, "Relative Power Calculations for ECS Limits," NES-RFI-900063, March 10, 1990.
10. W. M. Massey, "Sensitivity of Mark 22 Flow Instability Limits to Axial Power Shape, Revision 1," DPST-89-244, April, 1989.
11. R. L. Webb, "Radial and Azimuthal Power Profiles in Mark 22 Assemblies," WSRC-RP-89-724, August, 1989.
12. M. D. DeHart, "Relative Power Calculation for the LOCA ECS Transient," RFICN-88-061-1-A, June 12, 1990.
13. G. A. Taylor and R. A. Dimenna, "RELAP5 Calculations of a Savannah River Reactor Large Break Loss-of-Coolant Accident (U)," WSRC-TR-90-484, October, 1990.

14. L. D. Koffman, "Flowzone Flows for Conversion of Power to Effluent Temperature," NES-CDG-910050, April 8, 1991.
15. W. M. Massey, "Revised Equations for Estimating Reactor Power," RTR-2174, March 27, 1984.
16. J. A. Steimke and C. M. Hart, "Thermal Excursion Powers in Rig FA," NES-ECS-890175, November 10, 1989.
17. J. A. Steimke, "Rig FA Data to Support Tsat Criterion, 8 gpm," NES-ECS-900308, March 19, 1990.
18. J. A. Steimke, "Rig FA Data to Support Tsat Criterion, 10 and 12 gpm," NES-ECS-900309, March 19, 1990.
19. J. A. Steimke and L. H. Menke, "Rig FA Data to Support Tsat Criterion, 4 to 14 gpm," NES-ECS-900324, April 10, 1990.
20. B. S. Johnston, "Thermal Excursions Under ECS Conditions in a Single Annulus with Azimuthal Tilt (U)," WSRC-TR-90-45, February, 1990.
21. B. S. Johnston and C. P. May, "Thermal Excursion Powers in Rig FB," NES-ECS-890183, November 15, 1989.

Appendix A. Linear Versus Nonlinear Response Surface

The uncertainty analysis assumes that a linear response surface is adequate and that any nonlinear behavior present will result in a higher power limit than predicted by the linear response surface. Previous analyses indicated that the linear response surface does in fact underpredict the FLOWTRAN-TF computed power limit for various combinations of the sensitivity variables set to their extreme values and is hence conservative. However, due to the non-linearity exhibited in computed FLOWTRAN-TF power limits, concerns were raised as to the possibility that the FLOWTRAN-TF computed response surface might drop below the linear response surface approximation for some combination of variable settings. A small subset of additional FLOWTRAN-TF case runs were made with various combinations of sensitivity settings chosen for the minimum post-incident liquid flowrate and the heat transfer correlation multipliers. These two variables have a significant impact on power limits (see Table 4-1). All of the other sensitivity variables were maintained at their nominal values. The nominal T_{wall} power limits computed by FLOWTRAN-TF are given in Table A-1 along with the corresponding sensitivity variable settings.

Table A-1 FLOWTRAN-TF computed T_{wall} power limits for various sensitivity variable settings.

Liquid flow (gpm)	Heat transfer coefficient multipliers		
	1.0 (nominal)	0.75 (1 σ)	0.50 (2 σ)
29.9 (nominal)	6.83	6.40	5.82
24.6 (1.7 σ)	5.29	4.70	3.82
21.2 (2.8 σ)	3.81	3.65	3.19

Table A-1 describes the actual response surface of the FLOWTRAN-TF computed T_{wall} power limit for the two sensitivity variables. The linear response surface approximation for just these two variables becomes:

$$\frac{P_{LRS} - P_{nominal}}{P_{nominal}} = -0.281 \left(\frac{\Delta Q_f}{2\sigma_{\Delta Q}} \right) - 0.148 \left(\frac{\Delta htc}{2\sigma_{\Delta htc}} \right)$$

where:

- P_{LRS} Linear response surface power limit approximation, MW
- P_{nominal} FLOWTRAN-TF nominal power limit, 6.83 MW
- ΔQ_f Flowrate reduction from nominal value of 30 gpm
- 2σ_{ΔQ} "Two-sigma" uncertainty in minimum liquid flowrate, ± 6.29 gpm
- Δhtc Heat transfer multiplier reduction from nominal value of 1.0
- 2σ_{Δhtc} "Two-sigma" uncertainty in heat transfer coefficient

Based upon the above equation, Table A-2 lists the corresponding linear response surface approximations to the power limits. The percent difference between the actual and the linear response surface is given in Table A-3. As indicated by the non-negative differences in the diagonal positions in Table A-3, the linear response surface technique to combine uncertainties appears to be slightly conservative; however, the magnitude of the conservatism can not be estimated as yet, since the necessary information to perform a full nonlinear response surface analysis is not available.

Table A-2 Linear response surface estimated T_{wall} power limits for various sensitivity variable settings.

Liquid flow (gpm)	Heat transfer coefficient multipliers		
	1.0 (nominal)	0.75 (1σ)	0.50 (2σ)
29.9 (nominal)	6.83	6.32	5.82
24.6 (1.7σ)	5.20	4.69	4.19
21.2 (2.8σ)	4.17	3.67	3.16

Table A-3 Magnitude in percent power change that linear response surface underpredicts actual surface.

Liquid flow (gpm)	Heat transfer coefficient multipliers		
	1.0 (nominal)	0.75 (1σ)	0.50 (2σ)
29.9 (nominal)	0	1.2	0
24.6 (1.7σ)	1.7	0.2	-9.7
21.2 (2.8σ)	-9.4	0.5	0.9

Since the results shown in Table A-3 indicated a relatively small degree of conservatism in the assumption of a linear response surface, an additional test of the linearity of the uncertainties was made. In this test the four major sensitivity variables in Table 4-1 were simultaneously set to their extreme values for a FLOWTRAN-TF calculation and the computed power was compared to the linear estimate. The major sensitivity variables are: inlet liquid flow, heat transfer coefficient, channel inlet void (civ), and tube thickness (tube). Using the results in Table 4-1, the assumption of a linear response gives the following relationship for predicted power:

$$\frac{P_{LRS} - P_{nominal}}{P_{nominal}} \approx -0.281 \left(\frac{\Delta Q_f}{2\sigma_{\Delta Q}} \right) - 0.148 \left(\frac{\Delta h_{tc}}{2\sigma_{\Delta h_{tc}}} \right) - 0.114 \left(\frac{\Delta civ}{2\sigma_{\Delta civ}} \right) - 0.092 \left(\frac{\Delta tube}{2\sigma_{\Delta tube}} \right)$$

The linear response function predicts a power level of 1.73 MW when the four sensitivities are combined assuming a liquid flow of 21.2 gpm and a 2σ variation in the other factors. When the actual power level was calculated using FLOWTRAN-TF with the four sensitivity variables at their extreme settings, a power level of 2.94 MW was obtained which is some 70% greater than the linear approximation. This result provides additional confirmation that the assumption of a linear response surface is conservative.

Appendix B. Fluid and Metal Characteristics at the Limiting Condition

In this appendix, we present plots of the fluid and metal conditions at the location and time when the $T_{wall} = T_{sat}$ limit criterion is met. For the nominal case, we found that the limit is set on the inner surface of the outer fuel tube about two thirds of the way down the heated channel at 137 seconds into the transient. The limit is set in the subchannel having both an azimuthal power peak and a decreased flow area from the model eccentricity.

Figures B-1 through B-6 plot fluid conditions in each of the three flow channels at the limiting condition. These plots show each flow channel unfolded into a flat projection with axial location on the vertical axis and the four subchannels running left to right along the horizontal axis. Figures B-1 through B-4 show contour plots of fluid void fraction, pressure in kPa, temperature in °C, and air mass fraction, respectively. We note that the outer channel is becoming highly voided ($> 85\%$ void) and the fluid temperature is peaking near the bottom of the channel at a value between 77.5 and 80 °C in the first two subchannels. Figures B-5 and B-6 show velocity vectors for the liquid and gas phases within each fluid subchannel at the time when the limit is set. We note that the gas phase is in upflow within the second subchannel of the outer flow channel and that the liquid velocity in this subchannel is reduced. Finally, Fig. B-7 shows contour plots of the surface temperature on both sides of the outer flow channel and on the outer surface of the outer fuel tube. The nomenclature used in Fig. B-7 is as follows: OS - outer surface, IS - inner surface, OF - outer fuel tube, OT - outer target tube. We note that the surface temperature on the inner surface of the outer target is peaking at approximately 95 °C about two thirds of the way down the channel at a location within the second subchannel. Our nominal limit criterion is $T_{wall} = T_{sat}$ where we have reduced T_{sat} by 5 °C to account for azimuthal temperature peaking not resolved in the FLOWTRAN-TF model. Therefore, the 95 °C temperature peak indicates that the limit criterion is met.

Figure B-1 Void Fraction Profiles at the Limiting Condition

Figure B-2 Pressure Profiles at the Limiting Condition

Outer
Time = 137.0071

Middle
Time = 137.0071

Inner
Time = 137.0071

Figure B-3 Fluid Temperatures at the Limiting Condition

Outer
Time = 137.0071

Middle
Time = 137.0071

Inner
Time = 137.0071

Figure B-4 Air Mass Fraction Profiles at the Limiting Condition

Figure B-5 Liquid Phasic Velocity Vectors at the Limiting Condition

Figure B-6 Vapor Phasic Velocity Vectors at the Limiting Condition

Figure B-7 Wall Temperatures at the Limiting Condition

OS-OT
Time = 137.0071

IS-OT
Time = 137.0071

OS-OF
Time = 137.0071

END

DATE
FILMED

2/17/93