WSRC-RP-92-653

Numerical Modeling of the Expansion
Phase of Steam Explosions
Part I: Method and Validation
(U)

M. L. Hyder
Safety Technology Section

Yousef M. Farawila, Said I. Abdel-Khalik,
and Peter J. Halvorson
Georgia Institute of Technology

May 1992

DOES NOT CONTAIN
UNCLASSIFIED CONTROLLED
NUCLEAR INFORMATION

Reviewing
Official: *Paul K. Davis*
(Name and Title)
Prin. Engr
Date: *10/30/92*

Westinghouse Savannah River Company
Savannah River Technology Center
Aiken, SC 29803

SRS

SAVANNAH RIVER SITE

PREPARED FOR THE U.S. DEPARTMENT OF ENERGY UNDER CONTRACT NO. DE-AC09-89SR18035

MASTER

So
DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DOCUMENT:

WSRC-RP-92-653

TITLE:

Numerical Modeling of the Expansion Phase of
Steam Explosions Part I: Method and
Validation (U)

APPROVALS

M. L. Hyder
Author

M. L. Hyder

Date: 5/20/92

I. K. Paik
Derivative Classifier

I. K. Paik

Date: 5/20/92

D. K. Allison
Technical Reviewer

David K. Allison

Date: 7-8-92

S. B. Whitfield
Technical Editor

Shirley B. Whitfield

Date: 7-8-92

L. A. Wooten, Manager
Safety Analysis and
Engineering Service

L. A. Wooten

Date: 10/19/92

M. J. Hitchler, Manager
Safety Technology Service

M. J. Hitchler

Date: 10/24/92

Introduction

In the development of the Severe Accident Analysis Program for the Savannah River production reactors, it was recognized that certain accidents have the potential for causing damaging steam explosions. Steam explosions can occur when metals, such as the aluminum-based fuel used at Savannah River, are melted and come into contact with water. This condition is unstable, and local turbulence can lead to the generation of great quantities of steam within a few milliseconds. This phenomenon has been observed in several reactor incidents and experiments (BORAX, SPERT-1, SL-1, probably Chernobyl) where it caused damage to the reactor and associated structures. The massive SRS reactor buildings are likely to withstand any imaginable steam explosion. However, reactor components and building structures including hatches, ventilation ducts, etc., could be at risk if such an explosion occurred.

Except for bounding techniques that returned very conservative values, no tools were available to estimate the effects of such explosions on actual structures. To meet this need, the Savannah River Laboratory (now the Savannah River Technology Center) contracted with the Georgia Institute of Technology Research Institute for development of a computer-based calculational tool for estimating the effects of steam explosions. Prof. S. I. Abdel-Khalik of the Nuclear Engineering Department of Georgia Tech was the principal investigator under this contract. The program to be developed was a modification of the K-FIX fluid dynamics code, modified specifically to simulate the expansion phase of steam explosions. Results from such calculations could then be coupled with structural response codes to predict the response of adjacent structures.

The goal for this study was to develop a computer code that could be used parametrically to predict the effects of various steam explosions on their surroundings. This would be able to predict whether a steam explosion of a given magnitude would be likely to fail a particular structure. This would require, of course, that the magnitude of the explosion be specified through some combination of judgment and calculation.

The requested code, identified as the K-FIX(GT) code, was developed and delivered by the contractor, along with extensive documentation. The several individual reports that constitute the documentation are each being issued as a separate WSRC report. Documentation includes several model calculations, and representation of these in graphic form. This report incorporates Report GTRSR-006, which gives an overview of the methods used in the development of K-FIX(GT), and the results of a comparison with experiments in the literature. The authors conclude that the results of the comparison calculation are in reasonable agreement with observations.

The K-FIX code has been delivered to SRS and turned over to the Probabilistic Risk Assessment group of the Safety Technology Section for their use in evaluating risks from steam explosions. Additionally, the K-

FIX(GT) code has also been used by its developers to address a specific problem of interest to SRS: the explosion of molten control rod material contacted with water in a septifoil. Results of this study are published in a separate report.

Currently only the original form of K-FIX(GT) exists at SRS. Development of the code is continuing at Georgia Tech, but this development is supported by other sources. There are no current plans to obtain updated versions of the code for SRS use.

Contents

Abstract	ii
1 Introduction	1
2 The Mathematical Model	4
2.1 Momentum Exchange	6
2.2 Mass Exchange	9
2.3 Energy Exchange	11
2.4 Explosion Energetics	12
3 Simulation of FITS-2B Experiment	13
3.1 Initial Conditions	14
3.2 Nodal Representation of FITS-2B	16
3.3 Simulated FITS-2B Results	17
4 Conclusions	19
Nomenclature	20
References	23

Abstract

The two-fluid, three-dimensional, fluid dynamics code K-FIX has been modified to produce the K-FIX(GT) code, in order to simulate the expansion phase of steam explosions. For a given explosion, the interaction zone is represented by a high pressure bubble as an initial condition; subsequent calculations are made to determine pressure histories and impulse at the test vessel or confinement building walls and internal structures. Explosion energetics, i.e. the work and mechanical energy yield, are also calculated as a measure of the destructive potential of the explosion. The main modifications involved in developing the K-FIX(GT) code consist of adding new components representing a non-condensable gas, air, and debris particles to the two-phase water mixture, and introducing new exchange functions for mass, momentum, and energy which are particularly suited to this type of fast transient. This report describes the theoretical models incorporated into the code. In addition, one of Sandia National Laboratories Fully Instrumented Test Series tests (FITS-2B) is simulated for the purpose of preliminary code and method validation. Comparison between experimental data and code predictions shows good agreement. In a companion report (GTRSR - 007), seven test cases with parametrically varied initial conditions and model parameters simulating hypothetical ex-vessel explosions in the Savannah River Plant confinement building are presented.

1 Introduction

An energetic vapor explosion may result if a large quantity of hot molten material is brought into contact with a cold volatile liquid. This situation may arise as a consequence of a nuclear reactor core meltdown accident. The interaction of molten core material with the remaining water coolant in the reactor vessel may be energetic enough to threaten its integrity and possibly result in "alpha-mode" containment failure. In a different accident scenario, the core material melts through the reactor vessel and falls into a water sump causing an ex-vessel explosion.

The extremely rapid heat transfer from the melt to the coolant, and the subsequent vapor production and pressurization, are attributed to the large melt/coolant contact area. This large area is generated due to the rapid breakup of the melt into fine fragments. An extensive review of the steam explosion literature can be found in reference [1].

A large-scale steam explosion is known to go through four distinct steps in the case of melt-on-coolant contact mode. Other contact modes (e.g. the stratified mode where the coolant is poured onto the higher density melt) are less probable.

a. Coarse Mixing: As the melt falls into the water coolant, it breaks up into globules of nearly 1 cm diameter. Film boiling occurs at the surface of each hot drop without significant heat transfer or melt temperature change. The metastable coarse mixture consists of melt drops, vapor film, vapor bubbles, and liquid coolant. The coarse mixing (or pre-mixing) process lasts about 1 sec. or less until the explosive interaction is triggered.

b. Triggering: Spontaneous initiation was observed experimentally as a localized disturbance, usually next to the wall of the test vessel. Spontaneous triggering of explosions may or may not occur even if the initial setup is kept unchanged. External triggers however succeed in initiating explosions almost every time. Triggering devices, e.g. small high explosive charges, produce a pressure pulse. The pressure pulse is thought to locally destabilize

film boiling and bring about direct liquid-liquid contact and fragmentation. Other film destabilizing techniques such as adding cold water have also resulted in escalating interactions but with less repeatability.

c. Propagation: Coherent interaction is necessary for producing considerable mechanical energy yield. Significant pressurization may occur only if the interaction zone expands only slightly against the confining inert surroundings; the interaction should be completed in a short time interval of the order of a few milliseconds. A propagating interaction rather than a simultaneous or sporadic uncoupled one is responsible for the observed energetic events. The proposed propagation theories depend on pressure coupling: a localized fragmentation results in rapid vapor production and pressure rise; the resulting pressure wave (or shock) initiates similar interaction in the adjacent material. The arrival of a pressure wave either merely destabilizes film boiling leading to direct liquid-liquid contact and fragmentation by a "thermal" mechanism, or it directly causes "hydrodynamic" fragmentation as the two liquids of different densities are accelerated to different velocities at the shock front. Board et al. [2] formulated the propagation of steam explosions in terms of the "steady detonation theory" in analogy to chemical explosives. Two difficulties arise for the validation of this theory. First, is the existence of a fragmentation mechanism which is fast enough to sustain a supersonic detonation wave. The other difficulty arises from the requirement of a powerful initial trigger. More recent studies [3,4] allow for transient (escalating) detonation where the shock magnitude, detonation speed and the width of the interaction zone change with time.

d. Expansion: No significant expansion of the explosion zone occurs during the short time interval needed for the propagation of the fragmentation; thus confined, high pressures are generated as the volatile liquid evaporates. The heat transfer from melt to coolant is significantly reduced due to vapor blanketing at the early stage of the expansion, and the expansion of the high pressure explosion "bubble" can therefore be treated as a separate (and the final) stage of the interaction. As the explosion bubble expands

against the surrounding material, a fraction of the thermal energy contained in the bubble is converted into mechanical energy, which is responsible for the explosion destructive potential. This energy takes the form of kinetic energy carried mainly by the fragmented and unfragmented debris and cold liquid slug, and also the pressure waves that propagate through the surrounding material.

The objective of this work is the study of the flow and pressure waves in a realistic three-dimensional representation of a reactor building resulting from a *given* explosion. The complex geometry of the cavity and its internal structures is expected to have a profound effect on the way the explosion energy is distributed.

It is not our objective to model the explosion physics itself, only the expansion phase as a source term for the subsequent transient in the surrounding fluid. A deterministic model of the explosion physics should be able to predict parameters such as the extent of fuel fragmentation, the amount of energy transferred, and the magnitude and speed of the propagation pressure wave. None of these parameters is important for our purpose. First, the propagation phase is completed in a time scale much smaller than the transient time of interest particularly for the large systems under study; the pressurization of the explosion zone is, in effect, instantaneous and any information regarding its rate is hardly useful. Second, the actual fraction of participating melt and the resulting energy transfer and pressurization are quite random. Experiments have shown that the explosion energy yield and pressure waves vary widely even for repeat tests with very similar initial conditions. No deterministic model is thus qualified to predict such quantities that are physically sensitive to very slight changes in the initial conditions. It is, therefore, practical and sufficient to focus on the rigorous simulation of the expansion phase and the subsequent transients, where the initial conditions representing the earlier explosion stages are represented parametrically.

Previous work that included simulation of the expansion phase of a steam explosion has a different focus. For example, the mechanistic analysis of

in-vessel steam explosion loads for the Zion/Indian Point study [5] utilized the two-dimensional fluid mechanics code SIMMER-II [6]. Also, the initial conditions are represented differently where the calculations start from an inequilibrium coarse mixture and the interaction is assumed to be triggered uniformly. Assumptions regarding the extent of fragmentation and the composition of the interaction zone among other parameters are adjusted in an attempt to reproduce pressurization data of a certain experiment for the sake of calibrating the model. In another study [7], the emphasis is placed on the structural aspects of an in-vessel steam explosion problem not on the thermal-fluid dynamics.

The remainder of this report is organized as follows. Section 2 describes the mathematical model including the relevant equations of change and exchange functions for mass, momentum, and energy. Section 3 describes the application of the code to the FITS-2B experiment as a means of validating the models. Conclusions are summarized in section 4. A companion report (GTRSR - 007) describes the results of applying the code to hypothetical steam explosion scenarios within the reactor building of the Savannah River Plant.

2 The Mathematical Model

The K-FIX computer code [8,9] uses a two-fluid model to simulate transient, two-phase, three-dimensional flow. The two fluids have generally different densities, velocities, and temperatures determined by separate mass, momentum, and energy equations. In the original code, the two fluids represent the vapor and liquid phases of a single component (water). Three components are represented in this work: water, air, and debris. The first fluid is a mixture of water vapor and a noncondensable gas (air) in both thermal and mechanical equilibrium. The second fluid is a mixture of liquid water and debris, again in equilibrium. In this section, the equations of change

and the exchange models for mass, momentum, and energy in the modified K-FIX(GT) code are presented.

The continuity equations are given as

Fluid 1:

$$\frac{\partial \rho'_g}{\partial t} + \nabla \cdot (\rho'_g \vec{u}_g) = J, \quad (1)$$

Air fraction in fluid 1:

$$\frac{\partial}{\partial t}(\rho'_g x_{\text{air}}) + \nabla \cdot (\rho'_g x_{\text{air}} \vec{u}_g) = 0, \quad (2)$$

Fluid 2:

$$\frac{\partial \rho'_l}{\partial t} + \nabla \cdot (\rho'_l \vec{u}_l) = -J, \text{ and} \quad (3)$$

Debris fraction in fluid 2:

$$\frac{\partial}{\partial t}(\rho'_l x_{\text{deb}}) + \nabla \cdot (\rho'_l x_{\text{deb}} \vec{u}_l) = 0. \quad (4)$$

Momentum equations are:

Fluid 1:

$$\begin{aligned} \frac{\partial}{\partial t}(\rho'_g \vec{u}_g) + \nabla \cdot (\rho'_g \vec{u}_g \vec{u}_g) &= -\theta \nabla p + K(\vec{u}_l - \vec{u}_g) \\ &+ \frac{1}{2}(J + |J|)\vec{u}_l + \frac{1}{2}(J - |J|)\vec{u}_g, \text{ and} \end{aligned} \quad (5)$$

Fluid 2:

$$\begin{aligned} \frac{\partial}{\partial t}(\rho'_l \vec{u}_l) + \nabla \cdot (\rho'_l \vec{u}_l \vec{u}_l) &= -(1 - \theta) \nabla p + K(\vec{u}_g - \vec{u}_l) \\ &- \frac{1}{2}(J + |J|)\vec{u}_l - \frac{1}{2}(J - |J|)\vec{u}_g. \end{aligned} \quad (6)$$

Energy equations are:

Fluid 1:

$$\begin{aligned} \frac{\partial}{\partial t}(\rho'_g I_g) + \nabla \cdot (\rho'_g I_g \vec{u}_g) &= -p \left[\frac{\partial \theta}{\partial t} + \nabla \cdot (\theta \vec{u}_g) \right] + [K + |J|/2] |\vec{u}_g - \vec{u}_l|^2 \\ &+ JH + R(T_l - T_g), \text{ and} \end{aligned} \quad (7)$$

Fluid 2:

$$\frac{\partial}{\partial t}(\rho'_l I_l) + \nabla \cdot (\rho'_l I_l \bar{u}_l) = -p \left\{ \frac{\partial}{\partial t}(1 - \theta) + \nabla \cdot [(1 - \theta) \bar{u}_l] \right\} - JH + R(T_g - T_l) \quad (8)$$

The system of equations is completed with the relations between the macroscopic and microscopic densities,

$$\rho'_g = \theta \rho_g, \text{ and} \quad (9)$$

$$\rho'_l = (1 - \theta) \rho_l \quad (10)$$

as well as the state equations specifying microscopic densities and temperatures as functions of pressure and specific internal energies.

The above equations are coupled through the condition of pressure equilibrium between the two interpenetrating fluids, and through the exchange of mass, momentum, and energy. The models for these exchange functions are presented next.

2.1 Momentum Exchange

Momentum exchange by mechanisms other than mass exchange is accounted for in the momentum equation via the momentum exchange function K . A very large value (effectively ∞) of the momentum exchange function K is used for some runs to simulate frozen two-phase flow. With no slip between the two fluids, the slug acceleration and impact is overestimated and the results serve as a conservative upper limit.

We have also experimented with using constant, finite, values of K to verify that instabilities (of Helmholtz type) occur for K values below a certain limit. For the usual representation of K as: $K = \frac{3}{8} \theta (1 - \theta) C_D \rho_c u_r / \tau_d$, a different kind of instability may occur even for relatively large values of K .

If the dispersed phase radius r_d is computed by requiring a constant critical Weber number $We_{cr} = 2\rho_c r_d u_r^2 / \sigma$, we get $r_d \sim u_r^{-2}$. For $C_D \sim Re^{-1} \sim r_d^{-1} u_r^{-1}$, we get $K \sim u_r^4$.

The strong nonlinear dependence of K on u_r resulted in chaotic behavior for many cases particularly those involving fast transients. A small value of u_r results in small K , which in turn allows large u_r to develop. Such over-compensation resulted in some cases in bounded or unbounded oscillations in both K and u_r . This problem was observed earlier in reference [6]; it was corrected by using an approximate advance time value of u_r to calculate K implicitly. In our method, we have abandoned the assumption of instantaneous adjustment of u_r to maintain a critical value of Weber number. Instead, fluid breakup and dispersion are treated more accurately. The number density of dispersed fluid particles N_d is calculated from the transport equation:

$$\frac{\partial N_d}{\partial t} + \vec{u}_d \cdot \nabla N_d = \omega(N_d^{eq} - N_d). \quad (11)$$

The equilibrium number density N_d^{eq} corresponds to a critical Weber number $We_{cr} = 12$, and is calculated from:

$$N_d^{eq} = \frac{3 \min[\theta, (1 - \theta)]}{4\pi r_{d_0}^3} \quad (12)$$

where

$$r_{d_0} = \frac{\sigma We_{cr}}{2\rho_c u_r^2} = \frac{6\sigma}{\rho_c u_r^2}. \quad (13)$$

The breakup parameter ω is assumed to be a function of Weber number, and its value is obtained by correlating the experimental data, given in reference [10], for water droplet breakup time. The following correlation was obtained:

$$\omega = 4 We^{0.678} \text{ (sec}^{-1}\text{)}. \quad (14)$$

The experiment was conducted for $15 < We < 95$; the correlation was assumed valid for all values of $We > 12$; it was applied to the breakup and coalescence of both droplets and bubbles.

Finally, a symmetric expression [11] of K , which has the advantage of continuity at $\theta = 0.5$ is used to get:

$$K = \frac{3}{2} \theta (1 - \theta) \left(\frac{1}{r_d} + \frac{1}{r_c} \right)^2 \left[\frac{3 \mu_d \mu_c}{\mu_d + \mu_c} + \frac{C_D \rho_d \rho_c u_r r_d r_c}{4 (r_c \rho_d + r_d \rho_c)} \right] \quad (15)$$

The dispersed and continuous fluid radii are obtained from

$$r_d = \left(\frac{3 \min[\theta, (1 - \theta)]}{4 \pi N_d} \right)^{1/3}, \text{ and} \quad (16)$$

$$r_c = \left(\frac{3 \max[\theta, (1 - \theta)]}{4 \pi N_d} \right)^{1/3} \quad (17)$$

The drag coefficient needed for equation (15) is obtained from the following correlations (Eqns. 18 - 22), found in reference [12], as a function of dispersed particle Reynolds number Re .

For large gas bubbles of radius > 0.9 cm, and for all Re ,

$$C_D = \frac{8}{3} + \frac{8(2 + 3\beta)}{(1 + \beta)Re}, \quad \text{where } \beta = \frac{\mu_g}{\mu_l}, \quad (18)$$

For smaller bubbles,

$$C_D = \frac{8(2 + 3\beta)}{(1 + \beta)Re}, \quad Re < 4, \text{ and} \quad (19)$$

$$C_D = \frac{3.05(783\beta^2 + 2142\beta + 1080)}{(60 + 29\beta)(4 + 3\beta)} Re^{-0.74}, \quad Re > 4. \quad (20)$$

The above drag correlations apply for droplet flow with $\beta = \mu_l/\mu_g$. For solid debris, we use

$$C_D = 24(1 + 0.1 Re^{0.75})/Re, \quad Re < 10^3, \text{ and} \quad (21)$$

$$C_D = 0.45 \text{ for } Re \geq 10^3. \quad (22)$$

2.2 Mass Exchange

The evaporation and condensation are calculated using a conduction-controlled model [13]. The two-phase surface is assumed to remain at the saturation temperature corresponding to the bulk vapor pressure. The local surface condition is assumed independent from effects such as air concentration gradient due to finite diffusion and pressure changes due to surface tension or inertia resistance to bubble growth. The liquid phase, having much larger conductivity, is taken as the source (or sink) of the latent heat, and the heat flux responsible for phase change is driven by the difference between the liquid bulk temperature and the saturation temperature. The surface area is already known from the dispersion number density and the average bubble or droplet radius determined from the momentum exchange calculation. An estimate of the nondimensional thermal boundary layer δ is obtained from reference [13]:

$$\delta^{-1} = \frac{6 \rho_l C_l (T_l - T_{sat})}{\pi \rho_v H_L} + \sqrt{\frac{2 \rho_l C_l u_r r_d}{\pi \kappa_l}}, \quad (23)$$

where the first term is the inverse static conduction boundary layer thickness, and the second term accounts for the reduction of the boundary layer thickness and the enhancement of conduction due to translation motion. The phase change rate per unit volume becomes

$$J = \frac{4 \pi r_d N_d \kappa_l (T_l - T_{sat})}{\delta H_L}. \quad (24)$$

For condensing bubble, i.e. $J < 0$, and $\theta < 0.5$, the condensation rate is retarded [14] by a factor of $(1 - x_{air} \rho_g / \rho_{air})$.

Unstable solutions were sometimes observed when very rapid pressure changes occur in the course of explosion simulation using the above phase change model. Large driving temperature difference occurs when the saturation temperature changes significantly, resulting in large phase change rate. The phase change in one time step, $J \Delta t$, is correct only for small time steps such that the resulting change in the liquid temperature is relatively small, at least not enough to reverse the sign of J in one time step. Overshooting the equilibrium state in this case results in the observed oscillations. Instead of reducing the time step, the change in temperature during one time cycle is accounted for, where the above expression of J serves as an initial condition. The phase change model becomes self-limiting and stable by using J to calculate $\bar{J}$, defined as the phase change rate averaged over one time cycle; thus

$$\bar{J} = \frac{\rho'_l C_l (T_l - T_{sat})}{H_L \Delta t} \left\{ 1 - \exp \left(\frac{-J H_L \Delta t}{\rho'_l C_l (T_l - T_{sat})} \right) \right\}. \quad (25)$$

For a large exponent, i.e. large initial $J \Delta t H_L$ relative to the liquid heat content, $\bar{J}$ reaches its maximum of $\rho'_l C_l (T_l - T_{sat}) / (H_L \Delta t)$, as the liquid temperature approaches saturation exponentially, while for small exponent, $\bar{J}$ approaches the initial value J . The value of $\bar{J}$ calculated from eqn. (25) is used to supply the required phase change rate in the finite difference representation of the equations of change.

2.3 Energy Exchange

The energy exchanged by mechanisms other than phase change is accounted for in the energy equation via the heat exchange function R . In some runs, a very large value (essentially $R \rightarrow \infty$) is used to force thermal equilibrium between the two fluids. In the other cases, a simple model is used to estimate R in a two-phase mixture. The energy transfer across the two-phase interface is assumed to result from mass exchange ignoring radiation contribution. Define ϕ_+ as the mass flux from liquid to vapor; $\phi_- \approx \phi_+$ is the opposite flux. The momentum exchange rate per unit volume can be written as:

$$\begin{aligned}\Delta(\dot{m}\vec{u}) &= A(\phi_+\vec{u}_l - \phi_-\vec{u}_g) \\ &= A\phi(\vec{u}_l - \vec{u}_g) + \frac{1}{2}(J + |J|)\vec{u}_l + \frac{1}{2}(J - |J|)\vec{u}_g,\end{aligned}\quad (26)$$

where A is the interface area per unit volume, $\phi = \min(\phi_+, \phi_-)$, and $J = A(\phi_+ - \phi_-) = A\Delta\phi$. Comparing the above equation with the momentum equation (5), we get $A\phi = K$. For energy exchange, we get

$$\Delta E = A\phi_+(I_l + H_L + u_l^2/2) - A\phi_-(I_g + u_g^2/2) \quad (27)$$

The kinetic energy dissipation and the energy carried by the net mass exchange are accounted for in the above equation and the energy equation (7); the remaining term is obtained by comparison as $R(T_l - T_g) = A\phi(I_l + H_L - I_g)$. With $I_l + H_L = I_g$ at liquid temperature, we get $R(T_l - T_g) = A\phi C_v(T_l - T_g)$, and $R = A\phi C_v$. Finally,

$$R = C_v K, \quad (28)$$

where the value of K is obtained from the momentum exchange model described earlier.

2.4 Explosion Energetics

The explosion mechanical energy yield as a function of time is measured by two parameters. The first is the kinetic energy of the entire system or parts thereof such as the explosion zone material. The second parameter is the explosion zone expansion work calculated directly from $W = \int p dV$. To perform the integration, the boundaries of the explosion zone must be identified at all times. The *Lagrangian Marker* method was used for that purpose. A number of uniformly distributed marker points is initially assigned to each explosion zone finite difference cell. At the end of each time cycle, the location of each marker point is updated (traced) as

$$\vec{x}_{new} = \vec{x}_{old} + \Delta t \vec{v}, \quad (29)$$

where the marker velocity $\vec{v}$ is computed by interpolation from the velocity components at the six boundaries of the host cell. To guarantee that the explosion zone cells will always be marked throughout its expansion, the number of markers N should satisfy

$$N \gg \frac{\text{Maximum Explosion Zone Volume}}{\text{Initial Explosion Zone Volume}}. \quad (30)$$

For all cells containing at least one marker, the six neighboring cells are checked for the presence of markers. The cell boundary separating a marker-containing - and an empty cell is identified as a segment of the explosion zone boundary. The work done across a segment of the explosion zone boundary in one time step is calculated from

$$\Delta W = P \Delta t S [\theta_D u_{g\perp} + (1 - \theta_D) u_{l\perp}], \quad (31)$$

where the fraction of the segment area S for the gas flow is taken as the void fraction of the donor cell θ_D , and the pressure P is that of the marker side of the boundary. The explosion work is thus computed as the sum of all ΔW at the explosion zone surface for all preceding time cycles.

In addition to work calculations, the markers are used to identify the explosion zone for the calculation of its kinetic energy, supply additional information on the extent of numerical diffusion, and are valuable for flow visualization.

3 Simulation of FITS-2B Experiment

The comparison of model results with experimental data is an essential step for its validation and extension to other systems. The most suitable experiment to compare with the expansion phase model is one where a steam explosion event occurs inside a relatively large cavity, and appropriate pressure data is collected not only in the explosion test vessel but also in the surrounding cavity atmosphere. The reason for this preference stems from the fact that our choice of initializing the expansion phase implies no details of the initial pressurization which occurs during the propagation phase. The flow in the cavity in response to the explosion is essentially independent of the pressurization rate if the cavity size is relatively large compared with that of the initial explosion zone, and if the location of points of interest is relatively distant from the explosion center. This description of scale is quite accurate for the systems (SRP ex-vessel) targeted for our analysis.

The most suitable experimental data for model validation is the Sandia National Laboratories Fully Instrumented Test Series (FITS). The FITS-B series of experiments involve the delivery of nominally 18.7 kg of molten iron-alumina into a lucite chamber partially filled with water at room temperature. The explosion chamber is placed inside the FITS containment chamber as shown in Fig. (1). The setup and instrumentation are described in detail in reference [15].

3.1 Initial Conditions

The FITS-2B test conditions are chosen for the validation test case calculations because the experimental data for this test received the most attention [16] where a best estimate for its compression conversion ratio is available. The thermodynamic state and configuration of the explosion zone were not measured (i.e. not reported) in the FITS-B tests. Measurements for the similar MD and FITS-A series [17] involving iron-alumina melt mass of $1 \sim 5 \text{ kg}$ showed pressure peaks of up to $\sim 175 \text{ bar}$ in the chamber base. In reference [17], internal pressures in the order of magnitude of $10^2 \sim 10^3 \text{ bar}$ are indicated. It also appears that a liquid water layer remains in the bottom of the chamber and side walls, while a steam channel or a bubbly mixture is formed atop the explosion zone.

The following procedure is followed to arrive at an estimate of the initial thermodynamic conditions in the explosion zone for the K-FIX(GT) calculations. First, ideal Hicks-Menzies calculations [18] for the maximum possible conversion ratio are performed for the 2750 K iron-alumina melt and 298 K water. Constant volume heat transfer from the melt to the coolant is assumed to occur until equilibrium is attained, and isentropic coolant expansion follows to an end pressure of 0.08 MPa . The coolant-to-melt mass ratio is varied to obtain the maximum conversion ratio for each given initial mixture volume or equivalently initial coolant void fraction. Figure (2) depicts the variation of the Hicks-Menzies conversion ratio as a function of coolant-to-fuel mass ratio for different initial values of coolant void fraction. Figure (3) shows the resulting ideal conversion ratio as a function of the initial coolant void fraction, which represents an upper envelope for different coolant-to-melt ratios. The actual value of the Hicks-Menzies conversion ratio is not important; our purpose is to estimate an intermediate thermodynamic state prior to the expansion phase. The ideal assumption of isentropic coolant expansion will then be replaced by detailed K-FIX(GT) calculations. The selected point shown in Fig. (3) represents an indirect relaxation of the ideal assumption of

constant volume heat addition, where a large initial void fraction (larger than expected at the end of the premixing stage) is selected near the knee of the curve prior to rapid reduction of the ideal conversion ratio. The intermediate state for the selected point ($P = 370 \text{ bar}$, $T = 925 \text{ K}$) indicates a pressure value within the range of experimental measurements for this melt/coolant pair, in contrast to a highly overestimated pressure of 9540 bar for the maximum value of Hicks-Menzies conversion ratio obtained at an initial void fraction of 0.2.

The above procedure is used to estimate the intensive thermodynamic state at the beginning of K-FIX(GT) calculations. To obtain the extensive properties, an estimate of the fraction of the melt participating in the explosive interaction is required. We assume a debris particle cut-off size of $300 \mu\text{m}$, below which the fragments can be considered to participate in the explosive heat transfer. Using the debris size distribution data given in reference [15], the mass fraction of the debris below the cut-off size is 0.14, which corresponds to a participating melt mass of 2.6 kg . Another set of thermodynamic model calculations is performed in order to support the assumption of the debris cut-off size. Following Hall [19], instead of Hicks-Menzies isentropic coolant expansion assumption, the compression of the gas surrounding the explosion zone is assumed isentropic. The result is a qualified minimum conversion ratio. Hall conversion ratio predictions are found to be in good agreement with experimental measurements [19]. In our case, the fraction of the 18.6 kg melt participating in the interaction is varied, and the maximum Hall conversion ratio corresponding to the optimum coolant-to-melt mass ratio is calculated as shown in Fig. (4). It should be noted that the conversion ratio defined here is the ratio between the explosion work and the entire thermal energy content in the melt, not only the participating fraction. The variation of the conversion ratio with the fraction of melt participation is not simply linear because the initial volume of the cover gas is constant (equal to the FITS confinement chamber volume of 5.6 m^3) for all values of participating melt mass. As shown in Fig. (4), a 14% melt participation pre-

Zone	P(bar)	T(K)	θ	x_{air}	x_{deb}
1. Explosion Zone	370.0	925.0	0.7866	0.0	0.968
2. Vapor Blanket	0.8	366.5	0.34	0.0	0.0
3. Water Zone	0.8	298.0	0.005	0.9	0.0
4. Atmosphere	0.8	298.0	0.9999	0.99	0.0

Table 1: Initial Composition and Thermodynamic Parameters for FITS-2B Simulation

dicted a Hall conversion ratio of 0.73%, which is close to the best estimate of conversion ratio of 0.8% calculated from the experimental data for FITS-2B in reference [16].

3.2 Nodal Representation of FITS-2B

The FITS containment chamber is represented in axisymmetric cylindrical coordinates by 9 radial cells and 21 vertical cells. Only one angular cell is used to impose the symmetry. The radial and vertical mesh sizes are 8.3 and 15.0 cm respectively. The support of the test chamber is represented as a flow obstruction extending 4 cells radially and 6 cells high. The materials in the square lucite test chamber are represented by equal volumes of cylindrical zones. The lucite chamber itself is not included as its resistance to the explosion is assumed negligible. Four fluid zones are specified. Zone # 1 is the high pressure explosion bubble which also contains 18.6 kg of debris. Zone # 2 is a layer of boiling water surrounding the explosion zone. Zone # 3 represents the noninteracting part of the liquid water which remains at the chamber side walls. Zone # 4 is the gas in the containment chamber. The location of these zones is shown in Fig. (5). The initial parameters of each zone are summarized in Table (1).

The variables used in Table (1) are the pressure P in bars, temperature

T in degrees Kelvin (K), the volume fraction of the gas phase θ , the mass fraction of air in the gas mixture x_{air} , and the mass ratio of the debris to the debris and liquid water x_{deb} . Initially, 128 Lagrangian markers are uniformly distributed in the explosion zone. The motion of these markers trace the flow of the expanding vapor.

3.3 Simulated FITS-2B Results

The problem was run for 50 ms using a 0.02 ms time step. Two cases are considered: run X which employs all the mass, momentum, and energy exchange functions described above, and run Y with simplified exchange laws where mass exchange is neglected and the two fluids are forced to have the same velocity and temperature fields.

As shown in Fig. (6) for run X, the pressure in the explosion zone cell (3,9,2) drops rapidly from 370 bar to ~ 2 bar in 4.0 ms as the explosion bubble expands, and continues to drop below the ambient pressure due to the inertia of the expanding material. A 25 bar pressure pulse is transmitted to the neighboring cell (5,9,2), while for farther cells considerable attenuation is evident due to radial expansion. As shown in Fig. (7), a pressure pulse peak of ~ 2 bar occurs at the containment chamber wall. Similar qualitative behavior can be seen in Fig. (8) for run Y. However, the transmitted pressure peak to cell (5,9,2) is ~ 50 bar, which is twice that of run X.

The drop of debris density in the explosion zone due to its expansion is shown in Fig. (9) for the cell (3,9,2). The transport of debris to the neighboring cells (5,9,2) and (7,9,2) is also shown as the debris density increases from initially zero to a peak value and then drops due to the continued expansion. The peak debris density is smaller and occurs at a later time for cells located farther from the explosion center than for closer cells.

The expansion of the explosion zone can be seen most clearly from the Lagrangian Marker plots given in Fig. (10) for run X. These markers trace the motion of the "gas" phase of the explosion zone primarily for the purpose

of identifying its boundaries for the mechanical work calculations. However, the velocity slip between the two fluids in this particular case was found to be only 10~15%, and the marker distribution approximates that of the debris as well. For run Y with no slip, the markers shown in Fig. (11) trace the explosion zone fluid including the debris. The more violent transient in run Y is evident as the markers expand to a volume larger than that of run X; also the surrounding gas is pressurized enough to reverse the direction of the flow and do work on the explosion zone reducing its size.

The kinetic energy of the system and the explosion work are shown in Fig. (12) for both runs. The rebound experienced by the explosion zone in run Y results in slight dip in the work curve, while the work done by the explosion zone in run X is monotonically increasing with time.

The kinetic energy and work shown in Fig. (12) are given per unit angle, and the actual values for the symmetric system is obtained by multiplying by 2π . The maximum total mechanical energy yield of the explosion is thus estimated for run X as $2\pi \times 0.08 = 0.5 \text{ MJ}$. With a total initial thermal energy of 52 MJ , the conversion ratio estimate from our simulation is thus 0.97 %. This conversion ratio is dominated by the compression component since the kinetic energy contribution at the end of simulation time is very small. The calculated value of the conversion ratio compares well with the best estimated value for the compression conversion ratio of 0.8 % computed in reference [16] from the experimental data for the FITS-2B test. This provides added confidence in the ability of the model to simulate a steam explosion or fast transient. It is interesting to note that a planar pressure wave was assumed to eventually form in order to arrive at the conversion ratio result in reference [16]. This behavior is indeed demonstrated as shown in the calculated pressure contour plots in Fig. (13).

The kinetic energy, explosion work, and pressure peaks are all found to be larger for run Y than for run X. This can be explained as primarily due to the effect of condensation of the working fluid due to mixing with the water slug, which is neglected for run Y. Also, with neglected slip in run Y, the

liquid water is forced to acquire higher kinetic energy initially and continue by inertia to do work on the surrounding gas. It should be noted that the essentially infinite frictional drag function used in run Y to force the no slip condition does not imply larger kinetic energy dissipation than the finite drag case. To the contrary, this actually implies no frictional dissipation for run Y, which explains in part its higher energetics.

4 Conclusions

The three-dimensional, two-fluid, transient fluid dynamics code K-FIX has been modified to produce the K-FIX(GT) code. The modifications aim at adding the capability to simulate the fast transients associated with the expansion phase of steam explosions. In particular, two additional components, noncondensable gas and debris, are added. Also, new models for the exchange of mass, momentum, and energy between the two fluids are incorporated in the new code.

This report focuses on the model description and code validation through simulating a well-instrumented experiment, Sandia National Laboratories FITS-2B. The initial conditions for the simulation have been estimated with the aid of thermodynamic models of steam explosions. The results show the success of the methodology and its validity for application to real reactor situations, as evidenced by the reasonable agreement between the calculated and experimental conversion ratios. In a companion report (GTRSR - 007), seven test cases with parametrically varied initial conditions and model parameters simulating *hypothetical* ex-vessel explosions in the confinement building of the Savannah River Plant are presented.

Nomenclature

- A Interfacial area per unit volume.
- C_D Drag coefficient.
- C_v Specific heat at constant volume for vapor.
- C_l Liquid specific heat.
- H Enthalpy exchange due to mass exchange.
- H_L Latent heat.
- I Specific internal energy.
- J Evaporation rate, negative for condensation.
- K Momentum exchange function.
- $\dot{m}$ Mass exchange rate.
- N Dispersion number density of fluid particles.
- p Pressure.
- r Radius of the average fluid particle.
- R Energy exchange function.
- Re Reynolds number.
- t Time.
- T Temperature.
- $\vec{u}$ Fluid velocity vector.
- u_r Relative velocity between the two fluids.

$\vec{v}$ Velocity of Lagrangian Markers.

We Weber number.

$x_{a,r}$ Mass fraction of noncondensible gas in the gas mixture.

x_{deb} Mass fraction of debris in the liquid/debris mixture.

Greek

θ Gas volume fraction.

κ Heat conductivity.

μ Viscosity.

ρ Microscopic density.

ρ' Macroscopic density.

σ Surface tension.

ϕ Mass flux.

ω Breakup parameter.

Subscripts

c Continuous fluid.

cr Critical.

d Dispersed fluid.

D Donor cell.

g Gas mixture.

l Liquid/debris mixture.

sat Saturation.

$\perp$ Normal to a surface.

Superscript

eq Equilibrium.

References

- (1) Y. M. FARAWILA and S. I. ABDEL-KHALIK, "A Literature Survey of Vapor Explosion Phenomena," Georgia Institute of Technology Report GTRSR-001 (May 1988).
- (2) S. J. BOARD, R. W. HALL, and R. S. HALL, "Detonation of Fuel Coolant Explosions," *Nature*, Vol.254, p.321 (March 1975).
- (3) C. CARACHALIOS, M. BÜRGER, and H. UNGER, "Triggering and Escalation Behavior of Thermal Detonations," Proceedings of National Heat Transfer Conference, Denver, Colorado (August 1985).
- (4) S. MEDHEKAR, M. ABOLFADL, and T. G. THEOFANOUS, "Triggering and Propagation of Steam Explosions," 25th ASME-AIChE National Heat Transfer Conference, Houston, Texas (July 1988).
- (5) M. G. STEVENS, Ed., "Report of the Zion/Indian Point Study," NUREG/CR-1411, LA-8306-MS, Los Alamos National Laboratory (April 1980).
- (6) L. L. SMITH, "SIMMER-II: A Computer Program for LMFBR Disrupted Core Analysis," Los Alamos National Laboratory Report LA-7515-M, NUREG/CR-0453 (June 1980).
- (7) W. H. AMARASOORIYA and T. G. THEOFANOUS, "An Assessment of Steam-Explosion-Induced Containment Failure. Part III: Expansion and Energy Partition," *Nucl. Sci. Eng.*, **97**, 296-315 (1987).
- (8) W. C. RIVARD and M. D. TORREY, "K-FIX: A Computer Program for Transient, Two-Dimensional, Two-Fluid Flow," LA-NUREG-6623 (April 1977).
- (9) W. C. RIVARD and M. D. TORREY, "K-FIX: A Computer Program for Transient, Two-Dimensional, Two-Fluid Flow - THREED:

An Extension of the K-FIX Code for Three-Dimensional Calculations,"
LA-NUREG-6623, Suppl. II (January 1979).

- (10) S. A. KRZECZKOWSKI, "Measurement of Liquid Droplet Disintegration Mechanisms," *Int. J. Multiphase Flow*, Vol. 6, pp. 227-239 (1980).
- (11) F. H. HARLOW and A. A. AMSDEN, "Flow of Interpenetrating Material Phases," *J. Comp. Phys.* **18**, 440-464 (1975).
- (12) R. CLIFT, J. R. GRACE, and M. E. WEBER, *Bubbles, Drops, and Particles*, Academic Press (1978).
- (13) C. W. HIRT et al., "SOLA-LOOP: A Nonequilibrium, Drift Flux Code for Two-Phase Flow in Networks," Los Alamos National Laboratory Report LA-7659, NUREG/CR-0626, (1979).
- (14) D. MOALEM and S. SIDEMAN, "The Effect of Motion on Bubble Collapse," *Int. J. Heat Mass Trans.*, **16**, 2321 (1973).
- (15) D. E. MITCHELL and N. A. EVANS, "Steam Explosion Experiments at Intermediate Scale: FITSB Series," SAND83-1057, Sandia National Laboratories (1986).
- (16) Y. M. FARAWILA and S. I. ABDEL-KHALIK, "On the Calculation of Steam Explosion Conversion Ratios from Experimental Data," *Nucl. Sci. Eng.*, **104**, 288-295 (1990).
- (17) D. E. MITCHELL, M. L. CORRADINI, and W. W. TARBELL, "Intermediate Scale Steam Explosion Phenomena: Experiments and Analysis," SAND81-0124, Sandia National Laboratories (1986).
- (18) E. HICKS and D. MENZIES, "Theoretical Studies on the Fast Reactor Maximum Accident," *Proc. Conf. Safety, Fuels, and Core Design in Large Fast Reactors*, Argonne, Illinois, October 11-14, 1965, ANL-7120, Argonne National Laboratory (1965).

- (19) A. N. HALL, "Outline of a New Thermodynamic Model of Energetic Fuel-Coolant Interactions," *Nucl. Eng. Design*, **109**, 407 (1988).

Figure 1: FITS Containment Chamber (from Reference 15)

Figure 2: Variation of the Hicks-Menzies Conversion Ratio with Coolant/Fuel Mass Ratio and Initial Coolant Void Fraction for the FITS-2B Experiment.

Figure 3: Variation of the Maximum Hicks-Menzies Conversion Ratio with Initial Coolant Void Fraction for the FITS-2B Experiment.

Figure 4: Variation of the Hall Conversion Ratio with Percent Melt Participation for the FITS-2B Experiment.

Figure 5: Initial Configuration for FITS-2B Simulation Showing the Four Zones Included in the K-FIX(GT) Model.

Figure 6: Calculated Pressure Histories during Run X for Three Different Locations.

Figure 7: Comparison Between the Calculated Pressure Histories During Runs X and Y for Cell (10,8,2).

Figure 8: Calculated Pressure Histories During Run Y for Three Different Locations.

Figure 9: Variations of the Calculated Debris Density vs Time During Run X for Three Different Locations.

TIME - 0.00E+00 ms

TIME - 5.00E+00 ms

TIME - 5.00E+01 ms

Figure 10: Lagrangian Marker Plots for Run X at Three Different Times (0, 5.0, and 50.0 ms)

TIME - 5.00E+00 ms

TIME - 2.50E+01 ms

TIME - 5.00E+01 ms

Figure 11: Lagrangian Marker Plots for Run Y at Three Different Times (5.0, 25.0, and 50.0 ms)

Figure 12: Time Variations of the Calculated Kinetic Energy and Mechanical Work for Runs X and Y.

TIME - 0.00E+00 ms TIME - 5.00E+00 ms TIME - 3.50E+01 ms

Figure 13: Calculated Pressure Contour Plots for Run X at Three Different Times (0, 5.0, and 35.0 ms). The Corresponding High and Low Contour Values and Increment are 352, 18.4, and 17.6 bars; 1.75, 0.43, and 0.066 bars; 1.26, 1.01, and 0.013 bars.

END

DATE
FILMED

6 / 23 / 93