DEVELOPMENT OF ADVANCED NO_x CONTROL CONCEPTS
FOR COAL-FIRED UTILITY BOILERS

DOE Contract No. DE-AC22-90PC90363

DOE/PC/90363--T4

Period of Performance: September 26, 1990 to October 26, 1992

DE92 017921

Quarterly Technical Progress Report No. 5

Period Covered by Report: October 1 to December 31, 1991

prepared by:

A. Evans
J. Newhall
G. England
W.R. Seeker

Energy and Environmental Research Corporation
18 Mason
Irvine, California 92718

Date Submitted: May 27, 1992

prepared for:

Mr. Charles E. Schmidt
U. S. Department of Energy
Pittsburgh Energy Technology Center
P. O. Box 10940
Pittsburgh, Pennsylvania 15236-0940

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1.0 INTRODUCTION	1-1
2.0 DEVELOPMENT OF IMPROVED NO/NO _x SAMPLING SYSTEM	2-1
2.1 MOTIVATION FOR STUDY	2-1
2.2 NEW NO/NO _x SAMPLING SYSTEM	2-4
3.0 VALIDATION OF THE PROPOSED NO/NO _x SAMPLING SYSTEM	3-1
3.1 Accuracy Checks Using the Validation System	3-1
3.1.1 Validation of Individual Components	3-1
3.1.2 Validation of the Complete NO/NO _x Sampling System	3-10
3.2 Accuracy Checks with Actual Flue Gas	3-17
4.0 SUMMARY	4-0

LIST OF FIGURES

<u>Figure</u>	<u>Page</u>
1-1 Application of CombiNO _x to a wall-fired utility boiler	1-2
2-1 Standard NO/NO _x sampling system schematic	2-2
2-2 Ice bath water trap and permeation dryer systems schematic	2-3
2-3 Results from ice bath water trap and permeation dryer sampling systems	2-5
2-4 Proposed NO/NO _x sampling system	2-7
3-1 NO/NO _x sampling system validation set-up	3-2
3-2 NO ₂ to NO conversion with stainless steel contact	3-7
3-3 New NO/NO _x sampling system validation results	3-14
3-4 Performance of sampling systems with a SO ₂ doped natural gas fired flue gas ...	3-19
3-5 Effect of SO ₂ on sampling systems	3-20
3-6 Performance of sampling systems with a coal fired flue gas	3-22
3-7 Effect of ash on NO/NO _x measurements in new sampling system	3-23
3-8 Phase discrimination probe	3-24
4-1 Final NO/NO _x sampling system	4-2

LIST OF TABLES

<u>Table</u>	<u>Page</u>
3-1 Water trap validation data	3-4
3-2 Teflon sample line validation data	3-6
3-3 Silica gel validation data	3-9
3-4 Pump validation data	3-11
3-5 Filter validation data	3-11
3-6 Complete system validation: larger chiller vs small chiller	3-12
3-7 Effect of water vapor on new sampling system	3-15
3-8 Effect of NH ₃ on new sampling system	3-16

1.0 INTRODUCTION

Hybrid technologies for the reduction of NO_x emissions from coal fired utility boilers have shown the potential to offer greater levels of NO_x control than the sum of the individual technologies, leading to more cost effective emissions control strategies. Energy and Environmental Research Corporation (EER) has developed a hybrid NO_x control strategy involving two proprietary concepts which has the potential to meet the U.S. Department of Energy's NO_x reduction goal at a significant reduction in cost compared to existing technology. The process has been named Combi NO_x .

Combi NO_x is an integration of three technologies: modified reburning, promoted selective non-catalytic reduction (SNCR) and methanol injection. These technologies are combined to achieve high levels of NO_x emission reduction from coal fired power plants equipped with SO_2 scrubbers. The first two steps, modified reburning and promoted SNCR are linked. It has been shown that performance of the SNCR agent is dependent upon local oxidation of CO. Reburning is used to generate the optimum amount of CO to promote the SNCR agent, although lower levels of reburning are needed than are traditionally applied in the reburning process. If the reburn fuel is natural gas, the combination of reburning and SNCR may result in a significant cost savings over conventional reburning. The third step, injection of methanol into the flue gas, is used to convert NO to NO_2 which may subsequently be removed in a wet scrubber. Figure 1-1 illustrates how Combi NO_x may be applied to a coal fired utility boiler.

The overall objective of this program is to demonstrate the effectiveness of the Combi NO_x process at a large enough scale and over a sufficiently broad range of conditions to provide all of the information needed to conduct a full-scale demonstration in a coal fired utility boiler. The specific technical goals of this program are:

- 70% NO_x reduction at 20% of the cost of selective catalytic reduction;
- NO_x levels at the stack of 60 ppm for ozone non-attainment areas;
- Demonstrate use of coal reburning in Combi NO_x process;
- Identify all undesirable by-products of the process and their controlling parameters;
- Demonstrate 95% NO_2 removal in a wet scrubber.

Figure 1-1. Application of CombiNO_x to a coal-fired utility boiler.

To achieve these goals, the program was broken down into two experimental phases. The first phase is referred to as the Fundamental Studies Test Program. In this phase, each of the CombiNO_x steps will be analyzed individually at laboratory and pilot scales. In addition, the potential synergism between the three processes will be studied at pilot scale. Phase II is termed Process Studies. It is in this stage that scale-up issues will be addressed. Testing of the complete CombiNO_x process will be performed in a 10 MMBtu/hr furnace which has been shown in the past to accurately simulate the thermal characteristics of a full scale utility boiler.

The primary objective during this reporting period was to design a NO/NO_x sampling system that would accurately measure NO and NO_x when large amounts of NO₂ are present. This report will explain the problems associated with the standard NO/NO_x sampling system, and describe the research performed towards the development of an improved system.

2.0 DEVELOPMENT OF IMPROVED NO/NO_x SAMPLING SYSTEM

During the pilot scale methanol injection tests, it was observed that NO/NO_x sampling problems exist when large amounts of NO₂ are present. These problems are not apparent with most combustion sources of NO_x due to the low NO₂ concentrations normally generated. In response to these sampling concerns, a new NO/NO_x sampling system was developed. This section will describe the motivation for and the development of the improved sampling system.

2.1 Motivation For Study

The NO/NO_x sampling system typically used by EER on experimental facilities is shown in Figure 2-1. As illustrated, the system consists of a simple water knock-out (usually a Teflon or stainless steel coil and reservoir submerged in an ice bath), filter, and a Thermo Electron Corp. (TECO) Model 10 NO/NO_x Analyzer. This system will be referred to as the "standard system". The TECO analyzer uses a chemiluminescent method for NO detection. This method exposes the dry gas sample to ozone; the ozone then reacts under vacuum with NO to form excited NO₂ molecules. As the excited NO₂ molecules relax to NO₂, they produce a directly proportional amount of light photons. These photons are then measured by a photomultiplier tube providing a direct NO measurement. In order to measure total NO_x (defined as NO + NO₂), the sample first passes through a converter which reduces any NO₂ to NO; the total NO_x in the sample can then be determined as described above. NO₂ can be determined from the difference of the NO and NO_x measurements.

Since NO₂ is water soluble, there was concern that it could be absorbed in the water collected in the ice bath water trap of the standard sampling system. To evaluate the efficiency of NO₂ absorption in the water trap, a permeation dryer system was used in parallel during a series of methanol injection tests conducted in September of 1991 on EER's Boiler Simulation Facility (BSF). A schematic of the dual gas conditioning system is shown in Figure 2-2. In the permeation dryer, the sample gas is passed through one side of a permeable membrane sleeve. Dry air passed on the other side of the sleeve removes moisture from the sample gas.

Figure 2-1. Standard NO/NO_x Sampling System Schematic.

Figure 2-2. Ice bath water trap and permeation dryer systems schematic.

The results of an initial series of methanol injection tests are shown in Figure 2-3. In these tests, coal was fired resulting in an initial NO level of 950 ppm. The measurements performed with the two gas conditioning systems indicate that inaccuracies occur with both systems. First, both systems show a decrease in NO_x suggesting that losses occur in the sampling system (since methanol injection is intended to convert NO-to-NO₂, total NO_x levels in the flue gas should remain constant throughout methanol injection). For the water trap system, it is hypothesized that most of the NO₂ generated in the methanol step was absorbed in the water collected in the trap. The difference between NO_x and NO measurements for the water trap system suggests that the absorption process is not 100 percent efficient. The decrease in NO_x measured by the permeation dryer system is less than that observed with the water trap system; however, this NO_x decrease indicates that losses also occur with the permeation dryer system.

The lack of agreement between NO measured with both conditioning systems suggests that another sampling artifact is being produced by one of the systems. At present, it is believed that, in the permeation dryer system, NO₂ was converted to NO resulting in artificially high NO measurements. However, it is also possible that, in the water trap system, NO could be oxidized to NO₂ at relatively cool temperatures associated with the cold sample lines and large chiller and subsequently absorbed in moisture in the sampling system. In any event, the results shown in Figure 2-3 made research into a reliable NO/NO_x sampling system for this project necessary.

2.2 The New NO/NO_x Sampling System

The primary objective of any gas sampling system is to deliver a properly conditioned gas sample to an analytical instrument or other measuring device. It is critical that the gas be conditioned in manner which does not influence the species of interest; otherwise the measurement will be in error. In order to obtain accurate NO₂ measurements, the following considerations must be taken into account.

Figure 2-3. Results from ice bath water trap and permeation dryer sampling systems.

Sampling System Considerations

For sampling of NO and NO_x species, the gas sampling system must consider the following four potential sources of error:

1. NO₂ absorption into the condensed water within the ice bath water trap,
2. NO-to-NO₂ conversion within the sample lines,
3. NO₂-to-NO conversion when in contact with stainless steel at high temperatures,
4. NO₂-to-NO conversion in the presence of fly ash.

The absorption of NO₂ into the condensed water of the water trap is not a concern for NO measurements. Total NO_x measurements, however, will be inaccurate if this artifact is not corrected. To avoid these losses of NO₂ during NO_x measurements, the NO_x conversion (NO₂-to-NO) can be performed before the gas sample ever comes into contact with condensed water, therefore avoiding any loss due to absorption.

NO-to-NO₂ conversion within the sample lines can be reduced if the lines are maintained at elevated temperatures and if residence times are minimized.

NO₂-to-NO conversion catalyzed by the presence of stainless steel can be avoided by eliminating any stainless steel in the system where high temperatures will be reached. Quartz components and Teflon tubing and fittings can be substituted to eliminate this problem.

When burning coal, the resulting fly ash may contain activated carbon which is a known catalyst for NO₂-to-NO conversion. For this reason, ash intake into the sample system needs to be minimized. A quartz probe with a 90° bend can be pointed downstream to slightly reduce such intake.

Proposed Sampling System

A modified sampling system was initially proposed as displayed in Figure 2-4. The stainless steel sample probe of the standard sampling system was replaced with a quartz probe to avoid stainless

Figure 2-4: Proposed NO/NO_x Sampling System.

steel contact at high temperatures. The probe nozzle has a 90° bend which can be pointed downstream to reduce particulate flow into the system.

The gas sample immediately passes through a glass fiber filter which is mounted on a glass frit inside a quartz filter housing. The complete filter set-up is housed inside a small Blue-M oven, which is used to maintain filter temperatures above 200°F. These elevated temperatures help avoid condensation and resulting NO₂ losses.

The gas sample is then transported into the control room by means of a heated Teflon sample line. Sample temperatures within the Teflon line are kept above 200°F to avoid condensation and to avoid NO-to-NO₂ conversion. The Teflon line is fitted with stainless steel fittings; this being the first stainless steel contact that the sample gas encounters. Temperatures are kept below 250°F to prevent the NO₂-to-NO conversion that can occur with stainless steel contact. Subsequent components within the system use stainless steel fittings to avoid leakage problems that accompany Teflon and quartz fittings. Exposed stainless steel, however, is still kept at a minimum.

A diaphragm sample pump is the first component inside the control room, followed immediately by the carbon converter. The carbon converter (purchased from Rosemount Analytical) consists of a carbon-material-filled glass tube wrapped with a heating jacket. Conversion efficiency is optimum between the temperatures of 660° to 750°F, and flow rates through the converter must stay below 500 cc/min. In order to accommodate this flow rate limit and, at the same time, prevent a highly extended response time, a by-pass exhaust line is incorporated just prior to the carbon converter. An electronic switch is used to direct the flow either through or around the carbon converter, depending on whether a NO_x or NO measurement is desired.

The carbon converter is followed by a water trap which consists of a spiral-formed stainless steel tube with a condensate-catching reservoir on the bottom. The trap is placed in an ice bath to condense out moisture present in the flue gas. The dry sample gas then enters a TECO Model 10 NO/NO_x Analyzer.

It should be noted that all lines preceding the carbon converter are well heated and insulated to avoid condensation. All lines in general are kept as short as possible to minimize residence time. Total residence time for the complete system is approximately 10 seconds.

3.0 VALIDATION OF THE PROPOSED NO/NO_x SAMPLING SYSTEM

Prior to performing measurements with the proposed system, a series of validation tests was conducted to verify its performance. These tests were performed using two separate approaches. Preliminary relative response tests were performed on a validation system that was designed just for this purpose. Real-time validation tests were also performed while sampling flue gas from a combustion tunnel.

3.1 Accuracy Checks Using the Validation System

A validation system was constructed that was capable of determining how the sample conditioning process influenced NO and NO₂ concentrations. The general concept behind the system was to pass known amounts of NO and NO₂ through the new sampling system and note any changes that occurred in the gas composition. This validation system is displayed in Figure 3-1. NO₂ gas was formed for the procedure by introducing NO to O₃; the O₃ was supplied by passing O₂ over an ultraviolet light source. Since it was not easy to set exact amounts of NO and NO₂, a measurement comparison system was constructed.

Two identical lines were assembled in parallel between the span gas bottles and the TECO analyzer. One of the two lines had an opening in which a test component could be inserted. The test component could consist of either the whole sampling system or any combination of its components. By comparing NO and NO₂ levels measured by the direct line to those measured by the test line, the influence of the test component on the gas composition was determined.

3.1.1 Validation of Individual Components

Before testing the system as a whole, individual components of the proposed system were tested to determine their effect on the NO/NO₂ composition. During these tests, the following problems

- NO/NO_x values are the same through both lines when no test component is present. This gives baseline NO/NO_x values.
- When a test component is inserted into one side of the line, a direct comparison can be made to determine any changes in NO/NO_x measurements.

Figure 3-1. NO/NO_x sampling system validation set-up.

were addressed:

- NO to NO₂ conversion within the water trap and sample lines,
- NO_x losses within the water trap,
- NO₂ to NO conversion in the presence of stainless steel,
- Silica Gel and Permeation Dryer water removal capabilities,
- the effect of the pump, sample line, and filter on NO/NO_x measurements.

The results of these tests are discussed below.

NO to NO₂ Conversion Within the Ice Bath Water Trap and Sample Lines

According to chemical equilibrium and kinetics, NO₂ is favored over NO at the cooler temperatures which are obtained in the unheated sample lines and ice bath water trap. For this reason, it was of interest to see how much conversion of NO-to-NO₂ occurs within these components.

Table 3-1 displays the results as the water trap was tested in the validation set-up. Tests were run with and without NO₂ present, as well as with and without water present. Residence time in the water trap is approximately 7 seconds.

The first set of data in the table contains no NO₂ or water. As the dry NO and O₂ sample passes through the water trap, approximately 4% of the NO is converted to NO₂. The next set of data is taken under the same conditions except water is added to the water trap. The same conversion of NO-to-NO₂ takes place, however more loss of total NO_x occurs due to absorption of the newly formed NO₂ into the water.

The last two sets of data in Table 3-1 pertain to samples containing both NO and NO₂. The NO-to-NO₂ conversion within the water trap was not as severe as the NO only case, perhaps due to the lower initial concentrations of NO. In this case, the addition of water into the system tended to increase the conversion of NO-to-NO₂.

TABLE 3-1. WATER TRAP VALIDATION DATA.

Conditions	Direct to TECO Analyzer		Through Water Trap		Percent NO Loss	Percent NO ₂ Loss	Percent NO _x Loss
	NO, ppm	NO _x , ppm	NO, ppm	NO _x , ppm			
NO + O ₂ (no NO ₂ , dry water trap)	686	687	655	682	4.5%	N/A	0.7%
NO + O ₂ (no NO ₂ , wet water trap)	682	683	649	655	4.8%	N/A	4.1%
NO + NO ₂ (dry water trap)	456	690	443	659	2.9%	7.7%	4.5%
NO + NO ₂ (wet water trap)	471	703	439	611	6.8%	25.9%	13.1%

Since the NO-to-NO₂ conversion is more apt to occur at cooler temperatures, the use of a heated sample line (as opposed to a non-heated line) should reduce these conversions. Table 3-2 compares NO and NO_x losses for both a heated and unheated Teflon sample line. 8.1% conversion of NO-to-NO₂ takes place when the sample line is cold, as compared to only 1.8% when the line is heated (230°F). Therefore, the heated line is beneficial not only for reasons of preventing condensation, but also in terms of reducing unwanted conversions. Note that, as would be expected, very little total NO_x is lost within the sample line in either case.

NO_x Losses Within the Water Trap

The ability of NO₂ to absorb into water is a known phenomenon, and it is this concept that initially prompted this study into an alternative sampling system for measurements of high NO₂. Referring back to Table 3-1, the last set of data shows that 25% NO₂ loss occurs when water is present within the water trap. In order to reduce these losses, residence time in the water trap was reduced from 7 to 3 seconds by decreasing its size. Results from these tests will be discussed in Section 3.1.2. Slight NO_x losses still occurred, but never more than 5%. Further research into a better water removal method may be desired in the future.

NO₂-to-NO Conversion in the Presence of Stainless Steel,

Stainless steel is a known catalyst for the conversion of NO₂-to-NO (stainless steel is used in the TECO analyzer specifically for this conversion). Since stainless steel is often used for fittings and components within sampling systems, it was of interest to see at which temperatures these conversions occur. An experiment was performed in which NO and NO₂ gases were sent through a two foot long, heated 1/8" stainless steel tube. The temperature was increased from ambient to 500°F, and NO/NO_x measurements were taken throughout. The results are displayed in Figure 3-2. Two different runs were performed, and two different results were obtained.

The first run showed that almost all of the NO₂ present in the gas was converted to NO before the tube reached 400°F. This would indicate that care should be taken when using stainless steel at high temperatures. The second run, performed exactly like the first, demonstrated that some, but not much, of the NO₂ converted to NO. It is known that the catalytic reaction will only occur if the

TABLE 3-2. TEFLON SAMPLE LINE VALIDATION DATA.

Conditions	Direct to TECO Analyzer		Through Sample Line		Percent NO Loss	Percent NO ₂ Gain	Percent NO _x Loss
	NO, ppm	NO _x , ppm	NO, ppm	NO _x , ppm			
NO + NO ₂ (sample line is cold)	459	698	422	697	8.1%	15.1% gained	0.1%
NO + NO ₂ (sample line is hot)	452	697	444	692	1.8%	1.2% gained	0.7%

Figure 3-2. NO₂ to NO conversion with stainless steel contact.

stainless steel surface is well oxidized. It is hypothesized that the oxidation condition of the tube was inconsistent between the two runs, resulting in less conducive conditions for NO_2 -to- NO conversion during the second run.

Validation checks for the sample system will be performed while using stainless steel fittings at locations where temperatures are kept below 250°F. Figure 3-2 demonstrates that these temperatures should be safe from NO_2 -to- NO conversions.

Alternate Water Removal Systems

Since large NO_x losses occur within the current water removing device, two other methods of removing water were considered. Silica gel and a permeation dryer were tested in the validation set-up.

Silica gel is a moisture removing desiccant that is commonly used in combination with other water removal methods as a reinforcer. Since the sample flow rates entering the NO_x analyzer are so low for the new sampling system (due to carbon converter restrictions), the possibility of using silica gel to remove moisture was considered. A 3/8" Teflon tube filled with silica gel was tested in the validation set-up. Results (displayed in Table 3-3) showed that the silica gel removed all NO_2 and 29% of the NO present in the gas sample. This demonstrates that silica gel is not an appropriate water removal method for NO_x measurement systems.

The permeation dryer is a water removal device that consists of a permeable membrane through which only water is intended to pass. A counter-flow stream of dry air is used to purge the water vapor from the sample stream through the permeable membrane. The purge gas flow rate must stay greater than that of the sample gas. This will keep the partial pressure of the water within the sample stream greater than that within the purging stream, forcing the water vapor through the membrane into the purging gas.

Suspensions of measurement inaccuracies associated with the permeation dryer (similar to those discussed in Section 2.0) motivated investigation of this water removal technique. The results show that the permeation dryer normally used on site had a tendency to convert NO_2 -to- NO . Specialized

TABLE 3-3. SILICA GEL VALIDATION DATA.

Conditions	Direct to TECO Analyzer		Through Silica Gel		Percent NO Loss	Percent NO ₂ Loss	Percent NO _x Loss
	NO, ppm	NO _x , ppm	NO, ppm	NO _x , ppm			
NO + NO ₂	445	670	316	315	29.0%	100%	53.0%

permeation dryers recommended for NO_x measurements are available and should be tested for accuracy in the future.

Validation Check of Pump and Filter

Both the pump and the filter were tested to determine their effects on the NO/NO₂ composition. Table 3-4 displays the results obtained while testing the sample pump under both ambient and elevated temperatures. During sampling, the pump must be heated in order to prevent condensation. Both cases showed little effect on NO/NO_x measurements.

The influence of the filter was tested by means of comparing the results of the complete system with and without the filter on line. Results are displayed in Table 3-5. The filter proved to have no effect on the NO/NO_x measurements.

3.1.2 Validation of the Complete NO/NO_x Sampling System

The final step was to validate the complete NO/NO_x sampling system. This procedure was also performed on the validation system displayed in Figure 3-1. It should be noted that when measuring NO_x through the sampling system, the carbon converter was used for the NO₂-to-NO conversion, in lieu of the TECO's stainless steel converter (as used for the direct line measurements). Depending upon converter efficiencies, NO_x values may vary slightly between the two test lines.

It also should be noted that stainless steel fittings are used for these validation tests in locations where temperatures will remain below 250°F. A close watch for any conversions of NO₂-to-NO due to this stainless steel will be conducted.

The first tests of the complete system were performed using the large water trap that was proved inaccurate for NO/NO_x measurements. In Table 3-6, these results are compared to those obtained with the new, reduced residence time, water trap. The new water trap yielded more accurate results than the old, larger volume water trap in terms of NO-to-NO₂ conversion as well as NO₂ losses.

TABLE 3-4. PUMP VALIDATION DATA.

Conditions	Direct to TECO Analyzer		Through Pump		Percent NO Loss	Percent NO ₂ Loss	Percent NO _x Loss
	NO, ppm	NO _x , ppm	NO, ppm	NO _x , ppm			
NO + NO ₂ (cold pump)	319	556	318	549	0.3%	2.5%	1.3%
NO + NO ₂ (pump hot)	335	558	335	551	0.0%	3.1%	1.3%

TABLE 3-5. FILTER VALIDATION DATA.

Conditions	Direct to TECO Analyzer		Through Entire System		Percent NO Loss	Percent NO ₂ Gain	Percent NO _x Loss
	NO, ppm	NO _x , ppm	NO, ppm	NO _x , ppm			
NO + NO ₂ (w/o filter)	410	578	382	563	6.8%	7.7% gained	2.6%
NO + NO ₂ (w/ filter)	415	585	388	574	6.5%	9.4% gained	1.9%

* When going through system, NO_x conversions (NO₂ to NO) are made with carbon converter.
(line going directly to TECO uses TECO converter.)

TABLE 3-6. COMPLETE SYSTEM VALIDATION: LARGE CHILLER VS SMALL CHILLER.

Conditions	Direct to TECO Analyzer			Through Entire System		Percent NO Loss	Percent NO ₂ Loss	Percent NO _x Loss
	NO, ppm	NO _x , ppm	NO _x , ppm	NO, ppm	NO _x , ppm			
NO + NO ₂ (w/ large water trap, wet)	115	191		107	179	7.0%	5.3%	6.3%
NO + NO ₂ (w/ small water trap, wet)	104	258		99	252	4.8%	0.6%	2.3%

* When going through system, NO_x conversions (NO₂ to NO) are made with carbon converter.
(line going directly to TECO uses TECO converter.)

Using the new water trap and assuring all conditions to be as if actually testing (i.e., all lines heated above dew point and water present in the water trap), the complete system was ready for validation. The results are displayed in Figure 3-3. For dry NO, NO₂ and O₂ gases passing through the new sampling system, an average of 95% NO recovery was obtained. NO concentrations were varied between 104 ppm and 407 ppm; percent recovery did not appear to be dependant upon NO concentration.

The presence of stainless steel fittings within the system did not seem to initiate the catalytic NO₂-to-NO conversion. NO₂ recovery was very successful.

Effect of Water Vapor

Since the water removal step of the sample conditioning process results in large NO_x losses, it was important to validate the system with water present in the sample. Steam was generated with the use of a syringe pump and stainless steel tubing that was heated to vaporizing temperatures. 20% molar ratio of steam to simulated flue gas was injected. The results, displayed in Table 3-7, indicate that, even with water present in the system, approximately 95% NO and even higher NO_x was recovered.

Effect of NH₃

The effect of ammonia on NO_x measurements was of interest because ammonia is known to partially oxidize to NO in the presence of stainless steel at high temperatures (hence concern with the TECO's stainless steel converter which operates at 1200°F). The results of the ammonia tests are displayed in Table 3-8. When ammonia is added, 15% dilution occurs due to the ammonia carrier, N₂. The addition of 130 ppm of NH₃ into the system only seems to affect NO by means of dilution; no NH₃-to-NO conversion appears to be taking place. However, due to materials within the NO_x converters, NO_x measurements became inconsistent when high levels of ammonia were present.

Data was obtained using NO/NOx sampling system validation set-up.

Except for case #4, no water present except slight moisture inside water trap.

Figure 3-3. New NO/NOx sampling system validation results.

TABLE 3-7. EFFECT OF WATER VAPOR ON NEW SAMPLING SYSTEM.

Conditions	Direct to TECO Analyzer		Through Entire System		Percent NO Loss	Percent NO ₂ Gain	Percent NO _x Loss
	NO, ppm	NO _x , ppm	NO, ppm	NO _x , ppm			
NO + NO ₂ w/o Steam Addition	388	542	367	529	5.4%	5.2% gained	2.4%
NO + NO ₂ w/ Steam Addition	378	538	358	527	5.3%	5.6% gained	2.0%

* When going through system, NO_x conversions (NO₂ to NO) are made with carbon converter.
(line going directly to TECO uses TECO converter.)

TABLE 3-8. EFFECT OF AMMONIA ON NEW SAMPLING SYSTEM.

Conditions	Direct to TECO Analyzer		Through Entire System	
	NO, ppm	NO _x , ppm	NO, ppm	NO _x , ppm
NO + NO ₂ w/o NH ₃	363	524	350	509
NO + NO ₂ w/ 130 ppm NH ₃ (15% dilution by N ₂)	312	545	295	378

* When going through system, NO_x conversions (NO₂ to NO) are made with carbon converter.
(line going directly to TECO uses TECO converter.)

When the sample is passed directly to the TECO Analyzer, the stainless steel converter is used to convert NO_2 -to- NO for the NO_x measurements. Using this converter, the NO_x measurement was larger for the case with NH_3 present than that without NH_3 present. This suggests that a NH_3 -to- NO conversion is taking place. The stainless steel converter is not recommended for high ammonia conditions; all ammonia should be removed prior to the converter. It should be noted that the stainless steel within the sample system itself does not appear to be at a high enough temperature for a long enough residence time to encourage the NH_3 -to- NO conversion.

As the sample passes through the sampling system, the carbon converter is responsible for converting NO_2 -to- NO for the NO_x measurements. This type of converter also promotes problems in an ammonia rich environment. Total NO_x was found to decrease as the ammonia was passed through the carbon converter. In the presence of activated carbon, NO and NH_3 can reduce to molecular nitrogen; the carbon within the converter could be responsible for such a reaction. Again, it is advisable that NH_3 be scrubbed before entering the carbon converter. At conditions near optimum, Combi NO_x has produced very low ammonia slip levels, therefore these conversions should not be a problem for this project.

3.2 Accuracy Checks with Actual Flue Gas

While Combi NO_x tests were being performed on the BSF, both the standard and new sampling systems were used in parallel so that a reference was always available. Methanol injection was being performed so that high levels of NO_2 were present. The results are as follows.

Natural Gas Fired Flue Gas

The two sampling systems agreed on NO measurements throughout the methanol injection tests that were performed while burning natural gas on the BSF. NO_2 was not lost within the new sampling system as it was with the old. For the new system, total NO_x remained constant throughout the methanol injection procedure as was expected.

Since NO measurements were in agreement between the two sampling systems throughout the methanol injection, it can be concluded that the stainless steel probe on the old system had no effect on NO/NO_x measurements; i.e., no NO₂-to-NO conversions occurred. This could be because the walls of the stainless steel sample probe stay fairly cool due to the water cooling jacket, thus preventing the conversions from occurring. Another explanation could be the loss of the stainless steel oxidation that was discussed earlier. A switch back to stainless steel may be desirable (for low ammonia systems) due to its durability and ease of use as compared to the quartz probe.

Natural Gas Fired Flue Gas Doped With SO₂

SO₂ was not thought to be an interference on the NO_x sampling system until a disparity between measurements was noted during CombiNO_x's pilot scale tests. When 3000 ppm of SO₂ was doped into a natural gas fired system (performed to determine the effect of SO₂ on methanol's NO-to-NO₂ conversion), a discrepancy between the standard and new NO_x sampling systems was detected (see Figure 3-4). The two systems began disagreeing when high levels of NO₂ and SO₂ were simultaneously present. A validation test was performed to determine which sampling system was sensitive to the high levels of SO₂.

The validation test consisted of injecting 3000 ppm of SO₂ into the furnace immediately upstream of the sample probe (≈400°F) under high NO₂ conditions (NO₂ obtained with methanol injection). Injecting the SO₂ at this temperature should avoid any interferences with the methanol injection reactions, yet any sampling system interferences would be detected. NO and NO_x measurements were taken with both systems before and after injecting the SO₂. Figure 3-5 shows that the standard sampling system detected a NO interference when the SO₂ was injected. A possible explanation is the oxidation of SO₂ to SO₃ via NO₂-to-NO conversion within the ice bath water trap. The new sampling system showed little signs of interference from the SO₂, perhaps due to the small size of its water trap.

Figure 3-4. Performance of sampling systems with a SO₂ doped natural gas fired flue gas.

This test was designed to determine whether SO₂ created an interference on either of the sampling systems. Results show that 3000 ppm SO₂ creates an interference for the old system when NO₂ is present.

Figure 3-5. Effect of SO₂ on sampling systems.

Coal Fired Flue Gas

When injecting methanol into coal fired flue gas, it was expected that the old sampling system would measure lower NO conversions than the new due to the SO₂ interference discussed above. In actuality, the opposite occurred. NO conversion due to methanol injection was measured to be worse with the new sampling system than with the standard (see Figure 3-6). It was suggested that ash (or activated carbon) build-up within the filter in the new system could be converting the NO₂ back to NO, causing the new sample system to measure a lower NO conversion. For the standard sample system, the gas sample flows through the water trap before the filter, therefore all NO₂ is removed before in the sample comes in contact with the ash build-up. This eliminates the NO₂-to-NO conversion within the standard system.

This theory was tested while firing natural gas on the BSF. NO/NO_x measurements were taken with a clean filter before and after methanol injection to determine baseline values. The sample probe for the new system was then pulled out of the furnace and fed with coal ash collected from the bag-house. When a fair amount of ash was collected on the filter, the probe was returned to the furnace and NO/NO_x measurements were taken again, before and after methanol was injected. The results are displayed in Figure 3-7. It is apparent that the ash on the filter does convert NO₂-to-NO, as suspected.

To reduce the ash build-up problem, a stainless steel phase discrimination probe was used in place of the quartz probe (stainless steel was proven satisfactory for a low ammonia system). A phase discrimination probe (displayed in Figure 3-8) is designed to reduce particulate intake into a sampling system. The sample gas travels through two 180° turns before exiting the probe. In theory, only gas, no particulate, will travel through the turns. Reducing the amount of particulate build-up on the filter is intended to reduce the NO₂-to-NO conversion that occurs. While burning coal, it is suggested that the filter be cleaned (and sample lines purged with N₂) prior to any high NO₂ measurements.

Figure 3-6. Performance of sampling systems with a coal fired flue gas.

Figure 3-7. Effect of ash on NO/NO_x measurements in new sampling system.

Figure 3-8. Phase discrimination probe with water cooling jacket.

4.0 SUMMARY

Figure 4-1 displays the new NO/NO_x sampling system that was used for the remainder of the BSF tests; this system will also be used for the scale-up Reburn Tower (10 MMBtu/hr furnace) tests.

Since the stainless steel within the sampling system was found to have no effect on the NO/NO_x measurements, the recommended quartz probe was replaced with a stainless steel phase discrimination probe. This probe will reduce particulate intake into the sampling system, however a frequent filter change will still be necessary. The NO₂-to-NO converter (in this case a carbon converter) was moved external to the NO_x analyzer and prior to the water trap; this will prevent NO₂ loss when water is removed. All lines must be kept above 200°F before the converter to prevent condensation, and to ultimately prevent NO₂ losses. The sample gas must also remain below 250°F to avoid NO₂-to-NO conversion in the presence of the stainless steel fittings and probe.

This new system is recommended when high levels of NO₂ are present. The NO/NO_x sampling system used in the past is suitable when measuring low NO₂ concentrations. For both systems, any existing ammonia should be removed prior to the NO₂-to-NO converter.

Figure 4-1. Final NO/NO_x sampling system.

END

**DATE
FILMED**

9 / 4 / 92