34.8
1/8/79

HR. 2081

DOE/NASA CONTRACTOR REPORT

DOE/NASA CR-150818

LONG-TERM WEATHERING EFFECTS ON THE THERMAL PERFORMANCE
OF THE LENNOX/HONEYWELL (LIQUID) SOLAR COLLECTOR

Prepared by

Wyle Laboratories
Solar Energy Systems Division
Huntsville, Alabama

Under Subcontract with IBM Corp. , Federal Systems Div, Huntsville, Alabama 35805

Contract NAS8-32036

National Aeronautics and Space Administration
George C. Marshall Space Flight Center, Alabama 35812

For the U. S. Department of Energy

U.S. Department of Energy

MASTER

Solar Energy

DISTRIBUTION DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

1. REPORT NO. DOE/NASA CR-150818	2. GOVERNMENT ACCESSION NO.	3. RECIPIENT'S CATALOG NO.	
4. TITLE AND SUBTITLE Long-Term Weathering Effects on the Thermal Performance of the Lennox/Honeywell (Liquid) Solar Collector		5. REPORT DATE November 1978	
		6. PERFORMING ORGANIZATION CODE	
7. AUTHOR(S)		8. PERFORMING ORGANIZATION REPORT #	
9. PERFORMING ORGANIZATION NAME AND ADDRESS Wyle Laboratories Solar Energy Systems Division Huntsville, Alabama 35805		10. WORK UNIT NO.	
		11. CONTRACT OR GRANT NO. NAS8-32036	
12. SPONSORING AGENCY NAME AND ADDRESS National Aeronautics and Space Administration Washington, D. C. 20546		13. TYPE OF REPORT & PERIOD COVERED Contractor Report	
		14. SPONSORING AGENCY CODE	
15. SUPPLEMENTARY NOTES This work was done under the technical management of Mr. Charles N. Thomas, George C. Marshall Space Flight Center, Alabama.			
16. ABSTRACT <p>This report presents the test procedures used and the results obtained during the evaluation test program of the Lennox/Honeywell double covered liquid solar collector. The tests were performed under simulated conditions, following long-term exposure to natural weathering conditions.</p> <p>The Lennox/Honeywell collector is a flat-plate solar collector. The absorber plate is steel with copper tubes bonded on the upper surface, and is coated with black chrome with an absorptivity factor of .95 and emissivity factor of .12. It has a double glass cover of 1/8-inch tempered glass and weighs about 153 pounds. The overall dimensions of the collector are 3' x 6' x 6-1/2".</p> <p>For further information on the Lennox/Honeywell collector test procedures and performance evaluation, see DOE/NASA CR-150510.</p>			
17. KEY WORDS		18. DISTRIBUTION STATEMENT UC-59c Unclassified-Unlimited <i>William A. Brooksbank</i> WILLIAM A. BROOKSBANK, JR. Mgr, Solar Heating and Cooling Project Office	
19. SECURITY CLASSIF. (of this report) Uncl	20. SECURITY CLASSIF. (of this page) Uncl	21. NO. OF PAGES 12	22. PRICE NTIS

TABLE OF CONTENTS

		<u>Page No.</u>
	SUMMARY	ii
1.0	PURPOSE	1
2.0	REFERENCES	1
3.0	TEST REQUIREMENTS AND PROCEDURES	2
	3.1 Collector Thermal Efficiency Test Requirements	2
	3.2 Test Procedure	2
4.0	ANALYSIS OF RESULTS	4
	4.1 Thermal Performance Test	4
TABLE I	LENNOX/HONEYWELL COLLECTOR PERFORMANCE RECHECK AFTER LONG TERM EXPOSURE TO NATURAL WEATHERING CONDITIONS	7
TABLE II	LENNOX/HONEYWELL COLLECTOR PERFORMANCE TEST DATA BEFORE LONG TERM WEATHER EXPOSURE	8
Figure 1.	Lennox/Honeywell Collector Indoor Thermal Performance Test Results	9

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

leg

SUMMARY

Thermal performance tests were conducted on the Lennox/Honeywell double-covered liquid solar collector, following long term exposure to natural weathering conditions. The collector was mounted on the weathering test stand at the Solar Test Facility at Marshall Space Flight Center, Alabama, with exposure to the natural ambient environment. The collector was under stagnation conditions from June 1, 1977, to September 11, 1978. The collector was retested at the Marshall Space Flight Center Solar Simulator on September 13, 1978. The total weathering period was approximately fifteen and one-half months.

Visual inspection of the collector, prior to re-test, indicated slight discoloration of the absorber plate. The test results indicated that performance degradation had occurred and the lack of change in the slope of the efficiency curve, from the original data, is a direct indicator of no increase in the collector heat loss coefficient. The change in the intercept of the efficiency curve on the ordinate axis implies that the absorptivity and/or transmissivity has decreased as a result of the weathering.

1.0

PURPOSE

The purpose of this report is to present the test procedures used and the test results obtained during an evaluation test program. The test program was conducted to obtain thermal performance data on a Lennox/Honeywell double-covered liquid solar collector under simulated conditions (Reference 2.1), following long term exposure to natural weathering conditions. The tests were conducted utilizing the Marshall Space Flight Center Solar Simulator in accordance with the test procedures specified in Reference 2.2 and the test requirements of Reference 2.3.

2.0

REFERENCES

2.1	DOE/NASA-CR-150510	Indoor Test for Thermal Performance Evaluation of the Lennox/Honeywell Solar Collector
2.2	MTCP-FA-SHAC-400	Procedure for Operation of the MSFC Solar Simulator Facility
2.3	ASHRAE 93-77	Method of Testing to Determine the Thermal Performance of Solar Collectors
2.4	ASHRAE 93-P	Method of Testing Solar Collectors Based on Thermal Performance

3.0 TEST REQUIREMENTS AND PROCEDURES

3.1 Collector Thermal Efficiency Test Requirements

Thermal performance evaluation criteria shall correspond to that of Reference 2.1 with the exception that gross collector area is used according to Reference 2.3. The original data was based on the aperture area according to Reference 2.4. Reference 2.4 was superseded by Reference 2.3, which is the current standard. The original data has been modified based on this standard for comparative purposes as shown in Figure 1 and Table II. Data shall be obtained at inlet temperatures of 0, 25, 50, 75, and 100°F above the ambient temperature at a liquid flow rate of 225 lb/hr (0.45 GPM) at a solar insolation rate of 300 BTU/Hr·Ft² and a wind speed of 7.5 mph. The following data shall be recorded during the test at each test condition.

1. Ambient temperature.
2. Collector inlet liquid temperature.
3. Collector outlet liquid temperature.
4. Collector differential temperature.
5. Differential pressure across collector.
6. Liquid flow rate.
7. Insolation rate.
8. Wind speed.

3.2 Test Procedure

1. Mount test specimen on test table at a 45° angle with respect to the floor.
2. Assure that simulator lamp array is adjusted to an angle of 45° with respect to the floor.
3. Align the test table so that the test specimen's vertical centerline coincides with the vertical centerline of the lamp array and the distance from the top of the test specimen to the lens plane of the lamp array is 9 feet.
4. Insulate all pipes.
5. Assure that data acquisition system is operational.

3.0 TEST REQUIREMENTS AND PROCEDURES (Continued)

3.2 Test Procedure (Continued)

6. Start liquid flow loop and establish a flow rate of 225 Lb/Hr (0.45 GPM).
7. Establish the wind speed of 7.5 mph.
8. Power up simulator and establish a solar flux level of 300 BTU/Ft²·Hr.
9. Determine the ambient air temperature.
10. Adjust the inlet temperature of the collector to the ambient air temperature value.
11. After steady state conditions have been established, record data for a minimum of five minutes.
12. Repeat steps 9, 10, and 11, changing the liquid inlet temperature as necessary until data has been obtained for each test condition specified in Paragraph 3.1.
13. Upon completion of testing, power down simulator and liquid loop.

4.0 ANALYSIS OF RESULTS

4.1 Thermal Performance Test

The analysis of data contained in this report is in accordance with the National Bureau of Standards recommended approach. This approach is outlined below.

The efficiency of a collector is stated as:

$$\eta = \frac{q_u/A}{I} = \frac{\dot{m} C_{tf} (t_{f,e} - t_{f,i})}{I} \quad (1)$$

where:

q_u = rate of useful energy extracted from the solar collector (BTU/Hr)

A = Gross collector area (Ft²)

I = Total solar energy incident upon the plane of the solar collector per unit time per unit area (BTU/Hr·Ft²)

$\dot{m}$ = Mass flow rate of the transfer liquid through the collector per unit area of the collector (Lbm/Ft²·Hr)

C_{tf} = Specific heat of the transfer liquid (BTU/Lb·°F)

$t_{f,e}$ = Temperature of the transfer liquid leaving the collector (°F)

$t_{f,i}$ = Temperature of the transfer liquid entering the collector (°F)

Rewriting Equation (1) in terms of the total collector area yield:

$$\eta = \frac{(\dot{m}A)C_{tf} (t_{f,e} - t_{f,i})}{(IA)} = \frac{\dot{M} C_{tf} (t_{f,e} - t_{f,i})}{P_i} \quad (2)$$

Notice that:

$P_i = IA$ = Total power incident on the collector

$\dot{m}A = \dot{M}$ = Total mass flow rate through the collector

Therefore, $\dot{M} C_{tf} (t_{f,e} - t_{f,i})$ = Total power collected by the collector.

4.0

ANALYSIS AND RESULTS (Continued)

4.1

Thermal Performance Test (Continued)

Substitution in Equation (2) results in:

$$\eta = \frac{P_{abs}}{P_{inc}} \quad (3)$$

where:

P_{abs} = Total collected power

P_{inc} = Total incident power

This value of efficiency is expressed as a percentage by multiplying by 100. This expression for percent efficiency is:

$$\text{Collector Efficiency} = \frac{P_{abs}}{P_{inc}} \times 100 \quad (4)$$

or from Equation (2), collector efficiency is defined by the equation:

$$\% \text{ Eff} = \frac{\dot{M} C_{tf} (t_{f,e} - t_{f,i})}{P_{inc}} \times 100 \quad (5)$$

Each term in Equation (5) was measured and recorded independently during the test.

The mean value of efficiency was determined over a five-minute period during which the test conditions remained in a quasi-steady state. Each five-minute period constitutes one "data point" as is graphically depicted on a plot of percent efficiency versus

$$\left((t_i - t_a)/I \right)$$

where:

t_i = Liquid inlet temperature ($^{\circ}\text{F}$)

t_a = Ambient temperature ($^{\circ}\text{F}$)

I = Incident flux per unit area ($\text{BTU}/\text{Hr} \cdot \text{Ft}^2$)

The abscissa term $\left((t_i - t_a)/I \right)$ was used to normalize the effect of operating at different values of I , t_i and t_a . The results are shown graphically in Figure 1 with the supporting test data given in Table I. An update of the original efficiency data is shown in Table II, based on the gross collector area.

4.0 ANALYSIS AND RESULTS (Continued)

4.1 Thermal Performance Test (Continued)

Reference 2.3 uses the following terms relating to the thermal efficiency graph:

$F_R \alpha \tau$ = intercept of the efficiency curve on the ordinate axis

$F_R U_L$ = the negative of the slope of the efficiency curve

F_R = the solar heat removal factor

α = absorptance of the collector surface for solar radiation

τ = transmittance of the solar collector cover plate

U_L = solar collector heat transfer loss coefficient

A comparison of the before and after weathering efficiency curves indicates that the slope, $F_R U_L$, did not change noticeably; however, the value of $F_R \alpha \tau$ did change significantly. With no noticeable change in the transmissivity of the cover plates, the conclusion would be that the absorptivity has degraded as a result of the weathering.

TABLE I

LENNOX/HONEYWELL COLLECTOR PERFORMANCE RECHECK
 AFTER LONG TERM EXPOSURE TO NATURAL WEATHERING CONDITIONS
 7.5 MPH WIND

Ambient Air Temperature (T_a), °F	81.4	81.2	81.0	78.4	79.7
Fluid Inlet Temperature (T_i), °F	86.7	107.1	132.7	150.5	184.2
Fluid Outlet Temperature (T_e), °F	100.5	119.9	144.5	161.3	193.8
Differential Fluid Temperature (ΔT), °F	13.8	12.8	11.8	10.8	9.6
Total Solar Flux (I), BTU/Hr·Ft ²	295.4	295.4	295.4	299.1	299.1
Flow Rate, GPM	.472	.470	.464	.463	.472
$(T_i - T_a)/I$ °F·Hr·Ft ² /BTU	.018	.088	.175	.241	.349
Efficiency (η), %	61.1	56.7	51.2	45.9	41.2
Specific Gravity	.997	.993	.985	.981	.970

TABLE II

LENNOX/HONEYWELL COLLECTOR PERFORMANCE TEST DATA
BEFORE LONG TERM WEATHER EXPOSURE
10 MPH WIND

Collector Side °F	97.5	100.1	99.5	101.4	101.5	94.3	101.6	101.0	100.6
Collector Back °F	80.2	85.2	86.9	88.9	90.2	87.6	90.2	94.4	94.4
Outer Cover °F	91.0	94.0	95.0	95.8	97.2	92.0	96.7	98.1	98.7
Surface - North °F	121.4	138.0	144.3	156.0	161.7	179.0	188.0	224.6	231.5
Surface - Center °F	116.6	133.2	138.9	151.2	156.3	175.1	183.0	220.8	227.2
Surface - East °F	116.3	132.5	137.9	150.0	154.9	172.9	181.1	217.4	223.6
Surface - South °F	109.5	125.8	131.8	145.6	150.1	170.8	177.6	217.2	222.8
Ambient °F	79.7	81.4	82.4	83.0	84.4	78.7	79.5	80.7	80.9
T _{in} °F	81.3	99.5	99.7	119.5	119.4	149.7	149.6	199.6	199.8
T _{out} °F	98.1	115.7	118.7	134.6	137.3	161.1	165.1	208.6	211.5
ΔT °F	16.8	16.2	19.0	15.1	17.9	11.4	15.5	9.0	11.7
Flow Rate Lb/Hr	224.8	225.1	224.3	225.6	223.5	224.2	224.3	226.1	224.4
Flux BTU/Hr·Ft ²	255.4	255.0	297.9	255.0	297.6	243.6	297.0	243.6	283.0
Efficiency %	64.5	64.2	64.1	61.2	61.5	48.7	54.7	39.2	43.2
(T _i -T _a) / I °F·Hr·Ft ² /BTU	.006	.071	.058	.143	.118	.291	.236	.488	.420

Figure 1. Lennox/Honeywell Collector Indoor Thermal Performance Test Results