190
10-5-78

10 572

MASTER

MASTER

SAND78-1315
Unlimited Release
UC-32

User's Manual for Computer Code SOLTES-1 (Simulator of Large Thermal Energy Systems)

Merton E. Fewell, Norman R. Grandjean, James C. Dunn, Michael W. Edenburn

Prepared by Sandia Laboratories, Albuquerque, New Mexico 87185
and Livermore, California 94550 for the United States Department
of Energy under Contract AT(29-1)-789

Printed September 1978

Sandia Laboratories

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

Issued by Sandia Laboratories, operated for the United States
Department of Energy by Sandia Corporation.

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

Printed in the United States of America

Available from
National Technical Information Service
U. S. Department of Commerce
5285 Port Royal Road
Springfield, VA 22161

Price: Printed Copy \$10.75; Microfiche \$3.00

USER'S MANUAL FOR COMPUTER CODE SOLTES-1
(Simulator of Large Thermal Energy Systems)

Volume I
Edition 1

Merton E. Fewell
Fluid Mechanics and Heat Transfer Division II, 5512

Norman R. Grandjean
Dispersed Power Applications Division 4722

James C. Dunn
Fluid Mechanics and Heat Transfer Division II, 5512

Michael W. Edenburn
Systems Analysis Division 4716

Sandia Laboratories
Albuquerque, NM 87185

ABSTRACT

SOLTES simulates the steady-state response of thermal energy systems to time-varying data such as weather and loads. Thermal energy system models of both simple and complex systems can easily be modularly constructed from a library of routines. These routines mathematically model solar collectors, pumps, switches, thermal energy storage, thermal boilers, auxiliary boilers, heat exchangers, extraction turbines, extraction turbine/generators, condensers, regenerative heaters, air conditioners, heating and cooling of buildings, process vapor, etc; SOLTES also allows user-supplied routines. The analyst need only specify fluid names to obtain readout of property data for heat-transfer fluids and constants that characterize power-cycle working fluids from a fluid property data bank. A load management capability allows SOLTES to simulate total energy systems that simultaneously follow heat and power loads and demands. Generalized energy accounting is available and values for system performance parameters may be automatically determined by SOLTES. Because of its modularity and flexibility, SOLTES can be used to simulate a wide variety of thermal energy systems such as solar power/total energy, fossil-fired power plants/total energy, nuclear-fired power plants/total energy, solar energy heating and cooling, geothermal energy, and solar hot-water.

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

ACKNOWLEDGMENTS

The authors wish to acknowledge J. F. Banas of Div. 4722 for his continuing support of this project. We would also like to acknowledge R.H. Nilson of Div. 5512 for his contributions through technical discussions and comments.

CONTENTS

	<u>Page</u>
1. Introduction	1-1
1.1 Background	1-1
1.2 Philosophy	1-2
1.2.1 Quasi-Transient Method	1-2
1.2.2 Modularity and Routines Library	1-2
1.2.3 Steady-State Algorithm	1-4
1.2.4 Output	1-5
1.2.5 Executive Routine	1-5
1.2.6 Energy Accounting	1-5
1.2.7 Fluid Property Data	1-8
1.2.8 Unit System and Time	1-8
2. SOLTES Input	2-1
2.1 Component/Information Routine Data (TAPE 1)	2-1
2.2 Executive Routine Control Data (TAPE 6)	2-1
2.2.1 Discussion	2-1
2.2.2 Format	2-2
2.3 Loop Definition Data (TAPE 8)	2-6
2.3.1 Discussion	2-6
2.3.2 Format	2-7
2.4 Fluid Property Data (TAPE 9)	2-8
2.4.1 Discussion	2-8
2.4.2 Format	2-9
2.5 Weather Data (TAPE 12)	2-11
2.5.1 Discussion	2-11
2.5.2 Format	2-11
2.6 Time-Varying Load Data (TAPE 11)	2-12
2.6.1 Discussion	2-12
2.6.2 Format	2-12
3. Model Construction	3-1
3.1 Discussion	3-1
3.2 Procedure	3-2
4. Conclusion	4-1
5. Reference	5-1
APPENDIX A -- The Preprocessor (PRESOL)	A-1
APPENDIX B -- Generalized Rankine-Type Power Conversion Cycles	B-1
APPENDIX C -- Routine Library Index	C-1
APPENDIX D -- SOLTES Examples	D-1

ILLUSTRATIONS

<u>Figure</u>		<u>Page</u>
1	Routine Categories	1-3
2	Open Component Types	3-1
B1	A Typical Complex Rankine-Type Power Cycle	B-2
D1	System Model Schematic for a Solar, Open Hot-Water System for a Residence	D-1
D2	System Model Schematic for a Solar Total-Energy System	D-11
D3	Electrical Loads for a Typical Day During the Simulation Period	D-12

TABLES

<u>Table</u>		<u>Page</u>
I	Power-Cycle Fluid Constants	2-9
II	Goldhammer's Constant	2-9
III	Thermal Energy System - Environment Energy Transfer Categories	3-3
IV	System Internal Energy Transfer	3-4

MAILBACK SHEET

I would like to receive any new information regarding SOLTES, and all
change pages for this document (SAND78-1315).

(please print or type)

LAST NAME **FIRST NAME** **MIDDLE INITIAL**

COMPANY NAME

STREET ADDRESS OR P.O. BOX NUMBER

CITY **STATE** **ZIP CODE**

Fold, staple, and mail. (No stamp needed if mailed in the United States.)

CUT OR TEAR ALONG DASHED LINE

**FIRST CLASS
PERMIT NO. 676
ALBUQUERQUE
NEW MEXICO**

BUSINESS REPLY MAIL
NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

POSTAGE WILL BE PAID BY

**N. R. Grandjean
Division 5722
Sandia Laboratories
Albuquerque, NM 87185**

USER'S MANUAL FOR COMPUTER CODE SOLTES-1 (Simulator of Large Thermal Energy Systems)

1. Introduction

1.1 Background

The 1973 energy crisis reminded us that fossil-fuel reserves are finite, and that we must therefore use our energy resources more prudently. Identifying potential alternate energy sources such as solar, wind, nuclear fusion and fission, and geothermal is easy. Developing energy-efficient systems to use these alternate sources and to conserve fossil fuel, however, is difficult.

Since we can no longer waste the energy rejected from conventional power plants, the co-generation of power and process heat from these plants should be matched with both power and process heat loads. We must determine the design and feasibility of small solar systems that provide hot water, heating, and cooling for residences and small businesses. Also, we need to investigate larger solar total-energy systems that can provide power and process heat for industrial and agricultural applications. Design options for these solar systems (such as collector type, thermal storage, load-following techniques, heat-transfer fluids, power-cycle working fluids, power cycles, etc) are seemingly endless. Moreover, point design studies cannot adequately predict the effects of time-varying weather and loads. Therefore, the task of choosing proper combinations of these options for each application and location would be overwhelming without computer simulation.

Computer codes for simulating solar energy systems have been written. TRNSYS,¹ a computer program that simulates solar hot water and heating-and-cooling systems, and SOLSYS,² a computer code for simulating solar energy systems that may include simple Rankine-power cycles, have been widely used. Since many studies require simulation of complex power cycles as well as process heat, heating, and cooling, a more general modular computer simulation code is needed. Such a code, SOLTES (Simulator of Large Thermal Energy Systems), has been developed at Sandia Laboratories, Albuquerque, NM and is currently available on a CDC6600 system. Some of the SOLSYS logic and mathematical models are used in SOLTES. The greater capabilities of SOLTES, including the addition of load management, energy accounting, and a preprocessor, make SOLTES much more flexible and usable.

Because of its modularity and flexibility, SOLTES can be used to simulate a wide variety of thermal-energy systems such as

Solar Power/Total Energy
Fossil-Fired Power Plants/Total Energy
Nuclear-Fired Power Plants/Total Energy
Solar Energy Heating and Cooling
Geothermal Energy
Solar Hot Water

1.2 Philosophy

This section acquaints users with SOLTES philosophy. This material is not essential in learning to execute the code; however, it provides information that will be useful in model construction and in interpreting SOLTES results. Subsequent sections and appendices of this manual include instructions and examples.

1.2.1 Quasi-Transient Method -- SOLTES simulates the time-varying performance of thermal-energy systems by a quasi-transient method, which assumes that the transient performance of the system can be predicted by steady-state calculations at successive time intervals. Simulation or problem time is specified by user input. The steady-state response of the system to the values of time-varying weather and load data at the start of the simulation period is calculated. Time is then advanced by a user-supplied, constant time interval; new values for the weather and load data are obtained; and a new steady-state response is calculated.

This procedure is repeated until time exceeds the end of the simulation period, whereupon a steady-state solution is not sought and the time-marching algorithm is ended. The accuracy of the quasi-transient method is improved by choosing a time interval small enough so that large variations in loads and weather data do not occur during the interval. Since many calculations are omitted at times during simulation when the energy system is operating at steady-state, the increase in computer time associated with small time steps is minimized.

1.2.2 Modularity and Routines Library -- Because of its flexibility, SOLTES can be used to model small thermal-energy systems such as residential hot-water systems or large thermal-energy systems that include complex power-generation cycles.* This flexibility is achieved by the selection of appropriate routines from a routine library. This library contains routines that mathematically model solar collectors, pumps, switches, thermal-energy storage, thermal boilers, auxiliary boilers, heat exchangers, extraction turbines, extraction turbine/generators, condensers, regenerative heaters, air-conditioners, heating and cooling of buildings, process vapor, etc. Thus the analyst can construct a system model that simulates his thermal-energy system. SOLTES also allows user-supplied routines.

*Simulation of generalized Rankine-type power cycles with load management is discussed in Appendix B.

Figure 1 shows the general categories of the routines used in system model construction.

¹Working fluids flow across the boundaries of devices modeled by open components.

²Working fluids do not flow across the boundaries of devices modeled by closed components.

Figure 1. Routine Categories

Information routines supply time-varying load and weather data to the system model. System performance routines calculate system performance parameters such as system efficiency and also assist in energy accounting and summing.

Open thermodynamic models are mathematical models of components in thermal-energy systems across the boundaries of which system working fluids flow. Each component routine is a "black box" or control volume in which changes in the thermodynamic states and flow rates of fluids flowing through it are calculated. These models satisfy the first and second laws of thermodynamics, conserve mass, and may include fluid mechanics and heat-transfer effects. In addition to energy convected across its boundaries by fluids flowing across them, energy can cross the boundaries by radiation or conduction, or may be convected to or from the boundaries by the flow of an external fluid or by shaft work and/or electricity.

Open control routines allow the analyst to switch fluid flows from one branch to another and to control such variables as flow rates and temperatures. Unlike open thermodynamic models, these routines do not allow energy to cross their boundaries other than that convected across by fluids flowing through them and do not consider heat-transfer effects. Hence, the laws of thermodynamics are automatically satisfied; the control routines may only consider steady-state conservation of mass and fluid mechanics effects.

Closed thermodynamic models are mathematical models of components in thermal-energy systems across the boundaries of which system working fluids do not flow. These models satisfy the first and second laws of thermodynamics, conserve mass, and may include fluid mechanics and heat-transfer effects. Energy can cross the boundaries by radiation or conduction or may be convected to or from the boundaries by the flow of an external fluid or by shaft work and/or electricity.

Closed control routines send signals to other components in the thermal-energy system model.

A set of unique numbers is specified by the user to identify all the state points and components in a system model. Values for the pressure, temperature, quality and fluid-flow rate at each of these state points, and energy flow rates between components, are calculated and stored.

1.2.3 Steady-State Algorithm -- The steady-state algorithm is initiated by calling the information routines (which the analyst has included in his system model) to obtain values for the time-varying data at the time corresponding to the beginning of the time step. Then the component and system performance routines are called in the order in which they occur in the system model. New values of pressure, temperature, quality, and flow rate are calculated for each state point and stored. The call sequence to the routines is repeated; current and old values of temperature, pressure, fluid flow rate, and quality are compared.

This procedure is repeated until convergence. The user defines convergence by specifying values for steady-state convergence error criteria for fluid flow rate, temperature, pressure, and quality. The iteration is considered to have converged to steady state when the convergence criteria for fluid flow rate, temperature, pressure, and quality are satisfied. The convergence criterion for fluid flow rate, temperature, and pressure is the weaker of the user-supplied absolute and relative convergence criteria for the respective variables, while the convergence criterion for quality is the user-supplied value for the absolute error.

If convergence is not achieved in a user-specified number of iterations, a diagnostic "UNABLE TO CONVERGE EXIT WILL BE CALLED" is printed and a user-supplied number of additional iterations are made before the run is terminated. After each additional iteration, the thermodynamic state and the values for pressure, temperature, fluid flow rate, and quality at each state point in the model are printed. (The printout for the thermodynamic state and the values of pressure, temperature, fluid flow rate, and quality is henceforth referred to as TABLE 1 output.) During the last of these iterations, diagnostics denoting unreasonable conditions in each routine are printed.

Upon reaching steady state, the values of pressure, temperature, fluid flow rate, and quality at each state point are checked for negative values. If a negative value is discovered, the diagnostic "ERROR ERROR ERROR CONVERGENCE WAS REACHED BUT THERE ARE NEGATIVE VALUES. CHECK THE FOLLOWING TABLE 1 DUMP PROGRAM STOP" is printed, followed by TABLE 1 output. Another call sequence to the routines is then made to calculate values for other output variables, check for unreasonable steady-state conditions in each routine, and allow the system performance routines to do energy accounting and summing. If an unreasonable steady state is reached, the program is stopped. Otherwise, the steady-state algorithm for the next time is initiated.

1.2.4 Output -- SOLTES has generalized output capability. The user-controlled output consists of several sets of information. One of these, TABLE 1, has already been discussed. The remaining user-controlled output data sets are component/information-routine input and initial conditions, component/information-routine output, system performance, and postprocessor output.

1.2.5 Executive Routine -- The main SOLTES program is referred to as the "executive routine." The executive routine manages quasi-transient solutions; controls output; and executes the steady-state algorithm by making calls to information, component, and system performance routines. Component routines may be used several times in a system model; however, information and system performance routines may be used only once. The executive routine's ability to direct calls enables the user to simulate several systems consecutively during a single computer run.

The flexibility to simulate many different thermal-energy systems can be achieved by including calls to every routine in the library, but this results in excessive computer core storage. To minimize core requirements, the user can either modify the executive routine to include calls only to those routines required by his system model, or he can use the preprocessor PRESOL (see Appendix A).

1.2.6 Energy Accounting -- Proper energy accounting is essential to evaluate and compare energy systems performance. Energy accounting includes the ability to make calculations of system efficiency, segregate energy from its primary and auxiliary sources, and sum energy by category (see Subroutine ENGAC1 in Appendix C). Energy accounting in SOLTES distinguishes among the following definitions of energy transfer rates:

An energy supply rate is the rate at which energy is transferred to the thermal-energy system model from an external energy source. SOLTES considers both primary and auxiliary sources.

A load is the rate at which useful energy (excluding sources) crosses the boundaries of the thermal-energy system model. Useful energy is energy that benefits the system's environment; i. e. energy for cooling, heating, electrical power, etc. Energy exchanges between components in a system model are not loads. Loads or load information as a function of time may be read from a data file, or loads can be calculated by component routines in the thermal-energy model. SOLTES considers heating, cooling, hot-water, electrical power, mechanical power, and thermal loads. A characteristic temperature is associated with each thermal load. Cooling loads are the rate at which energy is added to the system, whereas all the other loads are energy rates leaving the system.

A demand is the rate at which energy (excluding that convected across component boundaries by fluids flowing through the components) is required for steady-state operation of a component that provides a benefit in the system or the system's environment. A demand can cross system boundaries. SOLTES considers heating, cooling, electrical power, and mechanical power demands. Cooling demands are positive in components calculating the demand and negative in those satisfying the demand. The other demands are positive in components demanding the energy and negative in those meeting those demands.

A parasitic is the rate at which energy must be transferred by electrical or mechanical work to a component. The component provides no benefit but is necessary for system operation. SOLTES distinguishes between electrical and mechanical parasitics. Parasitics are positive for components requiring energy and negative in those supplying the energy to satisfy the parasitic.

A heat loss is the rate at which energy is lost from a system component that is space-heated.

An advective loss is the rate at which energy is lost from the system by working fluids leaving the system. Energy added to the system by working fluids entering the system (an advective gain) is a negative advective loss.

A thermal loss is the rate (excluding heat and advective losses) at which energy is lost from the thermal-energy system.

A heat gain is the rate at which energy is gained (excluding energy gained from equipment, people, etc) by a component that is air-conditioned.

Heat is the rate (excluding those rates defined above) at which energy is transferred as heat into components in the system. This energy may be calculated by components in the system or read from a data file, and transferred across system boundaries or between components in the system.

Storage rate is the rate at which energy is stored within a component in the system. The rate is positive when energy is added to the component.

A particular component may have no energy transferred across its boundaries, or it may have energy transferred across its boundaries by various combinations of the above categories.

The following examples may clarify the relationships among these various energy-transfer rates.

Example 1

An analyst needs to simulate a solar total-energy system that is to provide electricity for lighting and cooling via a vapor-compression chiller for a new apartment complex. The electrical power required for lighting is known as a function of time, but cooling requirements are unknown. The system model includes the necessary routines for collectors, pumps, boilers, turbines, air conditioners, etc, for the system, including a routine for heating and cooling buildings. Since the electricity required for lighting is known, an information routine reads this information as an electrical load from data files. The routine for heating and cooling buildings calculates the energy-transfer rate required to cool the building, a heat gain, plus heat transferred from equipment in the building. This rate is passed to an air-conditioner component routine as a cooling demand on the air-conditioner. A vapor-compression air-conditioner component calculates the electrical or mechanical power required to meet the cooling demand. These electrical or mechanical requirements for cooling are electrical or mechanical demands that may be met by another component--a turbine, for instance--in the system model, or by electrical or mechanical energy transferred across the system boundaries. If the energy that must leave the condenser of the vapor-compression chiller is transferred to the ambient air outside the building, this energy transfer rate is heat transferred from the system model. Energy lost from the solar collectors is a thermal loss, and the power required to run each pump in the system is either an electrical or mechanical parasitic. On the other hand, if the vapor-compression condenser is cooled by a heat-transfer fluid flowing through it and this energy is ultimately stored in thermal storage, there is no heat transferred from the air-conditioner model. There is, however, a storage rate in the thermal-energy storage model.

Example 2

A system similar to that of Example 1 is to be designed for an existing building. Both the electricity required for lighting and the rate at which energy must be extracted from the building for cooling are known functions of time. In this case, the system model need not include the heating and cooling routine, and the energy extraction rate from the building is a cooling load on the air-conditioners. This cooling load is supplied to the air-conditioner component model by an information routine that reads from a data file.

Example 3

The existing vapor-compression chiller in the system in Example 2 had been monitored so that the electrical requirements for air-conditioning are known as a function of time. The system model need not include an air-conditioner model. Electrical requirements are supplied to the system model as electrical loads that are read by an information routine from a data file.

Example 4

The power required to run each collector pump and each boiler-feed pump in a solar irrigation system is either an electrical or mechanical parasitic; but since the power required to run the irrigation pump provides a useful function other than continuous system operation, this power is either an electrical or mechanical load, or an electrical or mechanical demand.

1.2.7 Fluid Property Data -- Component routines, which model components in Rankine-type power cycles, require only constants to characterize the working fluid. These constants and the properties of heat-transfer fluids, as functions of temperature, are stored and retrieved from a fluid property data file by fluid name. Thus only the fluid name is required as SOLTES input.

1.2.8 Unit System and Time -- Although almost half of SOLTES is written to allow the user to define the unit system, SOLTES currently uses only the International (SI) system of units.

Since SOLTES time is the local standard time at the energy system site, load and weather data must therefore be supplied to SOLTES in local standard time. Also, the first day of the year is assumed to be Sunday. The SOLTES clock is a 24-hour clock with hour zero denoting midnight.

2. SOLTES Input

Four categories of input are essential to make a SOLTES run. Depending on the system model and the options chosen, there may be two additional categories of input. The following list contains the categories and their associated file names.

Component/Information Routine Data (TAPE 1)

Executive Routine Control Data (TAPE 6)

Loop Definition Data (TAPE 8)

Fluid Property Data (TAPE 9)

Weather Data (TAPE 12) - optional

Load Data (TAPE 11) - optional

This section describes the general format associated with each category. A preprocessor PRESOL has been written to aid the user in constructing the first four categories of input (see Appendix A). To aid the user in the relationship between a system model and the required input to SOLTES, examples are furnished in Appendix D.

2.1 Component/Information Routine Data (TAPE 1)

This file contains the input required by individual information, component, and system performance routines. Actual data requirements and formats for each routine are contained in Appendix C. The general format of this file is a series of card-image records^{*} followed by an end-of-file (EOF)^{**},^{***} record for each routine in the system model. If more than one system model is to be run, a double EOF separates the system models.

2.2 Executive Routine Control Data (TAPE 6)

2.2.1 Discussion -- This file contains the executive routine input data that define the simulation period, time increment, desired output, steady-state convergence, and problem identification.

SOLTES uses the following names as identifiers for executive routine control data:

ID, TIME, PRINT, PRNTCON, WRITE, CONVER, and RUN

ID (Optional) -- The ID card is used to supply the simulation with a descriptive name that appears on the printed output. If this card is not used, no descriptive name will be printed. After the ID card, up to four additional cards are permitted.

TIME -- The TIME card specifies the simulation period and the constant time increment.

^{*}"Cards" and "records" are words used interchangeably in this report. Also, the words "characters" and "columns" are interchangeable.

^{**}An EOF record for batch is a card with a 7/8/9 punch in Column 1.

^{***}An EOF record for NOS is a record containing only a keyboard RETURN character.

PRINT -- PRINT cards specify the tables that are to be printed, the time interval for printing, and the frequency within the interval in which the tables are to be printed. If the interval is omitted, printing occurs during the entire simulation period. If the frequency is omitted, printing occurs at each time step within the interval. Four tables may be printed: TABLES 1, 2, 3, and DUMP. TABLE 1 contains the values for temperature, pressure, fluid flow rate, quality (if applicable), and thermodynamic state at each state point. TABLE 2 contains values for selected parameters defined by each component and information subroutine. TABLE 3 contains system performance data. DUMP is TABLE 1 output that is printed after every iteration within a user-selected time interval.

PRINTCON (Optional) -- A summary of input data will be printed unless it is suppressed using the PRINTCON card.

WRITE -- The WRITE card enables the user to write values for selected parameters which are defined by each routine and written to TAPE 40 for post-plotting or printing.

CONVER (Optional) -- The CONVER card contains convergence criteria data, the number of maximum iterations permitted per time step, and the number of iterations with TABLE 1 output if convergence fails. The use of this card allows changes to one or more of the program default value parameters.

RUN -- The RUN card marks the end of the executive routine control data and directs the executive program to execute the system simulation.

NOTE: If two or more system models are to be run, the user does not need to repeat all of the executive routine control information. SOLTES uses previously defined data unless changed by new information. The RUN card is the only exception--there must be one RUN card for every system model.

2.2.2 Format -- The following formats define each of the executive routine control cards.

ID -- The ID card gives the simulation a name and may contain up to five data cards. The word "LAST" must appear in Columns 71 to 74 of the last data card.

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
"ID"	A2	1-2	Card identifier
Name	A380	11 of first card to 70 of last card	Any desired name or description
"LAST"	A4	71-74 of last card	

TIME -- The TIME card specifies start time, end time, and time step (in local standard time).

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
"TIME"	A4	1-4	Card identifier
NYEARI	I5	11-15	Initial year
NDAYI	I5	16-20	Initial day
NHRI	I5	21-25	Initial hour
NSECI	I5	26-30	Initial second
NYEARF	I5	31-35	Final year
NDAYF	I5	36-40	Final day
NHRF	I5	41-45	Final hour
NSECF	I5	46-50	Final second
ITIME	I10	51-60	Time step size (s)
"LAST"	A4	71-74	

PRINT -- If printouts of DUMP, TABLE 1, TABLE 2, or TABLE 3 are desired, print cards for these tables must be included in the data deck.

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
"PRINT"	A5	1-5	Card identification
NAME	A10	11-20	Table name, DUMP, TABLE1, TABLE2, or TABLE3 (left-justified)
NYI	I5	21-25	Starting year
NDI	I5	26-30	Starting day
NHI	I5	31-35	Starting hour
NSI	I5	36-40	Starting second
NYF	I5	41-45	Final year
NDF	I5	46-50	Final day
NHF	I5	51-55	Final hour
NSF	I5	56-60	Final second
NT	I5	61-65	Print every NT time steps (not used for DUMP)
IT	I5	66-70	0=> print 1=> don't print
"LAST"	A4	71-74	

PRNTCON -- The PRNTCON card is used to suppress printing tables containing input parameter summaries.

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
"PRNTCON"	A7	1-7	Card identification
IFLAG	I10	11-20	-1 to suppress input printout
"LAST"	A4	71-74	

WRITE -- The WRITE card instructs the program to store values for parameters for future printing and/or plotting by user-written postprocessors. The file or tape written on is TAPE 40.

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
"WRITE"	A4	1-4	Card identifier
NAME	A10	11-20	Descriptive name attached to plot variables (left-justified)
NYI	I5	21-25	Initial year
NDI	I5	26-30	Initial day
NHI	I5	31-35	Initial hour
NSI	I5	36-40	Initial second
NYF	I5	41-45	Final year
NDF	I5	46-50	Final day
NHF	I5	51-55	Final hour
NSF	I5	56-60	Final second
NT	I5	61-65	Plot variables recorded every NT time steps
IP	I5	66-70	1⇒ suppresses plotting 0⇒ allows plotting -1⇒ special option for storing data on a tape contains information from <u>previous</u> runs
"LAST"	A4	71-74	

TAPE 40 Format as Generated by SOLTES

Card 1

ID , NV
Format (A10 , I10)

Card 2

IDVAR_i i = 1, NV
Format (8A10)

Card 3

Data _{ij} i = 1, NV j = 1
Format (8E10.4)

Card 4

Data _{ij} i = 1, NV j = 2
.
.
.
.

These data records are repeated throughout the time interval as specified by the WRITE card.

Following the last data record, SOLTES writes an EOF.

When the SOLTES run is completed, an additional EOF is written.

- NOTES: 1. The ID on Card 1 is the user-supplied ID found on the WRITE card.
(It is suggested that unique ID's are given for each system model in a SOLTES run.)
2. NV is automatically calculated for each system model.
3. IDVAR_i are the variable names.
4. j = 1 corresponds to the initial time as specified on the WRITE card.
Each data record thereafter corresponds to the increment as specified by the parameter NT on the WRITE card.

CONVER -- This card can be omitted entirely, resulting in all parameters taking default values as specified.

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Descriptions</u>
"CONVER"	A6	1-6	Card identifier
EAT	F5.0	11-15	Absolute error - temperature Blank => default value of 0.1 K
ERT	F5.0	16-20	Relative error - temperature Blank => default value of 0.01%
EAF	F5.0	21-25	Absolute error - fluid flow rate Blank => default value of 0.05 kg/s
ERF	F5.0	26-30	Relative error - fluid flow rate Blank => default value of 0.01%
EAP	F5.0	31-35	Absolute error - pressure Blank => default value of 0.1 Pa
ERP	F5.0	36-40	Relative error - pressure Blank => default value of 0.01%
EAQ	F5.0	41-45	Absolute error - quality Blank => default value of 0.005
MAXIT	I5	46-50	Maximum number of iterations allowed in seeking steady-state convergence Blank => default value of 50
EXTIT	I5	51-55	Number of iterations after failure of steady-state convergence. With TABLE 1 printout after each iteration Blank => default value of 10
"LAST"	A4	71-74	

RUN -- The RUN card tells the executive program that system definition is complete and that the call sequence can be started.

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
"RUN"	A3	1-3	Card identifier
"LAST"	A4	71-74	

An EOF must follow the last RUN card in the executive routine data file.

2.3 Loop Definition Data (TAPE 8)

2.3.1 Discussion -- This file contains the data required to define the fluid loops in each system model. Each loop must be defined by specifying the fluid name; a unique loop integer between 1 and 10; initial values for temperature, pressure, and fluid flow rate; and a set of unique integers that contain all the component and state numbers within the loop.

The initial values for temperature, pressure, and fluid flow rate for each loop should be good estimates for the values at the inlet state point for the first component called in the loop. This is not a stringent requirement but will expedite steady-state convergence.

Each loop may contain several records of data. There must be an EOF card following the last record for the loop. After the last loop has been defined (including its EOF), there must be an additional EOF card. These data must be repeated if additional system models are to be run.

2.3.2 Format

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
Name	A10	1-10	Fluid name (must correspond to a name on TAPE 9 input)
Number	I5	11-15	Unique loop integer between 1 and 10
T ₀	F10.4	16-25	Initial temperature (K)
P ₀	E12.5	26-37	Initial pressure (Pa)
F ₀	E12.5	38-49	Initial mass flow rate (kg/s)
N ₁	I5	50-54	Component and state numbers in loop.
N ₂	I5	55-59	
N ₃	I5	60-64	
N ₄	I5	65-69	
<u>Card 2</u>			
N ₅	I5	1-5	Additional component and state numbers in loop.
N ₆	I5	6-10	
⋮	⋮	⋮	
⋮	⋮	⋮	
N20	I5	76-80	

Card 2 may be omitted or repeated as many times as needed in specifying the component and state numbers in the loop.

Card 3 (EOF)

Cards 1, 2, and 3 must be repeated for each fluid loop in the system model. After the last loop has been defined, an additional EOF card must be specified.

2.4 Fluid Property Data (TAPE 9)

2.4.1 Discussion -- This file contains the constants used to calculate heat-transfer fluid properties as a function of temperature, and the constants that characterize power-cycle working fluids.

Calculations of the heat-transfer fluid properties--density (ρ), specific heat (c), kinematic viscosity (ν), and thermal conductivity (k)--are based on polynomial fits of measured data.

Density, specific heat, and thermal conductivity are expressed by a power series in absolute temperature as

$$(\rho, c, k) = C_0 + C_1 T + C_2 T^2 + C_3 T^3 + C_4 T^4 + C_5 T^5 ,$$

while kinematic viscosity is expressed by a power series in reciprocal temperature as

$$\nu = C_0 + C_1/T + C_2/T^2 + C_3/T^3 + C_4/T^4 + C_5/T^5 .$$

In all cases the series coefficients are obtained from available data by a least-squares procedure.

The temperature range for which each property correlation is valid is defined by a low- and high-temperature limit. Property data calculated outside this range are unreliable.

The temperature range for each property is divided into two subranges by an intermediate temperature. Power series coefficients must be supplied for each of these subranges. Therefore, 12 coefficients ($C_{01} - C_{52}$), and 3 temperatures (T_L, T_I, T_H) must be provided for each property in the following order: ρ, c, ν, k .

The constants in Table I characterize each power-cycle working fluid. The first 13 constants may be found for some 200 fluids in Appendix A, of Reid and Sherwood.³ Values for the other constant, Goldhammer's constant, may be obtained from Table II.

TABLE I
Power-Cycle Fluid Constants

<u>Parameters</u>	<u>Description</u>
MOLWT	Molecular weight
TB	Normal boiling point (K)
TC	Critical temperature (K)
PC	Critical pressure (atm)
VC	Critical volume (cm ³ /g-mol)
OMEGA	Pitzer's acentric factor
LIQDEN	Liquid density at TDEN (g/cm ³)
TDEN	Reference temperature for LIQDEN (K)
CPVAPA, CPVAPB, CPVAPC, CPVAPD	Constants in ideal-gas heat-capacity equation, with CP in calories per gram-mole kelvin and T in kelvins. CP = CPVAPA + (CPVAPB) * T + (CPVAPC) * T ** 2 + (CPVAPD) * T ** 3
HV	Heat of vaporization at normal boiling point (cal/g-mol)
N	Goldhammer's constant

TABLE II
Goldhammer's Constant

<u>Fluid Classification</u>	<u>Goldhammer's Constant</u>
Alcohols and water	0.25
Hydrocarbons and ethers	0.29
All other organic compounds	0.31
All other inorganic compounds except water	0.33

The preprocessor PRESOL will automatically generate TAPE 9 from a fluid property data bank that contains property data for some of the more common heat-transfer fluids and power-cycle working fluids (see Appendix A, p A-4).

2.4.2 Format

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
Fluid	A10	1-10	Fluid name must correspond with the name on TAPE 8
Type	A5	11-15	"POWER" or "THERM"

Parameter	Format	Columns	Description
<u>Card 2</u> (Omit if TYPE = "POWER")			
$T_{L\rho}$	E12.6	1-10	Lower temperature limit for density (K)
$T_{I\rho}^*$	E12.6	11-20	Intermediate temperature for density (K)
$T_{H\rho}$	E12.6	21-30	Upper temperature limit for density (K)

* If $C_{\rho 02}$ --- $C_{\rho 52}$ are all zeroes $T_{I\rho} = T_{H\rho}$

Card 3 (Omit if TYPE = "POWER")

$C_{\rho 01}$	E12.6	1-12	Coefficients for $\rho(T) = C_{01} + C_{11}T + C_{21}T^2 \dots$ $T_{L\rho} \leq T \leq T_{I\rho}$
$C_{\rho 11}$	E12.6	13-24	
.	.	.	
$C_{\rho 51}$	E12.6	61-72	

Card 4 (Omit if TYPE = "POWER")

This record must be included even if coefficients are all zeroes.

$C_{\rho 02}$	E12.6	1-12	Coefficients for $\rho(T) = C_{02} + C_{12}T \dots$ $T_{I\rho} < T \leq T_{H\rho}$
.	.	.	
.	.	.	
$C_{\rho 52}$	E12.6	61-72	

NOTE: Cards 2, 3, and 4 must be repeated if TYPE = "THERM" for defining C, ν , and k in this order.

Card 5 (Omit if TYPE = "THERM")

MOLWT	E12.6	1-12	Molecular weight
TB	E12.6	13-24	Normal boiling point (K)
TC	.	.	Critical temperature (K)
PC	.	.	Critical pressure (atm)
VC	.	.	Critical volume (cm ³ /g-mol)
OMEGA	E12.6	61-72	Pitzer's acentric factor

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 6</u> (Omit if TYPE = "THERM")			
LIQDEN	E12.6	1-12	Liquid density at TDEN (g/cm^3)
TDEN	E12.6	13-24	Reference temperature for LIQDEN (K)
CPVAP A	.	.	Constants in ideal-gas heat-capacity equation, with CP in calories per gram-mole kelvin and T in kelvins
CPVAP B	.	.	Same as above
CPVAP C	.	.	Same as above
CPVAP D	E12.6	61-72	Same as above
<u>Card 7</u> (Omit if TYPE = "THERM")			
HV	E12.6	1-12	Heat of vaporization at normal boiling point (cal/g-mol)
N	E12.6	13-24	Goldhammer's constant

NOTE: Cards 1-7 are to be repeated for additional fluids in the system model.
The maximum number of fluids is 10.

Card 8 (EOF)

NOTE: If additional system models are to be run, the above sequence must be repeated for each.

2.5 Weather Data (TAPE 12)

2.5.1 Discussion -- The weather records are specified hourly with an EOF after the last record, and each station is on a separate magnetic tape. These data are compatible with the typical year data⁴ for 26 locations compiled by SLA using the SOLMET weather data tapes.

2.5.2 Format -- The sequence of variables for each record is

Station No.

Year

Month

Day

Hour

Direct Normal Radiation ($\text{kJ/m}^2/\text{hr}$)

Standard Year Corrected Total Horizontal ($\text{kJ/m}^2/\text{hr}$)

Station Pressure (kPa)

Dry Bulb Temperature ($^{\circ}\text{C}$)

Wind Direction (degrees)

Windspeed (m/s)

The time-varying weather data format for SOLTES is

(I5, 3I2, I4, 9X, F4.0, 26X, F4.0, 40X, F5.2, F4.1, 4X, F3.0, F4.1).

2.6 Time-Varying Load Data (TAPE 11)

2.6.1 Discussion -- The time-varying load input (TAPE 11) to SOLTES may contain multiple files. Each file may contain load data for cooling, heating, hot-water, electrical, mechanical power, and thermal loads. Subroutine DAREXL reads this file.

2.6.2 Format

Record 1

ID₁, ID₂, IDIM, NV, IYEAR IDAY I HOUR

Format (2A10, 5I10)

ID₁ first word identifier of file
ID₂ second word identifier of file
IDTM constant time interval in seconds between data
NV number of load variables to be read
IYEAR starting year of file
IDAY starting day of file
I HOUR starting hour of file

Record 2

IVAR_i (i = 1, NV)

Format (8A10)

This record contains the unique identifiers for each load variable.

Record 3

XDATA_i (i = 1, NV)

Format (5E16.8)

This record contains load or load information data. The units for each category depend on the component that will use the load.

Record 4 (EOF)

An EOF record must follow each file on TAPE 11. After the last file there must be at least two EOFs.

NOTE: Days 1, 8, 15 --- are Sundays.

3. Model Construction

3.1 Discussion

Component routines in the SOLTES library are individual models for thermal-energy system components and controls.

SOLTES thermal-energy system models contain a unique set of integers ranging from 1 to 150. This unique set is created by assigning component numbers to each component model and outlet state numbers for each open component.

Open components in the SOLTES library are of the types depicted in Figure 2. These types are distinguished by the number of sides, inlets, and outlets.

Nomenclature:

NSTAI - Inlet state number
NSTAI1 - Inlet 1 state number
NSTAI2 - Inlet 2 state number
NCOM - Component number
NCOM1 - Side 1 component number
NCOM2 - Side 2 component number
NSTAO - Outlet state number
NSTAO1 - Outlet 1 state number
NSTAO2 - Outlet 2 state number

Figure 2. Open Component Types

A single component number is assigned for models of Types 1, 2, or 3, and a component number is assigned for each side of two-sided models (Type 4). Unique numbers must be given to outlet states of models with two outlets (Type 3). For the other types (Types 1, 2, and 4), the outlet state number is the same as the component number.

Fluid loops in the system model must be defined and each loop uniquely numbered with integers ranging from 1 to 10. A fluid loop may contain a single component or many components through which the same fluid flows. Each of these components must be connected to at least one of the other components in the loop by a fluid path.

SOLTES models are included in the examples of Appendix D.

3.2 Procedure

The following is a step-by-step procedure for creating system models. The intent is to provide a useful procedure for new SOLTES users and a reference for the experienced.

- a. Draw a system model schematic with boxes or appropriate system symbols for each component in the thermal-energy system. Each symbol denoting open components must be one of the four types shown in Figure 2. Denote fluid paths between open components as straight lines with arrowheads that indicate the direction of fluid flow.
- b. Choose the names of the routines that simulate components in the thermal-energy system from the SOLTES routine library. These routines may be used more than once in a system model.
- c. Place routine names next to the appropriate boxes or symbols.
- d. Choose an open component in the schematic and assign component and outlet state numbers. These numbers must be integers ranging from 1 to 150.
- e. Repeat d., choosing unique numbers, until all the open components in the schematic are assigned unique component and outlet state numbers.
- f. Assign a unique component number to each closed component in the system model.
- g. Draw arrows denoting the directions of energy transferred across the system boundaries and the components receiving or rejecting the energy. Place the word describing the category of energy transfer next to each arrow. Table III lists these words and conventions for directions of energy transfer. (See 1.2.6 for an explanation of each category.)

- NOTES: 1. Demands or parasitics cross the boundaries of the system model only if the demand or parasitic is not satisfied by another component in the system.
2. A characteristic temperature is denoted with each thermal load as shown in Table III.

TABLE III
Thermal Energy System -
Environment Energy Transfer Categories

Nomenclature:

A =

B =

Word	Convention	Category
ELCLD*	B	Electrical load
POWLD*	B	Mechanical load
HWATLD	B	Hot-water load
THMLD, T	B	Thermal load, characteristic temperature
HEATLD	B	Heating load
COOLLD	A	Cooling load
ELCPS	A	Electrical parasitic
POWPS	A	Mechanical parasitic
PRISUP	A	Supply rate from primary source
AUXSUP	A	Supply rate from auxiliary source
HTGAIN	A	Heat gain
ELCDM	A	Electrical demand
POWDM	A	Power demand
COOLDM	B	Cooling demand
HEATDM	A	Heating demand
HTLOSS	B	Heat loss
THMLOS	B	Thermal losses
HEAT	A or B	Heat
ADLOS	B	Advective loss
ADGAIN	A	Negative advective loss

* Electrical and mechanical loads are associated only with load management components.

- h. Draw arrows denoting the energy exchanges between components. Place the word describing the category of energy exchange next to each arrow. Table IV lists these words and conventions for energy transfer directions. Place the number of the component receiving the energy next to the arrow into that component and next to the arrow out of the component supplying the energy.

TABLE IV
System Internal Energy Transfer*

Nomenclature:

A -

B -

LM = Load management routine

R = Component requiring the demand
or parasitic

S = Component, other than load management,
satisfying the demand or parasitic

<u>Word</u>	<u>Energy Exchange Relationship</u>	<u>Convention</u>	<u>Category</u>
ELCDM	R	A	Electrical demand
ELCDM	LM	B	Electrical demand
POWDM	R	A	Mechanical demand
POWDM	LM	B	Mechanical demand
COOLDM	R	B	Cooling demand
COOLDM	S	A	Cooling demand
HEATDM	R	A	Heating demand
HEATDM	S	B	Heating demand
ELCPS	R	A	Electrical demand
ELCPS	LM	B	Electrical parasitic
POWPS	R	A	Mechanical parasitic
POWPS	LM	B	Mechanical parasitic
HEAT	To	A	Heat
HEAT	From	B	Heat

* Energy transferred between turbines and load management is automatically accounted and should not be denoted on the system schematic.

i. Denote fluid and power loops by enclosing all open components and outlet states in a loop with dashed lines. Power loops are more restrictive than fluid loops. See Appendix B for power-loop restrictions.

j. Assign a unique integer between 1 and 10 to each loop.

- k. Choose from the SOLTES routine library the names of information routines that provide load and energy source information for components and denote on the schematic.
- l. Choose from the SOLTES routine library the appropriate system performance routines.
- m. Construct component/information input data from the schematic by referring to Appendix C for individual routine input information.

NOTES: 1. Calls are made to the routines in the order that individual routine data is input.

- (a) The component/information input data must be sequenced as follows:
 - (1) Input for all information routines.
 - (2) Input for all component routines.
 - (3) Input for all system performance routines.
 - (b) Unless otherwise specified in the individual routine writeup, there are no rigid restrictions on the order of calls to component routines. However, the steady-state convergence can take much longer for system models that have awkward sequencing. The suggested sequence of open component models is as follows:
 - (1) The component that receives the energy from the primary source; i.e., a solar collector.
 - (2) The remaining components in this loop in the same sequence that the fluid enters the models as it flows through the loop.
 - (3) The components in an adjacent loop into which the fluid flows or in which energy is transferred between the two loops.
 - (4) The routines in this loop in the same sequence that the fluid flowing through the loop enters the models.
 - (5) Repeat (3) and (4) for the remaining adjacent loops.
 - (6) Repeat (3) through (5) until all the open component data are constructed.
2. The outlet state for model Types 1, 2, and 4 are automatically equated to the component number. Thus, the outlet state numbers are required input only for model Type 3.

3. Inlet state numbers are the outlet state numbers of upstream components.
4. Systems models with only closed components do not have state numbers.

n. Construct the fluid loop information data from the schematic and from the instructions in Section 3.

- NOTES:
1. The state-point and component numbers that must be placed on TAPE 8 are the unique set of all component and state-point numbers found in each loop shown on the schematic.
 2. Closed components are not included in fluid loops. System models with only closed components do not have fluid loops but may require fluid property data.

o. Other required SOLTES input such as executive routine control data is straightforward and can be constructed from the instructions in Section 2.

4. Conclusion

In addition to completing or writing those routines in the routine library index (Appendix C, p. C-1) that are denoted as being partially written or as extensions of present methods, the following extension to SOLTES would further expand its applications and usefulness:

- Add generalized thermal energy storage management
- Add generalized second law of thermodynamics accounting; i.e., generalized availability accounting
- Add photovoltaics with load management
- Extend the generalized Rankine-cycle capabilities to include supercritical cycles
- Add generalized Brayton cycles with load management
- Add more detailed heat exchanger, condenser, and thermal boiler models to include heat-transfer effects and off-design performance
- Include more detailed collector and storage models
- Include storage models with rate effects
- Add generalized Stirling cycles with load management

5. References

1. S. A. Klein, et al, TRNSYS, A Transient Simulation Program, prepared by the Solar Energy Laboratory, University of Wisconsin-Madison, Madison, WI, October 1977.
2. M. W. Edenburn and N. R. Grandjean, SOLSYS, Energy System Simulation Computer Program, SAND75-0048, Sandia Laboratories, Albuquerque, NM, June 1975.
3. R. C. Reid, J. M. Prausnitz, and T. K. Sherwood, The Properties of Gases and Liquids, 3rd ed., McGraw-Hill Book Co., NY, 1977.
4. I. J. Hall, R. R. Prairie, H. E. Anderson, and E. C. Boes, "Generation of Typical Meteorological Year for 26 SOLMET Stations," National Climatic Center in Ashville, NC, to be published.
5. R. C. Reid and T. K. Sherwood, The Properties of Gases and Liquids: Their Estimation and Correlation, 2nd ed., McGraw-Hill Book Co., NY, 1966.

APPENDIX A
The Preprocessor (PRESOL)

CONTENTS

	<u>Page</u>
Introduction	A-3
Disk or Tape Input for PRESOL	A-4
Component/Information Routine Data Bank (TAPE 2)	A-4
Fluid Property Data Bank (TAPE 7)	A-4
Partial Executive Routine (TAPE 10)	A-4
Disk or Tape Output From PRESOL	A-5
Constructing TAPE 1 From Terminal Input	A-5
Entering RECORDS Into a FILE	A-5
Closing a FILE	A-5
Closing a SYSTEM	A-6
Starting Another SYSTEM	A-6
Exiting PRESOL	A-6
Saving FILES and SYSTEMS From TAPE 1 for Future Use by PRESOL as TAPE 2 Input	A-6
Saving a Single FILE ("SAVE" Edit Command)	A-6
Saving a SYSTEM ("SAVE" Edit Command)	A-6
Retrieving a SYSTEM or FILE From the Component/Information Data Bank (TAPE 2)	A-7
First RECORD ACCESS	A-7
PRESOL "SYSTEM" Command	A-7

CONTENTS (contd)

	<u>Page</u>
Editing Commands for FILES and SYSTEMS (TAPE 1)	A-7
Edit Command "MARK"	A-8
Edit Command "LIST"	A-8
Edit Command "EDIT"	A-8
Edit Command "REPLACE"	A-8
Edit Command "INSERT"	A-9
Edit Command "DELETE"	A-9
Edit Command "RECONNECT"	A-9
Edit Command "CLOSE"	A-10
Edit Command "NEWSYS"	A-10
Constructing Executive Routine Data (TAPE 6)	A-10
Constructing Loop Definition Data (TAPE 8)	A-10
"LOOP" Command	A-10
Constructing Fluid Property Data and Constants (TAPE 9)	A-11
"PROP" Command	A-11
Generating the Executive Routine (TAPE 4)	A-12
Incorporating User-Written Subroutines	A-12
"ADD" Command	A-12
Summary of Commands	A-13
Diagnostic Messages and Cautions	A-16
Examples	
Example 1: Generating a SOLTES Model on NOS and Sending It To the BATCH Processor for Execution	A-19
Example 2: Retrieving a SYSTEM from an NOS Permanent File, Modifying It, and Replacing the Modified Version for Future Executions of PRESOL. The Component/Information Data Generated, TAPE1, Is Also Replaced on an NOS Routine Permanent File	A-23

APPENDIX A

The Preprocessor (PRESOL)

Introduction

The preprocessor PRESOL is a computer code that aids users in creating SOLTES input. The code also generates the SOLTES executive routine with calls only to those subroutines required by a particular system model. Although PRESOL has been written for execution under SLA's Network Operations System (NOS) time-sharing system, minimum changes should enable it to run under other time-sharing systems or under batch. Extensive knowledge of NOS is not required to make full use of PRESOL.

In general, PRESOL accepts user input and determines if it is data or command. The following SOLTES data may be prepared by PRESOL:

Component/Information Data (TAPE 1)

Executive Routine Control Data (TAPE 6)

Property Data for Heat-Transfer Fluids and Constants
Characterizing Power-Cycle Working Fluids (TAPE 9)

Loop Definition Data (TAPE 8)

All this data need not be generated in a single execution of PRESOL, because component/information data may be built in modules saved in the component/information routine data bank and in future execution of PRESOL retrieved, edited, and again saved. This process can continue until the complete system model has been constructed. This feature of PRESOL also enables the user to construct partial system models that at a later date may be merged and edited to form an entirely new system. A complete list of PRESOL commands can be found on page A13.

The following terms and definitions may help in using and understanding PRESOL:

RECORD - a record or card image consisting of 80 characters.
By definition, eight CDC 6600 words.

FILE - one or more records followed by an EOF mark.
(RETURN key on NOS.) Input data to each SOLTES routine is a FILE.

SYSTEM - one or more files.

CN1 - always refers to Columns 11 through 20 of the first RECORD for every FILE.

WORD - 10 consecutive characters, the first character of which must be in Columns 1, 11, 21, ..., or 71.

Disk or Tape Input for PRESOL

This section briefly describes the necessary disk or tape input to PRESOL. PRESOL does not require all this input to be present for every execution.

Component/Information Routine Data Bank (TAPE 2) -- This file may contain component/information routine data for complete or partial system models. PRESOL is directed to access this data bank by the "SYSTEM..." command or when the user specifies "DATA" in Columns 51-54 of the first RECORD of a FILE. TAPE 2 must be an NOS local file before executing PRESOL only if the data bank is to be accessed. This data bank is generated for future executions of PRESOL by the "SAVE..." command.

Fluid Property Data Bank (TAPE 7) -- This file contains fluid property data for heat-transfer fluids and for constants characterizing power-cycle working fluids. Before PRESOL runs containing "LOOP..." commands, TAPE 7 must be attached with the NOS command "GET, TAPE 7/UN=NRGRAND". Heat-transfer properties and power-cycle constants are now available for the following fluids:

Heat-Transfer Fluids

Data Bank Name	Fluid	Temperature Range in K			
		(ρ, C _p , k)		ν	
		Lower	Upper	Lower	Upper
"THERM 44"	Therminol 44	219	533	255	533
"THERM 44"	Therminol 55	255	616	283	616
"THERM 60"	Therminol 60	219	616	255	616
"THERM 66"	Therminol 66	255	644	283	644
"THERM 88"	Therminol 88	422	755	422	755
"WATER"	Water	273	573	273	573
"SILON B"	Silicone B	228	644	228	644

Power-Cycle Fluids

"WATER"	Water
"TOLUENE"	Toluene
"FREON 11"	Freon 11
"FREON 12"	Freon 12

Partial Executive Routine (TAPE 10)--This is a three-file source deck containing most of the coding for the executive routine. This file is necessary only when the user desires to generate an executive routine by answering "YES" to the question, "DO YOU WISH TO GENERATE THE EXECUTIVE ROUTINE YES OR NO". Before execution of PRESOL in which the executive routine

is to be generated, TAPE 10 must be attached to the user's local file with the NOS command "GET, TAPE 10/UN=NRGRAND".

Disk or Tape Output From PRESOL

TAPE 1 - SOLTES component/information routine data.

TAPE 5 - PRESOL component/information routine data bank. (This file may be an input for future executions of PRESOL under the name TAPE 2.)

TAPE 6 - SOLTES executive routine

TAPE 8 - SOLTES loop definition data.

TAPE 9 - SOLTES fluid property data and power-cycle constants.

Constructing TAPE 1 From Terminal Input

Entering RECORDS Into a FILE--Component/information data file TAPE 1 is easily constructed using PRESOL. Once the preprocessor has been initiated

.
. NOS commands for logging into the system, etc
.

/ GET, BINPRE/UN=NRGRAND

/ BINPRE

? PRESOL response

the user starts inputting data RECORDS as prescribed for each FILE in creating his SYSTEM.

For example, if the user wishes to create a FILE of information for component XXXXX, the sequence would be

.
.
? XXXXX 1 14 RETURN
? 30.4 RETURN
? 1 RETURN
? RETURN
? (at this point PRESOL is waiting for a new FILE to begin or for a command)

The keyboard "RETURN" is given after the last entry for each RECORD has been made in the proper character positions.

Closing a FILE--To close a FILE, the user must send a record containing only a RETURN keyboard code (EOF). The keyboard RETURN as in the above example will be henceforth referred to as RETURN. The sequence shown in the example may continue until all the FILES have been constructed and the user wishes to close the SYSTEM and either start another SYSTEM or exit PRESOL.

Closing a SYSTEM--To close a SYSTEM, the user inputs "CLOSE" after the "?", and answers the PRESOL question "DO YOU..." with a "RETURN"

Starting Another SYSTEM -- After the user has closed his SYSTEM he may build a completely new system by entering "NEWSYS" (see A10) or by modifying the FILES currently available on TAPE1.

Exiting PRESOL -- To exit PRESOL the user must close the SYSTEM as above and then send an EOF to PRESOL. PRESOL will then respond with two self-explanatory questions. The user will exit PRESOL by answering "NO" to the first question and "YES" or "NO" to the second.

Saving FILES and SYSTEMS From TAPE 1 for Future Use by PRESOL as TAPE 2 Input

PRESOL allows the user to SAVE a single FILE of information or a set of FILES. This feature of PRESOL enables the user to build modularly and edit SOLTES system models by saving discrete FILES of information from TAPE 1. The "SAVE..." command initiates a write to TAPE 5, which then may be input to PRESOL in future executions as TAPE 2. The "SAVE..." command may be exercised at any time while building a SYSTEM and as many times as necessary, but must be exercised

After a FILE has been closed;

Before the SYSTEM is closed.

NOTE: The user must permanently retain TAPE 5 using the NOS command "SAVE" or "REPLACE" after exiting PRESOL.

Saving a Single FILE ("SAVE" Edit Command)--The PRESOL command by characters is

(Column) 1-4	11-20	21-30	31-40
"SAVE"	Name	CN1	File Name

where Name is the routine name. CN1 is the component number. File Name is a unique name under which the FILE is to be saved on TAPE 5 for future recall.

Saving a SYSTEM ("SAVE" Command) -- The user may SAVE a SYSTEM from TAPE1 before advancing to another SYSTEM by issuing the command

(Column) 1-4	11-20	21-30	31-40
"SAVE"	"SYSTEM"	Blank	File Name

Individual FILES from the SYSTEM or the entire SYSTEM, may be retrieved in future runs of PRESOL.

Retrieving a SYSTEM or FILE From the Component/Information Data Bank (TAPE 2)

Individual FILES or SYSTEMS may be entered to TAPE 1 from the data bank (TAPE 2). This data bank may contain whole SYSTEMS and/or individual FILES. PRESOL is directed to access this data bank when the user enters the word "DATA" in Columns 51-54 of the first RECORD for a given FILE, or when the "SYSTEM..." command is issued. TAPE 2 must be a local file before the execution of PRESOL whenever access is intended.

First RECORD ACCESS--This procedure is used when the FILE was saved using the "SAVE (name)..." command (saving a single FILE). PRESOL will search TAPE 2 whenever the user enters "DATA" in Columns 51-54 of the first RECORD of a FILE. PRESOL matches the first 10 characters of the given RECORD and Columns 61-70 of that RECORD with identifications found in the data bank. Upon finding a match, the preprocessor loads to TAPE 1 the first 50 characters found on RECORD 1 given through the terminal and then the last 30 characters of RECORD 1 from the data bank, along with any remaining RECORDS in the data bank for that FILE.

PRESOL "SYSTEM" Command--This command allows the user to retrieve a single FILE from a SYSTEM or the entire SYSTEM. The data retrieved is then written to TAPE 1.

If the user wishes to retrieve a particular FILE from a SYSTEM, he gives the command:

(Column)	1-6	11-20	21-30	31-40
	"SYSTEM"	File Name	Name	CN1

If the user wishes to retrieve the entire SYSTEM, Columns 21-40 of the above command must be blank.

Editing Commands for FILES and SYSTEMS (TAPE 1)

Various editing commands have been established to aid the user in generating, modifying, and correcting FILES and SYSTEMS on TAPE 1. Thus far the commands that have been introduced allow the user to SAVE and retrieve ("SYSTEM" command) data in constructing TAPE 1. As mentioned previously, PRESOL distinguishes between commands and data. For this reason commands and data may be given to the preprocessor in almost any order, following only a few basic rules:

A FILE must be closed before starting another

A FILE must be closed before issuing a command.

Once a SYSTEM is closed, the user may not return to it.

Issuing any command, excluding the MARK and SYSTEM command, when TAPE 1 is empty is fatal.

This section deals with each command individually. A summary may be found on page A-13.

Edit Command "MARK"--This command provides the user with reference numbers indicating column positions on the terminal.

Edit Command "LIST"--This command will list the first RECORD of each FILE of your current SYSTEM as found on TAPE 1. If you choose to see all the RECORDS of every FILE, this may be done by including "ALL" in Columns 11-13.

Edit Command "EDIT"--This command enables the user to change any number of words in one or all RECORDS within a FILE. To issue, the user inputs

(Column)	1-4	11-20	21-30
	"EDIT"	Name	Number (CN1)

PRESOL will respond by

1. Automatically printing the "MARK" card
2. Printing the first RECORD of the FILE
3. Accept changes to the RECORD (if no changes are desired, do a RETURN).

NOTES: a. Some components require two data entries in a WORD.
If the user desires to change either one, he must also enter the other.

b. To convert a WORD to all blanks, enter "XXXXXXXXXX".

4. Print the new RECORD.

The above sequence will continue for the remaining RECORDS until either the preprocessor encounters an EOF for that file or until the user types "NEXT" (this will return the user to the control).

Edit Command "REPLACE"--This command allows the user to remove a file from his SYSTEM and replace it with another. To use this command the user input is:

(Column)	1-7	11-20	21-30
	"REPLACE"	Name	CN1

The processor then removes the FILE given and replaces it with the next FILE, which is either retrieved from the data bank or input from the terminal. Only one FILE may be inputted. If more than one file is needed, the "DELETE" and "INSERT" commands should be used.

Edit Command "INSERT"--The "INSERT" command has two forms.

(Column)	1-6	11-20	21-30
	"INSERT"	Name	CN1

The first allows the user to insert before that specified FILE any number of FILES, either from the terminal or the data bank or both. This feature is helpful when introducing a subsystem into TAPE 1. With this command, PRESOL continues accepting FILES until you type "NEXT" in Columns 1-4.

The second form of the "INSERT" command enables the user to insert RECORDS within a specified FILE. Columns 1-30 designate which file, as before, and Columns 31-40 (right-adjust) specify the record in the file where the insert is to take place. A positive number in this field causes the insert to take place after the record specified; a negative, before. After the last RECORD has been inserted, do a RETURN from the keyboard and then type "NEXT" in Columns 1-4.

Edit Command "DELETE"--The "DELETE" command is of the same form as the INSERT. To delete an entire file, the user inputs

(Column)	1-6	11-20	21-30
	"DELETE"	Name	CN1

To delete a RECORD within a FILE, add the record number to be deleted in Columns 31-40 (right-adjust).

Edit Command "RECONNECT"--The "RECONNECT" command allows the user to change from one to four of six numbers (CN1, US1, OS1, CN2, US2, OS2) found on the first RECORD of each component FILE. (These numbers correspond to the component and state numbers.) This command is useful when inserting or deleting files in the SYSTEM. The full command for RECONNECT is:

<u>Column</u>	<u>Instruction</u>
1-9	"RECONNECT"
11-20	Name
21-30	CN1 (right-adjust)
31-35	Old number
36-40	New number
41-45	Second old number
46-50	Second new number
51-55	Third old number
56-60	Third new number
61-65	Fourth old number
66-70	Fourth new number

The sequence of the changes is not important; i.e., if the user wanted to change CN1 and US1 to CN1' and US1', he could specify on his RECONNECT card US1 in Columns 31-35, US1' in 36-40, and then CN1 and CN1' in 41-50. The user is reminded that only four of the six numbers may be changed since there is no component type in SOLTES that requires more than four of the six to be set at any one time.

Edit Command "CLOSE"--When the user is finished building and editing a SYSTEM and has saved his current SYSTEM, if so desired (see "Saving FILES and SYSTEMS," page A-6), he may start building another SYSTEM, closing his current SYSTEM with a "CLOSE" command.

Edit Command "NEWSYS"--Immediately after the "CLOSE" command is given, PRESOL regenerates the previous SYSTEM for modification. If the new SYSTEM is an entirely new SYSTEM to be built, the user must inform PRESOL with a "NEWSYS" command. This command will cause PRESOL to forget what it knew about the previous SYSTEM and start a new one for you.

Other commands that are recognized by the preprocessor are:

"LOOP", "PROP", "CONVER", "PRINT", "PLOT", "TIME", "PRINTCON", "ID", "WRITE".

It is important that these keys are never used as names of FILES. These commands, used in building the other SOLTES input files, are discussed next.

Constructing Executive Routine Data (TAPE 6)

EXECUTIVE CONTROL data (PRINT, TIME, etc) is written to TAPE 6. Unlike the component/information routine data, PRESOL returns to the monitor control when it processes the "LAST" flag in Columns 71-74 of the Executive Control Data.

Constructing Loop Definition Data (TAPE 8)

TAPE 8 is generated for the user when the "LOOP" control/command is executed in PRESOL.

"LOOP" Command--The "LOOP" command furnishes PRESOL with the following information:

Fluid name (FNAME)

Loop number (LN)

Initial temperature (T_0)

Initial pressure (P_0)

Initial flow rate (F_0)

The component and state numbers in the loop (N_i)

To execute the "LOOP" command, type:

<u>Variable</u>	<u>Column</u>
"LOOP"	1-4
FNAME	11-20 (left-adjust)
LN	21-30 (right-adjust)
T ₀	31-40
P ₀	41-50
F ₀	51-60
N ₁	61-65
N ₂	66-70
N ₃	71-75
N ₄	76-80

(right-adjust)

If there are more than four component or state numbers to be entered, they must appear on the next record, which has the following format:

<u>Variable</u>	<u>Column</u>
N ₅	1-5
N ₆	6-10
.	.
.	.
.	.
N ₁₈	76-80

Records with the above format may be repeated if necessary. After all the loop data for a specific loop has been entered it is necessary to give PRESOL an EOF. This will return PRESOL to the monitor level.

Constructing Fluid Property Data and Constants (TAPE 9)

The PRESOL command "LOOP" aids the user in building TAPE 9 (Fluid Property Data and Constants). To execute the "LOOP" command, TAPE 7 (Fluid Property Data and Constants Data Bank) must be present. PRESOL searches TAPE 7 for the various coefficients required to build TAPE 8 (see LOOP definition data, TAPE 8). If the user wishes to specify his own coefficients and/or constants, as described in Section 2.3, he may enter them with the "PROP" control command. The "PROP" command not only permits new coefficients to be written to TAPE 9, but also allows the user to override coefficients that already exist on TAPE 7 (as long as he used the same fluid name).

"PROP" Command--To execute the "PROP" command, the user types "PROP" in Columns 1-4, the fluid name in 11-20, and either "POWER" or "THERM" in 21-30. If

Columns 21-30 contain "THERM", then Columns 31-40 must contain either "DENS", "SPHT", "VISC", or "COND". This is all that is contained on the first record. PRESOL will respond by asking for the data in free format (separate the data by commas). Once the user supplies all the data, PRESOL returns to the monitor or control level.

Generating the Executive Routine (TAPE 4)

Once the user has generated the component/information routine data (TAPE 1) and is satisfied with his system model(s), he can generate the executive routine for SOLTES by

1. Executing the "CLOSE"
2. Entering an EOF
3. Entering a second EOF
4. Answering "NO" to the second question "DO YOU WANT TO RETURN... "
5. Answering "YES" to the question "DO YOU WANT TO GENERATE THE EXECUTIVE ROUTINE?"

TAPE 10 (the partial executive routine) and TAPE 1 must be local files before executing the above commands. PRESOL will search the entire set of data on TAPE 1 and select all the unique component and information routines it finds for as many SYSTEMS as it finds on TAPE 1. The proper data statement and the necessary call statements are then written into the executive routine.

Incorporating User-Written Subroutines

PRESOL, when generating the executive routine, automatically includes call statements to any component/information routines that it finds on TAPE 1. The user may input his source deck by using the "ADD" command.

"ADD" Command--This command automatically adds source decks to the proper file for compilation. After the last record of the source decks, the user must supply PRESOL with a record containing "LAST" in Columns 71-74, whereupon the preprocessor returns to the control point.

Summary of Commands

Variable	Column	Format	Description
ADD			
"ADD"	1-3	A3	Control identifier
CLOSE			
"CLOSE"	1-5	A-5	Control identifier
DELETE			
"DELETE"	1-6	A6	Control identifier
Name	11-20	A10	Routine name
Number	21-30	I10	CN1 (component number)
Record	31-40	I10	Record to be deleted (if blank, delete entire file)
EDIT			
"EDIT"	1-4	A4	Control identifier
Name	11-20	A10	Routine name
Number	21-30	I10	CN1 (component number)
INSERT			
"INSERT"	1-6	A6	Control identifier
Name	11-20	A10	Routine name
Number	21-30	I10	CN1 (component number)
Record	31-40	I10	If blank, insert 1-n new files before file specified
NOTE: If Columns 31-40 are blank, end each new FILE with an EOF; then end the INSERT with "NEXT". If Columns 31-40 are not blank, end the INSERT of records with an EOF and then "NEXT".			
LIST			
"LIST"	1-4	A4	Control identifier
"ALL"	11-13	A3	Optional: if omitted, list only the first record of each FILE. If included, list all records of each FILE.
LOOP			
"LOOP"	1-4	A4	Control identifier
Name	11-20	A10	Fluid name
LN	21-30	I10	Loop number
T ₀	31-40	F10.0	Initial temperature
P ₀	41-50	F10.0	Initial pressure
F ₀	51-60	F10.0	Initial flowrate

Variable	Column	Format	Description
N ₁	61-65	I5	Component and state numbers in loop LN
N ₂	66-70	I5	
N ₃	71-75	I5	
N ₄	76-80	I5	
Next Record (if needed)			
N ₅	1-5	I5	Additional component and state numbers in loop LN
N ₆	6-10	I5	
↓	↓	↓	
N ₁₈	76-80	I5	
Repeat above for additional numbers			
Return to control level when finished with an EOF			
MARK			
"MARK"	1-4	A4	Control identifier
NEWSYS			
"NEWSYS"	1-6	A6	Control identifier
NEXT			
"NEXT"	1-4	A4	Control identifier
PROP			
"PROP"	1-4	A4	Control identifier
Name	11-20	A10	Fluid name
	21-30	A10	"POWER" or "THERM"
Type	31-40	A4	Blank if TYPE is "POWER"; "DENS", "SPHT", "VISC", or "COND" if TYPE is "THERM"
Next record if TYPE = "THERM"			
T _L	Free		Lower temperature limit (K)
T _I			Intermediate limit (K) (T _I = T _H if C ₀₂ ... C ₅₂ are all zeros)
T _H			Upper temperature limit (K)

Variable	Column	Format	Description
Next record if TYPE = "THERM"			
C ₀₁	Free		Heat-transfer-fluid property constants (refer to Section 2.4)
C ₁₁			
C ₅₁			
C ₀₂			
C ₁₂			
C ₅₂			
Next record if TYPE = "POWER"			
MOLWT	Free		Power-cycle working-fluid constants (refer to Section 2.4)
TB			
TC			
PC			
VC			
OMEGA			
LIQDEN			
TDEN			
CPVAP			
CPVAP B			
CPVAP C			
CPVAP D			
HV			
N			
Control to monitor level is automatic after completing data input			
RECONNECT			
"RECONNECT"	1-9	A9	Control identifier
Name	11-20	A10	Routine name
Number	21-30	I10	CN1 (component number)
O ₁	31-35	I5	Old number
N ₁	36-40	I5	New number

<u>Variable</u>	<u>Column</u>	<u>Format</u>	<u>Description</u>
O ₂	41-45	I5	Old number
N ₂	46-50	I5	New number
O ₃	51-55	I5	Old number
N ₃	56-60	I5	New number
O ₄	61-65	I5	Old number
N ₄	66-70	I5	New number
REPLACE "REPLACE"	1-7	A7	Control identification
Name	11-20	A10	Routine name
Number	21-30	I10	CN1 (component number)
SAVE "SAVE"	1-4	A4	Control identifier
"SYSTEM" or Name	11-20	A10	Leave blank if 11-20 is "SYSTEM"
Number	21-30	I10	
ID	31-40	A10	
SYSTEM "SYSTEM"	1-6	A6	Control identifier
ID	11-20	A10	Identification of system
Name*	21-30	A10	Routine name
Number*	31-40	I10	CN1 (component number)

*If Columns 21-40 are blank, retrieve entire SYSTEM; otherwise, retrieve the FILE as indicated by name and number.

Diagnostic Messages and Cautions

Nonfatal diagnostic messages are provided to the user when mistakes detectable by PRESOL are encountered.

All the diagnostics in PRESOL are self-explanatory, therefore, details will be omitted in this manual. However, the following cautions should be kept in mind.

1. PRESOL does not permanently retain or save any of the files produced. The user must use the NOS commands "SAVE" or "REPLACE" after exiting PRESOL.
2. TAPE 1 and TAPE 10 must be local files before generating the executive routine for SOLT ES.
3. TAPE 7 must be a local file before executing a "LOOP" command.
4. Do not execute a LIST, EDIT, etc. command if TAPE 1 is empty.
5. Correct spelling of PRESOL commands is important. Also, be sure they are all left-justified.
6. Execute the PRESOL "SAVE" command before advancing to the next SYSTEM or exiting PRESOL.

NOTE: If during the execution of PRESOL the user encounters problems, he can always regain control by sending a series of EOFs until the question "DO YOU WANT TO RETURN TO YOUR CURRENT SYSTEM?" appears. By answering "YES" the user may then return to the SYSTEM and edit it.

Examples

Example 1: Generating a SOLTES Model on NOS and Sending It to the BATCH Processor for Execution -- This example demonstrates the generation of a SOLTES model from start to end using PRESOL. The example corresponds directly with Example 1 in Appendix D. Following the example are the two procedure files used in sending the model to execute under SLA's 6600 Batch system. The construction of procedure files may be seen in the NOS News Notes.

```

1
6000 SYSTEM UP

78/08/28. 18.44.23.
SANDIA NOS SN53 ECS
USER NUMBER, PASSWORD

NOS 1.2-460

TERMINAL: 12, TTY
RECOVER /SYSTEM: BAT
$RFL: 0.
/GET, BINPRE/UN=NRGRAND
/GET, TAPE7/UN=NRGRAND
/GET, TAPE10/UN=NRGRAND
/BINPRE
? MARK
? 5 10 15 20 25 30 35 40 45 50 55 60 65 70 75
? WEATHR 23050
?
? DAREXL
? HWATLD 88.76E -6
? LAST
? MKPFLD 1 290. 3.E 5
? 3ND
? PUMP 2 1 4.E 5.9 FIXED
? 2.2E -5
? FLTPLT 3 2 3 16.31E
? 3 3.16E -62. 1.7 .15 2. 35. .03 .05
? .077 .91 .1 .9 .06 .08
? PIPE 4 3 10. .011 6.
? 1.25
? STORES 5 4 .5 340.
? 30.6 VARIABLE 8
? PIPE 6 5 10. .011 6.
? 1.25
? AUXFUR 7 6 340. .9
? WATHTR 8 7 1
? ENGAC1
? LIST ALL
? WEATHR 23050

END OF FILE

DAREXL
HWATLD 88.76E -6
LAST
END OF FILE

```

```

MKPFLD          1          290.      3.E      5
      3ND
      END OF FILE
PUMP            2      1          4.E      5.9      FIXED
2.2E      -5
      END OF FILE
FLTPLT          3      2          3          16.31E
3.16E      -62.      1.7      .15      2.      35.      .03      .05
.077      .91      .1      .9      .06      .08
      END OF FILE
PIPE            4      3          10.      .011      6.
      1.25
      END OF FILE
STORES          5      4          .5      340.
      30.6      VARIABLE      8
      END OF FILE
PIPE            6      5          10.      .011      6.
      1.25
      END OF FILE
AUXFUR          7      6          340.      .9
      END OF FILE
WATHTR          8      7          1
      END OF FILE
ENGAC1
      END OF FILE
? MARK
? TIME 5 10 15 20 25 30 35 40 45 50 55 60 65 70 75
? PRINT 1975 84 12 0 1975 85 12 0 3600 LAST
? PRINT TABLE1 1975 84 12 0 1975 85 12 0 1 OLAST
? PRINT TABLE3 1975 84 12 0 1975 85 12 0 1 OLAST
? PRINT TABLE2 1975 84 12 0 1975 85 12 0 .1 OLAST
? ID EXAMPLE 1 FOR REPORT
? HOT WATER SYSTEM LAST
? RUN LAST
? MARK
? LOOP 5 10 15 20 25 30 35 40 45 50 55 60 65 70 75
      WATER 1290. .3E 6.01 1 2 3
4
? 5 6 7 8
?
? CLOSE
  WOULD YOU LIKE TO ENTER ANY "SAVE" COMMANDS ? IF "YES"
  PLEASE TYPE "YES" AND THEN ENTER THEM AND THEN THE "CLOSE" CONTROL
  IF NOT DO A RETURN.
?
? DO YOU WANT TO RETURN TO YOUR CURRENT SYSTEM YES OR NO
? NO
? DO YOU WANT TO GENERATE THE EXECUTIVE ROUTINE YES OR NO
? YES
  1.196 CP SECONDS EXECUTION TIME
/-SYS
  ROUTE COMPLETE. JOB NAME IS MEFR1RF
/-BYE

19.09.56 78/08/28.
OFF MEFEWEL
TTY 012 3.754 SRU

```

Procedure Files

CSYS --

JOB CARD

ACCOUNT CARD

REQUEST,DUMF12,HY,S. VRN=14606
COPYCF,DUMF12,TAPE12.
UNLOAD,DUMF12.
COPYBF,INPUT,MAIN.
REWIND,MAIN.
FTN,I=MAIN.
ATTACH,LG01,A9SOLLIB.
REWIND,OUTPUT.
PREP,LG01,X.
COLLECT,LG0,X,FTNLIB,FXMATH.
COPYBF,INPUT,TAPE1,12.
COPYBF,INPUT,TAPE6.
COPYBF,INPUT,TAPE8,2.
COPYBF,INPUT,TAPE9.
ATTACH,TAPE13,SOL-UNITS-DATABNK,CY=1,CN=MEF.
LG0,LC=77777.

SYS

NDEXIT.
REWIND,TAPE1.
REWIND,TAPE4.
REWIND,TAPE6.
REWIND,TAPE8.
REWIND,TAPE9.
COPYBF,TAPE4,FILE1.
COPYBF,TAPE1,FILE1,12.
COPYBF,TAPE6,FILE1.
COPYBF,TAPE8,FILE1,2.
COPYBF,TAPE9,FILE1.
CALL,SENDJOB(CC=CSYS,D=FILE1,CS=R1)

Example 2: Retrieving a SYSTEM from an NOS Permanent File, Modifying It, and Replacing the Modified Version for Future Executions of PRESOL. The Component/Information Data Generated, TAPE 1, Is Also Replaced on an NOS Routine Permanent File -- The purpose of this example is to show the following:

1. The retrieval of a previously generated component/information routine data bank from an NOS permanent file (GET, TAPE2=TAPE5).
2. The modification of the SYSTEM using most of the PRESOL edit commands.
3. The saving of the modified SYSTEM by PRESOL for future use.
4. The replacement of the newly generated component/information routine data tape (TAPE1) in an NOS permanent file and the replacement of the newly generated component/information routine data bank, TAPE5. (REPLACE, TAPE1, TAPE5)

Note: The input on TAPE1 is similar to Example 2 in Appendix D but does not correspond exactly.

```

/GET,BINPRE,TAPE2=TAPE5
/BINPRE
? SYSTEM      TAPE
? DELETE      SOLEN1
? MARK
? 5           10   15   20   25   30   35   40   45   50   55   60   65   70   75
? INSERT      DAREXL
? WEATHR
?
? NEXT
? DELETE      STORE2
? RECONNECT   THMBLR
? LIST        ALL
? WEATHR
23050
23050

DAREXL      END OF FILE
TEST        CASE
THMLD      18.1      437.5
ELCLD      14TAPE
GRID        AIRCOND
.9          100000.  1.
LAST
FOCOL      END OF FILE
1          9
120.       40.       .9
PIPE        END OF FILE
2          1          3.          .100      20.
10.25
PUMP        END OF FILE
30         2          4.E          5.7      VARIABLE
MIXJNT      END OF FILE
3          12         30
END OF FILE

```

THMBLR	6	3	13	23	10.	1.	
PUMP	END OF FILE	10	6		4.E	5.9	VARIABLE
SWITCH	END OF FILE	7	10	8		1TEMP	400.
1000.		9					
PIPE	END OF FILE	11	8		3.	.100	20.
	10.25						
AUXFUR	END OF FILE	12	11		600.	.7	4.4E
LODMG	END OF FILE	14	13		POWER	YES	
ELCDM	NONE						
ELCPS							
1	30						
2	10						
3	21						
POWDM	NONE						
POWPS							
3ALL							
XTURBG	END OF FILE	15	14	16	17	95.	85.
65.	75.	437.5	437.5				
PRSVAP	END OF FILE	18	16		350.	1.013	E5
437.5	30.		1	11.		19	
MKPFLD	END OF FILE	19			288.	1.E	5
	16ND	POWER					
MIXJNT	END OF FILE	31	18	19			
DCONHT	END OF FILE	20	31	25	380.	5.516E	5
XTURBG	END OF FILE	24	17	25	26	90.	UNSPEC 80.
60.	70.	437.5	310.				
BFDPMF	END OF FILE	21	20		1.379E	685.	95.
CNDHTR	END OF FILE	27	26	28	29		
10.	5.	LAST					
	END OF FILE						


```

MIXJNT          22  27          21
END OF FILE
BFDPMF          23  22          1.379E  680.    90.
POWER
END OF FILE
COOLTDW          29  28          295.
END OF FILE
ENGAC1
END OF FILE
? REPLACE SWITCH          7  10  7
? FLODIV          7  10  9          8          1
? EDIT          FOCOL          1
? FOCOL          5  10  15  20  25  30  35  40  45  50  55  60  65  70  75
          FOCOL          1  9
? FOCOL          1  9          600.
          600.
          5  10  15  20  25  30  35  40  45  50  55  60  65  70  75
          120.          40.          .9

? NEXT
? SAVE          SYSTEM          REPORT
? CLOSE
WOULD YOU LIKE TO ENTER ANY "SAVE" COMMANDS ? IF "YES"
PLEASE TYPE "YES" AND THEN ENTER THEM AND THEN THE "CLOSE" CONTROL
IF NOT DO A RETURN.
?
?
DO YOU WANT TO RETURN TO YOUR CURRENT SYSTEM YES OR NO
? NO
DO YOU WANT TO GENERATE THE EXECUTIVE ROUTINE YES OR NO
? NO
2.009 CP SECONDS EXECUTION TIME
/REPLACE,TAPE5,TAPE1
/

```

APPENDIX B

Generalized Rankine-Type Power-Conversion Cycles

Simple-to-complex Rankine-type power-conversion cycles can be constructed modularly from component routines. A generalized equation-of-state for real gases--the HMBS equation--is used along with thermodynamic state relationships, the Watson correlations for latent heat of vaporization, Riedel-Plank-Miller and Miller semireduced correlations for vapor pressure, and correlations for real fluid heat capacities at zero pressure to calculate the change in thermodynamic state between any two subcritical states. The 14 constants required by this method are input to SOLTES for each power-cycle working fluid in the system model (see Section 2.4.1, p 2-8).

A typical power cycle is shown in Figure B1. The cascaded turbines may be separate pieces of hardware, or the cascading can be used to simulate a single turbine with multiple extraction ports. Turbines and/or extraction turbines are separately and automatically numbered in the sequence in which their data occur in the information/control data file.

The number of flow branches from the turbine cascade is equal to the number of extraction turbines in the cascade plus one. The turbine cascade may consist of any combination of extraction and nonextraction turbines, and each turbine may or may not be coupled with an electrical generator.

The cascade may include one or more turbines or extraction turbines, but the total number may not exceed five (to minimize computer storage, the number of turbines is limited to five). Each flow branch may include a regenerative heater, condensers, and/or components that supply process heat. However, the second law of thermodynamics restricts the total number of regenerative heaters in a power cycle to the number of extraction turbines in the cascade, and fixes the number of flow branches from which energy can be independently transferred from the power cycle.

SOLTES power-cycle operating modes are distinguished by the independent energy transfer rates from the power cycle. These modes are as follows:

<u>Mode</u>	<u>Description</u>
Power	The electrical and/or mechanical power outputs of the power cycle are independent and must be specified; i.e., electrical and/or mechanical power loads are followed; electrical demands, electrical parasitics, mechanical demands, and/or

Figure B1. A Typical Complex Rankine-Type Power Cycle

Mode

Description

mechanical parasitics are satisfied. Energy can be independently transferred from all but one of those flow branches that do not contain regenerative heaters. Thus, the number of independent energy-transfer rates from the flow branches is equal to the number of extraction turbines in the cascade less the number of regenerative heaters. There must be at least one flow branch that does not contain a regenerative heater. The independent transfer rates from the flow branches are specified by thermal load information that may be read from a data file and/or by flow rates demanded by condensers. Neither the fluid-flow rate through nor the energy-transfer rate from the remaining flow branch is independent. For continuous operation of the power cycle, the energy required by specifying all of these energy-transfer rates must be supplied by thermal boilers and/or auxiliary boilers.

Heat

The energy transfer from each flow branch that does not contain a regenerative heater is independent and the rate must be specified. The energy-transfer rate in each of these flow branches is specified by flow demands from the thermal side of condensers or by thermal load information that may be read from a data file. The mechanical and electrical outputs from the cascade are not independent. For continuous operation of the power cycle, the energy required by specifying all of these energy-transfer rates must be supplied by thermal boilers and/or auxiliary boilers.

Simulation

No energy-transfer rates are independent, but the extraction rates from each turbine must be specified. The mechanical and electrical outputs of the turbine cascade and the energy-transfer rates from each flow branch vary as the energy that can be transferred from the thermal to the power sides of the thermal boilers varies.

A load management routine manages the energy transfer from generalized Rankine-type power cycles and performs energy accounting for each power loop. Load management also allows the user to (1) select one of the three operational modes discussed above, (2) select the electrical demands/parasitics and/or mechanical demands/parasitics that are satisfied by the power loop, and (3) direct the power loop to follow electrical and mechanical loads. In addition, the load management routine determines the unspecified fluid-flow rates and energy-transfer rates for each of the three operational modes and automatically informs the user if the independent energy-transfer rates defined by his input to the components in the power loop are under or overspecified.

SOLTES will simulate systems with parallel power loops, but load information must be provided separately for each power loop. Each power loop must operate in the POWER or HEAT mode.

Load management places the following restrictions on power loops:

1. Each power loop is a fluid loop that may include other components but must include a load management component, each turbine in the turbine cascade, all process-heat components from which the energy-transfer rate is independent, all regenerative heaters, and the power sides of all condensers.*
2. The load management component must be downstream of all boilers and upstream to all turbines, components following thermal loads, and condensers.

* For generalized power cycles that do not contain turbines and the energy-transfer rate from each process-heat component is unspecified, a load management component is not required.

APPENDIX C

Routine Library Index

This appendix contains the routine library of information, component, and system performance routines.

Routine Library Index

I. Information Routines

	<u>Subcategory</u>	<u>Section</u>	<u>Article</u>	<u>Description</u>	<u>Page</u>
1. Weather	-	1			C-I-1
WEATHR		1	1	TMY data and sun angle	C-I-3
2. Loads		2			C-I-5
DAREXL		2	1	Load definition	C-I-7

II. Component Routines

1. Thermodynamic Models					C-II-1
a. Air Conditioners	a	1			C-II-3
AIRCOND		1	1	Absorptive - COP model	C-II-3
ABSFLC [†]		1		Absorptive - COP model liquid-cooled	-----
VAPCM1 [†]		1	2	Vapor compression - COP model	-----
VAPCM2 [†]		1	3	Vapor compression - COP model liquid-cooled	-----
VAPCM3 [†]		1	4	Vapor compression - detailed model	-----
VAPCM4 [†]		1	5	Vapor compression - detailed model liquid-cooled	-----
b. Attenuator		2			-----
DCONAT [†]		2	1	Direct contact	-----
c. Boilers		3			C-II-5
THMBLR		3	1	Thermal boiler	C-II-5
AUXBLR		3	2	Auxiliary boiler	C-II-13
BOIL [†]		3	3	Boiler	-----
d. Collectors		4			C-II-17
FOCOL		4	1	Focusing collector-efficiency model	C-II-17
DISH		4	2	Parabolic dish - efficiency model	C-II-19
FLTPLT		4	3	Flat plate - detailed model	C-II-23
FOCMWE		4	4	Parabolic trough - detailed model	C-II-27
FLTPLE [†]		4	5	Flat plate - efficiency model	-----
e. Condensers		5	1		C-II-31
CNDHTR		5	1	Condenser - heater	C-II-31
COND [†]		5	2	Condenser	-----

Routine Library Index (cont)

	<u>Subcategory</u>	<u>Section</u>	<u>Article</u>	<u>Description</u>	<u>Page</u>
f. Cooling Towers	a	6			C-II-39
COOLTOW		6	1		C-II-39
g. Furnaces		7			C-II-41
AUXFUR		7	1	Auxiliary furnace	C-II-41
h. Heat Exchangers		8			C-II-43
HTEXC		8	1	Counter flow	C-II-43
i. Heating and Cooling		9			
HTCOL [†]		9	1	ASHRAE heating and cooling of buildings	-----
j. Hot Water Heaters		10			C-II-47
HOTWAT		10	1	With water makeup	C-II-47
WATHTR		10	2	Without water makeup	C-II-49
k. Load Management		11			C-II-51
LODMG		11	1	Complex Rankine cycle	C-II-51
l. Mixers		12			C-II-59
MIXJNT		12	1	Mixing junction - liquids	C-II-59
MIXFLD [†]		12	2	Mixing junction - liquids, liquid-vapor mixture, superheated vapors	-----
m. Miscellaneous		13			C-II-61
DUMCOM		13	1	Dummy component	C-II-61
MKPFLD		13	2	Makeup fluid	C-II-63
n. Pipes		14			C-II-67
PIPE		14	1		C-II-67
o. Power Generation [‡]		15			-----
TUCOPU [†]		15	1	Simple Rankine cycle - efficiency model	-----
p. Process Heat and Vapor		16			C-II-71
PRSVAP		16	1	Process vapor	C-II-71
PRCHT1 [†]		16	2	Process heat - condenser model	-----
PRCHT2 [†]		16	3	Process heat - thermal model	----
q. Pumps		17			C-II-75
PUMP		17	1	Heat-transfer fluid pump	C-II-75
BFDPMF		17	2	Boiler feed pump power-cycle fluids	C-II-77
IRGPMP [†]		17	3	Irrigation pump	-----
r. Regenerative Heaters		18			C-II-81
DCONHT		18	1	Direct contact	C-II-81

Routine Library Index (cont)

	Subcategory	Section	Article	Description	Page
s. Space Heaters	a	19			C-II-85
SPHEAT		19	1	Hot fluid system	C-II-85
ELRES [†]		19	2	Electrical resistance	-----
HTPMP1 [†]		19	3	Heat pump -COP model	-----
HTPMP2 [†]		19	4	Heat pump - COP model liquid source	-----
HTPMP3 [†]		19	5	Heat pump-detailed model	-----
HTPMP4 [†]		19	6	Heat pump-detailed model liquid source	-----
t. Thermal Storage					C-II-87
STORE1		20	1	Two-fluid sensible heat	C-II-87
STORE2		20	2	One-fluid sensible heat	C-II-91
STORE3		20	3	Two-fluid sensible heat intermediate-heat exchanger	C-II-93
STORE5		20	4	One-fluid sensible heat with mass accumulation	C-II-97
TCSTORE		20	5	Thermocline storage	C-II-101
u. Throttles		21			
THRTL [†]		21	1		
v. Turbines		22			C-II-105
XTURBG		22	1	Extraction turbine/ generator	C-II-105
TURBG		22	2	Turbine/generator	C-II-108
XTURB		22	3	Extraction turbine	C-II-111
TURB		22	4	Turbine	C-II-115
2. Controls	b				
a. Fluid Flow Control		1			C-II-119
FLODIV		1	1	Flow divider	C-II-119
FLOVLV		1	2	Flow valve	C-II-121
DIVJNT		1	3	Divide joint	C-II-123
SWITCH		1	4	Switch	C-II-125
TIMSWH		1	5	Time switch	C-II-127
b. Miscellaneous		2			-----
TIMER [†]		2	1	Timer	-----
c. Temperature		3			C-II-135
TEMCON		3	1	Heat-transfer fluid temperature control	C-II-135

Routine Library Index (cont)

	<u>Subcategory</u>	<u>Section</u>	<u>Article</u>	<u>Description</u>	<u>Page</u>
III. <u>System Performance</u>					
<u>Routines</u>					C-III-1
1. Energy Accounting		1			C-III-1
ENGAC1		1	1		C-III-3
2. Energy Summing		2			C-III-7
QMETER		2	1		C-III-9

[†] These routines are not currently available; however, they are either near completion or are simple extensions of methods now employed in SOLTES.

[‡] Complex Rankine-type power-generation cycles with load management can be modularly constructed from routines in this library (see Appendix B).

CI. INFORMATION ROUTINES

1. Weather

1. Weather

Subroutine WEATHR

Program Description -- WEATHR is an information routine that supplies the system model with time-varying weather information and sun angles. WEATHR reads typical meteorological year (TMY)* weather data from TAPE 12. Data for 26 stations are currently available. The routine also calculates the sun's azimuth angle from the south and elevation angle, using results of a geometric analysis.

The information read from TAPE 12 is:

Station No.
Year
Month
Day
Hour
Direct Normal Radiation ($\text{kJ}/\text{m}^2\text{hr}$)
Standard Year Corrected Total Horizontal ($\text{kJ}/\text{m}^2\text{hr}$)
Station Pressure (kPa)
Dry Bulb Temperature ($^{\circ}\text{C}$)
Wind Direction (degrees)
Windspeed (m/s)

(See p for TAPE 12 format)

Input --

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A6	1-6	"WEATHR"
SN	110	51-60	Station number
LAD	F10.0	61-70	Latitude** of station site (degrees) Blank $\Rightarrow$ table lookup
LON	F10.0	71-80	Longitude** of station site (degrees) Blank $\Rightarrow$ table lookup

Card 2

EOF

* I. J. Hall, R. R. Prairie, H. E. Anderson, and E. C. Boes, "Generation of Typical Meteorological Year for 26 SOLMET Stations," Nat'l Climatic Center in Ashville, NC, to be published.

**Latitude and longitude may be table lookup if station is one of 26 TMY data.

CI. INFORMATION ROUTINES

2. Loads

2. Loads

Subroutine DAREXL

Program Description -- DAREXL is an information routine that provides load or load-related information to one or more components in the system model. The load or load-related information is for the following types:

Electrical Power	"ELCLD"	(W)
Mechanical Power	"POWLD"	(W)
Thermal	"THMLD"	(kg/s or W)
Hot Water ¹	"HWATLD"	(m ³ /s or W)
Cooling	"COOLLD"	(W)
Heating	"HEATLD"	(W)
Heat ²	"HEAT"	(W)

Upon user direction, DAREXL will supply constant or time-varying information for any of the above types. DAREXL reads time-varying information from the user-supplied TAPE 11 (see p 2-12 for TAPE 11 format). The data contained on TAPE 11 may be combined by DAREXL in forming each load type. This feature of DAREXL allows the user to conduct parametric studies for evaluating the effects of individual loads or combinations of separate loads. It also allows simulation of peak-shaving and load-scaling. Up to four loads may be used in defining a load type.

Input --

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A6	1-6	"DAREXL"
ID ₁	A10	51-60	First word identifier of file on TAPE 11 (blank if all loads are constant)
ID ₂	A10	61-70	Second word identifier of file on TAPE 11 (blank if all loads are constant)

¹ Although the name implies hot water, this load can be used to provide load or load-related information for providing other hot liquids.

² HEAT is not a load or load information. However, the manner in which data for HEAT are defined in DAREXL is identical to the subsequent description for defining load or load-related information. See Section 1 for the definition of heat and loads.

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 2</u>			
TYPE	A10	1-10	Load type to be satisfied: "ELCLD", "POWLD", "THMLD", "HWATLD", "COOLLD", "HEATLD", "HEAT".
NUMBER	I10	11-20	Component number where load is to be used
FLAG	A10	21-24	"TAPE" $\Rightarrow$ loads to be read from tape or Constant value of load to be used
or	or	or	
CONSTANT	F10.0	21-30	
TEMP	F10.0	31-40	Character's temperature (K) needed only if TYPE = "THMLD)

Card 3

This card is required only if Col. 21-24 of Card 2 is "TAPE")

IVAR ₁ *	A10	1-10	Identifier for load variable
IVAR ₂	A10	21-30	Identifier if needed
IVAR ₃	A10	41-50	↓
IVAR ₄	A10	61-70	

Card 4

This card required only if 21-24 of Card 2 is "TAPE"

C ₁	F10.0	1-10	Coefficients for equation: TYPE (t) = C ₁ (IVAR ₁ (t) - B ₁) + C ₂ (IVAR ₂ (t) - B ₂) + C ₃ (IVAR ₃ (t) - B ₃) + C ₄ (IVAR ₄ (t) - B ₄)
B ₁	F10.0	11-20	
C ₂	F10.0	21-30	
B ₂	F10.0	31-40	
C ₃	F10.0	41-50	
B ₃	F10.0	51-60	
C ₄	F10.0	61-70	
B ₄	F10.0	71-80	

* These names need not be sequential on the file

NOTE: Cards 2, 3, and 4 may be repeated in defining up to 48 other load or load-related information data for the system model. After the last load has been defined, the user must include

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 5</u>			
ENDFLG	A4	1-4	"LAST"

Card 6

EOF

This completes the input to DAREXL.

Example Input --

```

DAREXL                               S14      TEST
THMLD          18.1          437.5
ELCLD          14TAPE
GRID           AIRCOND
.9      50000.      1.      0.
LAST
END OF FILE RECORD HERE

```

In this example, Component 18 is supplied for load type THMLD, with a characteristic temperature of 437.5 K, a constant value of 0.1 kg/s for its load-related data.

Component 14 is supplied a time-varying electrical load by combining loads "GRID" and "AIRCOND" from file "S14 TEST" on TAPE II. The equation used is

$$ELCLD(t) = 0.9(GRID(t) - 50000.) + AIRCOND(t)$$

Diagnostics -- Diagnostics are provided when

1. The user defines time-varying load without specifying the file from TAPE 11 (fatal).
2. DAREXL cannot find the file as specified on TAPE 11 (fatal).
3. DAREXL cannot find a specified load-variable identifier (fatal).

CII. COMPONENT ROUTINES

1. Thermodynamic Models

a. Air Conditioners

Subroutine AIRCOND*

Program Description--Subroutine AIRCOND models an absorption air-conditioning unit. The air conditioner removes energy from its inlet fluid and returns the fluid at a specified lower temperature. The rate of energy removal depends on the cooling loads and demands and the COP of the unit. Fluid-flow rate is calculated to satisfy all loads and demands.

Mathematical Algorithm--

$$\dot{m} = \frac{\sum (C_D + C_L)}{-\text{COP} \int_{T_i}^{T_o} C \, dT}$$

where

$\dot{m}$ = fluid-flow rate through air conditioner (kg/s)

C_D = cooling demand (COOLLD) (W)

C_L = cooling load (COOLDM) (W)

C = fluid specific heat (J/kg/K)

T_i = fluid inlet temperature (K)

T_o = fluid outlet temperature (K)

COP = coefficient of performance

Input--

* Open Type 1 thermodynamic model

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (AIRCOND)
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Upstream state number
TOFIX	F10.0	51-60	Fixed outlet temperature (K)
COP	F10.0	61-70	Coefficient of performance

<u>Card 2</u>			
LOAD	A10	1-10	LOAD = "COOLLD" if external cooling load is supplied by subroutine DAREXL. This field is blank when external loads are not supplied.
DEMAND	A10	11-20	DEMAND = "COOLDM" if component supplied cooling demands are to be met. This field is <u>blank</u> if no demands are to be met.
NCD	I5 or A5	21-80	List of component numbers supplying demands, in fields of five. If all cooling demands in the system are met by this air-conditioning component, the word "ALL" can be used in Columns 21-25.

Card 3

EOF

Table 2 Output--

<u>Parameter</u>	<u>Description</u>
EER	Rate at which energy is extracted from fluid (W)

Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
EER	Rate at which energy is extracted from fluid (W)
TO	Outlet temperature (K)
PO	Outlet pressure (Pa)
FM	Outlet flow rate (kg/s)

Note -- This component uses heat-transfer-fluid property data

c. Boilers

Subroutine THMBLR*

Program Description--THMBLR is a model for an adiabatic boiler wherein energy is transferred to the power-cycle working fluid (power side) by cooling a counterflowing heat-transfer fluid (thermal side). The power-side inlet and outlet states may be superheated vapor, liquid-vapor mixture, or compressed liquid states. Temperature differences between the power and thermal fluids at the thermal-side inlet and at the pinch-point or the power-side inlet are user input. Pressure is assumed constant in each side of THMBLR.

Mathematical Algorithm--

* Open Type 4 thermodynamic model

$$T_2 = T_3 - \Delta T_{23} \quad (1)$$

$$T_{\text{pnch}} = T_A + \Delta T_{\text{pnch}} \quad (2)$$

Case I. $T_2 > T_A$, $T_1 < T_A$, and $T_3 < T_{\text{pnch}}$

$$\dot{m}_p (h_2 - h_B) = \dot{m}_t \int_{T_{\text{pnch}}}^{T_3} C \, dT \quad (3)^1$$

$$\dot{m}_p (h_B - h_1) = \dot{m}_t \int_{T_4}^{T_{\text{pnch}}} C \, dT \quad (4)$$

$$\dot{Q}_{\text{PH}} = \dot{m}_p (h_B - h_1) \quad (5)$$

$$\dot{Q}_{\text{VP}} = \dot{m}_p (h_A - h_B) \quad (6)$$

$$\dot{Q}_{\text{SH}} = \dot{m}_p (h_2 - h_A) \quad (7)$$

$$T_{\text{SH}} = T_2 - T_A \quad (8)$$

Case II. $T_2 < T_1$ or $T_2 = T_1 \neq T_A$

The thermal- and power-side outlet states are set to ambient conditions,
and

$$\dot{m}_p = \dot{m}_t = \dot{Q}_{\text{PH}} = \dot{Q}_{\text{VP}} = \dot{Q}_{\text{SH}} = T_{\text{SH}} = 0 \quad (9)$$

Case III. $T_2 > T_A$ and $T_1 = T_A$

$$T_4 = T_{\text{pnch}} \quad (10)$$

If $T_4 \geq T_3$, algorithm is the same as for Case II.

$$\dot{m}_p (h_2 - h_1) = \dot{m}_t \int_{T_{\text{pnch}}}^{T_3} C \, dT \quad (11)^1$$

$$\dot{Q}_{PH} = 0 \quad (12)$$

$$\dot{Q}_{VP} = \dot{m}_p (h_A - h_1) \quad (13)$$

$$\dot{Q}_{SH} = \dot{m}_p (h_2 - h_A) \quad (14)$$

$$T_{SH} = T_2 - T_A \quad (15)$$

Case IV. $T_2 > T_A$, $T_1 > T_2$, and $T_1 < T_2$

$$T_4 = T_1 + \Delta T_{pnch} \quad (16)$$

If $T_4 \geq T_3$, algorithm is the same as for Case II; otherwise,

$$\dot{m}_p (h_2 - h_1) = \dot{m}_t \int_{T_3}^{T_4} C \, dT \quad (17)^1$$

$$\dot{Q}_{PH} = \dot{Q}_{VP} = 0 \quad (18)$$

$$\dot{Q}_{SH} = \dot{m}_p (h_2 - h_1) \quad (19)$$

$$T_{SH} = T_2 - T_A$$

Case V. $T_2 = T_A$ and $T_1 < T_A$

If $T_3 \leq T_{pnch}$, algorithm is the same as for Case II; otherwise,

$$\dot{m}_p (h_B - h_A) = \dot{m}_t \int_{T_{pnch}}^{T_3} C \, dT \quad (20)^1$$

$$\dot{Q}_{PH} = \dot{m}_p (h_B - h_1) \quad (21)$$

$$\dot{Q}_{VP} = \dot{m}_p (h_A - h_B) \quad (22)$$

$$\dot{Q}_{SH} = T_{SH} = 0 \quad (23)$$

Case VI. $T_2 > T_A$, $T_1 \leq T_A$, and $T_3 \leq T_{pnch}$

Fatal diagnostic

Case VII. $T_2 = T_1 = T_A$

If $T_3 \leq T_{pnch}$, algorithm is the same as for Case II; otherwise,

$$T_4 = T_{pnch}$$

$$\dot{m}_p (h_A - h_1) = \dot{m}_t \int_{T_{pnch}}^{T_3} C \, dT \quad (24)^1$$

$$\dot{Q}_{PH} = \dot{Q}_{SH} = T_{SH} = 0 \quad (25)$$

$$\dot{Q}_{VP} = \dot{m}_p (h_A - h_1) \quad (26)$$

Case VIII. $T_2 < T_A$, $T_1 < T_A$, and $T_2 > T_1$

$$T_4 = T_1 + \Delta T_{pnch}$$

If $T_4 \geq T_3$, algorithm is the same as for Case II; otherwise,

$$\dot{m}_p (h_2 - h_1) = \dot{m}_t \int_{T_4}^{T_3} C \, dT \quad (27)^1$$

$$\dot{Q}_{PH} = \dot{m}_p (h_2 - h_1) \quad (28)$$

$$\dot{Q}_{VP} = \dot{Q}_{SH} = T_{SH} = 0 \quad (29)$$

Case IX. $T_1 > T_A$, $T_2 > T_A$, and $T_2 > T_1$

$$T_4 = T_1 + \Delta T_{pnch} \quad (30)$$

If $T_4 \leq T_3$, algorithm is the same as for Case II; otherwise,

$$\dot{m}_p (h_2 - h_1) = \dot{m}_t \int_{T_4}^{T_3} C dT \quad (31)^1$$

$$\dot{Q}_{PH} = \dot{Q}_{VP} = 0 \quad (32)$$

$$\dot{Q}_{SH} = \dot{m}_p (h_2 - h_1) \quad (33)$$

$$T_{SH} = T_2 - T_A \quad (34)$$

For each of these cases,

$$\dot{Q} = \dot{Q}_{PH} + \dot{Q}_{VP} + \dot{Q}_{SH} \quad (35)$$

-when

$$\dot{Q} = 0, \text{ EFF} = 0$$

and when

$$\dot{Q} \neq 0, \text{ EFF} = \frac{\dot{Q}}{\dot{Q} + \dot{m}_p (h_{2'} - h_2)} \quad (36)$$

where

- $\dot{m}_p$ is the fluid-flow rate through the power side,
- $\dot{m}_t$ is the fluid-flow rate through the thermal side,
- h_1 is the specific enthalpy of the power fluid entering THMBLR,
- h_2 is the specific enthalpy of the power fluid leaving THMBLR,
- h_3 is the specific enthalpy of the thermal fluid entering THMBLR,
- h_4 is the specific enthalpy of the thermal fluid leaving THMBLR,
- A denotes the saturated vapor state of the power fluid at the pressure $P_p = P_1$,
- B denotes the saturated liquid state of the power fluid at the pressure $P_p = P_1$,

T_A is the power fluid saturation temperature,
 P_P is the power-side pressure,
 P_t is the thermal-side pressure,
 ΔT_{23} is the temperature difference between the thermal fluid and power fluid at the thermal-fluid inlet,
 ΔT_{pnch} is the temperature difference between the thermal fluid and power fluid at the pinch point or at the power-fluid inlet,
 T_1 is the temperature of the power fluid entering THMBLR,
 T_2 is the temperature of the power fluid leaving THMBLR,
 T_3 is the temperature of the thermal fluid entering THMBLR,
 T_4 is the temperature of the thermal fluid leaving THMBLR,
 T_{pnch} is the temperature of the thermal fluid at the pinch point,
 h_A is the specific enthalpy of the power fluid at the saturated vapor state,
 h_B is the specific enthalpy of the power fluid at the saturated liquid state,
 C is the specific heat of the thermal fluid,
 $\dot{Q}_{PH}$ is the preheater heat rate,
 $\dot{Q}_{VP}$ is the vaporizer heat rate,
 $\dot{Q}_{SH}$ is the superheater heat rate,
 $\dot{Q}$ is the boiler heat rate,
 T_{SH} is degrees superheat of the power fluid leaving THMBLR,
 EFF is the boiler effectiveness,
 $h_{2'}$ is the specific enthalpy of the power fluid at state 2'.

Input--

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A6	1-6	"THMBLR"
NCOMT	I10	11-20	Thermal-side component number
NSTAIT	I5	21-25	Thermal-side inlet state number
NCOMP	I5	31-35	Power-side component number
NSTAIP	I5	36-40	Power-side inlet state number
DT23	F10.0	51-60	Temperature difference between thermal-side inlet and power-side outlet states (K)
DTpnch	F10.0	61-70	Temperature difference between thermal fluid and power fluid at the pinch point or between the thermal-side outlet and power-side inlet states (K)

Card 2

EOF

Notes--

1. The thermal-side flow rate is calculated from this equation when the power side demands energy from the thermal side. The load management routine LODMG directs the boiler to demand energy from the thermal side in the POWER or HEAT operational modes. The power-side flow rate is calculated from this equation when the power side does not demand energy from the thermal side. The power side does not demand energy from the thermal side in systems with no load management or in system with LODMG in the simulation operational mode.
2. This component requires both heat-transfer-fluid properties and power-cycle working-fluid constants.

Table 2 Output--

<u>Parameter</u>	<u>Description</u>
T_{SH}	Power-side inlet superheat (K)
T_4	Vaporization temperature (K)
$\dot{Q}_{PH}$	Preheater heat rate (W)
$\dot{Q}_{VP}$	Vaporizer heat rate (W)

<u>Parameter</u>	<u>Description</u>
$\dot{Q}_{SH}$	Superheater heat rate (W)
$\dot{Q}$	Boiler heat rate (W)
EFF	Boiler effectiveness (%)

Tape 40 Output--

<u>Parameter</u>	<u>Description</u>
$\dot{Q}$	Boiler heat rate (W)
T_2	Power-side outlet temperature (K)
P_p	Power-side pressure (Pa)
$\dot{m}_p$	Power-side fluid-flow rate (kg/s)
$\dot{m}_t$	Thermal-side fluid-flow rate (kg/s)
EFF	Boiler effectiveness (%)

Subroutine AUXBLR*

Program Description--AUXBLR is a model for an adiabatic auxiliary boiler. The heat rates required for preheating, vaporizing, and superheating the fluid entering AUXBLR and leaving at the user-supplied thermodynamic state are calculated. The entering fluid may be a compressed liquid, liquid-vapor mixture, or superheated vapor. AUXBLR may be placed in series or parallel to other boilers in the system model.

Mathematical Algorithm--

Case I. $T_1 > T_2$, or $T_1 = T_2 \neq T_A$

Fatal diagnostic

Case II. $T_2 < T_A$

Fatal diagnostic

Case III. $T_1 < T_A$, $T_2 = T_A$

$$\dot{Q}_{PH} = \dot{m}(h_A - h_1) \quad (1)$$

$$\dot{Q}_{VP} = \dot{m}(h_2 - h_A) \quad (2)$$

$$\dot{Q}_{SH} = 0 \quad (3)$$

$$T_{SH} = 0 \quad (4)$$

* Open Type 1 thermodynamic model

$$T_1 < T_A, T_2 > T_A$$

$$\dot{Q}_{PH} = \dot{m}(h_A - h_1) \quad (5)$$

$$\dot{Q}_{VP} = \dot{m}(h_B - h_A) \quad (6)$$

$$\dot{Q}_{SH} = \dot{m}(h_2 - h_B) \quad (7)$$

$$T_{SH} = T_2 - T_B \quad (8)$$

Case IV. $T_1 = T_2 = T_A$

$$\dot{Q}_{PH} = \dot{Q}_{SH} = T_{SH} = 0 \quad (9)$$

$$\dot{Q}_{VP} = \dot{m}(h_2 - h_1) \quad (10)$$

Case V. $T_1 = T_A; T_2 > T_A$

$$\dot{Q}_{PH} = 0 \quad (11)$$

$$\dot{Q}_{VP} = \dot{m}(h_B - h_1) \quad (12)$$

$$\dot{Q}_{SH} = \dot{m}(h_2 - h_B) \quad (13)$$

$$T_{SH} = T_2 - T_B \quad (14)$$

Case VI. $T_1 > T_A, T_2 > T_1$

$$\dot{Q}_{PH} = \dot{Q}_{VP} = 0 \quad (15)$$

$$\dot{Q}_{SH} = \dot{m}(h_2 - h_1) \quad (16)$$

$$T_{SH} = T_2 - T_1 \quad (17)$$

Case VII. $\dot{m} = 0$

The outlet state is set to ambient conditions.

Input--

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A6	1-6	"AUXBLR"
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Inlet state number
T_2	F10.0	51-60	Outlet temperature (K)
X_2	F10.0	61-70	Outlet quality (%) if outlet state is a liquid-vapor mixture

Table 2 Output--

<u>Parameter</u>	<u>Description</u>
T_S	Vaporization temperature (K)
$\dot{Q}_{PH}$	Preheater heat rate (W)
$\dot{Q}_{VP}$	Vaporizer heat rate (W)
$\dot{Q}_{SH}$	Superheater heat rate (W)
$\dot{Q}$	Boiler heat rate (W)
T_{SH}	Outlet superheat (K)

Tape 40 Output--

<u>Parameter</u>	<u>Description</u>
P	Boiler pressure (Pa)
T_s	Vaporization temperature (K)
$\dot{Q}_{PH}$	Preheater heat rate (W)
$\dot{Q}_{VP}$	Vaporizer heat rate (W)

<u>Parameter</u>	<u>Description</u>
$\dot{Q}_{SH}$	Superheater heat rate (W)
$\dot{Q}$	Boiler heat rate (W)
T_{SH}	Outlet superheat (K)

Note--Power-cycle working-fluid constants are required by this component.

d. Collectors

Subroutine FOCOL*

Program Description -- Subroutine FOCOL is a simple model of a focusing collector based on known-collector efficiency. A specified fraction of the incident solar energy is transmitted to the fluid flowing through the collector. Two options are available. In the first, outlet temperature is specified. Fluid-flow rate through the collector needed to achieve this temperature is then calculated. In the second, outlet temperature is not specified. The inlet-flow rate is not changed and outlet temperature is calculated. When the sun's elevation angle is less than zero, the fluid-flow rate is set to zero, and outlet temperature and pressure are set to ambient conditions. Pressure drop through the collector is not calculated.

Mathematical Algorithm--

$$Q_f = W \cdot L \cdot \eta \cdot q_s \cdot N = \dot{m} \int_{T_i}^{T_o} C \, dT$$

$$\text{PRISUP} = [\text{ENT} + \text{ENS} (1 - \sin \alpha)] \cdot W \cdot L \cdot N$$

$$\text{THMLOS} = \text{PRISUP} - Q_f$$

where

Q_f = rate of energy transfer to fluid (W)

W = reflector width (m)

L = reflector length (m)

η = collector efficiency (-)

q_s = direct solar insolation (W/m^2)

N = number of collectors in parallel (-)

$\dot{m}$ = fluid-flow rate (kg/s)

C = fluid specific heat ($\text{J}/\text{kg}/\text{K}$)

T = fluid temperature (K)

T_i = fluid temperature at inlet conditions (K)

T_o = fluid temperature at outlet conditions (K)

$$\text{PRISUP} = [\text{ENT} + \text{ENS} (1 - \sin \alpha)] \cdot W \cdot L \cdot N$$

ENT = total horizontal solar insolation (W/m^2)

ENS = the specular insolation (W/m^2)

α = elevation angle

THMLOS = thermal loss (W)

* Open Type 1 thermodynamic model

Input--

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (FOCOL)
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Upstream state number
TOFIX	F10.0	51-60	Fixed outlet temperature (K) (when left blank, outlet temperature will be calculated)

<u>Card 2</u>			
NCOL	I10	11-10	Number of collectors in parallel
W	F10.0	11-20	Reflector width (m)
XL	F10.0	21-30	Reflector length (m)
FRACT	F10.0	31-40	Collector efficiency (-)

Card 3

EOF

Table 2 Output --

<u>Parameter</u>	<u>Description</u>
Q	Rate of energy transfer to fluid (W)

Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
Q	Rate of energy transfer to fluid (W)
TO	Outlet temperature (K)
PO	Outlet pressure (Pa)
FM	Outlet flow rate (kg/s)

Note-- This component uses heat-transfer-fluid property data.

Subroutine DISH*

Program Description--Subroutine DISH models a focusing dish reflector with its own receiver.

A complete field of collectors is specified in a regular diamond or rectangle pattern. Dish-shadowing calculations are made at each time step. Receiver efficiency is calculated based on an energy balance at the receiver. Dish efficiency combines reflectance, receiver efficiency, and shadowing effects. Rate of energy transfer to fluid flowing through the receiver is computed as a function of dish efficiency, area, and solar insolation. Two options are available for computation of the outlet fluid state. In the first, outlet temperature is specified. Fluid-flow rate through the receiver needed to achieve this temperature is then calculated. In the second, outlet temperature is not specified. The inlet-flow rate is not changed and outlet temperature is calculated. When the sun's elevation angle is less than zero, the fluid-flow rate is set to zero, and outlet temperature and pressure are set to ambient conditions. Pressure drop through the receiver is not calculated.

Mathematical Algorithm--

$$Q_{i,r} = q_s A_d \rho_d \eta_{shad} \quad ; \quad A_d = \frac{\pi}{4} D_d^2 \quad (1)$$

$$Q_{l,r} = A_r \left[\epsilon_r \sigma T_w^4 + h_c (T_w - T_a) \right] \quad (2)$$

$$\eta_r = \alpha_r - \frac{Q_{l,r}}{Q_{i,r}} \quad (3)$$

$$\eta_d = \rho_d \eta_{shad} \eta_r \quad (4)$$

$$Q_f = Q_{i,r} \eta_r N = \dot{m} \int_{T_i}^{T_o} C \, dT \quad (5)$$

$$PRISUP = [ENT + ENS (1 - \sin \alpha)] \cdot A_d \cdot N$$

$$THMLOS = PRISUP - Q_f$$

where

$Q_{i,r}$ = energy rate incident on receiver (W)

q_s = direct solar insolation (W/m^2)

ρ_d = dish reflectance (-)

* Open Type 1 thermodynamic model

* η_{shad} = fraction of dish reflector surface not shadowed (-)

D_d = dish diameter (m)

$Q_{l,r}$ = radiation and convection losses from receiver (W)

A_r = receiver aperture area (m^2)

ϵ_r = receiver emittance (IR) (-)

σ = Stephan-Boltzmann constant ($\text{W}/\text{m}^2/\text{K}^4$)

T_w = receiver wall temperature (K)

T_a = ambient air temperature (K)

h_c = convection heat-transfer coefficient ($\text{W}/\text{m}^2/\text{K}$)
(Note: $h_c = 22.713 \text{ W}/\text{m}^2/\text{K}$ is used)

η_r = receiver efficiency (-)

α_r = receiver absorptance (solar) (-)

η_d = dish efficiency (-)

Q_f = rate of energy transfer to fluid (W)

N = number of collectors in parallel (-)

$\dot{m}$ = fluid-flow rate (kg/s)

C = fluid specific heat ($\text{J}/\text{kg}/\text{K}$)

T = fluid temperature (K)

T_i = fluid temperature at inlet conditions (K)

T_o = fluid temperature at outlet conditions (K)

PRISUP = primary supply rate (W)

ENT = total horizontal solar insolation (W/m^2)

ENS = the specular insolation (W/m^2)

α = elevation angle

THMLOS = thermal loss (W)

Input --

* Subroutine furnished by J. C. Zimmerman, Sandia Laboratories, Dispersed Power Applications Division, Albuquerque, NM.

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (DISH)
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Upstream state number
TOFIX	F10.0	51-60	Fixed outlet temperature (K) (when left blank, outlet temperature will be calculated)

Card 2

NCOL	I10	1-10	Number of collectors in parallel
DISHDIA	F10.0	11-20	Dish diameter (m)
REFL	F10.0	21-30	Dish spectral reflectance
NSHAPE	A10	31-40	Field layout (rectangle or diamond)
SNS	F10.0	41-50	North-south dish spacing (m)
SEW	F10.0	51-60	East-west dish spacing (m)
DWEST	F10.0	61-70	Slope of land to the west (m/100 m)
DNORTH	F10.0	71-80	Slope of land to the north (m/100 m)

Card 3

AREC	F10.0	1-10	Receiver aperture area (m ²)
ABSOR	F10.0	11-20	Receiver absorptance (solar)
EMITT	F10.0	21-30	Receiver emittance (infrared)

Card 4

EOF

Table 2 Output --

<u>Parameter</u>	<u>Description</u>
HTFLD	Rate of energy transfer to fluid (W)
COLEFF	Dish efficiency

Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
HTFLD	Rate of energy transfer to fluid (W)
COLEFF	Dish efficiency (-)

TO

Outlet temperature (K)

PO

Outlet pressure (Pa)

FM

Outlet flow rate (kg/s)

Note--This component uses heat-transfer-fluid property data.

Subroutine FLTPLT*

Program Description -- Subroutine FLTPLT models a flat-plate collector with up to nine equally spaced glass plates above the receiver plate, which is insulated below (see figure).

Flat-Plate Collector With Equally Spaced Glass
Plates Above the Insulated Receiver Plate

The model considers visible spectrum and infrared radiative transfer between the glass and receiver plates, convective and radiative losses from the top plate, conductive transfer across the gaps between the plate surfaces, conductive losses through the insulation, and convective energy transfer into the fluid (assuming a uniform temperature-receiver plate). Energy balance equations for the glass plates and receiver plate are solved simultaneously to determine temperatures. The rate of energy transfer to the fluid is calculated.

Mathematical Algorithm -- **

$$\begin{aligned}\text{PRISUP} &= [\text{ENT} + \text{ENS} (1 - \sin \alpha)] \cdot A_r \cdot N \\ \text{THMLOS} &= \text{PRISUP} - Q_f\end{aligned}$$

*Open Type 1 thermodynamic model

**M. W. Edenburn and N. R. Grandjean, Energy System Simulation Computer Program - SOLSYS, SAND75-0048, Sandia Laboratories, Albuquerque, NM, June 1975.

where

PRISUP = primary supply rate (W)
 ENT = total horizontal solar insolation (W/m^2)
 ENS = the specular insolation (W/m^2)
 A_r = receiver area (m^2)
 N = number of collectors in parallel
 α = elevation angle
 THMLOS = thermal loss (W)
 Q_f = rate of energy transfer to fluid (W)

Input --

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (FLTPLTC)
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Upstream state number
NCOL	I10	51-60	Number of collectors in parallel
NG	I10	61-70	Number of glass plates
PERIFL	F10.0	71-80	Wetted perimeter of fluid channel (m)
<u>Card 2</u>			
ARFL	F10.0	1-10	Cross-sectional area of fluid channel (m^2)
XLFL	F10.0	11-20	Length of fluid channel (m)
ARPL	F10.0	21-30	Receiver area (m^2)
SPACPL	F10.0	31-40	Spacing between plates (m)
XLPL	F10.0	41-50	Receiver length (m)
BET	F10.0	51-60	Collector tilt from horizontal (degrees)
CGAP	F10.0	61-70	Thermal conductivity of gap between plates (W/m/K)
REFCV	F10.0	71-80	Receiver reflectance (visible)

Card 3

REFGV	F10.0	1-10	Glass reflectance (visible)
TRNGV	F10.0	11-20	Glass transmittance (visible)
EMTCI	F10.0	21-30	Receiver emittance (IR)
EMTGI	F10.0	31-40	Glass emittance (IR)
CONDINS	F10.0	41-50	Thermal conductivity of back insulation (W/m/K)
THCKINS	F10.0	51-60	Insulation thickness (m)

Table 2 Output --

<u>Parameter</u>	<u>Description</u>
EFF	Collector efficiency (-)
HTFLD	Rate of energy transfer to fluid (W)

Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
EFF	Collector efficiency (-)
HTFLD	Rate of energy transfer to fluid (W)
TO	Outlet temperature (K)
PO	Outlet pressure (Pa)
FM	Outlet flow rate (kg/s)

Note -- This component uses heat-transfer-fluid property data.

Subroutine FOCMWE*

Program Description--Subroutine FOCMWE determines the performance of a focusing cylindrical parabolic collector using the following assumptions.

1. The system is in equilibrium.
2. The incident sun's rays are parallel.
3. The reflector has a perfect parabolic surface.
4. Envelope- and receiver-tube temperatures are uniform circumferentially.
5. The envelope- and receiver-tube walls are thin and have no temperature gradient through them in the radial direction.

Energy balance equations for the envelope and receiver tube consider the following (see figure).

1. Solar-energy reflection and transmission.
2. Infrared radiation transfer between the receiver-tube surface and separate silvered envelope and envelope-window surfaces.
3. Radiation energy losses from the envelope's outside surface.
4. Convective heat transfer from the receiver tube to a fluid flowing in the receiver tube.
5. Convective heat transfer between the receiver tube and envelope.
6. Convective losses from the envelope to the ambient.
7. Wind velocity over the envelope.

Receiver-tube and envelope temperatures that solve the energy balance equations are determined using a nonlinear equation solver. The temperature rise of the fluid flowing through the receiver tube is computed.

End effects due to the sun's rays not being perpendicular to the collector's axis are considered.

Orientation for east-west, north-south, and tracking collectors are determined as functions of the sun's azimuth and elevation angles.

Fluid pressure drop through the receiver is calculated.

* Open Type thermodynamic model

Receiver Tube, Envelope Geometry

Mathematical Algorithm --*

$$\text{PRISUP} = [\text{ENT} + \text{ENS} (1 - \sin \alpha)] \cdot W \cdot L \cdot N$$

$$\text{THMLOS} = \text{PRISUP} - Q_f$$

where

PRISUP = primary supply rate (W)

ENT = total horizontal solar insolation (W/m^2)

ENS = the specular insolation (W/m^2)

W = reflector width (m)

L = reflector length (m)

N = number of collectors in parallel

α = elevation angle

THMLOS = thermal loss (W)

Q_f = rate of energy transfer to fluid (W)

Input --

* M. W. Edenburn, "Performance Analysis of a Cylindrical Focusing Collector and Comparison with Experimental Results," Solar Energy, 18, pp 437-444, 1976.

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (FOCMWE)
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Upstream state number
NCOL	I10	51-60	Number of collectors in parallel
RW	F10.0	61-70	Reflector width (m)
XLR	F10.0	71-80	Reflector length (m)
<u>Card 2</u>			
XLC	F10.0	1-10	Receiver length (m)
XF	F10.0	11-20	Focal length (m)
DE	F10.0	21-30	Receiver envelope diameter (m)
DC	F10.0	31-40	Receiver diameter (m)
DI	F10.0	41-50	Plug diameter (m)
BETAD	F10.0	51-60	Tilt angle for NS collector (degrees)
TYPE	A10	61-70	Collector type (NS, EW, or TR)
INL	I10	71-80	Inlet side (+1 if south or east)
<u>Card 3</u>			
REFRV	F10.0	1-10	Reflector reflectance (visible)
REFWV	F10.0	11-20	Window reflectance (visible)
TRNWV	F10.0	21-30	Window transmittance (visible)
REFCV	F10.0	31-40	Receiver reflectance (visible)
REFWI	F10.0	41-50	Window reflectance (IR)
EMTWI	F10.0	51-60	Window emittance (IR)
REFEI	F10.0	61-70	Silvered envelope reflectance (IR)
EMTEI	F10.0	71-80	Silvered envelope emittance (IR)

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 4</u>			
REFCI	F10.0	1-10	Receiver reflectance (IR)
EMTCI	F10.0	11-20	Receiver emittance (IR)
NAIR	F10.0	21-30	Annulus condition (-1 for conduction, 0 for low pressure convection, 1 for atmospheric-pressure convection)
CONDA	F10.0	31-40	Annulus heat-transfer parameter (thermal conductivity (W/m/K) for NAIR = -1; convective heat-transfer coefficient (W/m ² /K) for NAIR = 0; not required for NAIR = 1).

Card 5

EOF

Table 2 Output --

<u>Parameter</u>	<u>Description</u>
EFF	Collector efficiency (-)
HTFLD	Rate of energy transfer to fluid (W)

TAPE 40 Output --

<u>Parameter</u>	<u>Description</u>
EFF	Collector efficiency (-)
HTFLD	Rate of energy transfer to fluid (W)
TO	Outlet temperature (K)
PO	Outlet pressure (Pa)
FM	Outlet flow rate (kg/s)

Note -- This component uses heat-transfer-fluid property data.

e. Condensers

Subroutine CNDHTR*

Program Description--CNDHTR is a model for an adiabatic condenser heater wherein energy is removed from the power-cycle working fluid (power side) by heating a counterflowing heat-transfer fluid (thermal side). The power-side inlet and outlet states may be superheated vapor, liquid-vapor mixture, or compressed liquid states. Temperature differences between the power and thermal fluids at the thermal-side inlet and at the pinch-point or at the power-side inlet are user input. Pressure is assumed constant in each side of CNDHTR.

Mathematical Algorithm--*

* Open Type 4 thermodynamic model

$$T_2 = T_3 + \Delta T_{32} \quad (1)$$

$$T_{\text{pnch}} = T_A - \Delta T_{\text{pnch}} \quad (2)$$

Case I. $T_2 < T_A$, $T_1 > T_A$, and $T_3 < T_{\text{pnch}}$

$$\dot{m}_p (h_A - h_2) = \dot{m}_t \int_{T_3}^{T_{\text{pnch}}} C \, dT \quad (3)^1$$

$$\dot{m}_p (h_1 - h_A) = \dot{m}_t \int_{T_{\text{pnch}}}^{T_4} C \, dT \quad (4)$$

$$\dot{Q}_{LQ} = \dot{m}_p (h_B - h_2) \quad (5)$$

$$\dot{Q}_{LH} = \dot{m}_p (h_A - h_B) \quad (6)$$

$$\dot{Q}_{VP} = \dot{m}_p (h_1 - h_A) \quad (7)$$

$$TSH = T_1 - T_A \quad (8)$$

Case II. $T_2 > T_1$, or $T_2 = T_1 \neq T_A$

The thermal- and power-side outlet states are set to ambient conditions, and

$$\dot{m}_p = \dot{m}_t = \dot{Q}_{LQ} = \dot{Q}_{LH} = \dot{Q}_{VP} = \text{EFF} = T_{SH} = 0 \quad (9)$$

Case III. $T_2 < T_A$ and $T_1 = T_A$

$$T_4 = T_{\text{pnch}} \quad (10)$$

If $T_4 \leq T_3$, algorithm is the same as for Case II;

otherwise,

$$\dot{m}_p (h_1 - h_2) = \dot{m}_t \int_{T_3}^{T_{\text{pnch}}} C \, dT \quad (11)^1$$

$$\dot{Q}_{LQ} = \dot{m}_p (h_B - h_2) \quad (12)$$

$$\dot{Q}_{LH} = \dot{m}_p (h_A - h_B) \quad (13)$$

$$\dot{Q}_{VP} = T_{SH} = 0 \quad (14)$$

Case IV. $T_2 < T_A$, $T_1 < T_A$, and $T_1 > T_2$

$$T_4 = T_1 - \Delta T_{pnch} \quad (15)$$

If $T_4 \leq T_3$, algorithm is the same as for Case II;

otherwise

$$\dot{m}_p (h_1 - h_2) = \dot{m}_t \int_{T_3}^{T_4} C \, dT \quad (16)^1$$

$$\dot{Q}_{LQ} = \dot{m}_p (h_1 - h_2) \quad (17)$$

$$\dot{Q}_{LH} = \dot{Q}_{VP} = T_{SH} = 0 \quad (18)$$

Case V. $T_2 = T_A$ and $T_1 > T_A$

If $T_3 \geq T_{pnch}$, algorithm is the same as for Case II;

otherwise

$$\dot{m}_p (h_A - h_B) = \dot{m}_t \int_{T_3}^{T_{pnch}} C \, dT \quad (19)$$

$$\dot{m}_p (h_1 - h_A) = \dot{m}_t \int_{T_{pnch}}^{T_4} C \, dT \quad (20)$$

$$\dot{Q}_{LQ} = 0 \quad (21)$$

$$\dot{Q}_{LH} = \dot{m}_p (h_A - h_B) \quad (22)$$

$$\dot{Q}_{VP} = \dot{m}_p (h_1 - h_A) \quad (23)$$

$$T_{SH} = T_1 - T_A \quad (24)$$

Case VI. $T_2 < T_A$, $T_1 \geq T_A$, and $T_3 \geq T_{pnch}$

Fatal diagnostic

Case VII. $T_2 = T_1 = T_A$

If $T_3 \geq T_{pnch}$, algorithm is the same as for Case II;

otherwise

$$T_4 = T_{pnch}$$

$$\dot{m}_p(h_1 - h_B) = \dot{m}_t \int_{T_3}^{T_{pnch}} C \, dT \quad (25)^1$$

$$\dot{Q}_{LQ} = \dot{Q}_{VP} = T_{SH} = 0 \quad (26)$$

$$\dot{Q}_{LH} = \dot{m}_p(h_1 - h_B) \quad (27)$$

Case VIII. $T_2 > T_A$, $T_1 > T_A$, and $T_1 > T_2$

$$T_4 = T_1 - \Delta T_{pnch} \quad (28)$$

If $T_4 \leq T_3$, algorithm is the same as for Case II;

otherwise

$$\dot{m}_p(h_1 - h_2) = \dot{m}_t \int_{T_3}^{T_4} C \, dT \quad (29)^1$$

$$\dot{Q}_{LQ} = \dot{Q}_{LH} = 0 \quad (30)$$

$$\dot{Q}_{VP} = \dot{m}_p(h_1 - h_2) \quad (31)$$

$$T_{SH} = T_1 - T_A \quad (32)$$

Case IX. $T_1 < T_A$, $T_2 < T_A$, and $T_1 > T_2$ (32)

$$T_4 = T_1 - \Delta T_{pnch} \quad (33)$$

If $T_4 \leq T_3$, algorithm is the same as for Case II;

otherwise

$$\dot{m}_p (h_1 - h_2) = \dot{m}_t \int_{T_3}^{T_4} C \, dT \quad (34)^1$$

$$\dot{Q}_{LQ} = \dot{m}_p (h_1 - h_2) \quad (35)$$

$$\dot{Q}_{VP} = \dot{Q}_{LH} = T_{SH} = 0 \quad (36)$$

For each of these cases

$$\dot{Q} = \dot{Q}_{LQ} + \dot{Q}_{LH} + \dot{Q}_{VP} \quad (37)$$

when

$$\dot{Q} = 0, \text{ EFF} = 0$$

and when

$$\dot{Q} \neq 0, \text{ EFF} = \frac{\dot{Q}}{\dot{Q} + \dot{m}_p (h_2 - h_{2'})} \quad (38)$$

where

$\dot{m}_p$ is the fluid-flow rate through the power side,

$\dot{m}_t$ is the fluid-flow rate through the thermal side,

h_1 is the specific enthalpy of the power fluid entering CNDHTR,

h_2 is the specific enthalpy of the power fluid leaving CNDHTR,

h_3 is the specific enthalpy of the thermal fluid entering CNDHTR,

h_4 is the specific enthalpy of the thermal fluid leaving CNDHTR,

A denotes the saturated vapor state of the power fluid at the pressure $P_p = P_1$,

B denotes the saturated liquid state of the power fluid at the pressure $P_p = P_1$,

T_A is the power-fluid saturation temperature,

P_p is the power-side pressure,

P_t is the thermal-side pressure,

ΔT_{32} is the temperature difference between the power fluid and the thermal fluid at the thermal-fluid inlet,

ΔT_{pnch} is the temperature difference between the power fluid and the thermal fluid at the pinch-point or at the power-fluid inlet,

T_1 is the temperature of the power fluid entering CNDHTR,

T_2 is the temperature of the power fluid leaving CNDHTR,

T_3 is the temperature of the thermal fluid entering CNDHTR,

T_4 is the temperature of the thermal fluid leaving CNDHTR,

T_{pnch} is the temperature of the thermal fluid at the pinch point,

h_A is the specific enthalpy of the power fluid at the saturated vapor state,

h_B is the specific enthalpy of the power fluid at the saturated liquid state,

C_p is the specific heat at constant pressure of the thermal fluid,

$\dot{Q}_{LQ}$ is the rate at which energy is removed from the power fluid while it is a liquid,

$\dot{Q}_{LH}$ is the rate at which energy is removed from the power fluid while it is condensing,

$\dot{Q}_{SH}$ is the rate at which energy is removed from the power fluid while it is a superheated vapor,

$\dot{Q}$ is the condenser heat rate,

T_{SH} is degrees superheat of the power fluid entering CNDHTR,

EFF is the condenser effectiveness and $h_{2'}$ is the specific enthalpy of the power fluid at state 2'

Input--

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A6	1-6	"CNDHTR"
NCOM1	I10	11-20	Power-side component number
NSTAT1	I5	21-25	Power-side inlet state number
NCOM2	I5	31-35	Thermal-side component number
NSTAI2	I5	36-40	Thermal-side inlet state number
<u>Card 2</u>			
DT32	F10.2	1-10	Temperature difference between power-side outlet and thermal-side inlet states (K)
DT _{pnch}	F10.2	11-20	Temperature difference between power fluid and thermal fluid at the pinch-point or between the power-side inlet and thermal-side outlet states (K)
NBR			Cascade flow branch number
Option 1	A10		Blank $\Rightarrow$ this component does not determine the flow rate in a flow branch
Option 2	A4	21-24	"LAST"--this component determines the flow rate in the condensate return from the last turbine in the cascade
Option 3	I10	21-30	This component determines the flow rate in the flow branch number NBR in the turbine cascade
IQMTCH	I10	31-40	"1", "0", or blank IQMTCH = 1 $\Rightarrow$ the thermal-side demands energy from the power side; IQMTCH = 0 or blank $\Rightarrow$ the thermal side does not demand energy from the power side

Card 3

EOF

- Notes--1. The power-side flow rate is calculated from this equation when the thermal side demands energy from the power side. The thermal-side flow rate is calculated from this equation when the thermal side does not demand energy from the power side. If the thermal- and power-side flow rates are zero, the outlet states are set to the ambient state.
2. This component requires both heat-transfer-fluid properties and power-cycle working-fluid constants.

Table 2 Output--

<u>Parameter</u>	<u>Description</u>
T_{SH}	Power-side inlet superheat (K)
T_A	Power-side saturation temperature (K)
$\dot{Q}_{VP}$	Vapor-heat rate (W)
$\dot{Q}_{LH}$	Latent-heat rate (W)
$\dot{Q}_{LQ}$	Liquid-heat rate (W)
$\dot{Q}_c$	Condenser-heat rate (W)
EFF	Condenser effectiveness (%)

Tape 40 Output--

<u>Parameter</u>	<u>Description</u>
$\dot{Q}_c$	Condenser-heat rate (W)
T_2	Power-side outlet temperature (K)
P_p	Power-side pressure (Pa)
$\dot{m}_p$	Power-side fluid-flow rate (kg/s)
$\dot{m}_t$	Thermal-side fluid-flow rate (kg/s)
EFF	Effectiveness (%)

f. Cooling Towers

Subroutine COOLTOW*

Program Description -- Subroutine COOLTOW models a dry cooling tower with an outlet temperature specified for the tower. If the fluid's inlet temperature exceeds this specified temperature, the outlet temperature is set to the specified value. The rate at which energy must be removed from the fluid to reach the outlet temperature is calculated. If the fluid's inlet temperature is less than the specified temperature, the outlet temperature is set equal to the inlet temperature, and the energy extraction rate is zero.

Mathematical Algorithm --

$$\text{for } T_i > T_o, q = \dot{m} \int_{T_o}^{T_i} C dT \quad (1)$$

$$\text{for } T_i \leq T_o, q = 0 \quad (2)$$

$$\text{HEAT} = q$$

where

T_i = fluid inlet temperature (K)

T_o = fluid outlet temperature (K)

q = rate at which heat is lost by fluid (W)

$\dot{m}$ = fluid-flow rate (kg/s)

C = fluid specific heat (J/kg/K)

* Open Type 1 thermodynamic model

Subroutine COOLTOW

Input --

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (COOLTOW)
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Upstream state number
TOFIX	F10.0	51-60	Specified outlet temperature (K)

Card 2

EOF

Table 2 Output --

<u>Parameter</u>	<u>Description</u>
ENEXT	Rate of energy extraction from fluid (W)

Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
ENEXT	Rate of energy extraction from fluid (W)
TO	Outlet temperature (K)
PO	Outlet pressure (Pa)
FM	Outlet flow rate (kg/s)

Note -- This component uses heat-transfer-fluid property data.

g. Furnaces

Subroutine AUXFUR*

Program Description -- Subroutine AUXFUR models a furnace that heats a fluid flowing through the furnace. Fluid temperature at the furnace outlet is specified. Inlet fluid temperature is monitored, and if it is below the outlet temperature heat is added to the fluid at the furnace efficiency. Furnace heat rate necessary to maintain the desired outlet temperature is calculated. The rate at which energy must be supplied by the auxiliary source is also computed.

Mathematical Algorithm --

If $T_i \geq T_{o, \text{fix}}$, the furnace is not operated, $T_o = T_i$

If $T_i < T_{o, \text{fix}}$ (1)

$$Q = \dot{m} \int_{T_i}^{T_o} C \, dT \quad (2)$$

$$\text{AUXSUP} = Q/\eta \quad (3)$$

$$T_o = T_{o, \text{fix}} \quad (4)$$

$$\text{THMLOS} = \text{AUXSUP} - Q$$

where

- T_i = fluid inlet temperature (K)
- T_o = fluid outlet temperature (K)
- $T_{o, \text{fix}}$ = specified fluid-outlet temperature (K)
- Q = furnace-heat rate (W)
- $\dot{m}$ = fluid-flow rate (kg/s)
- C = fluid specific heat (J/kg/K)
- AUXSUP = rate of energy supplied by auxiliary source (W)
- η = thermal loss (W)
- THMLOS = thermal loss (W)

* Open Type 1 thermodynamic model

Input --

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (AUXFUR)
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Upstream state number
TOFIX	F10.0	51-60	Specified outlet temperature (K)
EFF	F10.0	61-70	Furnace efficiency

Card 2

EOF

Table 2 Output --

<u>Parameter</u>	<u>Description</u>
Q	Furnace heat rate (W)
AUXSUP	Rate of energy supplied by auxiliary source (W)

Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
Q	Furnace heat rate (W)
AUXSUP	Rate of energy applied by auxiliary source (W)
TO	Outlet temperature (K)
PO	Outlet pressure (Pa)
FM	Outlet flow rate (kg/s)

Note -- This component uses heat-transfer-fluid property data.

h. Heat Exchanger

Subroutine HTEXC *

Program Description -- Subroutine HTEXC models a counterflow heat exchanger. The heat exchanger is assumed to have a uniform heat-transfer coefficient between the two fluids. The local heat transfer depends on the heat-transfer area and coefficient and on the temperature difference between the two fluids. Temperature gradients due to local heat transfer are integrated to determine outlet temperatures.

Mathematical Algorithm -- for $\dot{m}_2 C_2 \neq \dot{m}_1 C_1$:

$$T_{o,1} = T_{i,1} + \frac{\dot{m}_2 C_2}{\dot{m}_1 C_1} (T_{i,2} - T_{o,2}) \quad (1)$$

$$T_{o,2} = \frac{T_{i,2} \left(1 - \frac{\dot{m}_2 C_2}{\dot{m}_1 C_1}\right) + T_{i,1} \left\{ \exp \left[\frac{UA}{\dot{m}_2 C_2} \left(1 - \frac{\dot{m}_2 C_2}{\dot{m}_1 C_1}\right)\right] - 1 \right\}}{\exp \left[\frac{UA}{\dot{m}_2 C_2} \left(1 - \frac{\dot{m}_2 C_2}{\dot{m}_1 C_1}\right)\right] - \frac{\dot{m}_2 C_2}{\dot{m}_1 C_1}} \quad (2)$$

for $\dot{m}_2 C_2 = \dot{m}_1 C_1$:

$$T_{o,1} = T_{i,1} + (T_{i,2} - T_{o,2}) \quad (3)$$

$$T_{o,2} = \frac{T_{i,2} + \frac{UA}{\dot{m}_2 C_2} T_{i,1}}{1 + \frac{UA}{\dot{m}_2 C_2}} \quad (4)$$

Rate of heat transfer is

$$Q = \dot{m} \int_{T_{o,1}}^{T_{i,1}} C_1 dT \quad (5)$$

* Open Type 4 thermodynamic model

where

$\dot{m}_1$ = fluid-flow rate - Side 1
 $\dot{m}_2$ = fluid-flow rate - Side 2
 C_1 = fluid specific heat - Side 1
 C_2 = fluid specific heat - Side 2
 $T_{o,1}$ = outlet-fluid temperature - Side 1
 $T_{o,2}$ = outlet-fluid temperature - Side 2
 $T_{i,1}$ = inlet-fluid temperature - Side 1
 $T_{i,2}$ = inlet-fluid temperature - Side 2
 U = overall heat-transfer coefficient ($W/m^2/K$)
 A = heat-transfer surface area (m^2)
 Q = rate of heat transfer from Side 1 fluid to Side 2 fluid

Input --

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (HTEXC)
NCOM1	I10	11-20	Component number - Side 1
NSTAI1	I5	21-25	Upstream state number - Side 1
NCOM2	I5	31-35	Component number - Side 2
NSTAI2	I5	36-40	Upstream state number - Side 2
U	F10.0	51-60	Heat-transfer coefficient ($W/m^2/K$)
S	F10.0	61-70	Heat-transfer surface area (m^2)

Card 2

EOF

Table 2 Output --

<u>Parameter</u>	<u>Description</u>
Q	Rate of heat transfer from Side 1 fluid to Side 2 fluid (W)

Tape 40 Output --

Q	Rate of heat transfer from Side 1 fluid to Side 2 fluid (W)
TO1	Outlet temperature - Side 1 (K)
PO1	Outlet pressure - Side 2 (Pa)
FM1	Outlet flow rate - Side 1 (kg/s)
TO2	Outlet temperature - Side 2 (K)
PO2	Outlet pressure - Side 2 (Pa)
FM2	Outlet flow rate - Side 2 (kg/s)

Note -- This component uses heat-transfer-fluid property data.

j. Hot Water Heaters

Subroutine HOTWAT*

Program Description--Subroutine HOTWAT determines the rate (a hot-water load HWATLD) at which energy must be supplied to heat water from the water supply temperature to the hot-water temperature. The water-supply temperature is user input; the hot-water temperature is the water temperature entering HOTWAT. The hot-water requirements (volumetric flow rate) may be read as a function of time from a data file.

Mathematical Algorithm --

If $m_i = 0$, HWATLD = 0, and the outlet pressure and temperature are set to ambient conditions; otherwise

$$T_o = T_s \quad (1)$$

$$P_o = P_s \quad (2)$$

$$\dot{m} = \rho_i G \quad (3)$$

where

$\dot{m}_i$ is the water-flow rate entering HOTWAT (kg/s)

$\dot{m}$ is the water-flow rate through HOTWAT (kg/s)

HWATLD is the hot-water load (W)

T_o is the temperature of the hot water leaving HOTWAT (K)

P_o is the pressure of the hot water leaving HOTWAT (Pa)

ρ_i is water density entering HOTWAT (kg/m³)

G is the volumetric flow rate of the hot water (m³/s)

T_i is the water-entering temperature (K)

T_s is the water-supply temperature (K)

P_s is the water-supply pressure (Pa)

C is the water specific heat (J/kg/K).

Input --

* Open Type 1 thermodynamic model

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (HOTWAT)
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Inlet state number
TOFIX	F10.0	51-60	Fixed water supply temperature (K)
POFIX	F10.0	61-70	Fixed water-supply temperature (K)

Card 2

EOF

Table 2 and Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
VFR	Hot-water volumetric flow rate (m^3/s)
HWATLD	Rate at which energy must be supplied to heat the water (W)

Notes--1. This component uses heat-transfer-fluid property data.

2. HWATLD load-related information must be defined for this routine in the information routine DAREXL. This information must be supplied to DAREXL as a volumetric flow rate (m^3/s).
3. Although the name and description imply that this routine simulates hot-water heaters, it is equally applicable for simulating devices that provide hot liquids other than water.

Subroutine WATHTR*

Program Description -- Subroutine WATHTR determines the rate (a hot-water load HWATLD) at which energy must be supplied to heat water from the makeup water temperature to the hot-water temperature. The state point number of the makeup water is user input. The hot-water supply temperature and pressure are the water temperature and pressure entering WATHTR. The hot-water requirements (volumetric flow rate) may be read as a function of time from a data file.

Mathematical Algorithm -- If $\frac{|G_i - G|}{G} > \epsilon_{RF}$ and $G \neq 0$, fatal diagnostic

$$\text{otherwise} \quad T_o = T_i \quad (1)$$

$$P_o = P_o \quad (2)$$

$$\dot{m} = \rho_i G \quad (3)$$

$$\text{HWATLD} = \dot{m} \int_{T_i}^{T_{MKP}} C \, dT \quad (4)$$

where

- G_i is the water volumetric flow rate entering WATHTR (m^3/s),
- G is the volumetric flow rate of the hot water (m^3/s),
- ϵ_{RF} is the steady-state relative convergence criteria for fluid flow rate (-),
- $\dot{m}$ is the water flow rate through WATHTR (kg/s),
- HWATLD is the hot-water load (W),
- T_o is the hot-water supply temperature (K)
- T_i is the temperature of the water entering WATHTR (K),
- ρ_i is the density of the hot water (kg/m^3),
- G is the volumetric flow rate of the hot water (m^3/s),
- T_{MKP} is the temperature of the makeup water (K)
- C is the water specific heat ($\text{J}/\text{kg}/\text{K}$).

* Open Type 1 thermodynamic model.

Input --

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A6	1-6	Subroutine name (WATHTR)
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Inlet state number
NMKP	I10	51-60	Outlet state number of component MKPFLD

Card 2

EOF

Table 2 and Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
VFR	Hot-water volumetric flow rate (m^3/s)
HWATLD	Rate that energy must be supplied to heat the water (W)

- Notes --
1. This component uses heat-transfer-fluid property data.
 2. HWATLD load-related information must be defined for this routine in the information routine DAREXL. This information must be supplied to DAREXL as a volumetric flow rate (m^3/s).
 3. Although the name and description imply that this routine simulates hot-water heaters, it is equally applicable for simulating devices that provide hot liquids other than water.

k. Load Management

Subroutine LODMG*

Program Description--LODMG is a model that provides load management for generalized Rankine-type power cycles and performs energy accounting for each power loop. LODMG also allows the user to (1) select one of the three power-loop operational modes discussed in Appendix B, (2) select the electrical demands and parasitics, mechanical power demands and/or parasitics that are satisfied by the power loop, and (3) direct the power loop to follow external electrical and/or mechanical power loads. In addition, LODMG determines the unspecified fluid-flow rates and energy-transfer rates for each of the three operational modes and automatically informs the user if the independent energy-transfer rates defined by this input to the components in the power loop are under - or overspecified.

Mathematical Algorithm--For each operational mode, the values of pressure, temperature, and quality at the inlet and outlet states are identical.

Power Mode

$$(A - B_I)\dot{m} = \sum_{i=1}^{I-1} (B_i - B_I)\dot{m}_i + \sum_{i=I+1}^{NT} (B_i - B_I)\dot{m}_i - B_I \dot{m}_{NT+1} + \frac{\dot{W}_M}{\eta_{M_{jun}}} + \frac{\dot{W}_E}{\eta_{G_{jun}}} \quad (1)$$

$$\dot{m}_I = \dot{m} - \sum_{i=1}^{I-1} \dot{m}_i - \sum_{i=I+1}^{NT+1} \dot{m}_i \quad (2)$$

$$\dot{W} = \dot{W}_E + \dot{W}_M \quad (3)$$

$$\dot{W}_E = ELCLD + ELCDM + ELCPS \quad (4)$$

$$\dot{W}_M = POWLD + POWDM + POWPS \quad (5)$$

where

A and B_i are functions of the enthalpy change, and mechanical efficiency of each turbine in the cascade; and the mechanical efficiency, electrical generating efficiency, and the ratio of mechanical and electrical power outputs of each turbine/generator in the cascade,

$\dot{m}$ is the fluid-flow rate through LODMG that is necessary to meet the electrical and mechanical power, and thermal loads; and the electrical demands and parasitics, mechanical power demands and parasitics satisfied by the power loop,

$\dot{m}_i$ is the fluid-flow rate through the i^{th} flow branch in the cascade,

$\dot{m}_I$ is the fluid-flow rate through the flow branch number I from which thermal loads are not specified or a flow rate is not demanded by a condenser,

NT is the number of turbines in cascade,

$\eta_{M_{\text{jun}}}$ is the mechanical efficiency of the turbine/generator for which the ratio of the mechanical and electrical outputs is unspecified (if there are no turbine/generators in the cascade, $\text{jun} = \text{NT}$)

$\eta_{G_{\text{jun}}}$ is the electrical-generator efficiency of the turbine/generator for which the ratio of the mechanical and electrical outputs is unspecified (if there are no turbine/generators in the cascade, $\text{jun} = \text{NT}$),

$\dot{W}$ is the total power output of the loop,

ELCLD are the electrical loads followed by this power loop and defined by Subroutine DAREXL,

ELCDM is the electrical power required to meet all the electrical demands satisfied by the power loop,

ELCPS is the electrical power required to meet all the electrical parasitics satisfied by the power loop,

POWLD are the mechanical power loads followed by this power loop and defined by Subroutine DAREXL,

POWDM is the mechanical power required to meet all the mechanical power demands satisfied by the power loop,

POWPS is the mechanical power required to meet all the mechanical power parasitics satisfied by the power loop.

Heat Mode

$$\dot{m} = \sum_{i=1}^{\text{NBR}} \dot{m}_i$$

(6)

$$\dot{W}_E = \sum_{i=1}^{NT} \dot{W}_{E_i} \quad (7)$$

$$\dot{W}_M = \sum_{i=1}^{NT} \dot{W}_{M_i} \quad (8)$$

$$\dot{W} = \dot{W}_E + \dot{W}_M \quad (9)$$

$$ELCLD = \dot{W}_E - ELCDM - ELCPS \quad (10)$$

$$POWLD = W_M - POWDM - POWPS \quad (11)$$

where

NBR is the number of flow branches in the turbine cascade,

$\dot{m}_i$ is the flow rate in the i^{th} flow branch that is required for a component in the flow branch to follow a thermal load or meet the flow-rate demand of a condenser,

$\dot{W}_{E_i}$ is the electrical power output of the i^{th} turbine in the cascade,

$\dot{W}_{M_i}$ is the mechanical power output of the i^{th} turbine in the cascade,

ELCLD is the electrical power crossing the system boundaries from LODMG. If ELCLD is negative, electrical power is required from the system's environment so that the electrical demands and parasitics are satisfied,

POWLD is the mechanical power crossing the system boundaries from LODMG. If POWLD is negative, mechanical power is required from the system's environment so that the mechanical demands and parasitics are satisfied,

W_E , W_M , ELCDM, ELCPS, POWDM, and POWPS are defined as for the POWER mode.

Simulation Mode -- The mathematical algorithm for the simulation mode is the same as that for the HEAT mode except the fluid-flow rate from LODMG is not calculated but is set equal to that entering.

Input--

Parameter	Format	Columns	Description
<u>Card 1</u>			
NAME	A5	1-5	"LODMG"
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Inlet state number
LOPMOD ¹	A5	51-55	Power loop operational mode "POWER", "HEAT", or blank; Blank ⇒ simulation mode
NLPB ²	I5	56-60	Fluid-loop number that contains the thermal boiler (THMBLR) that supplies the energy for this power loop; Blank ⇒; thermal-boiler loop number and this LODMG are in the same fluid loop
ELCLD	A10	61-70	Required only if LOPMOD = "POWER" Blank ⇒; no external electrical load is followed by this power loop. Otherwise an external electrical power load is read from component DAREXL and followed
POWLD	A10	71-80	Required only if LOPMOD = "POWER" Blank ⇒; no external mechanical load is followed by this power loop; otherwise an external mechanical power load is read from component DAREXL and followed

LODMG reads and processes demand definition cards in the following order:

Electrical demands - ELCDM

Electrical parasitics - ELCPS

Mechanical power parasitics - POWPS

Each demand card must be input in sequence until all the demands and parasitics for the power loop have been specified. For example, in power loops that satisfy electrical parasitics, both the ELCDM and ELCPS definition cards must be input to LODMG. However, the POWDM and POWPS cards may be omitted if the power loop is not directed to satisfy these demands and parasitics.

Demand and Parasitic Input Data Format

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
DEM	A5	1-5	Demand or parasitic type "ELCDM", "ELCPS", "POWDM", and "POWPS" denote electrical demands, electrical parasitics, mechanical power demands, and mechanical power parasitics, respectively.
DEMMOD	A4	11-14	<p>"ALL" ⇒ ; all type DEM parasitics or demands in the system model are satisfied by this power loop</p> <p>"NONE" ⇒ ; no type DEM demands or parasitics are satisfied for this power loop</p> <p>Blank ⇒ ; only those type DEM demands or parasitics required by the components, which are specified by the next series of cards, are satisfied by this power loop</p>
<u>Card 2</u>			
LPNO		1-5	Required only if Columns 11-14 of the previous card are blank
Option 1	A5	1-5	Blank ⇒ ; this power loop satisfies those type DEM demands or parasitics required by the components whose component numbers appear in Columns 11-80 of this card.
Option 2	I5	1-5	Fluid-loop number that contains components with type DEM demands or parasitics that are satisfied by this power loop
LPMD	A5	6-10	<p>Read only when Option 2 is used</p> <p>Blank ⇒ ; this power loop satisfies those type DEM demands or parasitics required by the components in the fluid loop designated by the number in Columns 1-5 of this card and whose component numbers appear in Columns 11-80 of this card</p> <p>"ALL" ⇒ ; this power loop satisfies all of the type DEM demands or parasitics required by components in the fluid loop designated by the number in Columns 1-5 of this card</p>

Parameter	Format	Columns	Description
NCOM ₁	I5	11-15	Component numbers for Option 1 or Option 2 with LPMD = Blank
NCOM ₂	I5	16-20	
.	↓	.	
.		.	
.		.	
NCOM ₁₄	I5	76-80	

Notes--1. See Appendix B for a discussion of power-loop operational modes.

2. Must be used to simulate parallel power loops.
3. After the last data card, there must be an EOF card.
4. Power-cycle working-fluid constants are required for this routine.

Examples--

- Example 1
- Inlet state number = 3
 - Component number = 5
 - LOPMOD = POWER
 - The power loop and thermal boiler are in the same fluid loop
 - External electrical loads are followed
 - No external mechanical power loads are followed
 - No electrical demands or parasitics or mechanical demands or parasitics are satisfied

LODMG Input--

LODMG 5 3 Power Yes
 EOF Card

- Example 2
- Inlet state number = 3
 - Component number = 5
 - LOPMOD = POWER
 - The power loop and thermal boiler are in the same fluid loop
 - No external electrical loads are followed
 - External mechanical-power loads are followed

- Electrical demands are required by components with component numbers 4, 6, and 8 and are satisfied by this power loop. No other components in the system model require electrical demands. Components 4 and 6 are in fluid-loop No. 1 while Component 8 is a closed component.
- No electrical parasitics or mechanical power or parasitics are to be satisfied by this power loop.

Example 2 Input:

```

LODMG      5  3      Power  Yes
          ELCDM      All
          EOF Card

```

Example 3 • Inlet state number = 3

- Component number = 5
- LOPMOD = HEAT
- The power loop is fluid loop No. 2
- Thermal boiler is in fluid loop No. 3
- Mechanical power parasitics are required by Components 7 and 8 in Fluid Loop 6 and by 11, 12, 13 in Fluid Loop 7. Other components in the system model may require mechanical power but are not satisfied by this power loop.
- No electrical demands or parasitics or mechanical demands are satisfied by this power loop.

Example 3 Input:

```

LOGMG      5  3      Heat    3
ELCDM      None
ELCPS      None
POWDM      None
POWPS
  7  8  11 12 13
          EOF Card

```

Note --The demand cards for POWPS could have been input as

```

POWPS 6    7  8
      7  11 12 13

```

1. Mixers

Subroutine MIXJNT*

Program Description--Subroutine MIXJNT combines fluid flow from two inlets into one outlet flow.

Mathematical Algorithm--

$$\dot{m}_o = \dot{m}_{i,1} + \dot{m}_{i,2} \quad (1)$$

$$T_o = \frac{\dot{m}_{i,1} T_{i,1} + \dot{m}_{i,2} T_{i,2}}{\dot{m}_o} \quad (2)$$

$$P_o = \frac{\dot{m}_{i,1} P_{i,1} + \dot{m}_{i,2} P_{i,2}}{\dot{m}_o} \quad (3)$$

where

$\dot{m}_o$ = fluid-flow rate at outlet

$\dot{m}_{i,1}$ = fluid-flow rate at Inlet 1

$\dot{m}_{i,2}$ = fluid-flow rate at Inlet 2

T_o = fluid temperature at outlet

$T_{i,1}$ = fluid temperature at Inlet 1

$T_{i,2}$ = fluid temperature at Inlet 2

P_o = fluid pressure at outlet

$P_{i,1}$ = fluid pressure at Inlet 1

$P_{i,2}$ = fluid pressure at Inlet 2

Input--

* Open Type 2 thermodynamic

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (MIXJNT)
NCOM	I10	11-20	Component number
NSTAI1	I5	21-25	Upstream state number - Inlet 1
NSTAI2	I5	36-40	Upstream state number - Inlet 2

Card 2

EOF

Table 2 Output -- None

Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
TO	Outlet temperature (K)
PO	Outlet pressure (Pa)
FM	Outlet flow rate (kg/s)

m. Miscellaneous

Subroutine DUMCOM*

Program Description--Subroutine DUMCOM supplies fluid at a constant outlet temperature and pressure. This component is often used when entire system simulation is not desired or when the operation of only one or two components is evaluated. Energy accounting does not include energy transfer required by DUMCOM.

Mathematical Algorithm--

$$T_o = T_{o,fix} \quad (1)$$

$$P_o = P_{o,fix}$$

where

T_o = fluid-outlet temperature (K)

$T_{o,fix}$ = specified fluid-outlet temperature (K)

P_o = fluid-outlet pressure (Pa)

$P_{o,fix}$ = specified fluid-outlet pressure (Pa)

Input--

* Open Type 1 thermodynamic model

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (DUMCOM)
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Inlet state number
TOFIX	F10.0	51-60	Fixed outlet temperature (K)
POFIX	F10.0	61-70	Fixed outlet pressure (Pa)

Card 2

EOF

Table 2 Output--None

Tape 40 Output--

<u>Parameter</u>	<u>Description</u>
TO	Outlet temperature (K)
PO	Outlet pressure (Pa)
FM	Fluid-flow rate (kg/s)

Subroutine MKPFLD*

Program Description--MKPFLD is a model that calculates the fluid-flow rate for steady-state operation of the system. MKPFLD does not require an inlet state number since the makeup fluid crosses the system boundary and, therefore, the inlet is not connected to any other component on the system. The fluid-flow rate required for makeup is determined by calculating the difference in fluid-flow rate at two user-supplied state points. The user also specifies if the makeup fluid is a heat-transfer fluid or a power-cycle working fluid. The rate at which energy is gained by the system (a negative advective loss) is calculated unless the user directs MKPFLD not to make this calculation. The reference state for this calculation is the ambient state for heat-transfer fluid makeup and the normal boiling point state for power-cycle makeup.

Mathematical Algorithm--

$$\dot{m} = \dot{m}_2 - \dot{m}_1 \quad (1)$$

If $\dot{m} \leq 0$, reset to $\dot{m} = 0$

$$T = T_{\text{fix}} \quad (2)$$

$$P = P_{\text{fix}} \quad (3)$$

$$\text{If IADV} = 0, \text{ ADLOSS} = 0 \quad (4)$$

If IADV = 1

$$\text{Heat-transfer fluids, ADLOS} = -\dot{m} \int_{T_{\text{amb}}}^T C_p dT \quad (5)$$

$$\text{Power-cycle working fluids, ADLOS} = -\dot{m}(h - h_{\text{ref}}) \quad (6)$$

where

$\dot{m}$ = the makeup fluid-flow rate,

$\dot{m}_2$ = the fluid-flow rate at state point NS2,

$\dot{m}_1$ = the fluid-flow rate at state point NS1, or =0,

T = the temperature of the makeup fluid,

T_{fix} = the fixed user-specified makeup fluid temperature,

*Open Type 1 thermodynamic model

P_{fix} = fixed user-specified makeup fluid pressure,
 $ADLOS$ = advective loss,
 C_p = heat-transfer fluid specific heat at constant pressure,
 T_{amb} = ambient pressure
 $(h-h_{ref})$ = enthalpy of the makeup fluid relative to the normal boiling point state.

Input--

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A6	1-6	"MKPFLLD"
NCOM	I10	11-20	Component number
T_{fix}	F10.0	51-60	Fixed makeup fluid temperature (K)
P_{fix}	F10.0	61-70	Fixed makeup fluid pressure (Pa)
NS1	I5	71-75	Reference 1 state number Blank $\Rightarrow \dot{m}_1 = 0$
NS2	I5	76-80	Reference 2 state number
<u>Card 2</u>			
TYPE	A5	1-5	"THERM" $\Rightarrow$ heat-transfer fluid "POWER" $\Rightarrow$ power-cycle working fluid
IADV	I5	6-10	Blank $\Rightarrow$ IADV = 1; advective gains are calculated No $\Rightarrow$ IADV = 0; advective gains are <u>not</u> calculated
<u>Card 3</u>			
EOF			

Table 2 Output--None

Tape 40 Output--

<u>Parameter</u>	<u>Description</u>
T	Makeup fluid temperature (K)
P	Makeup fluid pressure (Pa)
FM	Makeup fluid-flow rate (kg/s)

Note--Type = "THERM"; heat-transfer fluid properties are required.
Type = "POWER"; power-cycle working constants are required.

Subroutine PIPE*

Program Description -- Subroutine PIPE models thermal and viscous losses in a pipe. Thermal losses are computed based on an energy balance written for a differential pipe length. Pipe pressure drop is determined using a friction factor that is calculated as a function of Reynolds number. If pressure drop exceeds a specified acceptable drop, the pipe system is redesigned to meet the acceptable pressure drop.

Mathematical Algorithm --Outlet Temperature

$$T_o = T_a + (T_i - T_a) / \exp \left(\frac{\pi D L U}{\dot{m} C} \right) \quad (1)$$

where

T_o = outlet fluid temperature (K)

T_i = inlet fluid temperature (K)

T_a = ambient temperature (K)

D = pipe diameter (m)

L = pipe length (m)

$\dot{m}$ = fluid-flow rate (kg/s)

C = fluid specific heat (J/kg/K)

U = overall heat transfer coefficient ($W/m^2/K$)

For a pipe insulated with N layers of insulation

$$U = \frac{1}{r_1 \sum_{i=1}^N \frac{1}{k_i} \ln \left(\frac{r_{i+1}}{r_i} \right) + \frac{r_1}{r_N} \frac{1}{h_o}} \quad (2)$$

* Open Type 1 thermodynamic model

where

r_1 = pipe outside radius (m)

r_i = inside radius of i^{th} insulation layer (m)

k_i = thermal conductivity of i^{th} insulation layer (W/m/K)

h_o = outside convection heat transfer coefficient (W/m²/K)

Pressure Drop

$$p_o = p_i - \frac{1}{2} \rho f \frac{L}{D} V^2 \quad (3)$$

where

$$V = \frac{4\dot{m}}{\pi D^2 \rho}$$

and f is computed as a function of Reynolds number, Re .

$$Re = \frac{VD}{\nu}$$

for

$$0 < Re < 2100: f = 64/Re \quad (4)$$

$$2100 \leq Re < 10,000: f = 0.0305 + 0.0037(Re - 2100)/7900 \quad (5)$$

$$Re \geq 10,000: f = 0.008 + 0.5/Re^{0.32} \quad (6)$$

where

p_o = outlet fluid pressure (Pa)

p_i = inlet fluid pressure (Pa)

ρ = fluid density (kg/m³)

f = pipe friction factor (-)

V = fluid velocity (m/s)

ν = fluid kinematic viscosity (m²/s)

Energy Loss Rate

$$\dot{E}_\ell = - \dot{m} \int_{T_i}^{T_o} C dT \quad (7)$$

$$THMLOS = \dot{E}_\ell$$

where

$$\dot{E}_\ell = \text{pipe energy loss rate (W)}$$

THMLOS = thermal loss (W)

Input --

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (PIPE)
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Upstream state number
XL	F10.0	51-60	Pipe length (m)
DI	F10.0	61-70	Pipe diameter (m)
H	F10.0	71-80	Overall heat-transfer coefficient (W/m ² /K)
<u>Card 2</u>			
NPIPE	I10	1-10	Number of pipes in parallel
PLOSS	F10.0	11-20	Maximum acceptable pressure drop (fraction of inlet pressure)
<u>Card 3</u>			
EOF			

Table 2 Output --

<u>Parameter</u>	<u>Description</u>
ELR	Rate of energy loss (W)

Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
ELR	Rate of energy loss (W)
TO	Outlet temperature (K)
PO	Outlet pressure (Pa)
FM	Outlet flow rate (kg/s)

Note -- This component uses heat-transfer-fluid property data.

Subroutine PRSVAP*

Program Description -- PRSVAP is a model for a device that supplies process vapor at a specified saturation temperature. The process-vapor flow-rate requirements are defined in Subroutine DAREXL as load information for a thermal load at the specified saturation temperature, or process vapor is supplied at an unspecified rate. The inlet temperature may be greater than the specified saturation temperature. Fluid losses in the device are considered part of the energy requirement for supplying the process vapor (a thermal load) and are assumed to be lost at the outlet thermodynamic state. Energy is transferred from PRSVAP as heat; the heat-transfer rate is either the thermal load or the rate at which this energy must be removed from a region to maintain it at ambient pressure and at the user-supplied reference temperature.

Mathematical Algorithm --

$$\text{THMLD} = \dot{m}_1(h_1 - h_2) + \dot{m}_3(h_2 - h_4) \quad (1)$$

$$\dot{m}_3 = X\dot{m}_1 \quad (2)$$

$$|T_S - \text{Temp}| \leq \text{TOL or fatal diagnostic} \quad (3)$$

and

$$\text{HEAT} = \text{THMLD} \quad (4)$$

or

$$\text{HEAT} = \dot{m}_1(h_1 - h_2) + \dot{m}_3(h_2 - h_{\text{ref}}) \quad (5)$$

where

THMLD = thermal load (W),

$\dot{m}_1$ = fluid-flow rate into PRSVAP (the process-vapor flow rate) (kg/s),

$\dot{m}_3$ = fluid flow losses in PRSVAP (kg/s),

* Open Type 1 thermodynamic model

X = fraction of the inlet flow that is lost from PRSVAP,
 T_S = saturation temperature at the inlet pressure (K),
Temp = process-vapor temperature (K),
TOL = temperature tolerance (K),
 $(h_1 - h_2)$ = drop in specific enthalpy as the fluid flows through PRSVAP (J/kg)
 $(h_2 - h_4)$ = difference in enthalpy between the outlet state and the thermodynamic state of the makeup fluid (J/kg),
HEAT = rate at which energy is transferred as heat from PRSVAP (W),
 $(h_2 - h_{ref})$ = difference in enthalpy between the outlet state and the state defined by the user-supplied reference temperature and ambient pressure (J/kg).

Input --

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A6	1-6	"PRSVAP"
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Inlet state number
T_2	F10.0	51-60	Outlet state temperature
P_2		61-70	Outlet state pressure
Option 1	F10.0	61-70	Value for pressure (Pa)
Option 2	A10	61-70	Blank $\Rightarrow$ exit state will be defined by X_2 and T_2 ; i.e., liquid-vapor mixture
X_2	F10.0	71-80	Required only for Option 2 exit state quality - value 0 to 100%

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 2</u>			
TEMP	F10.0	1-10	Process-vapor temperature (K) If IQMTCH = 1, this value must be equal to the temperature associated with the thermal load in DAREXL
X	F10.0	11-20	Fluid-flow loss-percent of inlet flow
NBR		21-30	Flow branch number in turbine cascade
Option 1	A10	21-30	Blank - This component does not determine the fluid-flow rate in a flow branch in the turbine cascade. IQMTCH must be 0.
Option 2	A4	21-23	"LAST" - This component determines the fluid-flow rate in the condensate return from the last turbine in the cascade. IQMTCH must be 1.
Option 3	I10	21-30	This component determines the fluid-flow rate in flow branch number NBR in the turbine cascade. IQMTCH must be 1.
IQMTCH	I10	31-40	IQMTCH = 0 $\Rightarrow$ A thermal load is not followed. IQMTCH = 1 $\Rightarrow$ A thermal load is followed and must be defined in DAREXL.
TOL	A10	41-50	The allowable tolerance between the process-vapor temperature TEMP and the saturation temperature of the inlet state.
Option 1	A10	41-50	Blank - defaults to steady-state absolute temperature convergence error.
Option 2	F10.0	41-50	Value (K)
N _{MKP}	I10	51-60	Outlet state number of component MKPFLD
T _{ref}	F10.0	61-70	Reference temperature
Option 1	A10	61-70	Blank $\Rightarrow$ The heat-transfer rate from PRSVAP is the thermal load
Option 2	F10.0	61-70	T _{ref} (K) $\Rightarrow$ The heat-transfer rate from PRSVAP is the rate at which the energy from PRSVAP must be removed from a region to maintain it at ambient pressure and at T _{ref} .

Card 3

EOF

Table 2 Output --

<u>Parameter</u>	<u>Description</u>
THMLD	Energy required to supply to process vapor
$\dot{m}_3$	Fluid-flow rate loss (kg/s)
HEAT	Heat-transfer rate (W)

Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
THMLD	Energy required to supply the process vapor (W)
$\dot{m}_3$	Fluid-flow rate loss (kg/s)
HEAT	Heat-transfer rate (W)

Note -- The component requires power-cycle working-fluid constants.

q. Pumps

Subroutine PUMP*

Program Description -- Subroutine PUMP models a pump. The pump restores fluid pressure to a specified value and computes the necessary power. Two options are available for outlet flow rate. In the first, the pump maintains a fixed volume flow rate. In the second, the outlet mass flow rate is set equal to the inlet mass flow rate. Outlet temperature is set equal to the inlet temperature.

Mathematical Algorithm --

$$\text{ELCPS} = \frac{\dot{v}(p_o - p_i)}{\eta} \quad (1)$$

$$\dot{v} = \dot{v}_{\text{fixed}} \text{ for "FIXED" operation} \quad (2)$$

$$\dot{v} = \frac{\dot{m}}{\rho_f} \text{ for "VARIABLE" operation} \quad (3)$$

where

ELCPS = pump power (electrical parasitic) (W)

$\dot{v}$ = volume-flow rate (m^3/s)

p_o = pump-outlet pressure (Pa)

p_i = pump-inlet pressure (Pa)

η = pump efficiency (-)

$\dot{m}$ = mass-flow rate (kg/s)

ρ_f = fluid density (kg/m^3)

* Open Type 1 thermodynamic model

Input --

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (PUMP)
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Upstream state number
PFIX	F10.0	51-60	Fixed outlet pressure (Pa)
EFF	F10.0	61-70	Pump efficiency
NPUOP	A10	71-80	Pump operation ("FIXED" or "VARIABLE")

<u>Card 2</u>			
FMV	F10.0	1-10	Fixed volume-flow rate (m^3/s) (only required when NPUOP = FIXED)

Card 3
EOF

Table 2 Output --

<u>Parameter</u>	<u>Description</u>
ELCPS	Pump power used (W)

Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
ELCPS	Pump power used (W)
TO	Outlet temperature (K)
PO	Outlet pressure (Pa)
FM	Outlet flow rate (kg/s)

Note -- This component uses heat-transfer-fluid property data.

Subroutine BFDMP*

Program Description -- BFDMP is a model for a boiler-feed pump. The power required to operate the pump is either an electrical- or mechanical-power parasitic.

Mathematical Algorithm -- The power required to run the pump is given by

$$\dot{W}_p = \frac{v_1(P_2 - P_1)\dot{m}}{\eta_I \eta_M} \quad (1)$$

and the liquid temperature at the pump outlet is obtained by inverting the following equation

$$[h_2(T_2, P_2) - h_1] = \eta_M \dot{W}_p \quad (2)$$

and

$$G = \dot{m}V_1 \quad (3)$$

where

- $\dot{W}_p$ = power required to run the pump (W)
- v_1 = specific volume of liquid entering the pump (m^3/kg),
- P_2 = pressure of the liquid leaving the pump point (Pa),
- P_1 = pressure of the liquid entering the pump (Pa),
- $\dot{m}$ = liquid flow rate through the pump (kg/s),
- η_I = isentropic efficiency of the pump (-),
- η_M = mechanical efficiency of the pump (-),
- $[h_2(T_2, P_2) - h_1]$ = liquid enthalpy rise through the pump (J/kg),
- G = volumetric flow rate through the pump (m^3/s).

* Open Type 1 thermodynamic model

Input --

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A6	1-6	"BEDPMP"
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Inlet state number
P2	E10.4	51-60	Outlet pressure (Pa)
ETAI	F10.2	61-70	Pump isentropic efficiency (%)
ETAM	F10.2	71-80	Pump mechanical efficiency (%)
<u>Card 2</u>			
PARMOD	A10	1-10	Blank => pump power is supplied by electrical power. ¹ Power => pump power is supplied by mechanical power. ²
<u>Card 3</u>			
EOF			

Table 2 Output --

<u>Parameter</u>	<u>Description</u>
G	Liquid volumetric flow rate (m ³ /s)
$\dot{W}_P$	Pump power requirements (W)

Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
G	Liquid volumetric flow rate (m^3/s)
$\dot{W}_P$	Pump power requirements (W)
T_2	Outlet temperature (K)
$\dot{m}$	Liquid flow rate (kg/s)

- Notes --
1. The electrical power supplied is an electrical parasitic; i.e., $\text{ELCPS} = \dot{W}_P$, $\text{POWPS} = 0$.
 2. The mechanical power supplied is a mechanical power parasitic; i.e., $\text{POWPS} = \dot{W}_P$, $\text{ELCPS} = 0$.
 3. This routine requires power-cycle working-fluid constants.

r. Regenerative Heaters

Subroutine DCONHT*

Program Description -- DCONHT is a model for a direct contact, regenerative heater. Fluid in the liquid state flows into one inlet and is mixed and heated by fluid entering through the other inlet. The same fluid type must flow through both inlets. The heating fluid may enter DCONHT as a liquid-vapor mixture or as a superheated vapor but not as a compressed liquid. The fluid mixture leaves DCONHT as a compressed liquid at user-supplied values for pressure and temperature. The hotter fluid-flow rate and the outlet fluid-flow rate are calculated; the heating fluid-flow rate is the fluid-flow rate through the flow branch in the turbine cascade designated by user-input.

Mathematical Algorithm --

$$\dot{m}_2 = \dot{m}_1 \frac{(h_3 - h_1)}{(h_2 - h_3)} \quad (1)$$

$$\dot{m}_3 = \dot{m}_1 + \dot{m}_2 \quad (2)$$

$$\dot{Q} = \dot{m}_1 (h_3 - h_1) \quad (3)$$

where

$\dot{m}_2$ = fluid-flow rate of the hotter fluid (kg/s),

$\dot{m}_1$ = liquid flow rate (kg/s),

$(h_3 - h_1)$ = enthalpy rise of the liquid (J/kg),

$(h_2 - h_3)$ = enthalpy drop of the hotter fluid (J/kg),

$\dot{m}_3$ = fluid-flow rate leaving DCONHT (kg/s),

$\dot{Q}$ = regeneration heat rate (W).

* Open Type 2 thermodynamic model

Input --

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A6	1-6	"DCONHT"
NCOM	I10	11-20	Component number
NSTAI1	I5	21-25	Inlet 1 state number - the liquid inlet
NSTAI2	I5	36-40	Inlet 2 state number - the heating-fluid inlet
T3	F10.4	51-60	Outlet temperature (K)
P3	E10.4	61-70	Outlet pressure (Pa)
NBR		71-80	Flow branch number in turbine cascade
Option 1	A10	71-80	Blank => this component does not determine the fluid-flow rate in a flow branch in the turbine cascade
Option 2	A4	71-80	"LAST" - this component determines the fluid-flow rate in the condensate return from the last turbine in the cascade
Option 3	I10	71-80	This component determines the fluid-flow in flow branch number NBR in the turbine cascade

Card 2

EOF

Table 2 Output --

<u>Parameter</u>	<u>Description</u>
$\dot{Q}$	Regeneration heat rate (W)

Tape 40 Output --

Parameter

Description

$\dot{Q}$

Regeneration heat rate (W)

Note -- This component requires power-cycle working-fluid constants.

s. Space Heaters

Subroutine SPHEAT*

Program Description--Subroutine SPHEAT models a space-heating unit which removes energy from its inlet fluid and returns it at a specified lower temperature. The rate of energy removal depends on the heating demands and heating loads specified on input. Fluid-flow rate is calculated to satisfy all loads and demands.

Mathematical Algorithm--

$$\dot{m} = \frac{\sum (H_D + H_L)}{-\int_{T_i}^{T_o} C dT}$$

where

$\dot{m}$ = fluid-flow rate through space heater (kg/s)

H_D = heating demand (HEATDM) (W)

H_L = heating load (HEATLD) (W)

C = fluid specific heat (J/kg/K)

T_i = fluid inlet temperature (K)

T_o = fluid outlet temperature (K)

Input--

*Open Type 1 thermodynamic model

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (SPHEAT)
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Upstream state number
TOFIX	F10.0	51-60	Fixed outlet temperature (K)

<u>Card 2</u>			
LOAD	A10	1-10	If external heating load is supplied by subroutine DAREXL, LOAD = HEATLD. If external heating load is not supplied, this field is blank.
DEMAND	A10	11-20	DEMAND = HEATDM if component-supplied heating demands are to be met. This field is blank if no demands are to be met.
NCD	I5 or A5	21-80	List of component numbers supplying demands in fields of five. If all demands are to be met by this space-heating component, the word "ALL" can be used in Columns 21-25.

Card 3

EOF

Table 2 Output --

<u>Parameter</u>	<u>Description</u>
EER	Rate at which energy is extracted from fluid (W)

Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
EER	Rate at which energy is extracted from fluid (W)
TO	Outlet temperature (K)
PO	Outlet pressure (Pa)
FM	Outlet flow rate (kg/s)

Note -- This component uses heat-transfer-fluid property data.

t. Thermal Storage

Subroutine STORE1*

Program Description--Subroutine STORE1 models a two-fluid, mixed, sensible-heat-storage unit (see figure). The storage unit consists of two reservoirs that may contain two different fluids. Heat is transferred from the warmer to the cooler fluid through the separating wall. Temperatures in each reservoir are assumed to be uniform (perfect mixing), and the outlet fluid temperature of each reservoir is equal to the reservoir temperature. Reservoir temperatures change with time due to heat transfer between reservoirs and due to the reservoir's inlet fluid temperature being either warmer or cooler than the reservoir's temperature.

Storage Unit for STORE1

Mathematical Algorithm--

Storage Temperature

$$T_{s,1} = T_{s,1 \text{ old}} + \frac{\dot{m}_1(T_{i,1} - T_{s,1 \text{ old}}) \Delta t}{M_1} - \frac{\bar{h}_c A(T_{s,1 \text{ old}} - T_{s,2 \text{ old}}) \Delta t}{M_1 C_1} \quad (1)$$

$$T_{s,2} = T_{s,2 \text{ old}} + \frac{\dot{m}_2(T_{i,2} - T_{s,2 \text{ old}}) \Delta t}{M_2} + \frac{\bar{h}_c A(T_{s,1 \text{ old}} - T_{s,2 \text{ old}}) \Delta t}{M_2 C_2} \quad (2)$$

* Open Type 4 thermodynamic model

where

$$\bar{h}_c = \frac{h_{c,1} h_{c,2}}{h_{c,1} + h_{c,2}}$$

$T_{s,1}$ = stored fluid temperature - Side 1 (K)

$T_{s,1 \text{ old}}$ = stored fluid temperature - Side 1 at previous time (K)

$T_{s,2}$ = stored fluid temperature - Side 2 (K)

$T_{s,2 \text{ old}}$ = stored fluid temperature - Side 2 at previous time (K)

$T_{i,1}$ = fluid inlet temperature - Side 1 (K)

$T_{i,2}$ = fluid inlet temperature - Side 2 (K)

$\dot{m}_1$ = fluid-flow rate - Side 1 (kg/s)

$\dot{m}_2$ = fluid-flow rate - Side 2 (kg/s)

M_1 = fluid mass stored in Side 1 (kg)

M_2 = fluid mass stored in Side 2 (kg)

C_1 = fluid specific heat - Side 1 (J/kg/K)

C_2 = fluid specific heat - Side 2 (J/kg/K)

Δt = time increment(s)

$h_{c,1}$ = convection-heat-transfer coefficient, wall to fluid - Side 1 (W/m²/K)

$h_{c,2}$ = convection-heat-transfer coefficient wall to fluid - Side 2 (W/m²/K)

A = heat-transfer area between Sides 1 and 2 (m²)

Energy Storage Rate

$$\dot{E}_{s,1} = \dot{m}_1 (C_{1i} T_{i,1} - C_{1s} T_{s,1}) \quad (3)$$

$$\dot{E}_{s,2} = \dot{m}_2 (C_{2i} T_{i,2} - C_{2s} T_{s,2}) \quad (4)$$

where

$E_{s,1}$ = rate of energy storage - Side 1 (W)

$E_{s,2}$ = rate of energy storage - Side 2 (W)

C_{1i} = fluid specific heat at Inlet 1 conditions (J/kg/K)

C_{2i} = fluid specific heat at Inlet 2 conditions (J/kg/K)

C_{1s} = fluid specific heat at Side 1 storage conditions (J/kg/K)

C_{2s} = fluid specific heat at Side 2 storage conditions (J/kg/K)

Input--

Parameter	Format	Columns	Description
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (STORE1)
NCOM1	I10	11-20	Component number - Side 1
NSTAI1	I5	21-25	Upstream state number - Side 1
NCOM2	I10	31-35	Component number - Side 2
NSTAI2	I5	36-40	Upstream state number - Side 2
H1	F10.0	51-60	Wall convection heat-transfer coefficient - Side 1 (W/m ² /K)
H2	F10.0	61-70	Wall convection heat-transfer coefficient - Side 2 (W/m ² /K)
A	F10.0	71-80	Heat-transfer area between Sides 1 and 2 (m ²)
<u>Card 2</u>			
M1	F10.0	1-10	Fluid mass - Side 1 (kg)
M2	F10.0	11-20	Fluid mass - Side 2 (kg)
TI1	F10.0	21-30	Initial stored fluid temperature - Side 1 (K)
TI2	F10.0	31-40	Initial stored fluid temperature - Side 2 (K)
<u>Card 3</u>			
EOF			

Table 2 Output --

<u>Parameter</u>	<u>Description</u>
ESR1	Energy storage rate - Side 1 (W)
ESR2	Energy storage rate - Side 2 (W)

Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
ESR1	Energy storage rate - Side 1 (W)
ESR2	Energy storage rate - Side 2 (W)
TO1	Outlet temperature - Side 1 (K)
PO1	Outlet pressure - Side 1 (Pa)
FM1	Outlet flow rate - Side 1 (kg/s)
TO2	Outlet temperature - Side 2 (K)
PO2	Outlet pressure - Side 2 (Pa)
FM2	Outlet flow rate - Side 2 (kg/s)

Note -- This component uses heat-transfer-fluid property data.

Subroutine STORE2*

Program Description--Subroutine STORE2 models a mixed sensible-heat storage unit with one inlet and one outlet. Outlet flow rate is equal to the inlet flow rate; therefore, storage accumulation or depletion cannot occur. The fluid is assumed to be completely mixed at a uniform temperature. Fluid enters storage at a temperature of the upstream component and leaves at the mixed-mean-storage temperature.

Mathematical Algorithm--

$$T_s = T_{old} + \frac{\dot{m}\Delta t}{M} (T_i - T_{old})$$

where

T_s = computed storage temperature at present time (K)

T_{old} = storage temperature at previous time (K)

$\dot{m}$ = fluid-flow rate (kg/s)

Δt = time step (s)

ρ = fluid density (kg/m³)

M = stored-fluid mass (kg)

T_i = inlet temperature (K)

Input--

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (STORE2)
NCOM	I10	11-20	Component number

* Open Type 1 thermodynamic model

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
NSTAI	I5	21-25	Upstream state number
M	F10.0	51-60	Stored fluid mass (kg)
STEMP	F10.0	61-70	Initial storage temperature (K)

Card 2

EOF

Table 2 Output --

<u>Parameter</u>	<u>Description</u>
ENERS	Energy storage rate (W)

Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
ENERS	Energy storage rate (W)
TO	Outlet temperature (K)
PO	Outlet pressure (Pa)
FM	Outlet flow rate (kg/s)

Note -- This component uses heat-transfer-fluid property data.

Subroutine STORE3*

Program Description--Subroutine STORE3 models a one-material, sensible-heat storage unit with heat exchangers between the two energy-carrying fluids and the storage medium (see figure). One fluid enters the storage unit at Side 1, passes through a heat exchanger and leaves the unit. The same process occurs at Side 2. Energy is exchanged between the two fluids and the storage medium. The local heat-transfer coefficient and the temperature of the storage medium are assumed to be uniform. The amount of heat transferred between the storage medium and the flowing fluid depends on the local fluid temperature, heat-transfer coefficient, and the surface area of the heat-exchanger. Total heat-transfer rate is found by integrating local heat-transfer rates; the storage temperature is determined by integrating the total heat-transfer rate over time.

Storage Unit for STORE3

Mathematical Algorithm--

Storage and Outlet Fluid Temperatures

$$T_{o,1} = T_s + (T_{i,1} - T_s) / \exp \left(\frac{U_1 A_1}{\dot{m}_1 C_1} \right) \quad (1)$$

$$T_{o,2} = T_s + (T_{i,2} - T_s) / \exp \left(\frac{U_2 A_2}{\dot{m}_2 C_2} \right) \quad (2)$$

$$T_s = T_{s,old} + \frac{(T_{i,1} - T_{o,1}) \dot{m}_1 C_1 \Delta t}{M_s C_s} + \frac{(T_{i,2} - T_{o,2}) \dot{m}_2 C_2 \Delta t}{M_s C_s} \quad (3)$$

* Open Type 4 thermodynamic model

where

$T_{o,1}$ = fluid outlet temperature - Side 1 (K)

$T_{o,2}$ = fluid outlet temperature - Side 2 (K)

$T_{i,1}$ = fluid inlet temperature - Side 1 (K)

$T_{i,2}$ = fluid inlet temperature - Side 2 (K)

T_s = stored-fluid temperature (K)

$T_{s, old}$ = stored-fluid temperature at previous time (K)

$\dot{m}_1$ = fluid-flow rate - Side 1 (kg/s)

$\dot{m}_2$ = fluid-flow rate - Side 2 (kg/s)

U_1 = heat-transfer coefficient - Side 1 (W/m²/K)

U_2 = heat-transfer coefficient - Side 2 (W/m²/K)

A_1 = heat-transfer area - Side 1 (m²)

A_2 = heat-transfer area - Side 2 (m²)

C_1 = fluid specific heat - Side 1 (J/kg/K)

C_2 = fluid specific heat - Side 2 (J/kg/K)

C_s = stored material specific heat (J/kg/K)

M_s = mass of stored material (kg)

Δt = time increment (s)

Energy Storage Rate

$$\dot{E}_s = \dot{m}_1 \int_{T_{i,1}}^{T_{o,1}} C_1 dT + \dot{m}_2 \int_{T_{i,2}}^{T_{o,2}} C_2 dT \quad (4)$$

Input--

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
------------------	---------------	----------------	--------------------

Card 1

NAME	A10	1-10	Subroutine name (STORE3)
NCOM1	I10	11-20	Component number - Side 1
NSTAI1	I5	21-25	Upstream state number - Side 1
NCOM2	I10	31-35	Component number - Side 2
NSTAI2	I5	36-40	Upstream state number - Side 2
U1	F10.0	51-60	Heat-transfer coefficient - Side 1 ($\text{W/m}^2/\text{K}$)
U2	F10.0	61-70	Heat-transfer coefficient - Side 2 ($\text{W/m}^2/\text{K}$)
A1	F10.0	71-80	Heat-transfer area - Side 1 (m^2)

Card 2

A2	F10.0	1-10	Heat-transfer area - Side 2 (m^2)
TMS	F10.0	11-20	Total storage mass (kg)
SPHTS	F10.0	21-30	Specific heat of stored material (J/kg/K)
TS	F10.0	31-40	Initial temperature of stored material (K)

Card 3

EOF

Table 2 Output --

<u>Parameter</u>	<u>Description</u>
ESR	Energy storage rate (W)

Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
ESR	Energy storage rate (W)
TO1	Outlet temperature - Side 1 (K)
PO1	Outlet pressure - Side 1 (Pa)
FM1	Outlet flow rate Side 1 (kg/s)
TO2	Outlet temperature - Side 2 (K)
PO2	Outlet pressure - Side 2 (Pa)
FM2	Outlet flow rate - Side 2 (kg/s)

Note -- This component uses heat-transfer-fluid property data.

Subroutine STORE5*

Program Description--Subroutine STORE5 models a mixed sensible-heat storage unit with one inlet and one outlet. Storage mass accumulates (or is depleted) according to the difference between inflow and outflow. Three options exist for control of the outlet flow rate: (1) fixed outlet flow rate, (2) variable flow rate equal to the flow rate of a specified component, (3) outlet flow rate equal to inlet flow rate. The fluid is assumed to be completely mixed. Heat capacity of the tank and surrounding insulation is included, as is heat loss (a thermal loss) to the environment. The tank temperature is assumed equal to the mixed mean-fluid temperature. Temperature in the insulation is assumed to vary linearly between the mean-storage temperature and ambient temperature. Fluid enters storage at a temperature of the upstream component and leaves at the mean-storage temperature.

Mathematical Algorithm--

Storage Temperature -- For exit flow rate not equal to the inlet flow rate.

$$T_s = \frac{\frac{\dot{m}_i C_i T_i + UAT_a}{\dot{m}_i C_s + UA} + \left(T_{s,old} - \frac{\dot{m}_i C_i T_i + UAT_a}{\dot{m}_i C_s + UA} \right)}{\frac{\dot{m}_i C_s + UA}{C_s (\dot{m}_i - \dot{m}_o)}} \cdot \left[1 + \frac{C_s (\dot{m}_i - \dot{m}_o) \Delta t}{C_s M_{s,old} + C_w M_w + 1/2 C_I M_I} \right] \quad (1)$$

When exit flow rate is equal to the inlet flow rate,

$$T_s = \frac{\dot{m}_i C_i T_i + UAT_a}{\dot{m}_i C_s + UA} + \frac{T_{s,old} - \frac{\dot{m}_i C_i T_i + UAT_a}{\dot{m}_i C_s + UA}}{\exp \left[\frac{(\dot{m}_i C_s + UA) \Delta t}{C_s M_{s,old} + C_w M_w + 1/2 C_I M_I} \right]} \quad (2)$$

*Open Type 1 thermodynamic model

where

T_s = new mixed mean-storage temperature (K)

$T_{s, old}$ = old mixed mean-storage temperature - at previous time (K)

T_i = inlet fluid temperature (K)

T_a = ambient temperature (K)

$\dot{m}_i$ = inlet fluid-flow rate (kg/s)

$\dot{m}_o$ = outlet fluid-flow rate (kg/s)

U = overall heat-transfer coefficient for heat loss from storage tank (W/m²/K)

A = outermost surface area of insulated tank (m²)

C_i = fluid specific heat at inlet temperature (J/kg/K)

C_s = fluid specific heat at storage temperature (J/kg/K)

C_w = specific heat of storage tank wall (J/kg/K)

C_i = specific heat of insulation (J/kg/K)

$M_{s, old}$ = mass of stored fluid at previous time (kg)

M_w = mass of tank wall (kg)

M_i = mass of insulation (kg)

Δt = time increment (s)

Stored Mass

$$M_s = M_{s, old} + (\dot{m}_i - \dot{m}_o)\Delta t \quad (3)$$

Energy Storage Rate

$$\dot{E}_s = \dot{m}_i C_i T_i - \dot{m}_o C_s T_s - UA(T_s - T_a) \quad (4)$$

Thermal Loss

$$THMLOS = UA(T_s - T_a)$$

Input--

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (STORE5)
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Upstream state number
SVOLI	F10.0	51-60	Initial stored-fluid volume (m ³)
STEMPI	F10.0	61-70	Initial stored-fluid temperature (K)
VOLMIN	F10.0	71-80	Minimum allowed fluid volume (m ³)
<u>Card 2</u>			
SPHMW	F10.0	1-10	Mass/specific-heat product for tank wall (J/K)
SPHMI	F10.0	11-20	Mass/specific-heat product for insulation (J/K)
UA	F10.0	21-30	Overall heat-transfer coefficient - area product (W/K)
NFMOP	A10	31-40	Outlet flow option ("EQUAL", "FIXED", or "VARIABLE")
FMFIX	F10.0	41-50	Fixed outlet-flow rate (kg/s) (used when NFMOP = FIXED)
NCC	I10	41-50	Component number controlling outlet-flow rate (used when NFMOP = VARIABLE)

Table 2 Output --

<u>Parameter</u>	<u>Description</u>
VOLS	Stored fluid volume (m ³)
ENERS	Energy storage rate (W)

Tape 40 Output --

Parameter

Description

VOLS	Stored fluid volume (m^3)
ENERS	Energy storage rate (W)
TO	Outlet temperature (K)
PO	Outlet pressure (Pa)
FM	Outlet flow rate (kg/s)

Notes -- This component uses heat-transfer-fluid property data.

Subroutine TCSTORE*

Program Description--Subroutine TCSTORE models a stratified or thermocline storage unit (see figure). The storage unit is assumed to contain a thermally stratified fluid with two uniform temperature regions. Warm fluid is pumped into the top of the unit on Side 1 and out on Side 2. Cool fluid is pumped out of the bottom on Side 1 and in on Side 2. Inlet fluid is mixed with the fluid already in the temperature region into which it is pumped. If the inlet temperature on Side 1 is not between T_L and T_H , the fluid is diverted to the bottom of the tank and is mixed with the low-temperature fluid. There are no heat losses from the sides of the unit and no heat transferred across the thermocline. It is assumed that a discontinuous change in temperature is maintained across the thermocline.

Storage Unit for TCSTORE

Mathematical Algorithm--

Stored Mass

If $T_L < T_{i,1} < T_H$,

then

$$M_{\text{hot}} = M_{\text{hot, old}} + (\dot{m}_1 - \dot{m}_2) \Delta t \quad (1)$$

and

$$M_{\text{cold}} = M_s - M_{\text{hot}}$$

*Open Type 4 thermodynamic model

If $T_L < T_{i,1} < T_H$ is not satisfied,

then

$$M_{\text{cold}} = M_{\text{cold, old}} + \dot{m}_2 \Delta t \quad (3)$$

and

$$M_{\text{hot}} = M_s - M_{\text{cold}} \quad (4)$$

where

T_L = low limit-control temperature (K)

T_H = high limit-control temperature (K)

$T_{i,1}$ = fluid-inlet temperature - Side 1 (K)

M_s = total fluid-mass stored (kg)

M_{hot} = fluid mass - hot side (kg)

$M_{\text{hot, old}}$ = fluid mass - hot side at previous time (kg)

M_{cold} = fluid mass - cold side (kg)

$M_{\text{cold, old}}$ = fluid mass - cold side at previous time (kg)

$\dot{m}_1$ = fluid-flow rate - Side 1 (kg/s)

$\dot{m}_2$ = fluid-flow rate - Side 2 (kg/s)

Δt = time increment (s)

Storage Temperatures

If $T_L < T_{i,1} < T_H$,

then

$$T_{\text{hot}} = \frac{M_{\text{hot, old}}}{M_{\text{hot}}} T_{\text{hot, old}} + \frac{(\dot{m}_1 T_{i,1} - \dot{m}_2 T_{\text{hot, old}}) \Delta t}{M_{\text{hot}}} \quad (5)$$

and

$$T_{\text{cold}} = \frac{M_{\text{cold, old}}}{M_{\text{cold}}} T_{\text{cold, old}} + \frac{(\dot{m}_2 T_{i,2} - \dot{m}_1 T_{\text{cold, old}}) \Delta t}{M_{\text{cold}}} \quad (6)$$

If $T_L < T_{i,1} < T_H$ is not satisfied,

then

$$T_{\text{hot}} = T_{\text{hot, old}}$$

and

$$T_{\text{cold}} = \frac{M_{\text{cold, old}}}{M_{\text{cold}}} T_{\text{cold, old}} + \frac{[\dot{m}_2 T_{i,2} + \dot{m}_1 (T_{i,1} - T_{\text{cold, old}})] \Delta t}{M_{\text{cold}}}$$

where

T_{hot} = fluid temperature - hot side (K)

$T_{\text{hot, old}}$ = fluid temperature - hot side at previous time (K)

T_{cold} = fluid temperature - cold side (K)

$T_{\text{cold, old}}$ = fluid temperature - cold side at previous time (K)

$T_{i,2}$ = fluid inlet temperature - Side 2 (K)

Energy Storage Rate

$$\dot{E}_s = \dot{m}_1 (C_1 T_{i,1} - C_{\text{cold}} T_{\text{cold}}) + \dot{m}_2 (C_2 T_{i,2} - C_{\text{hot}} T_{\text{hot}}) \quad (9)$$

where

C_1 = inlet fluid specific heat - Side 1 (J/kg/K)

C_2 = inlet fluid specific heat - Side 2 (J/kg/K)

C_{cold} = stored fluid specific heat - cold side (J/kg/K)

C_{hot} = stored fluid specific heat - hot side (J/kg/K)

$\dot{E}_s$ = energy storage rate (W)

Input--

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (TCSTORE)
NCOM1	I10	11-20	Component number - Side 1
NSTAI1	I5	21-25	Upstream state number - Side 1
NCOM2	I10	31-35	Component number - Side 2
NSTAI2	I5	36-40	Upstream state number - Side 2
MS	F10.0	51-60	Total stored fluid mass (kg)
MHI	F10.0	61-70	Initial high-temperature-fluid mass (kg)
THI	F10.0	71-80	Initial high-temperature-fluid temperature (K)

<u>Card 2</u>			
TCI	F10.0	1-10	Initial cold-temperature-fluid temperature (K)
TH	F10.0	11-20	High-limit control temperature (K)
TL	F10.0	21-30	Low-limit control temperature (K)

Card 3

EOF

Table 2 Output --

<u>Parameter</u>	<u>Description</u>
ESR	Energy Storage Rate (W)

Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
ESR	Energy storage rate (W)
TO1	Outlet temperature - Side 1 (K)
PO1	Outlet pressure - Side 1 (Pa)
FM1	Outlet flow rate - Side 1 (kg/s)
TO2	Outlet temperature - Side 2 (K)
PO2	Outlet pressure - Side 2 (Pa)
FM2	Outlet flow rate - Side 2 (kg/s)

v. Turbines

Subroutine XTURBG*

Program Description--This routine is a model for a turbine generator with a single extraction port. The turbine/generator output is electrical and/or mechanical power.

Mathematical Algorithm--

$$\dot{W}_M = X \dot{W}_E \quad (1)$$

$$\dot{W}_E = \frac{\eta_g \eta_m}{(1 + X \eta_g)} \left[\dot{m}_1 (h_1 - h_3) - \dot{m}_2 (h_2 - h_3) \right] \quad (2)$$

$$\dot{m}_2 = Y \dot{m}_1 \quad (3)$$

$$(h_2 - h_3) = \eta_L (h_2 - h_{3s}) \quad (4)$$

$$(h_1 - h_3) = \eta_H (h_1 - h_{2s}) + (h_2 - h_3) \quad (5)$$

where

- $\dot{W}_M$ is the mechanical-power output of the turbine/generator (W),
- $\dot{W}_E$ is the electrical-power output of the generator (W),
- X is the ratio of mechanical- and electrical-power outputs of the turbine generator (-),
- η_g is the generator efficiency (-),
- η_m is the turbine-mechanical efficiency (-),
- $\dot{m}_1$ is the fluid-flow rate entering the turbine (kg/s),
- $\dot{m}_2$ is the fluid-flow rate through the turbine extraction port (kg/s),
- $(h_2 - h_3)$ is the change in enthalpy between the extraction port and exit thermodynamic states (J/kg),
- η_L is the isentropic efficiency for the expansion from the turbine extraction port state to the turbine exit state (-),
- $(h_2 - h_{3s})$ is the enthalpy drop during an isentropic expansion from the extraction port state to the exit state pressure (J/kg),
- $(h_1 - h_3)$ is the change in enthalpy between the inlet state and exit state (J/kg),

* Open Type 3 thermodynamic model

η_H is the isentropic efficiency for the expansion from the turbine inlet state to the extraction port state (-),

$(h_1 - h_{2s})$ is the enthalpy drop during an isentropic expansion from the inlet state to the extraction port state,

and Y is the extraction rate.

Input--

Parameter	Format	Columns	Description
<u>Card 1</u>			
NAME	A6	1-6	"XTURBG"
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Inlet state number
NSTAP	I5	26-30	Extraction port state number
NSTAE	I5	41-45	Exit state number
ETAG	F10.2	51-60	Electrical generator efficiency (%)
X		61-70 ¹	Ratio of mechanical- and electrical-power output (%)
Option 1	Blank	61-70	X = 0
Option 2	F10.2	61-70	Value input in percent
Option 3	A6	61-70	"UNSPEC"
ETAM	F10.2	71-80	Turbine mechanical efficiency (%)
<u>Card 2</u>			
ETAH	F10.2	1-10	Isentropic efficiency for expansion from inlet to extraction port (%)
ETAL	F10.2	21-30	Isentropic efficiency for expansion from extraction port to exit (%)

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 2 (cont)</u>			
T_B	F10.2	21-30	Saturation temperature of extraction port state (K)
T_D	F10.2	31-40	Saturation temperature of exit state (K)
Y	F10.2	41-50 ²	Turbine extraction rate - ratio of fluid flow through extraction port and the fluid-flow rate entering the turbine (%)

Card 3

EOF

Table 2 Output--

<u>Parameter</u>	<u>Description</u>
$\dot{W}_E$	Electrical-power output of generator (W)
$\dot{W}_M$	Mechanical-power output from turbine/generator (W)

Tape 40 Output--

<u>Parameter</u>	<u>Description</u>
$\dot{W}_E$	Electrical-power output of generator (W)
$\dot{W}_M$	Mechanical-power output of turbine/generator (W)
T_P	Extraction port temperature (K)
T_E	Exit temperature (K)

Notes--

- Options 1 and 2 for X are used for each turbine/generator when the LODMG power loop operational mode is not "POWER". Option 1 is used for each turbine/generator when the LODMG operational mode is "POWER" and no mechanical-power output is specified by LODMG for the power loop. Options 1 and 2 are used for all but one of the turbine/generators in the cascade when the LODMG operational mode is "POWER". Option 3 is used for the remaining turbine/generator in the cascade.
- Values for Y are only required when the LODMG routine for this power loop is the simulation mode.
- This routine requires power-cycle working-fluid constants.

Subroutine TURBG*

Program Description--This routine is a model for a turbine/generator with output of electrical and/or mechanical power.

Mathematical Algorithm--

$$\dot{W}_M = X \dot{W}_E \quad (1)$$

$$\dot{W}_E = \left[\frac{\eta_g \eta_m}{(1 + X\eta_g)} \right] \dot{m}(h_1 - h_2) \quad (2)$$

$$(h_1 - h_2) = \eta_I (h_1 - h_{2s}) \quad (3)$$

$\dot{W}_M$ is the mechanical-power output of the turbine/generator (W),

$\dot{W}_E$ is the electrical-power output of the turbine/generator (W),

X is the ratio of mechanical- and electrical-power outputs of the turbine/generator (-),

η_g is the electrical-generator efficiency (-),

η_m is the turbine-mechanical efficiency (-),

$\dot{m}$ is the fluid-flow rate through the turbine (kg/s),

$(h_1 - h_2)$ is the change in enthalpy between the inlet and exit states (J/kg),

η_I is the turbine isentropic efficiency (-),

$(h_1 - h_{2s})$ is the enthalpy drop during an isentropic expansion from the inlet state to the exit state pressure (J/kg).

Input--

* Open Type 1 thermodynamic model

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A5	1-10	"TURBG"
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Inlet state number
ETAG	F10.2	51-60	Electrical generator efficiency (%)
X		61-70 ¹	Ratio of mechanical- and electrical-power outputs
Option 1	Blank	61-70	X = 0
Option 2	F10.2	61-70	Value input in percent
Option 3	A6	61-70	UNSPEC
ETAM	F10.2	71-80	Turbine mechanical efficiency (%)

<u>Card 2</u>			
ETA	F10.2	1-10	Turbine isentropic efficiency (%)
T _B	F10.2	11-20	Saturation temperature of exit state (K)

Card 3

EOF

Table 2 Output--

<u>Parameter</u>	<u>Description</u>
$\dot{W}_E$	Electrical-power output of generator (W)
$\dot{W}_M$	Mechanical-power output of turbine/ generator (W)

Tape 40 Output--

<u>Parameter</u>	<u>Description</u>
$\dot{W}_E$	Electrical-power output of generator (W)
$\dot{W}_M$	Mechanical-power output of turbine/ generator (W)
T _E	Exit temperature (K)

Notes--

1. Options 1 and 2 for X are used for each turbine/generator when the LODMG power loop operational mode is not "POWER". Option 1 is used for each turbine/generator when the LODMG operational mode is "POWER" and no mechanical-power output is specified by LODMG for the power loop. Options 1 and 2 are used for all but one of the turbine/generators in the cascade when the LODMG operational mode is "POWER". Option 3 is used for the remaining turbine/generator in the cascade.
2. This routine requires power-cycle working-fluid constants.

Subroutine XTURB*

Program Description--This routine is a model for a turbine with a single extraction port; the output is mechanical power.

Mathematical Algorithm--

$$\dot{W}_M = \eta_M [\dot{m}_1(h_1 - h_3) - \dot{m}_2(h_2 - h_3)] \quad (1)$$

$$\dot{m}_2 = Y\dot{m}_1 \quad (2)$$

$$(h_2 - h_3) = \eta_L(h_2 - h_{3s}) \quad (3)$$

$$(h_1 - h_3) = \eta_H(h_1 - h_{2s}) + (h_2 - h_3) \quad (4)$$

where

- $\dot{W}_M$ is the mechanical-power output of the turbine/generator (W),
- η_M is the turbine mechanical efficiency (-),
- $\dot{m}_1$ is the fluid-flow rate entering the turbine (kg),
- $\dot{m}_2$ is the fluid-flow rate through the turbine extraction port (kg/s),
- $(h_2 - h_3)$ is the change in enthalpy between the extraction port and exit thermodynamic states (J/kg),
- η_L is the isentropic efficiency for the expansion from the turbine extraction port state to the turbine exit state (-),
- $(h_2 - h_{3s})$ is the enthalpy drop during an isentropic expansion from the extraction port state to the exit state pressure (J/kg),
- $(h_1 - h_3)$ is the change in enthalpy between the inlet state and exit states (J/kg),
- η_H is the isentropic efficiency for the expansion from the turbine inlet state to the extraction port state (-),
- $(h_1 - h_{2s})$ is the enthalpy drop during an isentropic expansion from the inlet state to the extraction port state (J/kg),
- Y is the extraction rate (-).

* Open Type 3 thermodynamic model

Input--

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A6	1-6	"XTURB"
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Inlet state number
NSTAP	I5	26-30	Extraction port state number
NSTAE	I5	41-45	Exit state number
ETAM	F10.2	51-60	Turbine mechanical efficiency (%)
<u>Card 2</u>			
ETAH	F10.2	1-10	Isentropic efficiency for expansion from inlet to extraction port (%)
ETAL	F10.2	11-20	Isentropic efficiency for expansion from extraction port to exit (%)
T _B	F10.2	21-30	Saturation temperature of extraction port state (K)
T _D	F10.2	31-40	Saturation temperature of exit state (K)
Y	F10.2	41-50	Turbine extraction rate-ratio of fluid flow through extraction port and the fluid-flow rate entering the turbine (%)
<u>Card 3</u>			
EOF			

Table 2 Output--

<u>Parameter</u>	<u>Description</u>
$\dot{W}_M$	Mechanical-power output from turbine/ generator (W)

Tape 40 Output--

<u>Parameter</u>	<u>Description</u>
$\dot{W}_M$	Mechanical-power output of turbine generator (W)
T_P	Extraction port temperature (K)
T_E	Exit temperature (K)

Notes--

1. Values for Y are only required when the LODMG routine for this power loop is in the simulation mode.
2. This routine requires power-cycle working-fluid constants.

Subroutine TURB*

Program Description--This routine is a model for a turbine with mechanical-power output.

Mathematical Algorithm--

$$\dot{W}_M = \eta_m \dot{m}(h_1 - h_2) \quad (1)$$

$$(h_1 - h_2) = \eta_I(h_1 - h_{2s}) \quad (2)$$

where

$\dot{W}_M$ is the mechanical-power output of the turbine/generator (W),

η_m is the turbine mechanical efficiency (-),

$\dot{m}$ is the fluid-flow rate through the turbine (kg/s),

$(h_1 - h_2)$ is the change in enthalpy between the inlet and exit states (J/kg),

η_I is the turbine isentropic efficiency (-),

$(h_1 - h_{2s})$ is the enthalpy drop during an isentropic expansion from the inlet state to the exit state pressure (J/kg).

Input--

* Open Type 1 thermodynamic model

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A5	1-6	"TURB"
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Inlet state number
ETAM	F10.2	51-60	Turbine mechanical efficiency (%)

<u>Card 2</u>			
ETA	F10.2	1-10	Turbine isentropic efficiency (%)
T _B	F10.2	11-20	Saturation temperature of exit state (K)

Card 3
EOF

Table 2 Output--

<u>Parameter</u>	<u>Description</u>
$\dot{W}_M$	Mechanical-power output of turbine/ generator (W)

Tape 40 Output--

<u>Parameter</u>	<u>Description</u>
$\dot{W}_M$	Mechanical-power output of turbine/ generator (W)
T _E	Exit temperature (K)

Note--This routine requires power-cycle working-fluid constants.

CII. COMPONENT ROUTINES

2. Controls

a. Fluid-Flow Controls

Subroutine FLODIV*

Program Description -- FLODIV is a model that allows the flow to be divided.

Mathematical Algorithm --

$$\dot{m}_1 = \text{Minimum of } \dot{m}_{\text{inlet}} \text{ and } \dot{m}_{\text{ref}} \quad (1)$$

$$\dot{m}_2 = \dot{m}_{\text{inlet}} - \dot{m}_1 \quad (2)$$

where

$\dot{m}_1$ is the flow-through outlet state NSTA01,

$\dot{m}_2$ is the flow-through outlet state NSTA02,

$\dot{m}_{\text{inlet}}$ is the inlet flow to FLODIV from the upstream state point NSTAI,

$\dot{m}_{\text{ref}}$ is the flow-through a user-supplied state point NSREF.

Input --

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A6	1-6	"FLODIV"
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	System state point
NSTA01	I5	26-30	Outlet State 1
NSTA02	I5	41-45	Outlet State 2
NSREF	I10	51-60	Reference state point

* Open Type 3 control model

Card 2

EOF

Output -- Table 1 output only.

Note -- No property data required.

Subroutine FLOVLV*

Program Description -- FLOVLV is a model that sets the output flow to either the inlet flow or to zero, depending on the inlet temperature and user-supplied temperatures.

Mathematical Algorithm --

$$\text{If } T_{in} \geq T_L \text{ or } \leq T_H, \quad (1)$$

$$\text{then } \dot{m}_{out} = \dot{m}_{in}; \quad (2)$$

otherwise, $\dot{m}_{out} = 0$, pressure and temperature set to ambient conditions.

where

$\dot{m}_{out}$ is the flow rate out of FLOVLV,

$\dot{m}_{in}$ is the fluid-flow rate into FLOVLV,

T_{in} is the temperature entering FLOVLV,

T_L is the user-specified value for the low temperature,

T_H is the user-specified value for the high temperature,

Input --

Parameter	Format	Columns	Description
<u>Card 1</u>			
NAME	A6	1-6	"FLOVLV"
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Inlet state number
T_L	F10.0	51-60	Low temperature (K)
T_H	F10.0	61-70	High temperature (K)

* Open Type 1 control model

Card 2

EOF

Note -- No fluid properties are required.

Subroutine DIVJNT*

Program Description -- Subroutine DIVJNT divides a fluid stream into two fluid streams. Fluid enters the component through a single inlet and leaves through two outlets, each having a specified fraction of the inlet flow rate. Temperatures and pressures are not altered.

Mathematical Algorithm --

$$\dot{m}_{o,1} = f_1 \dot{m}_i \quad (1)$$

$$\dot{m}_{o,2} = (1 - f_1) \dot{m}_i \quad (2)$$

where

$\dot{m}_{o,1}$ = fluid-flow rate at Outlet 1

$\dot{m}_{o,2}$ = fluid-flow rate at Outlet 2

$\dot{m}_i$ = fluid-flow rate at inlet

f_1 = fraction of flow leaving Outlet 1

Input --

Parameter	Format	Columns	Description
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (DIVJNT)
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Upstream state number
NSTA01	I5	26-30	Outlet state number - Outlet 1
NSTA02	I5	41-45	Outlet state number - Outlet 2
FRACT1	F10.0	51-60	Fraction of flow leaving Outlet 1

* Open Type 3 control model

Card 2

EOF

Table 2 and Tape 40 Output -- None

Subroutine SWITCH*

Program Description -- Subroutine SWITCH models a two-branch switch. If the parameter ACON is "TEMP", the subroutine uses the outlet temperature of component NCC as a control parameter. If ACON is "CORD", the value of SAVEVAR (1, NCC) is used as a control parameter. At this time, the following subroutines store values in SAVEVAR (1, NCC):

<u>Subroutine</u>	<u>Parameter</u>
TCSTORE	High-temperature storage volume
STORE5	Volume of stored fluid

If the control parameter is less than X_L , the flow is sent through Outlet 1 (flow through Outlet 2 is zero). If the control parameter is greater than X_H , the flow is sent through Outlet 2. If the control parameter is between X_L and X_H , the flow goes through the same outlet through which it previously went.

If the flow in a fluid branch connected to the switch has been zero and then becomes positive due to a start-up situation, the switch component will switch to direct flow into this branch. (The solar collectors have start-up logic to start operation at the beginning of each day when the sun's elevation angle becomes greater than zero.)

Mathematical Algorithm --

$$\text{if } X < X_L, \quad \dot{m}_{o,1} = \dot{m}_i \text{ and } \dot{m}_{o,2} = 0 \quad (1)$$

$$\text{if } X > X_H, \quad \dot{m}_{o,1} = 0, \text{ and } \dot{m}_{o,2} = \dot{m}_i \quad (2)$$

$$\text{if } X \leq X \leq X_H, \quad \text{flow path remains the same} \quad (3)$$

where

X = control parameter

X_L = low-control value

X_H = high-control value

$\dot{m}_i$ = inlet fluid-flow rate

$\dot{m}_{o,1}$ = Outlet 1 fluid-flow rate

$\dot{m}_{o,2}$ = Outlet 2 fluid-flow rate

* Open Type 3 control model.

Input --

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (SWITCH)
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Upstream state number
NSTA01	I5	26-30	State number - Outlet 1
NSTA02	I5	41-45	State number - Outlet 2
NCC	I10	51-60	Component number supplying control parameter
ACON	A10	61-70	Type of control ("TEMP" for temperature control; "CORD" for other variable control)
XL	F10.0	71-80	Low-control value
<u>Card 2</u>			
XH	F10.0	1-10	High-control value
NOUT	I10	11-20	Outlet number for initial flow ("1" or "2")
<u>Card 3</u>			
EOF			

Table 2 Output -- None

Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
FM1	Flow rate - Outlet 1 (kg/s)
FM2	Flow rate - Outlet 2 (kg/s)

Subroutine TIMSWH*

Program Description -- TIMSWH is a model that allows the user to select the fluid path as a function of time and/or sun angle. User-input directs fluid flow through either the outlet state point NSTA01 or through NSTA02.

Normally fluid flows through NSTA01 but is directed through NSTA02 via the cards

PERIOD, WEEK, DAY, HOUR, WEEKEND, NIGHT, END.

In general, the user selects groups of days, then hours and/or sun elevation angles during those days for which flow is diverted through NSTA02. Various modes of operation may be constructed for an entire year by supplying TIMSWH with sets of the above control cards.

The sequence in which the control cards are specified within a set is very important. For example, if TIMSWH encounters a DAY card it will not honor a PERIOD or WEEK card until it encounters an END card.

The sequence in which each set is provided to TIMSWH is also critical. For example, the user supplies set (1) date, which directs the flow through NSTA02 for every weekend of the year, and then supplies TIMSWH with an additional set such that the flow through NSTA02 should occur only in weekends during the winter months. This sequence will not work. Once flow has been directed through NSTA02 for a particular time, it cannot be directed through NSTA01 for that time.

The following section describes TIMSWH control cards and is in the same order in which each control card is processed by TIMSWH. Individual control cards may be omitted from a set, and no more than one card of each type is allowed per set.

* Open Type 3 control model

PERIOD Card -- Eight separate groups of days have been preestablished for use with this card. The user is allowed to specify up to three of the groups on the PERIOD card or define his own days for which flow is to be diverted. By definition, Day 1 is the first day of the year and is a Sunday. Thus, the day sequence is:

Sundays 1, 8, 15, . . .
Mondays 2, 9, 16, . . .
Etc.

The eight groups of days and associated names are:

<u>Name</u>	<u>Days (inclusive)</u>
"WINTER"	1 - 78 and 354 - 365
"SPRING"	79 - 170
"SUMMER"	171 - 262
"FALL"	263 - 353
"QUARTER 1"	1 - 90
"QUARTER 2"	91 - 181
"QUARTER 3"	182 - 273
"QUARTER 4"	274 - 365

WEEK Card -- The WEEK card allows the user to specify which weeks of the year he will switch on. Up to seven separate weeks may be defined on the card. Using the day definition above. Week 1 is Days 1 - 7 inclusive; Week 2 is 8 - 14; etc.

DAY Card -- This card defines on which day(s) of the week switching is to take place for the time frame given by the PERIOD and WEEK cards. The numbers on this card may range from 1 to 7 only. If omitted, switching will take place every day of the week in the time frame for the hours as specified on the HOUR card.

HOUR Card -- This card allows the user to specify within which groups of hours of each day switching is to take place for the defined time frame. If the HOUR, WEEKEND, and NIGHT cards are omitted in a set, switching occurs for every hour of each day in the time frame. Up to three groups of hours may be included on this card.

WEEKEND Card -- The use of this card allows switching to take place from a specified time on Friday through and including a specified time on Monday for every hour of each Friday, Saturday, Sunday, and Monday in the time frame.

T_1 , the first time on this card, is for Friday; the second time, T_2 , is for Monday. The default time for T_1 is 6 p.m. Friday. The default time for T_2 is 7 a.m. Monday.

NIGHT Card -- The input on this card is:

α_m morning elevation angle - default sunrise
 Δt_m time increment in hours. Morning - default 0
 α_e evening elevation angle - default sunset
 Δt_e time increment in hours. Evening - default 0

Given the above input TIMSWH calculates times T_M and T_E as follows:

$$\left. \begin{aligned} T_M &= T(\alpha_m) + \Delta t_m \\ T_E &= T(\alpha_e) + \Delta t_e \end{aligned} \right\} \text{TM and TE are rounded to the nearest hour.}$$

Switching for each day as specified in the time frame will occur through NSTA02 for the hours 00 - T_M and T_E - 23.

END Card -- This card ends each set and initiates the search for new PERIOD, WEEK, . . . cards.

NOTES --

1. Once flow is directed through NSTA02 for a particular time, the flow for that time cannot be changed. Therefore, it is very important that users carefully construct their input to TIMSWH.
2. If both the PERIOD and WEEK cards are omitted from a set, TIMSWH assumes that switching will take place for every day of the year.
3. If the DAY card is omitted from a set, TIMSWH assumes switching is to take place for every day of the week in the time frame as specified by the PERIOD and WEEK card(s).
4. If the HOUR, WEEKEND, and NIGHT cards are omitted from a set, switching will occur for every hour of the time frame as specified by the PERIOD, WEEK, and DAY cards in the set.
5. When Week 52 is included on the WEEK card, Days 358 - 365 inclusive are added to the time frame.
6. Day 1 is assumed to be Sunday and the first day of the year. Therefore, if TIMSWH is being used with time-varying loads data, the day must be adjusted accordingly.
7. TIMSWH cannot switch on an interval less than a whole hour.
8. An output table may be printed that indicates the outlet state through which the fluid will flow (see input for Card 1).

Formats --

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
"TIMSWH"	A6	1-6	Component name
NCOM	I10	11-20	Component number
NCOMI	I5	21-25	Upstream component number
NSTA01	I5	26-30	Outlet State 1
NSTA02	I5	41-45	Outlet State 2
FLAG	A10	51-60	{ Blank => Do not print switch setting table Nonblank => Print switch setting table

Card 2 (Optional)

"PERIOD"	A6	1-6	Card name
NAME ₁	A10	11-20	Group name "WINTER", "FALL", etc (left-adjust)
or	or		or
S _{D1}	I10		Starting day of time frame (right-adjust)
E _{D1}	I10	21-30	Ending day of time, frame (right-adjust)
NAME ₂	A10	31-40	Group name if any
or	or		or
S _{D2}	I10		Starting day of next time frame (if any)
E _{D2}	I10	41-50	Ending day of next time frame (if any)
NAME ₃	A10	51-60	Group name if any
or	or		or
S _{D3}	I10		Starting day of next time frame (if any)
E _{D3}	I10	61-70	Ending day of next time frame (if any)

Card 3 (Optional)

"WEEK"	A4	1-4	Card name
N ₁	I10	11-20	Weeks of year 1 ≤ N _i ≤ 52
N ₂	I10	21-30	
.	.	.	
.	.	.	
N ₇	I10	71-80	

Parameter	Format	Columns	Description
Card 4 (Optional)			
"DAY"	A3	1-3	Card name
DOW ₁	I10	11-20	Weeks of year $1 \leq \text{DOW}_i \leq 7$
DOW ₂	I10	21-30	
.	.	.	
.	.	.	
DOW ₇	I10	71-80	
Card 5 (Optional)			
"HOUR"	A4	1-4	Card name
S _{H1}	I10	11-20	Starting and ending hours for switching $S_{Hi} \leq E_{Hi}$ $0 \leq S_{Hi}$ and $E_{Hi} \leq 23$
E _{H1}	.	21-30	
S _{H2}	.	31-40	
E _{H2}	.	41-50	
S _{H3}	.	51-60	
E _{H3}	I10	61-70	
Card 6 (Optional)			
"WEEKEND"	A7	1-7	Card name
T ₁	I10	11-20	Friday time
T ₂	I10	21-30	Monday time
Card 7 (Optional)			
"NIGHT"	A5	1-5	Card name
α_m	F10.0	11-20	Morning sun elevation angle (degrees) Blank $\Rightarrow$ sunrise; $0. \leq \alpha_m \leq 90$
Δt_m	I10	21-30	Time constant in hours, which is added to T (α_m); Blank $\Rightarrow$ 0
α_e	F10.0	31-40	Evening sun elevation angle (degrees) Blank $\Rightarrow$ sunset; $0. \leq \alpha_e \leq 90$
Δt_e	I10	41-50	Time constant in hours, which is added to T(α_e); Blank $\Rightarrow$ 0

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 8</u>			
"END"	A3	1-3	Card name

Cards 2 - 8 may be repeated in creating the switching effect desired. After the last "END" card there must be a Card 9.

Card 9

EOF

This concludes the input description for TIMSWH.

Examples --

1. The following input will switch the flow through state point 15 for every weekend of the year from Friday at 6 p.m. to and including 5 a.m. Monday.

```
TIMSWH          12  11  13          15
WEEKEND          5
END
```

2. In this example, flow will be switched as in Example 1 and also when the sun is down.

```
TIMSWH          12  11  13          15
WEEKEND          5
NIGHT
END
```

3. This example is similar to 2 above but also switches the flow for the entire last week of the year.

```
TIMSWH          12  11  13          15
WEEKEND          5
NIGHT
END
WEEK            52
END
```

4. In this final example, switching through state point 15 will occur for the days 1-120 and 305-365 for hours 0-7 and 17-23. The following figure illustrates the mode of operation for a single day in the time frame. The input data would look like:

```
TIMSWH          12  11  13          15
PERIOD  QUARTER 1          91      120      305      365
HOUR      0          7      17          23
END
```

In this example, the period card could have been

```
PERIOD          1          120      305          365
```

Mode of Operation for a Single Day in the Selected Time Frame

TABLE 1 output only from TIMSWH.

No diagnostics.

No fluid property data needed for TIMSWH.

c. Temperature

Subroutine TEMCON*

Program Description -- Subroutine TEMCON is used to control the outlet temperature of an individual component or a string of components by adjusting flow rate. Rate of energy addition to the component string is computed based on temperature rise and flow rate at the previous iteration. Flow rate for the present iteration is calculated using this energy rate, the present inlet temperature to the string, and the desired outlet temperature. In system model construction, component TEMCON must be placed immediately in front of the component string to be controlled.

Mathematical Algorithm --

$$\dot{m}_{\text{new}} = \dot{m}_{\text{old}} \frac{\int_{T_{i,\text{old}}}^{T_o} C dT}{\int_{T_{i,\text{new}}}^{T_d} C dT}$$

where

- $\dot{m}_{\text{new}}$ = component string flow rate for present iteration (kg/s)
- $\dot{m}_{\text{old}}$ = component string flow rate at previous iteration (kg/s)
- C = fluid specific heat (J/kg/K)
- $T_{i,\text{old}}$ = temperature of upstream state at previous iteration (K)
- $T_{i,\text{new}}$ = temperature of upstream state for present iteration (K)
- T_o = controlled string outlet temperature at previous iteration (K)
- T_d = desired controlled string outlet temperature (K)

Input --

* Open Type 1 thermodynamic model

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (TEMCON)
NCOM	I10	11-20	Component number
NSTAI	I5	21-25	Upstream state number
NO	I10	51-60	Outlet state number of controlled string
TOD	F10.0	61-70	Desired outlet temperature (K)
ERR	F10.0	71-80	Allowed error (K)

<u>Card 2</u>			
FMAX	F10.0	1-10	Maximum allowed flow rate (kg/s)
FMIN	F10.0	11-20	Minimum allowed flow rate (kg/s)

Card 3
EOF

Table 2 Output -- None

Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
TO	Outlet temperature (K)
PO	Outlet pressure (Pa)
FM	Outlet flow rate (kg/s)

Notes --

1. This component uses heat-transfer-fluid property data.
2. Component TEMCON must immediately precede the component string to be controlled.

CIII. SYSTEM PERFORMANCE ROUTINES

1. Energy Accounting

Subroutine ENGAC1 *

Program Description -- ENGAC1 is a system performance routine that performs energy accounting for the system model. Current values and integrated values from the beginning of the simulation period to the current time for the energy transfer rates are defined in 1.2.6, and the system energy conversion efficiency is calculated. These system performance data are printed as TABLE 3 output for times defined by the PRINT card (see Section 2.2). Only values for those rates that are associated with the system model are printed; all others are automatically deleted from TABLE 3 output. All rates are written to Tape 40 for post-SOLTES calculations, plotting, and printing.

Mathematical Algorithm --

$$Q(t_s) = 0 \quad (1)$$

$$Q(t + \Delta t) = \int_{t_s}^{t + \Delta t} \dot{Q}(\sigma) d\sigma = \int_{t_s}^t \dot{Q}(\sigma) d\sigma + \int_t^{t + \Delta t} \dot{Q}(\sigma) d\sigma \quad (2)$$

$$\approx Q(t) + \dot{Q}(t) \Delta t \quad (3)$$

$$\begin{aligned} \dot{B}(t) = & L_{EL}(t) + L_{PW}(t) + L_{TH}(t) + L_{CL}(t) + L_{HT}(t) \\ & + L_{HW}(t) + D_{CL}^S(t) + D_{HT}^S(t) - [D_{EL}(t) - D_{EL}^S(t)] \\ & - [D_{PW}(t) - D_{PW}^S(t)] - [P_{EL}(t) - P_{EL}^S(t)] - [P_{PW}(t) - P_{PW}^S(t)] \end{aligned} \quad (4)$$

$$\dot{S}(t) = S_P(t) + S_A(t) \quad (5)$$

If $\dot{S}(t) = 0$, $\eta(t)$ is undefined;

otherwise

$$\text{If } \dot{S}_T(t) \geq 0, \eta(t) = \frac{\dot{B}(t)}{\dot{S}(t)} \quad (6)$$

$$\text{If } \dot{S}_T(t) < 0, \eta(t) = \frac{\dot{B}(t)}{\dot{S}(t) - \dot{S}_T(t)} \quad (7)$$

If $S(t) = 0$, $\eta_c(t)$ is undefined,

$$\eta_c(t) = \frac{B(t)}{S(t) + S_{Ti}} \quad (8)$$

* System performance routine

where

t_s	is the starting time of the simulation period,
$Q(t)$	is the integrated value of an energy transfer rate $\dot{Q}$ over the time interval from t_s to t ,
Δt	is the SOLTES time increment,
$\dot{Q}(t)$	is an energy transfer rate at time t ,
$\dot{B}(t)$	is the rate that the system provides beneficial energy at time t ,
${}^1L_{EL}(t)$	is the total electrical load produced by the system at time t (ELCLD),
${}^2L_{PW}(t)$	is the total mechanical-power load produced by the system at time t (POWLD),
$L_{TH}(t)$	is the total thermal load met by the system at time t (THMLD),
$L_{CL}(t)$	is the total cooling load met by the system at time t (COOLLD),
$L_{HT}(t)$	is the total heating load met by the system at time t (HEATLD),
$L_{HW}(t)$	is the total hot-water load met by the system at time t (HWATLD),
$D_{CL}^s(t)$	is the total of the cooling demands satisfied by the system at time t (COOLDM),
$D_{HT}^s(t)$	is the total heating demands satisfied by the system at time t (HEATDM),
$[D_{EL}(t) - D_{EL}^s(t)]$	is the total electrical demands satisfied externally to the system at time t ,
$D_{EL}(t)$	is the total electrical demands of the system at time t (ELCDM),
$D_{EL}^s(t)$	is the total electrical demands satisfied by the system at time t (ELCDM),
$[P_{EL}(t) - P_{EL}^s(t)]$	is the total electrical parasitics satisfied externally to the system at time t ,
$P_{EL}(t)$	is the total electrical parasitics of the system at time t (ELCPS),
$P_{EL}^s(t)$	is the total electrical parasitics satisfied by the system at time t (ELCPS),
$[D_{PW}(t) - D_{PW}^s(t)]$	is the total mechanical-power demands satisfied externally to the system at time t ,
$D_{PW}(t)$	is the total mechanical-power demands of the system at time t (POWDM),
$D_{PW}^s(t)$	is the total mechanical-power demands satisfied by the system at time t (POWDM),
$[P_{PW}(t) - P_{PW}^s(t)]$	is the total mechanical-power parasitics satisfied externally to the system at time t ,

P_{PW}	is the total mechanical-power parasitics of the system at time t (POWPS),
P_{PW}^s	is the total mechanical-power parasitics satisfied by the system at time t (POWPS),
$\dot{S}(t)$	is the total rate at which energy is supplied to the system at time t,
$\dot{S}_P(t)$	is the rate that energy is supplied from the primary source at time t (PRISUP),
$\dot{S}_A(t)$	is the rate that energy is supplied from the auxiliary source at time t (AUXSUP),
$\dot{\eta}(t)$	is the system energy conversion efficiency at time t,
$\eta_c(t)$	is the cumulative system energy conversion efficiency over the time interval from t_s to t,
$B(t)$	is the integrated value of $\dot{B}(t)$ over the time interval from t_s to t,
$S(t)$	is the integrated value of $\dot{S}(t)$ over the time interval from t_s to t,
S_{Ti}	is the thermal energy that is stored in the system at the beginning of the simulation period; i. e., at time t_s ,
$S_T(t)$	is the rate that thermal energy is stored in the system at time t (THMSTO),

Input --

<u>Parameter</u>	<u>Format</u>	<u>Column</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A6	1-6	ENGAC1

Card 2

EOF

Table 2 Output -- None

Table 3 Output -- Integrated values and values for those energy transfer rates defined in Section 1.2.6 that are associated with the system and system energy conversion efficiencies are printed. The output format is self-explanatory.

Tape 40 Output -- The energy transfer rates associated with the system, $\dot{B}(t)$, and $\dot{S}(t)$ are available at each time step.

Notes --

1. A negative value indicates that electricity must be transferred into the system from the system's environment at the rate corresponding to the absolute value of $L_{EL}(t)$.
2. A negative value indicates that mechanical power must be transferred into the system from the system's environment at the rate corresponding to the absolute value of $L_{PW}(t)$.

CIII. SYSTEM PERFORMANCE ROUTINES

2. Energy Summing

Subroutine QMETER*

Program Description -- Subroutine QMETER measures the rate of energy addition to a fluid in a single component or in a string of components. Up to nine combinations of strings and components can be monitored. The total energy added is approximated by multiplying the rate of energy addition at a given time by the time step.

Mathematical Algorithm --

$$Q_k = \dot{m}_k \int_{T_{i,k}}^{T_{o,k}} C_k dT \quad (1)$$

and

$$E_k = Q_k \Delta t \quad (2)$$

where

Q_k = rate of energy addition to fluid in k^{th} component string,

E_k = total energy added to fluid during time step,

$\dot{m}_k$ = fluid-flow rate in k^{th} component string,

C_k = fluid specific heat in k^{th} component string,

$T_{i,k}$ = inlet-fluid temperature to k^{th} component string,

$T_{o,k}$ = outlet-fluid temperature of k^{th} component string,

Δt = time interval.

Table 2 and Tape 40 Output --

<u>Parameter</u>	<u>Description</u>
Q_k	Rate of energy addition to k^{th} component string
E_k	Total energy added to k^{th} component string during calculation time period

Note -- This component uses heat-transfer-fluid property data.

* System performance routine

Input --

<u>Parameter</u>	<u>Format</u>	<u>Columns</u>	<u>Description</u>
<u>Card 1</u>			
NAME	A10	1-10	Subroutine name (QMETER)
NCAL	I10	51-60	Number of energy measurements (maximum is nine)
NI	I10	61-70	State number upstream of component string to be monitored
NO	I10	71-80	Component number of last component in string
<u>Cards 2 and 3</u>			
NI	I10	1-10	State number upstream of component string to be measured
NO	I10	11-20	Component number of last component in string
NI	I10	21-30	State number upstream of component string to be measured
NO	I10	31-40	Component number of last component in string
NI	I10	41-50	State number upstream of component string to be measured
NO	I10	51-60	Component number of last component in string
NI	I10	61-70	State number upstream of component string to be measured
NO	I10	71-80	Component number of last component in string

APPENDIX D

SOLTES Examples*

The following examples are included to complement the discussion and instructions for SOLTES and to show the flexibility of SOLTES. These examples do not necessarily represent good system designs but are illustrations.

Example 1

A solar, open hot-water system for a residence is simulated. The system model schematic is shown in Figure D1. Three parallel flat-plate solar collectors heat water to charge an uninsulated, thin-walled tank that is used for thermal storage. An auxiliary heater is placed in series with the storage to assure that the hot-water supply temperature is at least 340 K. The hot-water volumetric flow requirement is $8.76 \times 10^{-6} \text{ m}^3/\text{s}$ (200 gal/day) and is constant throughout the day and night. The volumetric flow rate through the collectors is controlled by the pump at $2.2 \times 10^{-5} \text{ m}^3/\text{s}$. The performance of this system is simulated with an hourly time step from noon of the 84th day through noon of the 85th day of a typical meteorological year in Albuquerque, NM.

Figure D1. System Model Schematic for a Solar, Open Hot-Water System for a Residence

*The necessary EOF records are not shown in these listings.

Component/Information Routine Data (TAPE 1) --

Executive Routine Control Data (TAPE 6) --

Loop Definition Data (TAPE 8) --

Fluid Property Data (TAPE 9) --

2. TAPE9 is automatically generated by PRESOL.

D-2

Weather Data (TAPE 12) -- intentionally omitted

Executive Routine -- intentionally omitted

Output

EXAMPLE 1 FOR REPORT
HOT WATER SYSTEM

NYEARI = 1975 INITIAL YEAR
NDAYI = 84 INITIAL DAY
NHRI = 12 INITIAL HOUR
NSECI = 0 INITIAL SECOND
NYEARF = 1975 FINAL YEAR
NDAYF = 85 FINAL DAY
NHRF = 12 FINAL HOUR
NSECF = 0 FINAL SECOND

ITIME = 3600 TIME INCREMENT (SECONDS)

CONVERGENCE PARAMETERS

ABSOLUTE CONVERGENCE CRITERIA FOR TEMPERATURE = .1000
RELATIVE CONVERGENCE CRITERIA FOR TEMPERATURE (PERCENT) = .0100
ABSOLUTE CONVERGENCE CRITERIA FOR FLOW RATE = .0500
RELATIVE CONVERGENCE CRITERIA FOR FLOW RATE (PERCENT) = .0100
ABSOLUTE CONVERGENCE CRITERIA FOR PRESSURE = .0500
RELATIVE CONVERGENCE CRITERIA FOR PRESSURE (PERCENT) = .0100
ABSOLUTE CONVERGENCE CRITERIA FOR QUALITY = .0050
MAXIMUM NUMBER OF ITERATIONS PER TIME STEP = 50
NUMBER OF EXTENDED ITERATIONS WITH TABLE 1 PRINTOUT = 10

Output: Example 1 (cont'd)

DATA FOR SUBROUTINE WEATHR

ISTATNO= 23050 STATION NUMBER
OLAT = 35.05 LATITUDE ANGLE (DEG)
DLAT = 106.62 LONGITUDE ANGLE (DEG)

DATA FOR COMPONENT DAREXL

NO LOAD TAPE REQUESTED

LODTYP = HMATLO LOAD TYPE
NCOM = 8 NUMBER OF THE COMPONENT RECEIVING THIS LOAD
EXLOAD = .8780E-05 CONSTANT VALUE OF LOAD

DATA FOR COMPONENT MKPFLO

NCOM = 1 COMPONENT NUMBER
NSTAO = 1 OUTLET STATE NUMBER
NLP = 1 LOOP NUMBER
TO = .2900E+03 MAKEUP FLUID TEMPERATURE (DEG K)
PO = .3000E+06 MAKEUP FLUID PRESSURE (PA)
FLUID = WATER WORKING FLUID
NS1 = REFERENCE STATE 1
NS2 = 3 REFERENCE STATE 2
TYPE = THERM HEAT TRANSFER FLUID PROPERTIES ARE REQUIRED
IADV = 0 ADVECTIVE GAINS ARE NOT CALCULATED

DATA FOR COMPONENT PUMP

NCOM = 2 COMPONENT NUMBER
NSTAI = 1 INLET STATE NUMBER
TOI = .2900E+03 INITIAL INLET TEMPERATURE (DEG K)
POI = .3000E+06 INITIAL INLET PRESSURE (N/M2)
FMI = .1000E-01 INITIAL INLET FLUID FLOW RATE (KG/S)
PFIX = .4000E+06 FIXED OUTLET PRESSURE (N/M2)
EFF = .9000E+00 PUMP EFFICIENCY
FLUID = WATER FLUID PUMPED
NPUOP = FIXED PUMP OPERATION (#FIXED# OR #VARIABLE#)
FMV = .2200E-04 FIXED VOLUME FLOW RATE (M3/S)

Output: Example 1 (cont'd)

DATA FOR COMP

NCOM = 3 COMPONENT NUMBER
 NSTAI = 2 INLET STATE NUMBER
 TOI = .290E+03 INITIAL OUTLET TEMPERATURE (K)
 POI = .400E+06 INITIAL OUTLET PRESSURE (PA)
 FMI = .220E-01 INITIAL VOLUME FLOW RATE (M3/S)
 NCOL = 3 NUMBER OF COLLECTORS IN PARALLEL
 NG = 1 NUMBER OF GLASS PLATES
 PERIFL = .631E-02 WETTED PERIMETER (M)
 ARFL = .316E-05 FLOW CROSS SECTIONAL AREA (M2)
 XLFL = .200E+01 LENGTH OF FLUID CHANNEL (M)
 ARPL = .170E+01 PLATE AREA (M2)
 SPACPL = .150E+00 SPACING BETWEEN PLATES (M)
 XLPL = .200E+01 PLATE LENGTH (M)
 BET = .350E+02 COLLECTOR TILT FROM HORIZONTAL (DEG)
 CGAP = .300E-01 CONDUCTIVITY OF GAP BETWEEN PLATES (W/M/K)
 REFCV = .500E-01 COLLECTOR REFLECTANCE VISIBLE
 REFGV = .770E-01 GLASS REFLECTANCE VISIBLE
 TRNGV = .910E+00 GLASS TRANSMITTANCE VISIBLE
 EMTCI = .100E+00 COLLECTOR EMITTANCE INFRARED
 EMTEI = .900E+00 GLASS EMITTANCE INFRARED
 CONDINS = .600E-01 INSULATION CONDUCTIVITY (W/M/K)
 THKINS = .800E-01 INSULATION THICKNESS (M)
 FLUID = WATER FLUID

DATA FOR COMPONENT PIPE

NCOM = 4 COMPONENT NUMBER
 NSTAI = 3 INLET STATE NUMBER
 TOI = .3064E+03 INITIAL INLET TEMPERATURE (K)
 POI = .3145E+06 INITIAL INLET PRESSURE (N/M2)
 FMI = .2201E-01 INITIAL FLUID FLOW RATE (KG/S)
 FLUID = WATER FLUID
 XL = .1000E+02 PIPE LENGTH (M)
 DI = .1100E-01 PIPE DIAMETER (M)
 H = .6000E+01 HEAT TRANSFER COEFFICIENT (W/M2/K)
 NPIPE = 1 NUMBER OF PIPES IN PARALLEL
 PLOSS = .2500E+00 MAX ACCEPTABLE PRESS DROP (FRACTION OF INLET PRESSURE)

DATA FOR COMPONENT STORES

NCOM = 5 COMPONENT NUMBER
 NSTAI = 4 UPSTREAM COMP COMP NUMBER
 TOI = .3050E+03 INITIAL INLET TEMPERATURE (K)
 POI = .3137E+06 INITIAL INLET PRESSURE (N/M2)
 FMI = .2201E-01 INITIAL FLUID FLOW RATE (KG/S)
 SVOLI = .5000E+00 INITIAL STORED FLUID VOL (M3)
 STEMPI = .3400E+03 INITIAL STORED FLUID TEMP (K)
 VOLMIN = 0. MIN. FLUID VOL ALLOWED (M3)
 SPHMW = 0. MASS-SPHT PRODUCT FOR TANK WALL (J/K)
 SPHMI = 0. MASS-SPHT PRODUCT FOR INSULAT. (J/K)
 UA = .3060E+02 OVERALL H.T. COEF.-AREA PRODUCT (W/K)
 NFMOP = VARIABLE OUTLET FLOW OPTION (#EQUAL#, #FIXED#, OR #VARIABLE#)
 NCC = 8 COMP. NO. CONTROLLING OUTLET FLOW
 FLUID = WATER STORED FLUID

Output: Example 1 (cont'd)

DATA FOR COMPONENT PIPE

NCOM	=	6	COMPONENT NUMBER
NSTAI	=	5	INLET STATE NUMBER
TOI	=	.3400E+03	INITIAL INLET TEMPERATURE (K)
POI	=	.3137E+06	INITIAL INLET PRESSURE (N/M2)
FMI	=	.2201E-01	INITIAL FLUID FLOW RATE (KG/S)
FLUID	=	WATER	FLUID
XL	=	.1000E+02	PIPE LENGTH (M)
DI	=	.1100E-01	PIPE DIAMETER (M)
H	=	.6000E+01	HEAT TRANSFER COEFFICIENT (W/M2/K)
NPIPE	=	1	NUMBER OF PIPES IN PARALLEL
PLOSS	=	.2500E+00	MAX ACCEPTABLE PRESS DROP(FRACTION OF INLET PRESSURE)

DATA FOR COMPONENT AUXFUR

NCOM	=	7	COMPONENT NUMBER
NSTAI	=	6	UPSTREAM COMPONENT NUMBER
TOI	=	.3387E+03	INITIAL INLET TEMPERATURE (K)
POI	=	.3130E+06	INITIAL INLET PRESSURE (N/M2)
FMI	=	.2201E-01	INITIAL FLUID FLOW RATE (M3/S)
FLUID	=	WATER	FLUID
TOFIX	=	.3400E+03	FIXED OUTLET TEMPERATURE (K)
EFF	=	.9000E+00	EFFICIENCY OF FURNACE

DATA FOR COMPONENT WATHTR

NCOM	=	8	COMPONENT NUMBER
NSTAO	=	8	OUTLET STATE NUMBER
NSTAI	=	7	INLET STATE NUMBER
NSMKP	=	1	OUTLET STATE NUMBER OF MKPFLD
NLP	=	1	LOOP NUMBER
FLUID	=	WATER	FLUID
TOI	=	.3400E+03	INITIAL INLET TEMPERATURE (DEG K)
POI	=	.3130E+06	INITIAL INLET PRESSURE (PA)
FMI	=	.2201E-01	INITIAL FLUID FLOW RATE (KG/S)

ELECTRICAL PARASITICS IN SYSTEM

COMPONENT NUMBER
GENERATING
PARASITIC
2

LOOP NUMBER WHERE
PARASITIC IS MET
(*99 IF NOT MET)
*99

Output: Example 1 (cont'd)

 YEAR = DAY = 85 HOUR = 12

TABLE OF PRIMARY SUPPLY (PRISUP)

COMPONENT		VALUE	INTEGRATED
NAME	NO.	(W)	(J)
FLTPLT	3	5.1163E+03	1.2946E+08
TOTALS		5.1163E+03	1.2946E+08

TABLE OF AUXILIARY SUPPLY (AUXSUP)

COMPONENT		VALUE	INTEGRATED
NAME	NO.	(W)	(J)
AUXFUR	7	1.4932E+03	1.1759E+08
TOTALS		1.4932E+03	1.1759E+08

TABLE OF THERMAL STORAGE (THMSTO)

COMPONENT		VALUE	INTEGRATED
NAME	NO.	(W)	(J)
STORES	5	1.9035E+04	2.8819E+08
TOTALS		1.9035E+04	2.8819E+08

TABLE OF THERMAL LOSSES (THMLOS)

COMPONENT		VALUE	INTEGRATED
NAME	NO.	(W)	(J)
FLTPLT	3	1.1909E+03	5.7291E+07
PIPE	4	9.4482E+01	3.5650E+06
STORES	5	5.2167E+02	7.7007E+07
PIPE	6	3.4350E+01	5.0705E+06
TOTALS		1.8414E+03	1.4293E+08

Output: Sample 1 (cont'd)

TABLE OF ELECTRICAL LOADS REQUIRING

COMPONENT NAME	NO.	VALUE (W)	INTEGRATED VALUE (J)	SATISFYING COMPONENT NAME	NO.
PUMP	2	2.4444E+00	1.1440E+05		
TOTALS		2.4444E+00	1.1440E+05		

TOTAL SATISFIED BY THE SYSTEM (W)
 TOTAL SATISFIED EXTERNAL TO THE SYSTEM (W)
 CUMULATIVE TOTAL SATISFIED BY THE SYSTEM (J)
 CUMULATIVE TOTAL SATISFIED EXTERNAL TO THE SYSTEM (J)

0.
 2.4444E+00
 0.
 1.1440E+05

TABLE OF HOT WATER OR LIQUID LOADS (HWATLD)

COMPONENT NAME	NO.	VALUE (W)	INTEGRATED VALUE (J)
WATHTR	8	1.7981E+03	1.5536E+08
TOTALS		1.7981E+03	1.5536E+08

Output: Example 1 (cont'd)

SUMMARY

TOTAL ENERGY SUPPLY RATE TO THE SYSTEM (W)	6.6096E+03
RATIO OF PRIMARY AND TOTAL SUPPLY RATES (PERCENT)	77.41
RATE THAT THE SYSTEM PROVIDES BENFICIAL ENERGY (W)	1.7957E+03
SYSTEM ENERGY CONVERSION EFFICIENCY (PERCENT)	27.17
CUMULATIVE TOTAL ENERGY SUPPLIED TO THE SYSTEM (J)	2.4705E+08
RATIO OF CUMULATIVE PRIMARY AND TOTAL ENERGY SUPPLIES (PERCENT)	52.40
CUMULATIVE BENFICIAL ENERGY PROVIDED BY THE SYSTEM (J)	1.5524E+08
CUMULATIVE SYSTEM ENERGY CONVERSION EFFICIENCY (PERCENT)	42.06
ELECTRICITY REQUIRED TO RUN THE SYSTEM (W)	2.4444E+00
ELECTRICITY SUPPLIED TO THE SYSTEM (W)	2.4444E+00
CUMULATIVE ELECTRICITY REQUIRED TO RUN THE SYSTEM (J)	1.1440E+05
CUMULATIVE ELECTRICITY SUPPLIED TO THE SYSTEM (J)	1.1440E+05

Output: Example 1 (cont'd)

***** TABLE 1 OUTPUT *****

YEAR = 1975 DAY = 85 HOUR = 12 SEC = 0

COMPONENT NAME	OUTLET NUMBER	STATE	FLOW RATE (KG/S)	TEMPERATURE (DEG K)	PRESSURE (PA)	STATE	QUALITY (PERCENT)
MKPFLO	1		.2201E-01	.2900E+03	.3000E+06	COMPRESSED LIQUID	
PUMP	2		.2201E-01	.2900E+03	.4000E+06	COMPRESSED LIQUID	
FLTPLT	3		.2201E-01	.3326E+03	.3098E+06	COMPRESSED LIQUID	
PIPE	4		.2201E-01	.3316E+03	.3091E+06	COMPRESSED LIQUID	
STORE5	5		.8590E-02	.3035E+03	.3091E+06	COMPRESSED LIQUID	
PIPE	6		.8590E-02	.3026E+03	.3089E+06	COMPRESSED LIQUID	
AUXFUR	7		.8590E-02	.3400E+03	.3089E+06	COMPRESSED LIQUID	
WATHTR	8		.8590E-02	.3400E+03	.3089E+06	COMPRESSED LIQUID	

***** TABLE 2 OUTPUT *****

YEAR = 1975 DAY = 85 HOUR = 12 SEC = 0

WEATHR		AMBIENT TEMPERATURE (K)	.2865E+03
WEATHR		PRESSURE (PASCALS)	.8350E+05
WEATHR		WIND SPEED (M/S)	.3600E+01
WEATHR		TOTAL HORIZONTAL SOLAR INTENSITY (W/M2)	.8640E+03
WEATHR		DIRECT NORMAL SOLAR INTENSITY (W/M2)	.8456E+03
WEATHR		SOLAR ELEVATION ANGLE (DEG)	.5665E+02
WEATHR		SOLAR AZIMUTH ANGLE (DEG)	.4071E-12
MKPFLO	1	MAKE UP FLUID MASS FLOW RATE (KG/S)	.2201E-01
PUMP	2	POWER-PUMP POWER (WATTS)	.2444E+01
FLTPLT	3	COLLECTOR EFFICIENCY	.7672E+00
FLTPLT	3	RATE OF ENERGY TRANSFER TO FLUID	.3925E+04
PIPE	4	PIPE HEAT LOSS	.9448E+02
STORE5	5	FLUID VOLUME STORED (M3)	.8297E+00
STORE5	5	ENERGY STORAGE RATE (W)	.1903E+05
PIPE	6	PIPE HEAT LOSS	.3435E+02
AUXFUR	7	AUXILIARY FURNACE HEAT RATE (W)	.1344E+04
AUXFUR	7	AUXILIARY FURNACE-ENERGY SUPPLIED BY FUEL (W)	.1493E+04
WATHTR	8	VOLUMETRIC FLOW RATE (M3/S)	.8760E-05
WATHTR	8	ENERGY REQUIRED -HWATLD (W)	.1798E+04
EXECUTIVE		NUMBER OF ITERATIONS REQUIRED FOR CONVERGENCE	3

Example 2

A solar total-energy system that supplies 437.5 K process steam at a constant flow rate 0.1 kg/s and follows external electrical loads is simulated. The system model schematic is shown in Fig. D2. Solar energy is collected by a 800 m² field of focusing collectors with an overall

Figure D2. System Model Schematic for a Solar Total-Energy System

thermal efficiency of 60%. The heat-transfer fluids in the collector loop and in the cooling tower loop are Therminol 66 and water, respectively. The collectors and the auxiliary furnace supply the thermal boiler with Therminol 66 at 600 K. No thermal storage is included; however, an auxiliary furnace is included in the system to assure that sufficient energy is supplied to meet the loads and satisfy parasitics. The electrical loads are defined as a function of time by the sum of the electricity required for air conditioning (AIRCOND) and 95% of the electrical grid load (GRID) above 100,000 W (see Fig. D3). The power required to run the pumps (Components 30, 10, and

Figure D3. Electrical Loads for a Typical Day During the Simulation Period

21) is supplied by electricity and are parasitics. The electrical parasitics associated with Components 30 and 10 are satisfied by the system, while the electricity required to run Component 21 is supplied externally. The power required to run the other pump, Component 23, is supplied by mechanical power and is a mechanical power parasitic that is satisfied by the system. The power loop, Fluid Loop 3, contains two extraction turbine/generators and a direct-contact regenerative heater. Since the electrical power and mechanical power output of the loop is specified, and the energy transferred from the first flow branch is specified by meeting the process steam requirement, and one flow branch contains a regenerative heater, the energy transferred from the other flow branch through the condenser cannot be specified. This unspecified energy is transferred into water in the condenser and is ultimately rejected from the system by a cooling tower. The water lost in supplying the process steam is supplied by makeup fluid at 288 K and 1×10^5 Pa. The first turbine/generator produces only electricity and the second turbine generator produces both electrical and mechanical power. The performance of this system is simulated by an hourly step from noon of the 84th day through noon of the 97th day of a typical meteorological year in Albuquerque, NM.

The extrapolated computer time required to simulate this system for a year is 16 minutes; the simulation requires 137.3_8 K of central memory.

Input

Component/Information Routine Data (TAPE 1)--

WEATHR	50	CASE		
DAREXL	18.1	437.5		
THMLD	14	TAPE		
ELCLO	AIRCOND			
GRID	1.	0.		
.9	100000.			
LAST				
FOCOL	1	9	600.	
PIPE	120.	40	.6	
	2	1	3.	.100 20.
PUMP	10.25	30	2	4.E 5.7 VARIABLE
MIXJNT		3	12	
THMBLR		6	3	10. 1.
PUMP		10	6	4.E 5.9 VARIABLE
FLODIV		7	10	
PIPE		11	8	3. .100 20.
	10.25			
AUXFUR		12	11	600. .7 4.4E 7
LODMG		14	13	POWER YES
ELCDM	NONE			
ELCPS				
1	30			
2	10			
POWDM	NONE			
POWPS				
3ALL				
XTURBG		15	14	16 17 95. 85.
65.	75.	437.5	437.5	
PRSVAP		18	16	350. 1.013 E5
437.5	30.		1	11. 19 1.E 5 18
MKPFLD		19		288.
16NO		POWER		
MIXJNT		31	18	19
DONHT		20	31	25
XTURBG		24	17	25 26 380. 5.516E 5 2
60.	70.	437.5	310.	90. UNSPEC 80.
BFDPMF		21	20	1.379E 685. 95.
CNDHTR		27	26	28 29
10.	5.	LAST		
MIXJNT		22	27	21
BFDPMF		23	22	1.379E 580. 90.
POWER				
COOLTOW		29	28	295.
ENGAC1				

Executive Routine Control Data (TAPE 6)--

TIME	1975	84	12	0	1975	97	12	0	3600		LAST	
PRINT	TABLE1		1975	84	12	0	1975	97	12	0	24	OLAST
PRINT	TABLE3		1975	97	11	0	1975	97	12	0	1	OLAST
PRINT	TABLE2		1975	84	12	0	1975	97	12	0	24	OLAST
ID	EXAMPLE 2 FOR REPORT											
	TOTAL ENERGY SYSTEM											
RUN	LAST											

Loop Definition Data (TAPE 8)--

THERM 66	2	550.0000	.40000E+06	.10000E+02	1	5	6	10		
THERM 66	11	12	0	0	0	0	0	0	0	0
WATER	3	550.0000	.13790E+07	.20000E+00	14	13	15	16		
WATER	17	18	19	31	20	21	22	23	24	25
WATER	4	304.9000	.10000E+06	.12000E+02	28	29	0	0		

Fluid Property Data (TAPE 9)--

- NOTES: 1. The constants characterizing the power-cycle working fluid for THERMINOL 66 are not necessary.
2. TAPE9 is automatically generated by PRESOL.

THERM 66	THERM				
.255000E+03	.644000E+03	.644000E+03			
.124975E+04	-.812334E+00	0.	0.	0.	0.
0.	0.	0.	0.	0.	0.
.255000E+03	.644000E+03	.644000E+03			
.390480E+03	.382071E+01	0.	0.	0.	0.
0.	0.	0.	0.	0.	0.
.283000E+03	.394000E+03	.644000E+03			
.701064E-01	-.996187E+02	.529938E+05	-.125100E+08	.110599E+10	
-.317083E-04	.862897E-01	-.932986E+02	.505262E+05	-.137203E+08	.151416E+10
.255000E+03	.644000E+03	.644000E+03			
.137560E+00	-.512883E-04	0.	0.	0.	0.
0.	0.	0.	0.	0.	0.
THERM 66	POWER				
0.	0.	0.	0.	0.	0.
0.	0.	0.	0.	0.	0.
0.	0.				
WATER	THERM				
.273000E+03	.573000E+03	.573000E+03			
.921342E+03	.740090E+00	-.130148E-02	-.106738E-05		0.
0.	0.	0.	0.		0.
.273000E+03	.573000E+03	.573000E+03			
-.365498E+05	.554955E+03	-.296600E+01	.778268E-02	-.100529E-04	.514200E-08
0.	0.	0.	0.	0.	0.
.273000E+03	.353000E+03	.573000E+03			
.806824E-04	-.113673E+00	.601153E+02	-.141529E+05	.125809E+07	0.
.995082E-05	-.208012E-01	.174487E+02	-.725029E+04	.148851E+07	-.119064E+09
.273000E+03	.573000E+03	.573000E+03			
-.117614E+01	.791539E-02	.148630E-04	-.131695E-06	.247601E-09	-.155647E-12
0.	0.	0.	0.	0.	0.
WATER	POWER				
.180150E+02	.373200E+03	.647300E+03	.217600E+03	.560000E+02	.344000E+00
.998000E+00	.293000E+03	.770100E+01	.459500E-03	.252100E-05	-.859000E-09
.971700E+04	.250000E+00				

NOTE: This listing has been shortened.

(each succeeding day is the same)

Executive Routine--intentionally omitted

Weather Data--intentionally omitted

Output

NOTE: For TABLE1, TABLE2, and TABLE 3 only the output for the simulation end time is shown.

EXAMPLE 2 FOR REPORT
TOTAL ENERGY SYSTEM

NYEARI = 1975 INITIAL YEAR
NDAYI = 84 INITIAL DAY
NHRI = 12 INITIAL HOUR
NSECI = 0 INITIAL SECOND
NYEARF = 1975 FINAL YEAR
NDAYF = 97 FINAL DAY
NHRF = 12 FINAL HOUR
NSECF = 0 FINAL SECOND

ITIME = 3600 TIME INCREMENT (SECONDS)

CONVERGENCE PARAMETERS

ABSOLUTE CONVERGENCE CRITERIA FOR TEMPERATURE	=	.1000
RELATIVE CONVERGENCE CRITERIA FOR TEMPERATURE (PERCENT)	=	.0100
ABSOLUTE CONVERGENCE CRITERIA FOR FLOW RATE	=	.0500
RELATIVE CONVERGENCE CRITERIA FOR FLOW RATE (PERCENT)	=	.0100
ABSOLUTE CONVERGENCE CRITERIA FOR PRESSURE	=	.0500
RELATIVE CONVERGENCE CRITERIA FOR PRESSURE (PERCENT)	=	.0100
ABSOLUTE CONVERGENCE CRITERIA FOR QUALITY	=	.0050
MAXIMUM NUMBER OF ITERATIONS PER TIME STEP	=	50
NUMBER OF EXTENDED ITERATIONS WITH TABLE 1 PRINTOUT	=	10

Output: Example 2 (cont)

DATA FOR SUBROUTINE WEATHR

ISTATNO= 23050 STATION NUMBER
DLAT = 35.05 LATITUDE ANGLE (DEG)
DLAT = 106.62 LONGITUDE ANGLE (DEG)

DATA FOR COMPONENT DAREXL

ID1 =TEST FIRST WORD IDENTIFER OF LOAD DATA TAPE
ID2 =CASE SECOND WORD IDENTIFER OF LOAD DATA TAPE
IYEAR = 1975 INITIAL YEAR OF DATA ON LOAD TAPE
IDAY = 84 INITIAL DAY OF DATA ON LOAD TAPE
IHOURL = 0 INITIAL HOUR OF DATA ON LOAD TAPE
IDTM = 3600 CONSTANT TIME INTEVERAL BETWEEN DATA ON LOAD TAPE (SEC)

LODTYP =THMLD LOAD TYPE
NCOM = 18 NUMBER OF THE COMPONENT RECEIVING THIS LOAD
TEMP = .4375E+03 THERMAL LOAD SUPPLY TEMPERATURE
EXLOAD = .1000E+00 CONSTANT VALUE OF LOAD

LODTYP =ELCLO LOAD TYPE
NCOM = 14 NUMBER OF THE COMPONENT RECEIVING THIS LOAD
NAME =GRID LOAD NAME
C = .9000E+00 C OF EQUATION C(NAME-B)
B = .1000E+06 B OF EQUATION C(NAME-B)
NAME =AIRCOND LOAD NAME
C = .1000E+01 C OF EQUATION C(NAME-B)
B =0. B OF EQUATION C(NAME-B)

DATA FOR COMPONENT FOCOL

NCOM = 1 COMPONENT NUMBER
NSTAO = 1 OUTLET STATE NUMBER
NSTAI = 9 INLET STATE NUMBER
NLP = 1 LOOP NUMBER
FLUID = THERM 66 RECEIVER HEAT TRANSFER FLUID
TOUT = .6000E+03 COLLECTOR OUTLET TEMPERATURE (DEG K)
NCOL = 1 NUMBER OF COLLECTORS IN PARALLEL
W = .2000E+02 REFLECTOR WIDTH (M)
XL = .4000E+02 REFLECTOR LENGTH (M)
EFF = .6000E+00 COLLECTOR EFFICIENCY (-)
TOI = .5500E+03 INITIAL INLET TEMPERATURE (DEG C)
POI = .4000E+06 INITIAL INLET PRESSURE (PA)
FMI = .1000E+02 INITIAL INLET FLOW RATE (KG/S)

Output: Example 2 (cont)

DATA FOR COMPONENT PIPE

```

NCOM      =      2 COMPONENT NUMBER
NSTAI     =      1 INLET STATE NUMBER
TOI       = .6000E+03 INITIAL INLET TEMPERATURE (K)
POI       = .4000E+06 INITIAL INLET PRESSURE (N/M2)
FMI       = .2721E+00 INITIAL FLUID FLOW RATE (KG/S)
FLUID     =THERM 66 FLUID
XL        = .3000E+01 PIPE LENGTH (M)
DI        = .1000E+00 PIPE DIAMETER (M)
H         = .2000E+02 HEAT TRANSFER COEFFICIENT (W/M2/K)
NPIPE     =      1 NUMBER OF PIPES IN PARALLEL
PLOSS     = .2500E+00 MAX ACCEPTABLE PRESS DROP(FRACTION OF INLET PRESSURE)

```

DATA FOR COMPONENT PUMP

```

NCOM      =      30 COMPONENT NUMBER
NSTAI     =      2 INLET STATE NUMBER
TOI       = .5916E+03 INITIAL INLET TEMPERATURE (DEG K)
POI       = .4000E+06 INITIAL INLET PRESSURE (N/M2)
FMI       = .2721E+00 INITIAL INLET FLUID FLOW RATE (KG/S)
PFIX      = .4000E+06 FIXED OUTLET PRESSURE (N/M2)
EFF       = .7000E+00 PUMP EFFICIENCY
FLUID     =THERM 66 FLUID PUMPED
NPUOP     =VARIABLE PUMP OPERATION (#FIXED# OR #VARIABLE#)

```

DATA FOR COMPONENT MIXJNT

```

NCOM      =      3 COMPONENT NUMBER
NSTAI1    =      12 FIRST UPSTREAM COMPONENT NUMBER
NSTAI2    =      30 SECOND UPSTREAM COMPONENT NUMBER
TOI1      = .5500E+03 INITIAL TEMPERATURE-INLET 1 (K)
POI1      = .4000E+06 INITIAL PRESSURE-INLET 1 (N/M2)
FMI1      = .1000E+02 INITIAL FLOW RATE-INLET 1 (KG/S)
TOI2      = .5916E+03 INITIAL TEMPERATURE-INLET 2 (K)
POI2      = .4000E+06 INITIAL PRESSURE-INLET 2 (N/M2)
FMI2      = .2721E+00 INITIAL FLOW RATE-INLET 2 (KG/S)
FLUID     =THERM 66 FLUID

```

Output: Example 2 (cont)

DATA FOR COMPONENT THMBLR

```

NCOMT = 6 THERMAL SIDE COMPONENT NUMBER
NSTAOT = 6 THERMAL SIDE OUTLET STATE NUMBER
NSTAIT = 3 THERMAL SIDE INLET STATE NUMBER
NLPT = 2 THERMAL LOOP NUMBER
FLUIDT = THERM 66 THERMAL LOOP WORKING FLUID
NCOMP = 13 POWER SIDE COMPONENT NUMBER
NSTAOP = 13 POWER SIDE OUTLET STATE NUMBER
NSTAIP = 23 POWER SIDE INLET STATE NUMBER
NLPP = 3 POWER LOOP NUMBER
FLUIDP = WATER POWER LOOP WORKING FLUID
DT23 = .1000E+02 DIFFERENCE BETWEEN POWER SIDE OUTLET TEMPERATURE AND THERMAL SIDE INLET TEMPERATURE (DEG K)
DTPNCH = .1000E+01 DIFFERENCE BETWEEN POWER SIDE TEMPERATURE AND THERMAL SIDE TEMPERATURE AT THE PINCH POINT (DEG K)
TOIP = .5500E+03 INITIAL POWER SIDE INLET TEMPERATURE (DEG K)
POIP = .1379E+07 INITIAL POWER SIDE INLET PRESSURE (PA)
FMIP = .2000E+00 INITIAL POWER SIDE INLET FLOW RATE (KG/S)
TOIT = .5511E+03 INITIAL THERMAL SIDE INLET TEMPERATURE (DEG K)
POIT = .4000E+06 INITIAL THERMAL SIDE INLET PRESSURE (PA)
FMIT = .1027E+02 INITIAL THERMAL SIDE INLET FLOW RATE (KG/S)

```

DATA FOR COMPONENT PUMP

```

NCOM = 10 COMPONENT NUMBER
NSTAI = 6 INLET STATE NUMBER
TOI = .5500E+03 INITIAL INLET TEMPERATURE (DEG K)
POI = .4000E+06 INITIAL INLET PRESSURE (N/M2)
FMI = .1000E+02 INITIAL INLET FLUID FLOW RATE (KG/S)
PFI = .4000E+06 FIXED OUTLET PRESSURE (N/M2)
EFF = .9000E+00 PUMP EFFICIENCY
FLUID = THERM 66 FLUID PUMPED
NPUOP = VARIABLE PUMP OPERATION (#FIXED# OR #VARIABLE#)

```

DATA FOR COMPONENT FLODIV

```

NCOM = 7 COMPONENT NUMBER
NSTAI = 10 INLET STATE NUMBER
NLP = 2 LOOP NUMBER
NSTA01 = 9 OUTLET 1 STATE NUMBER
NSTA02 = 8 OUTLET 2 STATE NUMBER
NSREF = 1 OUTLET 1 FLOW RATE IS SET EQUAL TO THE FLOW RATE AT REFERENCE STATE
NUMBER NSREF
FLUID = THERM 66 WORKING FLUID
TOI = .5500E+03 INITIAL INLET TEMPERATURE (DEG K)
POI = .4000E+06 INITIAL INLET PRESSURE (PA)
FMI = .1000E+02 INITIAL INLET FLOW RATE (KG/S)

```

Output: Example 2 (cont)

DATA FOR COMPONENT PIPE

NCOM = 11 COMPONENT NUMBER
 NSTAI = 8 INLET STATE NUMBER
 TOI = .5500E+03 INITIAL INLET TEMPERATURE (K)
 POI = .4000E+06 INITIAL INLET PRESSURE (N/M2)
 FMI = .9728E+01 INITIAL FLUID FLOW RATE (KG/S)
 FLUID = THERM 66 FLUID
 XL = .3000E+01 PIPE LENGTH (M)
 DI = .1000E+00 PIPE DIAMETER (M)
 H = .2000E+02 HEAT TRANSFER COEFFICIENT (W/M2/K)
 NPIPE = 1 NUMBER OF PIPES IN PARALLEL
 PLOSS = .2500E+00 MAX ACCEPTABLE PRESS DROP (FRACTION OF INLET PRESSURE)

DATA FOR COMPONENT AUXFUR

NCOM = 12 COMPONENT NUMBER
 NSTAI = 11 UPSTREAM COMPONENT NUMBER
 TOI = .5498E+03 INITIAL INLET TEMPERATURE (K)
 POI = .3995E+06 INITIAL INLET PRESSURE (N/M2)
 FMI = .9728E+01 INITIAL FLUID FLOW RATE (M3/S)
 FLUID = THERM 66 FLUID
 TOFIX = .6000E+03 FIXED OUTLET TEMPERATURE (K)
 EFF = .7000E+00 EFFICIENCY OF FURNACE

DATA FOR COMPONENT LODMG

NCOM = 14 COMPONENT NUMBER
 NSTAO = 14 OUTLET STATE NUMBER
 NSTAI = 13 INLET STATE NUMBER
 NLP = 3 LOOP NUMBER
 FLUID = WATER WORKING FLUID

 LPMOD = POWER THIS POWER LOOP PRODUCES ELECTRICAL POWER AND MECHANICAL POWER TO MEET ALL POWER LOADS, POWER DEMANDS, AND POWER PARASITICS AS DEFINED BY INPUT TO THIS ROUTINE AND SATISFIES THERMAL LOADS AND THERMAL DEMANDS WHOSE SUM TOTAL IS EQUAL TO THE NUMBER OF EXTRACTION TURBINES LESS THE NUMBER OF REGENERATIVE HEATERS IN THIS POWER LOOP. ENERGY IS TRANSFERRED FROM THE OTHER FLOW BRANCH AT AN UNSPECIFIED RATE.
 IELCLO = YES EXTERNAL ELECTRICAL POWER LOADS ARE SATISFIED BY THIS POWER LOOP
 IPOWLO = NO EXTERNAL MECHANICAL POWER LOADS ARE SATISFIED BY THIS POWER LOOP
 EDMOD = NONE NO ELECTRICAL DEMANDS ARE SATISFIED BY THIS POWER LOOP
 EPSMOD = ELECTRICAL PARASITICS GENERATED BY COMPONENTS WHOSE NUMBERS ARE IN THE FOLLOWING LIST ARE SATISFIED BY THIS POWER LOOP
 30 10
 PDMOD = NONE NO MECHANICAL POWER DEMANDS ARE SATISFIED BY THIS POWER LOOP
 PPSMOD = MECHANICAL POWER PARASITICS GENERATED BY COMPONENTS WHOSE NUMBERS ARE IN THE FOLLOWING LIST ARE SATISFIED BY THIS POWER LOOP
 14 13 15 16 17 18 19 31 20 21
 22 23 24 25 26 27
 TOI = .5500E+03 INITIAL INLET TEMPERATURE (DEG K)
 POI = .1379E+07 INITIAL INLET PRESSURE (PA)
 FMI = .2000E+00 INITIAL INLET FLOW RATE (KG/S)

Output: Example 2 (cont)

DATA FOR COMPONENT XTURBG

```
NCOM      =      15 COMPONENT NUMBER
NSTAP     =      16 EXTRACTION PORT STATE NUMBER
NSTAE     =      17 EXIT STATE NUMBER
NSTAI     =      14 INLET STATE NUMBER
NLP       =      3 LOOP NUMBER
FLUID     = WATER   WORKING FLUID
NT        =      1 TURBINE NUMBER
NXT       =      1 EXTRACTION TURBINE NUMBER
ETAH      =      65.00 TURBINE ISENTROPIC EFFICIENCY FROM INLET TO EXTRACTION PORT (PERCENT)
ETAL      =      75.00 TURBINE ISENTROPIC EFFICIENCY FROM EXTRACTION PORT TO EXIT (PERCENT)
ETAG      =      95.00 GENERATOR EFFICIENCY (PERCENT)
ETAM      =      85.00 TURBINE MECHANICAL EFFICIENCY (PERCENT)
TB        = .4375E+03 SATURATION TEMPERATURE AT THE TURBINE EXTRACTION PORT (DEG K)
TD        = .4375E+03 SATURATION TEMPERATURE AT TURBINE EXIT (DEG K)
X         =      -0.00 RATIO OF TURBINE MECHANICAL POWER AND ELECTRICAL POWER (PERCENT)
TOI       = .5500E+03 INITIAL INLET TEMPERATURE (DEG K)
POI       = .1379E+07 INITIAL INLET PRESSURE (PA)
FMI       = .2000E+00 INITIAL INLET FLOW RATE (KG/S)
```

DATA FOR COMPONENT PRSVAP

```
NCOM      =      18 COMPONENT NUMBER
NSTAO     =      18 OUTLET STATE NUMBER
NSTAI     =      16 INLET STATE NUMBER
NLP       =      3 LOOP NUMBER
NBR       =      1 THIS COMPONENT DETERMINES THE THE FLOW RATE IN THE FLOW BRANCH NUMBER NBR
FLUID     = WATER   WORKING FLUID
TEMP      = .4375E+03 PROCESS VAPOR SUPPLY TEMPERATURE (DEG K)
TOL       = .1000E+01 PROCESS VAPOR TEMPERATURE TOLERANCE (DEG K)
FMLOSS    =      30.00 FLUID LOSS IN PRSVAP (PERCENT)
T2        = .3500E+03 FIXED OUTLET STATE TEMPERATURE (DEG K)
P2        = .1013E+06 FIXED OUTLET STATE PRESSURE (PA)
IQMTCH    =      1 EXTERNAL LOADS ARE FOLLOWED
NMKP      =      19 MKPFLD OUTLET STATE NUMBER
TREF      =      HEAT IS EQUAL TO THMLD
TOI       = .4946E+03 INITIAL INLET TEMPERATURE (DEG K)
POI       = .7042E+06 INITIAL INLET PRESSURE (PA)
FMI       = 0.      INITIAL INLET FLOW RATE (KG/S)
```

Output: Example 2 (cont)

DATA FOR COMPONENT MKPFLO

NCOM = 19 COMPONENT NUMBER
 NSTAO = 19 OUTLET STATE NUMBER
 NLP = 3 LOOP NUMBER
 TO = .2880E+03 MAKEUP FLUID TEMPERATURE (DEG K)
 PO = .1000E+06 MAKEUP FLUID PRESSURE (PA)
 FLUID = WATER WORKING FLUID
 NS1 = 18 REFERENCE STATE 1
 NS2 = 16 REFERENCE STATE 2
 TYPE = POWER POWER CYCLE WORKING FLUID CONSTANTS ARE REQUIRED
 IADV = 0 ADVECTIVE GAINS ARE NOT CALCULATED

DATA FOR COMPONENT MIXJNT

NCOM = 31 COMPONENT NUMBER
 NSTAI1 = 18 FIRST UPSTREAM COMPONENT NUMBER
 NSTAI2 = 19 SECOND UPSTREAM COMPONENT NUMBER
 TOI1 = .3500E+03 INITIAL TEMPERATURE-INLET 1 (K)
 POI1 = .1013E+06 INITIAL PRESSURE-INLET 1 (N/M2)
 FMI1 = .7000E-01 INITIAL FLOW RATE-INLET 1 (KG/S)
 TOI2 = .2880E+03 INITIAL TEMPERATURE-INLET 2 (K)
 POI2 = .1000E+06 INITIAL PRESSURE-INLET 2 (N/M2)
 FMI2 = 0. INITIAL FLOW RATE-INLET 2 (KG/S)
 FLUID = WATER FLUID

DATA FOR COMPONENT DCONHT

NCOM = 20 COMPONENT NUMBER
 NSTAO = 20 OUTLET STATE NUMBER
 NSTAI1 = 31 STATE NUMBER OF LIQUID INLET
 NSTAI2 = 25 STATE NUMBER OF SUPERHEATED VAPOR OR LIQUID-VAPOR MIXTURE INLET
 NLP = 3 LOOP NUMBER
 FLUID = WATER WORKING FLUID
 NBR = 2 THIS COMPONENT DETERMINES THE FLOW RATE IN THE FLOW BRANCH NUMBER NBR
 T3 = .3800E+03 OUTLET TEMPERATURE (DEG K)
 P3 = .5516E+06 OUTLET PRESSURE (PA)
 TOI1 = .3500E+03 INITIAL LIQUID INLET TEMPERATURE (DEG K)
 POI1 = .1013E+06 INITIAL LIQUID INLET PRESSURE (PA)
 FMI1 = .7000E-01 INITIAL LIQUID INLET FLOW RATE (KG/S)
 TOI2 = .5500E+03 INITIAL SUPERHEATED VAPOR OR LIQUID-VAPOR INLET TEMPERATURE (DEG K)
 POI2 = .1379E+07 INITIAL SUPERHEATED VAPOR OR LIQUID-VAPOR INLET PRESSURE (PA)
 FMI2 = .2000E+00 INITIAL SUPERHEATED VAPOR OR LIQUID-VAPOR INLET FLOW RATE (KG/S)

Output: Example 2 (cont)

DATA FOR COMPONENT XTURBG

NCOM	=	24	COMPONENT NUMBER
NSTAP	=	25	EXTRACTION PORT STATE NUMBER
NSTAE	=	26	EXIT STATE NUMBER
NSTAI	=	17	INLET STATE NUMBER
NLP	=	3	LOOP NUMBER
FLUID	=	WATER	WORKING FLUID
NT	=	2	TURBINE NUMBER
NXT	=	2	EXTRACTION TURBINE NUMBER
ETAH	=	60.00	TURBINE ISENTROPIC EFFICIENCY FROM INLET TO EXTRACTION PORT (PERCENT)
ETAL	=	70.00	TURBINE ISENTROPIC EFFICIENCY FROM EXTRACTION PORT TO EXIT (PERCENT)
ETAG	=	90.00	GENERATOR EFFICIENCY (PERCENT)
ETAM	=	80.00	TURBINE MECHANICAL EFFICIENCY (PERCENT)
TB	=	.4375E+03	SATURATION TEMPERATURE AT THE TURBINE EXTRACTION PORT (DEG K)
TD	=	.3100E+03	SATURATION TEMPERATURE AT TURBINE EXIT (DEG K)
X	=	UNSPEC	THE RATIO OF TURBINE MECHANICAL POWER AND ELECTRICAL POWER IS UNSPECIFIED
TOI	=	.4946E+03	INITIAL INLET TEMPERATURE (DEG K)
POI	=	.7042E+06	INITIAL INLET PRESSURE (PA)
FMI	=	.2000E+00	INITIAL INLET FLOW RATE (KG/S)

DATA FOR COMPONENT BFORMP

NCOM	=	21	COMPONENT NUMBER
NSTAO	=	21	OUTLET STATE NUMBER
NSTAI	=	20	INLET STATE NUMBER
NLP	=	3	LOOP NUMBER
FLUID	=	WATER	WORKING FLUID
P2	=	.1379E+07	OUTLET PRESSURE (PA)
ETAI	=	85.00	PUMP ISENTROPIC EFFICIENCY (PERCENT)
ETAM	=	95.00	PUMP MECHANICAL EFFICIENCY (PERCENT)
MODE	=		PUMP POWER IS SUPPLIED BY ELECTRICITY
TOI	=	.3800E+03	INITIAL INLET TEMPERATURE (DEG K)
POI	=	.5516E+06	INITIAL INLET PRESSURE (PA)
FMI	=	.7403E-01	INITIAL INLET FLOW RATE (KG/S)

Output: Example 2 (cont)

DATA FOR COMPONENT CNDHTR

NCOM1 = 27 POWER SIDE COMPONENT NUMBER
 NSTA01 = 27 POWER SIDE OUTLET STATE NUMBER
 NSTAI1 = 26 POWER SIDE INLET STATE NUMBER
 NLP1 = 3 POWER LOOP NUMBER
 FLUID1 = WATER POWER LOOP WORKING FLUID
 NCOM2 = 28 THERMAL SIDE COMPONENT NUMBER
 NSTA02 = 28 THERMAL SIDE OUTLET STATE NUMBER
 NSTAI2 = 29 THERMAL SIDE INLET STATE NUMBER
 NLP2 = 4 THERMAL LOOP NUMBER
 FLUID2 = WATER THERMAL LOOP WORKING FLUID
 NBR = LAST THIS COMPONENT DETERMINES THE FLOW RATE IN THE CONDENSATE RETURN FROM THE LAST TURBINE
 DT32 = .1000E+02 TEMPERATURE DIFFERENCE BETWEEN THERMAL SIDE INLET AND POWER SIDE OUTLET (DEG K)
 DTPNCH = .5000E+01 TEMPERATURE DIFFERENCE BETWEEN THERMAL SIDE AND POWER SIDE AT THE PINCH POINT (DEG K)
 IQMTCH = -0 THERMAL DEMAND IS NOT MET
 TOI1 = .3100E+03 INITIAL POWER SIDE INLET TEMPERATURE (DEG K)
 POI1 = .6150E+04 INITIAL POWER SIDE INLET PRESSURE (PA)
 FMI1 = .1960E+00 INITIAL POWER SIDE INLET FLOW RATE (KG/S)
 TOI2 = .3049E+03 INITIAL THERMAL SIDE INLET TEMPERATURE (DEG K)
 POI2 = .1000E+06 INITIAL THERMAL SIDE INLET PRESSURE (PA)
 FMI2 = .1200E+02 INITIAL THERMAL SIDE INLET FLOW RATE (KG/S)

DATA FOR COMPONENT MIXJNT

NCOM = 22 COMPONENT NUMBER
 NSTAI1 = 27 FIRST UPSTREAM COMPONENT NUMBER
 NSTAI2 = 21 SECOND UPSTREAM COMPONENT NUMBER
 TOI1 = .5500E+03 INITIAL TEMPERATURE-INLET 1 (K)
 POI1 = .6150E+04 INITIAL PRESSURE-INLET 1 (N/M2)
 FMI1 = .2000E+00 INITIAL FLOW RATE-INLET 1 (KG/S)
 TOI2 = .3800E+03 INITIAL TEMPERATURE-INLET 2 (K)
 POI2 = .1379E+07 INITIAL PRESSURE-INLET 2 (N/M2)
 FMI2 = .7403E-01 INITIAL FLOW RATE-INLET 2 (KG/S)
 FLUID = WATER FLUID

Output: Example 2 (cont)

DATA FOR COMPONENT BFOPMP

NCOM = 23 COMPONENT NUMBER
NSTAO = 23 OUTLET STATE NUMBER
NSTAI = 22 INLET STATE NUMBER
NLP = 3 LOOP NUMBER
FLUID = WATER WORKING FLUID
P2 = .1379E+07 OUTLET PRESSURE (PA)
ETAI = 80.00 PUMP ISENTROPIC EFFICIENCY (PERCENT)
ETAM = 90.00 PUMP MECHANICAL EFFICIENCY (PERCENT)
MODE = POWER PUMP POWER IS SUPPLIED BY MECHANICAL POWER
TOI = .5041E+03 INITIAL INLET TEMPERATURE (DEG K)
POI = .3770E+06 INITIAL INLET PRESSURE (PA)
FMI = .2740E+00 INITIAL INLET FLOW RATE (KG/S)

DATA FOR COMPONENT COOLTOW

NCOM = 29 COMPONENT NUMBER
NSTAI = 28 UPSTREAM COMPONENT COMP NUMBER
TOI = .3049E+03 INITIAL INLET TEMPERATURE (K)
POI = .1000E+06 INITIAL INLET PRESSURE (N/M2)
FMI = .1200E+02 INITIAL FLOW RATE (KG/S)
TOFIX = .2950E+03 FIXED OUTLET TEMPERATURE (K)
FLUID = WATER FLUID

Output: Example 2 (cont)

ELECTRICAL PARASITICS IN SYSTEM

COMPONENT NUMBER GENERATING PARASITIC	LOOP NUMBER WHERE PARASITIC IS MET (*99 IF NOT MET)
30	3
10	3
21	*99

MECH POWER PARASITICS IN SYSTEM

COMPONENT NUMBER GENERATING PARASITIC	LOOP NUMBER WHERE PARASITIC IS MET (*99 IF NOT MET)
23	3

Output: Example 2 (cont)

***** TABLE 3 OUTPUT *****

YEAR = 1975 DAY = 97 HOUR = 12 SEC = 0

TABLE OF PRIMARY SUPPLY (PRISUP)

COMPONENT NAME	NO.	VALUE (W)	INTEGRATED VALUE (J)
FOCOL	1	8.9865E+05	3.7294E+11
TOTALS		8.9865E+05	3.7294E+11

TABLE OF AUXILIARY SUPPLY (AUXSUP)

COMPONENT NAME	NO.	VALUE (W)	INTEGRATED VALUE (J)
AUXFUR	12	5.3772E+06	3.5399E+12
TOTALS		5.3772E+06	3.5399E+12

TABLE OF THERMAL LOSSES (THML0S)

COMPONENT NAME	NO.	VALUE (W)	INTEGRATED VALUE (J)
FOCOL	1	4.9981E+05	1.8267E+11
PIPE	2	5.7571E+03	6.3125E+09
PIPE	11	2.2497E+03	2.7561E+09
TOTALS		5.0782E+05	1.9174E+11

Output: Example 2 (cont)

TABLE OF HEAT TRANSFER (HEAT)

FROM COMPONENT			INTEGRATED	TO COMPONENT		
NAME	NO.	VALUE (W)	VALUE (J)	NAME	NO.	
PRSVAP	18	2.7581E+05	3.0981E+11			
COOLTOW	29	3.1851E+06	1.9258E+12			
TOTALS		3.4609E+06	2.2356E+12			

TOTAL TRANSFERRED BETWEEN COMPONENTS IN THE SYSTEM (W)

0.

TOTAL TRANSFERRED FROM THE SYSTEM (W)

3.4609E+06

CUMULATIVE TOTAL TRANSFERRED BETWEEN COMPONENTS (J)

0.

CUMULATIVE TOTAL TRANSFERRED FROM THE SYSTEM (J)

2.2356E+12

TABLE OF ELECTRICAL PARASITICS (ELCPS)

REQUIRING COMPONENT			INTEGRATED	SATISFYING COMPONENT		
NAME	NO.	VALUE (W)	VALUE (J)	NAME	NO.	
PUMP	30	1.1912E-02	6.0107E+03	LODMG	14	
PUMP	10	4.7094E+00	1.7949E+06	LODMG	14	
BFDPMF	21	1.2033E+02	1.3516E+08			
TOTALS		1.2505E+02	1.3696E+08			

TOTAL SATISFIED BY THE SYSTEM (W)

4.7214E+00

TOTAL SATISFIED EXTERNAL TO THE SYSTEM (W)

1.2033E+02

CUMULATIVE TOTAL SATISFIED BY THE SYSTEM (J)

1.8009E+06

CUMULATIVE TOTAL SATISFIED EXTERNAL TO THE SYSTEM (J)

1.3516E+08

Output: Example 2 (cont)

TABLE OF MECHANICAL POWER PARASITICS (POWPS)			
REQUIRING			SATISFYING
COMPONENT		INTEGRATED	COMPONENT
NAME	NO.	VALUE	NAME
		(W)	NO.
		(J)	
BFDMP	23	2.5008E+03	LODMG
TOTALS		2.5008E+03	14
		1.5167E+09	
		1.5167E+09	

TOTAL SATISFIED BY THE SYSTEM (W)
 TOTAL SATISFIED EXTERNAL TO THE SYSTEM (W)
 CUMULATIVE TOTAL SATISFIED BY THE SYSTEM (J)
 CUMULATIVE TOTAL SATISFIED EXTERNAL TO THE SYSTEM (J)

2.5008E+03
 0.
 1.5167E+09
 0.

TABLE OF ELECTRICAL LOADS (ELCLD)			
COMPONENT			INTEGRATED
NAME	NO.	VALUE	VALUE
		(W)	(J)
		(J)	
LODMG	14	1.2500E+05	8.0730E+10
TOTALS		1.2500E+05	8.0730E+10

TABLE OF MECHANICAL POWER LOADS (POWLO)			
COMPONENT			INTEGRATED
NAME	NO.	VALUE	VALUE
		(W)	(J)
		(J)	
LODMG	14	0.	0.
TOTALS		0.	0.

TABLE OF THERMAL LOADS (THMLD)			
COMPONENT			INTEGRATED
NAME	NO.	VALUE	VALUE
		(W)	(J)
		(J)	
PRSVAP	18	2.7581E+05	3.0981E+11
TOTALS		2.7581E+05	3.0981E+11

Output: Example 2 (cont)

SUMMARY

TOTAL ENERGY SUPPLY RATE TO THE SYSTEM (W)	6.2758E+06
RATIO OF PRIMARY AND TOTAL SUPPLY RATES (PERCENT)	14.32
RATE THAT THE SYSTEM PROVIDES BENEFICIAL ENERGY (W)	4.0069E+05
SYSTEM ENERGY CONVERSION EFFICIENCY (PERCENT)	6.38
CUMULATIVE TOTAL ENERGY SUPPLIED TO THE SYSTEM (J)	3.9128E+12
RATIO OF CUMULATIVE PRIMARY AND TOTAL ENERGY SUPPLIES (PERCENT)	9.53
CUMULATIVE BENEFICIAL ENERGY PROVIDED BY THE SYSTEM (J)	3.9040E+11
CUMULATIVE SYSTEM ENERGY CONVERSION EFFICIENCY (PERCENT)	9.98
ELECTRICITY REQUIRED TO RUN THE SYSTEM (W)	1.2505E+02
ELECTRICITY SUPPLIED TO THE SYSTEM (W)	1.2033E+02
ELECTRICITY PRODUCED AND USED BY THE SYSTEM (W)	4.7214E+00
ELECTRICITY PRODUCED AND AVAILABLE FOR EXTERNAL USE (W)	1.2500E+05
TOTAL ELECTRICITY PRODUCED BY THE SYSTEM (W)	1.2500E+05
CUMULATIVE ELECTRICITY REQUIRED TO RUN THE SYSTEM (J)	1.3696E+08
CUMULATIVE ELECTRICITY SUPPLIED TO THE SYSTEM (J)	1.3516E+08
CUMULATIVE ELECTRICITY PRODUCED AND USED BY THE SYSTEM (J)	1.8009E+06
CUMULATIVE ELEC PRODUCED AND AVAILABLE FOR EXTERNAL USE (J)	8.0730E+10
CUMULATIVE TOTAL ELECTRICITY PRODUCED BY THE SYSTEM (J)	8.0732E+10
MECHANICAL POWER REQUIRED TO RUN THE SYSTEM (W)	2.5008E+03
MECHANICAL POWER SUPPLIED TO THE SYSTEM (W)	0.
MECHANICAL POWER PRODUCED AND USED BY THE SYSTEM (W)	2.5008E+03
MECHANICAL POWER PRODUCED AND AVAILABLE FOR EXTERNAL USE (W)	0.
TOTAL MECHANICAL POWER PRODUCED BY THE SYSTEM (W)	2.5008E+03
CUMULATIVE MECHANICAL POWER REQUIRED TO RUN THE SYSTEM (J)	1.5167E+09
CUMULATIVE MECHANICAL POWER SUPPLIED TO THE SYSTEM (J)	0.
CUMULATIVE MECH POWER PRODUCED AND USED BY THE SYSTEM (J)	1.5167E+09
CUMULATIVE MECH PWR PRODUCED AND AVAILABLE FOR EXTERNAL USE (J)	0.
CUMULATIVE TOTAL MECHANICAL POWER PRODUCED BY THE SYSTEM (J)	1.5167E+09

Output: Example 2 (cont)

```

***** TABLE 1 OUTPUT *****
YEAR = 1975    DAY = 97    HOUR = 12    SEC = 0

COMPONENT OUTLET STATE FLOW RATE TEMPERATURE PRESSURE STATE QUALITY
NAME NUMBER (KG/S) (DEG K) (PA) (PERCENT)
FOCOL 1 .9163E+00 .6000E+03 .4000E+06 COMPRESSED LIQUID
PIPE 2 .9163E+00 .5977E+03 .4000E+06 COMPRESSED LIQUID
PUMP 30 .9163E+00 .5977E+03 .4000E+06 COMPRESSED LIQUID
MIXJNT 3 .9559E+01 .5998E+03 .3996E+06 COMPRESSED LIQUID
THMBLR 6 .9559E+01 .4128E+03 .3996E+06 COMPRESSED LIQUID
THMBLR 13 .1402E+01 .5898E+03 .1379E+07 SUPERHEATED VAPOR
PUMP 10 .9559E+01 .4128E+03 .4000E+06 COMPRESSED LIQUID
FLODIV 9 .9163E+00 .4128E+03 .4000E+06 COMPRESSED LIQUID
FLODIV 8 .8643E+01 .4128E+03 .4000E+06 COMPRESSED LIQUID
PIPE 11 .8643E+01 .4127E+03 .3996E+06 COMPRESSED LIQUID
AUXFUR 12 .8643E+01 .6000E+03 .3996E+06 COMPRESSED LIQUID
LODNG 14 .1402E+01 .5898E+03 .1379E+07 COMPRESSED LIQUID
XTURBG 16 .1000E+00 .5317E+03 .7042E+06 SUPERHEATED VAPOR
XTURBG 17 .1302E+01 .5317E+03 .7042E+06 SUPERHEATED VAPOR
PRSVAP 18 .7000E-01 .3500E+03 .1013E+06 COMPRESSED LIQUID
MKPFLD 19 .3000E-01 .2880E+03 .1000E+06 COMPRESSED LIQUID
MIXJNT 31 .1000E+00 .3314E+03 .1009E+06 COMPRESSED LIQUID
CONHT 20 .1093E+00 .3800E+03 .5515E+06 COMPRESSED LIQUID
XTURBG 25 .9317E-02 .5317E+03 .7042E+06 SUPERHEATED VAPOR
XTURBG 26 .1292E+01 .3100E+03 .6151E+04 LIQUID VAPOR MIXTURE 94.68
BFOPMP 21 .1093E+00 .3800E+03 .1379E+07 COMPRESSED LIQUID
CNDHTR 27 .1292E+01 .3050E+03 .6151E+04 COMPRESSED LIQUID
CNDHTR 28 .7683E+02 .3049E+03 .1000E+06 COMPRESSED LIQUID
MIXJNT 22 .1402E+01 .3109E+03 .1132E+06 COMPRESSED LIQUID
BFOPMP 23 .1402E+01 .3109E+03 .1379E+07 COMPRESSED LIQUID
COOLTOW 29 .7683E+02 .2950E+03 .1000E+06 COMPRESSED LIQUID

```

Output: Example 2 (cont)

***** TABLE 2 OUTPUT *****

YEAR = 1975 DAY = 97 HOUR = 12 SEC = 0

WEATHR		AMBIENT TEMPERATURE (K)	.2934E+03
WEATHR		PRESSURE (PASCALS)	.8377E+05
WEATHR		WIND SPEED (M/S)	.3600E+01
WEATHR		TOTAL HORIZONTAL SOLAR INTENSITY (W/M2)	.1021E+04
WEATHR		DIRECT NORMAL SOLAR INTENSITY (W/M2)	.8309E+03
WEATHR		SOLAR ELEVATION ANGLE (DEG)	.6130E+02
WEATHR		SOLAR AZIMUTH ANGLE (DEG)	.8366E-05
FOCOL	1	ENERGY RATE AVAILABLE FROM SUN -PRISUP (W)	.8986E+06
FOCOL	1	THERMAL LOSS -THMLOS (W)	.4998E+06
FOCOL	1	ENERGY TRANSFER RATE TO FLUID (W)	.3988E+06
PIPE	2	PIPE HEAT LOSS	.5757E+04
PUMP	30	POWER-PUMP POWER (WATTS)	.1191E-01
THMBLR	13	THERMAL BOILER OUTLET STATE SUPERHEAT (DEG K)	.1231E+03
THMBLR	13	THERMAL BOILER VAPORIZATION TEMPERATURE (DEG K)	.4667E+03
THMBLR	13	THERMAL SUPERHEATER HEAT RATE (W)	.3689E+06
THMBLR	13	THERMAL VAPORIZOR HEAT RATE (W)	.2699E+07
THMBLR	13	THERMAL PREHEATER HEAT RATE (W)	.1087E+07
THMBLR	13	THERMAL BOILER HEAT RATE (W)	.4155E+07
THMBLR	13	THERMAL BOILER EFFECTIVENESS (PERCENT)	.9929E+02
PUMP	10	POWER-PUMP POWER (WATTS)	.4709E+01
PIPE	11	PIPE HEAT LOSS	.2250E+04
AUXFUR	12	AUXILIARY FURNACE HEAT RATE (W)	.3764E+07
AUXFUR	12	AUXILIARY FURNACE-ENERGY SUPPLIED BY FUEL (W)	.5377E+07
LODMG	14	ELECTRICAL LOAD MET BY LOOP (W)	.1250E+06
LODMG	14	TOTAL ELECT POWER DEMANDS MET BY LOOP (W)	0.
LODMG	14	TOTAL ELECT PARISITICS MET BY LOOP (W)	.4721E+01
LODMG	14	TOTAL ELECT POWER PRODUCED BY LOOP (W)	.1250E+06
LODMG	14	MECHANICAL LOAD MET BY LOOP (W)	0.
LODMG	14	TOTAL MECH. POWER DEMANDS MET BY LOOP (W)	0.
LODMG	14	TOTAL MECH. PARISITICS MET BY LOOP (W)	.2501E+04
LODMG	14	TOTAL MECHANICAL POWER PRODUCED BY LOOP (W)	.2501E+04
LODMG	14	TOTAL POWER PRODUCED BY LOOP (W)	.1275E+06
XTURBG	15	EXTRACTION TURBINE ELECTRICAL POWER (W)	.1241E+06
XTURBG	15	EXTRACTION TURBINE MECHANICAL POWER (W)	0.
PRSVAP	18	PROCESS VAPOR RATE (W)	.2758E+06
PRSVAP	18	WORKING FLUID LOSSES (KG/S)	.3000E-01
MKPFLD	19	MAKE UP FLUID MASS FLOW RATE (KG/S)	.3000E-01
DCONHT	20	HEAT RATE (W)	.2353E+05
XTURBG	24	EXTRACTION TURBINE ELECTRICAL POWER (W)	.9537E+03
XTURBG	24	EXTRACTION TURBINE MECHANICAL POWER (W)	.2501E+04
BFDPPM	21	VOLUMETRIC FLOW RATE (M3/S)	.1174E-03
BFDPPM	21	PUMP ELECTRICAL POWER (W)	.1203E+03
CNDHTR	27	CONDENSER INLET STATE SUPERHEAT (DEG K)	.1200E+00
CNDHTR	27	CONDENSER SATURATION TEMPERATURE (DEG K)	.3099E+03
CNDHTR	27	CONDENSER VAPOR HEAT RATE (W)	.2909E+03
CNDHTR	27	CONDENSER LATENT HEAT RATE (W)	.3156E+07
CNDHTR	27	CONDENSER LIQUID HEAT RATE (W)	.2899E+05
CNDHTR	27	CONDENSER HEAT RATE (W)	.3185E+07

Output: Example 2 (cont)

```
***** TABLE 2 OUTPUT *****
YEAR = 1975    DAY = 97    HOUR = 12    SEC = 0

CNDHTR      27    CONDENSER EFFECTIVENESS (PERCENT)      .9818E+02
BFDPMP      23    VOLUMETRIC FLOW RATE (M3/S)            .1423E-02
BFDPMP      23    PUMP MECHANICAL POWER (W)              .2501E+04
COOLTOW     29    ENERGY EXTRACTED BY COOLING TOWER (W)  .3185E+07
COOLTOW     29    INTEGRATED ENERGY EXTRACTED BY COOLING TOWER (J) .1937E+13
EXECUTIVE                                2
```

DISTRIBUTION:

TID-4500-R66 UC-32 (189)

US Department of Energy (2)
Small Power Systems Branch
Office of Energy Technology
600 E Street
Washington, DC 20545
Attn: J. E. Rannels
M. E. Resner

US Department of Energy
Agricultural and Industrial Process Heat Branch
Office of Conservation and Solar Applications
600 E Street
Washington, DC 20545
Attn: J. F. Dollard

US Department of Energy
Research and Development Branch
Office of Conservation and Solar Applications
600 E Street
Washington, DC 20545
Attn: F. H. Morse

4231 F. Biggs
4700 J. H. Scott
4710 G. E. Brandvold
4710A J. V. Otts
4713 B. W. Marshall
4714 R. P. Stromberg
4715 R. H. Braasch
4716 H. M. Dodd
4716 M. W. Edenburn
4719 E. R. Schueler
4720 V. L. Dugan
4721 J. A. Leonard
4722 J. F. Banas
4722 N. R. Grandjean (200)
4723 W. P. Schimmel
4730 H. M. Stoller
4735 S. G. Varnado
4736 A. F. Veneruso
5162 L. D. Bertholf
5500 O. E. Jones
5511 D. F. McVey
5512 J. C. Dunn
5512 M. E. Fewell
5512 H. C. Hardee
8450 R. C. Wayne
8451 W. G. Wilson
8452 A. C. Skinrood
8266 E. A. Aas
3141 T. L. Werner (5)
3151 W. L. Garner (3)
For: DOE/TIC (Unlimited Release)