**Erosion of Heat Exchanger Tubes
in Fluidized Beds**

**1990
Annual Report**

**Eric K. Johnson
Rory L.C. Flemmer**

January 1991

Work Performed Under Contract No.: DE-FC21-87MC24207

**For
U.S. Department of Energy
Office of Fossil Energy
Morgantown Energy Technology Center
Morgantown, West Virginia**

**By
West Virginia University
Department of Mechanical and Aerospace Engineering
Morgantown, West Virginia**

MASTER

EP

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831; prices available from (615)576-8401, FTS 626-8401.

Available to the public from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

**Erosion of Heat Exchanger Tubes
in Fluidized Beds**

**1990
Annual Report**

**Eric K. Johnson
Rory L.C. Flemmer**

Work Performed Under Contract No.: DE-FC21-87MC24207

**For
U.S. Department of Energy
Office of Fossil Energy
Morgantown Energy Technology Center
P.O. Box 880
Morgantown, West Virginia 26507-0880**

**By
West Virginia University
Department of Mechanical and Aerospace Engineering
Morgantown, West Virginia 26506**

January 1991

ABSTRACT

This final report describes the activities of the 3-year project entitled "Erosion of Heat Exchanger Tubes in Fluidized Beds", which was completed at the end of 1990. Project accomplishments include the collection of a substantial body of wear data in a 24" x 24" fluidized bed, comparative wear results in a 6" x 6" fluidized bed, the development of a dragometer and the collection of a comprehensive set of drag force data in the 24" x 24" bed, Fast Fourier Transform (FFT) analysis of bubble probe data to establish dominant bubble frequencies in the 24" x 24" bed, the use of a heat flux gauge for measurement of heat transfer coefficients in the 24" x 24" bed and the modeling of the tube wear in the 24" x 24" bed.

Analysis of the wear data from the 24" square bed indicates that tube wear increases with increase in superficial velocity, and with increase in tube height. The latter effect is a result of the tubes higher up in the bed seeing greater movement of dense phase than tubes lower down in the bed. In addition, tube wear was found to decrease with increase in particle size, for constant superficial velocity.

Three models of tube wear were formulated and provided acceptable prediction of wear when compared with the experimental data.

List of Symbols

A	area
Ar	Arhenius number
BH	bed height
c	velocity of thermal disturbance
Cp	specific heat capacity
d	diameter
D	distance
E	erosion rate
f	fractional contace time
Fo	Fourier number
g	acceleration due to gravity
G	mass flowrate
h	heat transfer coefficient
H	height
K	thermal conductivity
L	length
Nu	Nusselt number
Pr	Prandtl number
q	heat flux
Re	Reynolds number
t	time
T	temperature
TH	tube height
U	velocity
UA	absolute rise velocity of a collection of bubbles
UB	rise velocity of a single bubble
V	velocity
W	wear rate
WPI	wear profile indicator parameter
Z	height above the distributor plate

Greek

α	thermal diffusivity
δ	film thickness
ϵ	voidage
ρ	density
τ	residence time
μ	viscosity
θ	residence time

List of Symbols (continued)Subscript

av	average
dp	distributor plate
D	dense phase
eff	effective
fs	free surface
g	gas
i	instantaneous
L	lean phase
max	maximum
min	minimum
mf	minimum fluidization
p	particle
s	solid
w	wall
O	superficial

TABLE OF CONTENTS

	PAGE
ABSTRACT	11
1. INTRODUCTION	1
1.1 PROJECT HISTORY	1
1.2 PROJECT RELEVANCE	1
1.3 TECHNICAL APPROACH	1
2. ACCOMPLISHMENTS	2
2.1 WEAR DATA	2
2.2 COMPARATIVE WEAR STUDIES	2
2.3 MODIFICATION OF THE DRAGOMETER	3
2.4 HEAT FLUX GAUGE	3
2.5 PRELIMINARY ANALYSIS OF WEAR DATA	3
2.6 MODELING TUBE WEAR	3
2.7 LITERATURE REVIEW	3
2.8 COMPLETION OF HIGHER DEGREES	3
3. LITERATURE REVIEW	3
3.1 INTRODUCTION	3
3.2 EROSION IN FLUIDIZED BEDS	3
3.3 HEAT TRANSFER IN FLUIDIZED BEDS	12
4. TECHNICAL APPROACH	44
4.1 APPROACH MODIFICATIONS	44
5. EXPERIMENTAL FACILITIES	51
5.1 THE 2' X 2' FLUIDIZED BED	51
5.2 THE 6" X 6" FLUIDIZED BED	56
5.3 THE DRAGOMETER	56
5.4 THE HEAT FLUX GAUGE	58
6. RESULTS AND DISCUSSION - PHASE I	68
TUBE WEAR IN A 2' X 2' FLUIDIZED BED	
7. RESULTS AND DISCUSSION - PHASE II	76
COMPARATIVE WEAR TESTS	
8. RESULTS AND DISCUSSION - PHASE III	78
THE DRAGOMETER	
9. RESULTS AND DISCUSSION - PHASE IV	82
HEAT FLUX GAUGE AND BUBBLE PROBE MEASUREMENTS	
10. MODELING TUBE WEAR	98
10.1 INTRODUCTION	98
10.2 ORIGINAL MODEL	98
10.3 NEW MODEL	103
10.4 A NEW MODEL FOR ROW 1 ONLY	111
10.5 DISCUSSION	115
11. CONCLUSION	117
REFERENCES AND BIBLIOGRAPHY	119
APPENDIX A	124

LIST OF FIGURES

	PAGE
3-1 Main features of the thin film model	13
3-2 Thin film and emulsion model	13
3-3 The finite difference grid employed for the solution of 2D unsteady heat conduction model of Botterill et al [34]	16
3-4 The packet renewal model	16
3-5 Baskakov's results compared to the measurements of Antonishin et al	20
3-6 Model of heat transfer between a horizontal tube and a fluidized bed	27
5-1 Fluidized bed - front view	59
5-2 Tube bundle geometry	60
5-3 Distributor plate	60
5-4 Test facility	61
5-5 Test facility instrumentation	62
5-6 Control problem logic	63
5-7 WVU 6" x 6" fluidized bed	64
5-8 Schematic diagram of dragometer circuit and dragometer mounted in-line on the tube	65
5-9 Dragometer central shaft	66
5-10 The heat flux gauge	67

LIST OF TABLES

3-1 Basic erosion related research summary	10
3-2 A summary of previous studies dealing with heat transfer to horizontal tubes immersed in fluidized beds	38
4-1 Test matrix - Phase I	47
4-2 Particle characteristics - Phase I	49
4-3 Test matrix - Phase II	49
4-4 Particle characteristics - Phase II	49
4-5 Test matrix - Phase III	50
4-6 Test matrix - Phase IV	50
6-1 Results - Phase I	69
7-1 Comparative wear test results	76
8-1 Dragometer data file specifications	79
9-1 Heat flux gauge test conditions	82

1. INTRODUCTION

1.1 Project History

The project was initiated in January of 1988. Its aim at that time was to gather experimental data on tube wear in fluidized beds in order to enable similarity laws for wear to be established. The first year of the project was concerned with building and debugging the experimental test facility. This was a 2 foot square fluidized bed with the walls such that varying tube bundle geometries could be inserted and measured for wear. The facility was set up to run under computer control and automatically to set bed temperature, maintain superficial flow velocity and control the residence time of the inventory.

When tests were done on aluminum specimens using 850 micron particles, whose size was chosen to maintain a one third ratio with the particles in the METC 6 foot bed, wear was found to be minimal. Considerable effort was expended in the attempt to increase the wear rate and to refine measurement techniques, and it was only in Fall 1989 that acceptable rates were achieved. Experimental work being reported in the literature over this period confirmed our results.

With a deeper bed, larger and sharper particles and using acrylic tube segments, an extensive body of wear data was obtained in the final year of the project. The data is presented and analyzed in this report.

1.2 Project Relevance

The problem of erosion in fluidized beds has become a major concern of power plant engineers and those involved in purchasing new boilers. The unpredictable nature of erosion in fluidized bed combustors (FBC's) has dampened the enthusiasm and acceptance of FBC boilers. However, several FBC boilers have not encountered any significant erosion, so erosion does not appear to be a necessary evil in FBC boiler performance. Thus research may lead to a design approach which may significantly mitigate the erosion problem. In order to accomplish this goal within a reasonable amount of time and money, it is appropriate that an approach be developed so that relatively inexpensive short-term research into erosion may be accomplished in small scale FBC units.

1.3 Technical Approach

The technical approach has been altered significantly since the start of the project in January 1988. The 1989 annual report discusses the development of the approach into 4 areas of effort, namely:

- (1) **Phase I** - capturing data on the wear of tubes in a 2' x 2' bed which has some relation to an industrial application. The bed has a tube bundle consisting of 21 tubes which can be set at different heights. In addition, the bed depth, superficial velocity and particle size can be varied.
- (2) **Phase II** - comparison between wear rates for different materials: A 6 inch square bed has been constructed and is used for simultaneous wear tests with tubes of different materials. The fluidization regime

around the four specimens being simultaneously eroded is such that differences in wear rates can be ascribed to the material properties.

- (3) **Phase III** - development and use of the Dragometer - a device to measure drag on the tubes concurrently with the wear measurements. A prototype has been developed and modified for continuous operation. The device is used to collect data on the drag suffered by the tubes in the bed. In addition, a bubble probe is used to measure pressure fluctuations in the bed and a fast Fourier transform (FFT) technique is used to establish the dominant bubble frequencies in the fluidized bed.
- (4) **Phase IV** - development and calibration of a Heat Flux Gauge. This device enables heat transfer coefficients to be evaluated concurrently with wear and drag measurements in the bed.

These 4 areas of work are discussed separately in the main body of the report.

2. ACCOMPLISHMENTS

The accomplishments of the project are:

2.1 Wear Data

Forty-five sets of wear data were collected. Each data set consists of wear data on 48 test segments which span variation with height and planform x-y coordinates within the tube bundle (i.e. 2160 mass loss data points were obtained). In addition, measurements were taken to determine the total decrease in wall thickness of the specimens at intervals of 30 degrees around the periphery of each segment. The test segments are 2 inches in length and have a diameter of 5/8". They are formed from PMMA (acrylic). As might be expected, the weight data is considerably more precise than the thickness data. The raw data is presented in Appendix A and the results, with some discussion, are presented in Section 6 of the report.

2.2 Comparative Wear Studies

A 6" x 6" Plexiglas bed was built and debugged and is shown in Figure 5-7. It offers control of a uniform slugging environment in which 4 tubes, 5/8" in diameter, but of different materials can experience the same wear environment .

A set of 11 runs was completed in which steel, aluminum, PVC and acrylic specimens were subjected to wear by particles (of quartz, limestone and a limestone-bottom ash mixture) of different sizes for a range of bed depths. In order to standardize the wear conditions, all tests were conducted with the bed slugging with a frequency of one cycle per second. The results are presented in Section 7 of the report.

2.3 Modification of the Dragometer

The initial laboratory prototype dragometer was rebuilt along the lines of an industrial instrument. It was modified to include pressure tappings so that the effects of fluid pressure could be separated from the effects of particle drag. The device is capable of monitoring pressures and forces at the rate of 100 Hz, displaying the data interactively and storing it on disc. The dragometer results are given in Section 8, together with measurements of pressure fluctuations in the bed and FFT analysis of bubble probe data to establish dominant bubble frequencies in the bed.

2.4 Heat Flux Gauge

A heat flux gauge was used to measure the heat transfer and local pressure gradient in the bed at 50 Hz. The results are given in Section 9.

2.5 Preliminary Analysis of Wear Data

The wear data has been analyzed to show the major trends occurring in the fluidized bed.

2.6 Modeling Tube Wear

Three models were developed to predict the wear suffered by tubes in the 2' x 2' fluidized bed. The models are assessed in terms of their ability to reflect the experimental wear data.

2.7 Literature Review

An analysis of erosion and heat transfer literature has been made in order to gain insight into the processes of tube erosion and heat transfer in FBC's.

2.8 Completion of Higher Degrees

Mr. W. Barnes successfully defended his M.S. thesis entitled "Development of a force sensing device for a bubbling fluidized bed". Ms. C. Merrow successfully defended her M.S. thesis entitled "The development of a test facility for the erosion study of the heat exchanger tubes in a fluidized bed". Both students were actively engaged in the project. Mr. D. Nichols is on the point of completing his M.S. degree, also on work supported by this project.

3. LITERATURE REVIEW

3.1 Introduction

Two major areas of interest in this project are the tube wear in FBC's and the heat transfer in FBC's. The literature review will treat the two areas separately.

3.2 Erosion in Fluidized Beds

In May 1989, two major conferences on fluidization were held [1,2]. The subject of erosion of in-bed tubes and of similarity analysis (scaling)

played a significant role. Papers on erosion which were presented at these meetings not only supported the initial results obtained in this study, but also provided insight into future courses of action.

3.2.1 General Comments

J. Stringer, et al [3] presented a review of the recent information on metal wastage in bubbling fluidized-bed combustors. This review was divided into three categories; namely, 1) industrial, 2) atmospheric utility, and 3) pressurized utility boilers. The basic differences between the categories are the bed height and the tube temperature. As for bed heights, industrial boilers are shallow with bed heights less than one meter, atmospheric utility boilers have bed heights of about 1.2 meters, and pressurized utility boilers usually have bed heights greater than three meters. These categories will be useful in analyzing the published results generated by the various investigators. Although the available results do not form a complete or consistent description of in-bed erosion (author's statement) the following conclusions (relative to the present project) have been developed:

- a) metal wastage is due to impact erosion and abrasion; the dominant mechanism is still unknown.
- b) the fluidization regime (velocity) and particle size are important.
- c) the metal temperature appears to be important.
- d) the importance of large particles has been reasonably well established.

An emerging concept from this review (the authors) is that erosion rates may change rapidly with a small change in one or more operating parameters.

The impact erosion phenomena appears to be the most popular mechanism for erosion of in-bed tubes. The bed material in the wake of bubble is accelerated to a relatively high velocity. These bed particles may be further accelerated as the bubbles coalesce in the bed. These relatively high velocity particles then strike the lower surface of a tube, thus causing erosion. However, there appears to be an increasing number of statements supporting abrasion as a mechanism to be considered.

A recent study of impact erosion, both in reviewing the theories and in the production of new experimental data, may be found in [4]. This data suggests that a threshold velocity may exist, below which no erosion occurs. Unfortunately, the data is for relatively high velocities and a linear extrapolation over the void in data may be inappropriate. Other recent studies in which attempts were made to simulate erosion in fluidized beds [5,6] have indicated a threshold velocity and/or an incubation period. Some incubation periods have been reported to be from 2 to 60 hours, before steady state erosion rates were established. Apparently PVC does not have an incubation period. The incubation period may not be significant for a boiler campaign, but it may cause significant erroneous results in relatively short time experimental studies.

3.2.2 Specific Results

(1) The Effect of Bed Material on Erosion

The significance of particle size on erosion rates has been demonstrated by Parkinson and by Glicksman [7]. One cannot investigate only the particle diameter effect on erosion in fluidized systems, keeping all other variables constant. The particle diameter significance is intertwined with the flow regime. The minimum fluidization velocity is a function of the particle diameter. Consequently Parkinson has attempted to correlate erosion data in terms of the particle diameter and the excess fluidizing velocity, $U_0 - U_{mf}$. In a recent paper [8] by J. Holmes, et al (including Parkinson), erosion data was presented for a deep bed in terms of particle diameter and excess fluidizing velocity. This data shows that the erosion rate parameter begins to be size dependent for Geldart D particles.

Also, recently, J. Zhu [9] et al., presented the results of a basic study on erosion-causing particle impacts on tubes in a two-dimensional fluidized bed. Zhu's observations of impacting velocities, and the associated number of particles within each velocity range, has led to a good agreement between measured erosion rate(s) and those predicted from an erosion formula developed as part of his dissertation. That formula implies that the erosion rate is proportional to particle diameter to the 1.5 power. The authors do not give any bounds for this empirical fact.

The shape of an eroding particle has been considered to play a role in erosion. In fluidization, there are two aspects to this concern. First, do the bed particles retain their sharp edges for a significant fraction of the residence time in a fluidized bed? Secondly, do particles that quickly lose their sharp edges, regain or produce new sharp edges during attrition? The very limited information the author has encountered on this subject indicates that the bed particles are abraded, producing rounded particles and fine powder. The erosion study of Ninham, et al [5] indicated significantly more erosion with fresh bed material than with "conditioned" material. However, Ninham's results are for a fluidization-simulation erosion-testing device, and not from an actual fluidization system.

(2) The Effect of Fluidization Velocity on Erosion

The fluidization velocity has always been considered a major factor in the erosion rate for in-bed tubes. The graphical presentations of Holmes, Parkinson, and others has employed the excess fluidization velocity as the velocity parameter. The fluidization velocity also dictates the fluidization regime. The erosion rate for a given particle increases with velocity in the bubbling regime, reaches a maximum in the slugging regime, and then decreases in the turbulent regime [7].

In their study to develop erosion-resistant in-bed tubes (including tube bundle design), Tsutsumi, et al [10] made measurements of the particle impact velocities on tubes and the effect of fluidization velocity on erosion rates. Their results are:

- a) maximum wear rate [$\mu\text{m}/50\text{ hr}$]

$$W_{\text{max}} = 242 U_o^{0.88} \quad (3-1)$$

- b) maximum particle speed impinging at 6 o'clock

$$U_p = 1.99 U_o^{0.89} \quad (3-2)$$

- c) maximum particle speed impinging at 7:30 o'clock

$$U_p = 3.24 U_o^{0.73} \quad (3-3)$$

for $1.5 < U_o < 3.5\text{ m/sec}$, $\langle d_p \rangle = 0.8\text{ mm}$ sand, and acrylic (PMMA) tubes.

Rathbone, et al [11] developed an instrument to measure particle velocities and associated stresses on immersed surfaces in fluidized beds. They evaluated their instrument in a two-dimensional bed. Although this paper is apparently a progress report, information is provided for the normal particle velocities striking the surface of a tube. It appears that the normal particle velocities are about one-half of the fluidizing velocities (0.64 and 0.79 m/sec).

A paper dealing with the bubble coalescence mechanism of tube erosion was presented by Levy and Bayat [12]. They measured the imposed bubble flow along a transparent wall in a three dimensional bed. The interaction of 1) single bubbles and 2) coalescing bubbles on tubes was noted. The tubes were a series of PVC segments which were used to measure erosion rates. The bubbles were injected into the bed operating at near the minimum fluidization velocity. An equation of the form

$$\frac{dE}{dt} = a U_w^n \quad (3-4)$$

was developed from the data. The quantity dE/dt is the erosion rate per bubble and U_w is the velocity of the particles in the bubble wake.

(3) The Effect of Tube Material on Erosion

Several materials have been employed in tubes with the goal of increasing erosion rates in experimental systems. These experimental studies are concerned more with establishing an erosion mechanism than evaluating the erosion resistance of various materials. In order to investigate the apparently large number of variables involved with erosion, the time required to obtain measureable wear must be minimized. After the bed design and bed operations have been selected for minimum erosion, the most erosion resistant steels may be selected as the tube material for minimum erosion. The experimental fluidization-erosion studies have employed materials such as PVC, PMMA (acrylic), and aluminum. However, basic erosion studies have also been conducted which employed the actual candidate steels at their expected operation temperature. This review will consider both aspects of the problems.

Aluminum, PVC, and PMMA appear to have the same tube wastage rate (mass loss rate) for the same fluidization conditions [6]. However, there have been several comments (verbal) about the difference in the erosion mechanism(s) between plastics and metals. The obvious difference between plastics and metals is that metals have a well ordered molecular structure and exhibit different erosion patterns from plastics [13]. MacAdam, et al [6] have developed a wear profile indicator parameter, WPI, defined as:

$$WPI = \frac{2W_{180^\circ}}{W_{m1} + W_{m2}} \quad (3-5)$$

where W_{180} is the tube wear at 180° (6 o'clock)

W_{m1} is the max tube wear for $\theta < 180^\circ$

and W_{m2} is the max tube wear for $\theta > 180^\circ$

For Class A tube wear [6], the value for the WPI is essentially zero and for Class B tube wear, the value for WPI is essentially one. It should be noted that W_{m1} and W_{m2} represent the symmetry of the erosion process.

Aluminum corresponds to $WPI \approx 1$ and plastic corresponds to $WPI \approx 0$.

There have been three interesting erosion reports relating to erosion rates for materials [4,5,6]. The reports by MacAdam, et al [6] and Ninham, et al [5] discuss the experimental fact that an incubation period exists for metals before a steady state erosion rate is established. However [6], PVC does not exhibit an incubation period and immediately attains a steady state erosion rate. Ninham, et al [5] reports results for steels which also indicate a threshold velocity is required before erosion begins. If one looks for a curve in the erosion data in [4], one may readily conclude that the possibility of a threshold velocity also exists in their results.

3.2.3 Novel Testing Devices

Two interesting erosion testing devices have recently produced results as described in this topical report. The device developed by MacAdam, et al [6] consists of oscillating a horizontal tube (specimen) in a fluidized bed. The fluidizing velocity is the U_{mf} and the bed particles were 800 μm quartz. Although this device represents only a simulation of the erosion process(es) in a fluidized bed, the results from this study are of interest. Of major concern is the fact that the tests with plastic specimens were 132 to 141 hours in duration. Also, the aluminum tests were from 243 to 492 hours in duration. Also of concern is the fact the aluminum exhibits an incubation period before steady state erosion rates occur.

The second interesting erosion device has been developed by Ninham, et al [5]. This device consists of rods being rotated in a fluidized bed. The interesting concept involved in this device is that each element of the rotating rod has a different relative velocity with respect to the

fluidized particles. The particles were alumina sand, 130 and 240 μm , fluidized at $1.2 U_{mf}$. The test periods were 100 hours. Again, this device represents a simulation of the erosion process within a bed. The results of concern are the threshold velocity for erosion and the incubation period.

3.2.4 Scaling

(1) General Comments

To date, there appear to be three approaches to scaling, or similarity, analysis. These three are:

- a) to investigate a fluidization process by investigating a relatively narrow vertical slice of the full-scale bed.
- b) similarity in particle dynamics.
- c) similarity in bubble dynamics.

The similarity in particle dynamics leads to a set of parameters referred to as the Fitzgerald-Glicksman relationships. The similarity in bubble dynamics is associated with Horio and his colleagues [1].

Although the narrow vertical slice approach to scaling has its problems (chance of slugging, etc.), it is the desirable approach in heat transfer [14] and erosion [8] studies. Approaches 2) and 3) lead to problems in scaling between fluidization systems involving different Geldart particle classifications. Erosion rates depend on fluidization velocity, particle size, etc. As the erosion process has not been well established, one must essentially use the full-scale conditions to determine actual erosion rates. The ability to scale erosion patterns within a fluidized bed remains a problem that has not drawn much attention.

(2) Specific Results

(a) PFBC Scaling

Recently, A. Almstedt, et al [15] presented a study on the validity of the Fitzgerald-Glicksman scaling parameters when applied to the full-scale PFBC at New York University and a scaled model at the Chalmers University of Technology [CUT]. Although the PFBC employed Geldart D particles and the CUT model employed Geldart B particles, the nondimensional bubble parameters were essentially in agreement. Attempts to employ the same size bed material produced less agreement in similarity between the beds.

(b) Scaling of Pressure Fluctuations

A paper by R. Roy and J. F. Davidson [16] appears to describe a rather thorough study of similarity of fluidized beds by considering the magnitude and frequency of pressure fluctuations in several beds. The conclusions are that the complete set of Fitzgerald-Glicksman parameters are required for similarity of PFBC-AFBC units and Horio's parameters are satisfactory for AFBC units. Unfortunately, this paper is so lacking in details that the questions arising from the scatter of data in their graphs cannot be answered. Thus this paper does not really do justice to the subject and to

the authors apparent research effort.

(c) Scaling of Injection Jets

Blake [17] reported, in abstract form, on his work to describe the penetration of jets into fluidized beds. The dimensionless parameters that describe the experimental results include a new parameter.

$$\frac{\rho_p U_o d_p^2}{\mu d} \quad (3-6)$$

which is the particle Reynolds number multiplied by the length ratio particle diameter to vessel diameter. This approach will be considered in greater detail in a later quarterly report when Blake's work is published in detail.

3.2.5 Summary of Erosion Literature

Table 3-1 summarises the recent research into the erosion of fluidized beds. In addition, the MSE theses of W. Barnes [18] and C Merrow [19] relate directly to the work performed in this investigation.

TABLE 3-1
BASIC EROSION RELATED RESEARCH SUMMARY

Investigators	Fluidization Velocity	Bed Material	Particle Diameter	Bed Depth	Test Period	Wear Rate	Tube Materials
—	m/sec	—	μm	m	hr	[gr/100hr]	—
A. Ninham * et al (5)	0.024	Brown Alumina Sand	130 and 240	—	100	—	ABS (plastic) Fe - Cr steels
S. MacAdam * et al (6)	0.25 to 1.25	Preconditioned Quartz	800	.457	140	0.009(plstc) 0.002 (Al) [0.6 gr/ 100hr] Al	PVC, PMMA, AL
E. Levy (12) et al	Bubble imposed on on u_{mf}	Sand	0.32 and 0.8	—	30	0.0013 max	PVC
R. Rathbone + et al (11)	0.64, 0.79 and 0.96	Sand	600 - 850	2D	—	—	—
J. Drennen + et al (20)	0.85	Sand	850 x 1190	1.3	100	0.024	PMMA

Notes

- * Erosion study in simulated fluidized bed
- + Erosion related particle velocity study

TABLE 3-1 (continued)
BASIC EROSION RELATED RESEARCH SUMMARY

Investigators	Fluidization Velocity	Bed Material	Particle Diameter	Bed Depth	Test Period	Wear Rate	Tube Materials
—	m/sec	—	μm	m	hr	in/50hr [gr/100hr]	—
W.F. Podolski (21)	1.22 - 1.83	Sand	1500	0.41	400 hours requested	—	Al, steel and PVC tube material
K. Tsutsumi (10) et al	1.5 - 3.5	Sand	800		50	0.008 max 0.0024 avg	PMMA (acrylic) tube
J. Holmes (8) et al	?	Sand	250 to 1200	2.7	?	No direct numbers	PVC
T. Hanada (22) et al	1.5	Coal Limestone	?	1.00	1400	0.0008 max 0.0004 avg	Austenitic and Stainless steel
J. Zhu (9) et al	1.87	Sand	1000	.680	?	0.00025 avg	Brass rings
R. Dennis (23) (Fluidization VI)	1.83 and 2.13 2.13	Gravel	6300 x 0 (2100)	.762 .914	150	0.0012 avg 0.013 max	PVC
R. Dennis (24) (METC/Argonne Test)	2.13	Gravel	3300		150	[1.20] [0.65]	Aluminum 6061 PVC
Glicksman (25) et al	1.37	Steel Grit	980 and 1100	.18	19 and 11.5	[0.274] Lowest row	Copper Tubes Plated with Silver and Copper

3.3 Heat Transfer In Fluidized Beds

3.3.1 Introduction

Fluidized bed systems have the potential for attractively high combustion efficiency. Consequently, one of the most important aspects of fluidized beds is the mechanism of heat transfer. In the first section of this review 4 broad classes of heat transfer models are discussed. This is followed by a review of the available expressions for evaluating the overall heat transfer coefficients in fluidized beds.

There is an increasing interest in the heat transfer between large particles and immersed surfaces in fluidized bed systems due to their advantages in the power generation industry. Studies which are pertinent to this area are reviewed in Section 3.3.4 of the review. A summary of the studies dealing with heat transfer to horizontal tubes immersed in fluidized beds is tabulated at the end of the review.

3.3.2 Heat Transfer Models

There are three main modes of heat transfer in fluidized bed systems: the transfer of heat between the particles and the fluidizing gas, the heat transfer from the bulk of the bed to the immersed surfaces (tubes, probes, walls, etc.), and the interparticle transfer. The interparticle transfer is of least interest to the investigators for the time being.

For large particles ($> 1000 \mu\text{m}$) convective heat transfer is the dominant mode of heat transfer from particles to fluidizing gas. However, for smaller particles the process of heat transfer is quite fast and the gas and solid phases are assumed to be in thermal equilibrium.

Several theoretical models have been proposed to explain the heat transfer process in fluidized bed systems. Most of these models have been used with the particle convective component. The particle convective component of heat transfer dominates and it is more significant for particles less than $400 \mu\text{m}$ in size ($\bar{d}_p$).

(1) Models Based on the Film Theory

Among the first workers to suggest a model or mechanism for heat transfer between a fluidized bed and a surface were Dow and Jakob [26], Reboux [27], Richardson and Witson [28], and Leva [29]. They used conductive heat transfer through a thin laminar gas layer between the fluidized solids and a surface. They defined the heat transfer coefficient, h , by

$$h = \beta_1 \frac{K_g}{\delta} \quad (3-7)$$

where β_1 is a constant, K_g is the thermal conductivity of the gas film and δ is the gas film thickness. The gas film thickness (δ) depends not only on the velocity and the properties of the fluid, but also on the motion intensity of particles near the surface. Increased particle motion causes a reduction in the effective film thickness and a resulting increase in

Figure 3-1 Main features of the thin film model

Figure 3-2 Thin film and emulsion model

heat transfer.

This model did not take into account the thermophysical properties of the solid material (such as specific heat). Moreover the thickness of the gas film (δ) could not be predicted from first principles.

Levenspiel and Walton [30] and Ruckenstein [31], adopted the same method and definition of heat transfer coefficient but used a somewhat different approach. Their approach was based on the formation of a laminar boundary layer beyond the moving particles. They proposed two expressions for gas boundary layers. One involved turbulent flow conditions and the other streamline flow conditions. Features of this model are shown in Figure 3-1.

The best of these proposed models based on the Film Theory diverge by a factor of more than four from the experimental results.

(2) Steady State Conduction Through Gas Film and Emulsion Resistances

This group trend of heat transfer models is based on the postulate that the moving solid material plays a dominant part in the heat transfer process in fluidized bed systems. Van Heerden, et al., [32] proposed a model to account for the thermal resistance of the thin gas film at the immersed surface as well as the emulsion layer of particles with the influence of solids thermophysical properties (such as heat capacity of solids).

The above model has been extended by Wicke and Fetting [33] to take into account the heat transfer from the bed to a small immersed object of length L_h , as shown in Figure 3-2. This mechanism simply assumes that heat, q , passes by conduction from the immersed surface through a layer of gas with a thickness δ . They assumed that the heat exchange process between the surface and flowing particle moving parallel to the surface will take place in a zone of thickness L_e . Part of this heat, q_h , is transferred into the bulk of the fluidized bed by interchange of solids, while q_p goes into the sensible heat of the particle.

(3) Unsteady State Conduction by Single Particles in Direct Contact With the Surface

Botterill and Williams [34] proposed a model for a single particle. They considered a row of particles perpendicular to the surface since the transfer of heat from a surface into the bed takes place in a direction which is normal to the surface. They assumed that for short contact times unsteady state conductive heat transfer is the only mode of heat transfer to a single spherical particle.

The governing equations for two-dimensional and unsteady heat conduction between a surface at one temperature and a spherical particle immersed in a gas at different temperature which touches the surface at time zero, are:

(a) Inside the solid phase:

$$\frac{1}{\alpha_1} \frac{\partial T_1}{\partial t} = \frac{\partial^2 T_1}{\partial x^2} + \frac{\partial^2 T_1}{\partial y^2} + \frac{1}{y} \frac{\partial T_1}{\partial y} \quad (3-8)$$

where $y = 0$, and

$$\frac{1}{\alpha_1} \frac{\partial T_1}{\partial t} = \frac{\partial^2 T_1}{\partial x^2} + 2 \frac{\partial^2 T_1}{\partial y^2} \quad (3-9)$$

where $y = 0$. The subscript 1 refers to the solid, α , T and t are thermal diffusivity, temperature and time, respectively.

(b) In the fluid phase:

$$\frac{1}{\alpha} \frac{\partial T_2}{\partial t} = \frac{\partial^2 T_2}{\partial x^2} + \frac{\partial^2 T_2}{\partial y^2} + \frac{1}{y} \frac{\partial T_2}{\partial y} \quad (3-10)$$

where $y = 0$, and

$$\frac{1}{\alpha_2} \frac{\partial T_2}{\partial t} = \frac{\partial^2 T_2}{\partial x^2} + \frac{\partial^2 T_2}{\partial y^2} \quad (3-11)$$

where $y = 0$. The subscript 2 refers to the gas.

A numerical solution to this set of equations was obtained by a step-by-step relaxation method for temperature profiles and for various fluidizing gases. The finite difference grid used by the authors is shown in Figure 3-3.

Ziegler, et al., [35] proposed other models for a spherical particle of diameter d_p and in contact with a surface at temperature T_w . They assumed that heat is transferred to the particle by unsteady conduction from the surrounding fluid during its contact with the heat transfer surface. Heat transfer by conduction was considered to be negligible due to a small particle-surface contact.

Botterill, et al., [36] extended the single-particle model to a two particle model (the two particles being in contact with each other). The same assumptions and equations have been used for a single particle model to formulate the two particle model.

Brusenback [37] proposed a model for unsteady conduction to four particles at the heat transfer surface. He neglected the solid phase

Figure 3-3 The finite difference grid employed for the solution of 2D unsteady heat conduction model of Botterill et al [34]

Figure 3-4 The packet renewal model

resistance and considered the resistance of the gas phase between the particles.

The single particle model was found to be reasonable up to $t/d_p^2 \approx 15$ hr/ft² while the two-particle model was adequate up to $t/d_p^2 \approx 50$ hr/ft². The four-particle model had satisfactory prediction up to $t/d_p^2 \approx 250$ hr/ft².

(4) The Packet Renewal Theory

Mickley and Fairbanks [38] proposed a model for heat transfer in a fluidized bed based on unsteady conduction heat transfer between a chunk or packet of solids and a surface. This mechanism considers packets of solid particles (continuous phase) coming to rest on a surface for a very short time and being swept periodically by gas bubbles. The rate of heat transfer depends on the rate of heating of the packets or particulate phase and on the frequency of their replacement at the surface. Features of this model are shown in Figure 3-4.

Consider a packet of particles from the core of the bed at temperature T_b coming into contact with a hot surface at temperature T_w . It resides on the surface for a time τ and exchanges heat by conduction with the surface. When a fresh packet at temperature T_b arrives at the surface, the first packet will be swept away or displaced. This is a continuous process since bubble motion is the main mechanism of heat transfer. Assuming the packet to be a semi-infinite body, the governing equations are:

$$\frac{\partial T_p}{\partial t} = \alpha_p \frac{\partial^2 T_p}{\partial x^2} \quad (3-12)$$

where T_p and α_p are the temperature and thermal diffusivity of the packet respectively, t , is the time, and x is the distance perpendicular to the surface.

The initial condition is

$$T_p(x, 0) = T_b \quad (3-13)$$

The boundary conditions on x are:

$$T_p(0, t) = T_w \quad (3-14)$$

$$T_p(x \rightarrow \infty, t) = T_b \quad (3-15)$$

The temperature profile for this problem is,

$$\frac{T_p(x,t) - T_b}{T_w - T_b} = \operatorname{erfc} \frac{x}{2\sqrt{\alpha_p t}} \quad (3-16)$$

Accordingly, the local instantaneous heat flux, q_1 , in the packet and the local instantaneous heat transfer coefficient can be obtained upon differentiating and rearranging:

$$q_1 = \frac{q_w}{A_p} = \sqrt{\frac{K_p \rho_p C_{p_p}}{\pi \tau}} (T_w - T_b) \quad (3-17)$$

$$h_1 = \sqrt{\frac{K_p \rho_p C_{p_p}}{\pi \tau}} \quad (3-18)$$

where K_p , ρ_p and C_{p_p} are the thermal conductivity, density and heat capacity of the packet respectively, τ , is the residence time, q_w , is the heat transfer rate into the packet which has an area A_p in contact with it. The thermo-physical properties for the packets were imagined to be made at minimum fluidization conditions. The time-averaged local heat transfer coefficient can be evaluated by integrating the local instantaneous heat transfer coefficient. Thus,

$$h_{av} = \frac{\int_0^\tau h_1 d\tau}{\int_0^\tau d\tau} = 2 \left(\frac{K_{mf} \rho_{mf} C_{p_{mf}}}{\pi \tau} \right)^{1/2} \quad (3-19)$$

The residence time, τ , of the particulate phase and a surface of length L in a slugging or a bubbling bed is given by Davidson [39] as:

$$\tau = \frac{L}{U_o - U_{mf}} \quad (3-20)$$

Therefore

$$h_{av} = 2 \left[\frac{K_{mf} \rho_{mf} C_{p_{mf}} (U_o - U_{mf})}{\pi L} \right]^{1/2} \quad (3-21)$$

where the voidage is held constant for packets of particulate phase.

Baskakov, et al., [40, 41] objected to the Mickley-Fairbanks model, due to the assumptions of constant thermo-physical properties for the packets and the short contact times with the surface. They mentioned that these properties are porosity dependent and since porosity of the bed varies due to the presence of a heating element, all thermal properties will not be constant.

Baskakov, et al., proposed an additional resistance in the vicinity of the surface in a zone where thickness is about one particle radius. The new thermal contact resistance was considered to be time independent. The packet thermal resistance of the bed, R_p , from Mickley-Fairbanks theory is defined as:

$$R_p = \left(\frac{\pi \tau}{K_{mf} \rho_{mf} C_{p_{mf}}} \right)^{1/2} \quad (3-22)$$

Considering a spherical particle in contact with the surface, Baskakov introduced an additional contact resistance, R_c , approximated by

$$R_c = \frac{d_p}{\pi K_g \left[\ln \left(10 K_s / K_g \right) - 1 \right]} \quad (3-23)$$

Using these equations for R_p and R_c , the following correlation for local instantaneous heat transfer rate per unit area was proposed as:

$$q = T_w - T_b \left(\frac{R_c}{R_p + R_c} \right) \quad (3-24)$$

Accordingly, the instantaneous heat transfer coefficient is given by:

$$h_i = \frac{1}{R} \exp \left(R_p / R_c \sqrt{\pi} \right)^2 \operatorname{erfc} \left(R_p / R_c \sqrt{\pi} \right) \quad (3-25)$$

This model is applicable for short contact times between a surface and the packets and reduces to the Mickley-Fairbanks model for long contact times. The modified packet model of Baskakov is considered to be a valuable contribution to the analytical prediction of heat transfer in fluidized bed combustors.

$$Nu = \frac{h d_p}{k_{eff}}$$

$$Fo = \frac{\alpha_{eff} T}{d_p}$$

Curve 1: Mickley and Fairbanks
Curve 2: Baskakov

Figure 3-5 Baskakov's results compared to the measurements of Antonishin et al.

Gorelik [43] proposed another modification to the packet theory by suggesting that the porosity of the packet near the surface is higher than the porosity of the packet near the bed. Therefore, the thermal properties of the packet will be different at two different zones in the packet due to the change of the porosity.

All these models for the particle convective heat transfer coefficient were based on the concept of transient heat transfer in a fluidized bed. It is obvious that these models have been developed to predict the heat transfer coefficient using two types of mechanisms, firstly, the single particle model and secondly, the particulate phase model. The determination or prediction of residence time, τ , for the packets or single particles with a surface is a fundamental difficulty in all proposed models.

Figure 3-5 represents a plot of dimensionless heat transfer coefficients (expressed as an effective Nusselt number, Nu_{eff}), and the dimensionless contact time, (Fo_{eff}) , as measured by Antonishin, et al., [44]. These results are in good agreement with the theoretical work of Baskakov.

3.3.3. Evaluation of Heat Transfer Coefficients

There are three main components for overall heat transfer coefficient between a gas fluidized bed and an immersed surface:

- a. The particle convective component, h_{pc} .
- b. The gas convective component, h_{gc} .
 - i) gas convection transfer in the dense phase.
 - ii) gas convection transfer in the bubbles phase, h_b
- c. The radiant component, h_r
 - i) radiation in the dense phase
 - ii) radiation in the lean phase

Gelperin and Einstien [45] proposed the following expression for the overall heat transfer coefficient in a bubbling or a slugging fluidized bed:

$$h = (1-f_o)(h_{pc} + h_{gc}) + f_o h_b + h_r \quad (3-26)$$

where f_o is the fraction of contact time between the immersed surface and bubbles. The bubble contribution is significant only for turbulent regimes. However, it is negligible in comparison with the particle and gas convective components. The radiative component, h_r , is important only at high temperature fluidized beds (800 to 1000°C).

For fine particles ($d_p < 400 \mu m$) the particle convective heat transfer coefficient is dominant; therefore, one may write

$$h \approx (1-f_o) h_{pc} \quad (3-27)$$

When large particles are fluidized (high volumetric gas flow rate) the gas convective component must be included, i.e.:

$$h \approx (1-f_o)(h_{pc} + h_{gc}) \quad (3-28)$$

The gas convective heat transfer has led workers to investigate the heat transfer in fluidized beds with large particles. Several approaches have been adopted to evaluate the contribution of this component to the overall heat transfer coefficient. Baskakov and Suprum [42] suggested a correlation based on the analogy between convective heat transfer and mass transfer by neglecting other factors affecting the mass transfer coefficient, such as erosion of the surface. Their correlation is based on the experimental data for mass transfer coefficients.

Many investigators have adopted the packed bed conditions in determining the gas convective heat transfer rate. Gabor [46] modeled a correlation based on:

1. gas velocity equal to or less than minimum fluidizing velocity.
2. all heat flow normal to the surface.
3. gas is in plug flow condition.
4. bed diameter large enough that all heat is removed by the gas and none by the wall.
5. thermo-physical properties for particles are constants.

The average gas convective heat transfer coefficient between a flat surface of length L and a fluidized bed is given by

$$h_{gc} = \left(\frac{4 K_o \rho_g C_{p_g} U}{\pi L} \right)^{1/2} \quad (3-29)$$

For a cylindrical surface by neglecting $K_o L / \rho_g C_{p_g} U r^2$, the equation is:

$$h_{gc} = \left(\frac{4 K_o \rho_g C_{p_g} U}{\pi L} \right)^{1/2} + \frac{1}{2} \frac{K_o}{r} \quad (3-30)$$

where r is the radius of the immersed surface, and K_o is the effective thermal conductivity of the bed.

$$K_{mg} = K_o + 0.1 C_{p_g} \rho_g U_{mf} d_p \quad (3-31)$$

Other equations have been proposed by some investigators such as Yagi and Kunii [47].

The experimental results for particle sizes up to 3.2 mm and for particle Reynolds number up to 230 were in good agreement with Gabor's model.

In the present investigation the radiant component of heat transfer will not be taken into consideration due to the fact that the experimental conditions are based on low temperature (about 100°C).

3.3.4 Large Particles Heat Transfer Studies

There is an increasing interest in the heat transfer between large particles and immersed surfaces in fluidized bed systems (FBS) due to their advantages in the power generation industry. Makhorin and Tishchenko [48] have reported data for heat transfer for a sphere; Traber, et al., [49] for a coil; Patel [50], Filippovsky and Baskakov [51] for a vertical plate; Gabor [46], Botterill and Denloyle [52] and Maskaev and Baskakov [53] for a vertical tube; Turton, et al., [54] for fine wires; and Wright, et al., [55] for tube bundles, and others.

Heat transfer between a fluidized bed and horizontal immersed tubes has been investigated by several investigators. Vreedenberg [56], was a pioneer in reporting experimental data for overall heat transfer coefficients for horizontal tubes. He conducted experiments in a 0.565m diameter bed over a wide range of conditions. The variables he considered were particle density ($1.6 \times 10^3 - 2.66 \times 10^3 \text{ kg/m}^3$), particle diameter (0.0635-0.316 mm), particle shape (sharp to round), a wide range of particle Reynolds numbers, and tube diameter (1.69-5.1 cm).

He proposed two different formulae, one for fine particles and the other for large particles. For fine particles his data were correlated within $\pm 42\%$ by the formula:

$$\frac{h}{K_g} \frac{dt}{dt} = 0.66 \left[\frac{G}{\rho_g} \frac{dt}{\mu_g} \frac{\rho_p}{\mu_g} \cdot \frac{1-\epsilon}{\epsilon} \right]^{0.44} \left(\frac{\mu_g C_p}{K_g} \right)^{0.3} \quad (3-32)$$

$$\text{for } \frac{G d_p \rho_p}{\rho_g \mu_g} < 2050$$

The correlation for coarse and heavy particles is

$$\frac{h dt}{K_g} = 420 \left[\frac{G}{\rho_g} \frac{dt}{\mu_g} \frac{\rho_p}{\mu_g} \cdot \frac{\mu_g^2}{d_p^3 \rho_p^2} \right]^{0.33} \left(\frac{\mu_g C_p}{K_g} \right)^{0.33} \quad (3-33)$$

$$\text{for } \frac{G d_p \rho_p}{\rho_g \mu_g} > 2550$$

where G is the mass velocity of fluidizing gas ($\text{kg/m}^2 \text{ sec}$) and dt is the outside diameter of the tube.

The correlation for coarse and heavy particles did not take into consideration the variation in bed voidage as the fluidization velocity was increased, since it was based on the diameter of tube. Andeen and Glicksman [57] proposed a correlation to account for the bed voidage variations. Their modified Vreedenberg correlation for coarse particles is:

$$\frac{h}{K_g} \frac{dt}{dt} = 900 (1 - \epsilon) \left[\frac{G}{\rho_g \mu_g} \frac{\rho_p}{\mu_g} \cdot \frac{\mu_g^2}{d_p^3 \rho_p^2 g} \right]^{0.326} \left(\frac{\mu_g C_{p_p}}{K_g} \right)^{0.3} \quad (3-34)$$

Xavier and Davidson [58] considered the particle convection contribution for a plane surface in a slugging bed since the particle residence time at the surface is well predicted for slug flow. They proposed a model which accounts for particle convective component, h_{pc} , and gas convective component, h_{gc} . The maximum particle convective component is based on the packet model of Mickley and Fairbanks [38] for slug flow, with a bubble rise velocity of U_B , and is given by:

$$h_{pc_{max}} = \left[\frac{K_{mf} \rho_{mf} C_{p_{mf}} U_B}{\pi L} \right]^{1/2} \quad (3-35)$$

The model of Baskakov [40] has been used to evaluate h_{pc} according to the expression:

$$\frac{h_{pc}}{h_{pc_{max}}} = \frac{\sqrt{\pi x}}{y(1+x)} (\operatorname{erfc} y \cdot \exp y^2 - 1) + \frac{2\sqrt{x}}{1+x} \quad (3-36)$$

where $y = h_{film} / (h_{pc_{max}} \sqrt{\pi x})$, $x = (U - U_{mf}) U_B$, $h_{film} = K_g / \delta$ (gas film heat transfer coefficient), $\delta = d_p / 10$ for vertical surfaces and $d_p / 4$ for horizontal tube banks. The gas convective component can be expressed as:

$$h_{gc} = \left[\frac{4 K_g C_{p_g} \rho_g U_{mf}}{\pi L} \right]^{1/2} \quad (3-37)$$

and the residence time (τ), for a slugging bed, is:

$$\tau = \frac{L}{U - U_{mf}} \quad (3-38)$$

The sum of h_{pc} and h_{gc} gives the overall coefficient of heat transfer between a surface of length L and a gas fluidized bed.

Xavier and Davidson [58], note that predictions from this model are in good agreement with their experimental data for pressures ranging from 1 to 10-20 bar, and for particle sizes of 84 to 2100 μm .

Staub et. al. [59] describe a model for the heat transfer between a surface and a fluidized bed, based on a turbulent convection mechanism and the packet renewal theory. Turbulent convection mechanisms generally assume a steady-state approach, since the turbulent regime is semi-homogeneous and in turn the solid particles reduces the film resistance. However, the packet renewal theory is basically a transient or unsteady state mechanism.

The experimental work was generated in two square fluidized beds (0.3 x 0.3 m and 0.6 x 0.6 m in size), with single tubes and with five to ten row tube bundles. The staggered horizontal tube bundles included 3.2 cm O.D. bare tubes and finned tubes. Static bed heights were varied from 25 cm to 70 cm, and glass and silica sand particles 650 μm and 2600 μm in size were used. Pressures ranged from one to ten atmospheres, with ambient temperatures, air and refrigerant R-12 as fluidizing gas and 6.5 m/s and 3.2 m/s superficial gas velocity.

Their proposed correlation for effective heat transfer coefficient in the dense phase is based on the packet theory and is given by:

$$h_p = \left(\frac{K_o C_p \pi}{\bar{\theta}_D} \right)^{1/2} \quad (3-39)$$

where $\bar{\theta}$ is the root mean square residence time of the dense-phase packets. They assumed that the heat transfer during lean-phase corresponds to turbulent convection, expressed as:

$$\frac{h_L}{h_g} = \left[1 + \frac{1}{4} \frac{\rho_p (1-\epsilon_L)}{\rho_g \epsilon_L} \right] \quad \text{For } d_p >, 1000 \mu\text{m} \quad (3-40)$$

and for $20 < d_p < 1000 \mu\text{m}$

$$\frac{h_L}{h_g} = \left[1 + \left(\frac{150}{d_p} \right)^{0.73} \frac{\rho_p (1-\epsilon_L)}{\rho_g \epsilon_L} \right]^{0.45} \quad (3-41)$$

where h_g , the heat transfer coefficient for gas flow alone, may be given by standard single-phase correlations for flow across the tubes, for example:

$$\frac{h_g dt}{K_g} = b \left(\frac{\rho_g U_{gm} dt}{\mu_m} \right)^n \left(\frac{Cp_g \mu_g}{K_g} \right)^{1/2} \quad (3-42)$$

where U_{gm} is the gas velocity based on minimum flow area, and b and n are coefficients.

Staub's turbulent flow model requires a knowledge of the fluidization parameters either from experimental data or from other correlations. The overall heat transfer coefficient can be expressed by:

$$h = f_L h_L + (1-f_L) h_D \quad (3-43)$$

where f_L is the fraction of the total time the lean phase is in contact. The model involves the concept of a particle mixing length which was taken to be equal to the tube spacing. The model is best suited to conditions of high gas flow velocity and large particle fluidization with tube banks immersed in fluidized beds.

Glicksman and Decker [60] proposed a correlation for the overall heat transfer coefficient to an immersed surface in large particle fluidized beds. They note that the solid material close to the heat transfer surface remains at a constant temperature during the residence time in a bubbling fluidized bed, while thermal time constants are higher. They added that the overall heat transfer coefficient for large particles has lower values at minimum fluidization than those at higher superficial velocities. This is due to an additional thermal resistance in the thermal boundary layer in the gas film between the particles and a surface. Their correlation is:

$$\frac{h d_p}{K_g} = (1 - \epsilon_B) [9.3 + 0.042 Re_p Pr] \quad (3-44)$$

where ϵ_B is the bubble voidage and may be obtained experimentally or evaluated from a correlation proposed by Staub et al., [59]

$$\epsilon_B = \frac{1}{1 - \epsilon_{mf}} \left[\frac{U_o}{C_o U_o + V_{gu}} - \epsilon_{mf} \right] \quad (3-45)$$

Figure 3-6 Model of heat transfer between a horizontal tube and a fluidized bed

where

$$V_{gu} = \left(\frac{1 - \epsilon_{mf}}{\epsilon_{mf}} \right) U_{mf} \quad (3-46)$$

Here $C_o \approx 0.95$ to 1.05 and ϵ_{mf} may be taken as 0.41 . This model was found to give better results for beds of millet than for beds of fire clay with widely spaced immersed surfaces.

Zabrodsky et al., [61] presented a semi-empirical correlation for the overall convective heat transfer coefficient between large-particle fluidized beds and immersed horizontal tube banks. The correlation is

$$h_c = \frac{7.2 K_g (1 - \epsilon)^{0.66}}{d_p} + 26.6 U_o^{0.2} C_{pg} \rho_g d_p \quad (3-47)$$

where ϵ may be obtained from Staub's equations 1.35 and 1.36.

The first term in the above correlation represents the particle convective component (h_{pc}) while the second term represents the gas convective component. They note that the heat transfer coefficients were more affected by the changes in horizontal pitch than in vertical pitch for staggered tube bundles in a fluidized bed.

Anekwe [62] developed a correlation for the overall convective heat transfer coefficient between a bubbling gas fluidized bed and immersed horizontal tubes under ambient conditions. Experimental data was gathered in a 25.4 square unit with a height of 2m. The bed was operated at a static height of 50 cm with sand particles ranging from $163 \mu m$ to $1840 \mu m$ in diameter and for single tube (teflon) and in-line tube bundles. The tube diameter varied from 1.95 cm to 5.08 cm with $U_o < 2$ m/sec and included a fixed bed ($U < U_{mf}$).

Anekwe [62] used the modified packet theory of Mickley and Fairbanks and the two-phase theory of fluidization to correlate the particle convective heat transfer coefficient in the form of:

$$h_{pc} = \frac{UA}{UB} \frac{\delta}{K_g} A1 \left\{ \operatorname{erfc} \left[\frac{K_g}{\delta} \left(\frac{1}{A1} \right)^{1/2} \right] \exp \left[\left(\frac{K_g}{\delta} \right)^2 \frac{1}{A1} \right] - 1 \right\} + 2 \frac{UA}{UB} \left(\frac{A1}{\pi} \right)^{1/2} \quad (3-48)$$

$$\text{where } A1 = K_{mf} \rho_{mf} C_{mf} / \tau \quad (3-49)$$

The quantities U_A and U_B are the absolute rise velocity of bubbles and the rise velocity of single bubble, respectively. The gas film thickness (δ) is taken as $\delta_{\min} = d_p/6$ on the 90° position on the tube, increasing to $d_p/4$ on the upstream and downstream locations.

In addition, a semi-empirical correlation was proposed for estimating the dense phase residence times, based on the bubble hydrodynamics as:

$$\tau = \frac{DB}{U_A} \left[\frac{3\pi}{8} \left(\frac{U_A}{U - U_{mf}} \right) - 1 \right] \quad (3-50)$$

The gas convective contribution is given by:

$$\frac{h_{gc}}{K_g} \frac{d_p}{p} = 0.0175 \text{ Ar}^{0.46} \text{ Pr}^{0.33} \left(\frac{U}{U_{mf}} \right)^{0.3} \quad (3-51)$$

The overall convective heat transfer coefficient between a fluidized bed and immersed horizontal tubes may then be given by:

$$h_c = h_{pc} + h_{gc} \quad (3-52)$$

Anekwe states that his model shows good agreement with experimental data for a single tube and for tube bundle studies; particularly with regard to Eq. (3-50), for residence time. The main features of this model are shown in Figure 3-6.

Abubaker and Tarasuk [63] investigated the local and overall heat transfer coefficients on a horizontal tube inside a shallow gas fluidized bed. They note that the bed height and probe location above the distributor plate greatly affect the heat transfer coefficient. The heat transfer coefficients for a square bed (height equal to diameter) were generally lower near the grid, higher at the top, and moderate in the middle of the fluidized bed. Grid open area (between 0.51 and 4.72%) was found to have a significant effect on reduced heat transfer coefficients values for fine activated carbon particles, (165 μm diameter) and a minor effect for coarse particles (480 μm diameter).

In their work a Plexiglas column having an internal diameter, of 278 mm was used. A probe 277 mm in length, 30 mm external diameter and made from 8.7 mm thick copper tube was placed at four positions above the grid (specifically at $H_t = 44, 115, 150$ and 215 mm for bed height (H_{mf}) ranging from 130 mm to 580 mm). They concluded that the overall heat transfer coefficients were highest at $H_{mf} = 250$ mm for all tube locations in the bed with fluidization velocity ranging between 0.03 and .80 m/s due to maximum solid mixing and circulation for a square bed.

Their experimental data showed good agreement with Andeen and Glicksman [57] correlation for moderate gas velocities:

$$Nu = 900 (1-\epsilon) Pr^{0.3} \left[U dt \mu/d_p^3 \rho_g g \right]^{0.325} \quad (3-53)$$

However, for low and high gas velocities there were big discrepancies and they suggested a modified correlation to account for tube and bed heights having the form:

$$Nu = \frac{h dt}{K} = 1135 (1-\epsilon) Pr^{0.3} \left[U dt \mu/d_p^3 \rho_g g \right]^{0.776} \left[H_t/H_{mf} \right]^{0.145} \quad (3-54)$$

where h , dt and H_t are the overall heat transfer coefficient, the tube diameter and the distance from the tube centerline to grid (SI Units) respectively.

The agreement between their experimental data and Eq. (3-54) is fairly good and has a maximum deviation of about 17%.

Adams [64] presents an approximate analytical model of the time averaged heat transfer coefficient for a horizontal tube immersed in a large-particle bubbling fluidized bed. This model is based upon the gas convection model proposed by Adams and Welty [65], Adams [66, 67] and the experimental data of Catipovic [68, 69]. The model involves the emulsion phase residence time and bubble phase (lean phase) contact time for a horizontal tube immersed in a 2-D cold bed.

The baseline geometry for this model consists of a single tube immersed horizontally in a two-dimensional atmospheric-pressure cold-bed with a single spherical bubble contacting the tube. Sand particles of 1.3 mm mean diameter and dolomite particles of 2.0, 2.8, 4.0, and 6.0 mm mean diameter were used to determine the heat transfer, dense phase residence times, and the bubble (lean phase) contact fraction. These were local values for a 5.08 cm horizontal tube. The operating conditions were $U_o/U_{mf} < 1$ (for a packed bed) to $U_c/U_{mf} = 2.75$ and particle Reynolds numbers at U_{mf} ranged from 46.2 for 1.3 mm sand to 817 for 6.6 mm Dolomite.

Adam's model for predicting the overall time-averaged Nusselt number at $U/U_{mf} \sim 1.1$, for a tube immersed horizontally in a bed was in excellent agreement with experiment data for the 4 mm dolomite particles, particularly at $\theta = 45^\circ$ and 135° from the bottom stagnation point of the immersed tube. However, the data for the 1.3 mm sand particles is over estimated for $U_o/U_{mf} > 1$ due to the single particle approach.

Chandran and Chen [70] proposed a model for local heat transfer for horizontal tubes immersed in a gas-fluidized bed based on combined dense phase and lean phase mechanisms and compared the model with data on bed-surface contact hydrodynamics from their previous investigations [71, 72]. They note that it is unrealistic to assume axial symmetry around the surface, even though the fluid flow is normal to the tube axis, since the local heat transfer coefficient is a quantity which depends upon circumferential position around the tube surface.

The local heat flux for a horizontal tube surface immersed in a fluidized bed is given as:

$$q = q_L + q_D \quad (3-55)$$

and

$$h = f_L h_L + (1-f_L) h_D \quad (3-56)$$

where f_L is the fractional contact time of the lean phase and h is the local heat transfer coefficient (weighted average) of the dense phase and the lean phase.

The dense-phase heat transfer consists of two components, one due to surface renewal of a medium with stagnant fluid (h_s), and the other due to gas flow (h_f):

$$h_D = h_s + h_f \quad (3-57)$$

The unsteady state component (h_s) is

$$h_s = 2C \left(\frac{K_D C_{pD}}{\pi \bar{\theta}_D} \right)^{1/2} \quad (3-58)$$

where C is the effective correction factor that accounts for the packet limit solution. The quantity $\bar{\theta}_D$ is the root-square average residence time of the dense-phase packets for the constant wall temperature boundary condition and is expressed in terms of different residence time, θ_{D1} , as:

$$\bar{\theta}_D = \left[\frac{\sum_{i=1}^n \theta_{D1}}{n \sum_{i=1}^n \sqrt{\theta_{D1}}} \right]^2 \quad (3-59)$$

They proposed that the heat transfer coefficient accounting for the effect of fluid-flow on conduction (ventilation effect approach), h_f , has the following limits

$$\begin{aligned} \lim_{Fo \rightarrow 0} h_f &= 0 \\ \lim_{Fo \rightarrow \infty} h_f &= h_{mf} \end{aligned} \quad (3-60)$$

where $Fo = (K_D \bar{\theta}_D / Cp_D \bar{d}_p^2)$ is the time-mean Fourier modulus. Using a weighting factor that approaches these limits, h_f is given as:

$$h_f = \left[1 - \exp \left(- \frac{x_p}{\bar{d}_p} \right) \right] h_{mf} \quad (3-61)$$

If x_p is defined as the heat penetration depth for $(T-T_b/T_w-T_b)$ to attain a value of 0.01, the use of semi-infinite layer approximation yields

$$x_p / \bar{d}_p \approx 3.6 \sqrt{Fo} \quad (3-62)$$

The effect of (K_D/K_g) on the penetration depth is ignored.

To determine h_{mf} , Chandran and Chen [71] derived the empirical relationship:

$$\frac{h_{mf} dt}{K_g} = 0.26 Ar^{0.31} \quad (3-63)$$

where dt is the tube diameter and Ar is Archimedes number

$$(g \bar{d}_p^3 \rho_g (\rho_s - \rho_g) / u_g^2)$$

The heat transfer during lean-phase contact is assumed to be the fluid convection mechanism. The concept follows Staub's approach in that;

$$\frac{h_1}{h_g} = f \left(\frac{G_s}{G_g}, \frac{Cp_s}{Cp_g} \right) \quad (3-64)$$

where G_s/G_g is the solid mass loading ratio (superficial mass velocity ratio).

The final form of equation (3-56) for the local heat transfer coefficient h is:

$$\begin{aligned}
h = f_L \left[\epsilon_L + 0.24 h_g \left\{ \frac{(1-\epsilon_L)}{\epsilon_L} C_{p_g} \frac{dt}{\bar{d}_p} \text{Ar}^{0.36} \right\}^{0.57} \right] \\
+ (1-f_L) \left[\gamma \sqrt{\frac{K_D C_{p_D}}{\pi \bar{\theta}_D}} + \left(1 - \exp \left(-3.6 \sqrt{Fo} \right) \right) h_{mf} \right] \quad (3-65)
\end{aligned}$$

The physical properties of the gas and the solids required for these calculations are ρ_g , K_g , C_{p_g} , μ_g , ρ_s , C_{p_s} , K_s . The fluidization parameters, $\bar{\theta}_D$, f_L , ϵ_D , ϵ_L , have to be determined experimentally. In addition, the system variables U_o , U_{gm} and the geometric factors ($\bar{d}_p$, dt) have to be known.

The values of h_g , C_{eff} and h_{mf} have to be determined using one of the available correlations. Candran and Chen [70] claim that their model predicts the variation in local and average heat transfer coefficients successfully for gas flow rate, particle size and system pressure. They note that the model has a tendency to underestimate the heat transfer coefficients at low gas velocities due to a mismatch in the wall boundary condition.

The properties of test particles ranged from 125 - 1580 μm particle mean diameter (soda lime glass) 0.024 - 0.801 m/s minimum fluidizing velocities at atmospheric pressure and 0.83 - 9.47 m/s particle terminal or free fall velocity at one atmosphere.

Goshayeshi et al., [73] investigated the time-average local heat transfer coefficients for a horizontal tube bundle in a high temperature, large-particle fluidized bed. A tube bundle of 9 tubes, 2 inch in diameter, arranged in 3 horizontal rows, with 6 inch spacing between tube centers was used. Lone grain particles ranging from 2.14 to 3.23 mm nominal diameter were used in beds having temperatures up to 1005 K.

Superficial velocities ranged from packed bed conditions to about two times U_{mf} ($U_{mf} \sim 1.1 - 2.3$ m/s) and were used for both tube banks and a single tube, for the sake of comparison. The instrumented tubes were the center tube in each array and the local heat flux and surface temperature were measured at intervals of 30 degrees from the bottom stagnation point to the top.

Results were presented in the form of time-average local heat transfer coefficients as a function of angular position ($\theta = 30 - 180$ degrees), superficial velocity, particle size and bed temperatures for tube banks and single tubes. In addition, comparisons between the top, middle and bottom

tubes data were compared with those for a single tube data. The uncertainty in local heat transfer coefficient was about $\pm 9\%$.

In a bubbling fluidized bed, they concluded that the local heat transfer coefficients for a single tube exhibit slightly lower values than those of tube banks, due to the presence of adjacent tubes. They suggested that single tube investigations are useful for predicting heat transfer with staggered tube bundles with a pitch to diameter ratio of three or greater. Captipovic [68] and Boroudulya [74] suggested a ratio of two or greater for pitch to diameter ratio.

Goshayeshi et al, [73] note the effect of increased superficial gas velocity, U_o , on the location of maximum local heat transfer coefficient, $h_{\theta \text{ max}}$. They mentioned that, h_{θ} , at 180 degrees shows an increase from 6 to 185 W/m²K with an increase of the superficial velocity from 1.3 to 2.43 m/sec. The bed contained 2.14 mm diameter particles at a bed temperature of 810 K. This is due to a relatively cool stagnant cap of particles which settled onto the top of the tubes at low superficial velocities and were swept out at higher superficial gas velocities.

The effect of particle size on time-averaged local heat transfer coefficients indicates that a bed of smaller particles is more sensitive to velocity changes and produces higher values than those for larger particles. This behavior also applies to single tube measurements. They found that the instrumented tube in the middle row exhibits higher and smoother values for heat transfer coefficients than those at the top and bottom of the bed. This behavior applies only for bubbling beds. However, in a slugging bed or with near slug flow for the same operating conditions, their results indicate higher values of heat transfer coefficients for the top tube for $\theta=0-90^\circ$ than those of middle and bottom tubes in the bed, this trend is reversed for $\theta=90-180^\circ$.

Biyikli et al [75] experimentally investigated the average heat transfer coefficients for a water-cooled single tube at different elevations in the free board of high-temperature fluidized beds. The tests were carried out in a 46 cm I.D. circular bed, 4.5 m in height, operating at temperatures of 300, 500, and 750°C and atmospheric pressure. Limestone of 1400 μm and silica sand of 465 μm and 1200 μm mean diameters were used as fluidizing particles. Various minimum fluidization and entrainment velocities of the test particles were used for different bed temperatures.

They proposed a general correlation for average heat transfer coefficients for tubes immersed horizontally in the free board region which deviates by 29% from the experimental data.

An instrumented tube, 3.8 cm O.D. and 24 cm in length was placed horizontally into the bed. They found that the heat transfer coefficient for a tube in the free board increased with increasing gas velocity and decreasing tube elevation, and for lower regions of the free board, the heat transfer coefficients approached values corresponding to a tube immersed in the fluidized bed.

Chung and Welty [76] performed heat transfer experiments for a tube array horizontally immersed in a fluidized bed operating at 812 K . The test operating conditions were similar to that of Goshayeshi et al., [73] except that a centrally-located instrumented tube was used in the array. Data are reported for both total and radiative heat transfer rates, for superficial velocities ranging from packed bed to over twice the minimum fluidization velocity and for five different particle sizes of Ione grain.

Local heat transfer coefficients measured around the tube periphery, and integrated averages are reported for all test conditions. A comparison of the convective and radiative components of heat transfer coefficients are compared for a tube in the array and a single tube with identical test conditions. They conclude that both mechanisms are competing effects, while the effects of particle size and superficial velocity are in good agreement with those of Goshayeshi [73].

Renganathan and Turton [77] introduced a model for time-averaged local heat transfer coefficients for a surface immersed horizontally in a fluidized bed system. Their model is based on thermal inertia or time lag (τ_r) between a surface and a packet of emulsion phase in contact in fluidized bed. The time-lag (τ_r) may be viewed as the transition time for an emulsion packet (heterogeneous) to acquire a continuous distribution of temperature and behave as a homogeneous media.

They considered an emulsion packet subjected to a step change in temperature at one end and experiencing two types of heat transfer; firstly, due to temperature difference, an external driving force, between the packet and the surface and secondly due to a nonsimilar behavior for interfacial transfer between solids and fluid phases.

Their model is formulated as follows:

$$\alpha e \frac{d^2 u}{dx^2} = \frac{du}{dt} + \tau_r \frac{d^2 u}{dt^2} \quad (3-66)$$

The initial and boundary conditions are:

$$u(0, t) = 1 \quad (3-66a)$$

$$u(\infty, t) = 0 \quad (3-66b)$$

$$u(x, 0) = 0 \quad (3-66c)$$

where u is a non-dimensionalized temperature. The equations were solved using a boundary layer approach and gave an approximate solution for $u(x, t)$.

The general solution for $u(x, t)$ can be expressed as

$$u = \left[1 - \operatorname{erf} (x/4\alpha_e t)^{0.5} \right] \left[1 - \exp \left(\frac{-t}{\tau_r} \right) \right] \quad (3-67)$$

Subsequently, they approximated the heat flux at the surface by

$$q = -K \frac{dt}{dx} = \Delta T \left[\frac{K_g \rho_g C_{p_g}}{\pi t} \right]^{0.5} \left[1 - \exp \left(\frac{-t}{\tau_r} \right) \right] \quad (3-68)$$

Therefore, the instantaneous heat transfer coefficient is

$$h_i = \frac{q}{\Delta T} = \left[\frac{K_g \rho_g C_{p_g}}{\pi t} \right]^{0.5} \left[1 - \exp \left(\frac{-t}{\tau_r} \right) \right] \quad (3-69)$$

Assuming the residence time for the packets at the surface to be exponentially distributed, then the time-averaged heat transfer coefficients for a surface immersed horizontally in a fluidized bed is:

$$\langle h \rangle = \int_0^{\infty} \left(\frac{1}{\bar{t}} \right) \exp \left(\frac{-t}{\bar{t}} \right) h_i dt \quad (3-70)$$

$$\text{where, } \tau_r = \frac{l_e}{c} \text{ or } \tau_r = \frac{l_e^2}{\gamma_e} \quad (3-71)$$

where c represents the velocity of the thermal disturbance, $c = (\gamma_e / \tau_r)^{0.5}$, l_e is the mean length of emulsion packet which can be estimated from Kunii and Levenspiel [78], γ_e is the emulsion thermal diffusivity (m^2/sec), and $\bar{t}$ is the average contact time of the emulsion packets at the surface.

They concluded that this model is basically applicable to fine and intermediate particle sizes but not to coarse-particles. They believe that the model is applicable to bubbling fluidized beds since the reported experimental data which fits the model were obtained under controlled conditions particularly those for the average contact time of the emulsion packet. Finally, they mention that agreement between their data and the Mickley and Fairbanks [38] correlation is good only for ($\bar{t} > 1sec$). Their model approaches the Mickley-Fairbanks equation as $\bar{t}$ goes to zero, since the heat transfer coefficient $\langle h \rangle$ of equation (3-70) goes to zero.

3.3.5 Summary

In general, heat transfer to horizontal tubes in a fluidized bed is affected by:

- (a) bed material characteristics
- (b) flow regime
- (c) bed geometry

The heat transfer rate is strongly influenced by the particle diameter, gas velocity, gas pressure and angular position on the immersed tube surface. The distributor plate design does not have a strong effect on the heat transfer characteristics of the bed, providing the tubes are above the jet impingement region (or active zone).

The studies on the effect of tube height and tube location in the bundle have conflicting results. In addition, factors which may be important in fluidized bed heat transfer such as the heat transfer coefficient variation along the surface of a tube (parallel to the tube axis), the flow regime and the effect of erosion on the heat transfer coefficient, have not received thorough investigation.

Table 3-2 summarizes the reported studies on heat transfer to horizontal tubes immersed in fluidized beds.

Table 3-2 A Summary of Previous Studies Dealing With Heat Transfer to Horizontal Tubes Immersed in Fluidized Beds

Investigator	Range of particle sizes, dp (mm)	Bed (m)	Velocity (m/s)	Other Details	Correlations & Remarks
Vreedenberg (1958)	0.0635 - 0.316 Cracking Catalyst Sand Iron Ore (Sharp & Round)	0.565 dia (Circular)	Wide range for mass velocity of air ($G \sim \text{kg/m}^2 \text{ s}$)	Single tube, water cooled, different tube diameter (.0169m - .0510m)	Widely used Vreedenberg correlation for very fine and less fine particles
Andeen and Glicksman (1976)	0.4 - 1.2 Sand	—	—	One row of tubes ($dt = 19 \text{ mm}$) single tube spacing	Vreedenbert correlation modified for intermediate and large particles
Xavier and Davidson (1978)	0.15 - 0.9 sand	—	—	staggered tube array ($dt = 28 \text{ mm}$) one tube spacing	Correlation based on h_{max} and h_{film}
Staub et al. (1980)	0.65 - 2.60 glass beads silica sand	0.3 x 0.3 0.6 x 0.6 (square)	up to 3.2	staggered tube array ($dt = 32 \text{ mm}$) one tube spacing, air at 1.5 and 10 bars, high velocities (turbulence regime)	Correlation based on turbulence flow model for intermediate and large particles

Table 3-2 (continued)

Investigator	Range of Particle Sizes d_p (mm)	Bed (m)	Velocity (m/s)	Other Details	Correlations & Remarks
Chandran et al (1980)	0.125 - 1.580 glass beads	0.203 m ID circular 0.305 x .305	1 Umf - 12 Umf Umf = .024 - .84	Single tube and one row of tubes (d_t = 28.58 mm)	None, but experimental data showed poor agreement with Vreedenberg and modified Vreedenberg correlations
Glicksman and Decker (1980)	Large particles $d_p \geq 1$ mm	—	—	Widely spaced tube bundles	A physical model of heat transfer for large particles with particle thermal time constant much higher than the particle residence time
Zabrodsky et al. (1981)	2.0 Spherical millet seeds 3.0 nonspherical fire clay	0.4 x .24	0.6 - 2.8 Umf = 0.55 and 0.95 respectively	Tube bundle in-line and staggered (d_t = 30 mm)	Correlation based on gas and particle contributions
Anekwe (1982)	0.163 - 1.840 Sand	.254 x .254	Less than 2 m/s max	Single tube (Teflon) and in-line tube bundle (d_t = 1.95 - 5.08 cm)	Correlation for local particle convective heat transfer coefficient and a correlation for residence times

Table 3-2 (continued)

Investigator	Range of particle sizes, d_p (mm)	Bed (m)	Velocity (m/s)	Other Details	Correlations & Remarks
Chandran et al. (1982)	0.245 - 1.58 (single tube) 0.65 (tube array) glass beads	0.305 x .305	Umf - 12 Umf Umf = .024 - .801	Single tube and staggered tube array ($d_t = 28.6$ mm and 31.8 mm) respectively, air at different pressures	None, bed-surface contact dynamics depends on gas flow rate, circumferential position, particle size and system pressure
Abubaker and Tarasuk (1983)	0.165 - 0.480 activated charcoal	0.278 ID circular	0.03 - 0.8	single tube ($d_t = 30$ mm), different grid open area and at different elevations	Andeen and Glicksman correlation (1976) Modified to account for tube and bed heights
Decker and Glicksman (1983)	$d_p \geq 1$ mm	—	—	—	Correlation for large particles based on: thermal time constants for large particles is much higher than their residence times at a heat transfer surface

Table 3-2 (continued)

Investigator	Range of Particle sizes d_p (mm)	Bed (m)	Velocity (m/s)	Other Details	Correlations & Remarks
Adams (1984)	1.3 Sand 2.0, 2.8, 4.0, 6.0 dolomite	2-D bed	$2.75 = U < 1$ U_{mf}	Single tube ($dt = 50.8$ mm), bubbling only	Correlations based on a single tube in contact with a single spherical bubble and a consolidation of approximations and refinements of the gas convective model of Adams and Welty (1979)
O'Brien et al. (1985)	0.215 - 3.4 glass beads	0.305 ID circular	$U_{mf} = 0.38 - 1.41$ $U_{opt} = .22 - 1.69$	tube bundle ($dt = 25.4$ mm)	None, using heat/mass transfer analogy to determine the contribution of gas convection to total heat transfer coefficient
Goshayeshi et al. (1985)	2.14 - 3.23 lone grain	0.3 x 0.6	packed bed to 2 U_{mf}	Single tube and staggered tube array ($dt = 50.8$ mm) high temperatures (1005K)	None $< h_{av} > = f(\theta, U, dp, T)$ spacing = $\frac{Pitch}{\geq 3}$ tube dia.

Table 3-2 (continued)

Investigator	Range of Particle sizes, d_p (mm)	Bed (m)	Velocity (m/s)	Other Details	Correlations & Remarks
Canada and McLaughlin (1985)	0.65 - 2.60 glass beads silica sand	0.3 x 0.3	$U_{mf} = 0.16 - .63$ $U_t = 1.96 - 13.47$	Staggered tube array of 5 rows and 10 rows tube banks, different pressures (1 - 10 atm)	None variation of $\langle h \rangle$ as a function of U/U_t was about the same at all pressures and gas flows
Chandran and Chen (1985)	0.125 - 1.580 soda lime, glass	.305 x .305	.024 - .801 $U_t = 0.63 - 9.47$	Single tube and staggered tube array (Chandran and Chen) 1982	Correlation based on bed surface contact dynamics from fluid mechanics investigations (Chandran and Chen, 1982)
Biyikli et al. (1987)	0.465 - 1.20 Silica sand 1.40 limestone	0.46 ID circular	U_{mf} and U_t wide range for different particles and bed temp.	Single test tube ($d_t = 38$ mm) at different elevations in the freeboard and high temperatures	Correlation for free board heat transfer (h) at lower region of freeboard approaches (h) immersed tube

Table 3-2 (continued)

Investigator	Range of Particle sizes, d_p (mm)	Bed (m)	Velocity (m/s)	Other Details	Correlations & Remarks
Chung and Weky (1989)	0.97 - 2.37 (5 different particle sizes) lone grain	0.3 x .6	Packed to greater than 2 U _{mf} , U _{mf} = 1 m/s	Single tube and 3 rows staggered tube array ($d_t = 5.1$ cm), hot gas at 812 K	None, total and radiative heat transfer rates measurements
Renganathan and Turton (1989)	fine and intermediate particle sizes	—	—	—	Correlation based on the physical concept of thermal inertia of emulsion packets, accounts for very short contact time as well as reproduces Mickley - Fairbanks Correlation for reasonable contact time

4. TECHNICAL APPROACH

4.1 Approach Modifications

Although the project was essentially on-schedule, the experimental results were not those that were initially anticipated. At the time that the experimental program was formulated, the primary objective was the development of a scaling procedure to predict in-bed heat transfer tube erosion rates in fluidized bed combustors (FBC's). However, after making an attempt to follow scaling parameters as closely as possible, it became apparent that the WVU 2' x 2' bed would not perform in a similar manner to the METC 6' x 6' bed. Thus it was concluded, by all concerned, that the WVU bed would operate at a fluidization velocity which caused the bed to appear to perform like the METC bed.

Comments by concerned engineers and researchers caused some delays in completing the development of the test facility. Their comments led to the design of a bed having constant fluidizing air temperature, constant bed inventory and maintenance of particle size distribution and shape.

In order to complete the desired test matrix for 1989, the erosion tests were to produce meaningful results within a 100-hour testperiod. To achieve this goal, aluminum was selected as the tube material. The erosion rate of the aluminum was unacceptably low, and the same problem was encountered when tubes of PVC and low carbon steel were tested. Tests on graphite tubes had the desired erosion rates but varied enormously. This, coupled with the difficulties in working with graphite, led to a search for a more acceptable tube material; PMMC (acrylic) proved to be the most suitable material. At this time (July 1989), two conferences on fluidization were held. A significant portion of these meetings was devoted to the subject of erosion. It became apparent that the subject of in-bed tube erosion was a complex mystery. However, the use of large bed particles, high superficial fluidizing velocities and tall beds appeared to result in enhanced erosion. It was concluded that the initial WVU test conditions would require unrealistically high run times before meaningful erosion was obtained.

In the light of these developments, a new technical approach was formulated. The approach had 4 phases, namely:

- (1) Capturing tube wear data for a 2' x 2' bed, with PMMA tubes, over a wide range of operating conditions.
- (2) Comparative wear tests on steel, aluminum, PVC and acrylic tubes in a 6 inch square bed with a range of bed particles.
- (3) The development and use of the Dragometer for measurements of the drag on the tubes, coupled with bubble probe measurements of pressure fluctuations and a Fast Fourier Transform (FFT) analysis of dominant bubble frequencies.
- (4) Development and use of a Heat Flux Gauge for measurement of heat transfer coefficients in the 2' x 2' bed.

Project changes are reviewed in the 1988 & 1989 annual reports [7].

The work schedule for each of the 4 phases is discussed in separate sections and test matrices are given for each of the 4 areas of work.

4.2 Work Schedule - Phase I

PMMA (acrylic) tube wear data (expressed as mass of material eroded) for the 2' x 2' bed was acquired according to the test matrix shown in Table 4-1. The test matrix consisted of 45 runs covering 3 particle mixes, 3 fluidization velocities (U), 3 static bed heights (BH), and 2 tube bundle heights (TH). The bed material was crushed quartz. Table 4-2 lists the average particle size of the 3 mixtures, together with the measured u_{mf} (minimum fluidization velocity) values. The bed was run for 50 hours for runs #1 through 11 and for 25 hours for runs #12 through 45.

In addition, measurements were taken to determine the local decrease in the wall thickness of tube specimens at intervals of 30 degrees around the periphery of each segment. The weight data was found to be considerably more precise than the thickness data, so the latter was discontinued and only weight data will be reported.

Somewhat more tests were completed than were listed in the proposed work schedule for this phase of the investigation:

4.3 Work Schedule - Phase II

The proposed work schedule for Phase II of the investigation was to perform 10 runs in a 6" x 6" bed with 4 tubes in 1 row, each tube being fabricated from a different material. The tubes were to be eroded by typical fluidized bed combustor bed materials, with the bed operating in slugging mode.

The tests performed for this area of the investigation are shown in Table 4-3. Eleven tests were performed on tubes made from steel, aluminum, PVC and acrylic, using 3 different bed materials (crushed quartz, limestone and a mixture of equal parts limestone and bottom ash) with a range of bed heights. The tests were run for 50 hours with the bed slugging at a frequency of 1 Hz in each test. Wear is reported as mass of material lost. Particle size was measured at the start and end of each test, and is given in Table 4-3. The minimum fluidization velocity (u_{mf}), the superficial velocity at the start of slugging (u_{ms}) and the superficial velocity corresponding to a bed slugging at a frequency of 1 cycle per second (u_{o1s}) are given in Table 4-4 for the 3 mixtures.

4.4 Work Schedule - Phase III

The proposed work schedule for Phase III of the investigation was to develop the Dragometer and collect data on the drag suffered by tubes in the 2' x 2' fluidized bed.

Seventy-two sets of data on the variation in vertical and horizontal

drag over a 10 second period were collected with the Dragometer according to the test matrix shown in Table 4-5. Drag measurements were recorded every 4 microseconds, together with the vertical and horizontal pressure difference. The bed material was crushed quartz with an average particle size of 1642 μm . The bed height was 30 inches and the tube height was 12 inches.

Fast Fourier Transform (FFT) analysis was applied to bubble probe data from the bed, in order to determine dominant bubble frequencies.

4.5 Work Schedule - Phase IV

The proposed work schedule for phase IV of the investigation was the development and calibration of a Heat Flux Gauge and the evaluation of heat transfer coefficients in the 2' x 2' fluidized bed.

The test matrix for this phase of the investigation is shown in Table 4-6, with tests covering 3 different quartz particle mixtures (with average particle size 1354, 1642 and 1776 μm respectively), 3 bed heights, 2 tube heights and 3 superficial fluidization velocities. The heat flux gauge was positioned at each of 4 locations in the bed.

Table 4-1 Test Matrix - Phase I**PMMA Tube Wear In A 2' x 2' Fluidized Bed**

RUN #	Mix #	Bed Height BH, (in.)	Tube Height TH, (in.)	Fluidization Velocity, V, (cm/s)
1	1	18	12	80
2	1	18	12	90
3	1	18	12	85
4	1	30	12	80
5	1	30	12	85
6	1	30	12	90
7	1	42	12	80
8	1	42	12	75
9	1	30	18	80
10	1	30	18	85
11	1	30	18	75
12	1	42	18	75
13	2	30	18	90
14	2	30	18	85
15	2	18	12	85
16	2	18	12	90
17	2	18	12	95
18	2	30	12	85
19	2	30	12	90
20	2	30	12	95
21	2	42	12	85
22	2	42	12	90
23	3	18	12	85
24	3	18	12	90
25	3	18	12	95
26	3	30	12	85
27	3	30	12	90

Table 4-1 (Continued)

Run #	Mix #	Bed Height BH, (in.)	Tube Height TH, (in.)	Fluidization Velocity, V, (cm/s)
28	3	30	12	95
29	3	42	12	85
30	3	42	12	90
31	3	30	18	85
32	3	30	18	90
33	3	30	18	95
34	3	42	18	85
35	3	42	18	90
36	2	30	18	95
37	2	42	18	85
38	2	42	18	90
39	1	42	18	85
40	1	42	18	80
41	1	42	12	85
42	2	42	18	95
43	3	42	18	95
44	3	42	12	95
45	2	42	12	95

Table 4-2 Particle Characteristics - Phase I

Mix #	Average Particle Size, d_p , (μm)	Minimum Fluidization Velocity, U_{mf} , (m/s)
1	1354	0.68
2	1642	0.70
3	1776	0.72

Table 4-3 Test Matrix - Phase II

**Comparative Wear Tests On Steel, Aluminum
PVC And Acrylic Tubes**

Run #	Particle Type	Particle Size (μm)		Bed Height (in.)
		Initial	Final	
1	quartz	1041	835	14
2*	quartz	928	786	20
3	quartz	769	700	20
4	quartz	813	787	20
5	quartz	809	790	28
6	quartz	869	852	28
7	limestone	611	570	14
8	limestone	611	570	20
9	limestone	611	570	28
10	limestone-bottom ash	769	759	14
11	limestone-bottom ash	769	759	20

*Run conditions unstable - test conditions repeated in tests #3 & 4.

Table 4-4 Particle Characteristics (Phase II)

Particle Type	u_{mf} (cm/s)	u_{mf} (cm/s)	u_{mf} (cm/s)
quartz	61.2	77.5	93.8
limestone	76.5	98.2	128.4
limestone-bottom ash	66.0	88.1	108.1

Table 4-5 Test Matrix - Phase III
Dragometer Measurements

Variable	Magnitude (s)
location #	1, 2, 3, 4
distance, in.	3, 7, 11, 13, 17, 21
pressure setting, psi	59, 61, 63

Table 4-6 Test Matrix - Phase IV
Heat Flux Gauge Measurements

Variable	Magnitudes
Particle Mixture #	1, 2, 3
Bed height (inches)	24, 30, 42
Tube height (inches)	12, 18
Superficial velocity (cm/s)	85, 90, 95

*Particle characteristics are listed in Table 4-2.

5. EXPERIMENTAL FACILITIES

5.1 The 2' x 2' Fluidized Bed

5.1.1 Experimental Modifications

The WVU 2' x 2' fluidized bed was modified in 1989 by adding an additional 3 feet in height to the freeboard. The bed is shown in Figure 5-1. The new bed-material injection system had to be elevated for the higher bed and modified to handle larger bed particles. The used bed-material extraction system was similarly modified for the larger bed particles.

The existing heat exchanger tube bundle was modified by raising the tube bundle. As anticipated, the larger particles required a greater tube spacing between the tubes in order to avoid excessive bridging between the tubes. The final tube bundle arrangement is shown in Figure 5-2, together with the nomenclature used in reporting the wear data. The tube material was selected to be PMMA (acrylic) because it is easy to work with and is inexpensive.

The distributor plate proved to be unsatisfactory and was modified. Initially, in an attempt to maintain dimensional similarity with the METC 6' x 6' bed, the plate was formed by drilling a uniform array of holes in a sheet of quarter inch aluminum. The holes were sized to provide a pressure drop of 3 psi across the plate, assuming pressure loss by entry and exit losses only. In order to avoid particles falling through the holes, 8192 holes of 0.030 inch diameter were drilled by CNC mill. Although this provided uniform fluidization during the course of experimental runs, it became locally clogged and this led to nonuniform fluidization.

After several unsuccessful attempts, a design was developed which proved to be satisfactory, in terms of pressure drop, longevity during test runs and symmetrical wear patterns of the tubes. The design is shown in Figure 5-3.

Difficulty was also experienced in the air supply. Because the project moved towards very much larger particles, the air requirements doubled. The high pressure compressor was used to drive an ejector, which increased the available air from 400 cfm at 100 psi to about 1000 cfm at 1.4 psi. In an attempt to augment the air, it was coupled with a low pressure blower system but because of the temperature increase in the air derived from the blower system, the desired bed temperature (40 degrees centigrade) could not be maintained. The test specimens are acrylic and, since their wear is probably sensitive to temperature, it was important to maintain a uniform temperature for the entire test matrix. Accordingly, care was taken to control the pressure drop across the distributor such that the back pressure to the ejector did not become excessive. Ejector discharge was very sensitive to discharge pressure. It was found that if this pressure was kept low enough, the ejector provided sufficient cool air. This is partly by virtue of the fact that the entrained air is at room temperature and suffers very little adiabatic heating. Notwithstanding the successful resolution of this problem, some effort was required in order to maintain an adequate air supply.

5.1.2 Experimental Details

The WVU 2' x 2' fluidized bed shown in Figure 5-1 was used to get wear data on the heat exchanger tubes. Figure 5-2 is a schematic diagram of the bed, showing the arrangement of tubes and the nomenclature used in reporting the wear data. The tubes were numbered from the bottom of the bed upwards, so that the fourth row of tubes was located near the top of the bed and the first row of tubes corresponded to the row nearest the distributor. Tube height (TH) is the distance from the distributor plate to the centerline of the lowest tubes. Bed height (BH) refers to the distance from the distributor plate to the top of the unfluidized bed.

Two opposing walls of the bed were removable Plexiglas panels and the other two walls were metal sheets. The Plexiglas walls contained the supports for the 4 staggered rows of 0.625 inch diameter tubes. These supports were designed so that a dummy tube might replace any tube while the bed was operating and without interrupting the fluidizing process.

The hood of the bed was also constructed of Plexiglas to allow observation of the bubble eruption frequency and distribution and was bolted to a metal frame 44 inches in height. The metal frame was bolted to the bed cavity and housed the 6 inch exhaust duct. The duct led to a filter bag house that was equipped with an induction fan.

5.1.3 System Design

(1) Air-Flow Control

The primary air was supplied as high-pressure house air. The primary air passes through an in-line heater, a thermal inertia cell and then through a control valve, (B), as shown in Figure 5-4. Since the capacity of the house compressor was not large enough for the selected test matrix, an ejector was installed downstream to the control valve. The secondary air was induced through the muffler and venturi tube and into the ejector. The primary and secondary air mix inside the ejector and flow into the plenum chamber. The plenum chamber had an appropriate baffle for distributing the flow into the distributor plate.

The air and any entrained particles left the fluidized bed through a six inch sheet metal duct to a bag house. An induction fan was employed to assist in the air flow. A five foot section of the exhaust pipe was made of polyvinyl chloride (PVC), and contained an orifice plate of 3.5 inches in diameter. The pressure differential across the orifice was monitored through the use of two pressure taps on either side of the orifice that led to a differential pressure transducer. The differential pressure was used in the calculation of the superficial velocity, and the density of the air was determined from the freeboard conditions. The pressure transducer was made by D.J. Instruments, Inc. and its range is -0.5 to +0.5 psi.

(2) Temperature Control

Given that the experimental runs were conducted over periods that included both winter and summer conditions, it was desirable to maintain a constant fluidizing gas temperature. It is not known if changing

temperatures affect the erosion of the tubes but a vigorous temperature control strategy will eliminate this uncertainty in the data. An in-line heater and thermal inertia cell provided the ability to maintain a constant temperature throughout an experimental run. The in-line heater was installed downstream of the main gas manifold and upstream to the thermal inertia cell, as shown in Figure 5-4.

The thermal inertia cell was a 4 inch diameter vertical section downstream to the in-line heater and upstream of the gas control valve, as shown in Figure 5-4. The thermal inertia was provided by a fixed bed of metal filings. The philosophy of the design was that the thermal inertia was sufficient to maintain a temperature throughout the control cycle, whether the heater was on or off for the cycle, and prevents a temperature fluctuation of the air supply to the plenum by not more than one degree.

(3) Inventory Control

The bed material underwent two processes during fluidization which may significantly affect the erosion process. First, elutriation occurred, thus reducing the bed height with time. Second, the bed particles tended to lose their sharp edges and become more rounded with time. Thus it is desirable to maintain a fixed amount of bed material, (mass), in the bed. New bed material should be fed into the bed as old material is withdrawn to maintain the bed height and to maintain particle sharpness. A bed material supply and drain system was installed into the bed system. A feed hopper plumbed with a series of "L-valves" supplies bed material to the bed when the bed pressure falls below a preset threshold. Also, to maintain an average residence time for the bed material, a solids removal system was installed. This system was also plumbed with a series of "L-valves" which drained material from the bed according to a preset time schedule.

5.1.4 Calibration of System

Thermistors and pressure transducers were used to control the superficial air velocity in the bed. The thermistors were calibrated by recording voltage outputs while immersing the thermistors into ice baths and then gradually increasing the water temperature to its boiling point. A relationship between voltage and temperature was derived and used in the control program. Pressure transducers ranging from 0 - 0.5 psi were calibrated with a water manometer by applying a known pressure to the transducers, and recording their corresponding output voltages. Pressure gradients were also derived and incorporated into the control program. The same method was used with pressure transducers from 0 - 5.0 psi and 100 psi transducers except these transducers required a mercury manometer. Flow was calibrated using a standard orifice with a water manometer.

5.1.5 Control System

(1) Introduction

Part of this project's uniqueness was the ability to run the fluidized bed completely unmanned. The bed had been provided with a control system that periodically collected pressure and temperature data from chosen sections of the fluidized bed system, analyzed the data, made control

decisions, and then produced control action. The control system primarily consists of an analog to digital (A/D) board installed in a personal computer. The A/D board received voltage signals from the pressure transducers and thermistors and converted the signals to analog data. A computer program was written to analyze the data, compute a decision based on the analysis and alert the A/D board to send out transistor-transistor logic, (TTL), signals. The signals were received by an electronics board equipped with relay switches that supply the means to make control changes.

(2) Control Variables/Control Program Logic

The controlled variables in this project are the mass flow rate of air into the plenum chamber (superficial velocity of the air), the temperature of the air in the plenum chamber, the solids inventory in the bed, and the average residence time of the bed material. Figure 5-5 shows the location of the instrumentation in the fluidized bed system. Pressure 1, (P1), is the pressure of the primary air supplied to the injector. Pressure 2, (P2), is the differential pressure across the orifice plate in the exhaust line. Pressure 3, (P3), is the pressure in the bed, and Pressure 4, (P4), is the air pressure in the plenum. Temperature 1, (T1), is the temperature of the primary air supplied to the injector and Temperature 2, (T2), is the air temperature in the plenum.

The control program allowed the experimenter to select the desired operating temperature and fluidizing velocity and then monitor pressure and temperature data every one second. Figure 5-6 shows the control program logic. The actual mass flow rate of the air, (superficial velocity), is calculated using P2, a discharge coefficient of 0.62 and the area of the orifice in the exhaust duct. It is then compared to the velocity setpoint. The control program makes mass flow rate adjustments by controlling a motorized valve, (B), in the primary air supply line. The primary air temperature is controlled by an electric heater and a thermal inertia bed. The secondary air temperature is essentially the room temperature in the hot bay of the FRC. The temperature of the combined streams, (T2), is monitored and adjustments of power to the electric heater provides the temperature correction required to maintain the temperature setpoint. The amount of time required for the air temperature to reach the temperature setpoint depends upon the time of year, (winter or summer). The system may require approximately ten minutes to reach the temperature setpoint in the winter.

This fluidized bed system was also designed to eliminate the effects of particle to particle attrition. After prolonged run times the particles may eventually wear off their rough edges and no longer create tube wastage rate. A fresh supply of rough particles from a hopper is added to this bed through a system of "L-valves" and air lines. The bed is also drained periodically through another air line and "L-valve" system.

The bed inventory is controlled by the time averaged bed pressure, (P3), above the distributor plate. This pressure corresponds to the mass of solids in the bed. As the pressure drops due to elutriation and programmed material removal, the computer opens a solenoid valve which supplies air to the "L-valve" system on the hopper, (B), that introduces fresh material to the bed.

In order to maintain a consistent particle size and shape during the long continuous runs, the bed material is to have a prescribed average residence time of 24 hours. The program periodically sends a signal to open another solenoid valve which supplies air to the "L-valves" system on the drain, (C), that removes approximately one-fourth of a cup of material from the bed.

5.1.6 System Performance

The computer-based control system was found to be entirely satisfactory. The control program allows the researcher to select the desired operating temperature and fluidizing velocity for the fluidized bed. The control system monitors the actual operating conditions and makes adjustments in the operating environment to reach the desired conditions. Periodic checks of the fluidized bed system showed that the bed temperature and superficial velocity were maintained to within plus or minus 2% of the setpoint. Visual inspection indicated that the system maintains the bed height and provides a continuous change of bed material. The researcher need only check the system conditions 3-4 times in a 24 hour period.

5.1.7 Measurement Technique

Wear data was recorded in two ways: firstly in terms of mass loss of the tube and secondly in terms of the change in the thickness of the tube wall. For the mass loss wear results, data for a particular run is reported in two ways: firstly as the wear across the tube (i.e. across specified segments of a particular tube) and secondly as the wear down a set of tubes (i.e. down the consecutive tubes in the bed at a particular segment). Each tube was divided uniformly into 12 sections along its length and the sections for which wear was measured were always segments 2, 4, 6, 7, 9, and 11. This recording can be visualized as follows: Consider that an x-axis is laid down in the longitudinal axis of the tubes and a y-axis horizontally and orthogonally. Then the plot along the tubes consists of wear measurements for a particular y value (that of the particular tube) and a varying value of x (along the tube). The plot across the tubes is one for constant x (the value of x at the center of the first segment, say) and varying y (corresponding to different tubes). By rating these 2 cross sections through the wear surface, it is possible to see any wear pattern.

An axial groove was milled on the outer surface of each tube segment to serve as a reference marker in aligning the segments and in placing the tubes into the bed. The tubes were placed in the bed so that the groove was in the 12 o'clock position. All segments were weighed on a Sartorius GMBH (Gottingen, Germany) scale with a 0.10001g resolution.

A fairly limited set of data was collected for wear expressed as change in tube wall thickness, as this was considerably less precise than the mass loss data. The former will not be reported, but may be found in reference 19.

5.2 THE 6" x 6" FLUIDIZED BED

5.2.1 Experimental Details

A 6" x 6" Plexiglas bed was built in order to generate data on the wear of different tube materials. Figure 5-7 is a schematic diagram of the bed. It offers control of a uniform slugging environment in which 4 tubes, 5/8" in diameter, but of different materials can experience the same wear environment.

Steel, aluminum, PVC and acrylic specimens were subjected to wear by crushed quartz particles of different sizes and for different bed depths. In order to standardize the wear conditions, all tests were conducted with the bed slugging with a frequency of 1 cycle per second. The bed material was changed every 50 hours to ensure that it remained essentially the same size from one run to the next (as confirmed by a sieve analysis on material removed from the bed after a 50 hour test run). Wear was reported in terms of the mass of material lost.

Bubble probe data was collected for the 1st 6 test runs and was analyzed using FFT analysis in order to determine dominant bubbling frequencies.

5.3 THE DRAGOMETER

5.3.1 Introduction

A force sensing device called the dragometer was designed and built and used to measure the net force being exerted on a tube in a bubbling fluidized bed. This instrument provides information on the net force being exerted in a fluidized bed on a short length of tubing. The dragometer records two components of force in the two directions orthogonal to the axis (horizontal and vertical) of the tube. Detailed information on the variation of the forces on short sections of tubing will hopefully do much to clarify conjectures as to wear mechanisms. This device can be operated in hot or cold beds and is totally non-intrusive in that it fits in-line, forming part of an existing tube and, therefore, causes no flow field disturbance.

5.3.2 Operating Principle and Test Apparatus

This apparatus consists of a ring of 5/8 inch outer diameter (for a 5/8" tube bundle) which fits onto a central shaft of 1/2 inch outer diameter. A .5 thousandths inch radial clearance exists between the inner diameter of the ring and the outer diameter of the shaft. The shaft has four 1/16 inch ports drilled at 90 degree intervals. These holes are connected in a pneumatic circuit as shown in Figure 5-8. The opposite ports are connected to 2 differential pressure transducers which measure vertical and horizontal force components. The circuit is operated at an upstream pressure of about 50 psia and a downstream pressure of about 17 psia. This ensures a supercritical pressure ratio across the valves. Thus, the mass discharge rate is independent of downstream pressure.

In order for the dragometer to function properly, the valves are adjusted such that the pressure at each of the four ports is equal and the pressure transducers give a zero reading. Thus the hydrodynamics of the system will symmetrically position the sensing ring. Any transverse load on the element will change the flow area available to the ports. As a result, each component of force is reflected as a reading on the appropriate transducer. The quantity of gas escaping from the dragometer into the bed is so small that no disturbance of the bed occurs. This leakage prevents intrusion of particles into the spaces at the ends of the sensing element. The tube can be slid axially, giving a scan of tube loadings along its length thus providing data for any location within the bed.

5.3.3 Design Requirements

The forces that are of interest on a horizontal tube within a fluidized bed are the steady and fluctuating drag forces in the vertical and horizontal directions. The fluctuating forces are caused by the bubble interaction within the bed. The interaction of the immersed tubes and the fluidized bed is the subject of current research for which this force transducer is intended. A transducer was desired that could measure all the local forces experienced by a tube in a fluidized bed. Information establishing transducer design criteria was limited because most tube force measurements had been made with strain-gage force transducers mounted outside the test beds and measuring average force patterns over the entire tube length. However the frequency range for the fluctuations described in the literature were of value in establishing the required dynamics of the dragometer. Also, a transducer was desired with sensing components that were durable enough to withstand the harsh conditions of a fluidized bed perhaps at high temperatures.

The forces of interest are primarily due to interaction between the tubes and bubbles, which occurs at frequencies of about 2-3 Hz (Fan et al, 1981) [82]. However, much smaller forces at higher frequencies exist due to the local bed chaos, but were of less interest in this study. A schematic of the force transducer mounted in-line in the tube is shown in Figure 5-8. As can be seen from the figure, the dragometer control box, containing the sensitive pressure transducers and electrical wiring, can be located outside the bed where bed temperatures and pressures would not effect them adversely. Figure 5-9 shows the dimensions of the sensing element.

5.3.4 Transducer Construction

The internal shaft of the dragometer was chosen to be brass for ease of machinability. The external force sensing ring material was chosen to be aluminum, for lightness and ease of machinability. Both materials are corrosion resistant. In machining the transducer shaft and sensing ring, particular attention was given to obtaining a uniform shaft outer diameter and ring inner diameter necessary in achieving the desired radial clearance. Achieving uniform clearance proved to be very difficult with the available machinery. In all, 14 external sensing rings were made and tested; only three were found to be within the desired clearance range (.0005 in to .00125 in.) and were fairly symmetrical. At clearances lower

than .0005 in., the ring was immobile around the circumference and the asymmetries present dominated. This resulted in signal output noise and produced unreliable readings. At sizes larger than .00125 in., more flow was required to reach the desired operating pressure. As a result, flow restrictions occurred upstream in the internal channels; not at the pressure ports where they should. The radial clearances were measured by placing a digital dial gage against the sensing ring (with the sensing ring on the central shaft), pressing against the sensing ring, and recording the displacement.

Precision was also required in milling and tapping the pressure ports to the desired specifications. Stainless steel tubing (1/16 in.) was silver soldered to the port holes and connected to the pneumatic circuit shown in Figure 5-8. This tubing was originally 12 inches long in the first prototype. It was found that tubing of this diameter and length, produced excessive pressure losses due to friction. As a result, the tubes were shortened and replaced by plastic tubing of greater diameter. It was also discovered that the original prototype was encountering internal restrictions resulting from a mound of solder. All port channels were re-drilled to ensure free air passage. With both of these mechanical problems corrected, the dragometer operated correctly with pressure losses occurring at the ports instead of inside the dragometer or in the tubing.

As can be seen from Figure 5-9, dummy sleeves can be screwed onto the dragometer shaft, butting the sensing ring. Sensing rings with several different axial gaps were investigated on the dragometer and optimized at a value of .006 in. These axial gaps were measured by inserting feeler gages into them. Gaps smaller than about .006 in. were found to restrict the flow through the device. Bed particles sometimes entered the sensing element when rings with gaps in excess of about .006 in. were tested.

The upstream air supply was connected to both the dragometer ports and to the differential pressure transducer (DJ Instruments model MLRA12256) via plastic tubing. Particular care was taken in assuring that no leaks were occurring in the system. All tubing connections and junctions were tested for leaks with a soapy solution each time the system was set up. Pressure transducer output signals passed to an A/D converter (RT1815) using a Zenith ATZ-286 as the host computer. The software program that was developed in Quick Basic version 4.5 and used for this study reads the digital signal from the A/D board and performs the appropriate conversions in calculating the output as a differential pressure.

5.4 THE HEAT FLUX GAUGE

A Heat Flux gauge was designed and built and used to measure the heat transfer coefficients in bubbling fluidized beds. The device is shown in Figure 5-10 and described in reference [7]. The Heat Flux Gauge was calibrated in the 6" x 6" fluidized bed and was then used to collect heat transfer data in the 2' x 2' bed.

**FLUIDIZED BED
FRONT VIEW**

Figure 5-1

Figure 5-2 Tube bundle geometry

Figure 5-3 The distributor plate

Figure 5-4

TEST FACILITY INSTRUMENTATION

Figure 5-5

CONTROL PROGRAM LOGIC

Figure 5-6

Figure 5-7 WVU 6" x 6" fluidized bed

Figure 5-8 Schematic of dragometer circuit and dragometer mounted in-line on the tube

Figure 5-9 Dragometer central shaft

Figure 5-10 The Heat Flux Gauge

6 RESULTS AND DISCUSSION - PHASE I

TUBE WEAR IN A 2' X 2' FLUIDIZED BED

6.1 RESULTS

Tube mass loss measurements are reported in Appendix A (Graphs A-7 through A-366) for the 45 test runs in the 2'x 2' fluidized bed. The average erosion rate recorded for each of the 4 tube rows is given in Table 6-1.

In the tests, the effect on tube wear of superficial velocity, static bed height, tube height and particle mix was investigated. Graphs 6-1 through 6-4 summarise the wear results.

Finally, 3D plots were generated for 5 representative test runs in order to gain insight into the 3 dimensional wear surface occurring in the bed. The plots are given in Graphs 6-5 through 6-9.

TABLE 6-1 RESULTS - PHASE I

RUN #	MIX #	BH (in.)	TH (in.)	U (cm/s)	AVERAGE EROSION RATE ($\mu\text{g/hr}$)			
					ROW 1	ROW 2	ROW 3	ROW 4
1	1	18	12	80	964	828	959	1094
2	1	18	12	90	1783	1424	1696	1781
3	1	18	12	85	1237	1061	1077	956
4	1	30	12	80	575	442	723	1150
5	1	30	12	85	643	493	786	1197
6	1	30	12	90	1029	811	1129	1667
7	1	42	12	80	629	491	760	1262
8	1	42	12	75	264	207	311	500
9	1	30	18	80	1111	1002	1122	1419
10	1	30	18	85	1339	1215	1295	1518
11	1	30	18	75	651	567	715	1050
12	1	42	18	75	550	451	615	837
13	2	30	18	90	1286	1161	1280	1836
14	2	30	18	85	1319	1232	1362	1735
15	2	18	12	85	879	683	864	1019
16	2	18	12	90	876	1047	872	1272
17	2	18	12	95	968	1163	969	1217
18	2	30	12	85	576	706	588	1261
19	2	30	12	90	519	683	569	1239
20	2	30	12	95	925	1130	942	1873
21	2	42	12	85	398	498	415	931
22	2	42	12	90	559	666	555	1205
23	3	18	12	85	910	1140	950	1152
24	3	18	12	90	681	885	737	952
25	3	18	12	95	890	1046	871	1010
26	3	30	12	85	331	405	338	923
27	3	30	12	90	375	513	428	1142
28	3	30	12	95	767	925	770	1558
29	3	42	12	85	257	317	264	647
30	3	42	12	90	285	338	282	649
31	3	30	18	85	661	746	866	1138
32	3	30	18	90	832	927	1018	1307
33	3	30	18	95	866	951	1083	1425
34	3	42	18	85	345	460	647	1060
35	3	42	18	90	634	760	947	1345
36	2	30	18	95	1684	1842	1846	2320
37	2	42	18	85	855	877	1026	1352
38	2	42	18	90	1196	1301	1431	2012
39	1	42	18	85	990	1100	1198	1795
40	1	42	18	80	692	830	838	1193
41	1	42	12	85	493	802	857	1087
42	2	42	18	95	759	857	1025	1590
43	3	42	18	95	1014	1084	1337	2087
44	3	42	12	95	354	443	572	749
45	2	42	12	95	620	773	817	1194

TUBE WEAR RESULTS - 2' X 2' FLUIDIZED BED

Row #	1	2	3	4
Legend	+	Δ	o	+

Graph 6-1 Effect of superficial velocity
for mean conditions (BH = 30"; TH = 12"; Mix # 2)

Graph 6-2 Effect of static bed height
for mean conditions (U = 85 cm/s; TH = 12"; Mix # 2)

TUBE WEAR RESULTS - 2' X 2' FLUIDIZED BED

Graph 6-3 Effect of tube height
for mean conditions ($U = 85$ cm/s; $BH = 30''$; Mix # 2)

Graph 6-4 Effect of particle mix
for mean conditions ($U = 85$ cm/s; $BH = 30''$; $TH = 12''$)

TUBE WEAR RESULTS - 2' X 2' FLUIDIZED BED

Graph 6-5 Run # 2 Row # 4
(Mix # 1; BH = 18"; TH = 12"; U = 90 cm/s)

Graph 6-6 Run # 20 Row # 2
(Mix # 2; BH = 30"; TH = 12"; U = 95 cm/s)

TUBE WEAR RESULTS - 2' X 2' FLUIDIZED BED

Graph 6-7 Run # 26 Row # 4
 (Mix # 3; BH = 30"; TH = 12"; U = 85 cm/s)

Graph 6-8 Run # 32 Row # 2
 (Mix # 3; BH = 30"; TH = 18"; U = 95 cm/s)

TUBE WEAR RESULTS - 2' X 2' FLUIDIZED BED

Graph 6-9 Run # 38 Row # 4
(Mix # 2; BH = 42"; TH = 18"; U = 90 cm/s)

6.2 DISCUSSION

The first observation is that, in the regime of the tests, the higher rows (such as row # 4) show more wear than the lower rows (such as row # 1). Visual inspection of the bubbling of the bed supported this observation. It seemed that the lowest row of tubes initiated bubbling so that there were many bubbles passing through the upper levels of the tube bundle, but considerably fewer being seen by the lowest tubes. Consequently, there was more movement of the dense phase past the upper tubes than the lower tubes and if wear is assumed to be primarily abrasive, then this would be in line with the observation. All of the tests were conducted with the tubes well submerged.

Graph 6-1 shows that wear increases with superficial velocity, as was expected.

Graph 6-2 shows that the bed height has little effect on the tube wear. Thus, for the range of experimental conditions covered in the investigation, the increase in static bed height had no significant effect on the tube wear in any of the 4 rows.

Graph 6-3 shows that an increase in tube height was accompanied by an increase in tube wear. This supports the notion that higher tubes suffer higher abrasion because of increased motion of the dense phase past the tubes.

Graph 6-4 shows that larger particles cause less tube wear than smaller particles, at the same superficial velocity. This was not expected.

Graphs 6-5 through 6-9 show 3D wear surfaces in the 2' x 2' fluidized bed for representative run conditions. The wear surfaces show a region of maximum wear in the central portions of the bed where there is maximum motion of the dense phase.

7 RESULTS AND DISCUSSION - PHASE II

COMPARATIVE WEAR TESTS

7.1 RESULTS

The wear results for the 4 different tube materials are shown in Table 7-1, together with the experimental conditions for the run.

TABLE 7-1 COMPARATIVE WEAR TEST RESULTS

RUN #	PARTICLE TYPE	BH (in.)	CHANGE IN MASS (mg/50 hr)				AVERAGE PARTICLE SIZE (μ m)
			STEEL	ALUM	PVC	ACRYLIC	
1	quartz	14	0.9	0.0	12.9	18.4	938.0
2*	quartz	20	0.0	0.5	5.1	0.2	857.0
3	quartz	20	0.5	0.7	17.2	18.5	734.5
4	quartz	20	0.3	0.7	14.7	16.3	800.0
5	quartz	28	0.6	1.1	0.6	0.4	799.5
6	quartz	28	2.0	0.8	4.5	2.3	858.0
7	limestone	14	0.0	0.0	32.5	26.5	590.5
8	limestone	20	3.6	5.1	7.6	5.5	590.5
9	limestone	28	0.4	1.0	1.2	3.9	590.5
10	limestone-bottom ash	14	0.2	1.8	9.5	4.6	769.0
11	limestone-bottom ash	20	0.7	0.0	8.3	1.2	759.0

* run conditions unstable - test conditions repeated in tests # 3 and 4

Run Conditions

Bubbling frequency: 1 Hz

Run time: 50 hours

Specimen length: 2"

7.2 DISCUSSION

Although the data is somewhat limited, it does show the following trends:

(1) Wear increases with increase in particle size. Thus, the small limestone particles cause relatively little tube wear compared with that caused by the larger quartz particles. Intermediate tube wear is associated with the mixture of limestone and bottom ash, which is intermediate in size between the quartz and the limestone.

(2) The PVC and acrylic tubes suffered the greatest wear in each test, as was expected since these are the softest of the four test materials.

(3) Aluminum tubes suffered slightly higher wear than steel tubes over the test regime, as was expected.

(4) Bed height does not appear to have a significant effect on the tube wear over the test regime.

8 RESULTS AND DISCUSSION - PHASE III

THE DRAGOMETER

8.1 RESULTS

The 2' x 2' fluidized bed was run at one of 3 superficial velocities (85, 90 or 95 cm/s) and the dragometer was used to collect data on the segments of a tube placed at one of 4 locations within the bed. Location # 1 corresponded to the top center tube, location # 2 to the top tube nearest the wall, location # 3 to the bottom center tube and location # 4 to the bottom tube nearest the wall. The conditions for each run are given in Table 8-1. For all test runs, the static bed height and the tube height were set at 30" and 12" respectively. Particle mix # 2 was used as the bed material in all runs.

For each run, the drag on the tube segment (both vertical and horizontal force) and the vertical and horizontal pressure difference across the tube segment were recorded over a period of 10 seconds. The data is stored on disc, under the filenames listed in Table 8-1 and consists of 2520 sets of data of vertical force, horizontal force, vertical pressure difference and horizontal pressure difference. Force is expressed in units of lbf multiplied by 1000 and pressure in units of psi multiplied by 1000. The multiplication factor is used so that the data can be stored as integers, reducing the size of the data file to one quarter of the size which would be required to store the real numbers. The length of the data precludes its listing in the report, but the data files may be readily accessed on the data disc.

TABLE 8-1 RESULTS - PHASE III
DRAGOMETER DATA FILE SPECIFICATIONS

RUN #	DATA FILENAME	TUBE LOCATION	SEGMENT DISTANCE (in.)	U (cm/s)
1	DS1359	1	3	85
2	DS1361	1	3	90
3	DS1363	1	3	95
4	DS1759	1	7	85
5	DS1761	1	7	90
6	DS1763	1	7	95
7	DS11159	1	11	85
8	DS11161	1	11	90
9	DS11163	1	11	95
10	DS11359	1	13	85
11	DS11361	1	13	90
12	DS11363	1	13	95
13	DS11759	1	17	85
14	DS11761	1	17	90
15	DS11763	1	17	95
16	DS12159	1	21	85
17	DS12161	1	21	90
18	DS12163	1	21	95
19	DS2359	2	3	85
20	DS2361	2	3	90
21	DS2363	2	3	95
22	DS2759	2	7	85
23	DS2761	2	7	90
24	DS2763	2	7	95
25	DS21159	2	11	85
26	DS21161	2	11	90
27	DS21163	2	11	95
28	DS21359	2	13	85
29	DS21361	2	13	90
30	DS21363	2	13	95
31	DS21759	2	17	85
32	DS21761	2	17	90
33	DS21763	2	17	95
34	DS22159	2	21	85
35	DS22161	2	21	90
36	DS22163	2	21	95
37	DS3359	3	3	85
38	DS3361	3	3	90
39	DS3363	3	3	95
40	DS3759	3	7	85
41	DS3761	3	7	90
42	DS3763	3	7	95
43	DS31159	3	11	85
44	DS31161	3	11	90
45	DS31163	3	11	95
46	DS31359	3	13	85
47	DS31361	3	13	90

TABLE 8-1 (continued)

RUN #	DATA FILENAME	TUBE LOCATION	SEGMENT DISTANCE (in.)	U (cm/s)
48	DS31363	3	13	95
49	DS31759	3	17	85
50	DS31761	3	17	90
51	DS31763	3	17	95
52	DS32159	3	21	85
53	DS32161	3	21	90
54	DS32163	3	21	95
55	DS4359	4	3	85
56	DS4361	4	3	90
57	DS4363	4	3	95
58	DS4759	4	7	85
59	DS4761	4	7	90
60	DS4763	4	7	95
61	DS41159	4	11	85
62	DS41161	4	11	90
63	DS41163	4	11	95
64	DS41359	4	13	85
65	DS41361	4	13	90
66	DS41363	4	13	95
67	DS41759	4	17	85
68	DS41761	4	17	90
69	DS41763	4	17	95
70	DS42159	4	21	85
71	DS42161	4	21	90
72	DS42163	4	21	95

Graph 8-1 shows a typical plot of the vertical and horizontal force measurements for run # 7 in which the dragometer was placed 11 inches along the tube at location # 1, with a superficial velocity of 85 cm/s.

Graph
Drag force —————
 vertical horizontal

Graph 8-1 Dragometer results - run # 7

9 RESULTS AND DISCUSSION - PHASE IV

HEAT FLUX GAUGE AND BUBBLE PROBE MEASUREMENTS

9.1 HEAT FLUX GAUGE RESULTS

Table 9-1 summarizes the test conditions for which heat flux gauge data was collected in the 2' x 2' fluidized bed.

TABLE 9-1 HEAT FLUX GAUGE TEST CONDITIONS

<u>RUN</u> #	<u>BH</u> (in.)	<u>TH</u> (in.)	<u>U</u> (cm/s)	<u>MIX</u> #	<u>ROW</u> #	<u>TUBE</u> #
1	30	18	85	2	1	1
2	30	18	85	2	1	2
3	30	18	85	2	1	3
4	30	18	85	2	4	1
5	30	18	85	2	4	2
6	30	18	90	1	1	1
7	30	18	90	2	1	1
8	30	18	90	3	1	1
9	30	18	90	1	4	1
10	30	18	90	2	4	1
11	30	18	90	3	4	1
12	30	18	90	2	1	1
13	24	18	90	2	1	1
14	42	18	90	2	1	1
15	30	18	90	2	4	1
16	24	18	90	2	4	1
17	42	18	90	2	4	1
18	30	18	90	2	1	1
19	30	12	90	2	1	1
20	30	18	90	2	4	1
21	30	12	90	2	4	1
22	30	18	85	2	1	1
23	30	18	90	2	1	1
24	30	18	95	2	1	1
25	30	18	85	2	1	2
26	30	18	90	2	1	2
27	30	18	95	2	1	2

Graphs 9-1 through 9-13 show the variation in the average heat transfer coefficient with distance along a tube for the experimental conditions covered in the investigation.

RESULTS - PHASE 1V HEAT TRANSFER COEFFICIENTS

Graph + Δ o
Tube # 1 2 3

Graph 9-1 Effect of tube position for tubes in row 1
(BH = 30"; TH = 18"; U = 85 cm/s; Mix # 2)

Graph 9-2 Effect of tube position for tubes in row 4
(BH = 30"; TH = 18"; U = 85 cm/s; Mix # 2)

RESULTS - PHASE 1V HEAT TRANSFER COEFFICIENTS

Graph Δ + o
Mix # 1 2 3

Graph 9-3 Effect of particle size for tubes in row 1
(BH = 30"; TH = 18"; U = 90 cm/s; Tube # 1)

Graph 9-4 Effect of particle size for tubes in row 4
(BH = 30"; TH = 18"; U = 90 cm/s; Tube # 1)

RESULTS - PHASE 1V
HEAT TRANSFER COEFFICIENTS

Graph 9-5 Effect of bed height for tubes in row 1
 (TH = 18"; U = 90 cm/s; Mix # 2; Tube # 1)

Graph 9-6 Effect of bed height for tubes in row 4
 (TH = 18"; U = 90 cm/s; Mix # 2; Tube # 1)

RESULTS - PHASE 1V HEAT TRANSFER COEFFICIENTS

Graph 9-7 Effect of tube height for tubes in row 1
(BH = 30"; U = 90 cm/s; Mix # 2; Tube # 1)

Graph 9-8 Effect of tube height for tubes in row 4
(BH = 30"; U = 90 cm/s; Mix # 2; Tube # 1)

RESULTS - PHASE 1V
HEAT TRANSFER COEFFICIENTS

Graph 9-9 Effect of superficial velocity for tubes in row 1
(BH = 30"; TH = 18"; Mix # 2; Tube # 1)

Graph 9-10 Effect of superficial velocity for tubes in row 1
(BH = 30"; TH = 18"; Mix # 2; Tube # 2)

RESULTS - PHASE 1V HEAT TRANSFER COEFFICIENTS

Graph 9-11 Effect of superficial velocity for tubes in row 1
(BH = 30"; TH = 18"; Mix # 2; Tube # 3)

Graph 9-12 Effect of superficial velocity for tubes in row 4
(BH = 30"; TH = 18"; Mix # 2; Tube # 1)

RESULTS - PHASE 1V HEAT TRANSFER COEFFICIENTS

Graph
Superficial velocity (cm/s) + Δ ○
85 90 95

Graph 9-13 Effect of superficial velocity for tubes in row 4
(BH = 30"; TH = 18"; Mix # 2; Tube # 2)

9.2 DISCUSSION

The heat transfer coefficient data shows the following trends:

(1) Graphs 9-1 and 9-2 show that the heat transfer coefficient increases with increase in the height of the tube above the distributor plate and, in addition, increases in the central regions of the bed. This reinforces the notion that tubes which are high up in the bed and in the central portion of the bed experience greater movement of dense phase and consequently have higher heat transfer coefficients than tubes which are low down (near the distributor plate) or near the walls of the bed.

(2) The effect of variation in particle size (refer to Graphs 9-3 and 9-4), bed height (refer to Graphs 9-5 and 9-6) and tube height (refer to Graphs 9-7 and 9-8) on tube heat transfer coefficient is not clear from the results, but there is a general observation in these tests that the high, central regions of the bed are associated with higher values of the heat transfer coefficient.

(3) Graphs 9-9 through 9-13 show the effect of superficial velocity on tube heat transfer coefficient. In general, there is an increase in the heat transfer coefficient with increasing superficial velocity, as expected.

9.3 BUBBLE PROBE RESULTS

Bubble probe measurements were made at 6 positions along the length of tube # 1 in row # 1 (nearest the distributor plate) in the 2' square fluidized bed, with the bed operating at the mean conditions (bed height of 30", tube height of 18", superficial velocity of 85 cm/s and mix # 2). For each position, the raw data was subjected to Fast Fourier Transform (FFT) analysis and the results plotted as the variation in Fourier coefficient magnitude and the power spectrum. The results are shown in Graphs 9-14 through 9-19.

Graph 9-14 Bubble probe results - position # 1

(a) Raw data

(b) Fast Fourier Transform

(c) Power spectrum

Graph 9-15 Bubble probe results - position # 2

(a) Raw data

(b) Fast Fourier Transform

(c) Power spectrum

Graph 9-16 Bubble probe results - position # 3

(a) Raw data

(b) Fast Fourier Transform

(c) Power spectrum

Graph 9-17 Bubble probe results - position # 4

(a) Raw data

(b) Fast Fourier Transform

(c) Power spectrum

Graph 9-18 Bubble probe results - position # 5

(a) Raw data

(b) Fast Fourier Transform

(c) Power spectrum

Graph 9-19 Bubble probe results - position # 6

(a) Raw data

(b) Fast Fourier Transform

(c) Power spectrum

9.4 DISCUSSION

Examination of Graphs 9-15 through 9-19 shows that the power spectra for segments near the wall have more high frequency energy than those near the center. The amplitude of the pressure fluctuations shows no strong variation. The conclusion to be drawn is that bubbling is more ordered in the center than at the edges of the bed. This is in line with visual observations of the bed and also with the figures showing the raw data. It might be expected that a more ordered ebb and flow of particles around the tube would produce higher abrasion and this is what is seen at the center of the bed.

10 MODELING TUBE WEAR

10.1 INTRODUCTION

Attempts were made to model the wear of tubes in the 2' x 2' fluidized bed, based on the Flemmer and Johnson model. The first model consisted of a 4-constant model, in which the effects of superficial velocity, minimum fluidization velocity, distance below the free surface, distance above the distributor plate and particle diameter were considered. The second model incorporated Rowe's bubble diameter expression [79] and involved only two empirical constants. Finally, the second model was applied to wear in the first row of tubes alone. The three models are described separately in the following sections.

10.2 ORIGINAL MODEL

The first attempt to model the tube wear in the 2' x 2' fluidized bed followed the Flemmer and Johnson model. In this model, the wear, in $\mu\text{g/hr}$, on any tube was proposed as a function of superficial velocity, minimum fluidization velocity, distance below the free surface, distance above the distributor plate and the particle diameter, according to the expression:

$$\text{Wear} = C_1 (U_0 - U_{mf})^{C_2} * D_{fs}^{C_3} * D_{dp} * d_p^{C_4} \quad (10-1)$$

where U_0 = superficial velocity (m/s)
 U_{mf} = minimum fluidization velocity (m/s)
 D_{fs} = distance below the free surface (m)
 D_{dp} = distance above the distributor plate (m)
 d_p = particle diameter (m)

and C_1 through C_4 are empirical constants.

Contributions to total wear from each size fraction were summed as:

$$\sum_{i=1}^n K_i (d_{p,i})^{C_4}$$

where K_i = percentage of particles in the i th size fraction
 $d_{p,i}$ = diameter of particles in the i th size fraction

Using this model and the data base in the Nelder and Mead simplex technique [80], the values of the four constants were found to be:

$C_1 = 16.2683$
 $C_2 = 0.7510$
 $C_3 = -0.1829$
 $C_4 = -0.8873$

for wear having units of $\mu\text{g/hr}$.

An analysis of this model showed that the data was well fitted. The error fraction was defined as:

$$\text{Error} = \frac{\text{Wear}_{\text{measured}} - \text{Wear}_{\text{predicted}}}{\text{Wear}_{\text{measured}}} \quad (10-2)$$

Graph 10-1 shows the error fraction of the data for each of the 4 rows. The prediction of wear is close to measured wear except in the 4th row, where the wear predictions are somewhat high (leading to a negative error fraction by equation (10-2)).

Graph 10-2 shows the variation in the error fraction with static bed height. The points are reasonably symmetrical about the zero error fraction axis.

Graph 10-3 shows the variation in the error fraction with tube height. The model predictions of wear were close to the experimental wear data for a tube height of 12 inches, but were consistently too high for a tube height of 18 inches.

Graph 10-4 shows the variation in the error fraction with superficial velocity. The symmetrical scatter of the data about the zero error fraction axis indicates that the model predictions of wear were acceptable over the range of superficial velocities covered in the tests.

Graph 10-5 shows the variation in the error fraction with particle mix (i.e. particle size). The wear predictions for mix 1 were somewhat high, but the overall prediction of wear was good.

In general, the fit from the model was good, but the use of four constants seemed excessive. Analysis of the wear data in the 2' x 2' fluidized bed showed a weak correlation between tube wear and the distance below the free surface. This suggests that, in terms of tube wear, there is little difference between a shallow and a deep bed. In addition, the literature [Parkinson] indicates that wear is proportional to $(U_0 - U_{mf})$. For this work, there is little change in U_{mf} , so the precise value of the coefficient, C_2 , would be hard to obtain. Based on these observations, a new model was developed.

FOUR CONSTANT MODEL - ERROR ANALYSIS

Graph	+	Δ	o	+
Row	1	2	3	4

Graph 10-1 Application of 4-constant model to entire data set

FOUR CONSTANT MODEL - ERROR ANALYSIS

Graph 10-2 Error analysis of 4-constant model with variation in bed height

Graph 10-3 Error analysis of 4-constant model with variation in tube height

FOUR CONSTANT MODEL - ERROR ANALYSIS

Graph 10-4 Error analysis of 4-constant model with variation in superficial velocity

Graph 10-5 Error analysis of 4-constant model with variation in particle size

10.3 NEW MODEL

A new model was proposed based on the analysis of the Flemmer and Johnson model. In line with the literature that holds that wear is proportional to $(U_0 - U_{mf})$, the coefficient, C_2 , was set equal to 1. In addition, since the dependance of tube wear on the distance below the free surface was shown to be small, this term was eliminated from the wear expression. Finally, the use of the term reflecting distance above the distributor plate lacked subtlety and was modified as follows. The distance above the distributor plate reflects the degree of bubble activity when seen in conjunction with the term $(U_0 - U_{mf})$ and for the improved model, a correlation for bubble size would be more appropriate. Accordingly, Rowe's bubble diameter expression [79] was used, i.e.:

$$d_b = (U_0 - U_{mf})^{0.5} Z^{0.75} g^{-0.25} \quad (10-3)$$

where d_b is the bubble diameter, Z the height above the distributor plate and g the acceleration due to gravity.

The new model took the form:

$$\text{Wear} = C_1 (U_0 - U_{mf}) d_b d_p$$

Substituting the bubble diameter expression (equation (10-3)) and summing the contributions to wear from each particle size fraction, this reduces to:

$$\text{Wear} = C_1 (U_0 - U_{mf})^{1.5} Z^{0.75} (0.565) \sum_i K_i (d_{pi})^{C_2}$$

with 2 unknown constants. Regression yielded the following values for the constants:

$$\begin{aligned} C_1 &= 6.4371 * 10^{-4} \\ C_2 &= -2.6548 \end{aligned}$$

Thus, the final expression predicting tube wear is:

$$\text{Wear} = 3.637 * 10^{-4} (U_0 - U_{mf})^{1.5} Z^{0.75} \sum_i K_i (d_{pi})^{-2.6548} \quad (10-4)$$

for wear in $\mu\text{g/hr}$, velocity in m/s and Z and particle diameter in meters.

The performance of this model was assessed. Graph 10-6 shows the error fraction for the different rows of the tube bundle. The prediction of tube wear is slightly high for Row 4 (yielding a negative error fraction), but is reasonably symmetrical for the other 3 rows.

Graph 10-7 shows the variation in the error fraction with bed height. The tube wear prediction for the lowest bed height (18 inches) was slightly high, but the overall wear prediction was good.

Graph 10-8 shows the variation in the error fraction with tube height. The tube wear prediction is slightly high for the tube height of 18 inches.

Graph 10-9 shows the variation in the error fraction over a range of five superficial velocities. The scatter of the data about the zero error fraction axis indicates that the wear prediction model is acceptable.

Graph 10-10 shows the variation in the error fraction with particle mix (and hence, particle size). The wear prediction is good for all three particle mixtures.

The significance of the model was analyzed by making excursions from the mean test conditions. The mean conditions corresponded to a bed height of 30 inches, a tube height of 12 inches, a superficial velocity of 0.9 m/s and particle mix # 2. In the analysis of the wear model, one of these conditions was varied, while keeping the others constant. Graph 10-11 shows the predicted wear for three bed heights. The graph shows that for any particular row of tubes in the bed, the predicted wear does not change with bed height. The reason for this is that bed height is not in the model equation (equation (10-4)). In addition, the graph shows that wear increases as the height, Z , above the distributor plate increases, i.e., the tubes in row 4 (at the top of the bed) suffer greater wear than the tubes in row 1 (at the bottom of the bed, nearest the distributor plate). This is expected, since the upper regions of the bed experience greater movement of the dense phase and therefore wear to a greater extent than tubes in the lower regions. The predicted wear behavior shown in Graph 10-11 mirrors the behavior of the experimental data, as shown in Graph 6-2.

Graph 10-12 shows the predicted effect of variation in tube height on wear, while keeping bed height, superficial velocity and particle mix constant. Wear increases with tube height, Z , since the wear model contains the factor $Z^{0.75}$ (see equation 10-4). The same behavior is seen in the experimental data as shown in Graph 6-3.

Graph 10-13 shows the predicted variation in wear with superficial velocity (all other conditions being held constant). The predicted wear increases almost linearly from one row to the next and in all rows increases with increase in superficial velocity because of the term $(U_0 - U_{mf})^{1.5}$ in equation (10-4) (with U_{mf} approximately constant). Once again, the model prediction mirrors the behavior of the experimental data, as shown in Graph 6-1.

Graph 10-14 shows the variation in predicted wear with particle mix (i.e. particle size), while keeping bed height, tube height and superficial velocity constant. The graph shows a sharp increase in wear with decrease in particle size. This supports the fact that the coefficient, C_2 , is negative, implying that larger particles are less abrasive for constant superficial velocity than small particles. This is a contradiction of the established wisdom reported in the literature. For this reason, the data and the regression were scrutinized with some assiduity, but the observation stands. The data base indicates clearly that runs where the mix changes but all other variables are constant show that mix # 3 (corresponding to the largest particle size of the three mixtures which were tested) has less wear than mix # 1 (corresponding to the smallest particle size). However for the case where uniformly-sized large particles are fluidized, larger particles will require a significantly higher superficial velocity than small particles (for comparable fluidization) and this is likely to mask the actual size effect. Further, in unit volume of uniformly sized particles, the number of particles present is proportional to d_p^{-3} . Thus although a single small particle may cause less wear than a single large particle, there are many more small particles than large particles, per unit volume, and consequently, the contribution to wear by small particles is more significant. This is confirmed by the value of the coefficient, C_2 , (which was found to be -2.6548), indicating that a mixture of small particles causes more wear than a mixture of large particles.

TWO-CONSTANT MODEL - ERROR ANALYSIS

Graph	+	Δ	○	+
Row	1	2	3	4

Graph 10-6 Application of 2-constant model to entire data set

TWO-CONSTANT MODEL - ERROR ANALYSIS

Graph	+	Δ	o
Bed height (in.)	18	30	42

Graph 10-7 Error analysis of 2-constant model
with variation in bed height

Graph	+	Δ
Tube height (in.)	12	18

Graph 10-8 Error analysis of 2-constant model
with variation in tube height

TWO-CONSTANT MODEL - ERROR ANALYSIS

Graph 10-9 Error analysis of 2-constant model
with variation in superficial velocity

Graph 10-10 Error analysis of 2-constant model
with variation in particle size

TWO-CONSTANT MODEL - WEAR PREDICTION

Graph 10-11 Two-constant model
Prediction of the effect of bed height

Graph 10-12 Two-constant model
Prediction of the effect of tube height

TWO-CONSTANT MODEL - WEAR PREDICTION

Graph 10-13 Two-constant model
Prediction of the effect of superficial velocity

Graph 10-14 Two-constant model
Prediction of the effect of particle size

10.4 A NEW MODEL FOR ROW 1 ONLY

It was thought that the wear on the bottom row (row 1) was independent of the rest of the tube bundle. Consequently, a model for row 1 alone was developed. The wear was modeled with the same basic equation, i.e.:

$$\text{Wear} = C_1 (U_0 - U_{mf})^{1.5} Z^{0.75} (0.565) \sum_i K_i (d_{pi})^{C_2}$$

The constants were found through regression and had the values:

$$\begin{aligned} C_1 &= 5.7657 * 10^{-3} \\ C_2 &= -2.3434 \end{aligned}$$

Thus, the model predicting the wear in the first row is:

$$\text{Wear} = 3.2575 * 10^{-3} (U_0 - U_{mf})^{1.5} Z^{0.75} \sum_i K_i (d_{pi})^{-2.3434} \quad (10-5)$$

for wear in $\mu\text{g/hr}$.

The error fraction for all the data, covering variation in bed height, tube height, superficial velocity and particle mix, is shown in Graph 10-15. The data points are scattered fairly close to the zero error fraction axis, indicating that the wear predictions using equation (10-5) are fairly good.

In Graph 10-16, the variation in error fraction with bed height is shown. For a bed height of 18 inches, the model predictions of tube wear are consistently too high, leading to a negative error fraction. The wear predictions for bed heights of 30 inches and 40 inches are acceptable.

Graph 10-17 shows the variation in error fraction with tube height. The data lies approximately symmetrically about the zero error fraction axis, indicating acceptable agreement between the measured and predicted tube wear.

Graph 10-18 shows the variation in error fraction with superficial velocity. Once again, there is acceptable agreement between measured and predicted wear for the range of superficial velocities covered in the investigation.

Graph 10-19 shows the variation in the error fraction with particle mix. The prediction of the wear caused by mix # 2 is consistently high (leading to a negative error fraction), but the prediction is acceptable for the other two mixes.

TWO-CONSTANT MODEL FOR ROW 1 ALONE
ERROR ANALYSIS

Graph 10-15 Application of two-constant model for row 1 to the entire data set

TWO-CONSTANT MODEL FOR ROW 1 ALONE
ERROR ANALYSIS

Graph 10-16 Error analysis for two-constant model for row 1 with variation in bed height

Graph 10-17 Error analysis for two-constant model for row 1 with variation in tube height

TWO-CONSTANT MODEL FOR ROW 1 ALONE
ERROR ANALYSIS

Graph 10-18 Error analysis for two-constant model for row 1 with variation in superficial velocity

Graph 10-19 Error analysis for two-constant model for row 1 with variation in particle size

10.5 DISCUSSION

The first model predicting tube wear rate was:

$$\text{Wear} = C_1 (U_0 - U_{mf})^{C_2} * D_{fs}^{C_3} * D_{dp} * d_p^{C_4} \quad (10-6)$$

where U_0 = superficial velocity (m/s)
 U_{mf} = minimum fluidization velocity (m/s)
 D_{fs} = distance below the free surface (m)
 D_{dp} = distance above the distributor plate (m)
 d_p = particle diameter (m)

and C_1 through C_4 are empirical constants with the values:

$$\begin{aligned} C_1 &= 16.2683 \\ C_2 &= 0.7510 \\ C_3 &= -0.1829 \\ C_4 &= -0.8873 \end{aligned}$$

for wear expressed in $\mu\text{g/hr}$. The model had good predictive power for the range of bed heights, tube heights, superficial velocities and particle mixes used in the investigation, but was limited by the excessive number of constants.

Based on the observations that wear is proportional to $(U_0 - U_{mf})$ and that wear is almost independent of distance below the free surface, a second simpler model was formulated. Rowe's bubble diameter expression [equation (10-3)] was incorporated into the model in order to reflect bubble activity in the bed. The new model proposed that tube wear rate (in $\mu\text{g/hr}$) was given by the expression:

$$\text{Wear} = 3.637 * 10^{-4} (U_0 - U_{mf})^{1.5} Z^{0.75} \sum_i K_i (d_{pi})^{-2.6548} \quad (10-7)$$

where Z is the height above the distributor plate (in meters). The model showed good agreement with experimental data over the range of experimental conditions and had the added advantage (over the first model) of greater simplicity.

Finally, it was felt that the first row of tubes (nearest the distributor plate) would see different bed conditions from the rest of the tube bundle. Consequently, a modified form of the second model was used to predict the wear behavior of tubes in the first row alone. The model was expressed as:

$$\text{Wear} = 3.2575 * 10^{-3} (U_0 - U_{mf})^{1.5} Z^{0.75} \sum_i K_i (d_{pi})^{-2.3434} \quad (10-8)$$

for wear in $\mu\text{g/hr}$. The model showed good agreement with the experimental data over the range of experimental conditions.

The models represented by equations (10-7) and (10-8) both indicate that wear is inversely related to particle diameter, so that small particles cause more wear than large particles (all other run conditions remaining constant). At first glance this seemed to be contradictory to the findings in the literature. However, there are many more small particles than large particles per unit volume of bed material which explains why the overall wear arising from a small-particle mixture is greater than that arising from a large-particle mixture.

11 CONCLUSION

The following conclusions were drawn from this investigation:

- 1) Tests in the 2' x 2' fluidized bed showed that there was a sharp increase in wear with decrease in particle size, while keeping bed height, tube height and superficial velocity constant. Thus, larger particles were found to be less abrasive for constant superficial velocity than small particles. This is a contradiction of the established wisdom reported in the literature. However, when uniformly-sized large particles are fluidized, larger particles require a significantly higher superficial velocity than small particles (for comparable fluidization) and this is likely to mask the actual size effect. Further, in unit volume of uniformly sized particles, the number of particles present is proportional to d_p^{-3} . Thus although a single small particle may cause less wear than a single large particle (of identical speed), there are many more small particles than large particles, per unit volume, and consequently, the contribution to wear by small particles is more significant.
- 2) Tube rows positioned high up in the tube bundle showed more wear than tubes lower down in the bundle (i.e. tubes nearest the distributor plate). Visual inspection of the fluidized bed showed that bubbling was initiated at the lower tubes and that the concentration of bubbles increased significantly with distance up the tube bundle. Thus, the higher tubes experienced greater movement of dense phase and, as a consequence, suffered greater abrasive wear than tubes lower down in the tube bundle.
- 3) Tube wear increased with increase in superficial velocity, as expected.
- 4) Bed height had little effect on the tube wear for the range of experimental conditions covered in the investigation.
- 5) The dragometer was built and found to be ideally suited to capturing accurate and detailed information on the drag forces experienced by the tubes in the fluidized bed.
- 6) Heat flux gauge measurements showed that the heat transfer coefficient increased with increasing height above the distributor plate and increased in the central regions of the bed. This reinforces the notion that tubes higher up in the tube bundle and tubes occupying central positions in the tube bundle experience greater movement of dense phase and consequently have higher heat transfer coefficients than tubes low down or in the wall regions of the bed.

7) Tube heat transfer coefficients were found to increase with increase in superficial velocity.

8) Comparative wear tests on tubes of steel, aluminum, PVC and acrylic in a 6" x 6" fluidized bed showed that PVC and acrylic tubes were most susceptible to wear. In addition, aluminum tubes suffered slightly higher wear than steel tubes for the same experimental conditions.

9) Three tube wear models were developed, namely a four-constant model involving superficial velocity, minimum fluidization velocity, distance above the free surface, distance above the distributor plate and particle diameter, a two-constant model incorporating Rowe's bubble diameter expression (equation (10-3)) and a two-constant model of the wear of tubes in the first row (nearest the distributor plate) of the tube bundle. The general two-constant model showed good predictive capabilities and had the added advantage of simplicity, compared with the four-constant model. The model predicted tube wear (in $\mu\text{g/hr}$) as:

$$\text{Wear} = 3.637 \times 10^{-4} (U_0 - U_{mf})^{1.5} Z^{0.75} \sum_i K_i (d_{pi})^{-2.6548}$$

where U_0 is the superficial velocity (in m/s), U_{mf} is the minimum fluidization velocity (in m/s), Z is the height above the distributor plate (in m), K_i is the percentage of particles in the i 'th size fraction and d_{pi} is the particle diameter of the i 'th size fraction. The negative exponent of particle diameter indicates that a mixture of small particles causes more wear than a mixture of large particles, confirming the experimental observations.

REFERENCES AND BIBLIOGRAPHY

- 1) Manaker, A., (Ed.), Proc. 1989 Int. Conf. on Fluidized-Bed Combustion, ASME, New York, NY, (1989).
- 2) Grace, J., Shemilt, L. and Bergougnou, M., (Ed.'s), Fluidization VI, Proc. Int. Conf. on Fluidization, Engg. Foundation, AIChE, NY, NY, (1989).
- 3) Stringer, J., Stallings, J. and Wheeldon, J., "Wastage in Bubbling Fluidized-Bed Combustors: An Update", in Ref. 1.
- 4) Majumdar, S., et al., "A review of solid particle erosion of engineering materials", ANL/FE-88-1, Argonne National Laboratory, Dec., (1987).
- 5) Ninham, A. J., et al., "A laboratory-scale fluidized bed rig for high-temperature tube wastage studies", in Ref. 1.
- 6) MacAdam, S. et al., "A novel laboratory test procedure for studying in-bed erosion-design and some early results", in Ref. 1.
- 7) Johnson, E. K., and Flemmer, R. L. C., "Erosion of heat exchanger tubes", 1988 and 1989 Ann. Rep., WVU/DOE/METC Cooperative Agreement, DE-FC21-87MC24207.
- 8) Holmes, J. et al., "Cold model studies of tube wear in deep fluidized beds", in Ref. 2.
- 9) Zhu, J. et al., "Erosion-causing particle impacts in tubes in fluidized beds", in Ref. 2.
- 10) Tsutsumi, K. et al., "Development of erosion-resistant in-bed tubes", in Ref. 2.
- 11) Rathbone, R. et al., "Measurement of particle velocities and associated stresses on immersed surfaces in fluidized beds", in Ref. 2.
- 12) Levy, E. and Bayat, F., "The bubble coalescence mechanism of tube erosion in fluidized beds", in Ref. 2.
- 13) Birkby, C. and Gibb, J., "Wastage of in-bed surfaces in fluidized-bed combustors", Workshop Proc., Wastage of In-Bed Surfaces in Fluidized-Bed Combustors, EPRI, Nov., (1987).
- 14) Werther, J., et al., "The influence of tube bundles on temperature homogeneity in pressurized fluidized-bed combustion", in Ref. 2.
- 15) Almstedt, A., et al., "An investigation of fluidized bed scaling laws", Report to the IEA Expert Meeting in Basic Research - PFBC, San Francisco, April, (1989).

- 16) Roy, R. and Davidson, J., "Similarity between gas-fluidized beds at elevated temperature and pressure", in Ref. 2.
- 17) Blake, T. R., "Modeling hydrodynamic mixing in process design and development of fluidized bed gasifiers", 9th Ann. Gasification and Gas Stream Cleanup Systems, Contractors Review Meeting, METC Center, DOE, June, (1989).
- 18) Barnes, W., MSME Thesis, West Virginia University, Morgantown, WV, (1989).
- 19) Merrow, C., MSME Thesis, West Virginia University, Morgantown, WV, (1989).
- 20) Drennen, J. et al., "Particle impact velocities and mass flux at fluidized bed tube surfaces in a cold flow model", in Ref. 1.
- 21) Foster Wheeler Inc., Pers. Comm., E. K. Johnson.
- 22) Hanada, T. et al, "Erosion/corrosion behaviors in 50 MW demonstration plant", Workshop Proceedings, EPRI, Argonne, Il., (1987).
- 23) Dennis, R., "Influence of design and operating conditions on the wear of an in-bed horizontal tube bundle", Fluidization VI Conf., Bamf, Canada, May, (1989).
- 24) Dennis, R., Workshop Proceedings, EPRI, Argonne, Il., (1987).
- 25) Glicksman, L. R., Mullens, G. and Yule, T. W., "Tube wear tests in the MIT scaled fluidized beds", EPRI workshop proc., Argonne, Il., (1987).
- 26) Dow, W. M. and Jacob, M., Chem. Eng. Progr., 47, 637, (1951).
- 27) Reboux, P., In "Fluidization", Davidson, J. F. and Harrison, D., Academic Press, London, (1971).
- 28) Richardson, J. F. and Witson, A. E., Trans. Inst. Chem. Eng., 36, 270 (1958).
- 29) Leva, M., in "Fluidization Engineering", Kunii, D. and Levenspiel, O., John Wiley and Sons Inc., New York, (1969).
- 30) Levenspiel, O. and Walton, J. S., Chem. Eng. Prog. Symp. Ser., 50, No. 9, 1, (1954).
- 31) Ruckenstein, E., In "Fluidization", Davidson, J. F. and Harrison, D., Academic Press, London, (1971).

- 32) Van Heerden, C., Nobel, P. and Van Krevelen, D. W., Chem. Eng. Sci., 1, 51, (1951).
- 33) Wicke, E. and Fetting, F., Chem. Eng. Tech., 26, 301, (1954).
- 34) Botterill, J. S. M. and Williams, J. R., "The mechanics of heat transfer to gas fluidized beds", Trans. Inst. Chem. Engrs., Vol. 41, 217, (1963).
- 35) Ziegler, E. M. and Brazelton, W. T., Ind. Eng. Chem. Fund., 3, 94, (1964).
- 36) Botterill, J. S. M., Brundett, G. W., Cain, G. L. and Elliot, D. E., AIChE Symp. Ser., No. 62, 1, (1966).
- 37) Brusenback, R. A., Ph. D. Thesis, Northwestern University, (1963).
- 38) Mickley, H. S. and Fairbanks, D. F., AIChE J., 1, 374, (1955).
- 39) Davidson, J. F. and Harrison, D., "Fluidization", Academic Press, London, (1971).
- 40) Baskakov, A. P., Int. Chem. Eng., 4, 320, (1964).
- 41) Baskakov, A. P., Berg, B. V., Vitt, O. K., Filippovsky, N. F., Kirakosyan, V. A., Goldobin, J. M. and Maskaev, V. K., Powder Tech., 8, 273, (1973).
- 42) Baskakov, A. P. and Suprum, V. M., Int. Chem. Eng., 12, 53, (1972).
- 43) Gorelik, A. G., Jrnl. Eng. Phys., 16, 6, 495, (1967).
- 44) Antonishin, N. V., Simchenko, L. Y. and Gorbackev, L. V., In "Fluidized Bed Combustion", Radovanovic, M., (1986).
- 45) Gelperin, N. I. and Einstein, V. G., in "Fluidization", J. F. Davidson and D. Harrison (Ed.'s), Academic Press, London, (1971).
- 46) Gabor, J. D. and Jakob, M., Chem. Eng. Sci., 25, 979, (1970).
- 47) Yagi, S. and Kunii, D., AIChE Jrnl., 3, 373, (1957).
- 48) Makhorin, K. and Tishchenko, A. T., Tekhika Press. Kiev., USSR, (1966).
- 49) Traber, D. G. etal, Zhurn. Prikl. Khim., 33, 10, (1960).

- 50) Patel, R. D., AEC Res. and Dev. Report # ANL-7353, Nov., (1967).
- 51) Filippovski, N. F. and Baskakov, A. P., Jrnl. Eng. Phys., 22, 2, 159, (1972).
- 52) Botterill, J. S. M. and Denloye, A. O. O., AIChE Symp. Ser., 74, 176, 194, (1978).
- 53) Maskaev, V. K. and Baskakov, A. P., Jrnl. Eng. Phys., 24, 4, 411, (1973).
- 54) Turton, R., Colakyan, M. and Levenspiel, O., Powder Tech., 53, 195, (1987).
- 55) Wright, S. J., Ketley, H. C. and Hickman, R. G., Jrnl. Inst. Fuel, 42, 235, (1969).
- 56) Vreedenberg, H. A., Chem. Eng. Sci., 9, 52, (1958).
- 57) Andeen, B. R. and Glicksman, L. R., ASME-AIChE Heat Transfer Jrnl., St. Louis, (1976).
- 58) Xavier, A. M. and Davidson, J. F., Proc. 2nd Engg. Foundation Conf., Cambridge, U.K., (1978).
- 59) Staub, F. W. et al, Final Report, EPRI, CS-1456, (1980).
- 60) Glicksman, L. R. and Decker, N. A., Proc. 6th Ann. Int. Conf. on Fluidized Bed Combustors, Atlanta, GA, 3, 152, (1980).
- 61) Zabrodsky, S. S., Epanov, G. Y., Galvershtein, D. M., Salena, S. C. and Kolar, A. K., Int. J. Heat and Mass Transfer, 24, 4, 571, (1981).
- 62) Anekwe, C. I., Ph. D. Thesis, West Virginia Univ., (1982).
- 63) Abubaker, M. Y., Tarasuk, J. D., Bergougnou, M. A. and Sullivan, J. L., Proc. 4th Int. Conf. on Fluidization, Japan, (1983).
- 64) Adams, R. L., ASME Jrnl. of Heat Transfer, 106, 85, (1984).
- 65) Adams, R. L. and Welty, J. R., AIChE Jrnl., Vol. 25, No. 3, 395, (1979).
- 66) Adams, R. L., ASME Jrnl. of Heat Transfer, 103, 395, (1981).
- 67) Adams, R. L., ASME Jrnl. of Heat Transfer, 104, 565, (1982).

- 68) Catipovic, N. M., Ph. D. Thesis, Oregon State Univ., Corvallis, Ore., (1979).
- 69) Catipovic, N. M., Fitzgerald, T. J., George, A. H. and Welty, J. R., AIChE Jrnl., 28, 5, 714, (1982).
- 70) Chandran, R., and Chen, J. C., AIChE Jrnl. of Heat Transfer, Vol. 31, No. 2, (1985).
- 71) Chandran, R., Chen, J. C. and Staub, F. W., ASME J. of Heat Transfer, Vol. 102, No. 1, (1980).
- 72) Chandran, R., and Chen, J. C., AIChE Jrnl. of Heat Transfer, Vol. 28, No. 6, (1982).
- 73) Goshayeshi, A., Welty, J. R., Adams, R. L. and Alavizadeh, N., AIChE Symp. Ser., 81, 245, 34, (1985).
- 74) Boroudulya, V. A., and Ganzha, V. L., Int. Jrnl. of Heat and Mass Transfer, 23, 1602, (1980).
- 75) Biyikli, S., Tuzla, K. and Chen, J. C., Powder Tech., 53, 187, (1987).
- 76) Chung, T. Y. and Welty, J. R., AIChE Jrnl., Vol. 35, No. 7, 1170, (1989).
- 77) Renganathan, K. and Turton, R., Proc. 10th Int. Conf. on Fluidized Bed Combustion, San Francisco, 2, 1095, (1989).
- 78) Kunii, D. and Levenspiel, O., "Fluidization Engineering", R. E. Krieger Publishing Co., New York, (1977).
- 79) Rowe, P. N., in "Fluidization", J. F. Davidson and D. Harrison, (Ed.'s), Academic Press, London, (1971).
- 80) Rosenbrock and Story, Computational techniques for chemical engineers", Pergamon Press, New York, (1962).
- 81) Geldart, D., "Gas Fluidization Technology", John Wiley and Sons, Chichester, (1986).

APPENDIX APHASE I - RAW DATA1 PARTICLE CHARACTERISTICS

The size data and minimum fluidization velocity are given in Graphs A-1 through A-6 for the three mixtures of quartz used in the 2' x 2' fluidized bed.

2 TUBE WEAR DATA

The mass loss wear measurements taken for the 45 test runs in the 2' x 2' fluidized bed are given in Graphs A-7 through A-366. The conditions for each run are given in the test matrix for Phase I of the investigation in the main body of the report.

PARTICLE SIZE DATA

Graph A-1 Size distribution - mix # 1

Graph A-2 Size distribution - mix # 2

Graph A-3 Size distribution - mix # 3

PARTICLE FLUIDIZATION CHARACTERISTICS

Graph A-4 Minimum fluidization velocity - mix # 1

Graph A-5 Minimum fluidization velocity - mix # 2

Graph A-6 Minimum fluidization velocity - mix # 3

WEAR DATA - RUN # 1

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-7 Row 1
 Down the tube

Graph A-8 Row 1
 Across the tubes

Graph A-9 Row 2
 Down the tube

Graph A-10 Row 2
 Across the tubes

WEAR DATA - RUN # 1

Tube # 1 2 3 4 5 6
 Legend + Δ ○ † ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ † ▲ ●

Graph A-11 Row 3
Down the tube

Graph A-12 Row 3
Across the tubes

Graph A-13 Row 4
Down the tube

Graph A-14 Row 4
Across the tubes

WEAR DATA - RUN # 2

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-15 Row 1
Down the tube

Graph A-16 Row 1
Across the tubes

Graph A-17 Row 2
Down the tube

Graph A-18 Row 2
Across the tubes

WEAR DATA - RUN # 2

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-19 Row 3
Down the tube

Graph A-20 Row 3
Across the tubes

Graph A-21 Row 4
Down the tube

Graph A-22 Row 4
Across the tubes

WEAR DATA - RUN # 3

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ o

Segment # 2 4 6 7 9 11
 + Δ o + Δ o

Graph A-23 Row 1
 Down the tube

Graph A-24 Row 1
 Across the tubes

Graph A-25 Row 2
 Down the tube

Graph A-26 Row 2
 Across the tubes

WEAR DATA - RUN # 3

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-27 Row 3
Down the tube

Graph A-28 Row 3
Across the tubes

Graph A-29 Row 4
Down the tube

Graph A-30 Row 4
Across the tubes

WEAR DATA - RUN # 4

Tube # 1 2 3 4 5 6
 Legend + Δ o ∇ $\blacktriangle$ $\bullet$

Segment # 2 4 6 7 9 11
 + Δ o ∇ $\blacktriangle$ $\bullet$

Graph A-31 Row 1
Down the tube

Graph A-32 Row 1
Across the tubes

Graph A-33 Row 2
Down the tube

Graph A-34 Row 2
Across the tubes

WEAR DATA - RUN # 4

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-35 Row 3
Down the tube

Graph A-36 Row 3
Across the tubes

Graph A-37 Row 4
Down the tube

Graph A-38 Row 4
Across the tubes

WEAR DATA - RUN # 5

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-39 Row 1
Down the tube

Graph A-40 Row 1
Across the tubes

Graph A-41 Row 2
Down the tube

Graph A-42 Row 2
Across the tubes

WEAR DATA - RUN # 5

Tube # 1 2 3 4 5 6
 Legend + Δ $\circ$ + Δ $\bullet$

Segment # 2 4 6 7 9 11
 + Δ $\circ$ + Δ $\bullet$

Graph A-43 Row 3
Down the tube

Graph A-44 Row 3
Across the tubes

Graph A-45 Row 4
Down the tube

Graph A-46 Row 4
Across the tubes

WEAR DATA - RUN # 6

Tube # 1 2 3 4 5 6
 Legend + Δ $\circ$ ∇ $\blacktriangle$ $\bullet$

Segment # 2 4 6 7 9 11
 + Δ $\circ$ ∇ $\blacktriangle$ $\bullet$

Graph A-47 Row 1
Down the tube

Graph A-48 Row 1
Across the tubes

Graph A-49 Row 2
Down the tube

Graph A-50 Row 2
Across the tubes

WEAR DATA - RUN # 6

Tube # 1 2 3 4 5 6
 Legend + Δ ○ † ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ † ▲ ●

Graph A-51 Row 3
Down the tube

Graph A-52 Row 3
Across the tubes

Graph A-53 Row 4
Down the tube

Graph A-54 Row 4
Across the tubes

WEAR DATA - RUN # 7

Tube # 1 2 3 4 5 6
 Legend + Δ o ∇ $\blacktriangle$ $\bullet$

Segment # 2 4 6 7 9 11
 + Δ o ∇ $\blacktriangle$ $\bullet$

Graph A-55 Row 1
 Down the tube

Graph A-56 Row 1
 Across the tubes

Graph A-57 Row 2
 Down the tube

Graph A-58 Row 2
 Across the tubes

WEAR DATA - RUN # 7

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ •

Segment # 2 4 6 7 9 11
 + Δ o + Δ •

Graph A-59 Row 3
 Down the tube

Graph A-60 Row 3
 Across the tubes

Graph A-61 Row 4
 Down the tube

Graph A-62 Row 4
 Across the tubes

WEAR DATA - RUN # 8

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-63 Row 1
 Down the tube

Graph A-64 Row 1
 Across the tubes

Graph A-65 Row 2
 Down the tube

Graph A-66 Row 2
 Across the tubes

WEAR DATA - RUN # 8

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ •

Segment # 2 4 6 7 9 11
 + Δ o + Δ •

Graph A-67 Row 3
Down the tube

Graph A-68 Row 3
Across the tubes

Graph A-69 Row 4
Down the tube

Graph A-70 Row 4
Across the tubes

WEAR DATA - RUN # 9

Tube # 1 2 3 4 5 6
 Legend + Δ $\circ$ ∇ $\blacktriangle$ $\bullet$

Segment # 2 4 6 7 9 11
 + Δ $\circ$ ∇ $\blacktriangle$ $\bullet$

Graph A-71 Row 1
Down the tube

Graph A-72 Row 1
Across the tubes

Graph A-73 Row 2
Down the tube

Graph A-74 Row 2
Across the tubes

WEAR DATA - RUN # 9

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-75 Row 3
Down the tube

Graph A-76 Row 3
Across the tubes

Graph A-77 Row 4
Down the tube

Graph A-78 Row 4
Across the tubes

WEAR DATA - RUN # 10

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-79 Row 1
 Down the tube

Graph A-80 Row 1
 Across the tubes

Graph A-81 Row 2
 Down the tube

Graph A-82 Row 2
 Across the tubes

WEAR DATA - RUN # 10

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-83 Row 3
Down the tube

Graph A-84 Row 3
Across the tubes

Graph A-85 Row 4
Down the tube

Graph A-86 Row 4
Across the tubes

WEAR DATA - RUN # 11

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-87 Row 1
 Down the tube

Graph A-88 Row 1
 Across the tubes

Graph A-89 Row 2
 Down the tube

Graph A-90 Row 2
 Across the tubes

WEAR DATA - RUN # 11

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-91 Row 3
Down the tube

Graph A-92 Row 3
Across the tubes

Graph A-93 Row 4
Down the tube

Graph A-94 Row 4
Across the tubes

WEAR DATA - RUN # 12

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ •

Segment # 2 4 6 7 9 11
 + Δ o + Δ •

Graph A-95 Row 1
 Down the tube

Graph A-96 Row 1
 Across the tubes

Graph A-97 Row 2
 Down the tube

Graph A-98 Row 2
 Across the tubes

WEAR DATA - RUN # 12

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ ●

Segment # 2 4 6 7 9 11
 + Δ o + Δ ●

Graph A-99 Row 3
Down the tube

Graph A-100 Row 3
Across the tubes

Graph A-101 Row 4
Down the tube

Graph A-102 Row 4
Across the tubes

WEAR DATA - RUN # 13

Tube # 1 2 3 4 5 6
 Legend + Δ $\circ$ ∇ $\blacktriangle$ $\bullet$

Segment # 2 4 6 7 9 11
 + Δ $\circ$ ∇ $\blacktriangle$ $\bullet$

Graph A-103 Row 1
Down the tube

Graph A-104 Row 1
Across the tubes

Graph A-105 Row 2
Down the tube

Graph A-106 Row 2
Across the tubes

WEAR DATA - RUN # 13

Tube # 1 2 3 4 5 6
 Legend + Δ ○ † ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ † ▲ ●

Graph A-107 Row 3
Down the tube

Graph A-108 Row 3
Across the tubes

Graph A-109 Row 4
Down the tube

Graph A-110 Row 4
Across the tubes

WEAR DATA - RUN # 14

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-111 Row 1
 Down the tube

Graph A-112 Row 1
 Across the tubes

Graph A-113 Row 2
 Down the tube

Graph A-114 Row 2
 Across the tubes

WEAR DATA - RUN # 14

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-115 Row 3
Down the tube

Graph A-116 Row 3
Across the tubes

Graph A-117 Row 4
Down the tube

Graph A-118 Row 4
Across the tubes

WEAR DATA - RUN # 15

Tube # 1 2 3 4 5 6
 Legend + Δ o $\dagger$ $\blacktriangle$ $\bullet$

Segment # 2 4 6 7 9 11
 + Δ o $\dagger$ $\blacktriangle$ $\bullet$

Graph A-119 Row 1
 Down the tube

Graph A-120 Row 1
 Across the tubes

Graph A-121 Row 2
 Down the tube

Graph A-122 Row 2
 Across the tubes

WEAR DATA - RUN # 15

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ •

Segment # 2 4 6 7 9 11
 + Δ o + Δ •

Graph A-123 Row 3
 Down the tube

Graph A-124 Row 3
 Across the tubes

Graph A-125 Row 4
 Down the tube

Graph A-126 Row 4
 Across the tubes

WEAR DATA - RUN # 16

Tube # 1 2 3 4 5 6
 Legend + Δ o ∇ $\blacktriangle$ $\bullet$

Segment # 2 4 6 7 9 11
 + Δ o ∇ $\blacktriangle$ $\bullet$

Graph A-127 Row 1
Down the tube

Graph A-128 Row 1
Across the tubes

Graph A-129 Row 2
Down the tube

Graph A-130 Row 2
Across the tubes

WEAR DATA - RUN # 16

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-131 Row 3
Down the tube

Graph A-132 Row 3
Across the tubes

Graph A-133 Row 4
Down the tube

Graph A-134 Row 4
Across the tubes

WEAR DATA - RUN # 17

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-135 Row 1
 Down the tube

Graph A-136 Row 1
 Across the tubes

Graph A-137 Row 2
 Down the tube

Graph A-138 Row 2
 Across the tubes

WEAR DATA - RUN # 17

Tube # 1 2 3 4 5 6
 Legend + Δ ○ † ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ † ▲ ●

Graph A-139 Row 3
 Down the tube

Graph A-140 Row 3
 Across the tubes

Graph A-141 Row 4
 Down the tube

Graph A-142 Row 4
 Across the tubes

WEAR DATA - RUN # 18

Tube # 1 2 3 4 5 6
 Legend + Δ o + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ o + ▲ ●

Graph A-143 Row 1
 Down the tube

Graph A-144 Row 1
 Across the tubes

Graph A-145 Row 2
 Down the tube

Graph A-146 Row 2
 Across the tubes

WEAR DATA - RUN # 18

Tube # 1 2 3 4 5 6
 Legend + Δ ○ † ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ † ▲ ●

Graph A-147 Row 3
 Down the tube

Graph A-148 Row 3
 Across the tubes

Graph A-149 Row 4
 Down the tube

Graph A-150 Row 4
 Across the tubes

WEAR DATA - RUN # 19

Tube #	1	2	3	4	5	6	Segment #	2	4	6	7	9	11
Legend	+	Δ	○	+	▲	●		+	Δ	○	+	▲	●

Graph A-151 Row 1
Down the tube

Graph A-152 Row 1
Across the tubes

Graph A-153 Row 2
Down the tube

Graph A-154 Row 2
Across the tubes

WEAR DATA - RUN # 19

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-155 Row 3
Down the tube

Graph A-156 Row 3
Across the tubes

Graph A-157 Row 4
Down the tube

Graph A-158 Row 4
Across the tubes

WEAR DATA - RUN # 20

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ •

Segment # 2 4 6 7 9 11
 + Δ o + Δ •

Graph A-159 Row 1
Down the tube

Graph A-160 Row 1
Across the tubes

Graph A-161 Row 2
Down the tube

Graph A-162 Row 2
Across the tubes

WEAR DATA - RUN # 20

Tube # 1 2 3 4 5 6
 Legend + Δ ○ † ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ † ▲ ●

Graph A-163 Row 3
Down the tube

Graph A-164 Row 3
Across the tubes

Graph A-165 Row 4
Down the tube

Graph A-166 Row 4
Across the tubes

WEAR DATA - RUN # 21

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ •

Segment # 2 4 6 7 9 11
 + Δ o + Δ •

Graph A-167 Row 1
Down the tube

Graph A-168 Row 1
Across the tubes

Graph A-169 Row 2
Down the tube

Graph A-170 Row 2
Across the tubes

WEAR DATA - RUN # 21

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ ●

Segment # 2 4 6 7 9 11
 + Δ o + Δ ●

Graph A-171 Row 3
Down the tube

Graph A-172 Row 3
Across the tubes

Graph A-173 Row 4
Down the tube

Graph A-174 Row 4
Across the tubes

WEAR DATA - RUN # 22

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ o

Segment # 2 4 6 7 9 11
 + Δ o + Δ o

Graph A-175 Row 1
 Down the tube

Graph A-176 Row 1
 Across the tubes

Graph A-177 Row 2
 Down the tube

Graph A-178 Row 2
 Across the tubes

WEAR DATA - RUN # 22

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ •

Segment # 2 4 6 7 9 11
 + Δ o + Δ •

Graph A-179 Row 3
Down the tube

Graph A-180 Row 3
Across the tubes

Graph A-181 Row 4
Down the tube

Graph A-182 Row 4
Across the tubes

WEAR DATA - RUN # 23

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-183 Row 1
 Down the tube

Graph A-184 Row 1
 Across the tubes

Graph A-185 Row 2
 Down the tube

Graph A-186 Row 2
 Across the tubes

WEAR DATA - RUN # 23

Tube # 1 2 3 4 5 6
 Legend + ▲ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + ▲ ○ + ▲ ●

Graph A-187 Row 3
Down the tube

Graph A-188 Row 3
Across the tubes

Graph A-189 Row 4
Down the tube

Graph A-190 Row 4
Across the tubes

WEAR DATA - RUN # 24

Tube #	1	2	3	4	5	6	Segment #	2	4	6	7	9	11
Legend	+	Δ	○	+	Δ	●		+	Δ	○	+	Δ	●

Graph A-191 Row 1
Down the tube

Graph A-192 Row 1
Across the tubes

Graph A-193 Row 2
Down the tube

Graph A-194 Row 2
Across the tubes

WEAR DATA - RUN # 24

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-195 Row 3
 Down the tube

Graph A-196 Row 3
 Across the tubes

Graph A-197 Row 4
 Down the tube

Graph A-198 Row 4
 Across the tubes

WEAR DATA - RUN # 25

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ •

Segment # 2 4 6 7 9 11
 + Δ o + Δ •

Graph A-199 Row 1
 Down the tube

Graph A-200 Row 1
 Across the tubes

Graph A-201 Row 2
 Down the tube

Graph A-202 Row 2
 Across the tubes

WEAR DATA - RUN # 25

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ ●

Segment # 2 4 6 7 9 11
 + Δ o + Δ ●

Graph A-203 Row 3
Down the tube

Graph A-204 Row 3
Across the tubes

Graph A-205 Row 4
Down the tube

Graph A-206 Row 4
Across the tubes

WEAR DATA - RUN # 26

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ •

Segment # 2 4 6 7 9 11
 + Δ o + Δ •

Graph A-207 Row 1
Down the tube

Graph A-208 Row 1
Across the tubes

Graph A-209 Row 2
Down the tube

Graph A-210 Row 2
Across the tubes

WEAR DATA - RUN # 26

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-211 Row 3
Down the tube

Graph A-212 Row 3
Across the tubes

Graph A-213 Row 4
Down the tube

Graph A-214 Row 4
Across the tubes

WEAR DATA - RUN # 27

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-215 Row 1
 Down the tube

Graph A-216 Row 1
 Across the tubes

Graph A-217 Row 2
 Down the tube

Graph A-218 Row 2
 Across the tubes

WEAR DATA - RUN # 27

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-219 Row 3
Down the tube

Graph A-220 Row 3
Across the tubes

Graph A-221 Row 4
Down the tube

Graph A-222 Row 4
Across the tubes

WEAR DATA - RUN # 28

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ •

Segment # 2 4 6 7 9 11
 + Δ o + Δ •

Graph A-223 Row 1
 Down the tube

Graph A-224 Row 1
 Across the tubes

Graph A-225 Row 2
 Down the tube

Graph A-226 Row 2
 Across the tubes

WEAR DATA - RUN # 28

Tube # 1 2 3 4 5 6
 Legend + Δ $\circ$ + Δ $\bullet$

Segment # 2 4 6 7 9 11
 + Δ $\circ$ + Δ $\bullet$

Graph A-227 Row 3
 Down the tube

Graph A-228 Row 3
 Across the tubes

Graph A-229 Row 4
 Down the tube

Graph A-230 Row 4
 Across the tubes

WEAR DATA - RUN # 29

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ ●

Segment # 2 4 6 7 9 11
 + Δ o + Δ ●

Graph A-231 Row 1
Down the tube

Graph A-232 Row 1
Across the tubes

Graph A-233 Row 2
Down the tube

Graph A-234 Row 2
Across the tubes

WEAR DATA - RUN # 29

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ •

Segment # 2 4 6 7 9 11
 + Δ o + Δ •

Graph A-235 Row 3
 Down the tube

Graph A-236 Row 3
 Across the tubes

Graph A-237 Row 4
 Down the tube

Graph A-238 Row 4
 Across the tubes

WEAR DATA - RUN # 30

Tube # 1 2 3 4 5 6
 Legend + Δ o ∇ $\blacktriangle$ $\bullet$

Segment # 2 4 6 7 9 11
 + Δ o ∇ $\blacktriangle$ o

Graph A-239 Row 1
Down the tube

Graph A-240 Row 1
Across the tubes

Graph A-241 Row 2
Down the tube

Graph A-242 Row 2
Across the tubes

WEAR DATA - RUN # 30

Tube # 1 2 3 4 5 6
 Legend + Δ $\circ$ + Δ $\bullet$

Segment # 2 4 6 7 9 11
 + Δ $\circ$ + Δ $\bullet$

Graph A-243 Row 3
Down the tube

Graph A-244 Row 3
Across the tubes

Graph A-245 Row 4
Down the tube

Graph A-246 Row 4
Across the tubes

WEAR DATA - RUN # 31

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ •

Segment # 2 4 6 7 9 11
 + Δ o + Δ •

Graph A-247 Row 1
Down the tube

Graph A-248 Row 1
Across the tubes

Graph A-249 Row 2
Down the tube

Graph A-250 Row 2
Across the tubes

WEAR DATA - RUN # 31

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-251 Row 3
Down the tube

Graph A-252 Row 3
Across the tubes

Graph A-253 Row 4
Down the tube

Graph A-254 Row 4
Across the tubes

WEAR DATA - RUN # 32

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ •

Segment # 2 4 6 7 9 11
 + Δ o + Δ •

Graph A-255 Row 1
 Down the tube

Graph A-256 Row 1
 Across the tubes

Graph A-257 Row 2
 Down the tube

Graph A-258 Row 2
 Across the tubes

WEAR DATA - RUN # 32

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-259 Row 3
Down the tube

Graph A-260 Row 3
Across the tubes

Graph A-261 Row 4
Down the tube

Graph A-262 Row 4
Across the tubes

WEAR DATA - RUN # 33

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ •

Segment # 2 4 6 7 9 11
 + Δ o + Δ •

Graph A-263 Row 1
 Down the tube

Graph A-264 Row 1
 Across the tubes

Graph A-265 Row 2
 Down the tube

Graph A-266 Row 2
 Across the tubes

WEAR DATA - RUN # 33

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ •

Segment # 2 4 6 7 9 11
 + Δ o + Δ •

Graph A-267 Row 3
 Down the tube

Graph A-268 Row 3
 Across the tubes

Graph A-269 Row 4
 Down the tube

Graph A-270 Row 4
 Across the tubes

WEAR DATA - RUN # 34

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ ●

Segment # 2 4 6 7 9 11
 + Δ o + Δ ●

Graph A-271 Row 1
 Down the tube

Graph A-272 Row 1
 Across the tubes

Graph A-273 Row 2
 Down the tube

Graph A-274 Row 2
 Across the tubes

WEAR DATA - RUN # 34

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-275 Row 3
Down the tube

Graph A-276 Row 3
Across the tubes

Graph A-277 Row 4
Down the tube

Graph A-278 Row 4
Across the tubes

WEAR DATA - RUN # 35

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + Δ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + Δ ●

Graph A-279 Row 1
 Down the tube

Graph A-280 Row 1
 Across the tubes

Graph A-281 Row 2
 Down the tube

Graph A-282 Row 2
 Across the tubes

WEAR DATA - RUN # 35

Tube # 1 2 3 4 5 6
 Legend + Δ o ∇ $\blacktriangle$ $\bullet$

Segment # 2 4 6 7 9 11
 + Δ o + $\blacktriangle$ $\bullet$

Graph A-283 Row 3
Down the tube

Graph A-284 Row 3
Across the tubes

Graph A-285 Row 4
Down the tube

Graph A-286 Row 4
Across the tubes

WEAR DATA - RUN # 36

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + Δ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + Δ ●

Graph A-287 Row 1
 Down the tube

Graph A-288 Row 1
 Across the tubes

Graph A-289 Row 2
 Down the tube

Graph A-290 Row 2
 Across the tubes

WEAR DATA - RUN # 36

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-291 Row 3
 Down the tube

Graph A-292 Row 3
 Across the tubes

Graph A-293 Row 4
 Down the tube

Graph A-294 Row 4
 Across the tubes

WEAR DATA - RUN # 37

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-295 Row 1
 Down the tube

Graph A-296 Row 1
 Across the tubes

Graph A-297 Row 2
 Down the tube

Graph A-298 Row 2
 Across the tubes

WEAR DATA - RUN # 37

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-299 Row 3
 Down the tube

Graph A-300 Row 3
 Across the tubes

Graph A-301 Row 4
 Down the tube

Graph A-302 Row 4
 Across the tubes

WEAR DATA - RUN # 38

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + ▲ ○ + ▲ ●

Graph A-303 Row 1
 Down the tube

Graph A-304 Row 1
 Across the tubes

Graph A-305 Row 2
 Down the tube

Graph A-306 Row 2
 Across the tubes

WEAR DATA - RUN # 38

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ ●

Segment # 2 4 6 7 9 11
 + Δ o + Δ ●

Graph A-307 Row 3
Down the tube

Graph A-308 Row 3
Across the tubes

Graph A-309 Row 4
Down the tube

Graph A-310 Row 4
Across the tubes

WEAR DATA - RUN # 39

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-311 Row 1
Down the tube

Graph A-312 Row 1
Across the tubes

Graph A-313 Row 2
Down the tube

Graph A-314 Row 2
Across the tubes

WEAR DATA - RUN # 39

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ ●

Segment # 2 4 6 7 9 11
 + Δ o + Δ ●

Graph A-315 Row 3
Down the tube

Graph A-316 Row 3
Across the tubes

Graph A-317 Row 4
Down the tube

Graph A-318 Row 4
Across the tubes

WEAR DATA - RUN # 40

Tube # 1 2 3 4 5 6
 Legend + Δ ○ † ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ † ▲ ●

Graph A-319 Row 1
 Down the tube

Graph A-320 Row 1
 Across the tubes

Graph A-321 Row 2
 Down the tube

Graph A-322 Row 2
 Across the tubes

WEAR DATA - RUN # 40

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ •

Segment # 2 4 6 7 9 11
 + Δ o + Δ •

Graph A-323 Row 3
Down the tube

Graph A-324 Row 3
Across the tubes

Graph A-325 Row 4
Down the tube

Graph A-326 Row 4
Across the tubes

WEAR DATA - RUN # 41

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-327 Row 1
 Down the tube

Graph A-328 Row 1
 Across the tubes

Graph A-329 Row 2
 Down the tube

Graph A-330 Row 2
 Across the tubes

WEAR DATA - RUN # 41

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ ●

Segment # 2 4 6 7 9 11
 + Δ o + Δ ●

Graph A-331 Row 3
Down the tube

Graph A-332 Row 3
Across the tubes

Graph A-333 Row 4
Down the tube

Graph A-334 Row 4
Across the tubes

WEAR DATA - RUN # 42

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-335 Row 1
 Down the tube

Graph A-336 Row 1
 Across the tubes

Graph A-337 Row 2
 Down the tube

Graph A-338 Row 2
 Across the tubes

WEAR DATA - RUN # 42

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ o

Segment # 2 4 6 7 9 11
 + Δ o + Δ o

Graph A-339 Row 3
 Down the tube

Graph A-340 Row 3
 Across the tubes

Graph A-341 Row 4
 Down the tube

Graph A-342 Row 4
 Across the tubes

WEAR DATA - RUN # 43

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ •

Segment # 2 4 6 7 9 11
 + Δ o + Δ •

Graph A-343 Row 1
 Down the tube

Graph A-344 Row 1
 Across the tubes

Graph A-345 Row 2
 Down the tube

Graph A-346 Row 2
 Across the tubes

WEAR DATA - RUN # 43

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-347 Row 3
Down the tube

Graph A-348 Row 3
Across the tubes

Graph A-349 Row 4
Down the tube

Graph A-350 Row 4
Across the tubes

WEAR DATA - RUN # 44

Tube # 1 2 3 4 5 6
 Legend + Δ o + Δ ●

Segment # 2 4 6 7 9 11
 + Δ o + Δ ●

Graph A-351 Row 1
Down the tube

Graph A-352 Row 1
Across the tubes

Graph A-353 Row 2
Down the tube

Graph A-354 Row 2
Across the tubes

WEAR DATA - RUN # 44

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-355 Row 3
Down the tube

Graph A-356 Row 3
Across the tubes

Graph A-357 Row 4
Down the tube

Graph A-358 Row 4
Across the tubes

WEAR DATA - RUN # 45

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-359 Row 1
 Down the tube

Graph A-360 Row 1
 Across the tubes

Graph A-361 Row 2
 Down the tube

Graph A-362 Row 2
 Across the tubes

WEAR DATA - RUN # 45

Tube # 1 2 3 4 5 6
 Legend + Δ ○ + ▲ ●

Segment # 2 4 6 7 9 11
 + Δ ○ + ▲ ●

Graph A-363 Row 3
Down the tube

Graph A-364 Row 3
Across the tubes

Graph A-365 Row 4
Down the tube

Graph A-366 Row 4
Across the tubes

END

**DATE
FILMED**

3 / 22 / 93