EGG-NRE--10619

DE93 007052

PRA INSIGHTS
APPLICABLE TO THE DESIGN OF THE BROAD APPLICATIONS TEST REACTOR

Soli T. Khericha and Harry J. Reilly

January 1993

EG&G IDAHO, INC.
IDAHO FALLS, IDAHO 83415

Prepared for the
U.S. Department of Energy
Idaho Operations Office
Under DOE Contract No. DE-AC07-76ID01570

MASTER *ds*
DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

ABSTRACT

Design insights applicable to the design of a new Broad Applications Test Reactor (BATR), being studied at Idaho National Engineering Laboratory, are summarized. Sources of design insights include past probabilistic risk assessments and related studies for Department of Energy-owned Class A reactors and for commercial reactors. The report includes a preliminary risk allocation scheme for the BATR.

CONTENTS

	<u>Page</u>
ACRONYMS	iv
INTRODUCTION	1
APPLICABILITY OF LESSONS LEARNED TO BATR	3
DOE CLASS A REACTOR PRAs	4
COMMERCIAL REACTORS	12
RISK ALLOCATION SCHEMES	20
SUMMARY OF INSIGHTS APPLICABLE TO BATR	27
REFERENCES	30

TABLES

1. Summary of Core Damage Frequency for DOE Reactors	21
--	----

ACRONYMS

ANL	Argonne National Laboratory
ATR	Advanced Test Reactor
ATWS	Anticipated Transient without Scram
BATR	Broad Applications Test Reactor
CCW	Component Cooling Water
CDF	Core Damage Frequency
DOE	Department of Energy
EBR-II	Experimental Breeder Reactor No. II
ECCS	Emergency Core Cooling System
EPRI	Electric Power Research Institute
FIS	Firewater Injection System
HFBR	High Flux Beam Reactor
HFIR	High Flux Isotope Reactor
HRA	Human Response Analysis
HTGR	High Temperature Gas-Cooled Reactor
INEL	Idaho National Engineering Laboratory
LOCA	Loss of Coolant Accident
NPR	New Production Reactor
PCS	Primary Coolant System
PRA	Probabilistic Risk Assessment
SRS	Savannah River Site

PRA INSIGHTS APPLICABLE TO THE DESIGN OF THE BROAD APPLICATIONS TEST REACTOR

INTRODUCTION

Idaho National Engineering Laboratory (INEL) is performing trade-off studies on a new advanced test reactor called the Broad Applications Test Reactor (BATR).¹ The trade-off studies have identified various features that might be incorporated to enhance the safety of BATR operation. The design work is at too preliminary a stage to allow for a complete safety analysis. However, many reactor design insights applicable to BATR may be obtainable from previous probabilistic risk assessments (PRAs) on Department of Energy (DOE)-owned Class A reactors and commercial nuclear power plants. This report summarizes the results of a brief survey of these sources.

The most important insight from the survey is that PRAs performed at appropriate design stages, preferably prior to the final construction stage, can help identify

- sources of risk
- the role of human intervention
- the role of passive systems
- diversification required in redundant systems
- containment type and systems to minimize releases
- test and maintenance schedules
- spatial and functional design dependencies.

It is not possible to discover all problems during the design phase; therefore, the PRA should be updated and reevaluated at every stage of design, construction, and operation.

Design insights presented in this report involve only level 1 PRA considerations; only those design features that reduce the reactor core damage frequency (CDF) are discussed. Levels 2 (severe accident progression and containment response) and 3 (atmospheric dispersion of radionuclides, and public health consequences) are not discussed. It is anticipated that a follow-on to this effort will cover level 2 and 3 design issues.

The first of the following sections describes features of BATR taken into consideration when selecting insights relevant to BATR. Subsequent sections discuss DOE reactor PRAs, commercial nuclear power plant PRAs, and lessons learned from functional dependencies found in commercial plants. The report concludes with a summary of important insights to consider in the design of the BATR.

APPLICABILITY OF LESSONS LEARNED TO BATR

The applicability to BATR of PRA insights from various sources depends somewhat on the specific features of BATR design and operation. Among known features of BATR design and operation are the following:

- BATR will be operated as a government-owned contractor-operated facility, subject to DOE regulations
- BATR will be a relatively low power reactor, perhaps 250 MWth, and will not produce electric power. Reactor heat will be transferred to a secondary system and exhausted to atmosphere using cooling towers. It will probably shut down for fuel and experiment changes about once per month. The reactor core may have a positive void coefficient in the test spaces.

Among leading concepts for the design is one that has aluminum fuel elements, H₂O cooling, and beryllium moderator, with D₂O in a reflector tank surrounding the reactor vessel.

It is obvious when considering these features that not all insights from previous PRAs are applicable to BATR. However, not many of the insights can be screened out on this basis, because PRA insights tend to carry lessons at two levels. One level is the specific finding for the plant analyzed by the PRA. The other level may be regarded as a more general indication that there may be undiscovered problems of similar nature in other designs, and designers of those plants had better consider such findings if problems in future plant operation are to be avoided. One way to look for them is to perform PRA during the design, update it continually or at least periodically at important stages of design and construction, and be aware of all past insights while developing the PRA, to ensure that all weaknesses in design are identified and dealt with appropriately.

DOE CLASS A REACTOR PRAs

Advanced Test Reactor

The Advanced Test Reactor (ATR) PRA is a Level 3 study with external events. The Level 1 PRA has been completed; Levels 2 and 3 of the study are still in progress. Mean core damage frequency (CDF) is estimated to be $4.9\text{E-}5/\text{yr}$ ($2.4\text{E-}5/\text{yr}$ from internal events and $2.5\text{E-}5/\text{yr}$ from external events). For internal events, loss of electric power events are dominant contributors. For external events, seismic events are dominant.

Desirable Features. The ATR PRA indicated the following are desirable features:

- Diverse mechanisms for long-term shutdown
- Natural circulation cooling of the core after shutdown, given a high- or low-pressure relief path
- No dependence on secondary coolant system for decay heat removal
- Passive injection of coolant to reactor vessel after primary coolant system has been depressurized
- Diverse mechanisms for vessel depressurization
- Diverse methods for core heat removal
- Slowly-developing accidents, providing opportunities for operator recovery
- Multiple drain paths for internal flooding events, preventing equipment submergence in vital areas
- Core design that prevents limited core damage events (local blockages, local overpower events, and other local faults) from propagating to the

rest of the core

- A large volume of primary coolant relative to core power
- Avoidance of functional dependencies between emergency diesel generators
- No water system piping in vital electrical areas
- Separation of electrical systems
- Avoidance of coolant downflow through the core during forced circulation, which can result in flow reversal if forced flow is lost and natural circulation must be established
- Avoidance of the potential for some low frequency sequences for which CDF may be as great as the initiating event frequency
- Capability for safe shutdown when offsite ac power is lost helps to reduce the overall CDF.

Additional PRA insights included the following:

- Minor design changes, such as eliminating the possibility of water propagation from the emergency diesel generator pit to the switchgear room, can dramatically reduce the overall CDF
- Common cause failures of redundant components can be dominant contributors to the overall CDF
- With good design practices, risk from internal fire and flooding can be reduced to less than 10% of the overall CDF.

High Flux Isotope Reactor

The High Flux Isotope Reactor (HFIR) PRA is a Level 1 study with external events. A scoping Level 2 and 3 report is planned. Level 1 results

were published in 1988.² The estimated mean CDF is $7.4\text{E-}4/\text{yr}$, with internal events contributing $3.1\text{E-}4/\text{yr}$, and external events $4.3\text{E-}4/\text{yr}$. These results were obtained after design and procedure changes were made to reduce the CDF. Flow blockage and large loss of coolant accident (LOCA) events dominate the CDF for internal events. Dominant external events include wind/tornado and seismic.

Desirable Features. The HFIR PRA indicated the following are desirable features:

- Battery-powered pony motors to provide forced circulation upon loss of ac power
- Passive injection of pool water into vessel through a check valve in case of a loss-of-coolant accident (LOCA)
- Secondary cooling system not needed for decay heat removal
- Core design that prevents limited fuel damage (from localized flow blockages) from propagating to most of the core
- No potential for some low frequency sequences for which CDF may be as great as the initiating event frequency.

Additional PRA insights included the following:

- Refinement of or changes to maintenance and/or shutdown operating procedures can significantly affect the CDF during power operation
- Strong winds, tornadoes, and seismic events, can contribute significantly to facility risk by affecting off-site and on-site emergency power supplies
- Seemingly-minor component features, interconnections, and functional dependencies between systems, can dramatically affect the CDF

- Vessel embrittlement can be of great concern in plants where the vessel is not well shielded from reactor neutrons by shielding or by distance.

High Flux Beam Reactor

The High Flux Beam Reactor (HFBR) PRA is a Level 1 study without external events. The PRA³ is being expanded to include external events and Level 2 and 3 analyses. Mean CDF for internal events is estimated to be $5.0\text{E-}4/\text{yr}$. Loss-of-coolant accidents (LOCAs) and beam tube rupture are dominant contributors. Also, some accidents of these two types are direct damage events, meaning that significant core damage occurs even with successful operation of safety systems. (However, more detailed fracture mechanics and thermal-hydraulic analyses may indicate lower frequencies for such events).

Desirable Features. The HFBR PRA indicated the following are desirable features:

- No primary coolant system (PCS) penetrations of the reactor vessel below the core region
- Dedicated dc-powered pumps for emergency circulation within the PCS
- No requirement for forced flow cooling after a scram and loss of primary coolant pumps
- No major components in the PCS below the reactor vessel, thereby maximizing the amount of primary coolant available for passive cooling
- No potential for low frequency sequences (certain large LOCAs and beam tube ruptures) for which CDF may be as great as the initiating event frequency.

Additional PRA insights included the following:

- Primary pressure boundaries other than the reactor vessel can present

potential LOCA hazards due to radiation embrittlement.

Savannah River Site K-Reactor

The Savannah River Site (SRS) K-Reactor PRA is a Level 3 study with external events. Level 1 results for full-power operation were completed in 1990. Levels 2 and 3 of the study, and a revision of the Level 1 analysis, are still in progress. For full-power operation and with the K-Reactor configuration as it existed in 1987, the mean CDF is estimated to be $3.1\text{E-}4/\text{yr}$. Internal events contribute $2.1\text{E-}4/\text{yr}$, and external events $1.1\text{E-}4/\text{yr}$.

Desirable Features. The PRA indicated the following are desirable features:

- Secondary system that can perform its shutdown cooling function without pumps (gravity-driven flow sufficient to remove decay heat)
- PCS pumps with dc-powered pony motors (with electricity supplied by dedicated diesel generators) to provide flow through the core if the ac pumps fail
- Dedicated diesel generators to provide power to important components if normal off-site power is lost
- Diverse shutdown system that ensures reactor shutdown after a seismic event, and improves overall reliability of shutdown
- No requirement for forced circulation through the core after shutdown
- No susceptibility of essential equipment to internal flooding events
- Material compatibility to prevent chemical attack such as intergranular stress corrosion cracking
- Long operator action time-frames for responding to accidents

- Minimal dependencies between systems and manual actions necessary in accident sequences.

N Reactor

The N Reactor PRA⁴ was prepared after N Reactor was shut down. The reactor differs from others in that it is graphite moderated, with water-cooled fuel in pressure tubes.

A complete Level 3 PRA was prepared to support continued operation of N Reactor. However, this continued operation did not occur; N Reactor is now scheduled for decommissioning. The PRA differed from other PRAs in the treatment of common cause failures. Unlike most PRAs, the PRA did not include a beta-factor, or similar kind of term, for unidentified sources of common cause failure of a component. The only common cause failure events included in the PRA were those that had actually occurred previously at N Reactor, plus those due to modeled common causes: e.g., dependency of two pumps on a common power supply.

Desirable Features. The N Reactor PRA indicated the following are desirable features:

- A type of moderator providing relatively long times for mitigating actions during accident situations
- Avoidance of designs with multiple flow paths, any one of which could rupture and cause fuel damage if the emergency cooling system (ECCS) were to be unavailable
- Provision to ensure redundant capability to close steam generator pressure relief valves after opening
- Avoidance of potential single failure points in support systems such as control and instrument air, which could be eliminated by redundant components

- Avoid inclusion of block valves, in safety system flow paths, operable only during shutdown maintenance.

Additional PRA insights included the following:

- Careful consideration of electrical system actions after loss of offsite power is necessary
- The significance of potential linked initiators must be explored in any new design
- Potential undetectable-and-consequential maintenance errors uncorrectable during operation must be avoided.

Experimental Breeder Reactor II

The Experimental Breeder Reactor-II (EBR-II) is located at INEL and operated by the Argonne National Laboratory (ANL). The EBR-II is a small liquid metal reactor that has been operating more than 25 yrs. ANL recently completed a Level 1 PRA for EBR-II.⁵ The scope of the analysis included determination of CDF from the internal and external event analysis (the seismic PRA is not yet complete).

A passive decay heat removal system is used in the EBR-II design. It is provided with passive redundant decay heat removal capability through both balance-of-plant and through shutdown coolers. These systems do not require electric power to perform their required functions. Therefore, the CDF from internal events, except for anticipated transient without scram (ATWS), is estimated to be less than $1.0\text{E-}6/\text{yr}$. CDF from ATWS events is estimated to be $1.6\text{E-}6/\text{yr}$. Internal fire is the dominant external event, with CDF of $3.6\text{E-}6/\text{yr}$. Overall CDF for EBR-II is estimated to be $5.2\text{E-}6/\text{yr}$ from internal and external events (seismic not included).

Desirable Features. The EBR-II PRA indicated the following are desirable features:

- Pool type reactor (higher coolant to fuel mass ratio)
- Liquid metal coolant (higher heat capacity)
- Multiple passive decay heat removal systems
- No requirement for electric power for short term decay heat removal
- Low sensitivity to human error because of relatively few required operator actions during an accident situation
- ATWS sequences self terminating (reactivity feedback limits temperature excursions)
- No single dominant source or cause of accident sequences
- No dependence on secondary coolant system for heat removal given a scram
- No requirement for long-term decay cooling after scram
- Diverse shutdown system
- No spatial dependencies allowing for liquid metal fires outside the reactor to affect the reactor
- Avoidance of possibility for Na-H₂O violent chemical reactions.

COMMERCIAL REACTORS

PRAs of operating U. S. commercial nuclear power plants are good sources for design insights. Individual PRAs were not examined for this survey; instead, two summary documents were reviewed. The first document - "Lessons Learned From Past PRA Experience for Design Application and Proposed Basis for Probabilistic Targets" - was produced⁶ as part of the New Production Reactor (NPR) program. Also, an Electric Power Research Institute (EPRI) report on functional dependencies was reviewed.⁷ Each of these two documents is summarized herein in following subsections.

NPR Summary of Commercial Reactor PRAs

Reference 6 contains an excellent summary of lessons learned from commercial reactor PRAs. The document was prepared for the NPR program, but most of the lessons are applicable to any reactor. It identified lessons in a number of different categories; for this paper, lessons were selected in four categories:

- why do PRA during BATR design
- how to do PRA during BATR design
- how to use PRA results during BATR design
- specific design insights applicable to BATR.

Selected lessons learned in each of these categories are summarized in following paragraphs.

Why do PRA during BATR design. The principal motivation for doing PRA during BATR design is to ensure the reactor will have an acceptably low risk when operating. However, there are several other important motivations discussed in Ref. 6:

- A convincing demonstration that the design meets the safety goals and

the plant performance objectives can go a long way toward justifying that the design is safe and will meet or exceed current expectations in the commercial reactor industry

- The PRA can ensure the design provides balance in contributions to risk; i.e., that the plant will not be unduly vulnerable to a certain type of accident initiator or scenario
- Performance of PRA during the design can ensure the plant will be compatible with a sound risk management capability when operating. The PRA can highlight the needs for adequate diagnostic instrumentation, and for adequate means for operator actions to mitigate and/or recover from accident scenarios.

There were many examples mentioned in Ref. 6 for the successful use of PRA during reactor design to identify important safety improvements that in many cases also enhanced operations while reducing the expected capital cost. Examples included the high temperature gas reactor (HTGR) and modular HTGR designs, the Combustion Engineering System 80+, and the Darlington station.

It is noteworthy that PRAs have found vulnerabilities at commercial plants even though they were in compliance with existing deterministic criteria. Just a few examples are the building interaction problem at Indian Point II, flooding vulnerability at Oconee, aux-feed reliability issue at Calvert Cliffs, service water/component cooling water vulnerability at Zion, and the emergency diesel generator cooling problem at Haddam Neck.

Findings from human response analyses (HRAs) conducted as part of the PRAs have resulted in many improvements in designs, procedures, and operator training. For example, at Diablo Canyon, operator training was changed as a result of the HRA. At Pennsylvania Power & Light, emergency procedures were developed using HRA results. At other plants, control room layout was changed, labeling of redundant system trains improved, new emergency operating procedures prepared, and operator training focused on important human errors identified by the PRA. Finally, the HRA is a source of information for simulators used in operator training.

How to do PRA during BATR design. Several excellent handbooks exist for performance of PRAs. It is not the purpose of this document to reiterate any of the material in PRA handbooks. However, there are some important lessons highlighted in Ref. 6 that do not appear in handbooks.

One lesson is that the real power of the approach during design is at levels below that of the overall safety goals and objectives; i.e., levels where targets are assigned to safety functions and systems. It is useful to make preliminary PRA goal apportionments for each initiating event and each mitigating system. A numerical reliability requirement can be included in each system design that is subcontracted to outside vendors.

A lesson was drawn that organizations responsible for safety and those responsible for engineering should have strong PRA capabilities.

Ref. 6 noted that the study and elimination of dependencies is crucial to the success of a design. We address this again in the next section, which discusses Ref. 7. Ref. 6 recommended a two-step approach for NPR:

- Use PRA to identify safety components vulnerable to dependent failures
- Use defensive strategies and tactics to eliminate or lessen the susceptibility of any group of particularly vulnerable components.

Ref. 6 identifies important lessons regarding passive safety systems. These are reiterated here because BATR will include passive safety systems:

- Availabilities of passive systems must be determined more rigorously than by assuming the unavailability is negligible.
- Major components of passive safety systems must be assessed using physics-of-failure models
- All potential failure modes of components that could defeat the system function must be identified

- System interfaces must be identified
- A thorough literature search should be conducted to identify any existing reliability models for such equipment.

Finally, an important issue for BATR is that of failure rate data. Generic data will be appropriate for use in estimating many standard component failure rates. However, unique and/or specialized components in BATR design will require careful attention and consideration in determining their failure rate estimates. Potential sources of generic data for BATR must be identified early. Bayesian methods should be considered for combining various sources of generic component failure rate estimates. A comprehensive component reliability data base should be developed, including mean failure rates and their associated probability distributions. Assignments of distributions should be made based on the analysis of available pertinent data rather than on assumption, for example, of log-normality.

How to use PRA results during BATR design. Although the performance of PRA during reactor design is useful, there are a number of cautionary statements in Ref. 6, having to do with interpretation and use of PRA results, that should be observed by BATR designers.

The first caution is that the probabilistic approach has not replaced the deterministic approach in design or regulation, because PRA regulatory guidelines can become problematic when compliance must be demonstrated. For the most part, safety requirements and criteria should continue to be deterministic, although PRA can be a valuable tool in determining the deterministic criteria.

The second general area for caution is that of safety goals for the BATR. Before establishing any quantitative safety goal for the BATR, DOE should give full consideration to why the NRC and ACRS discourage the application of quantitative safety goals to individual plants. The purpose and uses of the safety goals must be clearly understood from the start. Clear definitions are essential when specifying the safety goal and how compliance with it will be demonstrated. Extreme care must be taken when dealing with

multiple quantitative objectives of a safety goal. And in safety goals, uncertainties of PRA results need to be considered to ensure demonstration of meeting the goal.

Finally, it is observed that there is very little experience in the use of safety goals for worker risks.

Specific design insights applicable to BATR. Among specific design insights in Ref. 6, the following seem to be potentially applicable to BATR:

- In the Nuclear Regulatory Commission's NUREG-1150 study, station blackout and small LOCAs were the most significant contributors among all the core melt sequences. Estimated CDF for these plants ranged from about $1E-5$ to $1E-3$ /yr. External event contribution is highly plant specific, but generally such events are significant contributors to CDF. Among the major contributors to CDF were external events (especially seismic, fires, and floods), human errors, dependent failures, test-and-maintenance errors, failure of long-term decay heat removal, small LOCAs and transients, and station blackout. In NUREG-1150, risks were found to be driven by events that cause a multitude of systems to fail rather than failure of just one system
- Accidents initiated during shutdown operations may account for a significant fraction of CDF, because nuclear power plant defense capabilities are typically relaxed and actuation of many safety systems is not automatic when shutdown. Performance of PRA for shutdown is complicated by the numerous plant configurations that can exist during shutdown maintenance. It was observed that loss of residual heat removal capability during shutdown generally has been found to have a high frequency, there is decreased ability to prevent accidental releases to environment due to reduced containment integrity, and increased opportunity for plant incidents as a result of variations in plant configuration for test & maintenance
- Among external events, three events dominate: seismic, fires, and floods. Seismic is especially important. External events generally

contribute 50% or more to risk, and often have large uncertainties in risk

- Dominant seismic sequences usually involve loss of off-site power for those plants that require ac power for core cooling. Fragilities of emergency diesel generators and associated equipment become important. Recent controversies about seismic risk assessment include relay chatter and seismic-induced fires. Critical relays should be designed so they are not susceptible to chatter. Failure of non-seismic equipment may affect equipment that is designed against seismic failure. Support systems for critical functions should be hardened against seismic loads
- Flooding is important in some plants. Inside water sources are usually more important than outside sources. For flooding, hot shorts should be avoided by protecting critical electrical connections that are below grade. Adequate drains should be provided for rooms with critical below-grade equipment
- Regarding fires, control and power cabling to critical equipment should be redundant and separated such that a single fire cannot spread and fail multiple trains. The control room should be designed to reduce the likelihood of destructive fires and the need for evacuation
- Sabotage was a major contributor to risk of a facility in one study that was available to the authors of Ref. 6. It was recommended that protection against both internal and external sabotage threats be incorporated in the early phases of any reactor design
- Precursor studies have identified that frequency estimates for interfacing LOCAs should be increased 2 to 3 orders-of-magnitude over previous PRA studies. Whereas, loss of cooling water related sequences, found important in some PRAs, were not important in precursor studies. Some dependent failures observed in precursor studies were not traditionally modeled in PRAs (e.g., failure of isolation valves between reactor coolant system and ECCS in boiling water reactors)

- There is a significant impact on CDF due to dependencies among systems and human errors. It was observed that, unless supplemented by other defenses, redundancy is not a very effective design strategy. Finally, it was recommended that systems should be considered to have some lower limit of unavailability, since systems are susceptible to common cause failure; for example, the Central Electricity Generating Board Design Safety Guidelines require that the common cause failure probability of a system shall not be assumed to be less than $1E-5/\text{demand}$.

EPRI Study of Functional Dependencies

PRAs of five commercial PWRs were analyzed in reference 7 for functional dependencies among plant systems. The five PRAs were representative of current reactor vendors, nuclear steam supply system vendors, site characteristics, licensing history, PRA teams and PRA modeling techniques. The study was motivated by informal observations by experienced PRA analysts that functional dependencies dominated plant risk in commercial reactor PRAs.

The study confirmed the dominant importance of functional dependencies, especially dependencies on support functions and off-site ac power. The study identified nine principles for defense against functional dependencies, which are reiterated here in total because they are relevant to design of any plant, not excluding BATR:

- Design the plant using materials that withstand reasonably expected variations around potential operating and transient temperatures and pressures
- Design systems for each major safety function (e.g., core cooling, containment heat removal, etc.) with minimal dependence on external support systems. Similarly, design components and equipment so that key support functions are self-contained
- Design so that the same equipment (e.g., component, pipe, etc.) is not used for more than one function, more than one system, or more than one redundant train within a system

- Minimize the use of the same support system (or support system train) for interrelated functions or redundant functions. Do not tie together core cooling and containment heat removal system, for example, by a common support system although each frontline system is redundant
- Enhance diversity of how safety functions are accomplished
- Separate systems used primarily to control normal power production from systems used primarily for safety functions
- Provide a fluid boundary that minimizes vulnerable locations in which water can uncontrollably escape from the reactor coolant system
- Design to take advantage of passive ways to provide safety functions
- Design for inherent safety rather than designing active features to combat inherent weaknesses.

In addition to these principles, the study commented on the effects on PRAs of inadequate knowledge of physical behavior, exemplified by the variations in treatment of reactor coolant pump seal LOCA among the five PRAs. These comments were identified in the report as caveats; however, a further conclusion is drawn herein, that designers must be wary of technical areas in which lack of physical knowledge will lead to great uncertainty in estimating risks of the plant. It will be important to obviate such problems by avoiding them in the design, or by identifying them early and performing appropriate research to reduce the uncertainties.

RISK ALLOCATION SCHEMES

In this section, risks from internal and external events for five DOE water-cooled reactors are evaluated for the purpose of establishing reasonable and achievable risk allocations among different initiating event categories for BATR. Risk allocations are described in terms of maximum allowable CDF, for each category, from both internal and external events. The five DOE reactors were used for risk allocation purposes because commercial power plants are so much larger and use stainless steel or zircaloy clad fuel, compared to the aluminum fuel elements generally used in research reactors. EBR-II was excluded because it is a liquid metal reactor.

The CDFs for each of the major initiating event categories are listed for the five DOE reactors in Table 1. The CDFs vary within every category. For BATR, some of the CDFs will not apply, as per the following discussions.

Internal Events

Internal events consist of LOCA and non-LOCAs. Non-LOCA CDF is dominated by station blackout and anticipated transient event scram (ATWS) events. Station blackout is important because most reactors are dependent on electric power for the core coolant circulation systems. The estimated CDF from complete loss of flow and failure to provide makeup ranges from $3.0\text{E-}6/\text{yr}$ for the ATR to $1.0\text{E-}4/\text{yr}$ for the HFBR. The ATR value is low because it is provided with three diesel generators and one battery-powered emergency pump. Whereas, in the case of HFBR, in certain transients at least three minutes of forced circulation is required after the reactor scram. HFIR has a non-LOCA CDF estimated at $3.9\text{E-}5/\text{yr}$; postulated fuel blockage events unique to HFIR dominate this value.

CDF from ATWS sequences is fairly large, because most research reactors are not provided with the dedicated backup scram system required in commercial plants. CDF from ATWS is $3.5\text{E-}5/\text{yr}$ for HFBR and $2.0\text{E-}5/\text{yr}$ for ATR. Both have slow-acting set-back systems that may require operator actions.

Table 1. Summary of Core Damage Frequency for DOE Reactors

	-----Internal Events-----		-----Seismic-----		-----Internal Fire-----		-----Internal Flood-----		-----Other-----		-----Total-----	
	Non-LOCA	LOCA	LOCA	Total	Seismic	Internal Fire	Internal Flood	Other	Total	Other	Total	Total
ATR	2.3E-5	1.5E-6	2.4E-5	2.4E-5	1.9E-5	1.0E-6	1.0E-5	4.2E-6	2.5E-5	4.2E-6	2.5E-5	4.9E-5
HFBR	1.3E-4	3.8E-4	5.0E-4	5.0E-4	NA	NA	NA	NA	NA	NA	NA	5.0E-4
HFIR	3.9E-5	1.7E-4	2.1E-4	2.1E-4	1.9E-5	8.5E-6	<1.E-6	6.1E-5	8.8E-5	6.1E-5	8.8E-5	3.0E-4
K	3.6E-5	1.7E-4	2.1E-4	2.1E-4	1.1E-4	<1.E-6	<1.E-6	1.1E-4	2.2E-4	1.1E-4	2.2E-4	4.3E-4
N	NA	NA	6.4E-5	6.4E-5	1.7E-4	1.9E-5	NA	NA	1.9E-4	NA	1.9E-4	2.5E-4

NA: data not available

Our judgment is that if a dedicated emergency core cooling system (ECCS), dedicated backup scram system (mechanism that inserts different rods compared to primary scram system to avoid common cause failures), and diverse power system (e.g., battery power operated pump) are included in the BATR design, the CDF from non-LOCA events can be reduced below $5.0\text{E-}6/\text{yr}$.

LOCA is the other major category of internal events. A large LOCA is normally defined as having a break size equivalent to or greater than 6-in. diameter. However, with aluminum fuel, there is a potential of some fuel failure in case of a large LOCA, depending on break location and operating power level. In this type of LOCA the CDF may be as large as the initiating event frequency.

A significant variation exists in large LOCA frequencies in PRAs. The ATR PRA project included a special effort to determine large LOCA frequency. The large LOCA frequency for ATR was estimated using several different techniques. It was estimated that the large LOCA frequency for ATR PCS is less than $1.0\text{E-}6/\text{yr}$. Whereas, at the other extreme, the HFBR PRA estimated a large LOCA frequency $3.0\text{E-}4/\text{yr}$. This number was obtained using the Thomas method,⁸ which is considered to be conservative (high). The HFBR value includes the beam tube rupture event. For the purpose of a sensitivity analysis, the HFBR PRA team looked at the break probabilities used in commercial PRAs for pipe conditions similar to the HFBR primary and shutdown pipes. The component cooling water (CCW) pipes at Zion had specifications comparable to the HFBR specifications. Based on the pipe break frequency for Zion CCW pipes, the HFBR large break LOCA CDF would be smaller; i.e., $3.6\text{E-}5/\text{yr}$.

Large LOCA can cause damage because the pressure-decrease following the break causes boiling of the coolant and eventual fuel failure. For BATR, if some kind of a pressure surge system is included to ensure that pressure does not drop below the saturation point, then this contribution from the large LOCA event will be below the level of concern.

The small break LOCA initiating event frequency used in the ATR PRA is relatively large compared to the small break LOCA frequency used in other

PRAs. However, the CDF contribution from small LOCA in the case of ATR is estimated to be small ($1.5\text{E-}6/\text{yr}$). This is because of the passive low pressure injection system (Firewater Injection System - FIS), which requires no operator actions. An operator can initiate the FIS from the remote control panel located in the control room, in case the FIS fails to actuate due to loss of actuation signal.

For HFBR, the CDF from small LOCA event is estimated to be $7.5\text{E-}5/\text{yr}$. In order to make up the lost inventory, an operator action is required which dominates the sequence. Also, the HFBR requires continuous operation of forced circulation after a reactor scram for some LOCA events.

For K-Reactor, the CDF ($1.7\text{E-}4/\text{yr}$) from the LOCA event is dominated by bellows failure, which is a feature unique to K-Reactor.

It is our judgment that BATR can be designed with a CDF contribution less than $5.0\text{E-}6/\text{yr}$ from the sum of large and small break LOCAs.

External Events

Approximately 30 external events are identified as potential initiators in the PRA guide. Generally, for a given site less than half of these initiators are applicable. Most PRAs show that three events - seismic, internal flooding and fire - are the most significant risk contributors. Seismic is often a large contributor and has a large uncertainty in risk, mainly due to uncertainties in hazard rates.

Some external events are site-specific. Following discusses external events at INEL, which is one of the possible sites for BATR. The ATR PRA evaluated risks from the following external events:

- Internal flood
- Internal fire
- Extreme wind
- External flooding
- Volcanic activity

- Seismic
- Onsite chemical release
- Industrial facility accident
- Transportation accident
- Aircraft impact.

Risks from internal floods and internal fires depend on the spatial dependencies of equipment; e.g., water from the firewater sprinklers falling on the top of vital equipment or the instrumentation bus cabinet, or internal flooding from non-vital or vital systems disabling another vital system by spray or submergence. For most reactors, CDF from internal fire and internal flooding is less than $5.0\text{E-}6/\text{yr}$. The N Reactor PRA CDF from fire sequences ($1.9\text{E-}5/\text{yr}$) is high because of the location of so much equipment in one basement. We conclude that risk from internal fire and internal flooding can be reduced to the ATR value, less than $1.0\text{E-}6/\text{yr}$, by carefully designing BATR component layouts such that spatial interactions will be minimized.

The HFIR PRA reported a significant CDF ($6.1\text{E-}5/\text{yr}$) from extreme wind (tornado). HFIR is located at the Oak Ridge National Laboratory site in Tennessee. High winds and tornados are common in Tennessee. The frequency of straight winds over 100 mph at the INEL site is estimated to be less than $1.0\text{E-}6/\text{yr}$. Therefore, if BATR were to be located at INEL and buildings and facilities are designed to withstand straight wind over 100 mph, CDF from extreme wind would be less than $1.0\text{E-}6/\text{yr}$.

In the case of external flood at the INEL site, only the Mackay dam, located 50 miles upstream of the site on the Big Lost river, poses a threat. Mapping of the probable maximum flood for the INEL site⁹ provides water levels at different locations in the flood zone. The reactor can be located at higher elevation to avoid flooding. Localized flooding due to sudden thaw after heavy snowfall or thunderstorm can be avoided by providing proper drainage. Therefore, CDF from external flooding could be made insignificant for BATR at the INEL site.

Basaltic volcanism is the predominant form of volcanism relevant to the assessment of risk at the INEL site. Again, by locating the reactor at higher

ground level (away from the probable lava flow path) or providing diversion paths for the lava flow, the risk from volcanic activity can be reduced. The probability of volcano eruption (lava flow) at the INEL site is estimated to be less than $1.0\text{E-}5/\text{yr}$.¹⁰ The ATR PRA estimated an insignificant contribution from volcanism, and that appears to be possible for BATR as well. At some other sites, volcanism would not be an important external event.

The seismic CDF for DOE reactors varies from $2.0\text{E-}4$ to $2.0\text{E-}5/\text{yr}$. The differences are mainly due to differences in the hazard rates. A high CDF from seismic event is usually due to unsupported block walls, unanchored or marginally anchored control cabinets and equipment, and lack of seismically qualified diverse power system. Loss of off-site power is normally expected in case of seismic event; therefore, an emergency power system is vital. In many instances, operator action is required outside the control room. This may not be feasible during a seismic event.

It is very difficult to design the plant to withstand a higher magnitude acceleration without excessive cost. However, if the plant is designed to

- cooldown without electric power
- minimize operator actions, particularly those out of the control room
- reduce spatial interaction between equipments, and
- have seismically qualified diverse power systems,

then it is our judgment the risk from a seismic event can be reduced to less than $5.0\text{E-}6/\text{yr}$ for BATR.

CDFs from onsite chemical release, industrial facility accident, transportation accident, and aircraft impact were estimated to be less than $1.0\text{E-}6/\text{yr}$ for all PRAs.

Assuming an iterative process is established between the PRA and the design process, following CDFs are reasonable preliminary risk allocations among initiator types for BATR. (The values for external events might be somewhat dependent on the specific site).

<u>Initiator type</u>	<u>CDF/yr</u>
Internal events	
LOCA	<5.0E-6
Transients	<5.0E-6
External events	
Seismic	<5.0E-6
Internal fire	<1.0E-6
Internal flood	<1.0E-6
External flood	<1.0E-6
Volcanism	<1.0E-6
Others	<u><1.0E-6</u>
Total	<<2.0E-5

SUMMARY OF INSIGHTS APPLICABLE TO BATR

This report describes many insights from PRAs of DOE reactors. The insights apply to the specific reactors that were subjects of the PRAs; however, the lessons learned can be applied in the design of future reactors. Of the many insights, the most pertinent to BATR are the following:

- The design should include a diverse shutdown system
- The design should allow, if possible, for residual heat removal by natural circulation in both the primary and secondary systems
- ECCS injection should be by passive means
- If depressurization is required for ECCS injection or makeup, diverse means should exist for depressurization
- The design should allow ample time for operator actions during accident sequences
- Primary flow should be up through the core rather than down
- Means should be provided to obviate certain large LOCAs
- No vessel penetrations should be allowed below the top of the core
- Neutron flux on the vessel and other primary system boundaries should be low enough to obviate concerns about LOCAs due to radiation embrittlement
- Primary pump motors should have battery-powered dc pony motor backups if forced cooling is required for an interval after shutdown
- The reactor should shut down and cool safely without offsite ac power
- PRA should be performed during design

- PRA analysts should watch for dependencies of safety systems on other systems, and for common cause failures
- PRA analysts should watch for linked initiators
- Shutdown operations can contribute significantly to the risk
- Sabotage can contribute significantly to the risk
- PRA analysts should ensure that designers obtain sufficient knowledge of physical phenomena to support the safety analysis
- External events, especially seismic, fires and internally-caused flooding, can be important. For example, if sited at INEL, designers would have to consider the potential for Mackay dam failure and for volcanism
- PRA analysts and designers should be careful in specifying safety goals and the method of demonstrating compliance

Besides specific insights like these, there is a lesson of a different kind: it can be expected that a PRA will be required for any new reactor and its results compared to a safety goal. Prudent design practice dictates that the design be tested periodically during its development by performing and iterating a PRA for the design while it is being designed. Only in this manner can the eventual success of the post-design PRA be assured.

Finally, the following appear to be reasonable risk allocations among initiator types:

<u>Initiator type</u>	<u>CDF (/yr)</u>
Internal events	
LOCA	<5.0E-6
Transients	<5.0E-6
External events	
Seismic	<5.0E-6

	Internal fire	<1.0E-6
	Internal flood	<1.0E-6
	External flood	<1.0E-6
	Volcanism	<1.0E-6
	Others	<u><1.0E-6</u>
Total		<<2.0E-5

REFERENCES

1. J. M. Ryskamp et al., Safety Requirements, Facility User Needs, and Reactor Concepts for a New Broad Application Test Reactor, EG&G Idaho, Inc., EGG-NRRT-10332, July 1992.
2. D. H. Johnson et al., The High Flux Isotope Reactor Probabilistic Risk Assessment, Oak Ridge National Laboratory, ORNL/RRD/INT-36, 1988.
3. M. A. Azarm et al., Level 1 Internal Event PRA for the High Flux Beam Reactor, Brookhaven National Laboratory, Revision 1, July 1990.
4. M. D. Zentner et al., N Reactor Level 1 Probabilistic Risk Assessment: Final Report, Westinghouse Hanford Company, WHC-EP-0322, Revision 0, May 1990.
5. D. J. Hill, W. A. Ragland and J. Roglans, The EBR-II Probabilistic Risk Assessment: Results and Insights, American Nuclear Society International Topical Meeting, Clearwater Beach, Florida, January 27-29, 1993 (to be published).
6. SCIENTECH, Inc., Lessons Learned From Past PRA Experience for Design Application and Proposed Basis for Probabilistic Targets, Revision 2, Safety Division, Office of Safety and Quality, Office of New Production Reactors, Department of Energy, January 1991.
7. M. V. Frank and K. N. Fleming, Risk-Significant Functional Dependencies in PWRs, EPRI NP-5536, December 1987.
8. H. M. Thomas, "Pipe and Vessel Failure Probability," Reliability Engineering, 2, 1981, pp. 83-124.
9. K. N. Koslow and D. H. Van Haaften, Flood Routing Analysis for a Failure of Mackay Dam, EG&G Idaho, Inc., EGG-EP-7184, June 1986.
10. "Assessment of Potential Volcanic Hazards for New Production Reactor Site at the Idaho National Engineering Laboratory." Lawrence Livermore National Laboratory, UCRL-ID-104722, October 1990.

END

DATE
FILMED

5 / 10 / 93