Estimating the Market Penetration of Residential Cool Storage Technology Using Economic Cost Modeling

**R. O. Weijs
D. R. Brown**

September 1988

**Prepared for the U.S. Department of Energy
under Contract DE-AC06-76RLO 1830**

**Pacific Northwest Laboratory
Operated for the U.S. Department of Energy
by Battelle Memorial Institute**

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor Battelle Memorial Institute, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or Battelle Memorial Institute. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

PACIFIC NORTHWEST LABORATORY
operated by
BATTELLE MEMORIAL INSTITUTE
for the
UNITED STATES DEPARTMENT OF ENERGY
under Contract DE-AC06-76RLO 1830

Printed in the United States of America
Available from
National Technical Information Service
United States Department of Commerce
5285 Port Royal Road
Springfield, Virginia 22161

NTIS Price Codes
Microfiche A01

Printed Copy

Pages	Price Codes
001-025	A02
026-050	A03
051-075	A04
076-100	A05
101-125	A06
126-150	A07
151-175	A08
176-200	A09
201-225	A10
226-250	A11
251-275	A12
276-300	A13

ESTIMATING THE MARKET PENETRATION
OF RESIDENTIAL COOL STORAGE TECHNOLOGY
USING ECONOMIC COST MODELING

R. O. Weijo
D. R. Brown

September 1988

Prepared for
the U.S. Department of Energy
under Contract DE-AC06-76RL0 1830

Pacific Northwest Laboratory
Richland, Washington 99352

SUMMARY

This study estimated the market penetration for residential cool storage technology by using economic cost modeling. Residential cool storage units produce and store chill during off-peak periods of the day to be used during times of peak electric power needs. The report provides projections of unit sales expected in 5-year intervals for the years 1995, 2000, 2005, and 2010. Such projections help to determine the maximum amount of energy that could be displaced by this technology in the future.

In estimating market potential, it is found that shortfalls in electricity production during summer peak hours will occur first in the Mid-Atlantic and Central regions of the U.S., though nearly all of the country is expected to experience peak-period shortfalls by the year 2000. Thus, the market for cool storage technology is projected to be identical with that for central air conditioning. Of the two major submarkets (new homes and existing homes), the market for new units is greatest in the Southern and least in the Northern regions, averaging to 70% of all new homes in the nation. Retrofits to central air conditioning in existing homes were found to be necessary every 15 years. Thus, one-fifteenth of the existing housing market with central air conditioning was considered the potential market for residential cool storage technology in any given year. Regression analysis was used to project the total size of the existing housing market in each of the four target years (1995, 2000, 2005, 2010) and the probable average number of housing starts for each year. The study estimates a potential annual market for cool storage systems in existing homes to be approximately as follows:

1995	1,400,000 units
2000	1,500,000 units
2005	1,590,000 units
2010	1,680,000 units.

It is estimated that 1.5-million new houses will be constructed each year (based on average numbers of housing starts for the past 5 to 10 years), of which 62% will be single-family dwellings. Of these, approximately 70% will

install central air conditioning, or 650,000 houses per year. Thus, the potential annual market for residential cool storage technology for the four target years is as follows:

1995	2,050,000 units
2000	2,150,000 units
2005	2,240,000 units
2010	2,330,000 units.

This study also found that price incentives offered to households must be varied dramatically by region for residential cool storage systems to be economically competitive relative to conventional systems. Under the most likely scenario, this analysis estimated that residential cool storage units will eventually capture about one-half of the central air conditioning (A/C) market. To compare the two technologies, a base-case home was hypothesized. Assuming a \$2000 first-cost price differential for residential cool storage systems, a time-of-day (TOD) rate differential of approximately \$0.075/kWh would be required at 2000 cooling-degree-days (65-degree base) to allow residential cool storage technology to economically compete with central air conditioning. At 1000 cooling-degree-days, a TOD rate differential of approximately \$0.15/kWh would be required. Residential cool storage systems are not economically competitive at 500 cooling-degree-days or less. Very extreme price incentives would have to be offered to make these systems economically competitive in these climates. In the base case, a \$0.20/kWh TOD price differential and a \$1000 price rebate would be required.

An economic cost model determined that market penetration will vary significantly depending on the price incentives offered by the utilities. Using a \$0.10/kWh TOD rate differential to derive an estimate of eventual market penetration, it was estimated that residential cool storage units will eventually penetrate about one-half of the central air conditioning market. This study also specified the capital cost requirements for different peak-period lengths and for peak-shifting and peak-leveling load management strategies to achieve this same level of long-term market penetration.

Assuming a product introduction in 1990, the annual estimated unit sales for cool storage systems are as follows:

1995	60,000 units
2000	150,000 units
2005	300,000 units
2010	500,000 units.

If it is assumed that 2.5 kW of diversified demand are saved by cool storage per household, the estimated peak electricity savings achieved from this technology in 1995, 2000, 2005, and 2010 are approximately 0.6, 1.9, 4.7, and 9.9 GWs per year, respectively. The largest markets for this technology include Texas, Florida, Georgia, Louisiana, North Carolina, and Oklahoma.

Residential cool storage equipment can be designed to perform either load-shifting or load-leveling load management. This study evaluated capital cost requirements for different peak period lengths and for load-shifting and load-leveling strategies to assist identification of optimum equipment configurations. This study found that incremental capital cost requirements for equipment designed to serve either 6-, 9-, or 12-hour peak periods under either load-shifting or load-leveling load management strategies varied dramatically. As an example, equipment designed for load-leveling for a 9-hour time period has an incremental capital cost requirement of \$851 over a conventional central air conditioning system. This compares to the \$2000 capital cost requirement established for the base case scenario (load-shifting for a 12-hour peak period).

This study also evaluated the effect of capital cost reductions on national electricity displacement by the year 2010 for 6-, 9-, and 12-hour load-leveling and load-shifting strategies. This study found that residential cool storage equipment could displace between 5 and 10 gigawatts of electricity by the year 2010. Each capital cost reduction of \$500 will provide an additional 1 gigawatt of electricity displacement by the year 2010.

To estimate the probable market penetration of residential cool storage units, a comprehensive consumer research study must be conducted. Because

this study assumed that consumers are motivated only by economic considerations, tradeoff or conjoint analysis should be used to develop more accurate views of consumer motivations and, thus, more accurate estimates of the expected market penetration.

It is also recommended that hourly electric power consumption patterns for residential central air conditioning be studied. To accurately predict the impact of residential cool storage technology, more precise data is required on consumption by residences, coincidence of demand by multiple residences, and coincidence of air conditioning demand with total utility demand.

CONTENTS

SUMMARY	iii
1.0 INTRODUCTION	1.1
2.0 ESTIMATION OF MARKET POTENTIAL	2.1
2.1 EXPECTED REGIONAL SHORTFALLS OF ELECTRICITY	2.1
2.2 MARKET FOR RESIDENTIAL COOL STORAGE TECHNOLOGY	2.2
3.0 ESTIMATION OF MARKET PENETRATION	3.1
3.1 FACTORS INFLUENCING MARKET PENETRATION	3.1
3.2 ECONOMIC COST MODEL FOR ESTIMATING MARKET PENETRATION	3.1
3.3 SELECTION OF A BASE CASE HOME	3.3
3.4 COMPARISON OF LIFE-CYCLE COSTS FOR CONVENTIONAL CENTRAL A/C AND TES SYSTEM	3.5
3.5 EXPECTED MAXIMUM MARKET PENETRATIONS	3.8
4.0 ESTIMATION OF FUTURE UNIT SALES	4.1
4.1 PROJECTION OF SALES BY ANALOGY	4.1
4.2 ESTIMATED SALES AND PEAK ELECTRICITY SAVINGS	4.3
4.3 ESTIMATED SALES BY STATE	4.3
5.0 LOAD-SHIFTING VERSUS LOAD-LEVELING	5.1
5.1 ADVANTAGES AND DISADVANTAGES OF LOAD-SHIFTING VERSUS LOAD-LEVELING	5.1
5.2 THE INFLUENCE OF PEAK PERIOD LENGTH AND LOAD-SHIFTING OR LOAD-LEVELING STRATEGIES ON EQUIPMENT CAPITAL COST REQUIREMENTS	5.2
6.0 CONCLUSIONS AND RECOMMENDATIONS	6.1
6.1 MARKET POTENTIAL	6.1
6.2 MARKET PENETRATION	6.1

6.3	ESTIMATED UNIT SALES	6.2
6.4	CAPITAL COST REQUIREMENTS	6.3
6.5	RECOMMENDATIONS	6.3
7.0	REFERENCES	7.1

FIGURES

3.1	A Comparison of Life Cycle Costs for Conventional and TES A/C Systems at Selected Cooling-Degree-Days for TOD Rate Differentials Between \$0.00 and \$0.15/kWh	3.6
3.2	A Comparison of Life Cycle Costs for Conventional and TES A/C Systems at Selected Cooling-Degree-Days for Price Rebates Between \$0 and \$1000	3.7
6.1	The Effect of Capital Cost Reductions on National Electricity Displacement by the Year 2010 for 6-, 9-, and 12-Hour Load-Shifting Strategies	6.4
6.2	The Effect of Capital Cost Reductions on National Electricity Displacement by the Year 2010 for 6-, 9-, and 12-Hour Load-Leveling Strategies	6.4

TABLES

2.1	Anticipated Regional Power Shortages by the Years 1995 and 2000	2.2
2.2	New Single-Family Housing Completed with Central Air Conditioning or Heat Pump Units	2.3
2.3	New Single-Family Housing Completed with Central Air Conditioning or Heat Pump Units by Census Region	2.4
2.4	Saturation of Air Conditioning in Existing Residential Housing by Census Region and Division	2.5
3.1	Assumptions Used to Estimate Conventional and Residential Cool Storage Life Cycle Costs	3.4
3.2	Projected Maximum Market Penetration of Residential Cool Storage Technology at Selected TOD Rate Differentials and Price Rebates	3.9
4.1	Historical Sales of Central Air Conditioning and Heat Pump Units in the Single-Family and Multi-Family Residential Sector	4.2
4.2	Projected National Yearly Sales and Cumulative Sales for Single-Family Residential Cool Storage Units	4.4
4.3	Projected Annual Single-Family Residential Cool Storage Sales by State Using a Mandatory Time-of-Day Rate Differential of \$0.10/kWh	4.5
5.1	Comparative TES System Incremental Capital Cost Requirements to Maintain a Similar Expected Market Penetration to the Base Case	5.4

ESTIMATING THE MARKET PENETRATION OF RESIDENTIAL COOL STORAGE TECHNOLOGY USING ECONOMIC COST MODELING

1.0 INTRODUCTION

There are warnings about a serious electric power shortage by the mid-1990s (DOE 1988, Applied Economic Research 1987). This shortage is expected to occur during periods of peak electric power use, which occur on hot summer days for summer peaking utilities. Cool storage technology, developed for both commercial and residential applications, is one solution to meeting peak power needs. Demand for this technology is derived from utilities' hesitancy to pay the extremely high-capacity costs (per kW) required to generate electricity for use at peak periods.

This technology does not save energy--it merely shifts its use to a time when residential, commercial, and industrial demand for electricity is low. This technology produces and stores "chill" during off-peak periods of the day to be used during times of peak electric power needs. Thus, except for the electricity used to operate fans and recirculating pumps, all electric power use is shifted to late evening or early morning time periods.

The focus of this study, performed by Pacific Northwest Laboratory^(a), is cool storage technology for the residential single-family market. Its objective is to estimate the market potential and expected market penetration of residential cool storage technology. This report provides estimates of actual unit sales expected in the years 1995, 2000, 2005, and 2010. These sales projections help to determine the maximum amount of energy that could be displaced by this technology in the future. [See also QLA Inc. (1986).]

The demand for residential cool storage units is a derived demand. There will be little or no interest in this product until utilities devise programs to encourage their use. Several factors have been identified that will influence the ultimate market penetration of residential cool storage. Some

(a) Operated for the U.S. Department of Energy by Battelle Memorial Institute.

of these factors include the number of cooling-degree-days in an area, the time-of-day (TOD) electricity rates charged to households, price rebates offered by utilities to encourage purchase, and whether the cool storage unit is being installed in a new or an existing home. Several methods have been developed to generate market penetration estimates. This study will use a few of these methods (e.g., historical analogy and economic cost models) to develop an estimate of market penetration.

Projections are also made about the expected pattern of diffusion of this technology into the market place. This will be ascertained based on the market penetration pattern of a similar product in the market place. Of particular interest is the amount of time required to reach maximum market penetration. The diffusion pattern of residential central air conditioning systems will provide the historical analogy for residential cool storage units.

This report is organized around the key information that must be estimated in this study. Chapter 2 estimates the market potential for residential cool storage. Chapter 3 discusses the key factors that will influence the market penetration of residential cool storage units and develops estimates of the expected penetration of this technology into the central air conditioning market. Chapter 4 develops estimates of the expected unit sales of residential cool storage units in the years 1995, 2000, 2005, and 2010. Chapter 5 evaluates the influence of load and load-leveling strategies on equipment capital cost requirements. Chapter 6 concludes with a summary and recommendations.

2.0 ESTIMATION OF MARKET POTENTIAL

Market potential is typically defined as the total number of consumers who can benefit from using a new product or technology. For this study, market potential is specified as the total number of households that might benefit from the use of residential cool storage technology. The first place to begin in attempting to estimate market potential is to identify the need satisfied by this technology. The market for residential cool storage technology, especially considering the expected shortfalls of electricity in regions of the United States, is discussed below.

2.1 EXPECTED REGIONAL SHORTFALLS OF ELECTRICITY

The primary benefit of this technology is to shift demand for electricity off peak. Demand for this technology is derived from the extremely high-capacity costs (per kW) required by utilities to produce electricity at peak demand.

The first step in estimating market potential is to identify those geographic areas where there will be a problem in meeting peak summer electricity demand. The basis for making these estimates is an annual DOE study entitled Annual Outlook for U.S. Electric Power 1987 - Projections Through 2000 (EIA 1987a).

This study concludes that shortfalls in ability to provide peak electricity demands will become a serious problem in certain regions by the year 1995. By the year 2000, a serious power shortage will exist in almost all regions of the U.S.

Table 2.1 summarizes the findings from this study. This table describes the regions of the U.S. that are expected to have peak power shortages by the years 1995 and 2000. The first shortages of electricity will occur by 1995. The first areas to suffer from electricity shortages will be the Mid-Atlantic and Central regions. The EIA study concludes that virtually all of the U.S. will fall short of peak electric power by the year 2000. Only the North Central region is not expected to suffer from shortfalls.

TABLE 2.1. Anticipated Regional Power Shortages by the Years 1995 and 2000
(in Gigawatts)

<u>Region</u>	<u>Anticipated 1995 Power Shortage</u>	<u>Anticipated 2000 Power Shortage</u>
New England	0.0	2.1
New York/New Jersey	0.0	1.0
Mid-Atlantic	4.2	11.3
South Atlantic	0.0	3.0
Midwest	0.0	16.3
Southwest	0.0	12.5
Central	3.1	7.5
North Central	0.0	0.0
West	0.0	5.7
Northwest	0.0	0.5

Source: Energy Information Administration (1987a)

Given the pervasive character of power shortages by the year 2000, this study will not segment the potential market for residential cool storage technology by geographic area.

2.2 MARKET FOR RESIDENTIAL COOL STORAGE TECHNOLOGY

The market for cool storage technology is expected to be identical to the market that exists for central air conditioning (A/C). Central air conditioning includes both conventional central air conditioning systems as well as heat pump systems. There are two major submarkets for this technology: new homes and retrofits to the central A/C units in existing homes.

The first submarket is composed of new homes constructed in the U.S. Table 2.2 describes the proportion of new homes constructed in the U.S. that include central A/C. In recent years, approximately 70% of all new homes are constructed with central A/C. This percentage varies significantly from region

TABLE 2.2. New Single-Family Housing Completed with Central Air Conditioning or Heat Pump Units

<u>Year</u>	<u>New Single-Family Housing^(a)</u>	<u>With Central A/C or Heat Pumps^(a)</u>	<u>Percent with Central A/C or Heat Pumps^(a)</u>
1971	1014	365	36
1972	1143	489	43
1973	1197	582	49
1974	940	451	48
1975	875	403	46
1976	1034	511	49
1977	1258	679	54
1978	1369	797	58
1979	1301	784	60
1980	957	598	63
1981	819	530	65
1982	632	416	66
1983	924	642	70
1984	1025	723	71

(a) All units listed are in thousands.

Source: U.S. Department of Commerce (1985)

to region. Table 2.3 describes the regional differences in installing central A/C in new homes. Of new homes constructed in the south, 92% include central A/C. The northeast region has the lowest proportion of new homes constructed with central A/C. Only about one-third of new homes constructed in that area include central A/C.

The second submarket for residential cool storage are retrofits to the existing central A/C systems already included in homes. Brown and Spanner (1988) found that modifying the existing central A/C equipment to incorporate

TABLE 2.3. New Single-Family Housing Completed with Central Air Conditioning or Heat Pump Units by Census Region

Year	Northeast		North Central		South		West	
	Units ^(a)	%	Units ^(a)	%	Units ^(a)	%	Units ^(a)	%
1971	14	10	53	25	227	49	70	34
1972	17	11	68	29	299	56	105	43
1973	22	14	89	34	355	67	103	41
1974	21	16	78	35	284	72	64	34
1975	15	13	77	35	258	71	53	29
1976	16	13	107	40	320	78	68	29
1977	23	17	132	44	412	80	112	36
1978	28	20	141	47	480	84	149	42
1979	35	26	137	47	457	85	155	46
1980	29	29	77	45	384	84	109	47
1981	25	29	67	48	344	84	94	51
1982	21	27	40	43	290	85	64	53
1983	35	33	70	50	428	90	109	55
1984	44	34	86	55	466	92	127	55

(a) All units listed are in thousands.

Source: U.S. Department of Commerce (1985)

cool storage was economically feasible for residential households. However, they concluded that removal of the existing system and complete replacement with a new residential cool storage system in an existing home was not economically feasible.

The expected life of central A/C equipment is approximately 15 years. Therefore, a typical household with central A/C must make major retrofits to this equipment every 15 years. Thus, one-fifteenth of the existing housing market with central A/C was considered the potential market for residential cool storage technology in any given year. Table 2.4 summarizes the saturation of air conditioning in existing residential housing by census region in the U.S.

TABLE 2.4. Saturation of Air Conditioning in Existing Residential Housing by Census Region and Division

Census Region	Census Division	% of Housing with Central A/C Units	% of Housing with Room A/C Units	% of Housing without A/C
Northeast		10.9	39.9	49.2
	New England	4.7	37.2	58.1
	Middle Atlantic	12.5	41.1	46.4
North Central		27.3	32.4	40.3
	East North Central	21.1	32.2	46.7
	West North Central	40.6	34.4	25.0
South		47.3	29.9	22.8
	South Atlantic	44.9	27.2	27.9
	East South Central	43.1	39.7	17.2
	West South Central	54.5	28.4	17.1
West		22.9	15.9	61.2
	Mountain	35.5	15.6	48.9
	Pacific	18.4	16.0	65.6
Total U.S.		29.8	29.9	40.3

Source: Energy Information Administration (1987b)

A regression analysis was developed based on historical housing data to estimate the future size of the housing market. This model projected the total existing housing market to be as follows:

1995	111,459,000 units
2000	119,016,000 units
2005	126,572,000 units
2010	134,129,000 units.

Approximately 62% of these totals will be composed of single-family dwellings (U.S. Department of Commerce 1987). Approximately 30% of single-family dwellings are projected to have central air conditioning. If one-fifteenth of this market composes the potential market in any given year, the potential annual market for residential cool storage systems in existing homes is approximately as follows:

1995	1,400,000 units
2000	1,500,000 units
2005	1,590,000 units
2010	1,680,000 units.

A regression analysis model was also developed based on historical patterns of new housing starts. This model did not find a statistically significant relationship between annual new housing starts and time. Thus, the average value for housing starts over the last 5 to 10 years was used to estimate the expected annual new housing starts. On average, approximately 1,500,000 new housing units are constructed each year. Of this total, approximately 62% are single-family dwellings. Approximately 70% of these single-family houses will install central air conditioning. Thus, on average, approximately 650,000 new single-family homes are built annually with central air conditioning.

Including the totals estimated for both the new and existing housing market, the potential market for residential cool storage technology for the four target years is as follows:

1995	2,050,000 units
2000	2,150,000 units
2005	2,240,000 units
2010	2,330,000 units.

3.0 ESTIMATION OF MARKET PENETRATION

3.1 FACTORS INFLUENCING MARKET PENETRATION

Several factors have been identified that will influence the potential for residential cool storage. In a general sense, this will include the performance of residential cool storage units relative to its competitors. There are many dimensions to performance. Consumers generally make purchase decisions for expensive durable goods based on several product features: initial cost, operating cost, comfort, noise, warranties, familiarity of brand name, and maintenance requirements. This study did not attempt to study the influence of all of these features. Instead, it focused only on cost-related features. Cost competitiveness should be viewed as a necessary, but not sufficient, condition for the successful penetration of this technology into the market place.

There are several factors that influence the cost competitiveness of this technology. These include the TOD differential electric rate, price rebates offered by utilities, the first cost of the technology, operating and maintenance costs, and the cooling-degree-day requirements of an area. This study used an economic cost model to consider the importance of these factors in influencing the final market penetration.

3.2 ECONOMIC COST MODEL FOR ESTIMATING MARKET PENETRATION

Several methods have been developed to generate market penetration estimates (Raju and Teotia 1985; Resource Planning Associates 1982; Wind, Mahajan, and Cardozo 1984). The economic cost model is appropriate for applications where the system cost is an important attribute in product selection. Cost and performance goals for residential cool storage technology were recently estimated in a study conducted by Brown and Spanner (1988). Other more accurate methods, based on consumer research also do exist to estimate market penetration. However, no consumer research has been conducted on this technology that might be incorporated in an estimate of market penetration.

The basic methodology employed in an economic cost model is simple. Raju and Teotia (1985) provide a description of the steps in a typical economic cost model for estimating the market share of competing technologies:

Economic cost models estimate market share as a function of only the cost-related aspects of the product. There are essentially four steps in the economic cost models. First, a set of competing technologies or products is identified. Second, for each product identified, the initial and after tax costs (e.g., capital, installation, and operation and maintenance costs) are estimated over the life of the product. Third, depending on the approach used, the costs are actually converted to a standard cost measure such as the (1) net present value or life-cycle cost (\$), (2) internal rate of return (%), or levelized energy cost (\$/10⁶ or cents/kWh). Finally, the market share of each product is estimated from the cost measure.

Economic cost models have had application in estimating the likely market penetration of solar technologies (Schiffel et al. 1978; Warren 1980). The S-shaped logistic curve has been used to develop these estimates. A comparison of payback periods and life-cycle costs provides the basis for comparing the relative attractiveness of competing technologies.

The S-shaped logistic curve will be used in this study to estimate the likely market share of competing technologies. Raju and Teotia (1985) discussed the theoretical justification for using logistic curves in this analysis. They believe the logistic curve supports the theory that when technology is comparable only to conventional technology, only a small number of innovators will adopt it. As the technology becomes economically better, its market share increases rapidly. The growth rate for this technology slows when most of the market has been captured.

Important advantages and disadvantages have been presented for using logistic curves to estimate market penetration. The advantage of such a model is that cost factors can be developed early in the technology development process. In addition, sensitivity analysis can be performed using these cost estimates. A major criticism is that little empirical evidence is available to support the relationship between economic attractiveness and market share. Another disadvantage is that this model ignores most other customer attributes.

Further, the equilibrium market share calculated from such a model will not be attained immediately. Diffusion of this technology will take several years despite its economic attractiveness.

3.3 SELECTION OF A BASE CASE HOME

One of the required tasks of this study was to select a building prototype that would be representative of the cooling load requirements of homes in the U.S. The estimation of a building's cooling load is a complex analytical calculation involving the following key building-specific factors, among many others:

- building floor area and layout
- type, quantity, and location of insulation
- internal heating loads
- ventilation practices
- indoor target temperature and humidity.

The housing characteristics selected for comparative economic analysis are based on the study conducted by Brown and Spanner (1988). In that study, three different buildings were modelled to determine the impact of residential building size and type on the conventional cost of cooling. The housing characteristics analyzed in this study are a composite of characteristics common to these three house types. The energy-saving design practices, such as roof or wall insulating levels, were obtained from the ASHRAE Standard, which describes typical good building practices throughout the U.S. Table 3.1 provides a summary of the assumptions used to estimate conventional and residential cool storage system life-cycle costs.

An important element of the estimate of life-cycle costs computed in this study is the cooling loads in various locations and regions of the U.S. There is a wide range in the cooling-degree-day requirements at different locations in the U.S. Anchorage, Alaska, has less than 20 cooling-degree-days per year. At the other extreme, Miami, Florida, has over 4000 cooling-degree-days per year.

TABLE 3.1. Assumptions Used to Estimate Conventional and Residential Cool Storage Life Cycle Costs

<u>Model Assumptions</u>	
Building style	Ranch
Cooling system capacity	3.5 tons
Conventional system capital costs	\$2685
Conventional and thermal energy storage (TES) system coefficient-of-performance (COP)	1.75
On-peak period fraction of total daily load	0.73
Incremental capital costs for TES	\$2000
Annual maintenance costs	\$125
System life	15 yr
Property taxes	2% of initial capital/yr
General inflation rate	3.1%/yr
Electricity escalation rate	2.5%/yr
Maintenance escalation rate	3.1%/yr
Capital escalation rate	3.1%/yr
Discount rate	4.2%/yr

For this study, variations in cooling load requirements were modeled as a function of the cooling-degree-days (65-degree base) typical for locations in the U.S. Cooling load as a function of cooling-degree-days was calculated using the PEAR 2.0 program developed by Lawrence Berkeley Laboratory (1986). This program estimates the heating and cooling energy use of buildings of various size and construction characteristics in different cities in the U.S. A regression analysis model was developed from data computed from a sample of cities in the U.S. to estimate cooling load as a function of cooling-degree-days. This relationship was then included in the economic cost model to estimate state-level market penetrations.

3.4 COMPARISON OF LIFE-CYCLE COSTS FOR CONVENTIONAL CENTRAL A/C AND TES SYSTEM

The methodology employed by Brown and Spanner (1988) provided the basis for estimating the life-cycle costs for the conventional central air conditioning system and the residential cool storage system. This study used the same economic assumptions as in the Brown and Spanner study. Comparative life-cycle costs were developed, assuming various types of price incentives are offered by utilities. Figure 3.1 describes the findings of the influence of various T00 rates on the comparative life-cycle costs for a system. Figure 3.2 describes the influence of price rebates on the comparative life-cycle costs of the residential cool storage systems. The relevance of these findings is discussed below.

Figure 3.1 describes the effect of zero, \$0.05, \$0.10, and \$0.15/kWh T00 rate differentials on the economic competitiveness of residential cool storage systems compared to conventional central air conditioning systems. The 45-degree line on this graph indicates the point where the TES system cost/MBtu equals the conventional system cost/MBtu. The portions of the graph on the right side of the 45-degree line indicate points where the TES system cost is lower than the comparable conventional A/C system cost. An example is presented below to help clarify the interpretation of this figure.

Another line on Figure 3.1 describes the comparative costs of the TES and conventional systems in climates with 1000 cooling-degree-days. This cost line crosses the 45-degree line at a T00 rate differential of approximately \$0.14/kWh. This indicates that for T00 rate differentials greater than \$0.14/kWh, the TES system has a lower cost per MBtu than conventional air conditioning systems.

Figure 3.2 describes the influence of price rebates on the economic competitiveness of residential cool storage systems compared to conventional A/C systems. This figure might also be interpreted as the influence of a cost reduction on the economic competitiveness of this new technology. The interpretation of this figure is similar to the explanation provided above for

FIGURE 3.1. A Comparison of Life Cycle Costs for Conventional and TES A/C Systems at Selected Cooling-Degree-Days for TOD Rate Differentials Between \$0.00 and \$0.15/kWh

Figure 3.1. As an example, a \$1000 rebate in climates with 500 cooling-degree-days has a dramatic effect on the cost competitiveness of TES systems. However, even with a \$1000 rebate, a TOD rate differential of approximately \$0.20/kWh would be required for the new TES system to be cost competitive with the conventional central air conditioning system.

FIGURE 3.2. A Comparison of Life Cycle Costs for Conventional and TES A/C Systems at Selected Cooling-Degree-Days for Price Rebates Between \$0 and \$1000

From the findings described in Figures 3.1 and 3.2, this study concludes that pricing incentives must vary dramatically by region for residential cool storage units to be economically attractive relative to conventional central air conditioning systems. Assuming a \$2000 differential price for residential cool storage units, a TOD rate differential of approximately \$0.075/kWh would be required at 2000 cooling-degree-days (65-degree base) to allow residential cool storage technology to compete economically with central air conditioning. At 1000 cooling-degree-days, a TOD rate differential of approximately \$0.15/kWh would be required to allow residential cool storage to compete economically

with central air conditioning. Another option at 1000 cooling-degree-days is to offer a \$0.10/kWh TOD rate differential with a \$1000 rebate to make residential cool storage units economically competitive. Residential cool storage units are not economically competitive at 500 cooling-degree-days or less. Very extreme price incentives would have to be offered to make residential cool storage units economically competitive in these climates. This would require a \$0.20/kWh TOD price differential and a \$1000 price rebate.

3.5 EXPECTED MAXIMUM MARKET PENETRATIONS

The maximum national penetration of residential cool storage technology will be influenced by the average cooling requirements across the 50 states. States that have very low cooling requirements will have very low penetrations of residential cool storage technology. Two factors work against a high penetration of residential cool storage in states requiring little cooling. First, these states generally have a very low penetration of central air conditioning. In states such as Maine, window air conditioning is a much more economical way to cool than central air conditioning. Second, residential cool storage units, because of their high comparative life-cycle cost, are not competitive with central A/C that exists in these states. Both factors combine to minimize expected penetration in such states.

However, the reverse is true in other states. For example, in Florida, approximately 92% of newly constructed homes have central air conditioning. In such a climate, the high penetration of central air conditioning, along with the massive cooling required in such areas, can lead to very significant potential penetration for residential cool storage.

An economic cost model, developed using Lotus 123, estimated the maximum penetration of residential cool storage by state. This spreadsheet estimated the penetration for each state based on the average cooling-degree-days for that state. Each of the state estimates of market penetration was then weighted with the stock of existing housing and new construction occurring in each state.

These market penetration estimates were made over a variety of different scenarios. Different levels were set for TOD rate differentials and price

rebates offered by utilities. The TOD rates considered included zero, \$0.05, \$0.10, and \$0.15/kWh rate differentials above the off-peak rates. The price rebates that were considered include zero, \$250, \$500, \$750, and \$1000.

Table 3.2 presents the finding of estimated national market penetration of residential cool storage technology. Clearly, the penetration will vary significantly depending on the incentives offered by utilities. The worst case, when no incentives are offered, shows that residential cool storage would eventually replace only 2% of the central air conditioning market. In contrast, when a \$0.15/kWh TOD rate differential is offered to consumers along with a \$1000 rebate, over 80% of the central air conditioning market is expected to be eventually replaced by residential cool storage systems.

Under the most likely scenario, a \$0.10/kWh TOD rate differential was used to derive an estimate of final market penetration. This analysis estimated that residential cool storage units would eventually capture about one-half of the central air conditioning market.

TABLE 3.2. Projected Maximum Market Penetration^(a) of Residential Cool Storage Technology at Selected TOD Rate Differentials and Price Rebates

		Time-of-Day Rate Differential				
		None	\$0.05	\$0.10	\$0.15	\$0.20
Utility- Offered Price Rebates	None	1.9%	22.5%	47.8%	64.3%	75.2%
	\$250	2.4%	25.2%	50.7%	66.9%	77.3%
	\$500	3.1%	28.1%	53.7%	69.5%	79.3%
	\$750	3.9%	31.3%	56.9%	72.1%	81.3%
	\$1000	5.0%	34.8%	60.1%	74.7%	83.2%

(a) Based on the historical experience of residential control A/C systems, this maximum market penetration will probably be achieved about 40 years from product introduction. The above percentages represent the portion of the residential central A/C market replaced by residential cool storage technology.

rebates offered by utilities. The 100 rates considered included zero, 10.0¢, 20.1¢, and 20.15¢/kWh rate differentials above the off-peak rates. The price rebates that were considered include zero, \$250, \$500, \$750, and \$1000.

Table 3.2 presents the finding of estimated national market penetration of residential cool storage technology. Clearly, the generation will vary significantly depending on the incentives offered by utilities. The worst case, when no incentives are offered, shows that residential cool storage would eventually replace only 2% of the central air conditioning market. In contrast, when a 20.15¢/kWh 100 rate differential is offered to consumers along with a \$1000 rebate, over 80% of the central air conditioning market is expected to be eventually replaced by residential cool storage systems.

Under the most likely scenario, a 20.10¢/kWh 100 rate differential was used to derive an estimate of final market penetration. This analysis estimated that residential cool storage units would eventually capture about one-half of the central air conditioning market.

TABLE 3.2. Projected Maximum Market Penetration (%) of Residential Cool Storage Technology at Selected 100 Rate Differentials and Price Rebates

Rebate	Time-of-Day Rate Differential				
	None	20.05	20.10	20.15	20.20
None	1.9%	22.5%	47.8%	64.3%	78.2%
\$250	2.4%	28.2%	50.7%	66.9%	77.3%
\$500	3.1%	33.1%	53.7%	69.2%	79.3%
\$750	3.9%	37.3%	56.9%	72.1%	81.3%
\$1000	4.0%	38.8%	60.1%	74.7%	83.2%

(a) Based on the historical experience of residential control A/C systems, this maximum market penetration will probably be achieved about 40 years from product introduction. The above percentages represent the portion of the residential central A/C market replaced by residential cool storage technology.

4.0 ESTIMATION OF FUTURE UNIT SALES

4.1 PROJECTION OF SALES BY ANALOGY

The previous two sections have described the two important components of estimating unit sales, market potential and eventual national market penetration. The only variable that remains to be estimated is the length of time required for residential cool storage systems to achieve their maximum market penetration into the U.S. building stock. To develop estimates of the expected unit sales between 1995 and 2010, this study compared the pattern of diffusion for a similar product. This pattern of diffusion was then used to project future unit sales for residential cool storage. Central air conditioning is very similar to residential cool storage systems. In many respects, the diffusion pattern of these two technologies should be very similar.

In each instance, a less expensive substitute was available for each product: with central air conditioning, it was the window air conditioning units; with the residential cool storage system, it was the central air conditioning system. It is anticipated that the initial consumer demand for residential cool storage units will be tempered by the cost of the system, as well as concerns about the durability and reliability of the newer unit.

It is hypothesized that the early adopters of both of these technologies are also similar. The early adopters of the residential cool storage unit are expected to be the more affluent and upscale homeowners who are replacing their first home with a more expensive, custom-designed home. Later diffusion is expected to occur in medium-income new households and also as retrofits to central air conditioning systems in existing homes. Table 4.1 depicts the past sales of residential central A/C units.

Raju and Teotia (1985) discuss the merits and weaknesses of using the historical analogy method to estimate the diffusion pattern of a new technology:

Historical analogy is a forecasting method based on the comparison of a new product or technology with an existing one that is analogous. The market penetration share over time is assumed to be essentially the same for both technologies. The method thus does not explicitly consider variables other than time and assumes that the new and the analogous products are similar and exist in identical competitive markets.

TABLE 4.1. Historical Sales of Central Air Conditioning and Heat Pump Units in the Single-Family and Multi-Family Residential Sector

Year	Central A/C Sales	Heat Pump Sales	Combined Sales
1950	0	0	0
1951	0	0	0
1952	0	0	0
1953	41438	0	41438
1954	78101	0	78101
1955	109068	0	109068
1956	144149	0	144149
1957	119937	0	119937
1958	123954	21132	145086
1959	167299	33953	201252
1960	187544	39305	226849
1961	205707	42037	247744
1962	266738	51034	317772
1963	351599	62973	414572
1964	426247	63155	489402
1965	527315	59072	586387
1966	591648	67050	658698
1967	653505	64267	717772
1968	780444	71054	851498
1969	1107092	79484	1186576
1970	1111956	78941	1190897
1971	1341266	65584	1406850
1972	1746042	77095	1823137
1973	2060511	94718	2155229
1974	1792645	106251	1898896
1975	1046573	133497	1180070
1976	1449752	259396	1709148
1977	1582264	399704	1981968
1978	1798761	464862	2263623
1979	1676115	454586	2130701
1980	1366878	350948	1717826
1981	1414862	418972	1833834
1982	1148755	318317	1467072
1983	1750340	522714	2273054
1984	2046591	618512	2665103
1985	1987379	681512	2668891
1986	2079162	733888	2813050
1987	2441798	762298	3204096

Sources: Air Conditioning and Refrigeration Institute (1986),
Appliance (1988, 1981, 1972), Metal Products Manufacturing
(1963)

Historical analogy is useful especially when historical data are not available, e.g., because the product or technology has been introduced very recently. It can also provide a useful first approximation before more sophisticated forecasting methods are used. Its success, however, depends on identification of an analogous product or technology and is therefore less likely to be useful for pioneering technologies.

4.2 ESTIMATED SALES AND PEAK ELECTRICITY SAVINGS

Allowing for these limitations of the method, a logistic curve was fitted to the historical pattern of sales of conventional central air conditioning systems. Table 4.2 describes the diffusion pattern that fits the historical data. This diffusion pattern was used in Table 4.2 to estimate the expected unit sales by year for residential cool storage systems. This curve assumes that this technology is introduced to the market place in 1990. The first full year of sales is 1991. The estimated annual unit sales for this technology in 1995, 2000, 2005, and 2010 are approximately 60,000, 150,000, 300,000, and 500,000 units per year, respectively. If it is assumed that 2.5 kW of diversified demand are shifted per household, the estimated peak electricity savings achieved from this technology in 1995, 2000, 2005, and 2010 are approximately 0.6, 1.9, 4.7, and 9.9 GWs per year, respectively.

4.3 ESTIMATED SALES BY STATE

The economic cost model developed for this analysis estimated the unit sales for this technology by state. Table 4.3 describes the states that are expected to have the largest unit sales of this technology. The states that are anticipated to have the greatest unit sales are Texas, Florida, Georgia, Louisiana, North Carolina, Oklahoma, Arizona, Alabama, Tennessee, and North Carolina. It is apparent that the nearly all sales of this technology will be centered over the hot and humid southern tier states in the U.S.

TABLE 4.2. Projected National Yearly Sales and Cumulative Sales for Single-Family Residential Cool Storage Units

<u>Year</u>	<u>Projected Yearly Sales (a)</u>	<u>Projected Cumulative Sales (a)</u>	<u>Diffusion Pattern</u>
1990	INTRODUCTION		
1991	30	30	0.03
1992	40	70	0.04
1993	45	115	0.05
1994	55	170	0.06
1995	65	235	0.07
1996	75	310	0.08
1997	90	400	0.09
1998	105	500	0.10
1999	120	625	0.12
2000	140	765	0.14
2001	165	930	0.16
2002	190	1120	0.18
2003	220	1340	0.21
2004	250	1595	0.24
2005	290	1880	0.27
2006	325	2210	0.30
2007	370	2580	0.34
2008	415	2995	0.38
2009	460	3455	0.42
2010	510	3970	0.46

(a) All units are in thousands

TABLE 4.3. Projected^(a) Annual Single-Family Residential Cool Storage Sales by State Using a Mandatory Time-of-Day Rate Differential of \$0.10/kWh

State	Average Cooling-Degree- Days	1995 Sales	2000 Sales	2005 Sales	2010 Sales	Eventual TES System Replacement of Central A/C Units
Texas	2682	15,000	38,000	79,000	135,000	84%
Florida	3348	11,000	27,000	57,000	95,000	90%
Georgia	1780	3,000	9,000	18,000	30,000	65%
Louisiana	2588	3,000	8,000	17,000	25,000	83%
North Carolina	1390	3,000	6,000	13,000	20,000	50%
Oklahoma	2010	2,000	6,000	13,000	20,000	72%
Arizona	2606	2,000	5,000	11,000	15,000	83%
Alabama	1921	2,000	5,000	10,000	15,000	70%
Tennessee	1392	2,000	5,000	9,000	15,000	50%
South Carolina	1830	2,000	5,000	9,000	15,000	67%
California	779	1,000	4,000	8,000	10,000	16%
Virginia	1093	1,000	4,000	8,000	10,000	53%
Missouri	1335	1,000	4,000	8,000	10,000	45%
Arkansas	1861	1,000	3,000	7,000	10,000	68%
Mississippi	2163	1,000	3,000	7,000	10,000	75%
All other states		<u>10,000</u>	<u>18,000</u>	<u>26,000</u>	<u>65,000</u>	
		60,000	150,000	300,000	500,000	48%

(a) This analysis assumed that residential cool storage units are introduced into the market place sometime during 1990. The first full year of sales are 1991.

5.0 LOAD-SHIFTING VERSUS LOAD-LEVELING

Residential cool storage equipment can be designed to achieve either load-shifting or load-leveling. The economic modeling conducted in the previous sections of this study has assumed that all electricity use for chill generation will be transferred to an off-peak time period--referred to as load-shifting. Load-leveling, however, involves the creation and storage of ice or cold water both during peak and off-peak time periods.

5.1 ADVANTAGES AND DISADVANTAGES OF LOAD-SHIFTING VERSUS LOAD-LEVELING

There are various advantages and disadvantages to designing residential cool storage equipment to perform either load-shifting or load-leveling load management strategies. The major advantage of load-shifting is that it offers the maximum peak reduction for the utility and maximum reduction in the electric bill for the user because all cooling is created and stored during the off-peak time period. However, there are disadvantages created by this approach. First, residential cool storage equipment must be designed with a large compressor and storage facility to create and store all ice or cold water (or other storage media) during off-peak time periods. This increases the first cost of the product to the customer. This cost problem is further aggravated as the peak time period is lengthened. For example, an on-peak time period of only 4 hours would have only a limited effect on increasing equipment costs. However, if the on-peak time period is increased to 12 hours, a much larger compressor and storage facility will be required, further aggravating the first cost for this unit.

The second major disadvantage with load-shifting is it may create a new peak after the original peak. This "new" peak is created when all of the residential cool storage units that were turned-off during the on-peak period suddenly turn-on to start recharging the ice or cold water storage tank. To eliminate this problem, utilities must devise strategies to stagger the start-up and shutdown of these cool storage units.

The advantages and disadvantages to designing residential cool storage equipment to operate for load-leveling are, in many respects, reversed from

those listed for the load-shifting strategy. The major advantage of designing a residential cool storage unit that can operate 24 hours per day is that the compressor and storage tank size is minimized. Thus, the first cost of this equipment is cheaper than equipment designed for load-shifting. The problem of moving the peak to a new time period is not created when the equipment is operating for a longer time period during the day.

The major disadvantage of this equipment design is that not all of the chill generator power consumption is shifted to an off-peak time period. This is a disadvantage to the utility because they will not see the maximum possible reductions in peak period power usage. This is also a disadvantage to the user who will not see as large a reduction in the cooling portion of their electric bill.

5.2 THE INFLUENCE OF PEAK PERIOD LENGTH AND LOAD-SHIFTING OR LOAD-LEVELING STRATEGIES ON EQUIPMENT CAPITAL COST REQUIREMENTS

The above discussion helps to elucidate the important tradeoff that must be considered in the design of residential cool storage equipment. Should this equipment be designed to minimize the capital cost of the equipment, maximize the possible energy savings to the customer, or try to achieve some combination of these two considerations? Designing equipment that minimizes the first cost of the product favors a strategy of load-leveling for short peak periods. Designing equipment to maximize the dollar savings to the customer favors the strategy of load-shifting for long peak periods. The answer to this tradeoff depends on the actual cost and performance of the equipment being considered and the site-specific building load and utility rate structure characteristics.

Specification of capital cost requirements for different peak period lengths and for load-shifting and load-leveling is one way to assist engineers in identifying the optimum equipment configuration. The economic modeling conducted in the base case of this study assumed load-shifting of electricity for a 12-hour on-peak time period. Assuming the same time-of-day rate differential of \$0.10/kWh and a goal of obtaining the same long-term market

penetration, how much less expensive must cool storage equipment be priced if it operates for only 6 or 9 hours?

Table 5.1 summarizes the incremental capital cost requirements for equipment designed to serve either 6-, 9-, or 12-hour peak periods for either the load-shifting or load-leveling load management strategy. The data developed in this table are based on the base case home located in St. Louis. The incremental cost requirements listed in this table should be interpreted relative to the base case. The \$2000 capital cost requirements listed for the base case is based on the findings of an earlier EPRI-sponsored study (see QLA 1986).

As an example, this table indicates that to receive a comparable market penetration as the base case, equipment designed for load-leveling for a 9-hour time period has an incremental capital cost requirement of \$851 over a conventional central A/C system. This should be interpreted as meaning \$1149 less than the \$2000 capital cost requirement established for the base case scenario.

Although the allowable incremental capital costs for all of the alternative scenarios are lower (relative to the base case), the alternative requirements may actually be easier to achieve because the chill generator (compressor) and the storage equipment would be much smaller and, hence, much less costly.

TABLE 5.1. Comparative TES System Incremental Capital Cost Requirements to Maintain a Similar Expected Market Penetration to the Base Case^(a)

Peak Period, Hours	Load-Shifting				Load-Leveling			
	% of Load On-Peak	% of Load Shifted Off-Peak	% of Load Remaining On-Peak	Capital Cost Requirements	% of Load On-Peak	% of Load Shifted Off-Peak	% of Load Remaining On-Peak	Capital Cost Requirements
6	45	100	0	\$621	45	90	4.5	\$392
9	61	100	0	\$1,410	61	82	11.0	\$851
12	73	100	0	\$2,000 (Base case assumption)	73	71	21.2	\$922

(a) The base case in this study assumed load-shifting for 12 hours with a \$0.10/kWh time-of-day rate differential. This led to an expected long-term market penetration of approximately 48%. The \$2,000 capital cost requirement is based on an earlier EPRI-sponsored study (see QLA 1986). All of the above cases assume a \$0.10/kWh time-of-day rate differential is offered by the sponsoring utility.

6.0 CONCLUSIONS AND RECOMMENDATIONS

The objective of this study was to estimate the market potential and expected market penetration for residential cool storage technology. There will be little demand for residential cool storage until utilities offer sufficient incentives to motivate homeowners to purchase these units. Several factors will influence the likely market penetration of residential cool storage: the cooling-degree-day requirements of a region, the time-of-day rate differential charged to households, price rebates offered to encourage purchase of these units, the first cost of the product, and whether the cool storage unit is being installed in a new or existing home.

6.1 MARKET POTENTIAL

Market potential is defined as the number of customers who might be able to benefit from the use of a product. For this study, market potential was defined as those households that would typically purchase either central air conditioning units or heat pump systems for their single-family dwellings. Market potential estimates for each of the four years used in projections included new housing construction per year as well as estimates of central air conditioning retrofits/modifications in existing housing. The estimates of market potential were as follows:

1995	2,050,000 units
2000	2,150,000 units
2005	2,240,000 units
2010	2,330,000 units.

6.2 MARKET PENETRATION

This study found that incentives must vary dramatically by region for residential cool storage units to be economically competitive to central air conditioning units. Assuming a \$2000 differential price for residential cool storage units, a TOD rate differential of only \$0.075/kWh would be required at 2000 cooling-degree-days (65-degree base) to make residential cool storage

economically competitive to central air conditioning. At 1000 cooling-degree-days, a TOD rate differential of approximately \$0.15/kWh would be required to make residential cool storage economically competitive to central air conditioning. Another option at 1000 cooling-degree-days is to offer a \$0.10/kWh TOD rate differential with a \$1000 rebate to make residential cool storage units economically competitive to central air conditioning. Residential cool storage units are not economically competitive at 500 cooling-degree-days. Very extreme price incentives would have to be offered to make residential cool storage units economically competitive with central air conditioning. This would require a \$0.20/kWh TOD price differential and a \$1000 price rebate.

An economic cost model was used to estimate the eventual market penetration of residential cool storage units. This model determined that the final market penetration will vary dramatically depending on the price incentives that are offered. Under the most likely scenario, a \$0.10/kWh TOD rate differential was used to derive an estimate of final market penetration. This analysis estimated that residential cool storage units would eventually capture about one-half of the central air conditioning market.

6.3 ESTIMATED UNIT SALES

Under the assumption that the above conditions are met, this study estimated future unit sales for this technology. These estimates were based on an historical analogy to the diffusion time required for the penetration of central A/C units. The estimated unit sales for the four target years are approximately as follows:

1995	60,000 units
2000	150,000 units
2005	300,000 units
2010	500,000 units.

If it is assumed that 2.5 kW of diversified demand are shifted per household, the estimated peak energy savings achieved from this technology in 1995, 2000, 2005, and 2010 are approximately 0.6, 1.9, 4.7, and 9.9 GWs per year, respectively. The largest markets for this technology would include Texas and Florida.

6.4 CAPITAL COST REQUIREMENTS

This study evaluated capital cost requirements for different peak period lengths and for load-shifting and load-leveling strategies to aid identification of optimum equipment configurations. This study found that incremental capital cost requirements for equipment designed to serve either 6-, 9-, or 12-hour peak periods under either load-shifting or load-leveling load management strategies varied dramatically. As an example, equipment designed for load-leveling for a 9-hour time period has an incremental capital cost requirement of \$851 over a conventional central air conditioning system. This compares to the \$2000 capital cost requirement established for the base case scenario (load-shifting for a 12-hour peak period).

This study also evaluated the effect of capital cost reductions on national electricity displacement by the year 2010 for 6-, 9-, and 12-hour load-shifting and load-leveling strategies. Figures 6.1 and 6.2 describe the effects of capital cost reductions on national electricity displacement by the year 2010 for load-shifting and load-leveling strategies, respectively. This study found that residential cool storage equipment could displace between 5 and 10 gigawatts of electricity by the year 2010. Each capital cost reduction of \$500 per unit will provide an additional 1 gigawatt of electricity displacement by the year 2010.

6.5 RECOMMENDATIONS

Finally, the researchers recommend that a more comprehensive consumer research study be conducted to estimate the likely market penetration of residential cool storage units. This study has focused on the economic factors that will be required to make this technology attractive to residential households. This assumes that households are only motivated by economic factors in the purchase of technology. In reality, this is not true. The purchase of a complex durable good is based on multiple product features. Issues of comfort, ease of use, and durability will likely have a significant impact on the final market share obtained by this technology. Tradeoff analysis methodologies used in consumer research should be used with this technology to develop

FIGURE 6.1. The Effect of Capital Cost Reductions on National Electricity Displacement by the Year 2010 for 6-, 9-, and 12-Hour Load-Shifting Strategies

FIGURE 6.2. The Effect of Capital Cost Reductions on National Electricity Displacement by the Year 2010 for 6-, 9-, and 12-Hour Load-Leveling Strategies

more precise estimates of the probable final penetration of residential cool storage units.

The researchers also recommend that hourly electric power consumption patterns for residential central air conditioning be studied. The current lack of understanding regarding consumption by individual residences, the coincidence of demand by multiple residences, and the coincidence of demand for air conditioning with total utility demand are factors that make it difficult to specify the true impact of residential chill storage on utility demand.

more precise estimates of the probable final penetration of residential cool storage units.

The researchers also recommend that hourly electric power consumption patterns for residential central air conditioning be studied. The current lack of understanding regarding consumption by individual residences, the coincidence of demand by multiple residences, and the coincidence of demand for air conditioning with total utility demand are factors that make it difficult to specify the true impact of residential chill storage on utility demand.

7.0 REFERENCES

- Air-Conditioning & Refrigeration Institute (ARI). 1986. Statistical Profile of the Air Conditioning, Refrigeration, and Heating Industry. Arlington, Virginia.
- Appliance. April 1988. "Factory Unit Shipments." Dana Chase Publications, Inc., Oak Brook, Illinois.
- Appliance. April 1981. "Factory Unit Shipments." Dana Chase Publications, Inc., Oak Brook, Illinois.
- Appliance. April 1972. "Factory Unit Shipments." Dana Chase Publications, Inc., Oak Brook, Illinois.
- Applied Economic Research Co., Inc. 1987. The Adequacy of U.S. Electricity Supply Through the Year 2000. Utility Data Institute, Washington, D.C.
- Brown, D. R., and G. E. Spanner. 1988. Cost and Performance Goals for Residential Cool Storage Systems. PNL-6647, Pacific Northwest Laboratory, Richland, Washington.
- Department of Energy. 1988. Ensuring National Electrical Adequacy for the the 1990s: The Need for Advanced Technologies. U.S. Department of Energy, Office of Energy Storage and Distribution, Washington, D.C.
- Energy Information Administration (EIA). 1987a. Annual Outlook for U.S Electric Power: Projections Through 2000. U.S. Department of Energy - Energy Information Administration, Washington, D.C.
- Energy Information Administration (EIA). 1987b. Residential Energy Consumption Survey: Consumption and Expenditures. U.S. Department of Energy - Energy Information Administration, Washington, D.C.
- Lawrence Berkeley Laboratory. 1986. PEAR 2.0 - Program for Energy Analysis of Residences. Lawrence Berkeley Laboratory, Berkeley, California.
- Metal Products Manufacturing. April 1963. "Factory Unit Shipments." Dana Chase Publications, Inc., Oak Brook, Illinois.
- QLA, Inc. 1986. Market Constraints for Residential Cool Storage Systems. EM-4722, Electric Power Research Institute, Palo Alto, California.
- Raju, P. S., and A. P. S. Teotia. 1985. An Evaluation of Market Penetration Forecasting Methodologies for New Residential and Commercial Energy Technologies. Argonne National Laboratory, Argonne, Illinois.

- Resource Planning Associates, Inc. 1982. Methods for Analyzing the Market Penetration of End-Use Technologies: A Guide for Utility Planners. EA-2702, Electric Power Research Institute, Palo Alto, California.
- Schiffel, D., et al. 1978. The Market Penetration of Solar Energy: A Model Review Workshop Summary. Solar Energy Research Institute. Golden, Colorado.
- U.S. Department of Commerce. 1987. Statistical Abstract of the United States. Bureau of the Census, Washington, D.C.
- U.S. Department of Commerce. 1985. Characteristics of New Housing. C25 Reports, Bureau of the Census, Washington, D.C.
- Warren, E. H., Jr. 1980. "Solar Energy Market Penetration Models: Science or Number Mysticism?" Technological Forecasting and Social Change. 16:105-118.
- Wind, Y., V. Mahajan, and R. N. Cardozo. 1984. New-Product Forecasting. Lexington Books, D.C. Heath and Company, Lexington, Massachusetts.

DISTRIBUTION

No. of
Copies

No. of
Copies

OFFSITE

U.S. Department of Energy
Attn: K. Klein
Office of Energy Storage & Dist.
Forrestal Bldg, CE-32 5E-036
Washington, DC 20585

U.S. Department of Energy
Attn: E. Reimers
Office of Energy Storage & Dist.
Forrestal Bldg, CE-32 5E-036
Washington, DC 20585

10 DOE/Office of Scientific
and Technical Information

ANCO Engineers, Inc.
Attn: D. M. Bruder
9937 Jefferson Blvd.
Culver City, CA 90232-3591

Argonne National Laboratory
Attn: A. Gorsky
Building 362
9700 S. Cass Avenue
Argonne, IL 60439

Arizona State University
Attn: D. G. Scheatzle
College of Architecture and
Environmental Design
Tempe, AZ 85287

Ayres Ezer Lau Consulting
Engineers
Attn: H. Lau
1180 S. Beverly Drive
Suite 600
Los Angeles, CA 90035

Baltimore Aircoil Co. Inc.
Attn: R. E. Cates
PO Box 7322
Baltimore, MD 21227

Baltimore Gas and Electric
Attn: A. J. Killeen
1508 Woodlawn Drive
Baltimore, MD 21207

Brown and Caldwell
Attn: E. Knipe
150 South Arroya Parkway
Pasadena, CA 91109

Calmac Manufacturing Corporation
Attn: C. D. MacCracken
PO Box 710
150 S. Van Brunt St.
Englewood, NJ 07631

Davis Energy Group Inc.
Attn: R. C. Bourne
123 C Street
Davis, CA 95616

District Heating Development Co.
Attn: H. Jaehne
76 W. Kellogg Blvd.
St. Paul, MN 55102-1161

Dorgan Associates, Inc.
Attn: J. S. Elleson
5610 Medical Circle
Suite 31
Madison, WI 53719

Electric Power Research Institute
Attn: D. Geistert
P.O. Box 10412
Palo Alto, CA 94303

No. of
Copies

Electric Power Research Institute
Attn: V. Rabl
P.O. Box 10412
Palo Alto, CA 94303

Electric Power Research Institute
Attn: R. Wendland
P.O. Box 10412
Palo Alto, CA 94303

H. C. Fischer
PO Box 445
Maggie Valley, NC 28751

Florida Power and Light Co.
Attn: R. W. Wilkins
PO Box 029100
9250 West Flagler St.
Miami, FL 33102

Florida Solar Energy Center
Attn: C. J. Cromer
300 State Road 401
Cape Canaveral, FL 32920-4099

Florida Solar Energy Center
Attn: M. K. Khattar
300 State Road 401
Cape Canaveral, FL 32920-4099

George Reeves Associates, Inc.
Attn: G. Reeves
34 McNabb Road
Lk. Hopatcong, NJ 07849

Walter Hauz
4520 Via Vistosa
Santa Barbara, CA 93110

Institute of Gas Technology
Attn: J. O'Sullivan
3424 S. State
Chicago, IL 60612

No. of
Copies

Lennox Industries Inc.
Attn: R. E. Cawley
PO Box 877
Carrollton, TX 75011-0877

Lennox Industries Inc.
Attn: T. C. Gilles
PO Box 809000
Dallas, TX 75380-9000

Lennox Industries, Inc.
Attn: M. Michel
PO Box 809000
Dallas, TX 75380-9000

Charles F. Meyer
1141 Cima Linda Lane
Santa Barbara, CA 93108

New York State Energy
Research & Development
Agency
Attn: G. Walmet
Rockefeller Plaza
Albany, NY 12223

Northern States Power Company
Attn: W. Reder
414 Nicollet Mall
Minneapolis, MN 55401

Oak Ridge National Laboratory
Attn: M. Taylor
Building 9204-1, MS 8045
Y-12 Plant, Box 2009
Oak Ridge, TN 37831-8045

Oak Ridge National Laboratory
Attn: J. Tomlinson
Building 9204-1, MS 8045
Y-12 Plant, Box 2009
Oak Ridge, TN 37831-8045

No. of
Copies

Office of Congressman
Sid Morrison
Attn: Kevin Billings,
Legislative Asst.
1330 Longworth Bldg.
Washington, DC 20515

Office of Congressman
Tom Beville
2302 Rayburn Bldg.
Washington, DC 20515

Pacific Gas and Electric Co.
Attn: J. M. Yokoe
123 Mission Street
Room H-2656
San Francisco, CA 94106

Powell Energy Products, Inc.
Attn: D. P. Hart
PO Box 203
3041 Home Rd.
Powell, OH 43065-0203

Public Service Electric and
Gas Company
Attn: D. A. Pandya
80 Park Plaza
Newark, NJ 07101

Resource Efficiency, Inc.
Attn: Mark Spurr
340 Daly Street
St. Paul, MN 55102

Sacramento Municipal Utility
District
Attn: R. H. Kallett
PO Box 15830
6201 S Street, M.S. 73
Sacramento, CA 95852-1830

Salt River Project
Attn: W. F. James
PO Box 52025
Phoenix, AZ 85072-2025

No. of
Copies

Science Applications International
Corporation
Attn: R. H. Sterrett
10260 Campus Point Drive
San Diego, CA 92121

Southern California Edison
Attn: E. Steudtner
PO Box 800
2131 Walnut Grove Avenue
Room 157, G.O.3
Rosemead, CA 91770

South Carolina Electric and
Gas Company
Attn: C. P. Thomas-105
PO Box 764
Columbia, SC 29218

The North Carolina Alternative
Energy Corporation
Attn: D. R. Ferguson
PO Box 12699
Research Triangle Park, NC 27709

Thermal Energy Storage Inc.
Attn: V. J. Ott
PO Box 2033
Del Mar, CA 92014

TUELECTRIC
Attn: K. Schneider
1506 Commerce St.
Dallas, TX 75201

Turbo Refrigerating Co.
Attn: D. E. Knebel
PO Box 396
1815 Shady Oaks Drive
Denton, TX 76202

UHR Corporation
Attn: C. W. Uhr, Jr.
4562 Eisenhower Ave.
Alexandria, VA 22304

No. of
Copies

University of Alabama
Attn: E. Brett
School of Mines and Energy
Development
Box 6282
University, AL 35486

University of Massachusetts
at Amherst
Attn: D. Breger
Dept. of Mechanical Eng.
Eng. Laboratory Bldg.
Amherst, MA 01003

University of Massachusetts
at Amherst
Attn: J. E. Sunderland
Dept. of Mechanical Eng.
Eng. Laboratory Bldg.
Amherst, MA 01003

University of Minnesota
Attn: R. L. Sterling
Underground Space Center
Dept. of Civil and Mineral Eng.
790 Civil and Mineral Eng Bldg
Minneapolis, MN 55455

US Army Corps of Engineers
Construction Engineering
Research Laboratory
Attn: C. W. Sohn
PO Box 4005
Champaign, IL 61820-1305

US Department of Interior
Attn: Natural Resources
Library
Serials Branch (G/E)
Washington, DC 20240

Wehran Engineering
Attn: R. Miller
PO Box 2006
666 E. Main St.
Middletown, NY 10940

No. of
Copies

Wilke and Associates
Attn: D. Wilke
38 Roosevelt Avenue
Glen Head, NY 11545

FOREIGN

Bengt Hidemark Gosta Danielson
Arkitekter SAR
Attn: A. Boysen
Jarntorget 78
S-11 29 Stockholm
Sweden

Deutsche Forschungs- und
Versuchsanstalt fuer
Luft- und Raumfahrt
Attn: M. Becker
Linder Hoehe
D-5000 Koeln 90,
West Germany

Deutsche Forschungs- und
Versuchsanstalt fuer
Luft- und Raumfahrt
Attn: R. Tamme
Pfaffenwaldring 38
D-7000 Stuttgart 80
West Germany

Laboratory for Energetics
Attn: B. Qvale
Technical University of Denmark
DK-2800 Lyngby
Denmark

Ministry of Trade and Industry
Attn: Pirjo-Liisa Vainio
Energy Department
POHJ. Makasiinikatu 6
SF-00130 Helsinki 13
Finland

No. of
Copies

Public Works of Canada
Attn: E. L. Morofsky
C456 Sir Charles Tupper Bldg.
Riverside Dr. and Heron Rd.
Ottawa, Ontario
K1A 0M2 Canada

Swedish Council for Building
Research
Attn: S-E. Lundin
St. Goransgatan 66
S-112 33 Stockholm
Sweden

Swedish Council for Building
Research
Attn: W. Raldow
St. Goransgatan 66
S-112 33 Stockholm
Sweden

No. of
Copies

ONSITE

DOE Richland Operations Office

J. J. Sutey

33 Pacific Northwest Laboratory

R. C. Adams
J. M. Bates
D. R. Brown (5)
M. K. Drost
C. H. Imhoff
L. D. Kannberg (10)
G. E. Spanner
R. O. Weijs (5)
T. A. Williams
Technical Report Files (5)
Publishing Coordination (2)

Public Works of Canada		No. of	No. of
Attn: E. L. Horvath		Copies	Copies
Case 524 Charles Turner Bldg.			
Riverside Dr. and Heron Rd.			
Ottawa, Ontario			
KIA 0M2 Canada			
Swedish Council for Building			
Research			
Attn: S-E. Lundin			
SE. Gornsgatan 60			
S-112 33 Stockholm			
Sweden			
Swedish Council for Building			
Research			
Attn: W. Rabow			
SE. Gornsgatan 60			
S-112 33 Stockholm			
Sweden			
33 Pacific Northwest Laboratory			
J. J. Suley			
DOE Richland Operations Office			
ONSTE			
R. C. Adams			
J. M. Bates			
D. R. Brown (5)			
M. K. Frost			
C. W. Ignoffo			
L. O. Kunkin (10)			
G. E. Spawny			
R. O. Wertz (5)			
I. A. Williams			
Technical Report Files (5)			
Publishing Coordination (2)			