WSRC-TR-92-069

**RESPONSE OF DWPF THERMAL FLOWMETERS TO
COMPOSITION CHANGE - EFFECT ON O₂ DETERMINATION
IN SALT PROCESS CELL (U)**

by R. A. Jacobs

Westinghouse Savannah River Company
Savannah River Site
Aiken, South Carolina 29808

WSRC-TR--92-069

DE93 008508

Other Authors:

This paper was prepared in connection with work done under Contract No. DE-AC09-89SR18035 with the U. S. Department of Energy. By acceptance of this paper, the publisher and/or recipient acknowledges the U. S. Government's right to retain a nonexclusive, royalty-free license in and to any copyright covering this paper, along with the right to reproduce and to authorize others to reproduce all or part of the copyrighted paper.

REPRODUCTION OF THIS DOCUMENT IS UNLIMITED

EB
MASTER

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831; prices available from (615) 576-8401, FTS 626-8401.

Available to the public from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

RECEIVED

DEC 01 1993

OSTI

Westinghouse
Savannah River Company

INTER-OFFICE MEMORANDUM

WSRC-TR-92-0069

Keywords: DWPF, benzene,
Salt Process Cell,
precipitate hydrolysis,
air inleakage

Retention period: Permanent

cc: J. T. Carter, 704-1T
L. F. Landon, 704-T
M. A. Baich, 704-T
D. P. Lambert, 704-1T
J. C. Marek, 704-T
J. A. Ritter, 704-1T
H. B. Shah, 704-1T
S. R. Young, 704-1T
J. R. Zamecnik, 704-1T
SRL Records (4)*

February 3, 1992

TO: E. W. HOLTZSCHEITER, 773-A

FROM: R. A. JACOBS, 704-T

SRL
REFERENCE COPY

RESPONSE OF DWPF THERMAL FLOWMETERS TO COMPOSITION CHANGE -
EFFECT ON O2 DETERMINATION IN SALT PROCESS CELL (U)

Summary and Conclusions

Thermal flowmeters (more accurately described as hot wire anemometers) have been installed in the Salt Process Cell (SPC) to measure in-cell process flows. In conjunction with purge flow meters in the third level corridor, it was initially planned to use these meters to estimate the air inleakage and O2 concentration in each vessel system. The overall balance would be confirmed using a thermal flowmeter and O2 analyzer located at the exit of the Salt Cell Vent Condenser (SCVC).

C. T. Randall, 704-T
Authorized Derivative Classifier

When this methodology was looked at more closely to assess the accuracy of the estimates, the effect of changing vapor compositions on indicated vs actual flow was considered. In many vapor/gas flowmeters, correcting for composition is simple and even "rough" estimates of gas composition are sufficient to yield adequate results. However, upon investigating the effect of composition on thermal flow meters, it was concluded that determining a priori correction factors is a very complicated process requiring fairly precise knowledge of the vapor composition and the meter characteristics. In fact, one thermal flow meter manufacturer (Kurz) maintains that corrections can only be determined by calibration with the actual gas/vapor compositions. Other types of flow meters (orifice/ ΔP , vortex shedding, turbine, etc.) were considered and rejected, principally due to the large pressure drop occurring at the periodic high flow rates associated with the HAN process.

It is recommended that DWPF

- estimate air inleakage using a test procedure similar to one being developed in the Precipitate Hydrolysis Experimental Facility (PHEF)[†] which circumvents the correction problem by *in situ* calibration, and
- develop a profile which characterizes air inleakage as a function of ΔP to be used in conjunction with the inleakage test procedure.

The recommended test procedure has some distinct advantages over the simple material balance approach. More detailed information on the characteristics of thermal flow meters, the recommended air inleakage test procedure, and the inleakage profile are discussed below.

Discussion

Background

The SPC contains four vessel (diagram attached) systems which are maintained at a vacuum relative to the cell and which all vent through the SCVC:

- the Precipitate Reactor Feed Tank (PRFT),
- the Precipitate Reactor (PR) and PR Condenser/Decanter (PRCD),
- the Organic Evaporator (OE) and OE Condenser/Decanter (OECD), and
- the OE Condensate Tank (OECT).

[†] This procedure is being developed by H. B. Shah and S. R. Young and will be document in a future report.

The vacuum results in air leaking into the process vessels. Since the precipitate hydrolysis process produces a fuel (benzene), the vessels in the SPC have been designed to minimize air inleakage and each of the vessel systems has its own inert purge flow addition meter and in-process thermal flow meter located on the vent of the vessel system. Also, there is a flow meter and O₂ analyzer on the common vent line at the exit of the SCVC.

While the common O₂ analyzer can assure that sufficient inert is added for the total air inleakage, it cannot guarantee that each vessel system is adequately purged. If it were assumed that all the air inleakage (as determined at the SCVC) were into one system and sufficient inert added to each system for that leakage, then excessive benzene emissions would result. To assure that each system is safe and to minimize benzene emissions, it was intended to estimate the air inleakage on each system by doing a simple material balance using the purge and in-process flow meters.

Thermal Flowmeters

Thermal flow meters are hot wire anemometers and work on the fundamental principle of measuring the heat loss from a hot wire to the flowing gas. For a given meter and gas composition, the heat loss is measured by the current in the wire and is a non-linear function of velocity only. However if the composition of the gas varies, the velocity of the gas as a function of wire current is [1]

$$u = \frac{\left(\frac{I^2 R_w}{\Delta t}\right)^2 - 0.76 k_f \left(\frac{I^2 R_w}{\Delta t}\right) [N_{Pr}]_f^{0.2} K_1}{\rho_f K_2 \sqrt[3]{(C_p)_f^2 k_f^4 / \mu_f}} + \frac{k_f^2 [(0.38 [N_{Pr}]_f^{0.2})^2 - (0.25 ([N_{Gr}]_f [N_{Pr}]_f)^{1/8} + 0.45 ([N_{Gr}]_f [N_{Pr}]_f)^{1/4})^2] K_1^2}{\rho_f K_2 \sqrt[3]{(C_p)_f^2 k_f^4 / \mu_f}}$$

Where

- C_p = specific heat, B.t.u./lb-°F
- D = diameter, ft
- g = acceleration due to gravity, ft/hr²
- I = electrical current flowing through wire, mamp.
- k = thermal conductivity, B.t.u./hr-ft-°F
- K_1, K_2 = constants
- NGr = Grashof number, $(g \rho^2 D^3 \beta \Delta t / \mu^2)$

N_{Pr} = Prandtl number, $(C_p \mu / k)$
 R_w = wire resistance, ohms
 t = temperature, °F
 u = fluid velocity, ft/sec
 β' = coefficient of expansion of gas, $1/^\circ R$
 μ = fluid viscosity, lb/ft-hr
 ρ = fluid density, lb/ft³

Subscripts

f = mean (arithmetic) film
 w = wire

In addition to this complex correlation, calculations are further complicated by the fact that the thermal conductivity and viscosity of gas mixtures are in themselves rather complex functions of the pure component properties. [2] A calculational method using information from reference 1 and expected PHEF and DWPF compositions was developed. Copies of the calculations are contained in Reference 3.

In conversations with Mr. Greg Ochs, technical representative of Fluidic Components Incorporated (FCI), he indicated that actual vs indicated readings do, in fact, vary widely with gas composition and are complicated functions of density, thermal conductivity, viscosity, heat capacity, and compressibility at elevated pressures. FCI has developed a proprietary capability to estimate correction factors from known compositions. A comparison shows:

Table 1

	<u>Gas Composition - volume fraction</u>			
	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>
Component:				
Air	0.05	0.05	0.286	0.025
CO ₂	0	0	0.714	0.815
N ₂	0.81	0.86	0	0
N ₂ O	0.07	0.07	0	0.10
Benzene	0.07	0.02	0	0.06
Factor per FCI:	1.142*	1.078*	0.923**	1.030**
Factor by author:	1.182*	1.074*	0.817**	1.006**

* Meter calibrated for air

**Meter calibrated for CO₂

The estimates for a N₂ purged system (mixtures 1 and 2) are quite close while those for CO₂ dominated mixtures (3 and 4) are in the same direction but have larger differences. Further discussions with Mr. Ochs did not elucidate the reasons for the larger

differences with CO₂. PHEF data was also analyzed and compared to correction factors estimated by the author with similar results.

Test Procedure to Determine Air Inleakage

After considerable effort trying to develop a method for correcting actual vs indicated readings, the concept of a test procedure which completely circumvents the composition induced errors of the thermal flowmeter was formed (actually, it is a variation of a test procedure suggested by Mike Sodaro, formerly of DNPF-Technical). The principal is: calibrate the meter in place for the flowing gas by changing the volumetric flow by a known amount. This is followed by obtaining a reading at a different air inleakage rate caused by changing the process operating pressure. An example of such a test is:

- The test starts at quiescent conditions in the process vessels; the flow through the in-process (thermal) meter is essentially the sum of the purge flow plus the air inleakage at the current process operating pressure. Assume the CO₂ purge is 2.0 scfm (0°C & 14.7 psia) = 14.71 lbs/hr and the air inleakage is 0.5 scfm = 2.42 lbs/hr.; therefore, the O₂ concentration is 4.2%. Also, assume the thermal flowmeter reads (incorrectly) 18.8 lbs/hr. and the process pressure is -3.5"wc relative to the cell.
- The next step is to increase the CO₂ purge rate, say to 4.0 scfm. As soon as the process pressure settles out at -3.5"wc, read the thermal flow meter and immediately return the purge flow to the original setting. (NOTE: All steps not at the original, quiescent conditions need to be done as quickly as possible so that the composition/density of the gas flowing through the meter does not change.) Say the thermal meter reading at the increased purge rate is 37.2 lbs/hr. If the process vessel temperature is 35°C, this step shows that the meter response to a change in flow is

$$\frac{(37.2 - 18.8) \text{ lbs/hr}}{(4.0 - 2.0) \text{ ft}^3/\text{min} \times \frac{308^\circ\text{K}}{273^\circ\text{K}}} = 8.155 \text{ lbs/hr per acfm}$$

- The third step is to change the air inleakage by changing the process pressure. Assume the meter still reads 18.8 lbs/hr at -3.5"wc and reads 22.8 lbs/hr at -12.1"wc. From the previous step, the change in flow at the meter is

$$\frac{(22.8 - 18.8) \text{ lbs/hr}}{8.155 \text{ lbs/hr per acfm}} = 0.4905 \text{ ft}^3/\text{min}$$

- The final step is to calculate the initial air inleakage from the previous result. Assuming turbulent flow (that is, flow $\propto \sqrt{\Delta P}$), then it can be shown that the initial air leakage is

$$\frac{0.4905 \text{ ft}^3/\text{min}}{\sqrt{\frac{12.1}{3.5}} - 1} = 0.5708 \text{ ft}^3/\text{min}$$

NOTE: The flow may not be turbulent, see discussion of inleakage profile.

Correcting back to standard conditions, the calculated quiescent air leakage is

$$0.5708 * \frac{273^\circ\text{K}}{308^\circ\text{K}} = 0.506 \text{ scfm}$$

and the calculated O₂ concentration is

$$\frac{21\% * 0.506 \text{ scfm}}{0.506 \text{ scfm} + 2.0 \text{ scfm}} = 4.24\% \text{ O}_2$$

Test Procedure Advantages

This test procedure has two distinct advantages over the material balance approach (that is, using the flow meter readings at quiescent conditions):

- the results will be correct even if the thermal flow meter is out of calibration, and
- presence of other components (such as benzene) are automatically compensated for. Thus, they are not counted as air which would require additional, unnecessary purge flows resulting in increased benzene emissions.

Inleakage Profile

The above example assumes the flow through the points of leakage is turbulent. However, for low ΔP 's and for flows through slits, the flow could very well be laminar; in which case flow is $\propto \Delta P$. The exponent for the ΔP term could range anywhere from 1.0 (laminar) to 0.5 (turbulent). It will be necessary to characterize the air inleakage as a function of ΔP to use in the final calculation step. Probably the simplest way to establish this information would be to gather data on flow through the various thermal flow meters over a range of ΔP 's with no inert flow to the vessels; that is, there would be no change in

composition at the flow meters during the course of the characterization. The inleakage profile should probably be determined any time equipment in the SPC has been disassembled . . . bulk air leakage will have to be checked after each disassembly anyway.

References

1. W. T. Wasan, R. M. Davis, and C. R. Wilke, MEASUREMENT OF THE VELOCITY OF GASES WITH VARIABLE FLUID PROPERTIES, AIChE Journal, Vol. 14, No.2, March 1968, 1986.
2. R. C. Reid, J. M. Prausnitz, and T. K. Sherwood, THE PROPERTIES OF GASES AND LIQUIDS, McGraw Hill, 1977.
3. R. A. Jacobs, THERMAL FLOWMETER CALCULATIONS, SRL-PTD-92-0007, February 3, 1992.

Diagram of Precipitate Hydrolysis ProcessPRECIPITATE HYDROLYSIS PROCESS (PHP)

END

**DATE
FILMED**

4 129193