

ENERGY LABORATORY

MASSACHUSETTS INSTITUTE  
OF TECHNOLOGY

DOE/ET/37218-2

Development of a Model to Predict  
Flow Oscillations in Low-Flow Sodium Boiling

by

Alan E. Levin  
Peter Griffith

Energy Laboratory Report No. MIT-EL-80-006

April 1980



There is no objection from the patent  
point of view to the publication or  
dissemination of the document(s)  
referred to in this letter.

BY PATENT ADVISORY PATENT GROUP  
4/5/81 BY *gpl*

## **DISCLAIMER**

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**

**MASTER**

Development of a Model to Predict  
Flow Oscillations in Low-Flow Sodium Boiling

by

Alan E. Levin  
Peter Griffith

Energy Laboratory Report No. MIT-EL-80-006

April 1980

**DISCLAIMER**

This book was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

MGW

REPORTS IN REACTOR THERMAL HYDRAULICS RELATED TO THE  
MIT ENERGY LABORATORY ELECTRIC POWER PROGRAM

- A. Topical Reports (For availability check Energy Laboratory Headquarters, Room E19-439, MIT, Cambridge, Massachusetts, 02139)
- A.1 General Applications  
A.2 PWR Applications  
A.3 BWR Applications  
A.4 LMFBR Applications
- A.1 M. Massoud, "A Condensed Review of Nuclear Reactor Thermal-Hydraulic Computer Codes for Two-Phase Flow Analysis," MIT Energy Laboratory Report MIT-EL-79-018, February 1979.
- J.E. Kelly and M.S. Kazimi, "Development and Testing of the Three Dimensional, Two-Fluid Code THERMIT for LWR Core and Subchannel Applications," MIT Energy Laboratory Report MIT-EL-79-046, December 1979.
- A.2 P. Moreno, C. Chiu, R. Bowring, E. Khan, J. Liu, N. Todreas, "Methods for Steady-State Thermal/Hydraulic Analysis of PWR Cores," MIT Energy Laboratory Report MIT-EL-76-006, Rev. 1, July 1977 (Orig. 3/77).
- J.E. Kelly, J. Loomis, L. Wolf, "LWR Core Thermal-Hydraulic Analysis--Assessment and Comparison of the Range of Applicability of the Codes COBRA-IIIC/MIT and COBRA IV-1," MIT Energy Laboratory Report MIT-EL-78-026, September 1978.
- J. Liu, N. Todreas, "Transient Thermal Analysis of PWR's by a Single Pass Procedure Using a Simplified Model Layout," MIT Energy Laboratory Report MIT-EL-77-008, Final, February 1979, (Draft, June 1977).
- J. Liu, N. Todreas, "The Comparison of Available Data on PWR Assembly Thermal Behavior with Analytic Predictions," MIT Energy Laboratory Report MIT-EL-77-009, Final, February 1979, (Draft, June 1977).
- A.3 L. Guillebaud, A. Levin, W. Boyd, A. Faya, L. Wolf, "WOSUB-A Subchannel Code for Steady-State and Transient Thermal-Hydraulic Analysis of Boiling Water Reactor Fuel Bundles," Vol. II, Users Manual, MIT-EL-78-024. July 1977.

- L. Wolf, A Faya, A. Levin, W. Boyd, L. Guillebaud, "WOSUB-A Subchannel Code for Steady-State and Transient Thermal-Hydraulic Analysis of Boiling Water Reactor Fuel Pin Bundles," Vol. III, Assessment and Comparison, MIT-EL-78-025, October 1977.
- L. Wolf, A. Faya, A. Levin, L. Guillebaud, "WOSUB-A Subchannel Code for Steady-State Reactor Fuel Pin Bundles," Vol. I, Model Description, MIT-EL-78-023, September 1978.
- A. Faya, L. Wolf and N. Todreas, "Development of a Method for BWR Subchannel Analysis," MIT-EL-79-027, November 1979.
- A. Faya, L. Wolf and N. Todreas, "CANAL User's Manual," MIT-EL-79-028, November 1979.
- A.4 W.D. Hinkle, "Water Tests for Determining Post-Voiding Behavior in the LMFBR," MIT Energy Laboratory Report MIT-EL-76-005, June 1976.
- W.D. Hinkle, Ed., "LMFBR Safety and Sodium Boiling - A State of the Art Reprot," Draft DOE Report, June 1978.
- M.R. Granziera, P. Griffith, W.D. Hinkle, M.S. Kazimi, A. Levin, M. Manahan, A. Schor, N. Todreas, G. Wilson, "Development of Computer Code for Multi-dimensional Analysis of Sodium Voiding in the LMFBR," Preliminary Draft Report, July 1979.
- M. Granziera, P. Griffith, W. Hinkle (ed.), M. Kazimi, A. Levin, M. Manahan, A. Schor, N. Todreas, R. Vilim, G. Wilson, "Development of Computer Code Models for Analysis of Subassembly Voiding in the LMFBR," Interim Report of the MIT Sodium Boiling Project Covering Work Through September 30, 1979, MIT-EL-80-005.
- A. Levin and P. Griffith, "Development of a Model to Predict Flow Oscillations in Low-Flow Sodium Boiling," MIT-EL-80-006, April 1980.
- M.R. Granziera and M. Kazimi, "A Two Dimensional, Two Fluid Model for Sodium Boiling in LMFBR Assemblies," MIT-EL-80-011, May 1980.
- G. Wilson and M. Kazimi, "Development of Models for the Sodium Version of the Two-Phase Three Dimensional Thermal Hydraulics Code THERMIT," MIT-EL-80-010, May 1980.

B. Papers

- B.1 General Applications
- B.2 PWR Applications
- B.3 BWR Applications
- B.4 LMFBR Applications

- B.1 J.E. Kelly and M.S. Kazimi, "Development of the Two-Fluid Multi-Dimensional Code THERMIT for LWR Analysis," accepted for presentation 19th National Heat Transfer Conference, Orlando, Florida, August 1980.

J.E. Kelly and M.S. Kazimi, "THERMIT, A Three-Dimensional, Two-Fluid Code for LWR Transient Analysis," accepted for presentation at Summer Annual American Nuclear Society Meeting, Las Vegas, Nevada, June 1980.

- B.2 P. Moreno, J. Kiu, E. Khan, N. Todreas, "Steady State Thermal Analysis of PWR's by a Single Pass Procedure Using a Simplified Method," American Nuclear Society Transactions, Vol. 26

P. Moreno, J. Liu, E. Khan, N. Todreas, "Steady-State Thermal Analysis of PWR's by a Single Pass Procedure Using a Simplified Nodal Layout," Nuclear Engineering and Design, Vol. 47, 1978, pp. 35-48.

C. Chiu, P. Moreno, R. Bowring, N. Todreas, "Enthalpy Transfer Between PWR Fuel Assemblies in Analysis by the Lumped Subchannel Model," Nuclear Engineering and Design, Vol. 53, 1979, 165-186.

- B.3 L. Wolf and A. Faya, "A BWR Subchannel Code with Drift Flux and Vapor Diffusion Transport," American Nuclear Society Transactions, Vol. 28, 1978, p. 553.

- B.4 W.D. Hinkle, (MIT), P.M. Tschamper (GE), M.H. Fontana, (ORNL), R.E. Henry (ANL), and A. Padilla, (HEDL), for U.S. Department of Energy, "LMFBR Safety & Sodium Boiling," paper presented at the ENS/ANS International Topical Meeting on Nuclear Reactor Safety, October 16-19, 1978, Brussels, Belgium.

M.I. Autruffe, G.J. Wilson, B. Stewart and M. Kazimi, "A Proposed Momentum Exchange Coefficient for Two-Phase Modeling of Sodium Boiling," Proc. Int. Meeting Fast Reactor Safety Technology, Vol. 4, 2512-2521, Seattle, Washington, August 1979.

M.R. Granziera and M.S. Kazimi, "NATOF-2D: A Two Dimensional Two-Fluid Model for Sodium Flow Transient Analysis," Trans. ANS, 33, 515, November 1979.

## NOTICE

This report was prepared as an account of work sponsored by the United States Government and two of its subcontractors. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.



DEVELOPMENT OF A MODEL TO PREDICT  
FLOW OSCILLATIONS IN LOW-FLOW SODIUM BOILING

by

Alan E. Levin  
Peter Griffith

Energy Laboratory,  
Department of Nuclear Engineering and  
Department of Mechanical Engineering

Massachusetts Institute of Technology  
Cambridge, Massachusetts 02139

Topical Report of the  
MIT Sodium Boiling Project

sponsored by

U. S. Department of Energy,  
General Electric Co. and  
Hanford Engineering Development Laboratory

Energy Laboratory Report No. MIT-EL-80-006

April 1980





ABSTRACT

An experimental and analytical program has been carried out in order to better understand the cause and effect of flow oscillations in boiling sodium systems. These oscillations have been noted in previous experiments with liquid sodium, and play an important part in providing cooling during Loss-of-Piping Integrity (LOPI) accidents that have been postulated for the Liquid Metal-Cooled Fast Breeder Reactor.

The experimental program involved tests performed in a small scale water loop. These experiments showed that voiding oscillations, similar to those observed in sodium, were present in water, as well. An analytical model, appropriate for either sodium or water, was developed and used to describe the water flow behavior.

The results of the experimental program indicate that water can be successfully employed as a sodium simulant, and further, that the condensation heat transfer coefficient varies significantly during the growth and collapse of vapor slugs during oscillations. It is this variation, combined with the temperature profile of the unheated zone above the heat source, which determines the oscillatory behavior of the system.

The analytical program has produced a model which qualitatively does a good job in predicting the flow behavior in the wake experiment. Quantitatively, there are some discrepancies between the predicted and observed amplitudes of the oscillations. These discrepancies are attributable both to uncertainties in the experimental measurements and inadequacies in modelling the behavior of the condensation heat transfer coefficient. Currently,

several parameters, including the heat transfer coefficient, unheated zone temperature profile, and amount of mixing between hot and cold fluids during oscillations, are set by the user, and have a deterministic effect on the behavior of the model.

Additionally, criteria for the comparison of water and sodium experiments have been developed. These criteria have not been fully tested.

Several recommendations for future study are proposed, in order to advance the capability of modelling the phenomena observed.

#### ACKNOWLEDGEMENT

Funding for this project was provided by the United States Department of Energy, the General Electric Co., and the Hanford Engineering Development Laboratory. This support was deeply appreciated.

The authors also thank Dr. William Hinkle and Prof. Neil Todreas for their helpful suggestions, Messrs. Joseph Caloggero and Fred Johnson for their help in acquiring materials for and constructing the Water Test Loop, and Messrs. Chris Mulcahy and Lee Shermelhorn for their help with the data acquisition system.

The work described in this report was performed primarily by the principal author, Alan E. Levin, who has submitted the same report in partial fulfillment for the ScD degree in Nuclear Engineering at MIT.

TABLE OF CONTENTS

|  | <u>PAGE</u> |
|--|-------------|
| Title Page . . . . .   | 3           |
| Abstract . . . . .   | 4           |
| Acknowledgements . . . . .   | 6           |
| Table of Contents . . . . .  | 7           |
| List of Figures . . . . .  | 12          |
| List of Tables . . . . .   | 15          |
| Nomenclature . . . . .   | 16          |
| CHAPTER 1: INTRODUCTION . . . . .  | 20          |
| 1.1 Background . . . . .   | 20          |
| 1.2 Scope of the Work . . . . .  | 22          |
| CHAPTER 2: THE ANALYTICAL MODEL . . . . .                                      | 27          |
| 2.1 Overall Concept . . . . .  | 27          |
| 2.2 The Hydrodynamic Model . . . . .   | 28          |
| 2.3 The Thermal Model . . . . .  | 33          |
| 2.4 Solution of the Equations . . . . .  | 36          |
| 2.5 Limitations of the Model . . . . .   | 41          |
| CHAPTER 3: CRITERIA FOR THE COMPARISON OF BOILING<br>SODIUM TO WATER . . . . . | 43          |
| 3.1 Background . . . . .   | 43          |
| 3.2 Momentum Equations . . . . .   | 45          |
| 3.3 The Compressibility Equation . . . . .                                     | 47          |
| 3.4 The Energy Equation . . . . .  | 49          |

TABLE OF CONTENTS (Cont.)

|   | <u>PAGE</u> |
|---|-------------|
| 3.5 Comparison of Sodium Data to Water Data . . .                           | 52          |
| CHAPTER 4: EXPERIMENTAL APPARATUS AND<br>PROCEDURES . . . . .               | 53          |
| 4.1 Background and Experimental Apparatus . . .                             | 53          |
| 4.2 Experimental Set-up and Procedure . . . . .                             | 62          |
| 4.2.1 Pretest Set-up and Calibration . . . . .                              | 62          |
| 4.2.2 Experimental Procedure . . . . .                                      | 64          |
| 4.2.2.1 Stagnant Flow Tests . . . . .                                       | 64          |
| 4.2.2.2 Forced Convection Testing . . . . .                                 | 67          |
| 4.3 Safety Precautions . . . . .  | 68          |
| CHAPTER 5: EXPERIMENTAL AND ANALYTICAL RESULTS. . .                         | 70          |
| 5.1 Experimental Results . . . . .  | 70          |
| 5.1.1 Stagnant Flow Tests . . . . .   | 70          |
| 5.1.1.1 Data Analysis . . . . .   | 70          |
| 5.1.1.2 Test 4 . . . . .  | 73          |
| 5.1.1.3 Test 5 . . . . .  | 77          |
| 5.1.1.4 Test 6 . . . . .  | 81          |
| 5.1.1.5 Test 7 . . . . .  | 85          |
| 5.1.1.6 Tests 8 and 9 . . . . .   | 85          |
| 5.1.2 Forced Convection Testing . . . . .                                   | 92          |
| 5.1.3 Sources of Error and Uncertainties<br>in Experimental Tests . . . . . | 94          |



TABLE OF CONTENTS (Cont.)

|   | <u>PAGE</u> |
|---|-------------|
| 5.1.3.1 Stagnant Flow Tests . . . . .                                       | 95          |
| 5.1.3.2 Forced Convection Testing . . . . .                                 | 96          |
| 5.1.3.3 Other Sources of Error . . . . .                                    | 97          |
| 5.1.4 Calculation of Condensation Heat<br>Transfer Coefficient . . . . .    | 98          |
| 5.1.5 Comparison of Water Data to<br>Sodium Data . . . . .                  | 101         |
| 5.2 Analytical Results . . . . .  | 103         |
| 5.2.1 Features of Analytical Simulations . .                                | 104         |
| 5.2.2 Comparison of Analytical and Experi-<br>mental Test Results . . . . . | 114         |
| CHAPTER 6: CONCLUSIONS AND RECOMMENDATIONS FOR<br>FUTURE STUDY . . . . .    | 131         |
| 6.1 Conclusions . . . . .   | 131         |
| 6.2 Recommendations for Future Work . . . . .                               | 132         |
| REFERENCES . . . . .  | 135         |
| APPENDIX A: The Computer Code FLOSS . . . . .                               | 138         |
| A.1 General Description . . . . .   | 138         |
| A.2 Solution of the Hydrodynamic and<br>Thermal Models . . . . .            | 138         |
| A.2.1 The Hydrodynamic Model . . . . .                                      | 139         |
| A.2.2 The Thermal Model . . . . .   | 141         |
| A.3 The Structure of the Code . . . . .                                     | 141         |

TABLE OF CONTENTS (Cont.)

|  | <u>PAGE</u> |
|--|-------------|
| A.3.1 FLOSS-MAIN Program. . . . .  | 141         |
| A.3.2 Subroutine HYDRO. . . . .  | 143         |
| A.3.3 Subroutine HEAT. . . . .   | 143         |
| A.3.4 Subroutine AREA. . . . .   | 145         |
| A.3.5 Subroutine HTCOEF. . . . .   | 145         |
| A.3.6 Subroutine PGUESS. . . . .   | 146         |
| A.3.7 Subroutine RESIN. . . . .  | 148         |
| A.3.8 Subroutine FFACTR. . . . .   | 148         |
| A.3.9 Subroutine PROP . . . . .  | 150         |
| A.3.10 Subroutine PLOTTER. . . . .   | 150         |
| A.4 Restrictions on Code Use. . . . .  | 150         |
| APPENDIX B: Description and Use of the Computer<br>Controlled Data Acquisition System. . . | 152         |
| B.1 Background. . . . .  | 152         |
| B.2 Hardware. . . . .  | 152         |
| B.3 Software. . . . .  | 155         |
| B.4 Operation of the CCDAS. . . . .  | 158         |
| APPENDIX C: Example of Experimental Results. . . . .                                       | 161         |
| C.1 Data Conversion and Presentation. . . . .  | 161         |
| APPENDIX D: Calculation of Condensation Heat<br>Transfer Coefficients. . . . .             | 171         |
| D.1 Calculational Method. . . . .  | 171         |

TABLE OF CONTENTS (Cont.)

|   | <u>PAGE</u> |
|---|-------------|
| APPENDIX E: Computer Input and Output . . . . .                         | 175         |
| E.1 Contents of the Appendix . . . . .                                  | 175         |
| E.2 The FLOSS Code . . . . .  | 176         |
| E.3 Sample Input to FLOSS . . . . .                                     | 197         |
| E.4 FLOSS Output . . . . .  | 199         |
| APPENDIX F: A Comparison of FLOSS to the SAS<br>Computer Code . . . . . | 244         |
| F.1 The SAS Code. . . . .   | 244         |
| F.2 Comparing FLOSS to SAS. . . . .                                     | 245         |

LIST OF FIGURES

| <u>FIGURE</u> |  | <u>PAGE</u> |
|---------------|--|-------------|
| 1.1           | Potential Sequence of Events for a Loss-of-Piping-Integrity Accident | 23          |
| 1.2           | Potential Sequence of Events for a Loss-of-Flow Accident             | 24          |
| 2.1           | Model of Loop Used for Calculation                                   | 29          |
| 2.2           | Flow Chart of FLOSS Code Solution Scheme                             | 40          |
| 4.1           | Schematic of the M.I.T. Water Test Loop                              | 55          |
| 4.2           | Pump Performance Characteristics                                     | 61          |
| 5.1           | Results of Test 4 - Oscillations in Bubble Length                    | 74          |
| 5.2           | Results of Test 4 - Temperature of First Unheated Node               | 76          |
| 5.3           | Results of Test 5 - Oscillations in Bubble Length                    | 78          |
| 5.4           | Results of Test 5 - Temperature of First Unheated Node               | 80          |
| 5.5           | Results of Test 6 - Oscillations in Bubble Length                    | 82          |
| 5.6           | Results of Test 6 - Temperature of First Unheated Node               | 83          |
| 5.7           | Results of Test 7 - Oscillations in Bubble Length                    | 86          |
| 5.8           | Results of Test 7 - Temperature of First Unheated Node               | 87          |
| 5.9           | Results of Test 8 - Oscillations in Bubble Length                    | 88          |
| 5.10          | Results of Test 8 - Temperature of First Unheated Node               | 89          |

LIST OF FIGURES (Cont.)

| <u>FIGURE</u> |   | <u>PAGE</u> |
|---------------|---|-------------|
| 5.11          | Results of Test 9 - Oscillations in Bubble Length   | 90          |
| 5.12          | Results of Test 9 - Temperature of First Unheated Node  | 91          |
| 5.13          | Results of Forced Convection Test - Temperature of First Unheated Node                        | 93          |
| 5.14          | Example of THORS Results - Volumetric Flow Oscillations                                       | 102         |
| 5.15          | Computer Generated Plot - Simulation of Test 9: Volumetric Flow Rates in Legs 1 and 2         | 105         |
| 5.16          | Computer Generated Plot - Simulation of Test 9: Bubble Pressure                               | 106         |
| 5.17          | Computer Generated Plot - Simulation of Test 9: Total Bubble Length                           | 107         |
| 5.18          | Computer Generated Plot - Simulation of Test 9: Bubble Lengths in Legs 1 and 2                | 108         |
| 5.19          | Comparison of Analytical Results for Different Heat Transfer Coefficients - Test 4 Conditions | 109         |
| 5.20          | Comparison of Analytical Results for Different Heat Transfer Coefficients - Test 6 Conditions | 110         |
| 5.21          | Comparison of Analytical Results for Different Heat Transfer Coefficients - Test 9 Conditions | 111         |
| 5.22          | Analytical vs. Experimental Results - Test 4: Bubble Length                                   | 115         |
| 5.23          | Analytical vs. Experimental Results - Test 5: Bubble Length                                   | 116         |

LIST OF FIGURES (Cont.)

| <u>FIGURE</u> |  | <u>PAGE</u> |
|---------------|--|-------------|
| 5.24          | Analytical vs. Experimental Results -<br>Test 6: Bubble Length                               | 117         |
| 5.25          | Analytical vs. Experimental Results -<br>Test 7: Bubble Length                               | 118         |
| 5.26          | Analytical vs. Experimental Results -<br>Test 8: Bubble Length                               | 119         |
| 5.27          | Analytical vs. Experimental Results -<br>Test 9: Bubble Length                               | 120         |
| 5.28          | Analytical vs. Experimental Results -<br>Test 9: Bubble Lengths, No Delay Time<br>Adjustment | 122         |
| 5.29          | Analytical vs. Experimental Results -<br>Test 4: Unheated Zone Temperature                   | 125         |
| 5.30          | Analytical vs. Experimental Results -<br>Test 5: Unheated Zone Temperature                   | 126         |
| 5.31          | Analytical vs. Experimental Results -<br>Test 6: Unheated Zone Temperature                   | 127         |
| 5.32          | Analytical vs. Experimental Results -<br>Test 7: Unheated Zone Temperature                   | 128         |
| 5.33          | Analytical vs. Experimental Results -<br>Test 8: Unheated Zone Temperature                   | 129         |
| 5.34          | Analytical vs. Experimental Results -<br>Test 9: Unheated Zone Temperature                   | 130         |
| A.1           | Method for Guessing Pressures in FLOSS   | 147         |
| A.2           | Numbering System for Components in FLOSS   | 149         |
| B.1           | Schematic of Data Acquisition System   | 156         |
| B.2           | Data Acquisition Flow Chart  | 160         |

LIST OF TABLES

| <u>TABLE</u> |  | <u>PAGE</u> |
|--------------|--|-------------|
| 3.1          | Comparison of Water and Sodium Properties              | 44          |
| 4.1          | List of Loop Components                                | 56          |
| 4.2          | Experimental Conditions                                | 65          |
| 5.1          | Example of Condensation Heat Transfer Coefficients     | 99          |
| C.1          | Example of Results from Test 4                         | 164         |
| C.2          | Example of Results from Test 5                         | 165         |
| C.3          | Example of Results from Test 6                         | 166         |
| C.4          | Example of Results from Test 7                         | 167         |
| C.5          | Example of Results from Test 8                         | 168         |
| C.6          | Example of Results from Test 9                         | 169         |
| C.7          | Example of Results from Test 10<br>(Forced Convection) | 170         |
| F.1          | Comparison of FLOSS to SAS                             | 247         |

NOMENCLATURE

| <u>Symbol</u>  | <u>Explanation</u>              | <u>Units</u>                                       |
|----------------|---------------------------------|--|
| A              | Area                            | in <sup>2</sup>                                    |
| C <sub>o</sub> | Turbulent drift flux parameter  |  |
| C              | Specific heat                   | BTU/lbm°F  |
| D              | Diameter                        | in   |
| F              | Body force                      | lb <sub>f</sub>                                    |
| f              | Volumetric body force (Eq. 2.1) | lb <sub>f</sub> /ft <sup>3</sup>                   |
| f              | Friction factor                 |  |
| g              | Acceleration of gravity         | ft/sec <sup>2</sup>                                |
| H              | Enthalpy                        | BTU  |
| h              | Specific enthalpy               | BTU/lbm  |
| h              | Heat transfer coefficient       | BTU/hr-ft <sup>2</sup> °F                          |
| I              | Inertance                       | lb <sub>f</sub> -sec <sup>2</sup> /ft <sup>5</sup> |
| Ja             | Jakob number                    |  |
| k              | Thermal conductivity            | BTU/hr-ft°F  |
| L              | Length                          | in   |
| m              | Mass                            | lbm  |
| P              | Pressure                        | lb <sub>f</sub> /in <sup>2</sup>                   |
| P              | Power (App. D)                  | kw, BTU/hr   |
| Q              | Volumetric flow rate            | ft <sup>3</sup> /sec                               |
| q              | Heat                            | BTU  |
| R              | Resistance                      | lb <sub>f</sub> -sec/ft <sup>5</sup>               |



NOMENCLATURE (Cont.)

| <u>Symbol</u> | <u>Explanation</u> | <u>Units</u>                           |
|---------------|--------------------|--|
| R'            | Resistance         | $\text{lb}_f\text{-sec}^2/\text{ft}^5$ |
| Re            | Reynolds number    |  |
| St            | Stanton number     |  |
| T             | Temperature        | $^{\circ}\text{F}$                     |
| t             | Time               | sec                                    |
| U             | Internal Energy    | BTU                                    |
| V             | Volume             | $\text{ft}^3$                          |
| v             | Velocity           | ft/sec                                 |
| w             | Work               | BTU                                    |
| x             | Length scale       | in                                     |
| $\alpha$      | Void fraction      |  |
| $\epsilon$    | Error              |  |
| $\mu$         | Viscosity          | lbm/hr-ft                              |
| $\rho$        | Density            | $\text{lbm}/\text{ft}^3$               |
| $\sigma$      | Surface tension    | $\text{lb}_f/\text{ft}$                |
| $\tau$        | Shear stress       | $\text{lb}_f/\text{in}^2$              |

NOMENCLATURE (Cont.)

Subscripts

|      |  |
|------|--|
| acc  | Acceleration                                     |
| b    | Bubble   |
| com  | Compressible volume                              |
| con  | Condensation                                     |
| evap | Evaporation                                      |
| fg   | Difference between saturated vapor<br>and liquid |
| fric | Frictional                                       |
| g    | Vapor  |
| grav | Gravitational (hydrostatic)                      |
| H    | Hydrodynamic                                     |
| i    | Index  |
| l    | Liquid   |
| net  | Net  |
| S    | Source   |
| sat  | Saturation                                       |
| sys  | System   |
| T    | Thermal  |
| tot  | Total  |
| o    | Reference  |
| l    | Bypass leg                                       |

NOMENCLATURE (Cont.)

Subscripts (Cont.)

- |   |                     |
|---|---------------------|
| 2 | Unheated zone       |
| 3 | Compressible volume |

Superscripts

- |   |                                  |
|---|----------------------------------|
| * | Indicates dimensionless quantity |
| n | Time step                        |

CHAPTER I  
INTRODUCTION

1.1 Background

The liquid metal-cooled fast breeder reactor (LMFBR) is currently under consideration as the prototype for the next generation of nuclear power plants to be built in the United States, Europe, and Japan. A thoroughly different concept than present day water cooled reactors (LWR's), the LMFBR employs liquid sodium as a coolant. This permits operation of the reactor at high temperature and low pressure, thus increasing power cycle efficiency. It also allows the use of a compact core with a high power density, which is then surrounded with a blanket of depleted uranium. This configuration permits breeding - the production of more fuel than is consumed - to occur.

Along with the above advantages inherent in the LMFBR, there are several disadvantages. The fact that sodium is opaque means that the reactor cannot be easily inspected by direct visual means. The coolant may also become highly radioactive. Perhaps the most significant drawback is the possible effects of sodium boiling. When a light water reactor sustains an accident which causes the

coolant to boil, the reactor tends to shut itself off due to the decrease in the density of the moderator. In the LMFBFR, however, the boiling of the coolant would shift the neutron spectrum in the reactor so as to increase the power, thus creating a possible "autocatalytic" reaction that would cause the reactor power to increase rapidly.

There are also circumstances wherein the boiling of the coolant, while not causing large power excursions, could still have serious detrimental effects on the reactor core. In particular, the loss-of-piping-integrity (LOPI) accident must be considered. In such an accident, a coolant inlet pipe breaks, similar to the loss-of-coolant accident in the LWR. In the case of the LMFBFR, this pipe rupture causes a rapid decrease in flow rate. It is assumed in the analysis of this accident that the reactor has been shut down by control rods (scrammed). However, the residual heat remaining in the fuel due to decay of fission products and stored energy, may be sufficient to cause coolant boiling. There is significant uncertainty about the behavior of sodium during boiling. One school of thought asserts that, under conditions such as might occur during a LOPI, voiding process would propagate rapidly due to the high thermal conductivity of sodium, causing a rapid dryout of parts of the core, followed possibly by wide scale core melting and sub-

sequent loss of coolable core geometry.

It is also possible, though, that mitigating factors might come into play to prevent such a rapid dryout. Under this scenario, the stored heat would be rapidly removed without deleterious effects, and subsequent natural circulation and/or forced flow would be sufficient to remove the continuing decay power.

Figures 1.1 and 1.2 are taken from the Department of Energy's report on sodium boiling (1), and illustrate the complex sequences of events which have been developed for sodium boiling accidents. The heavy lines indicate the most likely sequences.

## 1.2 Scope of the Work

This project was conceived as an attempt both to model and simulate sodium boiling behavior, as part of the total D.O.E. effort in this area. Results from the Thermal-Hydraulic Out-of-Reactor Safety Facility (THORS) tests at Oak Ridge National Laboratory have indicated that stable sodium boiling may be expected under low-power, low flow conditions, such as might occur during a LOPI (2); current models do not accurately predict this type of behavior. In addition, significant flow oscillations occurred during some of these experiments. Upon analysis of the THORS results, it appeared that these oscillations might aid in postponing




FIGURE 1.1 POTENTIAL SEQUENCE OF EVENTS FOR A LOSS-OF-PIPING-INTEGRITY ACCIDENT




FIGURE 1.2 POTENTIAL SEQUENCE OF EVENTS FOR A LOSS-OF-FLOW ACCIDENT



the dryout of the core.

Since sodium experimentation is both costly and rather hazardous, due to sodium's tendency to ignite spontaneously in oxygen, a simpler approach was developed, using water as a simulant. The objectives of this project were:

1. Development of a simple, one-dimensional model for flow oscillations under low-power, low-flow conditions. This model should be easily understood and incorporate the necessary physical basis for the flow behavior to be modelled.
2. Performance of a series of experiments - with water - to ascertain whether the model would predict observed behavior, as well as to demonstrate the suitability of water as a simulant for liquid sodium.
3. Establishment of a set of criteria through which water and sodium experiments might be compared.
4. Comparison of data from the experiment to sodium data using the criteria developed under 3.

The fourth objective was to be met through comparison of the results obtained from the water experiments to those from the Sodium Boiling Test Facility (SBTF) at ORNL.

The following chapters will cover development of

the model, choice of the simulant, criteria for the comparison of water and sodium experimental results, the design of the M.I.T. Water Test Loop, and the results and analysis of experiments performed on the WTL. A brief description of the SBTF will also be included. Finally, the conclusions from this work are presented, along with recommendations for future work in this area.

CHAPTER 2  
THE ANALYTICAL MODEL

2.1 Overall Concept

The modelling of two-phase flow is an extremely complex task, due to the interactions of the phases with each other, as well as with their surroundings. Because of this fact, the model developed for this work was derived so as to keep the vapor phase essentially separated from the liquid. In addition, the flow oscillations to be modelled involve the expansion and contraction of a vapor space surrounded by two nearly incompressible liquid columns. The growth and collapse of such a bubble can be the result of either of two effects: a hydrodynamic effect, whereby the vapor space grows or collapses due to the differential pressure between the bubble and the liquid, or a thermal effect, through which the amount of vapor increases or decreases through the evaporation or condensation of the vapor. This second mechanism requires the transfer of heat, either latent or sensible, whereas the first does not. The two effects do not occur independently, however; the collapse of a steam bubble due to hydrodynamic effects would tend to increase the bubble pressure. This would then raise the saturation temperature of the bubble and cause condensation

to occur, possibly causing further collapse and starting the cycle again.

Due to the two possible methods of bubble growth and collapse, the model has been developed so as to incorporate both of these factors. This approach was proposed by Ford (3) in his Freon experiments and modelling. While Ford's original reasoning was followed, the details of the models differ, as well as the methods of solution.

In developing this model, the objective was to produce what would eventually be a module in a large system-scale code. There was no attempt made, therefore, to model the single phase flow configuration prior to the inception of boiling and flow oscillations, nor were there any means provided to carry the calculation past the point at which the limitations of model occur. The model limitations are discussed in Section 2.5, and recommendations for further calculational tools are presented in Chapter 6.

## 2.2 The Hydrodynamic Model

The system under consideration for the development of this model is illustrated in Fig. 2.1. The vapor space is assumed to be at constant pressure throughout, and the top of the upper plenum is assumed to be at atmospheric pressure. The liquid is considered to be incompressible, and acts essentially as a piston. The vapor space is not




FIGURE 2.1 LOOP MODEL FOR CALCULATION

assumed to be incompressible; in fact, its compressibility is one of the driving forces in the oscillations.

The system is assumed to be in a fixed configuration, with the vapor slug totally separated from the liquid. This "fixed-regime" type of model allows a simple mathematical description of the system.

The momentum equation for one-dimensional, incompressible, single phase flow in a pipe is

$$\frac{dv}{dt} = \frac{1}{\rho_l} \frac{dp}{dx} - \frac{1}{\rho} \frac{d\tau}{dy} - f_x \quad (2.1)$$

Integrating over the volume:

$$\rho_l AL \frac{dv}{dt} = A\Delta P - \frac{A_{\text{shear}}\tau}{\bar{A}} - F_x \quad (2.2)$$

This equation can be rearranged to show the contribution of each term:

$$\Delta P_{\text{tot}} = \Delta P_{\text{acc}} + \Delta P_{\text{fric}} + \Delta P_{\text{grav}} \quad (2.3)$$

The first term represents the acceleration of the fluid; the second is the pressure drop due to friction, and the third term represents the pressure drop due to body forces, in this case, gravity.

If the area is assumed constant, the term  $\rho AL \frac{dv}{dt}$  can be expressed as  $\rho L \frac{dQ}{dt}$ , where  $Q$  is the volumetric flow rate,  $vA$ .

Dividing Eq. (2.3) by the area, and combining the gravitational and total pressure drops

$$\Delta P' = \frac{\rho_l L}{A} \frac{dQ}{dt} + \tau \frac{A_{\text{shear}}}{A} \quad (2.4)$$

where  $\Delta P' = \Delta P_{\text{tot}} - \Delta P_{\text{grav}}$ .

The frictional term is now expressed, as is customarily done, using a friction factor,  $f$ :

$$\Delta P_{\text{fric}} = 4f \frac{L}{D} \frac{\rho_l v^2}{2} = \tau \frac{A_{\text{shear}}}{A} \quad (2.5)$$

Casting the equation in terms of the volumetric flow rate,  $Q$ ,

$$\Delta P_{\text{fric}} = 2f \frac{L}{D} \frac{\rho_l Q^2}{A^2} \quad (2.6)$$

Equation (2.4) now becomes

$$\Delta P' = \left( \frac{\rho_l L}{A} \right) \frac{dQ}{dt} + \left( 2f \frac{L}{D} \frac{\rho_l Q}{A^2} \right) Q \quad (2.7)$$

The term  $\frac{\rho_l L}{A}$  is the inertance of the fluid column indicated by  $I$ . The term  $2fL\rho_l Q/DA^2$  is the effective resistance due to friction on the fluid, and is indicated by  $R$ .

Thus

$$\Delta P' = I \frac{dQ}{dt} + RQ \quad (2.8)$$

This form of the equation is commonly used in system dynamics, and allows the creation of an electrical analog, with pressure drop paralleling voltage and volumetric flow rate analogous to current. The coefficients I and R would correspond to circuit inductances and resistances, respectively.

In Eq. (2.8), the pressure drop  $\Delta P'$  represents the non-gravitational pressure difference between the vapor space and the constant upper plenum pressure, and is common to the two liquid legs.

The equation for the vapor space is also derived from system dynamics. For a compressible volume, the conservation of mass equation states

$$\frac{dm}{dt} = \frac{d}{dt} (\rho_g V_g) = \rho_g Q_g \quad (2.9)$$

thus

$$Q_g = \frac{V_g}{\rho_g} \frac{d\rho_g}{dt} + \frac{dV_g}{dt} \quad (2.10)$$

If the motion of the boundaries of the compressible volume is examined, it is seen that the motion of the liquid legs, hereafter referred to as  $Q_1$  and  $Q_2$ , sum to the volume change,  $\frac{dV_g}{dt}$ . Therefore,

$$Q_{com} = \frac{V_g}{\rho_g} \frac{d\rho_g}{dt} = Q_3 \quad (2.11)$$



Using Eq. 2.8, the equations for the two liquid legs shown in Fig. 2.1 can be expressed as

$$\Delta P' = I_1 \frac{dQ_1}{dt} + R_1 Q_1 \quad (2.12)$$

$$\Delta P' = I_2 \frac{dQ_2}{dt} + R_2 Q_2 \quad (2.13)$$

since

$$Q_1 + Q_2 = \frac{dV_g}{dt} \quad (2.14)$$

As stated above, Eqs. (2.14) and (2.11) can be combined to define a source volumetric flow rate,  $Q_s$ , such that

$$Q_1 + Q_2 + Q_3 = Q_s \quad (2.15)$$

The four equations, 2.8 (one for each liquid leg), 2.11, and 2.12 comprise the hydrodynamic model.

### 2.3 The Thermal Model

The thermal model for bubble growth is derived directly from the first law of thermodynamics for a closed system. That law states:

$$\delta q - \delta W = \delta U \quad (2.16)$$

The definition of enthalpy

$$H = U + PV \quad (2.17)$$

is substituted into Eq. (2.16). Realizing that the term  $\delta W$  represents pressure-volume work done by the system, so that

$$\delta W = P\delta V \quad (2.18)$$

and making this substitution, as well, Eq. (2.16) becomes

$$\delta q - P\delta V = \delta H - P\delta V - V\delta P \quad (2.19)$$

or

$$\delta q + V\delta P = \delta H \quad (2.20)$$

Equation (2.20) is now divided by  $\delta t$ , and the limit is taken as  $\delta t$  approaches zero. This gives the differential form of the equation

$$\frac{dq}{dt} + V \frac{dP}{dt} = \frac{dH}{dt} \quad (2.21)$$

The enthalpy term for a two-phase system can be separated into its components. Thus

$$H = m_l h_l + m_g h_g \quad (2.22)$$

and

$$\frac{dH}{dt} = m_l \frac{dh_l}{dt} + m_g \frac{dh_g}{dt} + h_l \frac{dm_l}{dt} + h_g \frac{dm_g}{dt} \quad (2.23)$$

The system of bubble and surrounding liquid is chosen to be large enough so that the mass fluxes across the system boundaries are zero. This choice of a closed system sets a model limitation. This assumption is valid only when the vapor through-flow in the bubble is very small, a condition which exists for small bubble lengths only, as in the early stages of a transient. From the definition of a closed system, therefore

$$\frac{dm_{\text{sys}}}{dt} = 0 \quad (2.24)$$

and

$$\frac{dm_l}{dt} = - \frac{dm_g}{dt} \quad (2.25)$$

Substituting into Eq. (2.20):

$$\frac{dH}{dt} = (h_g - h_l) \frac{dm_g}{dt} + m_l \frac{dh_l}{dt} + m_g \frac{dh_g}{dt} \quad (2.26)$$

The last two terms represent the change in sensible heat of the system. For small changes in temperature and pressure, these contributions are negligible when compared to the latent heat of vaporization,  $(h_g - h_l)$  or  $h_{fg}$ .

Thus,

$$\frac{dH}{dt} \approx h_{fg} \frac{dm_g}{dt} \quad (2.27)$$

Substituting back into Eq. (2.18) yields

$$\frac{dq}{dt} + V_g \frac{dP}{dt} = h_{fg} \frac{dm_g}{dt} \quad (2.28)$$

Since  $m_g = \rho_g V_g$

$$\frac{dm_g}{dt} = V_g \frac{d\rho_g}{dt} + \rho_g \frac{dV_g}{dt} \quad (2.29)$$

and

$$\frac{dV_g}{dt} + \frac{V_g}{\rho_g} \frac{d\rho_g}{dt} = \left( \frac{dq}{dt} + V_g \frac{dP}{dt} \right) / \rho_g h_{fg} \quad (2.30)$$

It should be noted that the left hand side of Eq. (2.30) corresponds exactly to the source flow  $Q_s$  [Eq. (2.15)] derived in Section 2.2. Equation (2.30) comprises the thermal model for the system.

#### 2.4 Solution of the Equations

The thermal and hydrodynamic equations for the system are solved simultaneously and iteratively to find the net source flow and the bubble behavior. The solution is accomplished by means of a digital computer, using a program developed as part of this project.

To review, the equations that must be solved are

$$\Delta P' = I_1 \frac{dQ_1}{dt} + R'_1 Q_1^2 \quad (2.31)$$

$$\Delta P' = I_2 \frac{dQ_2}{dt} + R'_2 Q_2^2 \quad (2.32)$$

$$Q_3 = \frac{V_g}{\rho_g} \frac{d\rho_g}{dt} \quad (2.11)$$

$$Q_s = (\dot{q}_{net} + V \frac{d\rho}{dt}) / \rho_g h_{fg} = Q_1 + Q_2 + Q_3 \quad (2.30)$$

In rewriting these equations, the subscripts 1 and 2 refer to the two legs noted on Fig. 2.1; subscript 3 refers to the bubble itself. The total net heat flow to the bubble is symbolized by  $\dot{q}_{net}$ . Since the resistance term,  $R$ , depends on  $Q$  [Eq. (2.7)], a new coefficient,  $R'$ , has been introduced in Eqs. (2.31) and (2.32), such that

$$R' = 2f \frac{L}{D} \frac{\rho_l}{A^2} \quad (2.33)$$

There is still a dependence of  $R'$  on  $Q$ , since the friction factor,  $f$ , is a function of the Reynolds number and

$$Re = \frac{\rho Q D}{A \mu} \quad (2.34)$$

However, since this dependence is normally to a small fraction power in turbulent flow, the form in Eq. (2.33) has

been retained.

The number of bypass legs that are part of Leg 1 in Fig. 2.1 is immaterial since, by the analogy of parallel resistances and inductances, these can be combined into an effective single bypass leg. Additional resistances, such as elbows, tees, and other flow obstructions can be accommodated using an equivalent resistance concept, as well.

The solution scheme employed in the computer program sets the equations up in finite-difference form and solves them iteratively. Equations (2.31) and (2.32) are approximated by first order, explicit finite difference equations, while Eqs. (2.11) and (2.30) are solved by implicit first order difference equations. Details of the solution scheme may be found in Appendix A. The iterative technique itself consists of the following steps:

1. The pressure in the bubble is guessed, as well as the bubble lengths and vapor volumes, above and within the heater. The split must be made due to the fact that in the heated zone, evaporation occurs, while in the unheated section above the heater, evaporation occurs. Thus, in order to derive the net heat input to the vapor space, which is the difference between evaporation and condensation, the bubble must be split into two parts. The common vapor space pressure ties the two parts together.
2. The pressure guess allows the determination of the properties in the bubble, since the assumption is made that all vapor (as well as the liquid film on the walls of the heater) is at saturation. The liquid density is assumed to be constant, and

equal to that at saturation. This allows direct solution of Eqs. (2.11) and (2.27), since net heat input is a function of temperature and power to the heater. Other iterative loops determine the amount of power that goes into heating up or cooling the heater wall as pressure changes and the temperature profile of the liquid in the unheated section, as heat is introduced into this liquid by condensation.

3. Equations (2.31) and (2.32) are solved as described above.
4. The source flow ( $Q_1+Q_2+Q_3$ ) calculated from the thermal model is compared to that calculated from the hydrodynamic model. If these two flows are different by more than a specified convergence error limit, a new pressure is guessed and the calculation starts again from step 1.
5. If the two source flows are within the specified error, new bubble lengths and vapor volumes are calculated and compared to those that were guessed in step 1. If these are within a specified tolerance, time is incremented and the transient calculation proceeds. If they are not within the error limit, a new guess is made of bubble lengths and volumes, and the calculation returns to step 1 for another iteration.

A flow chart is shown in Fig. 2.2 illustrating this technique.

As noted in step 2 above, a temperature-time history of the upper unheated zone is calculated. This is done in order to allow calculation of the condensation of vapor which occurs in that part of the test section. The model used for this calculation is a nodal-averaged temperature scheme, whereby the upper section is split into a number of nodes, each with a single temperature, and new temper-




FIGURE 2.2 FLOW CHART OF FLOSS CODE SOLUTION SCHEME



atures are calculated based on the flow of liquid into and out of each node, as well as any condensation which might occur. The changing temperature in the unheated section determines the thermal contribution to bubble growth and collapse, and changes in the amplitude and period of oscillations may be related to this factor. Further discussion of this fact is found in Chapter 5. Details of the temperature calculational scheme can be found in Appendix A.

The method of solution outlined in this section has proven to yield satisfactory and physically realistic results. These results, along with comparison to experimental results can also be found in Chapter 5.

## 2.5 Limitations of the Model

A "fixed-regime" model is valid only insofar as the regime that is fixed actually exists physically. Once conditions proceed to a point where the assumptions incorporated into the model are no longer justifiable, the model is no longer useful in describing the system.

In the case of the model presented here, the model is valid for small bubble lengths and vapor volumes. Due to the assumptions made in both the hydrodynamic and thermal portions of the model, any deviation from a slug-flow regime would cause the model to fail. In addition, liquid and vapor through-flows are neglected in the formu-

lation of the thermal model. When the bubble becomes large enough to encourage substantial natural circulation flow, this assumption becomes invalid. For these reasons, once net evaporation exceeds net condensation, causing the bubble to grow without collapse, the transient calculation is stopped, and the assumption is made that another calculational tool can be used to determine subsequent occurrences.

CHAPTER 3  
CRITERIA FOR THE COMPARISON OF BOILING  
LIQUID SODIUM TO WATER

3.1 Background

The application of data from water experimentation to the question of what occurs during the boiling of liquid sodium requires that a group of criteria be developed with which to compare water data to sodium data. Several such criteria will be proposed in this chapter.

Clearly, the physical characteristics and properties of the two fluids are quite different, especially those properties dealing with heat transport. Therefore, heat conduction is not included in the comparison criteria. It is assumed that different temperature profiles may exist under the same flow conditions in water and sodium, and differences arising from this fact must be considered. However, from inspection of the equations of the model presented in Chapter 2, it can be seen that the properties that affect the equations are largely hydrodynamic in nature, and there is substantially less disparity between water and liquid sodium in this area. Table 3.1 lists both thermal and hydrodynamic properties of each fluid for comparison.

Table 3.1  
Comparison of Water and Sodium Properties

| Fluid Property                | Water at 14.7 psia         | Sodium at 25 psia<br>(Reactor Conditions) |
|-------------------------------|----------------------------|---|
| $T_{\text{sat}}$              | 212°F                      | 1670°F                                    |
| $\rho_{\ell}$                 | 59.8 lbm/ft <sup>3</sup>   | 46.4 lbm/ft <sup>3</sup>                  |
| $\rho_{\text{g}}$             | 0.0373 lbm/ft <sup>3</sup> | 0.025 lbm/ft <sup>3</sup>                 |
| $\rho_{\ell}/\rho_{\text{g}}$ | 1603                       | 1650                                      |
| $h_{\text{fg}}$               | 970.3 BTU/lbm              | 1650 BTU/lbm                              |
| $Cp_{\ell}$                   | 1.0 BTU/lbm°F              | 0.31 BTU/lbm°F                            |
| $\mu_{\ell}$                  | 0.687 lbm/hr-ft            | 0.363 lbm/hr-ft                           |
| $\sigma_{\ell}$               | 0.004 lb <sub>f</sub> /ft  | ~0.012 lb <sub>f</sub> /ft                |
| $k_{\ell}$                    | 0.394 BTU/hr-ft°F          | 31.5 BTU/hr-ft°F                          |

The criteria developed in this chapter, then, are mainly hydrodynamic in nature, and may be used under these special circumstances to compare boiling water to boiling liquid sodium.

### 3.2 Momentum Equations

The approach that is taken throughout this chapter involves the non-dimensionalization of the basic equations.

The momentum equation, as presented in Chapter 2 for unidimensional, single phase flow in a pipe is:

$$\frac{dv}{dt} = \frac{1}{\rho} \frac{dp}{dx} - \frac{\mu}{\rho} \frac{d^2v}{dy^2} - f_x \quad (2.1)$$

The body force  $f_x$  is, in this case, due to gravity; thus

$$\frac{dv}{dt} = \frac{1}{\rho} \frac{dp}{dx} - \frac{\mu}{\rho} \frac{d^2v}{dy^2} - g \quad (3.1)$$

Non-dimensionalization is accomplished by choosing new variables that are dimensionless. For the momentum equation, these variables are:

$$\begin{aligned} v_0 &= \sqrt{P_0/\rho_l} \\ v^* &= v/v_0 \\ t^* &= tv_0/D \end{aligned} \quad (3.2)$$

$$\begin{aligned}y^* &= y/D \\ \rho^* &= \rho/\rho_\ell \\ P^* &= P/P_0 \\ x^* &= x/D \\ \mu^* &= \mu/\mu_\ell\end{aligned}$$

The quantity  $P_0$  is a reference pressure, and  $D$  is the diameter, and serves as a reference length scale.

Substituting these quantities into Eq. (3.1) yields

$$\frac{v_0^2}{D} \frac{dv^*}{dt^*} = \frac{P_0}{\rho_\ell D} \frac{1}{\rho^*} \frac{dP^*}{dx^*} - \frac{\mu_\ell}{\rho_\ell} \frac{v_0}{D^2} \frac{\mu^*}{\rho^*} \frac{d^2v^*}{dy^{*2}} - g \quad (3.3)$$

Simplifying, and applying the definition of  $v_0$  [Eq. (3.2)] to the first term on the right hand side:

$$\frac{dv^*}{dt^*} = \frac{1}{\rho^*} \frac{dp^*}{dx^*} - \frac{\mu_\ell}{\rho_\ell v_0 D} \frac{\mu^*}{\rho^*} \frac{d^2v^*}{dy^{*2}} - \frac{Dg}{v_0^2} \quad (3.4)$$

The coefficient of the second term on the right hand side of the equation is the inverse of the Reynolds number. This is the first of the comparison criteria. The Froude number also appears, as the last term in Eq. (3.4). Although this sets another criterion, it reduces essentially to a density ratio for systems of similar geometry and pressure. Applying the definition of  $v_0$  to the expression

$\frac{Dg}{v_o^2}$  yields the result

$$\frac{Dg}{v_o^2} = \frac{\rho_l Dg}{P_o} \quad (3.5)$$

Since the liquid densities of sodium and water are similar, this criterion is satisfied. The choice of another geometry, however, would necessitate consideration of this parameter.

The appearance of the Reynolds number is not altogether unexpected. As stated above, the driving factors in the oscillatory flow behavior tend to be chiefly hydrodynamic in nature; thus, the prime basis for hydrodynamic scaling should appear.

### 3.3 The Compressibility Equation

The term expressing the compressibility effects is

$$Q_g = \frac{V_g}{\rho_g} \frac{d\rho_g}{dt} \quad (2.11)$$

The volumetric flow rate is defined in Chapter 2 as

$$Q_g = Av$$

Thus

$$Av = \frac{V_g}{\rho_g} \frac{d\rho_g}{dt} \quad (3.6)$$

or

$$A \frac{dx}{dt} = \frac{V_g}{\rho_g} \frac{d\rho_g}{dt} \quad (3.7)$$

Once again, dimensionless variables are chosen:

$$\begin{aligned} x^* &= x/D \\ A^* &= A/D^2 \\ V_g^* &= V_g/D^3 \\ t^* &= t/\tau \\ \rho^* &= \rho_g/\rho_\ell \end{aligned} \quad (3.8)$$

Equation (3.7) now becomes

$$\frac{D^3 A^*}{\tau} \frac{dx^*}{dt^*} = \frac{D^3 V_g^* \rho_\ell}{\rho_g \tau} \frac{d\rho^*}{dt^*} \quad (3.9)$$

Simplifying:

$$A^* \frac{dx^*}{dt^*} = V_g^* \frac{\rho_\ell}{\rho_g} \frac{d\rho^*}{dt^*} \quad (3.10)$$



The second dimensionless group, then is the liquid-to-vapor density ratio,  $\rho_l/\rho_g$ . This term behaves as a kind of variable spring constant, since it changes with pressure, and along with the length of the bubble and heat transfer, helps to determine the oscillatory behavior of the system. From the table of properties, it is clear that the density ratios for sodium and water at pressures near atmospheric are similar.

### 3.4 The Energy Equation

The energy equation, as derived in Chapter 2, is

$$\frac{dV_g}{dt} + \frac{V_g}{\rho_g} \frac{d\rho_g}{dt} = (\dot{q} + \frac{V_g dP}{dt}) / \rho_g h_{fg} \quad (2.27)$$

The left hand side of the equation is equivalent to a volumetric vapor generation rate,  $Q_s$ . The term  $VdP/dt$  is very small compared with the net heat flow,  $\dot{q}$ , and is neglected.

Thus

$$Q_s = \dot{q}_{net} / \rho_g h_{fg} \quad (3.11)$$

The source flow,  $Q_s$ , can be expressed, as in the previous section, in terms of an equivalent velocity and area:

$$Av_s = \dot{q}_{net}/\rho_g h_{fg} \quad (3.12)$$

The velocity,  $v_s$ , is now non-dimensionalized:

$$v_s^* = v_s/v_o \quad (3.13)$$

Then

$$Av_o v_s^* = \dot{q}_{net}/\rho_g h_{fg} \quad (3.14)$$

and finally

$$v_s^* = \dot{q}_{net}/\rho_g v_o A h_{fg} \quad (3.15)$$

The net heat input includes both power input to the lower part of the bubble, as well as condensation which occurs when vapor enters the unheated section above the heat source. The vapor generation occurs via evaporation at the liquid-vapor interface, at saturation, and the condensation is due to the interaction of saturated vapor with subcooled liquid. If this heat input is expressed in terms of an equivalent heat transfer coefficient and temperature difference, Eq. (3.15) becomes

$$v_s^* = \frac{h_{eq} (T-T_{sat})}{\rho_g v_o h_{fg}} \quad (3.16)$$

where

$$\dot{q}_{net} = h_{eq} A (T-T_{sat}) \quad (3.17)$$

The quantity on the right hand side of Eq. (3.16) is the Jakob number, Ja, multiplied by the Stanton number, St, since

$$Ja = \frac{\rho_l C_{p_l} (T - T_{sat})}{\rho_g h_{fg}} \quad (3.18)$$

and

$$St = \frac{h}{\rho_l C_{p_l} v} \quad (3.19)$$

More importantly, this combination serves as a kind of power-to-flow ratio, normalized by the latent heat of vaporization. It is this term which should be used as a comparison criterion. The factor of differing saturation temperatures is also taken into account. One factor which appears indirectly in Eq. (3.16) is the condensation in the unheated zone, since it is combined with the heat input term. The condensation potential in the unheated section appears to be the primary driving force in the flow oscillations under study, a fact that will be discussed more fully in Chapter 5. The heat input to the system is effectively a constant over the duration of the experiments, and it is this condensation term which provides the variation in  $\dot{q}_{net}$  and the ultimate potential for bubble growth and collapse. The characterization of the condensation heat transfer in order to determine this potential is therefore crucial.

### 3.5 Comparison of Sodium Data to Water Data

The Sodium Boiling Test Facility (SBTF) at Oak Ridge National Laboratory is almost an exact analog of the original MIT Water Test Loop, as described in Chapter 4. The SBTF also has a pump to provide for forced-flow experimentation; however, it does not include a bypass loop at this time.

The SBTF is a sodium loop, heated indirectly over its three-foot heated length by a quadelliptical radiant furnace. At the inception of this program, it was expected that some data would be available from SBTF in order to provide a direct comparison to water data. While several of the natural circulation tests performed on the original WTL have been reproduced, budgetary and experimental problems have forced a delay in the performance of forced-flow and flow oscillation testing. It is anticipated that these types of experiments will be performed in the near future, providing a direct test of the comparison criteria herein proposed.

CHAPTER 4  
EXPERIMENTAL APPARATUS AND PROCEDURES


4.1 Background and Experimental Apparatus

The expense and hazard involved in the use of liquid metals as an experimental medium led to the concept of the first M.I.T. Water Test Loop, constructed by Dr. W. D. Hinkle in 1976. The WTL was intended to be a simple, easy-to-operate alternative to complex sodium boiling facilities such as THORS. The first experiments performed and reported by Hinkle (4), involved natural circulation tests only, to determine critical heat fluxes under low-power conditions. These results, along with comparison criteria developed by Hinkle, were compared to sodium data obtained under similar conditions from the SBTL loop at Oak Ridge (5). Water was chosen as the simulant in the initial series of tests because of the similar liquid-to-vapor density ratios for the two liquids. Other similarity criteria were not considered.

Flow oscillations such as those observed in the THORS tests could not be modelled using Hinkle's approach, and so a more involved and sophisticated test program was developed. The performance of these experiments required that the Water Test Loop be modified somewhat from its

original design. Figure 4.1 shows the loop in its current configuration; Table 4.1 lists the dimensions and properties of the loop. The modifications consisted of the addition of a pump and a bypass leg, which would allow operation in either forced or natural circulation. Four ball valves were installed at the bypass to provide the means to change flow configurations. In addition, an orifice flange was added upstream of the inlet plenum to provide the capacity to vary the inlet flow resistance. Whereas the entire "primary" section - that part between the two plena consisting of the heater and unheated inlet and outlet sections - had been steel, the new loop was built with Pyrex glass tubing making up as much of the unheated sections as practical. This allowed visual observation of bubble growth and collapse patterns during a transient.

The instrumentation was also altered considerably for the new tests. Thermocouples had previously been fastened to the outside of the entire metal primary section, and strain-gauge type pressure transducers were installed in the inlet plenum, heater inlet and heater outlet. There was no flow measuring instrument included. Data acquisition was by means of a chart recorder. The modified version of the loop retained the thermocouples on the outside of the heater rod; however, the Pyrex sections were split into



Note: Numbers refer to Table 4.1 on following page

FIGURE 4.1 SCHEMATIC OF THE M.I.T. WATER TEST LOOP

Table 4.1. List of Loop Components

| <u>Component Number</u> | <u>Function</u>                         |
|-------------------------|---|
| 1                       | Heater Tube - 0.25" OD                  |
| 2                       | Pyrex Tubing - 6mm OD                   |
| 3                       | Swagelok Tee for Thermocouple Insertion |
| 4                       | Orifice for $\Delta P$ Transducer       |
| 5                       | Cooling/Heating Coil for Plenum         |
| 6                       | Upper Plenum - 8" I.D. x 8" ht.         |
| 7                       | Stainless Steel Bypass Pipe - 1" I.D.   |
| 8                       | Ball Valve for Flow Control             |
| 9                       | Pump                                    |
| 10                      | Orifice Flange                          |
| 11                      | Lower Plenum 8" I.D. x 8" ht.           |
| 12                      | Heat Exchange Loop Pump                 |
| 13                      | Heat Exchanger                          |
| 14                      | Connection to 7kw DC Generator          |
| 15                      | Insulator and Tyco Pressure Transducer  |
| 16                      | Validyne $\Delta P$ Cell across Orifice |
| 17                      | Thermocouple on Outside of Heater Tube  |
| 18                      | Thermocouple Inserted into Swagelok Tee |
| 19                      | Data Acquisition System                 |



smaller zones, with each end inserted into a Swagelok tee. The third port of the tee was used for insertion of a thermocouple directly into the fluid stream. The thermocouples were sealed into the ports using RTV Silicone Rubber Sealant. All thermocouples were copper-constantan.

Pressure transducers of the same type that Hinkle used were retained for the heater inlet and outlet. The inlet plenum transducer was not used. These gauges were Tyco type AB, with a range of 0-6 psig. When excited by a 6-volt dry cell battery, the response was linear, at a rate of 20 mv/psi.

For the new set of experiments, it was desired to have measurement of inlet and outlet flow rates. To accomplish this, flow orifices were installed just downstream of the inlet plenum and upstream of the outlet plenum. The orifices were about 80% of the test section diameter. They were made this way so as to cause as little interference with the flow as possible, while still generating enough of a pressure drop to measure flow rate. Pressure drop measurements were made using Validyne DP15 differential pressure transducers. These instruments can be adjusted as to the range of their output, from about  $\pm 0-1$  to  $\pm 0-10$  volts full scale. The transducers themselves are variable reluctance devices with interchangeable diaphragms,

permitting operation from  $\pm 0-0.1$  psid upward. In order to provide response as accurate as possible and to avoid pinning the data acquisition system at its maximum output, a range of  $\pm 0-1$  volt was chosen, with the lower transducer set for  $\pm 0-1.0$  psid, and the upper transducer for  $\pm 0-0.5$  psid. The Validyne transducers were supplied with their own carrier demodulators, which served as both a power source and voltage output device. Calibration of these transducers was done in place, using both upflow and downflow.

The loop was run in visual observation tests immediately after construction. On the basis of these observations and sodium test results, the decision was made to purchase a fast-scan data acquisition system, in order to collect data at a rapid enough rate to be able to trace the oscillatory motion. The system chosen was a Perkin-Elmer Low-Level Real Time Analog System (RTAS). The RTAS has the capability of scanning individual data points at rates up to 8000 points per second. The low level system permits inputs of  $\pm 0-1.0$  volts. To collect and store the data, a Perkin-Elmer Model 1610 minicomputer was acquired. This machine is a 16-bit computer with 64000 bytes of memory, with dual floppy disk drives to provide input-output capability. A Perkin-Elmer 550 CRT terminal was used as the system console, and a Perkin-Elmer 650 Thermal Printer

was connected to the rear of the CRT to provide hard copy output, if desired. Operating system software, including FORTRAN support, was supplied by Perkin-Elmer. Using the 1610 computer and driver programs developed by Perkin-Elmer for the RTAS, data acquisition was done at the rate of 600 points per second. The RTAS input supports twenty-four individual instruments, and scans were performed twenty-five times per second. The instrumentation consisted of: The two Validyne differential pressure transducers, the two Tyco gauge pressure transducers, and nineteen thermocouples, one each in the inlet and outlet plena, eight tied onto the outside of the heater at approximately 4.5 inch intervals, and nine in the unheated zones. The twenty-fourth point was connected to an RTD temperature reference on the RTAS termination panel to provide an equivalent ice-point for the thermocouples. The computer, through its line-frequency clock, is able to generate interrupts at up to 120 times per second. Each interrupt allows the RTAS to scan all 24 points at the maximum scan rate. The interrupt interval chosen for these experiments was 40 milliseconds. More detail on the data acquisition system can be found in Appendix B.

Power was supplied to the test section by a 7 kilowatt DC generator. The test section was directly

heated (resistance heating) by the generator. Power was measured using a Hewlett Packard Model 3465 B Digital Multi-meter. The voltage drop across the test section heater tube was measured, and multiplied by the generator current output. Generator current was ascertained by means of a calibrated shunt providing 50  $\mu$ v output at 1000 amperes.

The remainder of the test section, aside from the bypass legs, consisted of a heat transfer loop to cool the plena. The lower plenum was cooled by direct fluid exchange, whereby fluid was removed, pumped through a small heat exchanger, and returned to the plenum. The upper plenum, which was open to the atmosphere to provide a constant reference pressure, was cooled by a copper coil loop inside the plenum. Water was run from the city water pipes through this copper coil, and the temperature of this water could be varied, so as to hold the plenum at the desired temperature.

Both the main test section pump and the heat exchanger loop pump were Jabsco "Sturdi-Puppy" self-priming vane pumps, rated at 5 gpm at 8.5 psi. Figure 4.2 represents the pump curve.

The bypass legs were stainless steel piping. The large size of these pipes in relation to the primary tubing was to negate any significant bypass effect on flow dynamics.




FIGURE 4.2 PUMP PERFORMANCE CHARACTERISTICS

## 4.2 Experimental Set-up and Procedure

### 4.2.1 Pretest Set-up and Calibration

Prior to each set of experiments, several steps were followed to insure readings from instruments were as accurate as possible. With the loop filled, the battery for the Tyco pressure transducers was checked to make certain it still was charged at 6 volts. The transducers themselves were then checked for offset from zero. This was accomplished by checking the output from each transducer with a digital multimeter to ascertain the output, and then subtracting from that reading 20 mv for each psi of water head above the transducer.

The second step involved the calibration-in-place of the Validyne differential pressure transducers. Each transducer was calibrated in both upflow and downflow. Calibration in upflow was accomplished via a two step method. The loop was run at the beginning of the experimental program with the bypass line opened and the power at a low level. Using the thermocouples directly upstream and downstream of the heater, a heat balance was performed. Knowing the amount of power input and the temperature size of the water across the heater, it was then possible to determine the flow rate. This single point was used to calibrate the transducers in upflow, with the assumption

of linear transducer response. For downflow calibration, the primary side of the loop was isolated to prevent recirculation effect on the transducer. Water was then withdrawn from the lower plenum through the hole where the plenum pressure transducer had been mounted in Hinkle's experiment. Initially, since the water could be withdrawn at variable rates, several different measurements were made. The flow was collected for a timed interval, then measured to find the flow rate. The rate of withdrawal was sufficiently small, so that the driving pressure on the primary side did not change appreciably. This insured constant flow over time. The calibration with several points verified the linearity assumption made in upflow, and in later calibrations, only one point was taken for downflow calibrations. The transducers themselves were first bled, and then zeroed using the carrier demodulator adjusting dial. Output was again read using a digital multimeter.

Before beginning experimentation, the loop was operated for several minutes to remove all trapped air bubbles from the system.

The final step before beginning the experiment was to load the data acquisition system controller programs into memory. Once this was accomplished, the data collection procedure could be started by simply pressing on key

the system console.

#### 4.2.2 Experimental Procedure

The experimental procedure for each run was basically the same, with the exception of the final test. The last experiment will therefore be dealt with separately. The conditions for all tests analyzed are presented in Table 4.2.

##### 4.2.2.1 Stagnant Flow Testing

Three preliminary tests were run under stagnant flow conditions to test all of the equipment and to practice data-taking procedures. Six additional experiments were then run in which data was acquired and converted.

Preliminary analytical work using the computer model indicated that the temperature profile in the unheated zone was perhaps the single most important parameter in determining flow oscillatory behavior. It was therefore decided to run the experiment in the same way each time, varying only that temperature profile.

The temperature profile was established by running the loop with bypass flow. This made the velocity in the primary section sufficiently low that any temperature ranging from the lower plenum temperature to saturation could be established in the unheated zone by varying heater power. The temperature would then be uniform from the top of the



Table 4.2. Experimental Conditions

| Test Number | Stagnant/<br>Forced Convection | Unheated<br>Zone Temperature(°F)<br>Prior to Boiling<br>Inception | Heater<br>Power<br>(kw) |
|-------------|--------------------------------|---|-------------------------|
| 4           | S                              | 75  | 0.544                   |
| 5           | S                              | 102   | 0.544                   |
| 6           | S                              | 80  | 0.209                   |
| 7           | S                              | 100   | 0.326                   |
| 8           | S                              | 117   | 0.417                   |
| 9           | S                              | 140   | 0.390                   |
| 10          | FC                             | ~175 decreasing<br>to ~95 at top                                  | 1.09                    |

heater to the upper plenum, where the temperature was controlled using the heat transfer loop. Losses to the surroundings were assumed to be negligible. The temperature of the upper unheated zone was measured by connecting an Omega Model 403A digital thermometer connected to the first thermocouple downstream of the heater and in the water.

Once the temperature profile was established, the pump was stopped and the generator was disconnected from the heater. The bypass valve was then closed. The flow path, therefore, consisted of the primary loop with no bypass and a stalled pump in the downcomer. The pump was stalled to permit as little natural circulation as possible to raise the temperature of the unheated zone. Some leakage flow through the stalled pump was present, however. The power was then set at the desired level and applied in a step-change fashion to the test section. Shortly before the inception of boiling, the data acquisition system was started. Boiling and flow oscillations then were observed and data acquired. Upon termination of the data acquisition program in approximately fifteen seconds, the pump was restarted to bring the loop down below saturation at all points. Power was then measured using the procedure outlined in a previous section, and the generator was then shut off. Preparations were then made for the next run.

After the termination of experimentation, data reduction was accomplished using the data acquisition computer. A conversion program was written for the instrumentation present using calibration information to convert the Tyco transducer readings to psig and the Validyne transducer readings to flow rate. The thermocouples were converted by a four step method. Using calibration information supplied with the RTD temperature reference, the temperature of the thermocouple termination panel was determined. This temperature was then converted to millivolts for copper-constantan thermocouples using a standard curve fit with a 32°F reference power. This number was then added to each thermocouple reading. Finally, the adjusted thermocouple output was converted to temperature using a standard curve fit for a 32°F reference temperature. As a last step, bubble lengths in the heated and unheated zones were calculated by a stepwise integration of the flow rates with time. Results of these calculations, and the accuracy of the derived data, will be discussed in Chapter 5.

#### 4.2.2.2 Forced Convection Testing

One experiment was performed using forced, instead of stagnant, flow. This was done both to examine the effect of a nonuniform temperature profile in the unheated zone, and to determine the effect that forced flow would

the oscillatory behavior. Procedures for pretest calibration and set-up were the same as described in Section 4.2.1. In this experiment, though, the run was started with the bypass closed and the pump running. This generated a flow rate so large as to make the temperature rise across the heater very small. The bypass was then opened and data acquisition began simultaneously. The opening of the bypass reduced flow drastically to the primary section, allowing boiling to begin. Termination of the experiment and data reduction were then performed as outlined in Section 4.2.2.1.

#### 4.3 Safety Precautions

During all tests, the behavior of the bubble was observed visually in the Pyrex section. This was done to provide verification of the results derived through data reduction, and also to insure that the heater was not about to reach critical heat flux (CHF). Since the heater was clamped at both ends, the rapid heatup of the tube associated with CHF would have caused severe distortion (bowing) of the tube, possibly resulting in permanent heater deformation. The Pyrex was also checked to make certain that it did not crack.

A small amount of leakage was observed, due to the many fittings as well as the manner in which the thermocouples were sealed into the unheated zone. Leaks that were

small enough to have no appreciable effect on the experiment were ignored. Large leaks, however, were resealed.

CHAPTER 5  
EXPERIMENTAL AND ANALYTICAL RESULTS

5.1 Experimental Results

5.1.1 Stagnant Flow Tests

5.1.1.1 Data Analysis

Data reduction for each experiment was carried out as described in Chapter 4. Upon examination of the data, several facts were immediately evident.

The differential pressure transducer upstream of the upper plenum was nearly useless in trying to determine the bubble length in the unheated section. This was true because of the presence of air in the water. Since the loop was operated open to the atmosphere, it was not degassed, and the water used to fill the loop had a substantial amount of dissolved air in it. At boiling inception, this air was stripped out from the steam, and upon condensation, did not dissolve once again into the water, but instead travelled up the test section to the upper plenum. When these bubbles came near the Validyne transducer, they so distorted the differential pressure reading that any attempt to deduce the flow rate or to integrate the flow rate to find the bubble length yielded unrealistic results, based on what was observed visually during the experiment.

In addition, the Validyne transducer just downstream of the lower plenum registered extremely large pressure drops at times during each run. This phenomenon was attributed to a "water hammer" effect due to vapor condensation. This conclusion was reached due to the fact that these large pressure drops always occurred immediately after the bubble lengths, as calculated from the flow rate, reached zero. After peaking rapidly these shock waves would die away rapidly as well, until the next bubble growth-collapse cycle. The passage of these pressure waves across the orifice taps at the bottom of the test section caused large differential pressures to be recorded by the Validyne transducers, although the flow itself was not significantly affected, due to the high rate of speed of the wave. However, since flow rates are inferred from the readings of the Validynes, the response of the transducers to these pressure waves tended to distort flow rate measurements. No other distortion, such as that mentioned for the upper transducer due to air bubbles, was noted for the lower Validyne.

Several examples of experimental results are shown in Appendix C. The flow rate readings shown in several of the tables illustrates clearly the effect of the "water hammer" shock waves.

The thermocouples performed rather well, although there were cases of bead breakage and subsequent failure to function. In general, though, those couples connected to the outside of the heater tube tended to respond very slowly to changes in temperature inside the tube. This is understandable due to the time lag resulting from the tube wall thickness. The thermocouples in the fluid, though, responded rapidly to temperature changes and were quite valuable in determining bubble movement.

All of the stagnant flow tests exhibited the same basic characteristics. Upon boiling inception, the vapor bubble would begin to grow outward in both directions from the top of the heater. This tended to push warm fluid into the upper unheated zone, causing the temperature of that fluid to rise. In addition, condensation would deposit heat in this fluid. When the bubble grew far enough so that net condensation exceeded net evaporation, it would then begin to collapse. This, in turn, would pull the colder fluid above the bubble down into the heated zone, dropping the temperature at that point below saturation. This cycle was followed by the aforementioned "water hammer" shock effect, and then a short waiting period would occur while the water at the top of the heater was reheated to saturation. This cycle would repeat itself several times. The amplitude



and frequency of the bubble growth-collapse cycle tended to change over the course of the transient, due to the changing temperature profile in the unheated zone.

In the subsequent sections, each test will be examined individually in order to discuss its characteristics.

#### 5.1.1.2 Test 4

After the first three preliminary tests, the first run to be analyzed was number 4.

A plot of calculated bubble lengths in the heater versus time is presented in Fig. 5.1. Due to the anomalies in flow rate readings, from which the bubble length is calculated, mentioned in the previous section, these measurements can be treated only as approximate. However, several pieces of valuable information are discernable from these data.

The first thing to notice is, in general, the extremely rapid collapse of the bubbles after they have reached their peak lengths. This is likely due to the variation in condensation heat transfer during the oscillation cycle. This point will be discussed at length in a later section, due to its importance in determining bubble growth and collapse.

Although the growth-collapse pattern appears to be somewhat random at first, after about two seconds, a pattern




FIGURE 5.1 RESULTS OF TEST 4 - OSCILLATIONS IN BUBBLE LENGTH

of increasing and then decreasing bubble length becomes apparent. This looks very much like a "beat pattern" that is experienced in sound waves. It results from the superposition of two somewhat different frequencies. In this case, it appears that the short frequency is indeed the bubble oscillation frequency. The longer wave pattern is probably due to a sort of "enthalpy wave" flow instability. This instability results, at low flow rates, when a large amount of fluid is heated to saturation. Upon boiling inception, its density decreases, and the fluid accelerates out of the heated zone. It is replaced by colder fluid from below, which increases the density of the fluid once again, and decelerates the column back to its original condition. This beat pattern behavior is consistent with results of liquid metal experiments, another point which will be examined in more detail in a subsequent section.

The temperature at the first thermocouple in the fluid downstream of the heater is shown in Fig. 5.2 as a function of time. This plot clearly illustrates the temperature oscillations which occur as the bubble grows and collapses.

Another point to note is the waiting period evident after each bubble collapse. Part of this time is artificially induced by the pressure waves from the water




FIGURE 5.2 RESULTS OF TEST 4 - TEMPERATURE OF FIRST UNHEATED NODE

hammer effect. However, some of this period is caused by the necessity to heat the water back to saturation after a bubble collapses.

A final point to note is the amplitude of the oscillation. Since the flow rates are inferred from the pressure transducers, and bubble length is inferred by integrating the flow rate curve, several sources of uncertainty are available to distort the calculation. In addition, since the readings from the upper Validyne were highly unreliable, the bubble length above the heater can be inferred only by applying information gained from the analytical study. This point will be elaborated upon in the section on the comparison of analytical and experimental results, and when the condensation heat transfer coefficient is discussed.

#### 5.1.1.3 Test 5

The power to the heater in Test 5 was the same as that in Test 4; however the temperature in the upper unheated zone was approximately 25°F higher. The purpose of this run, then, was to compare it with the previous run to determine the effect of that temperature on the oscillatory flow behavior. A plot of bubble length within the heater versus time is presented in Fig. 5.3, and temperature of the fluid just downstream of the heater versus time is shown in Fig.




FIGURE 5.3 RESULTS OF TEST 5 - OSCILLATIONS IN BUBBLE LENGTH

5.4. There are some significant differences between Tests 4 and 5 which should be noted, as well as a few similarities.

The similarities basically relate to the character of the flow oscillations in general. The same pattern as that described in the previous section is evident. Some slight evidence of the "beating" that appeared in Test 4 shows again between about 1.5 and 3.5 seconds. However, the difference in amplitude is not as significant in Test 5 as in Test 4, a fact that can be attributed to the difference in unheated zone temperature. A second similarity is the waiting period between oscillations that was noted in Test 4. However, this waiting period tends to be shorter in this test. The higher upper zone temperature means that less time is needed to return the fluid to saturation.

The main differences between the two runs is the difference in oscillation frequency and amplitude over the transient. The average frequency - number of oscillations divided by transient time - is less in this test than in Test 4. This difference is especially clear after  $t=4$  seconds. Related to this fact is the slightly larger amplitude of the oscillations. However, the amplitude of the oscillation is more an inertial effect than a thermal one. Therefore, while the difference in amplitude is not particularly large, for bubbles of similar lengths in the two tests,




FIGURE 5.4 RESULTS OF TEST 5 - TEMPERATURE OF FIRST UNHEATED NODE



the collapse time in Run #5 is significantly longer, due to the lower temperature difference in condensation. This shows that bubble collapse, in the initial stage at least, is largely thermal in nature.

The remaining four stagnant flow tests were run at lower powers than the first two tests. However, no attempt was made to keep the power exactly the same in the four tests. The temperature of the unheated zone was increased from test to test, though, to further explore the influence of this temperature on flow behavior.

#### 5.1.1.4 Test 6

Conditions during Test 6 featured a very low power as well as a low temperature in the unheated zone. The results of this test are presented in Fig. 5.5 and 5.6. The same general pattern of flow behavior prevails in this test as in the previous two. The beat pattern is especially clear between about 2.5 and 6.5 seconds. However, the amplitudes of the oscillations in this case are smaller than in the previous tests, a fact attributable mainly to the extremely low power level. The average frequency of the oscillations is also much more rapid. This is due partly to the power level and partly to the low upper zone temperature.

An interesting point to note is that there appears




FIGURE 5.5 RESULTS OF TEST 6 - OSCILLATIONS IN BUBBLE LENGTH




FIGURE 5.6 RESULTS OF TEST 6 - TEMPERATURE OF FIRST UNHEATED NODE

to be less of a waiting period in this test than in previous tests. With a low power and low temperature, this is perhaps the reverse of what would be expected. However, the low amplitudes of the oscillations in this case mean that less cold fluid is pulled down during bubble collapse to mix with the hot fluid at the top of the heater. Even though the power is low, this decreased mixing effect contributes to a short waiting period. The effect of the low upper zone temperature is seen primarily in the extremely fast bubble collapse times. In virtually every cycle, the collapse rate is quite rapid, creating the asymmetrical growth-collapse curve. One additional feature to note is the long temperature coastdown between about 5 and 7 seconds. This temperature decrease was very likely due to two effects. First, there was some loss of heat to the environment, and although those losses were generally quite small, this contributed to the cooling. Second, and more important is the fact that there was a dense, low temperature column of water sitting on top of a warmer, lower density region. During the waiting period, then, colder water diffused into the warmer zone, causing some cooling to occur. The effect of this was to increase the waiting period, as seen between about 6 and 7 seconds in Fig. 5.5.

#### 5.1.1.5 Test 7

The power and unheated zone temperature for this test were both higher than their respective values in Test 6. It is perhaps in this run that the features of the flow behavior that have been discussed previously are most clearly seen. Figures 5.7 and 5.8 illustrate the bubble growth and temperature oscillations. In particular, the superposition of oscillatory patterns to create the "beating" seen in Tests 4, 5, and 6 is quite evident throughout the run. Not only does the beat pattern recur, but the beat frequency and average amplitude of the envelope each increase. This behavior is consistent with the higher power and temperature condition. The average frequency of the oscillation is slightly less than in Test 6, as is the waiting period between bubble growth cycle. In addition, the amplitudes of the oscillations, reflected by the maximum bubble lengths, are clearly larger.

#### 5.1.1.6 Tests 8 and 9

The last two stagnant flow tests are presented in Figs. 5.9 through 5.12. In each case, the features discussed in the previous sections pertaining to bubble growth patterns, beating, and amplitudes and frequencies can be seen. The fact that each test essentially reproduces the same behavior, with changes attributable to slightly differ-




FIGURE 5.7 RESULTS OF TEST 7 - OSCILLATIONS IN BUBBLE LENGTH




FIGURE 5.8 RESULTS OF TEST 7 - TEMPERATURE OF FIRST UNHEATED NODE




FIGURE 5.9 RESULTS OF TEST 8 - OSCILLATIONS IN BUBBLE LENGTH






FIGURE 5.10 RESULTS OF TEST 8 - TEMPERATURE OF FIRST UNHEATED NODE




FIGURE 5.11 RESULTS OF TEST 9 - OSCILLATIONS IN BUBBLE LENGTH




FIGURE 5.12 RESULTS OF TEST 9 - TEMPERATURE OF FIRST UNHILATED NODE

ing test conditions indicate that the same basic mechanisms are at work in creating the oscillatory flow behavior.

#### 5.1.2 Forced Convection Testing

Only one experiment was performed with non-stagnant flow. The results of this experiment are presented in Fig. 5.13. Only the temperature downstream of the heater is shown for this run, due to the highly ambiguous bubble length results for this run. The reason for the ambiguous results will be discussed shortly.

The features discussed in relation to stagnant flow oscillatory behavior are largely absent in this test, and the reason for this is quite evident.

The test was carried out by opening the bypass valve and allowing the flow to coast down from approximately 10-15 feet per second to approximately 0.7 feet per second. However, during this time, the power was constant at a level of about 1.09 kilowatts. Under these conditions, the water in the unheated zone was able to heat up to a substantially higher temperature than was present in the stagnant flow tests. The result of this high temperature at bubble inception was to allow the growth of the vapor volume to such an extent that net condensation never exceeded net evaporation by enough to collapse the bubbles, and steady state forced convection two-phase flow eventually was




FIGURE 5.13 RESULTS OF FORCED CONVECTION TEST - TEMPERATURE OF FIRST UNHEATED NODE

established. This is the reason for the ambiguous bubble length readings after data reduction. Since no real flow oscillations occurred, except for the normal variations associated with "steady" two-phase flow, integration of the flow rate did not give dependable void readings. In any case, the vapor present was mainly in the form of small bubbles, not a single vapor slug. This fact in itself would indicate a different flow behavior than that present in the stagnant flow tests. It was believed that setting the power high enough to allow boiling inception before the establishment of high unheated zone temperatures might possibly lead to critical heat flux and subsequent damage to the test section. This was not desirable, and further forced convection tests were not conducted. There were also instrumentation problems associated with the forced convection tests, as well as the same sources of uncertainty as in the other tests. These will be discussed in the following section.

### 5.1.3 Sources of Error and Uncertainties in Experimental Tests

Several factors were present in the experiments that created, or had the potential to create, errors in the measurement of key parameters. These factors were different in the two different types of experiments, and will be

examined separately.

#### 5.1.3.1 Stagnant Flow Tests

The sources of uncertainty and error in the stagnant flow tests are connected mainly with two factors: the dissolved air in the water being used, and the water hammer effects mentioned in Section 5.1.1.

The presence of air on the water has been previously discussed. After becoming liberated from the water in boiling, some of the air formed bubbles which travelled upward through the remainder of the test section. As already noted, these bubbles rendered the flow rate readings from the upper differential pressure transducer virtually meaningless. However, not all of the air travelled up out of the test section. Some of it very likely remained mixed with the steam in the bubble. Upon bubble collapse due to condensation, the air would remain to cushion the oscillation. Some of the very low amplitude oscillations seen in the experimental results may indeed be the result of these air bubbles.

The effect of the water hammer pressure waves on the flow rate measurements has also been mentioned previously in Section 5.1.1.2. The extremely high artificial flow rates inferred from differential pressure measurements during these pressure waves certainly distorted the bubble

length calculations. This effect also made it more difficult to calculate condensation heat transfer coefficients. It is also probable that the waiting period between bubble growth-collapse cycles is partially due to the decay of these pressure waves, although part of that period is undoubtedly genuine. One further possible effect of these waves involves the measurement of flow rates late in the course of the transients. In this case, though the waves generated by the water hammer do tend to decay rapidly, they also propagate throughout the test section, and would tend to reflect back and forth from the two plena. It is possible that, given enough growth-collapse cycles, as sufficient intensity could still remain to distort flow rate readings throughout the cycle, and not just at the beginning and end of the cycles. This may possible account for the behavior between about 7.5 and 9 seconds in Run 8 (Fig. 5.9), for example.

#### 5.1.3.2 Forced Convection Testing

The uncertainties present in this test are largely due to an effect related to the water hammer pressure waves noted in the previous section. When the bypass valve was opened to permit the flow to coast down, severe pressure waves resulted from this flow disturbance. As a result, the flow rate readings inferred from the pressure trans-



ducers are quite unreliable during the first part of the transient.

#### 5.1.3.3 Other Sources of Error

In both types of tests, there are sources of error related to the nature of the instruments themselves. The Validyne transducers proved to be extremely difficult to calibrate and to maintain in a zero-output condition at zero flow. This zero drift was compensated in both the calibration procedure and in the conversion program, but some uncertainties were still possible. The Tyco gauge pressure transducers functioned quite well, in general, and few uncertainties exist in the readings from these instruments. The thermocouples also functioned well, in general. However, thermocouples do have characteristic response times, and cannot record temperature changes instantaneously. The thermocouples in the fluid responded quite rapidly, and the readings were considered reliable. The thermocouples fastened onto the outside of the metal tube tended to respond much more slowly, due to the time constant of the tube itself, the time constant of the thermocouple, and the contact resistance of the thermocouple bead with the metal tube. The resultant response time of these thermocouples was somewhat less rapid, and the readings less reliable. Temperature changes related to the flow oscillations were not re-

corded by these thermocouples.

One final source of error was the data acquisition system itself. When the RTAS was tested, small offsets were found in the output of each channel. These offsets were subtracted from the instrument readings during data reduction, but there is no way of knowing if these offsets were truly constant during a run. In addition, the data acquisition system error band as per manufacturer's specifications was on the order of 0.5%, full scale. This inherent error also contributed somewhat to experimental error.

#### 5.1.4 Calculation of Condensation Heat Transfer Coefficient

Examination of the bubble growth-collapse patterns reveals an extremely asymmetrical behavior. Instead of a bubble collapse which parallels the growth curve, what is seen is a relatively long growth period, followed by a rapid collapse. This indicates a non-uniform heat transfer coefficient over the bubble growth-collapse cycle. In order to ascertain the nature of this non-uniformity, several calculations were performed to determine the condensation heat transfer coefficient.

Results of the calculations for various experiments are shown in Table 5.1. Details of the calculational method can be found in Appendix D.

Table 5.1 Example of Condensation Heat Transfer Coefficients

| Test Number | Bubble Condition | Heat Transfer Coefficient<br>(BTU/hr-ft <sup>2</sup> °F) | hA<br>(BTU/hr°F) |
|-------------|------------------|--|------------------|
| 4           | Growth           | 168.5  | 6.71             |
|             | Collapse         | 3167.1   | 62.71            |
| 5           | Growth           | 325.7  | 10.91            |
|             | Collapse         | 4456.3   | 180.03           |
| 6           | Growth           | 25.0   | 0.19             |
|             | Collapse         | 192.0  | 2.88             |
| 7           | Growth           | 102.4  | 0.36             |
|             | Collapse         | 871.2  | 25.53            |
| 8           | Growth           | 102.2  | 1.62             |
|             | Collapse         | 3587.2   | 100.80           |
| 9           | Growth           | 109.9  | 2.86             |
|             | Collapse         | 3457.5   | 67.08            |

The most interesting aspect of the results is the extremely large magnitude of the heat transfer coefficient during bubble collapse. The reason for this behavior involves another type of flow instability. When a vapor accelerates into a liquid medium, small waves may form at the liquid-vapor interface. This is due to Taylor instabilities. The waves may then break up into small droplets of liquid, creating a mist-flow regime at the very end of the bubble. This type of behavior was documented by Ford (3) in his Freon experiments. Since the heat transfer coefficient shown is based on an area which does not account for any such mechanisms, the result is a coefficient which is quite large. The important parameter is the product of the heat transfer coefficient and the heat transfer area, and this is also shown in Table 5.1. This product represents the heat removal rate ( $q/\Delta T$ ). The calculational method employed to determine the heat removal contains some assumptions, as presented in Appendix D, which might tend to distort the actual numbers; however, the way in which the condensation changes over the period of the bubble growth-collapse cycle is indisputable.

The fact that the heat transfer coefficient effects the oscillatory behavior of the system implies that a circular situation exists; that is, that the system behavior

in turn affects the heat transfer coefficient. The more violent the oscillation, the greater the acceleration of vapor into fluid, and the more extensive the fluid misting effect becomes. This is one reason for the behavior noted in Test 6 - the oscillation amplitude was so small and vapor generation reasonably slow, that the heat transfer coefficient did not have a chance to increase to the same magnitude as in the higher-power experiments.

Although it is qualitatively clear what is happening to the heat transfer coefficient in this type of flow, quantifying the behavior mechanistically is more difficult, and was not conceived as part of this work. Further discussion of this point can be found in Chapter 6.

#### 5.1.5 Comparison of Water Data to Sodium Data

Although the Sodium Boiling Test Facility was not able to operate in a mode precisely comparable to the WTL, it is interesting to compare the results of the water experiments to LOPI experiments carried out in the THORS facility at ORNL. It should be noted that the THORS facility is a multipin bundle, in which two-dimensional effects may be important. However, examination of the results of one of the LOPI tests reveals some interesting parallels.

Figure 5.14 shows the results from THORS test 71H-101. Note that the parameter plotted is flow rate




FIGURE 5.14 EXAMPLE OF THORS RESULTS - VOLUMETRIC FLOW  
OSCILLATIONS

versus time; however, since the flow oscillates about the zero-flow point, it is clear that the integration of the curve to show the bubble length would show the same characteristics. The most outstanding point is the beat pattern that appears during the course of the oscillation cycle. This characteristic is quite similar to the pattern seen in several of the water tests. In addition, there is a change in flow oscillation frequency over the transient, which again parallels the water results.

One other area in which a comparison between water and sodium tests can be drawn is the subject of noncondensable gases. Mention has already been made about some of the effects on dissolved air in the water. It must be noted that in a sodium system, inert gas blankets are used to preclude the potentially dangerous contact of sodium and oxygen. As a result, these gases become dissolved in the sodium, and can behave in much the same manner as air in water. Sodium systems cannot be examined visually during experimentation, of course, to determine the presence of inert gas in the sodium vapor; however, the presence of noncondensables in water experiments should not be considered as a non-prototypic parameter.

## 5.2 Analytical Results

The results of computer simulations of the stag-

nant flow tests are presented in Fig. 5.15 through 5.33. The features of the simulations themselves will be discussed in the next section. Comparison of analytical results to those obtained experimentally will be discussed in the Section 5.2.2.

#### 5.2.1 Features of Analytical Simulations

The information obtained from a computer run includes data on flow rates, bubble pressures, areas, and bubble lengths and volumes. An example of the actual output from the computer is presented in Appendix E. There exists, as part of the program, a subroutine which picks specific pieces of information and plots them, using a library plotting routine. Examples of these plots are presented in Figs. 5.15 through 5.18. The conditions for this run correspond to those shown in the output in Appendix E.

Some of the features to be noted in the plots include the rapid oscillation of all variables plotted as the bubble flows and collapses. Note also, the slight delay between oscillatory cycles and the asymmetric pattern of the growth-collapse cycle.

Figures 5.19 through 5.21 present a slightly different perspective. In these plots, the bubble length within the heater is shown. The conditions for these runs correspond to some of the stagnant-flow test conditions.






FIGURE 5.15 COMPUTER GENERATED PLOT - SIMULATION OF TEST 9: VOLUMETRIC FLOW RATES IN LEGS 1 AND 2




FIGURE 5.16 COMPUTER GENERATED PLOT - SIMULATION OF TEST 9: BUBBLE PRESSURE




FIGURE 5.17 COMPUTER GENERATED PLOT - SIMULATION OF TEST 9: TOTAL BUBBLE LENGTH




FIGURE 5.18 COMPUTER GENERATED PLOT - SIMULATION OF TEST 9: BUBBLE LENGTHS IN LEGS 1 AND 2.




FIGURE 5.19 COMPARISON OF ANALYTICAL RESULTS FOR DIFFERENT HEAT TRANSFER  
COEFFICIENTS - TEST 4 CONDITIONS




FIGURE 5.20 COMPARISON OF ANALYTICAL RESULTS FOR DIFFERENT HEAT TRANSFER COEFFICIENTS - TEST 6 CONDITIONS




FIGURE 5.21 COMPARISON OF ANALYTICAL RESULTS FOR DIFFERENT HEAT TRANSFER COEFFICIENTS - TEST 9 CONDITIONS

However, the condensation heat transfer coefficient has been varied so as to provide a comparison between the results for different heat removal rates.

It is not surprising that, when a high heat transfer coefficient is used, the cycle period is slightly smaller, and the amplitude of the cycle is considerably smaller. This is due largely to the manner in which the code is currently set up.

When the temperature nodal pattern is input to the code, the first node is normally made quite small - on the order of an inch - and the temperature therein is set at saturation. This permits no condensation to occur in that node. This is done for two reasons. First, from a physical standpoint, some hot fluid must flow into the unheated zone before the inception of boiling, due to natural circulation. The resistance of the stalled pump during the stagnant flow tests, however, made the natural circulation flow rate quite small. Therefore, this relatively small volume of fluid was used as a saturated length. This "zone of no condensation" permits growth of the bubble at the start of the cycle. In addition, the heat transfer coefficient, when input as a constant, as was done in these runs, must be set very high, to correspond to the large heat removal rate attained during bubble collapse. The small initial saturated node pro-



vides a de facto variation in condensation heat transfer coefficient. More preferable, of course, would be a mechanistic model of the variation of the heat transfer coefficient during the cycle. However, such a model does not presently exist.

The choice of the length of the saturated node and the condensation heat transfer coefficient together provides a "dial" which the user may adjust. The combination of these two parameters, along with the temperature profile chosen for the unheated zone, legislates, for all intents and purposes, the length of the bubble during the transient. Changes in the temperature profile by virtue of the heat input to or output from the unheated zone during the transient also provide some change in the cycle period and amplitude, and this, too, is demonstrated in all of the figures.

The variation of the heat transfer coefficient during the cycle in the simulations is correct in a broad sense - low at the beginning and high at the peak, and it was felt that trying to vary either the temperature profile or the heat transfer coefficient without some mechanistic base would cause more difficulties than it would solve. The results of this decision are discussed in the next section.

### 5.2.2 Comparison of Analytical and Experimental Test Results

The parameter which is best suited for comparison between the experimental tests and analytical simulations is the bubble length with the heater. This is true for a combination of reasons. First and foremost, this bubble length is the most reliable nonthermal datum that can be derived from the experimental results. The experimentally determined flow rates were subject to effects that do not show up analytically (non-condensables, "water hammer", etc.). Second, this parameter illustrates quite clearly the frequency, amplitude, and asymmetrical behavior of the oscillations.

The bubble length within the heater is plotted, therefore, in Figs. 5.22 through 5.27, for each stagnant flow test and its corresponding computer simulation. The simulations plotted here correspond to the high heat transfer coefficient runs, examples of which were shown and explained in Section 5.2.1. One small change has been made, however: the waiting period between oscillations has been adjusted in the analytical results to agree with that determined experimentally. Therefore, what is shown is actually a cycle-by-cycle comparison of the results.

The reason for the adjustment involves the method




FIGURE 5.22 ANALYTICAL VS. EXPERIMENTAL RESULTS - TEST 4: BUBBLE LENGTH




FIGURE 5.23 ANALYTICAL VS. EXPERIMENTAL RESULTS - TEST 5; BUBBLE LENGTH




FIGURE 5.24 ANALYTICAL VS. EXPERIMENTAL RESULTS - TEST 6: BUBBLE LENGTH




FIGURE 5.25 ANALYTICAL VS. EXPERIMENTAL RESULTS - TEST 7: BUBBLE LENGTH




FIGURE 5.26 ANALYTICAL VS. EXPERIMENTAL RESULTS - TEST 8: BUBBLE LENGTH




FIGURE 5.27 ANALYTICAL VS. EXPERIMENTAL RESULTS - TEST 9: BUBBLE LENGTH



by which the waiting period is determined in the code. The program uses the First Law of thermodynamics to increment the temperature of the initial node back to saturation. However, the temperature after bubble collapse is determined by mixing an arbitrary amount of fluid at saturation with the colder fluid from above the heater. While this arbitrary amount of fluid is chosen from the standpoint of how much physical mixing can occur, it is essentially another user-adjustable "dial". In addition, the large positive flow rate readings produced by the "water hammer" effect probably had a tendency to bias the calculations of bubble length to some extent. This would have shown up most in the waiting period between cycles, due to the decay of these pressure waves. In light of these facts, it was felt that to try to adjust the code to correspond to the actual experimental output would not be a productive exercise. To demonstrate how the actual computer output corresponds to the experimental results, Fig. 5.28 has been included on the following page. This is a combination of Fig. 5.11 and Fig. 5.18, and plots length versus time, calculated without adjusting the delay time against the experimental data. The difference in calculated versus experimental period can also be deduced by examining the temperature versus time plots in Fig. 5.29 through 5.34.




FIGURE 5.28 ANALYTICAL VS. EXPERIMENTAL RESULTS - TEST 9: BUBBLE LENGTHS, NO DELAY  
TIME ADJUSTMENT

In every case, the first and most obvious fact that is apparent is that the experimental results give much larger bubble lengths than the analytical results. The reasons for this are twofold. First, the previously mentioned bias in the experimental flow rate readings, due to pressure waves, tends to distort the bubble lengths determined from those readings. Second, the way in which the condensation heat transfer coefficient varies, both experimentally and analytically, has been discussed in previous sections. Although the variations in heat transfer coefficient throughout the entire cycle have not been accounted for analytically, it is interesting to note that, in almost every case, the initial rise of the bubble growth pattern is very close analytically to what is seen experimentally. This confirms the lack of condensation during this period of the cycle. In a few cases, in Test 6 especially, the entire cycle is very closely simulated, as well. This would tend to confirm the large jump in condensation heat transfer when the bubble begins to collapse. Other tests are more correct qualitatively, though. The fact that there is a mismatch in the experimental and analytical heat transfer coefficients during various times of the cycle explains much of the quantitative disagreement between the two types of results.

Figures 5.29 through 5.34 show the temperature of the first fluid thermocouple in the experiment compared to that of the first non-saturated analytical node, for each stagnant flow test. Note that while the values of the temperatures are not correct quantitatively, in every case, and that the flow oscillatory patterns are somewhat variant, the trends between experimental temperature results and computer simulations agree quite well.

From a qualitative standpoint, then, the analytical results and the experimental results agree quite well. In general, the period of the oscillatory cycles, as well as the asymmetric shape of the cycle curve are in close agreement. In addition, the variation of the amplitude and period during the transient agree fairly well. Due to the large uncertainties in the experimental results, this qualitative agreement in the areas mentioned are much more important than the quantitative disagreement in the actual magnitude of the parameters measured.




FIGURE 5.29 ANALYTICAL VS. EXPERIMENTAL RESULTS - TEST 4: UNHEATED ZONE TEMPERATURE




FIGURE 5.30 ANALYTICAL VS. EXPERIMENTAL RESULTS - TEST 5: UNHEATED ZONE TEMPERATURE




FIGURE 5.31 ANALYTICAL VS. EXPERIMENTAL RESULTS - TEST 6: UNHEATED ZONE TEMPERATURE




FIGURE 5.32 ANALYTICAL VS. EXPERIMENTAL RESULTS - TEST 7: UNHEATED ZONE TEMPERATURE






FIGURE 5.33 ANALYTICAL VS. EXPERIMENTAL RESULTS - TEST 8: UNHEATED ZONE TEMPERATURE




FIGURE 5.34 ANALYTICAL VS. EXPERIMENTAL RESULTS - TEST 9: UNHEATED ZONE TEMPERATURE

## CHAPTER 6

### CONCLUSIONS AND RECOMMENDATIONS

#### FUTURE STUDY

##### 6.1 Conclusions

The results of the experimental and analytical work performed for this project have led to the following conclusions.

1. A model has been developed which will qualitatively describe the processes occurring during flow oscillations of the type studied.
2. Experiments with water indicate that sodium behavior can be successfully simulated using water, despite the large disparity in the physical makeup and properties of the two liquids.
3. A set of criteria has been proposed whereby water and sodium data can be compared. Only a very limited amount of mostly qualitative testing of these criteria has been done as part of this work, however.
4. The temperature profile in the unheated region downstream of the source of heat for the fluid (i.e. core, heater pin, heater tube) has a significant effect in determining the behavior of the system during oscillations.
5. The heat transfer coefficient for condensation also has a significant effect on the flow oscillations. In addition, the coefficient changes over perhaps two orders of magnitude during the oscillations, due to the microscale processes at the liquid-vapor interface, and this change may be one of the driving forces during oscillatory behavior.
6. The existence of flow oscillations helps to draw cool fluid down from the unheated zone into the top of the heated zone. This behavior may well

delay dryout of the heater walls and any subsequent temperature excursions, which might otherwise prove detrimental to providing adequate core cooling during transients.

7. More study is needed in many of the areas delineated in points 1-6.

## 6.2 Recommendations for Future Work

The scope of this project was such that it did not allow detailed study of the condensation heat transfer coefficient. The type of behavior seen was not completely anticipated, and the experiment was not constructed in a way which would easily lead to the development of a mechanistic model of the condensation process during flow oscillations. Clearly, further work is needed in this area.

The criteria proposed for the comparison of sodium and water data have been tested only superficially. It would be useful if the SBTf experiment at ORNL were to be operated in such a way that low-power, low-flow oscillations could be generated for comparison to WTL results. Data from THORS and the multipin experiments is useful from a qualitative standpoint, but the existence of two-dimensional effects due to the radically different experimental geometry may distort efforts to quantitatively compare the data.

The model which has been developed for this project makes a good start toward describing, from a physical basis, the parameters which affect flow oscillatory behavior.

However, it is far from complete, especially with respect to the heat transfer calculational scheme. Further work is required on the model in this area, as well as in the area of expanding the model to a multidimensional tool. A considerable amount of work is underway presently to determine whether multidimensional effects exist in large LMFBR fuel pin bundles. The existence of a multidimensional model to aid in this work would be helpful, and consistent with the original objective of this work to provide a model which might become a module in a large systems code.

Experimentally, there appears to be a wide range of options regarding the simulation of sodium behavior using water. It is clear that certain types of flow behavior can be modelled using water instead of liquid sodium, namely, those types which depend mainly on hydrodynamic processes, rather than thermal ones. Consideration must be given to using small scale water experiments for preliminary investigations of sodium behavior, so that otherwise unexpected effects which might have an adverse effect on sodium experiments may be avoided.

Further work on the effect of loop dynamics on flow behavior should be performed. The means to do this on the Water Test Loop currently exists to some extent, using variable flow orifices in the orifice flange upstream

of the inlet plenum. A parametric study using the FLOSS model might also be valuable.

Finally, more work is needed in quantifying the effect of unheated zone temperature profiles on flow oscillations. Judging from the experimental results obtained in this work, there may, for a certain power, be an optimum temperature profile which would provide the best means of accident abatement. The design of LMFBR cores so that such effects could be used to maximum advantage would be the ultimate result of such future work.

REFERENCES

1. W.D. Hinkle, et.al., "LMFBR Safety and Sodium Boiling, A State of the Art Report", Department of Energy (June, 1978).
2. R.J. Ribando, et al., "Sodium Boiling in a Full Length 19-Pin Simulated Fuel Assembly (THORS Bundle 6A)", ORNL/TM-6553, Oak Ridge National Laboratory (January, 1979).
3. W.D. Ford, "Bubble Growth and Collapse in Narrow Tubes with Nonuniform Temperature Profiles", ANL-7746, Argonne National Laboratory (December, 1970).
4. W.D. Hinkle, "Water Tests for Determining Post Voiding Behavior in the LMFBR", M.I.T. Report MIT-EL-76-005, M.I.T. Energy Laboratory (June, 1976).
5. P.W. Garrison, R.H. Morris and B.H. Montgomery, "Dry-out Measurements for Sodium Natural Convection in a Vertical Channel", ORNL/TM-7018, Oak Ridge National Laboratory (December, 1979).
6. R.W. Bowring, "HAMBO: A Computer Programme for the Sub-channel Analysis of the Hydraulic and Burnout Characteristics of Rod Clusters", AEEW-R 582, UKAEA (1968).
7. A.E. Levin, "Simulation of Flow Behavior in BWR Coolant Channels During Transients", S.B. Thesis, M.I.T. (June, 1975).
8. G.H. Golden and J.V. Tokar, "Thermophysical Properties of Sodium", ANL-7323, Argonne National Laboratory (August, 1967).
9. Perkin-Elmer Computer Systems Division, "OS/16 Operator's Handbook", Perkin-Elmer Corporation (1975).
10. Perkin-Elmer Computer Systems Division, "OS/16 User's Handbook", Perkin-Elmer Corporation (1976).
11. Perkin-Elmer Computer Systems Division, "FORTRAN IV Reference Manual and User Guide", Perkin-Elmer Corporation (1976).

12. Perkin-Elmer Computer Systems Division, "FORTRAN IV Run Time Support", Perkin-Elmer Corporation (1977).
13. J. Aberle, et al., "Sodium Boiling Experiments in a 7-Pin Bundle under Flow Rundown Conditions", KFK 2378, GFK, Karlsruhe, FRG.
14. A.E. Bergles, "Review of Instabilities in Two-Phase Systems", Proc. NATO Advanced Study Institute in Two Phase Flows and Heat Transfer, V.1, Hemisphere Publishing Corp., Washington, D.C. (1977).
15. J. Costa and P. Charlety, "Forced Convection Boiling of Sodium in a Narrow Channel", in Liquid Metal Heat Transfer and Fluid Dynamics, A.S.M.E. (1970).
16. A.W. Cronenberg, "A Thermohydrodynamic Model for Molten  $UO_2$ -Na Interaction, Pertaining to Fast-Reactor Fuel-Failure Accidents", ANL-7947, Argonne National Laboratory (June, 1972).
17. M.H. Fontana, "THORS Bundle 6A Boiling Stability Test Results", Report presented at D.O.E. Conference, Boston (August, 1977).
18. P.W. Garrison, SBTF Test Results, Personal Communication (January, 1979).
19. R.E. Henry, et al., "OPERA Single-Pin Coastdown Expulsion and Reentry Test", ANL-75-17, Argonne National Laboratory (February, 1975).
20. W. Kowalchuk and A.A. Sonin, "A Model for Condensation Oscillations in a Vertical Pipe Discharging Steam into a Subcooled Water Pool", NUREG/CR-022, M.I.T. (June, 1978).
21. W. Peppler and E. G. Schlechtendahl, "Experimental and Analytical Investigations of Sodium Boiling Events in Narrow Channels", Proc. Winter Annual Meeting, ASME, in Liquid Metal Heat Transfer and Fluid Dynamics, A.S.M.E. (November, 1970).



22. M. Pezzilli, et al., "The NEMI Code for Sodium Boiling, and its Experimental Basis", in Liquid Metal Heat Transfer and Fluid Dynamics, A.S.M.E. (1970).
23. T.A. Shih, "The SOBOIL Program - A Transient, Multi-channel, Two-Phase Flow Model for Analysis of Sodium Boiling in LMFBR Fuel Assemblies, G.E. ST-TN-79008, General Electric Corp., A.R.S.D.
24. M.G. Stevenson, et al., "Current Status and Experimental Basis of the SAS LMFBR Accident Analysis Code System", CONF-740401-P3, Proc. Fast Reactor Safety Mtg., Beverly Hills, CA (April, 1974).
25. D.H. Thompson, et al., "SLSF In-Reactor Experiment P3A-Interim Post-Test Report", ANL/RAS 77-, Argonne National Laboratory (November, 1977).
26. J.G. Collier, Convective Boiling and Condensation, McGraw-Hill Book Company, LTD, London (1972).
27. R.H. Sabersky, A.J. Acosta, and E.G. Hauptmann, Fluid Flow, 2nd Ed., The MacMillan Co., New York (1971).
28. W.M. Rohsenow and H.Y. Choi, Heat, Mass and Momentum Transfer, Prentice-Hall, Inc., New Jersey (1961).
29. M. Clark, J. and K.F. Hansen, Numerical Methods of Reactor Analysis, Academic Press, New York (1964).
30. R.H. Perry and C.H. Chilton, Eds., Chemical Engineers' Handbook, 5th Ed., McGraw Hill Book Company, New York (1973).
31. R.L. Powell, et al., "Thermocouple Reference Tables Based on the IPTS-68", NBS Monograph 125, U.S. National Bureau of Standards (March, 1974).
32. F.E. Dunn, et. al., "The SAS2A LMFBR Accident Analysis Computer Code," ANL/RAS 73-39, Argonne National Laboratory (December, 1973).
33. R.E. Barry and R.E. Balshizer, "Condensation of Sodium at High Heat Fluxes," Proc. 3rd Int. Heat Transfer Conf., V.II (1966).

## APPENDIX A

### THE COMPUTER CODE FLOSS

#### A.1. General Description of the Code

The computer code FLOSS is a relatively small and simple program designed to solve the equations for the hydrodynamic and thermal models. It was developed as part of this project, and is envisioned as a module of a large system-scale code at some future time. Because of this ultimate aim, many complicating features, such as sophisticated heat transfer models, were omitted. In addition, since the model deals only with a fixed regime, single phase flow before the transient and two-phase flow after the transient have not been modelled. Instead, the primary aim was to develop a code which could be easily understood and would take small amounts of computer time to run, yet would include as much of the essential physics of the problem as possible. This aim has been, for the most part, achieved.

#### A.2. Solution of the Hydrodynamic and Thermal Models

The solution scheme for the equations presented in Chapter 2 is an amalgam of different techniques for finite difference solutions of differential equations. The entire code is semi-implicit, with an iterative scheme described in Chapter 2.

### A.2.1 The Hydrodynamic Model

The equations for the hydrodynamic model are:

$$\Delta P' = I_1 \frac{dQ_1}{dt} + R_1' Q_1^2 \quad (2.28)$$

$$\Delta P' = I_2 \frac{dQ_2}{dt} + R_2' Q_2^2 \quad (2.29)$$

$$Q_3 = \frac{V_g}{\rho_g} \frac{d\rho_g}{dt} \quad (2.11)$$

The first two equations are solved using a first-order, explicit finite difference scheme. The equations can be rearranged into the form

$$\frac{dQ_2}{dt} = \frac{\Delta P'}{I_i} - \frac{R_i'}{I_i} Q_2^2 \quad (A.1)$$

where  $i$  can be either 1 or 2.

This is then transformed into a finite difference equation:

$$\frac{Q_i^n - Q_i^{n-1}}{\Delta t} = \frac{\Delta P',n}{I_i^n} - \frac{R_i',n-1}{I_i^n} (Q_i^{n-1})^2 \quad (A.2)$$

where  $n$  is a time index.

The final form of the equation, upon rearrangement of terms, is

$$Q_i^n = Q_i^{n-1} + \frac{\Delta t}{I_i^n} [\Delta P^n - R_i^{n-1} (Q_i^{n-1})^2] \quad (A.3)$$

Equation (2.11) is solved by an implicit, first order finite difference approximation

$$Q_3^n = \frac{v_g^n}{\rho_g^n} \left( \frac{\rho_g^n - \rho_g^{n-1}}{\Delta t} \right) \quad (A.4)$$

Because of the explicit nature of the equations solved by Eq. (A.3), special attention must be paid to the time step. The time step size is limited by the Courant condition

$$\frac{\Delta x}{\Delta t} \geq v \quad (A.5)$$

That is, the time step must be small enough that the velocity does not allow the calculation to cross more than one node. This becomes important during the temperature profile calculation in the unheated zone. During condensation, the rapidity of the bubble collapse creates extremely large velocities, relative to the bubble growth period. For this reason, a variable time step is employed in the solution of Eq. (A.3). If the solution fails to converge at a large time step, the step is reduced by a factor of two, and the solution procedure is repeated. If convergence is not achieved

after several successive reductions, it is assumed the bubble has collapsed entirely or undergone an expulsion. The method for dealing with this problem is discussed in Section A.3.1.

### A.2.2 The Thermal Model

The equation for the thermal model is

$$Q_s = (\dot{q}_{\text{net}} + \frac{V_g}{dt} \frac{dP}{dt}) / \rho_g h_{fg} \quad (2.27)$$

This equation is also solved by an implicit, first-order finite difference approximation

$$Q_s^n = [\dot{q}_{\text{net}}^n + V_g^n (\frac{P^n - P^{n-1}}{\Delta t})] / (\rho_g^n h_{fg}^n) \quad (A.5)$$

## A.3 The Structure of the Code

To provide ease of handling and understanding, the code is split into a main section and several subroutines. Each routine is briefly explained in this section.

### A.3.1 FLOSS-MAIN Program

The MAIN portion of the code provides the basic framework for the simulation of transients. In addition, schemes for variable time step size and non-convergence restarting are included. Initially, data are input and con-

verted to an internally consistent set of units, a proper call sequence for the actual calculational subroutines is established, initial conditions are established, and output is arranged to be easily readable.

One of the limitations that has been determined by use of the code is the necessity to generate a sufficient amount of vapor during the initial time step of the transient. By trial and error, the amount of power required for this to occur is such that

$$(\text{Input Power}) \cdot (\text{time step}) \approx 0.025 \text{ kw-sec} \quad (\text{A.6})$$

This is the only initial constraint. However, for very low powers, large initial time steps must be used. The code, through the variable time step calculation, will adjust the size of the time step as necessary to allow convergence.

If convergence does not occur, as described in Chapter 2, that is, if the thermal and hydrodynamic models cannot be made to generate the same bubble size, a check is made of the temperature in the initial node downstream of the heater. If this temperature is below the saturation temperature at initial pressure, as is usually the case, it is an indication that the bubble has collapsed entirely, and the calculation is restarted. This is accomplished by

assuming that a small amount of fluid at the top of the heater, originally at saturation, is mixed with the lower temperature fluid in the first unheated node. The mean temperatures of this fluid is then determined, and a heat balance is performed on this fluid, using the heater power as a heat source. The temperature of the fluid in this node is thereby increased, while temperatures in the upper nodes of the unheated zone are held constant. When the temperature in the first node reaches saturation, the calculation of the transient proceeds anew. In this way, the "waiting period" seen experimentally is reproduced.

If the temperature of the initial unheated node is greater than or equal to saturation at nonconvergence, it is assumed that an expulsion of fluid has occurred, and the transient is ended at that point.

#### A.3.2 Subroutine HYDRO

This subprogram solves the hydrodynamic model, as previously outlined in A.2.1. The differencing scheme is established, as well as the iterative scheme for calculation of the bubble lengths and volumes. Error convergence limits, read in as data, are applied in this routine.

#### A.3.3. Subroutine HEAT

This routine solves the thermal model, as previously described. The bubble is split into two volumes, one in

the heated zone and one in the unheated zone. The heat inputs and outflows are calculated separately for each "half-bubble", and the total size is then determined. Convergence criteria are set up such that not only must the total bubble size be consistent, but the two separate zones must also converge. There also exists the means to account for wall heat capacity effects.

In addition, the unheated zone temperature profile is calculated. The method for this calculation is quite involved, and the code listing should be referred to in order to understand the details of the scheme. To summarize the scheme, a search is performed to locate the vapor-liquid interface at each time step. That having been accomplished, the temperature of each node is then calculated on a volume-averaged basis:

$$T_i^n = (T_i^{n-1} V_i^n + T_i^{n-1} dV_{ij} + \frac{q_i^{n-1} \Delta t}{\rho^{n-1} C_p^{n-1}}) / V_i \quad (A.7)$$

In Eq. (A.7),  $i$  and  $j$  represent the volume being calculated and the adjacent volume respectively. This volume is either above or below volume  $i$ , depending on whether the bubble is expanding or contracting. The term  $T_i^{n-1} V_i^n$  represents the temperature of the node at the previous time step multiplied by the volume of that fluid remaining in



the node at the current time step. The second term represents the temperature of the adjacent node, multiplied by the amount of fluid pushed from node  $j$  into node  $i$  by bubble movement, and the final term represents any heat input to the node due to condensation at liquid vapor interfaces multiplied by the volume over which the heat transfer occurs. This sum is then divided by the nodal liquid volume, the result being the volume-averaged temperature of the node. This procedure is performed for each node at each time step, during each iteration.

#### A.3.4 Subroutine AREA

This short subprogram calculates the cross-sectional area of the bubble, based on a weighted average of the film thickness. A constant void fraction is assumed at initial bubble formation, equal to the inverse of the turbulent velocity drift flux constant, i.e.  $1/C_0$ . Subsequent evaporation in the heated zone is accountable for areal changes. The void fraction in the unheated zone remains  $1/C_0$  at all times.

#### A.3.5 Subroutine HTCDEF

This portion of the code calculates the condensation heat transfer coefficient for the upper unheated zone. Three options exist for the determination of this parameter: a constant heat transfer coefficient which has been input

as data (KHT=1); the Dittus-Boelter correlation, based on vapor velocity and properties (KHT=2); or an option that allows the user to input his own correlation or model (KHT=3). If the first option is chosen, the heat transfer coefficient does not change at all over the period of the transient; however heat transfer rates may be changed by changing the unheated zone temperature profile.

#### A.3.6 Subroutine PGUESS

This subroutine contains the logic for guessing the pressure during the iterative process described in Chapter 2. For each pressure guess, an error is calculated based on the difference between the hydrodynamic and thermal flow rate:

$$\epsilon = (Q_H - Q_T) / [(|Q_H| + |Q_T|) / 2] \quad (\text{A.8})$$

This error may be positive or negative. If positive, the pressure is reduced until a negative error is generated. If the error is negative, the pressure is subsequently increased. When two errors exist of opposite sign, a method of successive linear approximations is employed to continue guessing the pressure until the convergence limits are reached. This method is shown in Fig. A.1. The equation represented by this linear method is




FIGURE A.1 METHOD FOR GUESSING PRESSURES IN FLOSS

$$P = \frac{\Delta P}{\Delta \epsilon} \epsilon + B \quad (\text{A.9})$$

where B is the y-intercept. The method has proven to be reliable, and, for the most part, rapidly convergent.

#### A.3.7 Subroutine RESIN

This routine calculates resistances and inertances for solution of the hydrodynamic equations. It also contains the logic for deriving equivalent values for parallel bypass loops, using an analog to electrical systems. The numbering scheme for this calculation is shown in Fig. A.2. The scheme must be followed exactly as shown for the code to calculate the bypass equivalent values properly.

#### A.3.8 Subroutine FFACTR

This subprogram calculates the friction factors for the previous subroutine RESIN, for determination of resistance terms. The calculation is based on the Reynolds number of the liquid flow in each part of the system. If the Reynolds number is less than 2000, the laminar value

$$f = \frac{16}{\text{Re}} \quad (\text{A.10})$$

is used.




FIGURE A.2 NUMBERING SYSTEM FOR COMPONENTS IN FLOSS

For 2000 <Re <50000

$$f = 0.0791 \text{ Re}^{-0.025} \quad (\text{A.11})$$

If Re > 50000

$$f = 0.046 \text{ Re}^{-0.020} \quad (\text{A.12})$$

#### A.3.9 Subroutine PROP

This routine calculates properties of either water or liquid sodium, depending on the option chosen. The water properties are based on polynomial expressions derived by Bowring (6), and are taken from Levin (7). The sodium properties were derived by Golden and Tokar (8).

#### A.3.10 Subroutine PLOTTER

The Joint Computer Facility at M.I.T. maintains a FORTRAN library subroutine called PICTR which enables computer developed plots to be made using a VARIAN electrostatic plotter. This subroutine contains the logic which sets up the output from a simulated transient in a form to be used by the PICTR routines. Information on these routines is available from the JCF.

#### A.4 Restrictions on Code Use

Several restrictions on the use of the code have

been noted already in this Appendix. These will be reviewed, and some other restrictions explained.

1. The energy input to the model during the start of the transient must be about 0.025 kw-sec.
2. The Courant condition  $\frac{\Delta x}{\Delta t} > v$  applies during rapid bubble movement. This restriction is automatically considered in the inclusion of a variable time step calculation.
3. The nodalization scheme for the unheated zone is very flexible, as it allows an input not only of the nodal temperatures, but of nodal lengths as well. The initial node should be very short - on the order of two inches or less - and the temperature should be at or near saturation, to allow bubble growth. It is believed that these are the conditions that physically prevail at bubble initiation. The remainder of the nodal lengths should be chosen judiciously. Too long a length will cause the nodal averaged temperature to be far too low, compared to reality, while too short a length would cause temperatures to be too high, and unnecessarily restrict time step size. A sample problem is shown in Appendix D. For most transients, nodal lengths on the order of 0.4 - 1.0 foot have been found to be satisfactory. The scheme for calculation of nodal temperature also breaks down if the bubble interface crosses two nodal interfaces in the same time step. This presents an additional restriction for which the Courant condition must account. Choice of nodal lengths must therefore be chosen such that time step sizes do not become so small as to significantly increase code execution time.
4. The error criterion for convergence of the thermal-to-hydrodynamic comparison has been kept relatively high for most simulations, to cut down on computer time requirements. Reduction of the convergence limit appears to have little effect on the values generated by the code. The convergence criteria for bubble lengths and volumes are related to the error convergence limit, and must be set to approximately the same value. The sample input in Appendix D illustrates this fact.

APPENDIX B  
DESCRIPTION AND USE OF THE COMPUTER  
DATA ACQUISITION SYSTEM

B.1 Background

The general structure of the CCDAS apparatus has been previously described in Chapter 4. The purpose of this appendix is to describe the hardware, software, and operating procedures associated with the system in more detail.

The system is now operating as a data acquisition and data conversion unit in the M.I.T. Heat Transfer Laboratory.

B.2 Hardware

The CCDAS is built from several different components in order to provide a wide range of usage, both as a computer and as a data acquisition system.

The heart of the system is a Perkin-Elmer Model 1610 Minicomputer. This is a 16-bit machine, with a currently installed capacity of 64 kilobytes of semiconductor memory. The memory may be expanded to as much as 128 kilobytes in 32 kb increments. The computer is equipped with a line frequency clock, which can provide processor interrupts at up to twice the line frequency (120 hz). Processor options on the HTL computer include a precision integral clock,



a battery backup system, and a hardware multiplication/division unit. The PIC will provide interrupts at a rate faster than the line frequency clock, if necessary. The battery backup system provides a power system backup to preserve information in memory in the event of a power failure. The hardware multiply/divide option allows the computer to perform these operations directly, instead of through software programming. This allows the operations to be done much more quickly.

These are several peripherals which are connected to the minicomputer. The system command console is a Perkin -Elmer Model 550 CRT. This is an essential piece of equipment, since the minicomputer itself has no built-in command-issuing unit. The CRT is a standard type of visual display unit, with a keyboard and viewing screen, providing interactive use of the computer. In addition, the CRT has a printer port built into the back of the unit, which allows connection to a CRT page printer. The page printer used in this system is the Perkin -Elmer Model 650 "Pussy-cat" Thermal Printer. The printer will print 24 lines, a full screen display, automatically upon receipt of 24-line feed signals from the CRT. The printer is a single buffer machine, which does not allow data to be received and stored while printing is taking place. Therefore the display must be advanced twenty-four lines and then halted,

printing permitted, and then display scrolling advanced in order to allow printing of all information.

Data and program storage are provided by a dual floppy disk system. Each disk contains space for up to 256 kilobytes of information, either in ASCII (source) or binary (object or image) form.

The last peripheral is the data acquisition unit, itself. The RTAS (see Chapter 4) currently allows up to 24 instruments to be connected for input to the computer, and capacity may be expanded to 32 channels in 4-channel increments, in the present configuration. The termination panel is supplied with a calibrated Resistance Temperature Device (RTD) to serve as an equivalent ice-point for thermocouples. If the RTD is used, it must be connected to one of the RTAS channels. Maximum scanning speed is 8000 points per second. Data is stored in the computer by means of software programming. Each data point is stored as a number ranging from -2048 to +2047. To convert these data to meaningful information, the value must be multiplied by a gain factor, which is set by the user. Each channel has a variable gain, which is set through input to the controlling software, which ranges from  $\pm 20$  to  $\pm 1000$  millivolts, full scale; the gain factor is then the full scale output divided by 2048. This

configuration provides a very flexible system which is not difficult to operate. The system is shown schematically in Fig. B.1.

### B.3 Software

The software supplied by Perkin-Elmer includes support for all peripherals, and is currently configured for the FORTRAN computer language. Support for other languages is available from the vendor.

The computer is controlled by an operating system, created by means of a system generation (SYSGEN). The SYSGEN procedure, which can be performed by the vendor or the user, sets the operating environment for the system, and tells the computer which peripherals are available and which processing options are necessary for the user's requirements. The SYSGEN is performed by using several assembly language programs supplied by Perkin-Elmer. These include a Configuration Utility Program (CUP), which sets the system environment, and three packages which tell the computer how to perform functions in the given environment. These are the Command Processor, The File Manager, and the System Executive. Once a SYSGEN is performed using these programs, the resultant operating system must be loaded into the computer before any operations can be performed.

The present system provides support for the RTAS,




FIGURE B.1 SCHEMATIC OF COMPUTER SYSTEM

CRT, and floppy disk drives. It also includes a partition system for the memory, which allows several programs to be held in memory simultaneously, although only one program may be active at a time. Currently, the system is configured for five foreground partitions and one background partition; the size of each partition may be set by the user. There is also a system partition, which must be allowed to exist for the computer to process information.

The software for FORTRAN programming includes a FORTRAN compiler and a run-time library. The former program allows the FORTRAN source programming to be converted to binary code, and the latter provides support for library mathematical and real-time routines. Linkage between user programs and FORTRAN library functions is provided through use of the vendor-supplied Task Establishment Utility Program. This program also converts the output from the FORTRAN compiler (object code) to executable code (image code).

The remaining software that has been supplied by Perkin-Elmer includes several driver programs to allow the RTAS to be operated. This software includes both assembly language and FORTRAN programming. The function of the programming is to provide for generation of interrupts, data sampling, data storage, disk allocation, and transfer of acquired data from computer memory to disk. Once the data

have been put onto the floppy disk, further data processing may be accomplished through user-written data conversion programming.

#### B.4 Operation of the CCDAS

The operation of the CCDAS involves several steps and will be explained briefly in this section. A detailed instruction manual is under preparation at this time, and Perkin-Elmer's own handbooks are also valuable references.

Initially, the system is started up using the operating system described in Section B.3. The foreground partitions are then set to accomodate two programs: a test supervisory program (TSTSUP) and a data acquisition system driver program (DATACQ). Logical input and output units are then assigned by the user. The input to DATACQ is provided by the RTAS. The input to TSTSUP is provided by the user and includes:

- 1) The name of the file in which acquired data is to be stored.
- 2) The time interval at which interrupts are to be generated.
- 3) The number of channels to be sampled.
- 4) The list of channels and their respective gains, in the order in which sampling is to be done.
- 5) The number of scans to be made.

The number of scans to be performed (item 5) is

determined by dividing the total transient time, which is not an input, by the sampling interval (item 2).

The TSTSUP program is activated upon the user's START command on the console. This command is issued about 5 seconds before the sampling period is to begin, to allow the programs to start properly. The initial program reads the input data, opens a file on one of the floppy disks for RTAS output, then initiates the DATAcq program and pauses. The DATAcq program generates interrupts at the desired intervals. Each interrupt allows the scanning to proceed. This is done at the maximum rate, and the data is stored in complete memory. After several scans, DATAcq sends a signal to TSTSUP, and TSTSUP activates a small data-logging subroutine, which transfers data from computer memory to the file opened initially by TSTSUP. This procedure continues until the number of samples input as item 3 have been acquired. The program then ceases execution. The user may then load a conversion program into the computer which reads the data from the floppy disk, and converts it, using the gain factors described in the previous section, plus any conversion tables (e.g., calibration curves, thermocouple tables), to engineering units or millivolts, depending on the user's desire.

A flowchart of the data acquisition procedure is shown in Fig. B.2.




FIGURE B.2 DATA ACQUISITION FLOW CHART



## APPENDIX C

### EXAMPLE OF EXPERIMENTAL RESULTS

#### C.1. Data Conversion and Presentation

After the acquisition of data as described in Appendix B, this information was converted to temperatures, pressures, and flow rates by use of calibration information and thermocouple tables, as described in Chapter 4. In addition, a stepwise integration of the flow rates was performed to estimate the length of the vapor bubbles above and below the top of the heater. As explained in Chapter 5, the readings of flow rate from the upper  $\Delta P$  transducers proved to be quite unreliable. Also, since 375 points were required for each instrument for each transient, it would be impractical to present every piece of data acquired. Therefore, an example of the output from each stagnant flow experiment will be shown in the first six tables. The data shown include:

1. The flow rate, as determined by the lower  $\Delta P$  cell.
2. The temperature of the first thermocouple in the fluid downstream of the top of the heater.
3. The length of the bubble below the top of the heater.

There are two important points to be made with respect to items 1 and 3. First, a negative flow rate indicates bubble growth downward. A positive flow rate

indicates bubble collapse. The second point, then, involves the large positive flow rates generated after bubble collapse. These readings were attributed in Chapter 5 to "water hammer" effects due to bubble collapse. This effect is clearly shown, for example, in Table C.4, at 1.8 and 2.4 seconds. Since a positive flow rate corresponds to bubble collapse, it is clear that continuing to integrate these flow rates after the bubble length has reached zero would provide non-physical results. Thus, upon bubble collapse to zero length, no further integration is performed until a negative flow rate is generated. This explains the form in which the results appear. The data are presented at 0.2-second intervals, which represents five data-taking cycles. Apparent mismatches in flow rate, bubble length, and temperature are attributable in every case to the fact that the duration of bubble growth-collapse cycle is not exactly a multiple of 0.2 seconds; therefore, in Table C.1, for instance, at 0.4 seconds, a positive flow rate (bubble collapsing) is shown, whereas the bubble length is greater than at 0.2 seconds. This indicates that the bubble grew considerably after 0.2 seconds, and had just begun to collapse at 0.4 seconds.

Results from the forced convection test are difficult to decipher because of the effects on the fluid of the valve movement when the flow rate was reduced. Qualitatively,

the results indicate that, after boiling inception, the flow oscillates slightly due to normal fluctuations that occur during "steady" two-phase flow. However, there are no real oscillations similar to those in the stagnant flow tests. The temperature downstream of the heater is shown, however, to indicate the high temperature at boiling inception, which caused the transition immediately to bubbly, steady two-phase flow.

Table C.1 - Example of Results from Test 4

| Time After Boiling<br>Inception | Flow Rate<br>( $10^{-4}$ ft <sup>3</sup> /sec) | Calculated Bubble<br>Length (In) | Temperature<br>At First TC<br>Downstream of<br>Heater (°F) |
|---------------------------------|--|----------------------------------|--|
| 0.0                             | -0.02  | 0.00                             | 74.64  |
| 0.2                             | -3.34  | 2.89                             | 94.63  |
| 0.4                             | 1.14   | 12.19                            | 163.32   |
| 0.6                             | -0.26  | 5.86                             | 144.52   |
| 0.8                             | 0.17   | 4.86                             | 157.78   |
| 1.0                             | 5.41   | 1.88                             | 171.12   |
| 1.2                             | 1.60   | 0.00                             | 173.54   |
| 1.4                             | -0.28  | 0.24                             | 184.05   |
| 1.6                             | -0.81  | 1.69                             | 182.11   |
| 1.8                             | 14.49  | 0.00                             | 193.30   |
| 2.0                             | 4.05   | 0.00                             | 173.93   |
| 2.2                             | -0.22  | 0.10                             | 174.72   |
| 2.4                             | -1.61  | 6.60                             | 172.29   |
| 2.6                             | 9.20   | 2.57                             | 188.30   |
| 2.8                             | 5.00   | 0.00                             | 176.59   |
| 3.0                             | 0.05   | 0.00                             | 173.54   |
| 3.2                             | -1.57  | 2.81                             | 169.62   |
| 3.4                             | 10.51  | 0.00                             | 167.27   |
| 3.6                             | -4.23  | 4.33                             | 171.98   |
| 3.8                             | 0.68   | 3.60                             | 174.72   |
| 4.0                             | 6.63   | 0.00                             | 206.66   |
| 4.2                             | 28.66  | 0.00                             | 181.72   |
| 4.4                             | -10.35   | 7.60                             | 162.93   |
| 4.6                             | 8.32   | 22.39                            | 197.82   |
| 4.8                             | 4.97   | 0.00                             | 210.82   |
| 5.0                             | 1.72   | 0.00                             | 194.45   |

Table C.2 - Example of Results from Test 5

| Time After Boiling<br>Inception | Flow Rate<br>( $10^{-4}$ ft <sup>3</sup> /sec) | Calculated Bubble<br>Length (In) | Temperature<br>At First TC<br>Downstream of<br>Heater (°F) |
|---------------------------------|--|----------------------------------|--|
| 0.0                             | -0.01  | 0.00                             | 102.21   |
| 0.2                             | 0.41   | 0.36                             | 106.40   |
| 0.4                             | 0.22   | 0.11                             | 115.46   |
| 0.6                             | -4.01  | 2.38                             | 148.93   |
| 0.8                             | 4.61   | 4.70                             | 172.21   |
| 1.0                             | -0.46  | 0.22                             | 159.68   |
| 1.2                             | 5.51   | 0.00                             | 166.40   |
| 1.4                             | -0.47  | 0.22                             | 161.27   |
| 1.6                             | -3.50  | 8.83                             | 182.03   |
| 1.8                             | 24.92  | 0.00                             | 178.92   |
| 2.0                             | -3.11  | 2.03                             | 169.94   |
| 2.2                             | 2.94   | 12.00                            | 189.38   |
| 2.4                             | 13.30  | 0.00                             | 190.92   |
| 2.6                             | -0.31  | 0.14                             | 178.92   |
| 2.8                             | -6.69  | 11.83                            | 189.76   |
| 3.0                             | 26.09  | 0.00                             | 206.96   |
| 3.2                             | 2.74   | 0.00                             | 195.83   |
| 3.4                             | -0.34  | 0.16                             | 188.22   |
| 3.6                             | -2.49  | 10.02                            | 204.68   |
| 3.8                             | 6.33   | 0.14                             | 212.25   |
| 4.0                             | 11.72  | 0.00                             | 211.12   |
| 4.2                             | 15.07  | 0.00                             | 208.47   |
| 4.4                             | 8.47   | 0.00                             | 200.49   |
| 4.6                             | -13.62   | 11.54                            | 181.26   |
| 4.8                             | 6.24   | 26.40                            | 198.20   |
| 5.0                             | 1.92   | 10.81                            | 193.99   |

Table C.3 - Example of Results from Test 6

| Time After Boiling<br>Inception | Flow Rate<br>( $10^{-4}$ ft <sup>3</sup> /sec) | Calculated Bubble<br>Length (In) | Temperature<br>At First TC<br>Down-<br>stream of Heater<br>(°F) |
|---------------------------------|--|----------------------------------|---|
| 0.0                             | -0.03  | 0.00                             | 78.12   |
| 0.2                             | -0.84  | 0.92                             | 81.55   |
| 0.4                             | -0.27  | 3.14                             | 152.63  |
| 0.6                             | 21.99  | 0.00                             | 156.22  |
| 0.8                             | -0.52  | 0.49                             | 148.24  |
| 1.0                             | 0.02   | 2.80                             | 155.42  |
| 1.2                             | 10.99  | 0.00                             | 154.23  |
| 1.4                             | -1.18  | 1.09                             | 152.63  |
| 1.6                             | 1.99   | 1.78                             | 163.04  |
| 1.8                             | 4.51   | 0.00                             | 162.56  |
| 2.0                             | -1.81  | 1.93                             | 160.58  |
| 2.2                             | 11.92  | 0.00                             | 175.13  |
| 2.4                             | 1.33   | 0.00                             | 163.75  |
| 2.6                             | -0.84  | 1.16                             | 170.83  |
| 2.8                             | 10.56  | 0.00                             | 166.90  |
| 3.0                             | -0.26  | 0.14                             | 160.98  |
| 3.2                             | -0.30  | 2.38                             | 178.95  |
| 3.4                             | -0.30  | 0.14                             | 166.11  |
| 3.6                             | -0.18  | 1.26                             | 163.35  |
| 3.8                             | 5.73   | 0.00                             | 158.60  |
| 4.0                             | 0.18   | 0.12                             | 155.03  |
| 4.2                             | -0.46  | 1.03                             | 151.04  |
| 4.4                             | -0.45  | 3.84                             | 168.47  |
| 4.6                             | 2.21   | 0.00                             | 161.38  |
| 4.8                             | 1.97   | 0.00                             | 159.40  |
| 5.0                             | -0.26  | 0.17                             | 154.63  |

Table C.4 - Example of Results from Test 7

| Time After Boiling<br>Inception | Flow Rate<br>( $10^{-4}$ ft <sup>3</sup> /sec) | Calculated Bubble<br>Length (In) | Temperature<br>At First TC<br>Downstream<br>of Heater (°F) |
|---------------------------------|--|----------------------------------|--|
| 0.0                             | 0.02   | 0.00                             | 99.56  |
| 0.2                             | -0.03  | 0.53                             | 105.85   |
| 0.4                             | -0.52  | 0.42                             | 110.43   |
| 0.6                             | -0.10  | 0.05                             | 115.91   |
| 0.8                             | -1.02  | 1.13                             | 131.02   |
| 1.0                             | -0.15  | 0.07                             | 141.56   |
| 1.2                             | -0.14  | 0.18                             | 164.30   |
| 1.4                             | 16.88  | 0.00                             | 160.35   |
| 1.6                             | -3.69  | 3.52                             | 155.59   |
| 1.8                             | 31.88  | 0.00                             | 173.73   |
| 2.0                             | -0.86  | 0.62                             | 149.68   |
| 2.2                             | -2.90  | 7.32                             | 161.14   |
| 2.4                             | 27.07  | 0.00                             | 163.91   |
| 2.6                             | -2.07  | 1.55                             | 149.20   |
| 2.8                             | 8.53   | 3.71                             | 182.30   |
| 3.0                             | 1.47   | 0.00                             | 163.51   |
| 3.2                             | -2.82  | 4.48                             | 165.09   |
| 3.4                             | 8.60   | 0.00                             | 179.27   |
| 3.6                             | -0.15  | 0.07                             | 170.20   |
| 3.8                             | -1.46  | 2.74                             | 169.42   |
| 4.0                             | 8.53   | 0.00                             | 172.95   |
| 4.2                             | -0.33  | 0.31                             | 167.85   |
| 4.4                             | -0.14  | 1.57                             | 177.24   |
| 4.6                             | 25.50  | 0.00                             | 176.07   |
| 4.8                             | -2.88  | 2.41                             | 166.67   |
| 5.0                             | 11.78  | 2.51                             | 183.85   |

Table C.5 - Example of Results from Test 8

| Time After Boiling<br>Inception | Flow Rate<br>( $10^{-4}$ ft <sup>3</sup> /sec) | Calculated Bubble<br>Length (In) | Temperature<br>At First TC<br>Downstream of<br>Heater (°F) |
|---------------------------------|--|----------------------------------|--|
| 0.0                             | -0.03  | 0.00                             | 116.64   |
| 0.2                             | -0.03  | 0.66                             | 124.14   |
| 0.4                             | 1.36   | 0.00                             | 128.56   |
| 0.6                             | -1.73  | 1.38                             | 158.75   |
| 0.6                             | 13.36  | 0.00                             | 174.50   |
| 1.0                             | -1.40  | 1.55                             | 185.07   |
| 1.2                             | 15.64  | 0.00                             | 176.91   |
| 1.4                             | -2.65  | 2.12                             | 171.05   |
| 1.6                             | 24.70  | 0.00                             | 178.86   |
| 1.8                             | -0.40  | 0.18                             | 167.83   |
| 2.0                             | -2.10  | 8.81                             | 187.77   |
| 2.2                             | 15.96  | 0.00                             | 183.52   |
| 2.4                             | -2.18  | 1.73                             | 179.56   |
| 2.6                             | 12.92  | 0.00                             | 182.28   |
| 2.8                             | -0.12  | 0.13                             | 178.78   |
| 3.0                             | -0.11  | 0.64                             | 199.21   |
| 3.2                             | 3.84   | 0.00                             | 182.28   |
| 3.4                             | -4.77  | 6.14                             | 186.54   |
| 3.6                             | 19.92  | 0.00                             | 193.47   |
| 3.8                             | 4.23   | 0.00                             | 209.09   |
| 4.0                             | -0.24  | 0.11                             | 193.09   |
| 4.2                             | -6.59  | 8.83                             | 197.00   |
| 4.4                             | 19.34  | 0.00                             | 207.66   |
| 4.6                             | 7.04   | 0.00                             | 211.44   |
| 4.8                             | -2.88  | 1.86                             | 195.77   |
| 5.0                             | -0.26  | 10.50                            | 205.76   |



Table C.6 - Example of Results from Test 9

| Time After Boiling<br>Inception | Flow Rate<br>( $10^{-4}$ ft <sup>3</sup> /sec) | Calculated Bubble<br>Length (In) | Temperature<br>At First TC<br>Downstream of<br>Heater (°F) |
|---------------------------------|--|----------------------------------|--|
| 1.0                             | -0.03  | 0.00                             | 139.20   |
| 0.2                             | -3.62  | 2.82                             | 146.53   |
| 0.4                             | -1.39  | 14.18                            | 199.29   |
| 0.6                             | 28.40  | 0.00                             | 188.62   |
| 0.8                             | -1.46  | 1.34                             | 187.38   |
| 1.0                             | 8.00   | 1.04                             | 174.96   |
| 1.2                             | 7.31   | 0.00                             | 171.91   |
| 1.4                             | -3.34  | 2.74                             | 169.16   |
| 1.6                             | 10.00  | 0.11                             | 192.39   |
| 1.8                             | 25.07  | 0.00                             | 195.08   |
| 2.0                             | -5.90  | 4.19                             | 172.61   |
| 2.2                             | -0.42  | 16.84                            | 193.16   |
| 2.4                             | 24.54  | 0.00                             | 205.38   |
| 2.6                             | -0.37  | 0.22                             | 190.85   |
| 2.8                             | -6.63  | 11.26                            | 188.93   |
| 3.0                             | 11.66  | 0.00                             | 188.54   |
| 3.2                             | 2.23   | 0.00                             | 188.16   |
| 3.4                             | -0.66  | 0.55                             | 186.30   |
| 3.6                             | -0.75  | 4.42                             | 206.14   |
| 3.8                             | 7.18   | 0.00                             | 194.77   |
| 4.0                             | -1.81  | 1.68                             | 188.54   |
| 4.2                             | 4.35   | 1.24                             | 210.00   |
| 4.4                             | 13.43  | 0.00                             | 211.43   |
| 4.6                             | -0.89  | 0.44                             | 186.61   |
| 4.8                             | -7.25  | 13.33                            | 185.45   |
| 5.0                             | 46.76  | 0.00                             | 209.17   |

Table C.7 - Example of Results from Test 10  
(Forced Convection)

| <u>Time After Boiling<br/>Inception</u> | <u>Temperature at First TC<br/>Downstream of Heater (°F)</u> |
|---|--|
| 0.0                                     | 165.39   |
| 0.2                                     | 167.35   |
| 0.4                                     | 169.71   |
| 0.6                                     | 171.67   |
| 0.8                                     | 175.58   |
| 1.0                                     | 179.09   |
| 1.2                                     | 179.79   |
| 1.4                                     | 181.42   |
| 1.6                                     | 186.46   |
| 1.8                                     | 180.65   |
| 2.0                                     | 185.68   |
| 2.2                                     | 180.65   |
| 2.4                                     | 187.54   |
| 2.6                                     | 194.16   |
| 2.8                                     | 194.92   |
| 3.0                                     | 178.62   |
| 3.2                                     | 174.02   |
| 3.4                                     | 185.68   |
| 3.6                                     | 180.18   |
| 3.8                                     | 199.06   |
| 4.0                                     | 184.14   |
| 4.2                                     | 204.08   |
| 4.4                                     | 194.92   |
| 4.6                                     | 210.90   |
| 4.8                                     | 212.79   |
| 5.0                                     | 218.06   |

APPENDIX D  
CALCULATION OF CONDENSATION HEAT  
TRANSFER COEFFICIENTS

D.1 Computational Method

Results from the reduction of the experimental data were used to estimate the magnitude of the condensation heat transfer coefficient during different stages of the bubble growth-collapse cycle. These calculated heat transfer coefficients were then used as a guide to the selection of input parameters to the model.

The only assumption that was made for these calculations was that the upper and lower halves of the bubble were approximately equal in length. An assumption of this sort was necessary due to the unreliable flow rate readings from the upper  $\Delta P$  cell. The assumption of equal lengths was chosen because of the approximately equal inertances of the two halves of the loop (see Chapter 2). Although the lower loop contains all of the bypass and downcomer piping, the fact that most of this piping was approximately six times the diameter of the primary side (and therefore 36 times the area) means that the relative contribution of this piping to the loop inertance was quite small.

Using this assumption, calculations were performed

for each of the stagnant flow experiments during bubble growth and collapse. Examples of these calculations are shown in the remainder of this Appendix. The reasons for the large change in magnitude of the heat transfer coefficient have been fully explored in Chapter 5.

For Test 4

Data Taking Conditions

$$\Delta t = 0.04$$

$$\text{Test Conditions } P = 0.544 \text{ kw} = 1857.2 \text{ BTU/hr}$$

At  $t = 12.32 \text{ sec}$ , Bubble is growing

$$p = 18.63 \text{ psia} \rightarrow T_{\text{sat}} \approx 223^\circ\text{F}, \rho_g \approx 0.045 \text{ lbm/ft}^3, \\ h_{fg} \approx 963 \text{ BTU/lbm}$$

$$T_{\text{liq}} = 192^\circ\text{F} \rightarrow \Delta t = 31^\circ\text{F}$$

$$L_1 = 13.08", Q_1 = 15.23 \times 10^{-4} \text{ ft}^3/\text{sec}$$

Assume

$$L_1 = L_2$$

$$L = 26.16"$$

$$Q_1 = Q_2 \quad \text{Thus} \quad V = 2.29 \times 10^{-4} \text{ ft}^3$$

$$A_1 = A_2 \quad A = 3.98 \times 10^{-2} \text{ ft}^2$$

$$\alpha = 1/C_o$$

$$\text{Since } \frac{V}{\rho} \frac{d\rho}{dt} = \frac{V}{\rho} \frac{dp}{dt} \frac{d\rho}{dp}; \Delta p = -0.21 \text{ psi}, \frac{d\rho}{dp} = 0.002 \text{ lbm/ft}^3/\text{psi}$$

$$Q_s = Q_1 + Q_2 + A_{\text{com}} = 2(15.23 \times 10^{-4}) + \frac{2.29}{0.045} \cdot \left( \frac{-0.21(0.002)}{0.04} \right) = \\ 2.99 \times 10^{-3} \text{ ft}^3/\text{sec}$$

$$\dot{q}_s = \rho_g h_{fg} Q_s = (2.99 \times 10^{-3})(0.045)(963)(3600) = 466.9 \frac{\text{BTU}}{\text{hr}}$$

$$\dot{q}_{\text{evap}} = (L_1/L_{\text{HTR}}) P = \left( \frac{13.08}{36} \right) 1857.2 = 674.8 \frac{\text{BTU}}{\text{hr}}$$

$$\dot{q}_{\text{con}} = \dot{q}_{\text{evap}} - \dot{q}_s = 207.9 \frac{\text{BTU}}{\text{hr}}$$

$$h_{\text{con}} = \dot{q}_{\text{con}} / \Delta T = \frac{207.9}{(3.98 \times 10^{-2}) (31)} = 168.5 \frac{\text{BTU}}{\text{hrft}^2 \text{ } ^\circ\text{F}}$$

At  $t = 14.76$  sec, Bubble is collapsing

$$p = 16.52 \text{ psia} \rightarrow T_{\text{sat}} \approx 220^\circ\text{F}, \rho_g \approx 0.041 \text{ lbm/ft}^3,$$

$$h_{\text{fg}} \approx 965 \frac{\text{BTU}}{\text{lbm}}$$

$$T_{\text{liq}} = 214.5 \text{ } ^\circ\text{F} \rightarrow \Delta T \approx 5.5 \text{ } ^\circ\text{F}$$

$$L_1 = 6.48'' , Q_1 = -0.34 \text{ ft}^3/\text{sec}, \Delta p = -0.04 \text{ psi},$$

$$\frac{d\rho}{dp} = 0.0023 \frac{\text{lbm/ft}^3}{\text{psi}}$$

Same assumptions are made,

$$\text{Thus } V = 1.1 \times 10^{-4} \text{ ft}^3$$

$$A = 1.98 \times 10^{-2} \text{ ft}^3$$

$$Q_s = -0.68 \times 10^{-4} + \left( \frac{1.1 \times 10^{-4}}{0.041} \right) \left( \frac{0.0023}{-0.04} \right) = -7.42 \times 10^{-5} \frac{\text{ft}^3}{\text{sec}}$$

$$\dot{q}_s = (-7.42 \times 10^{-5}) (0.041) (965) (3600) = 10.6 \frac{\text{BTU}}{\text{hr}}$$

$$\dot{q}_{\text{evap}} = \left( \frac{6.48}{36} \right) 1857.2 = 334.3 \frac{\text{BTU}}{\text{hr}}$$

$$\dot{q}_{\text{con}} = \dot{q}_{\text{evap}} - \dot{q}_s = 344.9 \text{ BTU/hr} \rightarrow h_{\text{con}} = 344.9 / [(1.98 \times 10^{-2}) (5.5)]$$

$$= 3167.1 \frac{\text{BTU}}{\text{hrft}^2 \text{ } ^\circ\text{F}}$$

APPENDIX E  
COMPUTER INPUT AND OUTPUT

E.1 Contents of the Appendix

This appendix contains a copy of the FLOSS computer code, a sample input to the code, and a sample of output from the code, as printed out by the computer.

E.2

The FLOSS Code



```

50 C *****PROGRAM FLOSH*****
100 C *****WRITTEN BY ALAN P. TRIVITT*****
150 C *****U.S. NAVAL ENGINEERING DEPARTMENT*****
200 C *****ANNOTATED VERSION, 1973*****
250 C *****ANNOTATION DATED, JANUARY, 1980*****
300 C
350 C
400 C THIS PROGRAM SIMULATES THE GROWTH AND OSCILLATION OF A
450 C VAPOR BUBBLE IN A LIQUID SECTION WHICH SIMULATES A
500 C ROD BUNDLE IN AN U-TUBE. THE THERMAL AND INERTIAL
550 C EFFECTS ON THE BUBBLE ARE BALANCED TO FIND THE POSITION OF
600 C THE INTERFACES AT EACH TIME STEP.
650 C THE CODE CONTAINS THE OPTION OF USING EITHER COBOL*
700 C OR BASIC PROGRAMS. IT ALSO CALCULATES THE TEMPERATURE
750 C PROFILE AS A FUNCTION OF TIME IN THE U-TUBE
800 C HEATED ZONE IN THE BASIC OPTION.
850 C THE CURRENT SET-UP HAS BEEN USED TO SIMULATE TESTS IN
900 C THE MIT WATER TEST LOOP.
950 C *****
1000 C
1050 C EXPLICIT DOUBLE PRECISION (A-N, Q-Z)
1100 C COMMON /P/ R(400), VVAR(400), RHO(400), ENOL(400), VVAR1(400),
1150 C 1012(4 1), VVAR2(400), R11(400), R12(400), R1(400), R(2,400),
1200 C 20(2,400), VVAR3(2,400), VVAR(2), VVAR(2), VVAR(2), VVAR(2), VVAR(400)
1250 C COMMON /Q/ Q(400), VVAR1(400), VVAR2(400), Q(400), Q(400),
1300 C 1001(400), Q(400), Q(400), Q(400), Q(400), Q(400),
1350 C Q(400), Q(400), Q(400), Q(400), Q(400), Q(400), Q(400),
1400 C COMMON /VISC/ VISC(400), VISC(400), R1TM, R1, QZERO, QZERO, Q,
1450 C 101, TIME(2,1), I(2,10), R11(2,10), SCORR(2), ANNO(2,10), XNT,
1500 C 2001(9,10), MCON(400), S1(2), K
1550 C COMMON /T/ T(400), T(400), T(400), QPS, DENS, RHO(2), R1PL,
1600 C 101, VVAR1, VVAR2, VVAR2
1650 C COMMON /SOL/ SOL, CHL, CHL
1700 C COMMON /PROP/ PR, V1(20), T1(20,400), TR15M, TR15M1
1750 C COMMON /ELOT/ XLOT, TIME, XPORT
1800 C COMMON /CONV/IT, IT14, I11M
1850 C COMMON /SOBTH/ SI
1900 C COMMON /RNDP/ RNDP, RNDP
1950 C COMMON /RNDP/ RNDP(1,400), TIME, QPS, I11M
2000 C CHARACTER*9, T1(1)
2050 C
2100 C *****
2150 C IN BT TO THE CODE READ FROM DATA FILE FORC06.DAT
2200 C *****
2250 C
2300 C INPUT THE TITLE OF THE RUN, UP TO 50 CHARACTERS
2350 C READ(5,5200) TITLE
2400 C WRITE(6,6200) TITLE
2450 C 6200 FORMAT(A50)
2500 C
2550 C
2600 C INPUT TIME STEP (SEC), TYPE OF TRANSIENT (GEN), GRAVITATIONAL
2650 C CONSTANT, ATMOSPHERIC PRESSURE (PSIA), PRESSURE AT POINT OF
2700 C THERM EQUATION (PSIA), DRY FLUX CONSTANT FOR EQUIPMENT
2750 C FLUX, TUBE RADIUS (INCHES), NUMBER OF LOOPS IN LEG 1
2800 C FOR PARALLEL RESISTANCE/EFFECTANCE CALCULATION, NO. OF ITERATIONS.
2850 C THE TRANSIENT TIME (INPUT #2) IS APPROPRIATE ONLY AND IS NOT
2900 C USED BY THE CODE. THE FINAL INPUT CONTROLS THE NUMBER OF
2950 C SERIAL ITERATIONS. DUE TO THE VARIABLE TIME STEP FEATURE,
3000 C THE TOTAL TRANSIENT TIME CANNOT BE SPECIFIED A PRIORI.
3050 C READ(5,100) DT, TIME, CC, PATH, RNDP, QZERO, RHO, R1

```

-177-



```

6150 C
6200 C   TUBING NUMBER OF POINTS DESIRED.  NUNIT = 1
6250 C   GIVES FLOW RATE VS TIME;  =2 GIVES 1 AND PRESSURE VS TIME;
6300 C   = 3 GIVES 2 AND TOTAL BUBBLE LENGTH VS TIME;  = 4 GIVES 3 AND
6350 C   INDIVIDUAL BUBBLE LENGTHS VS TIME.
6400 C   P=AD(5,700) NUNIT
6450 C
6500 C
6550 C   INPUT SODIUM FLAG:  NA=0 FOR WATER PROPERTIES, NA=1
6600 C   FOR SODIUM PROPERTIES.
6650 C   P=AD(5,700) NA
6700 C   700 P=AD(1,15)
6750 C
6800 C
6850 C   SET UP OUTPUT PREFIXES.  OUTPUT IS WRITTEN ONTO FILE FOR006.DAT
6900 C   WRITE(6,500) 'N1,NUNIT,OUTCO,FOUR,POSTAT
6950 C   6000 P=AD(5,700) 'N1=',NUNIT=',OUTCO=',FOUR=',POSTAT='
7000 C   1,7(3Y,700) 'PROFIL=',P5(2,7Y,700) 'M=',M',N',POSTAT=',P5(2)
7050 C   WRITE(6,600) 'N1,CELL,CELL
7100 C   5100 P=AD(5,700) 'FCI=',F5(3,5Y,700) 'CLL=',F5(3,5X,700) 'CIN=',F5(3)
7150 C   WRITE(6,1000) '(TIT0(T,1),I=1,NT)
7200 C   1000 P=AD(1,700) 'INITIAL TEMPERATURE PROFILE',7(3Y,700) /
7250 C   1,7(3Y,700) /,7(3Y,700) /
7300 C   WRITE(6,1000) '(T/ET(I),I=1,NT)
7350 C   1000 P=AD(1,700) 'X-CELL RANGE EXT.  DT/NODE',7(3Y,700) /
7400 C   1,7(3Y,700) /,7(3Y,700) /
7450 C   WRITE(6,500)
7500 C   5000 P=AD(1,700) 'TIMES',10Y,700 '01',15Y,700 '02',10Y,700 '012',15X,700 '03',12X,
7550 C   10Y,700 '13',10Y,700 'A1'
7600 C   WRITE(6,500)
7650 C   5100 P=AD(1,700) 'R11',10Y,700 'R12',15X,700 'R1',12X,700 'VVAR1',12X,700 'VVAR2',
7700 C   113X,700 'VVAR',11Y,700 'A2'
7750 C
7800 C
7850 C   SET INITIAL CONDITIONS FOR TRANSIENT AND CONVERT UNITS
7900 C   1000 P=AD(1,700)
7950 C   P=AD(1,700)
8000 C   P=AD(1,700)
8050 C   P=AD(1,700)
8100 C   P=AD(1,700)
8150 C   P=AD(1,700)
8200 C   P=AD(1,700)
8250 C   P=AD(1,700)
8300 C   P=AD(1,700)
8350 C   P=AD(1,700)
8400 C   P=AD(1,700)
8450 C   P=AD(1,700)
8500 C
8550 C   START TRANSIENT CALCULATION
8600 C   D=1000 NA=1,NUNIT
8650 C   IF(NUNIT.FO.1) GO TO 11115
8700 C   IF(NUNIT.FO.1) GO TO 5
8750 C   11115 P(0)=POSTAT
8800 C   T(0)=P(0)
8850 C   DT(0)=0.
8900 C   CALL PROP
8950 C   CALL RESIN
9000 C   CALL HYDR
9050 C   CALL LEAT
9100 C   CALL AREA
9150 C   GO TO 50000
9200 C   5 IF(NUNIT.FO.2) GO TO 55000

```

```

9200 IF(N,RT,2) GO TO 15
9250 55000 P(1)=CSTART
9300 P(2)=DTI
9350 VVA=I=VVA*IN
9400 RII=RLI*G
9450 CALL XROP
9500 GO TO 25
9550 15 XTEMP=C
9600 P(1)=DTI
9650 15 IF(NPRT=1,P0,3) NPRT=0
9700 P(1)=P(N-1)
9750 CALL XROP
9800 25 I=0
9850 CALL XROP
9900 IF(ITD,TO,ITLIN,OF,IT,P0,ITLIN) GO TO 4000
9950 TTIME=TTIME+DT(N)
10000 50000 I=P(N)/100.
10050 C
10100 C
10150 C AT THIS POINT, THE PRESSURE IN PSTA AND PSEA ARE WRITTEN ONTO
10200 C THE CRT SCREEN SO THAT THE USER MAY CHECK ON THE PROGRESS OF
10250 C THE SIMULATION.
10300 IY=*, PP,P(N)
10350 C
10400 C WRITE THE DATA FOR THE TIME STEP ONTO THE OUTPUT FILE.
10450 WRITE(6,2100) TTIME,(P(I,K),I=1,2),Q12(N),Q3(N),QTOT(N),PP,
10500 12001(N)
10550 WRITE(6,2100) RL1(N),RL2(N),RL(N),VVA1(N),VVA2(N),VVA(N),
10600 1A1,12(N)
10650 2000 BY=AT(//IV,F6.3,5(7),E10.3),77,F6.3,57,E10.3)
10700 1100 F=XX(57,F10.3,5(7),E10.3),4X,F10.3)
10750 IF(K=1,1,1) TO THE 10005
10800 IF(ABS(TIME-1.000,IPHS,70.1) GO TO 12001
10850 IF(NPRT=1,P0,2) NPRT=0
10900 IF(NPRT=1,P0,1) NPRT=2
10950 12001 I=XTEMP,P0,1)*FIC=0
11000 10000 XTEMP=
11050 XTEMP=NTIME
11100 GO TO 11000
11150 C
11200 C
11250 C VARIABLE TIME STEP ROUTINE--DIVIDES BY SUCCESSIVE FACTORS OF 2.0
11300 3000 XTEMP=TTIME*1
11350 XTEMP=XTEMP*1000
11400 D(C)=D(C)/(2.**X)
11450 TIME=FLI*G*NTIME GO TO 4100
11500 GO TO 15
11550 4100 XTEMP=
11600 XTEMP=1
11650 3000 F=XX(//100, AND CONVERGENCE AT THIS TIME STEP,5X,77,F6.3)
11700 IF(ABS(1,N),GO,TTOT(N)) GO TO 11111
11750 C
11800 C RESUME OPTION--IF CALCULATION FAILS TO CONVERGE AND THE FIRST
11850 C TOTAL TEMPERATURE IS LESS THAN CALIBRATION.
11900 WRITE(6,11112)
11950 11112 FORMAT(//V,*,*RESTART*)
12000 NPRT=1
12050 12001 IF(ABS(T,1) ITIME=0
12100 TTD(1,N)=(TDD(1,N-1)*VLT(1)+TOT(N-1)*HTRL/(2.*FLOAT(NT)))
12150 1/(VLT(1)+HTRL/(2.*FLOAT(NT)))+(POWER*DT(N)/FLOAT(NT))/(RHOL(N-1)
12200 2*CPL(N-1)*5.14159*RTURP*RTURP*HTRL/FLOAT(NT)))

```

```

12350 IF(TLIQ(1,N).LT.TSAT(1)) TTIME=1
12360 IF(TLIQ(1,N).GT.TSAT(1)) TLIQ(1,N)=TSAT(1)
12370 DO 12000 NT=2,NT
12400 TLIQ(NT,N)=TLIQ(NT,N-1)
12450 12000 CONTINUE
12500 IF(TTIME.NE.1) GO TO 12004
12550 IF(KT.EQ.1) GO TO 50000
12600 GO TO 100
12650 12000 KTIME=1
12700 GO TO 11115
12750 11111 KTIME(5,11113)
12800 11113 FORMAT(/1CY,'EXHAUSTION OCCURS')
12850 31000 KTIME(6,30000)
12900 30000 FORMAT(/5X,'TRANSIENT TEMPERATURE PROFILES')
12950 TTIME=1.
13000 DO 10000 I=1,NLIM
13050 TTIME=TTIME+DTIME
13100 KTIME(5,25000) TTIME, (TLIQ(I,N),I=1,NT)
13150 25000 FORMAT(/1CY,7(3X,F0.3)/,7(3X,F0.3)/,7(3X,F0.3))
13200 CONTINUE
13250 C *****
13300 C
13350 C PLOTTING LOGIC
13400 KCONT=0
13450 7000 KCONT=KCONT+1
13500 IF(KCONT.EQ.KPLT) GO TO 3000
13550 CALL PLOTTEMP
13600 IF(KPLT.EQ.1) GO TO 7000
13650 3000 STOP
13700 END
C
C
C
C
13750 SUBROUTINE HYDR0
13800 IMPLICIT DOUBLE PRECISION (A-H, O-Z)
13850 C 3-D HYDRODYNAMIC MODEL
13900 COMMON P(4,3),VV(1(400),2(400),3(400),4(400)),VV(1(400),
13950 2(400),3(400),4(400)),PL1(400),PL2(400),PI(400),P(2,400),
14000 20(2,400),ATMP(2,400),K1(2),K2(2),K3(2),V1(2),V2(400),
14050 COMMON DT(400),PFA1(400),VCOND(400),CF(400),CPI(400),
14100 10001(400),HFA1(400),T0AT(400),HFA2(400),HFA3(400),C0(400),
14150 20AT2(400),HFA(400),HT0(400),T000(400),PTEMP,PFACF
14200 COMMON VICON(400),VIG0(400),PITY,NI,CZERO,CPTCC,CC,
14250 11,2,P(1(2,10),2(2,10)),PI(2,10),KCON(2),K0(2,10),KVT,
14300 20,2,IP,VCOND(400),CPIDP,N
14350 COMMON DIMP,TMILL(400),CPHALL(400),CPS,DENS,VHCO,HTPL,
14400 1011,VV(1,2),VV(2,2)
14450 COMMON FCI,DT,DTI
14500 COMMON CONV/IF,ITLIM,ITLIM
14550 COMMON W/RESCALE/RESFAC
14600 CONV W/TRANS/DT(400),TTIME,DTI,HTPLIM
14650 IF(CPTEMP.EQ.1) GO TO 11200
14700 IF(CP.TE.1) GO TO 3000
14750 C TEMPERATURE OF VOLUMETRIC FLOW RATES AND VAPOR VOLUMES AND LENGTHS
14800 11200 DO 200 I=1,2
14850 200 DT(I,N)=0.
14900 CONTINUE
14950 VV(1(N))=0.
15000 VV(2(N))=0.
15050 VV(3(N))=0.
15100 PL1(N)=0.

```

```

15300      RT2(N)=0.
15350      Q12(N)=0.
15400      Q3(N)=0.
15450      Q102(N)=0.
15500      30  NO 40
15550  300  IC=0
15600      IT=
15650  400  N(N)=P(N-1)
15700      IT=IT+1
15750      IF(IT.GT.ITLIM) GO TO 55
15800      CALL PROP
15850      TP=J
15900  100  DELP=P(N)-PATM-((P*TL(2,1)+P*TL(2,2)-BL2(N))*RHOL(P))
15950      IC=IC+1
16000      IF(IC.GT.6) GO TO 25
16050      VVAP(N)=VVAP(T)
16100      RL(N)=RLI
16150      T*(IC,GT,1) GO TO 20
16200      T*(IC,GT,2) GO TO 50000
16250      T*(IC,GT,2) GO TO 20
16300  5000  VVAP1(N)=VVAP(T)*VM1
16350      VVAP2(N)=VVAP(T)*VM2
16400      BL1(N)=RLI*VM1
16450      BL2(N)=RLI*VM2
16500      VVAP1I=VVAP1(N)
16550      VVAP2I=VVAP2(N)
16600      RL1I=RL1(N)
16650      RL2I=RL2(N)
16700      APTA1(N)=3.14159*RTUBE*RTUBE/C7FR0
16750      APTA2(N)=APTA1(N)
16800      T*(APTA2,PD,2.) APTA2(N)=0.
16850      GO TO 25
16900  20  VVAP1(N)=VVAP1I
16950      VVAP2(N)=VVAP2I
17000      RL1(N)=RL1I
17050      RL2(N)=RL2I
17100      IT*(RL1(N),GO,2.) GO TO 25
17150      APTA1(N)=VVAP1(N)/RL1(N)
17200  25  IF(APTA2(N),GO,2.) APTA2(N)=3.14159*RTUBE*RTUBE/C7FR0
17250
17300  C
17350  C
17400  C EXPLICIT FIRST ORDER FINITE DIFFERENCE SCHEME FOR CALCULATION OF
17450  C ADIABATIC FLOW RATES IN THE HYDRODYNAMIC MODEL.
17450  DO 100 I=1,2
17500  Q(L,N)=Q(L,N-1)+DT(N)*(DEFP/VTNEP(I,N-1)-P(I,N-1)*Q(I,N-1)**2./
17550  VTI  P(L,N-1))
17600  100  CONTINUE
17650  Q3(N)=VVAP(N)/RHO(N)*(RHO(N)-RHO(N-1))/DT(N)
17700  Q12(N)=0.
17750  C  Q12 IS THE CHANGE IN VAPOR VOLUME PER UNIT TIME
17800  DO 110 I=1,2
17850  Q12(N)=Q12(I)+Q(I,N)
17900  110  CONTINUE
17950  CALL POSTN
18000  C
18050  C QTOT IS THE TOTAL HYDRODYNAMIC MODEL FLOW RATE
18100  QTOT(N)=Q12(N)+Q3(N)
18150  C CALCULATE THE THERMAL MODEL VOLUMETRIC FLOW RATE FOR COMPARISON
18200  CALL TSTAT
18250  C CALCULATE THE ERROR BETWEEN THE TWO MODEL CALCULATIONS
18300  ETST=ABS(QTOT(N))+ABS(QTS(N))

```

```

18350 IF(ETST.LF.1.0E-30) ETST=1.0E-30
18400 ERROR=2.0*(DTT(N)-DGS(N))/ETST
18450 IF(ABS(ERROR).LF.CCL) GO TO 10
18500 C
18550 C IF THE ERROR IS LESS THAN THE ERROR CONVERGENCE LIMIT, CONTINUE
18600 C WITH THE CALCULATION BASED ON THE PRESSURE GUESSED. IF THE
18650 C ERROR IS TOO LARGE, GUESS A NEW PRESSURE BASED ON THE ERROR
18700 C OF THE OLD ONE.
18750 C
18800 C
18850 C CALL PGUESS
18900 P(N)=PG
18950 IF(IP.EQ.IPLIM) P(N)=P(N-1)
19000 IF(IP.EQ.IPLIM) GO TO 55
19050 CALL PROP
19100 GO TO 1000
19150 C CALCULATE NEW VALUES OF THE VAPOR VOLUME AND BUBBLE LENGTH
19200 10 VVAP(N)=VVAP(N-1)+(D1(N)*DT(N))
19250 IF(VVAP(N).LT.0.) VVAP(N)=0.
19300 VVAP1(N)=VVAP1(N-1)+(D1(N)*DT(N))
19350 VVAP2(N)=VVAP2(N-1)+(D2(N)*DT(N))
19400 CALL AREA
19450 IF(AREA1(N).EQ.0.) GO TO 60
19500 RL1(N)=VVAP1(N)/AREA1(N)
19550 GO TO 60
19600 6 RL1(N)=0.
19650 30 IF(ABS(RL2(N).EQ.0.) GO TO 70
19700 RL2(N)=VVAP2(N)/AREA2(N)
19750 GO TO 40
19800 70 RL2(N)=0.
19850 40 RL(N)=RL1(N)+RL2(N)
19900 IF(ABS(RL(N).EQ.0.) RL(N)=0.
19950 IF(VVAP1(N).GT.0.0.AND.VVAP2(N).GT.0.0) GO TO 50
20000 IF(VVAP1(N).LT.0.) GO TO 150
20050 IF(VVAP2(N).LT.0.) GO TO 160
20100 150 VVAP1(N)=0.
20150 RL1(N)=0.
20200 RL2(N)=RL(N)
20250 VVAP2(N)=VVAP(N)
20300 IF(N.EQ.1.0E-48STRM.EQ.1) GO TO 55
20350 GO TO 50
20400 160 VVAP2(N)=0.
20450 RL2(N)=0.
20500 RL1(N)=RL(N)
20550 VVAP1(N)=VVAP(N)
20600 50 IF(N.EQ.1.0E-48STRM.EQ.1) GO TO 55
20650 IF(ABS(RL(N).EQ.0.) GO TO 101
20700 C
20750 C COMPARE THE GENERATED VALUES OF BUBBLE LENGTH AND VAPOR
20800 C VOLUME TO THOSE GUESSED. IF THEY FAIL WITHIN THE BAND BETWEEN
20850 C THE HIGH AND LOW CONVERGENCE LIMITS, INCREMENT THE TIME AND
20900 C PROCEED WITH THE CALCULATION. IF THEY ARE OUTSIDE OF THE BAND,
20950 C GUESS NEW VALUES AND CONTINUE TO ITERATE.
21000 C
21050 IF((RL1(N)/RL1I).GT.CLL.AND.(RL1(N)/RL1I).LT.CLU) GO TO 102
21100 GO TO 111
21150 101 IF(ABS(RL1(N).EQ.RL1I) GO TO 102
21200 GO TO 111
21250 102 IF(ABS(RL2(N).EQ.RL2I) GO TO 103
21300 IF((RL2(N)/RL2I).GT.CLL.AND.(RL2(N)/RL2I).LT.CLU) GO TO 104
21350 GO TO 111

```





```

24450      G) TO 50
24500      10 DP=(P(N)-P(N-1))/779.
24550      C CALCULATE THE AMOUNT OF HEAT THAT GOES INTO THE HEATER WALL
24600      CPWALL(N)=TL1(N)*2.0*3.14159*RTUHF*DFL*DP*SCPS
24650      TWALL(N)=CPWALL(N)
24700      TDP=DP*DFL*PL1(N)/DT
24750      IF(TL1(N).GT.HT2) TP=DP*DFL*(HT2(N-1)*(TWT(N)-TFL(N))
24800      +3.14159*RTUHF*SCPS*(2.0*3.14159*RTUHF*(TL1(N)-HT2)))
24850      P=V*TP
24900      20 IT=IT+1
24950      IF(IT*DP*GE.50) GO TO 20000
25000      IF(TL1(N).EQ.0.) GO TO 20000
25050      TWALL(N)=TWT(N)+TP/(2*HT2*3.14159*2.0*RTUHF*PL1(N))
25100      GO TO 20000
25150      30001 TWT(N)=TWT(N-1)
25200      40001 DCP=(CPWALL(N)+TWALL(N)-(CPWALL(N-1)+TWALL(N-1))/DT(N)
25250      TDP=TP*DFL*SCPS
25300      RAT=TP*DFL*PSAV
25350      IF(RAT.LT.0.99000) GO TO 45
25400      IF(RAT.LT.1.01) GO TO 45
25450      GO TO 30
25500      45 RAT=1.0
25550      TDP=TP*DFL*SCPS
25600      GO TO 30
25650      55 RAT=1.0
25700      TDP=TP*DFL*SCPS
25750      GO TO 30
25800      30 TWT(N)=TWT(N)+DP*DFL*RTUHF*SCPS) GO TO 65
25850      IF(RAT.EQ.0.) RAT=1.
25900      IF(RAT.GT.0.99000) RAT=L1.0.99) GO TO 40
25950      TDP=TP*DFL*SCPS
26000      IF(TWT(N).GT.HT2) TDP=PSAV/ABS(RAT)-DCP
26050      GO TO 20
26100      40 TDP=TP*DFL*SCPS/1.2
26150      GO TO 20
26200      65 TDP=(TDP+TDP*DFL*RTUHF*SCPS)
26250      GO TO 20
26300      30 TWT(N)=TWT(N)+DP*DFL*RTUHF*SCPS
26350      30 HTI=TP*DFL
26400      HGAS=SCPS*(4*PL1(N)/3.14159)
26450      IF(RAT.GT.0.99000) HGAS=RTUHF
26500      HAT(N)=HTI
26550      C CALCULATE THE VOLUMETRIC FLOW RATE IN IPS NUMERICAL
26600      VV1(N)=(HAT(N)+(VVAR1(N)*DFL/DT(N)))/(RHO(N)+HFC(N))
26650      VV2(N)=(HAT(N)+(VVAR2(N)*DFL/DT(N)))/(RHO(N)+HFC(N))
26700      C "BUBBLE"
26750      VV1(N)=VV1(N)
26800      VV2(N)=VV2(N)
26850      TL1(N+1,N)=TFL(N)+VV1(N)*DT
26900      VV1(N)=0.
26950      VV2(N)=3.14159*RTUHF*DFL*SCPS
27000      DT(N)=1+VVAR1(N)-VVAR2(N)
27050      VV1(N)=VVAR1(N)+VV1(N)
27100      VV2(N)=VVAR2(N)+VV2(N)+VVAR2(N)*VVAR2(N)
27150      VVAR1(N)=RT(1+VVAR1(N)/3.14159)
27200      IF(VVAR2(N).LT.0.) VVAR2(N)=0.
27250      IF(VVAR2(N).EQ.0.) VVAR2(N)=3.14159*RTUHF*DFL*SCPS
27300      HTI=HTI+1
27350      C FIND OUT IN WHICH TEMPERATURE NODE THE BUBBLE INTERFACE IS
27400      DO 60 J=2,NFT
27450      XLT(J)=VLT(J-1)+VLT(J-1)

```

```

27500      80 CONTINUE
27550      DO 90 K=1,NT
27600      V*AKK=K
27650      IF(PL2(N).GE.XLTT(K).AND.PL2(N).LT.XLTT(K+1)) GO TO 95
27700      90 CONTINUE
27750      C
27800      C THE UPPER UNHEATED ZONE TRANSIENT TEMPERATURE PROFILE IS CALCULATED
27850      C BY THIS SECTION. THE TEMPERATURE IS BASED ON A VOLUME AVERAGED
27900      C MODAL TEMPERATURE, AND IS CALCULATED DIFFERENTLY DEPENDING ON WHETHER
27950      C THE SURFACE IS INCREASING OR DECREASING IN SIZE, AND WHETHER IT
28000      C MOVES ACROSS A MODAL INTERFACE DURING ONE TIME STEP.
28050      C
28100      95 VTK(N)=V*AKK
28150      IF(VTK(N).GT.VTK(N-1)) GO TO 100
28200      IF(VTK(N).EQ.VTK(N-1).AND.PL2(N).GT.PL2(N-1)) GO TO 110
28250      IF(VTK(N).EQ.VTK(N-1).AND.PL2(N).LE.PL2(N-1)) GO TO 105
28300      DO 120 L=1,NT
28350      IF(L.GT.VTK(N-1)) GO TO 121
28400      IF(L.EQ.VTK(N-1)) GO TO 122
28450      IF(L.LE.VTK(N)) GO TO 123
28500      IF(L.LT.VTK(N)) GO TO 124
28550      121 TLIQ(L,N)=(TLIQ(L,N-1)*(XLT(L)*THURF-DVOL)+(TLIQ(L+1,N-1)
28600      1*DVOL))/(VLT(L)*ATHRF)
28650      GO TO 125
28700      122 TLIQ(L,N)=(TLIQ(L,N-1)*(THURF*(VIT(L)-(PL2(N-1)-VIT(T)))-
28750      1*(VIT(L)-VIT(N))))+(TLIQ(L,N-1)+(HTCO(N-1)*(TSAT(N-1)-TLIQ(L,N-
28800      21))*DT(N)*(3.14159*PCAS*PCAS+2.0*3.14159*PCAS*(PL2(N-1)-XLT(L)))
28850      3*(DIFF*1*(PL2(N-1)-VIT(L))*PHOL(N)*CPL(N)))*DT*1*(PL2(N-1)
28900      4-VIT(L)))+(TLIQ(L+1,N-1)*(3.14159*PCAS*PCAS*(PL2(N-1)-PL2(N)
28950      5)))/(VIT(L)*ATHRF)
29000      GO TO 125
29050      123 TLIQ(L,N)=(TLIQ(L,N-1)+(HTCO(N-1)*(TSAT(N-1)-TLIQ(L,N-1))*DT(N)*2.0
29100      1*3.14159*PCAS*XLT(L)/(DIFF*1*VIT(L)*PHOL(N)*CPL(N)))
29150      2*(THURF*1*(VIT(L)-(VIT(L+1)-PL2(N)))+(TLIQ(L+1,N-1)*THURF*
29200      3*(VIT(L+1)-PL2(N)))/(ATHRF*(VIT(L+1)-PL2(N)))+(DIFF*1*(XLT(L)-
29250      4*(VIT(L+1)-VIT(N))))
29300      GO TO 125
29350      124 TLIQ(L,N)=TLIQ(L,N-1)+(HTCO(N-1)*(TSAT(N-1)-TLIQ(L,N-1))*DT(N)*2.0
29400      1*3.14159*PCAS*VIT(L)/(DIFF*1*VIT(L)*PHOL(N)*CPL(N))
29450
29500      125 V=PLIQ(L,N).*VTK(N) TLIQ(L,N)=TSAT(N)
29550      126 CONTINUE
29600      GO TO 500
29650
29700      105 DO 135 I=1,NT
29750      IF(I.GT.VTK(N-1)) GO TO 131
29800      IF(I.EQ.VTK(N-1)) GO TO 132
29850      IF(I.LE.VTK(N)) GO TO 133
29900      131 TLQ(I,N)=(TLIQ(I,N-1)*(VIT(L)*THURF-DVOL)+(TLIQ(I+1,N-1)*
29950      1*DVOL))/(VLT(I)*ATHRF)
29950      GO TO 134
30000      132 TLIQ(I,N)=(TLIQ(I,N-1)*(VIT(I+1)-PL2(N-1)*ATHRF)+(TLIQ(I+1,N-1)
30050      1*DVOL)+(TLQ(I,N-1)+(HTCO(N-1)*(TSAT(N-1)-TLIQ(I,N-1))*DT(N)*(3.14159
30100      2*PCAS*PCAS+(2.0*3.14159*PCAS*(PL2(N-1)-VIT(I))))/(DIFF*1*
30150      3*(PL2(N-1)-XLT(L))*PHOL(N)*CPL(N)))+(DIFF*1*(PL2(N-1)-VIT(L)))
30200      4*(ATHRF*(VIT(I+1)-PL2(N)))+(DIFF*1*(PL2(N)-VIT(L))))
30250      GO TO 134
30300      133 TLIQ(I,N)=TLIQ(I,N-1)+(HTCO(N-1)*(TSAT(N-1)-TLIQ(I,N-1))*DT(N)*2.0
30350      1*3.14159*PCAS*XLT(I)/(DIFF*1*VIT(I))
30400      134 IF(TLIQ(L,N).GT.TSAT(N)) TLIQ(L,N)=TSAT(N)
30450      135 CONTINUE
30500      GO TO 500

```

```

3 550      101 DO 145 I=1,N
3 550      141 IE(I,GT,VTM('')) GO TO 141
3 550      142 IF(V,GT,VTM('')) GO TO 142
3 550      143 IF(L,LE,N-VM('')) GO TO 143
3 550      144 TITQ(L,N)=(TLIC(L,N-1)*(XIT(L)*ATUHF-DVCL)+TITQ(L-1,N-1)*DVCL)
3 550      145 1/(XLT(L)*VTM(''))
3 550      GO TO 145
3 550      142 TLT(L,N)=(TLIC(L,N-1)*(XIT(L)*ATUHF-DVCL)+TITQ(L-1,N-1)*
3 550      143 1/(XIT(L)-TLIC(L,N-1))*ATUHF+TITQ(L,N-1)*HCC(N-1)*(TSAT(')-1)-
3 550      2TITQ(L,N-1)*DT(N)*(3.14159*PCAS*PCAS+2.0*3.14159*PCAS*
3 550      3 550 3*(DT(N)-TITQ(L,N))/(DIFFA*(PI2(N)-TITQ(L,N)*RHOI('))*CFI(N))
3 550      4*(DIFFA*(PI2(N)-XIT(L,N))/(ATUHF*(XLT(L)-PI2(L,N)-XIT(L,N)))+
3 550      5*(DIFFA*(PI2(L,N)-XLT(L,N)))
3 550      GO TO 145
3 550      144 TITQ(L,N)=TITQ(L,N-1)+ICQ(N-1)*(TSAT(N-1)-TITQ(L,N-1))*DT(N)*
3 550      145 12.0*3.14159*PCAS*PCAS*TITQ(L,N)/(DIFFA*(XIT(L)*RHOI(N))*CFI(N))
3 550      145 IE(TITQ(L,N),GT,TSAT(N)) TITQ(L,N)=TSAT(N)
3 550      146 CONTINUE
3 550      DO 145 I=1,N
3 550      147 IF(I,GT,VTM('')) GO TO 151
3 550      148 IF(V,GT,VTM('')) GO TO 152
3 550      149 T(L,LE,N-VM('')) GO TO 153
3 550      151 TLT(L,N)=(TLIC(L,N-1)*(XIT(L)*ATUHF-DVCL)+TITQ(L-1,N-1)*
3 550      152 DVCL)/(XIT(L)*VTM(''))
3 550      153 TITQ(L,N)=(TITQ(L,N-1)*(XITQ(L+1)-TITQ(N))*ATUHF+(TITQ(L,N-1)
3 550      154 1+HCC(N-1)*(TSAT(N)-TITQ(L,N-1))*DT(N)*(3.14159*(PCAS*PCAS+2.0*
3 550      155 23.14159*PCAS*PCAS*(XITQ(L)-XITQ(N)))/(DIFFA*(PI2(N)-XITQ(L,N)*RHOI(N))
3 550      3*(XIT(L)-TITQ(L,N))/(DIFFA*(PI2(N)-XLT(L,N)-XITQ(L,N)))+
3 550      4*(DIFFA*(PI2(L,N)-XITQ(L,N)-XITQ(N))))
3 550      GO TO 154
3 550      153 TLT(L,N)=TITQ(L,N-1)+HCC(N-1)*(TSAT(N-1)-TITQ(L,N-1))*DT(N)*2.0
3 550      154 12.0*3.14159*PCAS*PCAS*TITQ(L,N)/(DIFFA*(XIT(L)*RHOI(N))*CFI(N))
3 550      154 IF(TLT(L,N),GT,TSAT(N)) TITQ(L,N)=TSAT(N)
3 550      155 CONTINUE
3 550      500 TITQ = .
3 550      501 TITQ = VTM('')
3 550      C 502 IF (V,GT,VTM('')) HEAT OUTPUT FROM THE BUNDLE IS NOW CALCULATED
3 550      503 DO 199 I=1,N
3 550      504 T(I,0.81) GO TO 199
3 550      505 HTIN=HTIN+HTC(N)*(TITQ(L,N)-TSAT(N))*2.0*3.14159*PCAS*XLT(I)
3 550      506 GO TO 200
3 550      199 HTO=HTO+HTC(')*(TLIC(I,N)-TSAT('))*(3.14159*PCAS*PCAS*
3 550      199 12.0*3.14159*PCAS*PCAS*(PI2(N)-TITQ(I)))
3 550      200 CONTINUE
3 550      507 TITQ=HTIN
3 550      C 508 CALCULATE THE VELOCITY FLOW RATE IN LFC NUMBER TWO
3 550      509 VC(')=(HTO+TITQ(')*(VVA2(')*RHOI(TITQ(')))/(RHOI(N)*HFC(N))
3 550      510 IF(VVA2('),IF,0.0) OGS2(N)=HTO2(N)/(RHOI(N)*HFC(N))
3 550      511 IF(VC('),0.1,0.0) HESTI('),0.1) GO TO 70
3 550      C
3 550      C CALCULATE THE TOTAL THERMAL MODEL FLOW RATE FOR COMPARISON
3 550      C TO THE CALCULATED BY THE HYDRODYNAMIC MODEL AND
3 550      C THEN TO SUBROUTINE "HYDRQ."
3 550      C
3 550      70 VC(N)=OGS1(N)+OGS2(N)
3 550      71 RETURN
3 550      END
3 550      C
3 550      C

```



```

36550 2POWER,IP,VNCF2(400),ERESP,N
36700 COMMON DELP,TRAIL(400),DBRILL(400),CFE,DFMS,KHTCO
36800 C
36850 C
36900 C SUBROUTINE HTCOLE CALCULATES THE CONDENSATION HEAT TRANSFER
36950 C COEFFICIENT USING ONE OF THREE OPTIONS. THE FIRST OPTION,
36975 C IDENTIFIED BY THE INPUT VARIABLE KHT=1 (SEE COMMENTS AT BEGINNING
37000 C OF THIS PROGRAM FOR INPUT FORMAT), USES THE NUMBER INPUT AS OUTPUT IN
37050 C THE INITIAL DATA INPUT THROUGHOUT THE TRANSIENT. EXPERIMENTAL EVIDENCE
37100 C INDICATES THAT THIS NUMBER IS IN THE RANGE OF 500-2000 FTU/IN-SD FT-F
37150 C FOR WATER AND 100-10000 BTU/HR-SD FT-F FOR LIGHT OILS.
37200 C THE OPTION KHT=2 USES THE DITUS-201777 CORRELATION TO CALCULATE A
37250 C COEFFICIENT ON THE BASIS OF FORCED CONVECTION TO THE VAPOR
37300 C IN AN ANNULAR FLOW PATTERN. THIS OPTION HAS NOT BEEN PARTICULARLY ACCURATE.
37350 C THE THIRD OPTION, AS NOTED IN THE BODY OF THE PROGRAM, CORRESPONDS
37400 C TO KHT=3, AND IS RESERVED FOR ANY OPTION THAT THE USER MIGHT DESIRE.
37450 C THE MOST DILIGENT MODEL IS PROBABLY A DETAILED CONDUCTION MODEL.
37500 C
37550 C
37600 C IF(KHT.EQ.2) GO TO 5
37650 C   HTO(N)=HTCO
37700 C   GO TO 10
37750 C 5 IF(KHT.EQ.3) GO TO 10
37800 C   F=ABS(3(2,4)/REF(E)*2.C*BTU*PHOG(N)/VISC(N)*360.)
37850 C   HTO(N)=VISC(N)*CL(E)/TCO(N)
37900 C   HTO(N)=0.023*(PEG**0.8)*(PRG**0.4)
37950 C   GO TO 10
38000 C KHT=3--USER SPECIFIED OPTION FOR HTCO, I.E. CONDUCTION MODEL
38050 C 10 CONTINUE
38100 C   HTO(N)=HTCO(N)/3600.
38150 C 50 RETURN
38200 C
38250 C
38300 C
38350 C
38400 C
38450 C SUPPLEMENTAL EQUATIONS
38500 C IMPLICIT DOUBLE PRECISION (A-H, O-Z)
38550 C COMMON P(400),VVAP(400),R1OR(400),F40L(400),VVAP1(400),
38600 C 1012(400),VVAP2(400),R11(400),R1(400),R1(400),P(2,400),
38650 C 2(2,400),VINE(2,400),VA1(2),VK1(2),XK1(2),VW(2),C3(400)
38700 C COMMON QTM(400),ATA1(400),MCI1(400),CFE(400),CFE(400),
38750 C 1001(400),HEAT(400),TSAT(400),RFA2(400),DPS2(400),DPS(400),
38800 C 2HEAT2(400),R11(400),HFO2(400),TCO2(400),RTHRE,FFACT
38850 C COMMON VISC(400),VISC2(400),PMT,PI,CZPRO,CHTCO,CC
38900 C 1EG,TDI(2,10),EI(2,10),PII(2,10),MOME(2),ANFR(2,10),KHT,
38950 C 2ESL-E,IP,VNCF2(400),ERESP,N
39000 C COMMON DELP,TRAIL(400),DBRILL(400),CFE,DFMS,KHTCO
39050 C COMMON/TRANS/DT(400),TIME,PII,ATLI
39100 C
39150 C
39200 C THIS ROUTINE GENERATES GUESSES FOR THE PRESSURE USED IN SUBROUTINE
39250 C HYDRO FOR ORIENTATION OF THE FLOW RATE. THE PROCEDURE USED IS
39300 C EXPLAINED FULLY IN THE MANUAL. BRIEFLY, A NEWTON'S METHOD
39350 C OF SUCCESSIVE LINEAR APPROXIMATIONS BASED ON THE ERROR BETWEEN THE
39400 C HYDRODYNAMIC AND THERMAL MODEL FLOW RATES IS USED
39450 C TO GENERATE THE GUESSES.
39500 C
39550 C IF(IP.EQ.1) GO TO 10
39600 C   FFAPOS=0.
39650 C   EPNVEG=0.

```

```

33510 C
33520 SUBROUTINE APT2
33530 IMPLICIT DOUBLE PRECISION (A-H, O-Z)
33540 COMMON I(400),VVVF(400),RHOT(400),RHOI(400),VVVF1(400),
33550 1012(400),VVVF2(400),HT1(400),HT2(400),IT(400),F(2,400),
33560 20(2,400),XTM(2,400),YK1(2),YK2(2),YK3(2),YK4(2),O3(400)
33570 COMMON DT(400),TETA1(400),VMCP1(400),CPG(400),CF1(400),
33580 10051(400),F1(2,10),PII(2,10),NCOMP(2),NCR(2,10),COS(400),
33590 2HEAT2(400),HTC(400),HTC2(400),TCOND(400),RTHEP,EFECT
33600 COMMON VISCF(400),VISCC(400),DIMP,N1,CZFR0,CNTR0,CC,
33610 1FC,PTDI(2,10),I(2,10),E1(2,10),NCOMP(2),NCR(2,10),KUT,
33620 2XOFR,IF,VMCP2(400),EPIC0,N
33630 C=3.141592653589793,CONVIL(400),CPS,DEFC,NUTCO
33640 COMMON/480T/RTHEP,EFECT
33650 COMMON/TRANS/DT(400),TIME,DTI,NTIM
33660
33670 C
33680 C
33690 C
33700 C
33710 C
33720 C
33730 C
33740 C
33750 C
33760 C
33770 C
33780 C
33790 C
33800 C
33810 C
33820 C
33830 C
33840 C
33850 C
33860 C
33870 C
33880 C
33890 C
33900 C
33910 C
33920 C
33930 C
33940 C
33950 C
33960 C
33970 C
33980 C
33990 C
34000 C
34010 C
34020 C
34030 C
34040 C
34050 C
34060 C
34070 C
34080 C
34090 C
34100 C
34110 C
34120 C
34130 C
34140 C
34150 C
34160 C
34170 C
34180 C
34190 C
34200 C
34210 C
34220 C
34230 C
34240 C
34250 C
34260 C
34270 C
34280 C
34290 C
34300 C
34310 C
34320 C
34330 C
34340 C
34350 C
34360 C
34370 C
34380 C
34390 C
34400 C
34410 C
34420 C
34430 C
34440 C
34450 C
34460 C
34470 C
34480 C
34490 C
34500 C
34510 C
34520 C
34530 C
34540 C
34550 C
34560 C
34570 C
34580 C
34590 C
34600 C
34610 C
34620 C
34630 C
34640 C
34650 C
34660 C
34670 C
34680 C
34690 C
34700 C
34710 C
34720 C
34730 C
34740 C
34750 C
34760 C
34770 C
34780 C
34790 C
34800 C
34810 C
34820 C
34830 C
34840 C
34850 C
34860 C
34870 C
34880 C
34890 C
34900 C
34910 C
34920 C
34930 C
34940 C
34950 C
34960 C
34970 C
34980 C
34990 C
35000 C
35010 C
35020 C
35030 C
35040 C
35050 C
35060 C
35070 C
35080 C
35090 C
35100 C
35110 C
35120 C
35130 C
35140 C
35150 C
35160 C
35170 C
35180 C
35190 C
35200 C
35210 C
35220 C
35230 C
35240 C
35250 C
35260 C
35270 C
35280 C
35290 C
35300 C
35310 C
35320 C
35330 C
35340 C
35350 C
35360 C
35370 C
35380 C
35390 C
35400 C
35410 C
35420 C
35430 C
35440 C
35450 C
35460 C
35470 C
35480 C
35490 C
35500 C
35510 C
35520 C
35530 C
35540 C
35550 C
35560 C
35570 C
35580 C
35590 C
35600 C
35610 C
35620 C
35630 C
35640 C
35650 C
35660 C
35670 C
35680 C
35690 C
35700 C
35710 C
35720 C
35730 C
35740 C
35750 C
35760 C
35770 C
35780 C
35790 C
35800 C
35810 C
35820 C
35830 C
35840 C
35850 C
35860 C
35870 C
35880 C
35890 C
35900 C
35910 C
35920 C
35930 C
35940 C
35950 C
35960 C
35970 C
35980 C
35990 C
36000 C
36010 C
36020 C
36030 C
36040 C
36050 C
36060 C
36070 C
36080 C
36090 C
36100 C
36110 C
36120 C
36130 C
36140 C
36150 C
36160 C
36170 C
36180 C
36190 C
36200 C
36210 C
36220 C
36230 C
36240 C
36250 C
36260 C
36270 C
36280 C
36290 C
36300 C
36310 C
36320 C
36330 C
36340 C
36350 C
36360 C
36370 C
36380 C
36390 C
36400 C
36410 C
36420 C
36430 C
36440 C
36450 C
36460 C
36470 C
36480 C
36490 C
36500 C
36510 C
36520 C
36530 C
36540 C
36550 C
36560 C
36570 C
36580 C
36590 C
36600 C

```

```

42750 C
4280 C
4285 C THIS ROUTINE CALCULATES RESISTANCES AND IMPEDANCES FOR INPUT TO SUBROUTINE
4290 C HYDRO. THE INPUT IS EXPLAINED IN THE COMMENTS PERTAINING TO THE
4295 C MAIN PROGRAM. TO REVISE, THE LENGTH AND DIAMETER OF EACH COMPONENT
4300 C IN THE SYSTEM ARE INPUT. IN ADDITION, ANY FLOWS OCCURRING
4305 C IN A COMPONENT ARE REPRESENTED BY THE TERM FI, IN EQUIVALENT
4310 C L/IN, AND ANY ADDITIONAL RESISTANCE IN A COMPONENT (PISTON
4315 C DEFICITS, STAINED PUMP, ETC.) IS REPRESENTED BY THE TERM ADDR.
4320 C ALSO IN EQUIVALENT L/D'S. THE COMPONENT NUMBERING SYSTEM
4325 C MUST BE FOLLOWED AS EXPLAINED IN THE THESIS IN ORDER FOR THE
4330 C CALCULATION OF EQUIVALENT LOOP RESISTANCES AND IMPEDANCES TO BE DONE
4335 C BY THE CODE. ANY DEVIATION FROM THIS SCHEME WILL CAUSE ERRONEOUS RESULTS.
4340 C
4345 C
4350 C DIMENSION XT(2,10),VR(2,10),PRASE(2),PPAP(2),BASFI(2),PART(2)
4355 C DO 100 I=1,2
4360 C JI= LCOMP(I)
4365 C DO 1000 K=1,JI
4370 C CALL FACTR(X,K)
4375 C C= 33.5*PI*(COP C(I))/ (C*(PIDI(I,K)**4.0)+(3.14159**2.0))
4380 C COMT=4.*HOL(N)/(3.14159*PIDI(I,K)*PIDI(I,K)*G)
4385 C I=(V.37.1) C TO 5
4390 C IF(.10.1.0R,HESTET.F(0.1) CO TO 5
4395 C I=(I.0.2) C TO 1-
4400 C XI(I,K)=(COT(I,K)-L1(N))/PIHT(I,K)+FI(I,K)+ADDR(I,K)*COMR
4405 C XIN(I,K)=( IL(I,K)-BL1(N))*COMT
4410 C DO TO 1000
4415 C 15 AP(I,K)=((PIL(I,K)-CL2(N))/PIDI(I,K)+FI(I,K)+ADDR(I,K))*COMR
4420 C XT(I,K)=(IL(I,K)-BL2(N))*COMT
4425 C DO TO 1000
4430 C 5 Y(I,K)=(CIL(I,K)/PIDI(I,K)+FI(I,K)+ADDR(I,K))*COMR
4435 C YI(I,K)=PIL(I,K)*COMI
4440 C 1000 CO TO 1000
4445 C DO 20 C I=1,NL
4450 C IF(T.(I.1) C) TO 30
4455 C M=2*(N1-1)+5
4460 C N1=N+1
4465 C P1=CF(1)=P(1,1)+VR(1,2)+VR(1,3)+XR(1,N)+XR(1,N)
4470 C BASFI(1)=YI(I,1)+XINT(1,2)+XINT(1,3)+YINT(1,N)+XINT(1,N)
4475 C P1=CF(1)=XU(1,4)
4480 C PART(1)=YIN(I,4)
4485 C 30 I=(T.F(0.1) CO TO 2000
4490 C JJ=I-1
4495 C KK=(3*JJ)+2
4500 C LL=KK+2
4505 C YIN(I,1J)=0.
4510 C YI(I,1J)=0.
4515 C PL(I, N)=YI(I,1J)
4520 C YI(I,1J)=YI(I,1J)+YI(I,N)
4525 C YI(I,1J)=YI(I,1J)+YI(I,N)
4530 C 100 CO TO 1000
4535 C 2000 CO TO 1000
4540 C JA=IL-1
4545 C I=(JA.F(0.1) CO TO 40
4550 C DO 200 I=1,JA
4555 C PFI(I)=((PFI(I)*XU(1,I))/(PPAP(1)+YI(I,I))
4560 C PFI(I)=((PFI(I)*YI(I,I))/(PART(1)+XINT(1,I))
4565 C 3000 CO TO 1000
4570 C 40 F(1,N)=RBASFI(1)+PFI(I)
4575 C XIN(I,N)=PFI(I)+PFI(I)

```





```

4850  COMMON N(400),VVAP(400),RHO(400),RHOI(400),VVAP1(400),
4860  1*12(400),VVAP2(400),RT1(400),RT2(400),SI(400),P(2,400),
4870  20(2,400),VT,TP(2,400),YF1(2),YF2(2),YF3(2),YK4(2),G3(400)
4880  COMMON JT(400),HFI(400),YHCP1(400),CP(400),CPI(400),
4890  10GT1(400),HFI1(400),TSAT(400),ARF12(400),QSF2(400),QCF(400),
4900  2HPT2(400),HPT(400),HTC(400),TCORG(400),PTURF,PFAC
4910  COMMON VISC(400),VTIC(400),PETH,VEL,CFER,THIC,CC,
4920  1PG,LDI(2,10),FI(2,10),PII(2,10),ICORP(2),ADDR(2,10),KUT,
4930  2FWR,IF,YNCP2(400),FRFR,4
4940  COMMON DELT,TRALL(400),CPWALL(400),CPS,DEFS,WHIC
4950  COMMON/CONTIN/NA

```

```

C
C
C THIS ROUTINE CALCULATES THE PROPERTIES OF WATER (NA=0)
C OR LIQUID SODIUM (NA=1). THE CORRELATIONS ARE TAKEN FROM
C IFTW (BACHFLORES THESIS) FOR WATER, AND FROM ILL-7323 FOR
C LIQUID SODIUM. THE PROPERTIES CALCULATED ARE
C WATER: TSAT, HFG, VISCOSITY (LIQUID), SPECIFIC HEAT (LIQUID)
C DENSITY (BOTH PHASES), SODIUM: TSAT, DENSITY (BOTH PHASES),
C HFG, LIQUID SPECIFIC HEAT, VISCOSITY (BOTH PHASES).

```

```

C
4950  IF (A.F0.1) GO TO 170
4960  CPG(1)=0.5
4970  VISC(1)=0.7
4980  TCOR(1)=0.05
4990  PP=1/144.
5000  U=0.17(PP)
5010  T=1-7.0
5020  IF (V.PT.205.) GO TO 5
5030  HLTG=((((((-0.4771D-04*H+0.9461FD-03)*H-0.5339D-02)*H
5040  1+0.123737D-01)*H+0.908517D-02)*H-0.4628D12D-01)*H
5050  2+0.1131229D-01)*H+0.2276511D-01)*H+0.22225+55001)*H
5060  3+0.333204227D-01)*H+0.69795537D-02
5070  GO TO 15
5080  HLTG=((((((-0.58728711D-04*A+0.11400811D-01)*A+0.7415344D-01)
5090  1*A+0.1187109D-02)*A+0.13891594D-02)*A+0.37492429D-02)*A
5100  2+(0.1617815D-03)*A+0.5715337D-03
5110  X=1.001*H
5120  Y1=1.03.
5130  C1=0.854+1.65*1-7.0*X*Y+10.6*(Y3-7.0*X*Y)3
5140  CFL(1)=1./CP
5150  VISC(1)=0.509+118.1/HLTG
5160  IF (HIT-90.) 1,2,2
5170  1 VISC(1)=0.509+118.1/(HIT+0.25*(90.-HIT))
5180  2 TP(OP.JT.450.) GO TO 15
5190  HVT=((((((-0.3674D-04*H-0.5862D-03)*H+0.43597578D-02)*H
5200  1-0.1471504D-01)*H+0.22775919D-01)*H+0.85450917D-01)*H
5210  2+0.14229318D-01)*H+0.11059525D-04
5220  GO TO 20
5230  15 HVT=((((((-0.37170415D-04*H-0.9111D-03D-01)*A-0.20447P1D-02)*A
5240  1-0.27217175D-02)*A-0.44206896D-02)*A-0.46351642D-02)*A
5250  2+0.1127602D-04
5260  HVT(1)=HVT-HLTG
5270  IF (P.PT.450.) GO TO 25
5280  VL=((((((-0.4651D-02*H-0.747D-07)*H+0.39596D-06)*H
5290  1-0.36945D-06)*H-0.274044D-05)*H+0.6746279D-05)*H
5300  2+0.3313273D-04)*H+0.10394514D-03)*H+0.16140034D-01
5310  GO TO 30
5320  25 VL=((((((-0.26391D-03*A+0.142578D-02)*A+0.21252D-02)*
5330  1A+0.119227D-02)*A+0.197421D-02)*A+0.40469FD-02)*A

```

```

519.0 2+C.219632PCD-C1
510.0 30 RWJ(V)=1.0/V1
520.0 IF(PP.GT.450.) GO TO 35
525.0 PVG=((((( (-0.196D-05*U-0.1200D-03)*U+0.6727D-03)
521.0 1**-.1307139D-2)*U-0.631125D-02)*U+0.5000167D-01)
521.0 2**+.11030915D-1)*U+0.10257401D-2)*U+0.93167056D-03
522.0 GO TO 40
522.0 35 PVG=((((( (-0.47458752D-01*A-0.65913524D-01)*A-0.72430605D-02)*A
523.0 1-0.27267054D-02)*A-0.53077282D-02)*A-0.61514671D-02)*A
523.0 2+0.49907454D-03
524.0 40 RWJ(V)=P/PVG
524.0 TP(1,3T,450.) TO TO 45
525.0 TSAT(V)=(((( (-0.196D-05*U+0.1405D-04)*U-3.265D-5)*U
525.0 1+2.3927D-3)*U+0.434614D-02)*U+0.17363004D-01)*U
525.0 2+0.22008149D-01)*U+0.33445776D-02)*U+0.10142472D-3
526.0 GO TO 50
527.0 45 TSAT(V)=(((( (-0.16074225D-00*A-0.69678576D-01)*A
527.0 1+0.61771105D-01)*A+0.1457723D-02)*A+0.12475475D-03)*A
527.0 2+0.55599496D-03
528.0 100 CONTINUE
529.0 C SATURATION PROPERTIES OF LIQUID AND GASEOUS SODIUM
529.0 PVP=P(V)/2114.724
530.0 IF(PPA.GT.0.1) GO TO 105
530.0 TSAT(V)=((14.65*DLOG10(PPA)-9515.4464)/(DLOG10(PPA)-4.57791
531.0 1))-450.7
531.0 GO TO 110
532.0 105 TSAT(V)=((83.16*DLOG10(PPA)-9091.1061)/(DLOG10(PPA)-4.7383
532.0 1))-450.7
533.0 110 PWL(V)=59.566-(7.0500D-3*TSAT(V))-(0.2872D-6*(TSAT(V)**2.))
533.0 1)+(0.5735D-3*(TSAT(V)**3.))
534.0 TARS=TSAT(V)+459.7
534.0 TAV=PV(-7.05045+(16598.3/TARS))
535.0 PVP=P(-74.5091+(37689.7/TARS))
535.0 U=13*TD0
536.0 M=(1.01**3.)*FOUR
536.0 Y1=0
537.0 115 X1P=1
537.0 Y1=1-(K*(X1**4)+(U*(Y1**2.))+Y1-1.)/(4.0*(X1**3.))+
538.0 1(2.0**Y1)+1.)
538.0 IF((145(Y1-Y1P)/Y1)-1.D-6) 120,120,115
539.0 120 Y2=U*(Y1**2.)
539.0 X4=1.-X1-Y2
540.0 AFB=22.91*(Y1+(2.*Y2)+(4.*X4))
540.0 VFB=(0.73022**TARS)/(ABAR*PPA)
541.0 PVP(V)=1./VFB
541.0 D1=20599.7-(7.21312*TARS)+(7.76274D-4*(TARS**2.))-1.4526
542.0 1D-7*(TARS**3.))
542.0 PVP2=(2.0*DH1)-1830.
543.0 D1F4=(4.0*DH1)-4147.
543.0 HPG(V)=1.5*((Y1*DH1)+(Y2*DH2)+(X4*DH4))/ABAR
544.0 CPI(V)=0.340352-(1.10509D-4*TARS)+(3.41173D-8*(TARS**2.))
544.0 TCV(V)=0.030
545.0 CP(V)=0.59
545.0 VISC(V)=0.07427*(0.176D-6*TSAT(V))
545.0 VISC=1.0273+(377.17/TARS)-(0.4925*DLOG10(TARS))
546.0 VISC(V)=10.**VISC
547.0 50 PTV=
547.0 FVD
548.0 C
549.0 C
549.0 C

```

```

54950 SUBROUTINE PLOTTER
55000 IMPLICIT DOUBLE PRECISION (A-H, O-Z)
55050 COMMON P(400),VVAP(400),PHOG(400),RHOL(400),VVAP1(400),
55100 1012(400),VVAP2(400),R11(400),R12(400),R1(400),R2(400),
55150 2012(400),XY1(2,400),XY2(2,400),XY3(2,400),XY4(2,400),
55200 COMMON ORTH(400),FFA1(400),XCP1(400),CPC(400),CPL(400),
55250 10GS1(400),FA1(400),TGT(400),HFR2(400),GGS2(400),GCF(400),
55300 2HGT2(400),HGS(400),HTC2(400),TCYC(400),CTPR,PERCT
55350 COMMON VISC(400),VISC2(400),PATM,VL,CFPR,CHTC,CC,
55400 1PG,1DI(2,10),1I(2,10),P1(2,10),VAMP(2),VDB(2,10),KUT,
55450 2POWER,IP,VAC2(400),FRFR,H
55500 COMMON/PLT/XPIT,TIME,KPCNT
55550 COMMON/TRANS/DT(400),TIME,DTI,DTIT
55600 C
55650 C
55700 C THIS ROUTINE USES THE LIBRARY SUBROUTINE PLOTP ON THE MIT
55750 C JOINT COMPUTER FACILITY VAX COMPUTER TO GENERATE
55800 C TRACES OF SELECTED CURVES. THE ROUTINE PLOTP IS ACCESSED
55850 C THROUGH A CALL STATEMENT THAT USES ARRAYS SET UP BY THE USER
55900 C AND CREATES THE PLOTS.
55950 C
56000 REAL*8 CURV(0,400)
56050 INTER=2 /IP(40)
56100 VPR=DTIT
56150 RTIME=0.
56200 C CREATE THE CURVES USING RESULTS FROM TRANSIENT CALCULATION
56250 DO 100 I=1,4
56300 DT=100 *I,400
56350 IF(I.EQ.2) GO TO 10
56400 CURV(I,0)=-2(I,0)*10000.
56450 GO TO 100
56500 10 IF(I.EQ.3) GO TO 20
56550 CURV(I,0)=I(I,0)*10000.
56600 GO TO 100
56650 20 IF(I.EQ.4) GO TO 30
56700 CURV(I,0)=I(I,0)/144.
56750 GO TO 100
56800 30 IF(I.EQ.5) GO TO 40
56850 CURV(I,0)=I(I,0)+12.
56900 GO TO 100
56950 40 IF(I.EQ.6) GO TO 50
57000 CURV(I,0)=0.
57050 GO TO 100
57100 50 IF(I.EQ.7) GO TO 60
57150 CURV(I,0)=-I(I,0)*12.
57200 GO TO 100
57250 60 IF(I.EQ.8) GO TO 70
57300 CURV(I,0)=I(I,0)*12.
57350 GO TO 100
57400 70 IF(I.EQ.9) GO TO 80
57450 CURV(I,0)=0.
57500 GO TO 100
57550 80 CURV(I,0)=CURV(I,0-1)+DT(V)
57600 100 CONTINUE
57650 IF(KPCNT.EQ.2) GO TO 1000
57700 IF(KPCNT.EQ.3) GO TO 2000
57750 IF(KPCNT.EQ.4) GO TO 3000
57800 C
57850 C
57900 C INPUT THE TITLES OF THE PLOTS. THESE ARE THE LAST
57950 C FOUR DATA LINES. THE TITLE FOR THE Y-AXIS OF THE PLOT

```

```

54000 C      GOSS IN THE FIRST FORTY COLUMNS OF THE LINE AND THE
54050 C      X-AXIS LABEL GOSS IN THE SECOND FORTY COLUMNS. THE LINE'S
54100 C      SHOULD BE CENTERED IN THE FORTY COLUMNS TO GET THEM ON THE
54150 C      PLOTS PROPERLY.
54200 C
54250 C
54300 C      READ(5,200) (YLAB(I),I=1,40)
54350 C      200 FORMAT(40A2)
54400 C
54450 C      CALL THE PLOTTING ROUTINE. DETAILED INFORMATION OF THE
54500 C      ORIGINAL ARGUMENTS IN THE CALL STATEMENTS IS AVAILABLE
54550 C      FROM MIT-JCF.
54600 C
54650 C      CALL PICTR(CURVE,8,XLAB,YSCL,-10,NPTS,8,0,4,1,FTIME,1)
54700 C      GO TO 500
54750 C      1000 READ(5,200) (YLAB(I),I=1,40)
54800 C      CALL PICTR(CURVE,8,YLAB,YSCL,-4,NPTS,8,0,4,1,FTIME,1)
54850 C      GO TO 500
54900 C      2000 READ(5,200) (YLAB(I),I=1,40)
54950 C      CALL PICTR(CURVE,8,YLAB,YSCL,-8,NPTS,8,0,4,1,FTIME,1)
55000 C      GO TO 500
55050 C      3000 READ(5,200) (YLAB(I),I=1,40)
55100 C      CALL PICTR(CURVE,8,XLAB,YSCL,-112,NPTS,8,0,4,1,FTIME,1)
55150 C      500 RETURN
55200 C      END

```

E.3

Sample Input to FLOSS

|      | SIMULATION OF TEST 9 CONDITIONS: LARGE HY COEF. |         |        |          |           |             |              |
|------|---|---------|--------|----------|-----------|-------------|--------------|
| 100  |   |         |        |          |           |             |              |
| 200  | 0.050   | 11.000  | 32.200 | 14.70000 | 17.20000  | 1.20000     | .07600 1 300 |
| 300  | 175.00000600                                    | 0.00000 | .390   | 0.04900  | 488.00000 | 0.110002000 | 0.00000 1 4  |
| 400  | 5   | 2       | 3.0    |          |           |             |              |
| 500  | .013  | 0.0     | 4.00   | 0.0      |           |             |              |
| 600  | .6667   | 0.0     | .6667  | 0.0      |           |             |              |
| 700  | .083  | 0.0     | 1.0    | 0.0      |           |             |              |
| 800  | .083  | 180.0   | 10.0   | 250.0    |           |             |              |
| 900  | .083  | 0.0     | 1.0    | 0.0      |           |             |              |
| 1000 | .013  | 0.0     | 4.0    | 0.0      |           |             |              |
| 1100 | .6667   | 0.0     | .6667  | 0.0      |           |             |              |
| 1200 | .355  | .000004 | .005   | .005     |           |             |              |
| 1300 | .25   | .95     | 1.35   | 75       | 75        |             |              |
| 1400 | 9   |         |        |          |           |             |              |
| 1500 | .100  | 225.0   |        |          |           |             |              |
| 1600 | .48   | 140.0   |        |          |           |             |              |
| 1700 | .48   | 140.0   |        |          |           |             |              |
| 1800 | .48   | 140.0   |        |          |           |             |              |
| 1900 | .48   | 140.0   |        |          |           |             |              |
| 2000 | .48   | 140.0   |        |          |           |             |              |
| 2100 | .48   | 140.0   |        |          |           |             |              |
| 2200 | .48   | 140.0   |        |          |           |             |              |
| 2300 | .64   | 140.0   |        |          |           |             |              |
| 2400 | 60.0  | 75.0    |        |          |           |             |              |
| 2500 | 4   |         |        |          |           |             |              |
| 2600 | 0   |         |        |          |           |             |              |
| 2700 |   |         |        |          |           |             |              |
| 2800 |   |         |        |          |           |             |              |
| 2900 |   |         |        |          |           |             |              |
| 3000 |   |         |        |          |           |             |              |

|  | TIME (SEC) | VOL. FLOW RATE (FT**3/SEC X 10**4) |
|--|------------|------------------------------------|
|  | TIME (SEC) | PRESSURE (PSIA)                    |
|  | TIME (SEC) | BUBBLE LENGTH (INCHES)             |
|  | TIME (SEC) | BUBBLE LENGTH (INCHES)             |

E.4

FLOSS Output

SIMULATION OF TEST ° CONDITIONS: LARGE HT COEF.  
 DT=0.050 KMT=1 CRYCO=6000.0 POWER= 0.39 KW PSTART=17.20  
 ECL=0.050 CLL=0.950 CLH=1.050

INITIAL TEMPERATURE PROFILE 225.000 140.000 140.000 140.000 140.000 140.000 140.000  
 140.000 140.000

MODAL ARRANGEMENT, FT/NODE 0.100 0.480 0.480 0.480 0.480 0.480 0.480 0.480  
 0.480 0.640

| TIME  | Q1         | Q2         | Q3         | Q4         | Q5         | Q6        | Q7        | Q8        | Q9        | Q10       | Q11       | Q12       |           |
|-------|------------|------------|------------|------------|------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| BL1   | BL2        | BL3        | BL4        | BL5        | BL6        | BL7       | BL8       | BL9       | BL10      | BL11      | BL12      | BL13      |           |
| 0.000 | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |           |
| 0.050 | 0.151E-05  | 0.163E-05  | 0.314E-05  | -0.103E-06 | 0.304E-05  | 16.646    | 0.105E-03 | 0.721E-03 | 0.774E-03 | 0.150E-02 | 0.757E-07 | 0.813E-07 | 0.177E-06 |
| 0.100 | 0.599E-05  | 0.643E-05  | 0.124E-04  | 0.199E-07  | 0.124E-04  | 16.669    | 0.105E-03 | 0.357E-02 | 0.384E-02 | 0.741E-02 | 0.375E-06 | 0.403E-06 | 0.778E-06 |
| 0.150 | 0.179E-04  | 0.192E-04  | 0.370E-04  | 0.166E-06  | 0.372E-04  | 16.728    | 0.105E-03 | 0.121E-01 | 0.133E-01 | 0.250E-01 | 0.127E-05 | 0.136E-05 | 0.243E-05 |
| 0.200 | 0.384E-04  | 0.412E-04  | 0.796E-04  | 0.469E-06  | 0.800E-04  | 16.794    | 0.105E-03 | 0.303E-01 | 0.326E-01 | 0.629E-01 | 0.319E-05 | 0.342E-05 | 0.661E-05 |
| 0.250 | 0.705E-04  | 0.756E-04  | 0.146E-03  | 0.126E-05  | 0.147E-03  | 16.879    | 0.105E-03 | 0.634E-01 | 0.586E-01 | 0.132E+00 | 0.671E-05 | 0.720E-05 | 0.139E-04 |
| 0.275 | -0.208E-03 | -0.224E-03 | -0.433E-03 | -0.465E-04 | -0.479E-03 | 12.094    | 0.105E-03 | 0.143E-01 | 0.151E-01 | 0.295E-01 | 0.151E-05 | 0.159E-05 | 0.310E-05 |
| 0.281 | -0.189E-03 | -0.204E-03 | -0.393E-03 | 0.311E-04  | -0.362E-03 | 17.707    | 0.105E-03 | 0.308E-02 | 0.300E-02 | 0.608E-02 | 0.324E-06 | 0.315E-06 | 0.639E-06 |

NO CONVERGENCE AT THIS TIME STEP T= 0.281

RESTART

|       |           |            |           |           |           |        |           |           |           |           |           |           |           |
|-------|-----------|------------|-----------|-----------|-----------|--------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 0.261 | 0.239E-06 | -0.239E-06 | 0.176E-19 | 0.424E-35 | 0.136E-19 | 17.707 | 0.000E+00 | 0.181E-34 | 0.191E-34 | 0.380E-34 | 0.000E+00 | 0.000E+00 | 0.399E-38 |
| 0.331 | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| 0.381 | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200 | 0.000E+00 |           |           |           |           |           |           |



|                    |                         |                         |                         |                         |                         |                     |           |
|--------------------|-------------------------|-------------------------|-------------------------|-------------------------|-------------------------|---------------------|-----------|
| 0.001E+00          | 0.000E+00               | 0.000E+00               | 0.000E+00               | 0.000E+00               | 0.000E+00               | 0.000E+00           | 0.000E+00 |
| 0.431<br>0.721E-03 | 0.151E-05<br>0.774E-03  | 0.163E-05<br>0.150E-02  | 0.314E-05<br>0.757E-07  | -0.103E-06<br>0.813E-07 | 0.304E-05<br>0.157E-06  | 16.646<br>0.105E-03 | 0.105E-03 |
| 0.441<br>0.357E-02 | 0.599E-05<br>0.384E-02  | 0.643E-05<br>0.741E-02  | 0.124E-04<br>0.375E-06  | 0.199E-07<br>0.403E-06  | 0.124E-04<br>0.778E-06  | 16.669<br>0.105E-03 | 0.105E-03 |
| 0.531<br>0.121E-01 | 0.179E-04<br>0.130E-01  | 0.192E-04<br>0.250E-01  | 0.370E-04<br>0.127E-05  | 0.166E-06<br>0.136E-05  | 0.372E-04<br>0.263E-05  | 16.728<br>0.105E-03 | 0.105E-03 |
| 0.581<br>0.307E-01 | 0.384E-04<br>0.326E-01  | 0.412E-04<br>0.629E-01  | 0.796E-04<br>0.319E-05  | 0.469E-06<br>0.342E-05  | 0.801E-04<br>0.641E-05  | 16.794<br>0.105E-03 | 0.105E-03 |
| 0.631<br>0.637E-01 | 0.705E-04<br>0.688E-01  | 0.756E-04<br>0.132E+00  | 0.146E-03<br>0.671E-05  | 0.126E-05<br>0.720E-05  | 0.147E-03<br>0.159E-04  | 16.879<br>0.105E-03 | 0.105E-03 |
| 0.656<br>0.190E-01 | -0.169E-03<br>0.201E-01 | -0.204E-03<br>0.591E-01 | -0.392E-03<br>0.199E-05 | -0.568E-04<br>0.211E-05 | -0.449E-03<br>0.410E-05 | 12.407<br>0.105E-03 | 0.105E-03 |
| 0.657<br>0.170E-01 | -0.196E-03<br>0.165E-01 | -0.212E-03<br>0.360E-01 | -0.408E-03<br>0.184E-05 | 0.000E+00<br>0.195E-05  | -0.408E-03<br>0.378E-05 | 12.407<br>0.105E-03 | 0.105E-03 |

NO CONVERGENCE AT THIS TIME STEP T= 0.657

RESTART

|                    |                        |                         |                        |                         |                        |                     |           |
|--------------------|------------------------|-------------------------|------------------------|-------------------------|------------------------|---------------------|-----------|
| 0.657<br>0.262E-34 | 0.339E-06<br>0.277E-34 | -0.339E-06<br>0.539E-34 | 0.136E-19<br>0.000E+00 | 0.640E-35<br>0.000E+00  | 0.136E-19<br>0.566E-38 | 12.407<br>0.105E-03 | 0.000E+00 |
| 0.707<br>0.000E+00 | 0.000E+00<br>0.000E+00 | 0.000E+00<br>0.000E+00  | 0.000E+00<br>0.000E+00 | 0.000E+00<br>0.000E+00  | 0.000E+00<br>0.000E+00 | 17.200<br>0.000E+00 | 0.000E+00 |
| 0.757<br>0.000E+00 | 0.000E+00<br>0.000E+00 | 0.000E+00<br>0.000E+00  | 0.000E+00<br>0.000E+00 | 0.000E+00<br>0.000E+00  | 0.000E+00<br>0.000E+00 | 17.200<br>0.000E+00 | 0.000E+00 |
| 0.807<br>0.721E-03 | 0.151E-05<br>0.774E-03 | 0.163E-05<br>0.150E-02  | 0.314E-05<br>0.757E-07 | -0.103E-06<br>0.813E-07 | 0.304E-05<br>0.157E-06 | 16.646<br>0.105E-03 | 0.105E-03 |
| 0.857<br>0.357E-02 | 0.599E-05<br>0.384E-02 | 0.643E-05<br>0.741E-02  | 0.124E-04<br>0.375E-06 | 0.199E-07<br>0.403E-06  | 0.124E-04<br>0.778E-06 | 16.669<br>0.105E-03 | 0.105E-03 |
| 0.907<br>0.121E-01 | 0.179E-04<br>0.130E-01 | 0.192E-04<br>0.250E-01  | 0.370E-04<br>0.127E-05 | 0.166E-06<br>0.136E-05  | 0.372E-04<br>0.263E-05 | 16.728<br>0.105E-03 | 0.105E-03 |
| 0.957              | 0.384E-04              | 0.412E-04               | 0.796E-04              | 0.470E-06               | 0.801E-04              | 16.794              | 0.105E-03 |

|       |            |            |            |            |            |           |           |  |
|-------|------------|------------|------------|------------|------------|-----------|-----------|--|
|       | 0.303E-01  | 0.326E-01  | 0.629E-01  | 0.319E-05  | 0.342E-05  | 0.661E-05 | 0.105E-03 |  |
| 1.007 | 0.705E-04  | 0.756E-04  | 0.146E-03  | 0.127E-05  | 0.147E-03  | 16.879    | 0.105E-03 |  |
|       | 0.639E-01  | 0.686E-01  | 0.132E+00  | 0.671E-05  | 0.720E-05  | 0.139E-04 | 0.105E-03 |  |
| 1.032 | -0.156E-03 | -0.169E-03 | -0.325E-03 | -1.631E-04 | -0.388E-03 | 12.933    | 0.105E-03 |  |
|       | 0.267E-01  | 0.284E-01  | 0.551E-01  | 8.280E-05  | 0.298E-05  | 0.579E-05 | 0.105E-03 |  |
| 1.038 | -0.205E-03 | -0.221E-03 | -0.427E-03 | 0.117E-04  | -0.415E-03 | 13.275    | 0.105E-03 |  |
|       | 0.145E-01  | 0.152E-01  | 0.297E-01  | 0.152E-05  | 0.160E-05  | 0.312E-05 | 0.105E-03 |  |

NO CONVERGENCE AT THIS TIME STEP T= 1.038

RESTART

|       |            |            |            |            |            |           |           |  |
|-------|------------|------------|------------|------------|------------|-----------|-----------|--|
| 1.038 | 0.236E-06  | -0.236E-06 | -0.305E-19 | 0.526E-35  | -0.305E-19 | 13.275    | 0.000E+00 |  |
|       | 0.216E-34  | 0.228E-34  | 0.445E-34  | 0.000E+00  | 0.000E+00  | 0.447E-38 | 0.105E-03 |  |
| 1.088 | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 17.200    | 0.000E+00 |  |
|       | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00 | 0.000E+00 |  |
| 1.138 | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 17.200    | 0.000E+00 |  |
|       | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00 | 0.000E+00 |  |
| 1.189 | 0.151E-05  | 0.163E-05  | 0.314E-05  | -0.103E-06 | 0.304E-05  | 16.646    | 0.105E-03 |  |
|       | 0.721E-03  | 0.774E-03  | 0.150E-02  | 0.757E-07  | 0.813E-07  | 0.157E-06 | 0.105E-03 |  |
| 1.238 | 0.599E-05  | 0.643E-05  | 0.124E-04  | 0.199E-07  | 0.124E-04  | 16.669    | 0.105E-03 |  |
|       | 0.357E-02  | 0.364E-02  | 0.741E-02  | 0.375E-06  | 0.403E-06  | 0.778E-06 | 0.105E-03 |  |
| 1.288 | 0.179E-04  | 0.192E-04  | 0.370E-04  | 0.166E-06  | 0.372E-04  | 16.728    | 0.105E-03 |  |
|       | 0.121E-01  | 0.130E-01  | 0.250E-01  | 0.127E-05  | 0.136E-05  | 0.263E-05 | 0.105E-03 |  |
| 1.338 | 0.384E-04  | 0.412E-04  | 0.796E-04  | 0.470E-06  | 0.801E-04  | 16.754    | 0.105E-03 |  |
|       | 0.303E-01  | 0.326E-01  | 0.629E-01  | 0.319E-05  | 0.342E-05  | 0.661E-05 | 0.105E-03 |  |
| 1.388 | 0.705E-04  | 0.756E-04  | 0.146E-03  | 0.127E-05  | 0.147E-03  | 16.879    | 0.105E-03 |  |
|       | 0.639E-01  | 0.686E-01  | 0.133E+00  | 0.672E-05  | 0.720E-05  | 0.139E-04 | 0.105E-03 |  |
| 1.438 | 0.546E-04  | 0.581E-04  | 0.113E-03  | -0.912E-05 | 0.104E-03  | 16.486    | 0.105E-03 |  |
|       | 0.899E-01  | 0.942E-01  | 0.186E+00  | 0.944E-05  | 0.101E-04  | 0.196E-04 | 0.105E-03 |  |
| 1.463 | -0.308E-03 | -0.332E-03 | -0.640E-03 | -0.699E-04 | -0.710E-03 | 10.753    | 0.105E-03 |  |
|       | 0.167E-01  | 0.171E-01  | 0.338E-01  | 0.175E-05  | 0.180E-05  | 0.355E-05 | 0.105E-03 |  |

NO CONVERGENCE AT THIS TIME STEP T= 1.463

RESTART

|           |            |            |            |            |            |           |           |
|-----------|------------|------------|------------|------------|------------|-----------|-----------|
| 1.463     | 0.789E-06  | -0.789E-06 | 0.177E-17  | 0.652E-35  | 0.177E-17  | 10.753    | 0.000E+00 |
| 0.257E-34 | 0.265E-34  | 0.522E-34  | 0.000E+00  | 0.000E+00  | 0.548E-38  | 0.105E-03 |           |
| 1.513     | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.060E+00  | 0.000E+00  | 17.200    | 0.000E+00 |
| 0.000E+00 | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00 | 0.000E+00 |
| 1.563     | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 17.200    | 0.000E+00 |
| 0.000E+00 | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00 | 0.000E+00 |
| 1.613     | 0.151E-05  | 0.163E-05  | 0.314E-05  | -0.103E-06 | 0.304E-05  | 16.646    | 0.105E-03 |
| 0.721E-03 | 0.774E-03  | 0.150E-02  | 0.757E-07  | 0.813E-07  | 0.157E-06  | 0.105E-03 |           |
| 1.663     | 0.599E-05  | 0.643E-05  | 0.124E-04  | 0.199E-07  | 0.124E-04  | 16.669    | 0.105E-03 |
| 0.357E-02 | 0.364E-02  | 0.741E-02  | 0.375E-06  | 0.403E-06  | 0.778E-06  | 0.105E-03 |           |
| 1.713     | 0.179E-04  | 0.192E-04  | 0.370E-04  | 0.166E-06  | 0.372E-04  | 16.728    | 0.105E-03 |
| 0.121E-01 | 0.130E-01  | 0.250E-01  | 0.127E-05  | 0.136E-05  | 0.263E-05  | 0.105E-03 |           |
| 1.763     | 0.384E-04  | 0.412E-04  | 0.796E-04  | 0.470E-06  | 0.401E-04  | 16.794    | 0.105E-03 |
| 0.304E-01 | 0.326E-01  | 0.629E-01  | 0.319E-05  | 0.342E-05  | 0.661E-05  | 0.105E-03 |           |
| 1.813     | 0.705E-04  | 0.757E-04  | 0.146E-03  | 0.127E-05  | 0.147E-03  | 16.879    | 0.105E-03 |
| 0.639E-01 | 0.686E-01  | 0.133E+00  | 0.672E-05  | 0.720E-05  | 0.139E-04  | 0.105E-03 |           |
| 1.863     | 0.906E-04  | 0.971E-04  | 0.188E-03  | 0.281E-05  | 0.190E-03  | 16.951    | 0.105E-03 |
| 0.854E-01 | 0.917E-01  | 0.177E+00  | 0.898E-05  | 0.963E-05  | 0.166E-04  | 0.105E-03 |           |
| 1.863     | -0.209E-03 | -0.226E-03 | -0.435E-03 | -0.120E-03 | -0.556E-03 | 11.774    | 0.105E-03 |
| 0.357E-01 | 0.375E-01  | 0.736E-01  | 0.375E-05  | 0.398E-05  | 0.773E-05  | 0.105E-03 |           |
| 1.870     | -0.273E-03 | -0.295E-03 | -0.568E-03 | 0.209E-04  | -0.547E-03 | 12.193    | 0.105E-03 |
| 0.194E-01 | 0.203E-01  | 0.397E-01  | 0.204E-05  | 0.213E-05  | 0.418E-05  | 0.105E-03 |           |

NO CONVERGENCE AT THIS TIME STEP T= 1.870

RESTART

|           |           |            |           |           |           |           |           |
|-----------|-----------|------------|-----------|-----------|-----------|-----------|-----------|
| 1.870     | 0.447E-06 | -0.447E-06 | 0.285E-18 | 0.000E+00 | 0.285E-18 | 12.193    | 0.000E+00 |
| 0.145E-34 | 0.152E-34 | 0.297E-34  | 0.000E+00 | 0.000E+00 | 0.313E-38 | 0.105E-03 |           |
| 1.920     | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
| 0.000E+00 | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

103-

|       |            |            |            |            |            |           |           |           |
|-------|------------|------------|------------|------------|------------|-----------|-----------|-----------|
| 1.970 | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| 2.070 | 0.151E-05  | 0.163E-05  | 0.314E-05  | -0.103E-06 | 0.304E-05  | 0.157E-06 | 16.646    | 0.105E-03 |
|       | 0.721E-03  | 0.774E-03  | 0.150E-02  | 0.757E-07  | 0.813E-07  | 0.157E-06 | 0.105E-03 |           |
| 2.070 | 0.599E-05  | 0.643E-05  | 0.124E-04  | 0.199E-07  | 0.124E-04  | 0.778E-06 | 16.669    | 0.105E-03 |
|       | 0.357E-02  | 0.364E-02  | 0.741E-02  | 0.375E-06  | 0.403E-06  | 0.778E-06 | 0.105E-03 |           |
| 2.120 | 0.179E-04  | 0.192E-04  | 0.370E-04  | 0.166E-06  | 0.372E-04  | 0.263E-05 | 16.728    | 0.105E-03 |
|       | 0.121E-01  | 0.130E-01  | 0.250E-01  | 0.127E-05  | 0.136E-05  | 0.263E-05 | 0.105E-03 |           |
| 2.170 | 0.384E-04  | 0.412E-04  | 0.796E-04  | 0.471E-06  | 0.801E-04  | 0.661E-05 | 16.794    | 0.105E-03 |
|       | 0.304E-01  | 0.326E-01  | 0.629E-01  | 0.319E-05  | 0.342E-05  | 0.661E-05 | 0.105E-03 |           |
| 2.220 | 0.706E-04  | 0.757E-04  | 0.146E-03  | 0.127E-05  | 0.148E-03  | 0.139E-04 | 16.879    | 0.105E-03 |
|       | 0.639E-01  | 0.686E-01  | 0.133E+00  | 0.672E-05  | 0.721E-05  | 0.139E-04 | 0.105E-03 |           |
| 2.270 | 0.551E-04  | 0.586E-04  | 0.114E-03  | -0.910E-05 | 0.105E-03  | 0.166E-04 | 16.490    | 0.105E-03 |
|       | 0.901E-01  | 0.965E-01  | 0.187E+00  | 0.947E-05  | 0.101E-04  | 0.166E-04 | 0.105E-03 |           |
| 2.255 | -0.274E-03 | -0.296E-03 | -0.570E-03 | -0.881E-04 | -0.658E-03 | 0.575E-05 | 11.787    | 0.105E-03 |
|       | 0.240E-01  | 0.210E-01  | 0.509E-01  | 0.262E-05  | 0.273E-05  | 0.575E-05 | 0.105E-03 |           |
| 2.301 | -0.294E-03 | -0.317E-03 | -0.611E-03 | 0.598E-04  | -0.751E-03 | 0.143E-05 | 15.023    | 0.105E-03 |
|       | 0.740E-02  | 0.716E-02  | 0.146E-01  | 0.777E-06  | 0.751E-06  | 0.143E-05 | 0.105E-03 |           |

NO CONVERGENCE AT THIS TIME STEP T= 2.301

RESTART

|       |           |            |            |            |            |           |           |           |
|-------|-----------|------------|------------|------------|------------|-----------|-----------|-----------|
| 2.301 | 0.490E-06 | -0.490E-06 | -0.149E-18 | 0.565E-35  | -0.149E-18 | 0.491E-38 | 15.023    | 0.000E+00 |
|       | 0.234E-34 | 0.231E-34  | 0.467E-34  | 0.000E+00  | 0.000E+00  | 0.491E-38 | 0.105E-03 |           |
| 2.351 | 0.000E+00 | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| 2.401 | 0.000E+00 | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| 2.451 | 0.151E-05 | 0.163E-05  | 0.314E-05  | -0.103E-06 | 0.304E-05  | 0.157E-06 | 16.646    | 0.105E-03 |
|       | 0.721E-03 | 0.774E-03  | 0.150E-02  | 0.757E-07  | 0.813E-07  | 0.157E-06 | 0.105E-03 |           |
| 2.501 | 0.599E-05 | 0.643E-05  | 0.124E-04  | 0.199E-07  | 0.124E-04  | 0.778E-06 | 16.669    | 0.105E-03 |
|       | 0.357E-02 | 0.364E-02  | 0.741E-02  | 0.375E-06  | 0.403E-06  | 0.778E-06 | 0.105E-03 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 2.551     | 0.179E-04 | 0.192E-04 | 0.370E-04 | 0.166E-06 | 0.372E-04 | 16.728    | 0.105E-03 |
| 0.121E-01 | 0.130E-01 | 0.250E-01 | 0.127E-05 | 0.136E-05 | 0.263E-05 | 0.105E-03 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 2.601     | 0.384E-04 | 0.412E-04 | 0.796E-04 | 0.471E-06 | 0.801E-04 | 16.795    | 0.105E-03 |
| 0.304E-01 | 0.326E-01 | 0.630E-01 | 0.319E-05 | 0.342E-05 | 0.661E-05 | 0.105E-03 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 2.651     | 0.706E-04 | 0.757E-04 | 0.146E-03 | 0.127E-05 | 0.148E-03 | 16.879    | 0.105E-03 |
| 0.640E-01 | 0.686E-01 | 0.133E+00 | 0.672E-05 | 0.721E-05 | 0.139E-04 | 0.105E-03 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 2.676     | 0.945E-04 | 0.101E-03 | 0.196E-03 | 0.564E-05 | 0.201E-03 | 17.010    | 0.105E-03 |
| 0.864E-01 | 0.928E-01 | 0.179E+00 | 0.908E-05 | 0.974E-05 | 0.168E-04 | 0.105E-03 |           |

|           |            |            |            |            |            |           |           |
|-----------|------------|------------|------------|------------|------------|-----------|-----------|
| 2.701     | -0.151E-03 | -0.164E-03 | -0.315E-03 | -0.134E-03 | -0.449E-03 | 12.657    | 0.105E-03 |
| 0.564E-01 | 0.537E-01  | 0.104E+00  | 0.530E-05  | 0.564E-05  | 0.109E-04  | 0.105E-03 |           |

|           |            |            |            |            |            |           |           |
|-----------|------------|------------|------------|------------|------------|-----------|-----------|
| 2.777     | -0.214E-03 | -0.232E-03 | -0.446E-03 | -0.287E-04 | -0.475E-03 | 12.358    | 0.105E-03 |
| 0.376E-01 | 0.399E-01  | 0.776E-01  | 0.396E-05  | 0.419E-05  | 0.815E-05  | 0.105E-03 |           |

|           |            |            |            |           |            |           |           |
|-----------|------------|------------|------------|-----------|------------|-----------|-----------|
| 2.714     | -0.268E-03 | -0.289E-03 | -0.657E-03 | 0.281E-04 | -0.529E-03 | 12.893    | 0.105E-03 |
| 0.217E-01 | 0.227E-01  | 0.445E-01  | 0.228E-05  | 0.239E-05 | 0.467E-05  | 0.105E-03 |           |

|           |            |            |            |           |            |           |           |
|-----------|------------|------------|------------|-----------|------------|-----------|-----------|
| 2.720     | -0.250E-03 | -0.269E-03 | -0.518E-03 | 0.669E-04 | -0.462E-03 | 17.571    | 0.105E-03 |
| 0.685E-02 | 0.676E-02  | 0.136E-01  | 0.720E-06  | 0.710E-06 | 0.143E-05  | 0.105E-03 |           |

NO CONVERGENCE AT THIS TIME STEP T= 2.720

RESTART

|           |           |            |           |           |           |           |           |
|-----------|-----------|------------|-----------|-----------|-----------|-----------|-----------|
| 2.720     | 0.120E-01 | -0.126E-06 | 0.678E-20 | 0.483E-35 | 0.678E-20 | 17.571    | 0.000E+00 |
| 0.208E-34 | 0.207E-34 | 0.415E-34  | 0.000E+00 | 0.000E+00 | 0.436E-38 | 0.105E-03 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 2.770     | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
| 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 2.820     | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
| 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |           |

|           |           |           |           |            |           |           |           |
|-----------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 2.870     | 0.151E-05 | 0.163E-05 | 0.314E-05 | -0.103E-06 | 0.304E-05 | 16.646    | 0.105E-03 |
| 0.721E-03 | 0.774E-03 | 0.150E-02 | 0.757E-07 | 0.813E-07  | 0.157E-06 | 0.105E-03 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 2.920     | 0.599E-05 | 0.643E-05 | 0.124E-04 | 0.199E-07 | 0.124E-04 | 16.669    | 0.105E-03 |
| 0.357E-02 | 0.384E-02 | 0.741E-02 | 0.375E-06 | 0.403E-06 | 0.778E-06 | 0.105E-03 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 2.970     | 0.179E-04 | 0.192E-04 | 0.370E-04 | 0.166E-06 | 0.372E-04 | 16.728    | 0.105E-03 |
| 0.121E-01 | 0.130E-01 | 0.250E-01 | 0.127E-05 | 0.136E-05 | 0.263E-05 | 0.105E-03 |           |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 3.020 | 0.384E-04 | 0.412E-04 | 0.797E-04 | 0.472E-06 | 0.801E-04 | 16.795    | 0.105E-03 |
|       | 0.304E-01 | 0.326E-01 | 0.630E-01 | 0.319E-05 | 0.342E-05 | 0.661E-05 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 3.070 | 0.706E-04 | 0.757E-04 | 0.146E-03 | 0.127E-05 | 0.148E-03 | 16.880    | 0.105E-03 |
|       | 0.644E-01 | 0.687E-01 | 0.133E+00 | 0.672E-05 | 0.721E-05 | 0.139E-04 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 3.095 | 0.911E-04 | 0.976E-04 | 0.189E-03 | 0.311E-05 | 0.192E-03 | 16.957    | 0.105E-03 |
|       | 0.856E-01 | 0.919E-01 | 0.178E+00 | 0.900E-05 | 0.965E-05 | 0.186E-04 | 0.105E-03 |

|       |            |            |            |            |            |           |           |
|-------|------------|------------|------------|------------|------------|-----------|-----------|
| 3.120 | -0.126E-03 | -0.136E-03 | -0.262E-03 | -0.126E-03 | -0.387E-03 | 13.121    | 0.105E-03 |
|       | 0.550E-01  | 0.595E-01  | 0.115E+00  | 0.586E-05  | 0.625E-05  | 0.121E-04 | 0.105E-03 |

|       |            |            |            |           |            |           |           |
|-------|------------|------------|------------|-----------|------------|-----------|-----------|
| 3.145 | -0.200E-03 | -0.216E-03 | -0.416E-03 | 0.964E-05 | -0.407E-03 | 15.327    | 0.105E-03 |
|       | 0.807E-02  | 0.812E-02  | 0.162E-01  | 0.850E-06 | 0.852E-06  | 0.170E-05 | 0.105E-03 |

NO CONVERGENCE AT THIS TIME STEP T= 3.145

RESTART

|       |           |            |            |           |            |           |           |
|-------|-----------|------------|------------|-----------|------------|-----------|-----------|
| 3.145 | 0.307E-06 | -0.307E-06 | -0.102E-19 | 0.604E-35 | -0.102E-19 | 15.227    | 0.000E+00 |
|       | 0.261E-34 | 0.262E-34  | 0.523E-34  | 0.000E+00 | 0.000E+00  | 0.549E-38 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 3.155 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 3.245 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

|       |           |           |           |            |           |           |           |
|-------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 3.255 | 0.151E-05 | 0.163E-05 | 0.314E-05 | -0.103E-06 | 0.304E-05 | 16.646    | 0.105E-03 |
|       | 0.721E-03 | 0.774E-03 | 0.150E-02 | 0.757E-07  | 0.813E-07 | 0.157E-06 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 3.345 | 0.599E-05 | 0.643E-05 | 0.124E-04 | 0.199E-07 | 0.124E-04 | 16.669    | 0.105E-03 |
|       | 0.357E-02 | 0.384E-02 | 0.741E-02 | 0.375E-06 | 0.403E-06 | 0.778E-06 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 3.395 | 0.179E-04 | 0.192E-04 | 0.370E-04 | 0.166E-06 | 0.372E-04 | 16.728    | 0.105E-03 |
|       | 0.121E-01 | 0.130E-01 | 0.250E-01 | 0.127E-05 | 0.136E-05 | 0.263E-05 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 3.445 | 0.384E-04 | 0.412E-04 | 0.797E-04 | 0.472E-06 | 0.801E-04 | 16.795    | 0.105E-03 |
|       | 0.304E-01 | 0.326E-01 | 0.630E-01 | 0.319E-05 | 0.342E-05 | 0.661E-05 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 3.455 | 0.706E-04 | 0.757E-04 | 0.146E-03 | 0.127E-05 | 0.148E-03 | 16.880    | 0.105E-03 |
|       | 0.644E-01 | 0.687E-01 | 0.133E+00 | 0.672E-05 | 0.721E-05 | 0.139E-04 | 0.105E-03 |

|       |           |           |           |            |           |           |           |
|-------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 3.545 | 0.649E-04 | 0.692E-04 | 0.134E-03 | -0.721E-05 | 0.127E-03 | 16.570    | 0.105E-03 |
|       | 0.949E-01 | 0.102E+00 | 0.196E+00 | 0.997E-05  | 0.107E-04 | 0.206E-04 | 0.105E-03 |

|       |            |            |            |            |            |           |           |
|-------|------------|------------|------------|------------|------------|-----------|-----------|
| 3.570 | -0.216E-03 | -0.233E-03 | -0.449E-03 | -0.125E-03 | -0.574E-03 | 12.979    | 0.105E-03 |
|       | 0.436E-01  | 0.461E-01  | 0.896E-01  | 0.498E-05  | 0.484E-05  | 0.942E-05 | 0.105E-03 |

|       |            |            |            |           |            |           |           |
|-------|------------|------------|------------|-----------|------------|-----------|-----------|
| 3.576 | -0.277E-03 | -0.298E-03 | -0.575E-03 | 0.224E-04 | -0.552E-03 | 12.910    | 0.105E-03 |
|       | 0.271E-01  | 0.283E-01  | 0.554E-01  | 0.785E-05 | 0.298E-05  | 0.562E-05 | 0.105E-03 |

|       |            |            |            |           |            |           |           |
|-------|------------|------------|------------|-----------|------------|-----------|-----------|
| 3.601 | -0.107E-03 | -0.114E-03 | -0.222E-03 | 0.369E-05 | -0.218E-03 | 19.158    | 0.105E-03 |
|       | 0.153E-02  | 0.119E-02  | 0.273E-02  | 0.161E-06 | 0.125E-06  | 0.286E-06 | 0.105E-03 |

NO CONVERGENCE AT THIS TIME STEP. T= 3.601

RESTART

|       |            |           |           |           |           |           |           |
|-------|------------|-----------|-----------|-----------|-----------|-----------|-----------|
| 3.601 | -0.652E-06 | 0.652E-06 | 0.339E-20 | 0.000E+00 | 0.339E-20 | 19.158    | 0.000E+00 |
|       | 0.184E-34  | 0.144E-34 | 0.324E-34 | 0.000E+00 | 0.000E+00 | 0.341E-36 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 3.651 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 3.701 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

|       |           |           |           |            |           |           |           |
|-------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 3.751 | 0.151E-05 | 0.163E-05 | 0.314E-05 | -0.103E-06 | 0.304E-05 | 16.446    | 0.105E-03 |
|       | 0.721E-03 | 0.774E-03 | 0.150E-02 | 0.757E-07  | 0.813E-07 | 0.157E-06 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 3.801 | 0.599E-05 | 0.643E-05 | 0.124E-04 | 0.199E-07 | 0.124E-04 | 16.669    | 0.105E-03 |
|       | 0.357E-02 | 0.344E-02 | 0.741E-02 | 0.375E-06 | 0.403E-06 | 0.778E-06 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 3.851 | 0.179E-04 | 0.192E-04 | 0.370E-04 | 0.166E-06 | 0.372E-04 | 16.728    | 0.105E-03 |
|       | 0.121E-01 | 0.130E-01 | 0.250E-01 | 0.127E-05 | 0.136E-05 | 0.213E-05 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 3.901 | 0.304E-04 | 0.412E-04 | 0.797E-04 | 0.472E-06 | 0.801E-04 | 16.795    | 0.105E-03 |
|       | 0.304E-01 | 0.326E-01 | 0.630E-01 | 0.319E-05 | 0.342E-05 | 0.661E-05 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 3.951 | 0.706E-04 | 0.758E-04 | 0.146E-03 | 0.127E-05 | 0.148E-03 | 16.880    | 0.105E-03 |
|       | 0.640E-01 | 0.627E-01 | 0.133E+00 | 0.672E-05 | 0.721E-05 | 0.139E-04 | 0.105E-03 |

|       |           |           |           |            |           |           |           |
|-------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 4.001 | 0.716E-04 | 0.764E-04 | 0.148E-03 | -0.590E-05 | 0.142E-03 | 16.625    | 0.105E-03 |
|       | 0.980E-01 | 0.104E+00 | 0.203E+00 | 0.103E-04  | 0.110E-04 | 0.213E-04 | 0.105E-03 |

|       |            |            |            |            |            |           |           |
|-------|------------|------------|------------|------------|------------|-----------|-----------|
| 4.026 | -0.200E-03 | -0.217E-03 | -0.417E-03 | -0.139E-03 | -0.557E-03 | 12.221    | 0.105E-03 |
|       | 0.504E-01  | 0.534E-01  | 0.104E+00  | 0.529E-05  | 0.561E-05  | 0.109E-04 | 0.105E-03 |

|       |            |            |            |           |            |           |           |
|-------|------------|------------|------------|-----------|------------|-----------|-----------|
| 4.032 | -0.263E-03 | -0.284E-03 | -0.547E-03 | 0.726E-05 | -0.540E-03 | 12.304    | 0.105E-03 |
|       | 0.347E-01  | 0.365E-01  | 0.713E-01  | 0.365E-05 | 0.384E-05  | 0.749E-05 | 0.105E-03 |

|       |            |            |            |           |            |           |           |
|-------|------------|------------|------------|-----------|------------|-----------|-----------|
| 4.039 | -0.301E-03 | -0.324E-03 | -0.626E-03 | 0.571E-04 | -0.569E-03 | 13.833    | 0.105E-03 |
|       | 0.164E-01  | 0.172E-01  | 0.340E-01  | 0.177E-05 | 0.181E-05  | 0.357E-05 | 0.105E-03 |

NO CONVERGENCE AT THIS TIME STEP T= 4.039

RESTART

|       |           |            |           |           |           |           |           |
|-------|-----------|------------|-----------|-----------|-----------|-----------|-----------|
| 4.039 | 0.363E-06 | -0.303E-06 | 0.386E-18 | 0.617E-35 | 0.386E-18 | 13.833    | 0.000E+00 |
|       | 0.244E-34 | 0.256E-34  | 0.504E-34 | 0.000E+00 | 0.000E+00 | 0.530E-38 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 4.089 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.290    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 4.139 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

|       |           |           |           |            |           |           |           |
|-------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 4.189 | 0.151E-05 | 0.163E-05 | 0.314E-05 | -0.103E-06 | 0.304E-05 | 16.646    | 0.105E-03 |
|       | 0.721E-03 | 0.774E-03 | 0.150E-02 | 0.757E-07  | 0.813E-07 | 0.157E-06 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 4.239 | 0.599E-05 | 0.643E-05 | 0.124E-04 | 0.199E-07 | 0.124E-04 | 16.669    | 0.105E-03 |
|       | 0.357E-02 | 0.384E-02 | 0.741E-02 | 0.375E-06 | 0.403E-06 | 0.778E-06 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 4.289 | 0.179E-04 | 0.192E-04 | 0.370E-04 | 0.166E-06 | 0.372E-04 | 16.728    | 0.105E-03 |
|       | 0.121E-01 | 0.130E-01 | 0.250E-01 | 0.127E-05 | 0.136E-05 | 0.263E-05 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 4.339 | 0.384E-04 | 0.412E-04 | 0.797E-04 | 0.472E-06 | 0.401E-04 | 16.795    | 0.105E-03 |
|       | 0.304E-01 | 0.326E-01 | 0.630E-01 | 0.319E-05 | 0.342E-05 | 0.661E-05 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 4.389 | 0.706E-04 | 0.758E-04 | 0.146E-03 | 0.128E-05 | 0.144E-03 | 16.880    | 0.105E-03 |
|       | 0.640E-01 | 0.687E-01 | 0.133E+00 | 0.672E-05 | 0.721E-05 | 0.129E-04 | 0.105E-03 |

|       |           |           |           |            |           |           |           |
|-------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 4.439 | 0.675E-04 | 0.720E-04 | 0.140E-03 | -0.673E-05 | 0.133E-03 | 16.591    | 0.105E-03 |
|       | 0.961E-01 | 0.103E+00 | 0.199E+00 | 0.101E-04  | 0.108E-04 | 0.209E-04 | 0.105E-03 |

|       |            |            |            |            |            |           |           |
|-------|------------|------------|------------|------------|------------|-----------|-----------|
| 4.489 | -0.187E-03 | -0.202E-03 | -0.388E-03 | -0.129E-03 | -0.518E-03 | 12.508    | 0.105E-03 |
|       | 0.517E-01  | 0.549E-01  | 0.107E+00  | 0.543E-05  | 0.576E-05  | 0.112E-04 | 0.105E-03 |

|       |            |            |            |           |            |           |           |
|-------|------------|------------|------------|-----------|------------|-----------|-----------|
| 4.489 | -0.190E-03 | -0.204E-03 | -0.394E-03 | 0.121E-04 | -0.382E-03 | 16.432    | 0.105E-03 |
|       | 0.650E-02  | 0.625E-02  | 0.128E-01  | 0.683E-06 | 0.657E-06  | 0.124E-05 | 0.105E-03 |

NO CONVERGENCE AT THIS TIME STEP T= 4.489

RESTART

|       |           |            |            |           |            |           |           |
|-------|-----------|------------|------------|-----------|------------|-----------|-----------|
| 4.489 | 0.914E-07 | -0.914E-07 | -0.678E-20 | 0.447E-35 | -0.678E-20 | 16.432    | 0.000E+00 |
|       | 0.193E-34 | 0.202E-34  | 0.395E-34  | 0.000E+00 | 0.000E+00  | 0.415E-38 | 0.105E-03 |



|       |           |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 4.539 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

|       |           |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 4.549 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

|       |           |           |           |            |           |           |           |
|-------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 4.639 | 0.151E-05 | 0.163E-05 | 0.314E-05 | -0.103E-06 | 0.304E-05 | 16.646    | 0.105E-03 |
|       | 0.721E-03 | 0.774E-03 | 0.150E-02 | 0.757E-07  | 0.813E-07 | 0.157E-06 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 4.669 | 0.599E-05 | 0.643E-05 | 0.124E-04 | 0.199E-07 | 0.124E-04 | 16.669    | 0.105E-03 |
|       | 0.357E-02 | 0.384E-02 | 0.741E-02 | 0.375E-06 | 0.403E-06 | 0.778E-06 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 4.739 | 0.179E-04 | 0.197E-04 | 0.370E-04 | 0.166E-06 | 0.372E-04 | 16.728    | 0.105E-03 |
|       | 0.121E-01 | 0.120E-01 | 0.250E-01 | 0.127E-05 | 0.136E-05 | 0.263E-05 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 4.769 | 0.384E-04 | 0.412E-04 | 0.797E-04 | 0.472E-06 | 0.801E-04 | 16.795    | 0.105E-03 |
|       | 0.304E-01 | 0.326E-01 | 0.630E-01 | 0.319E-05 | 0.342E-05 | 0.611E-05 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 4.839 | 0.699E-04 | 0.749E-04 | 0.145E-03 | 0.116E-05 | 0.146E-03 | 16.874    | 0.105E-03 |
|       | 0.631E-01 | 0.683E-01 | 0.132E+00 | 0.668E-05 | 0.717E-05 | 0.139E-04 | 0.105E-03 |

|       |           |           |           |            |           |           |           |
|-------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 4.889 | 0.731E-04 | 0.781E-04 | 0.151E-03 | -0.535E-05 | 0.146E-03 | 16.643    | 0.105E-03 |
|       | 0.984E-01 | 0.105E+00 | 0.204E+00 | 0.103E-04  | 0.111E-04 | 0.214E-04 | 0.105E-03 |

|       |            |            |            |            |            |           |           |
|-------|------------|------------|------------|------------|------------|-----------|-----------|
| 4.939 | -0.186E-03 | -0.202E-03 | -0.388E-03 | -0.528E-05 | -0.394E-03 | 14.549    | 0.105E-03 |
|       | 0.975E-02  | 0.938E-02  | 0.190E-01  | 0.102E-05  | 0.977E-06  | 0.200E-05 | 0.105E-03 |

NO CONVERGENCE AT THIS TIME STEP T= 4.939

RESTART

|       |           |            |            |           |            |           |           |
|-------|-----------|------------|------------|-----------|------------|-----------|-----------|
| 4.939 | 0.835E-06 | -0.835E-06 | -0.339E-20 | 0.000E+00 | -0.339E-20 | 14.549    | 0.000E+00 |
|       | 0.143E-34 | 0.146E-34  | 0.289E-34  | 0.000E+00 | 0.000E+00  | 0.303E-38 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 4.989 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 5.039 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

|       |           |           |           |            |           |           |           |
|-------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 5.089 | 0.151E-05 | 0.163E-05 | 0.314E-05 | -0.103E-06 | 0.304E-05 | 16.646    | 0.105E-03 |
|       | 0.721E-03 | 0.774E-03 | 0.150E-02 | 0.757E-07  | 0.813E-07 | 0.157E-06 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 5.139 | 0.599E-05 | 0.643E-05 | 0.124E-04 | 0.199E-07 | 0.124E-04 | 16.669    | 0.105E-03 |
|       | 0.357E-02 | 0.384E-02 | 0.741E-02 | 0.375E-06 | 0.403E-06 | 0.778E-06 | 0.105E-03 |

|       |            |            |            |            |            |           |           |
|-------|------------|------------|------------|------------|------------|-----------|-----------|
| 5.149 | 0.179E-04  | 0.192E-04  | 0.370E-04  | 0.166E-06  | 0.372E-04  | 16.728    | 0.105E-03 |
|       | 0.121E-01  | 0.130E-01  | 0.250E-01  | 0.127E-05  | 0.136E-05  | 0.263E-05 | 0.105E-03 |
| 5.239 | 0.384E-04  | 0.412E-04  | 0.797E-04  | 0.472E-06  | 0.801E-04  | 16.795    | 0.105E-03 |
|       | 0.304E-01  | 0.326E-01  | 0.630E-01  | 0.319E-05  | 0.342E-05  | 0.661E-05 | 0.105E-03 |
| 5.249 | 0.706E-04  | 0.758E-04  | 0.146E-03  | 0.128E-05  | 0.148E-03  | 16.880    | 0.105E-03 |
|       | 0.640E-01  | 0.687E-01  | 0.133E+00  | 0.672E-05  | 0.721E-05  | 0.139E-04 | 0.105E-03 |
| 5.339 | 0.662E-04  | 0.727E-04  | 0.141E-03  | -0.659E-05 | 0.134E-03  | 16.597    | 0.105E-03 |
|       | 0.964E-01  | 0.103E+00  | 0.200E+00  | 0.101E-04  | 0.108E-04  | 0.210E-04 | 0.105E-03 |
| 5.364 | -0.187E-03 | -0.203E-03 | -0.390E-03 | -0.131E-03 | -0.521E-03 | 12.487    | 0.105E-03 |
|       | 0.519E-01  | 0.551E-01  | 0.107E+00  | 0.545E-05  | 0.578E-05  | 0.112E-04 | 0.105E-03 |
| 5.370 | -0.248E-03 | -0.267E-03 | -0.515E-03 | 0.000E+00  | -0.515E-03 | 12.487    | 0.105E-03 |
|       | 0.372E-01  | 0.392E-01  | 0.763E-01  | 0.390E-05  | 0.411E-05  | 0.802E-05 | 0.105E-03 |
| 5.376 | -0.290E-03 | -0.313E-03 | -0.603E-03 | 0.494E-04  | -0.554E-03 | 13.561    | 0.105E-03 |
|       | 0.199E-01  | 0.206E-01  | 0.405E-01  | 0.209E-05  | 0.216E-05  | 0.425E-05 | 0.105E-03 |
| 5.383 | -0.237E-03 | -0.255E-03 | -0.492E-03 | 0.563E-04  | -0.436E-03 | 19.855    | 0.105E-03 |
|       | 0.574E-02  | 0.540E-02  | 0.112E-01  | 0.608E-06  | 0.567E-06  | 0.111E-05 | 0.105E-03 |

NO CONVERGENCE AT THIS TIME STEP T= 5.383

RESTART

|       |           |            |           |            |           |           |           |
|-------|-----------|------------|-----------|------------|-----------|-----------|-----------|
| 5.383 | 0.581E-07 | -0.591E-07 | 0.169E-19 | 0.390E-35  | 0.169E-19 | 19.855    | 0.000E+00 |
|       | 0.170E-34 | 0.168E-34  | 0.344E-34 | 0.000E+00  | 0.000E+00 | 0.361E-38 | 0.105E-03 |
| 5.433 | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00  | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| 5.463 | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00  | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00  | 0.000E+00 | 0.000E+00 | 0.000E+00 |
| 5.523 | 0.151E-05 | 0.163E-05  | 0.314E-05 | -0.103E-06 | 0.304E-05 | 16.746    | 0.105E-03 |
|       | 0.721E-03 | 0.774E-03  | 0.150E-02 | 0.757E-07  | 0.813E-07 | 0.157E-06 | 0.105E-03 |
| 5.583 | 0.599E-05 | 0.643E-05  | 0.124E-04 | 0.199E-07  | 0.124E-04 | 16.669    | 0.105E-03 |
|       | 0.357E-02 | 0.364E-02  | 0.741E-02 | 0.375E-06  | 0.403E-06 | 0.778E-06 | 0.105E-03 |
| 5.633 | 0.179E-04 | 0.192E-04  | 0.370E-04 | 0.166E-06  | 0.372E-04 | 16.728    | 0.105E-03 |
|       | 0.121E-01 | 0.130E-01  | 0.250E-01 | 0.127E-05  | 0.136E-05 | 0.263E-05 | 0.105E-03 |

5.663 0.384E-04 0.412E-04 0.797E-04 0.472E-06 0.001E-04 16.795 0.105E-03  
0.304E-01 0.324E-01 0.630E-01 0.319E-05 0.342E-05 0.671E-05 0.105E-03

5.753 0.699E-04 0.749E-04 0.145E-03 0.116E-05 0.146E-03 16.674 0.105E-03  
0.630E-01 0.683E-01 0.132E+00 0.668E-05 0.717E-05 0.139E-04 0.105E-03

5.743 0.722E-04 0.770E-04 0.149E-03 -0.555E-05 0.144E-03 16.635 0.105E-03  
0.977E-01 0.105E+00 0.203E+00 0.103E-04 0.110E-04 0.213E-04 0.105E-03

5.853 -0.185E-03 -0.201E-03 -0.386E-03 -0.532E-05 -0.392E-03 14.564 0.105E-03  
0.973E-02 0.931E-02 0.190E-01 0.102E-04 0.978E-06 0.200E-05 0.105E-03

5.853 -0.188E-03 -0.204E-03 -0.392E-03 0.480E-04 -0.344E-03 14.926 0.105E-03  
0.833E-02 0.779E-02 0.161E-01 0.875E-06 0.819E-06 0.109E-05 0.105E-03

5.834 -0.190E-03 -0.206E-03 -0.396E-03 0.703E-04 -0.325E-03 15.003 0.105E-03  
0.690E-02 0.620E-02 0.132E-01 0.727E-06 0.658E-06 0.138E-05 0.105E-03

5.835 -0.189E-03 -0.205E-03 -0.394E-03 0.911E-04 -0.303E-03 16.145 0.105E-03  
0.551E-02 0.474E-02 0.102E-01 0.579E-06 0.498E-06 0.108E-05 0.105E-03

5.836 -0.184E-03 -0.200E-03 -0.384E-03 0.104E-03 -0.280E-03 19.058 0.105E-03  
0.414E-02 0.325E-02 0.739E-02 0.435E-06 0.342E-06 0.776E-06 0.105E-03

NO CONVERGENCE AT THIS TIME STEP T= 5.836

RESTART

5.836 0.782E-06 -0.782E-06 0.678E-20 0.477E-35 0.678E-20 19.058 0.000E+00  
0.245E-34 0.191E-34 0.436E-34 0.000E+00 0.000E+00 0.458E-38 0.105E-03

5.836 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 17.200 0.000E+00  
0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00

5.936 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 17.200 0.000E+00  
0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00

5.986 0.151E-05 0.163E-05 0.314E-05 -0.103E-06 0.204E-05 16.446 0.105E-03  
0.721E-03 0.774E-03 0.150E-02 0.757E-07 0.813E-07 0.107E-06 0.105E-03

6.036 0.599E-05 0.643E-05 0.124E-04 0.199E-07 0.124E-04 16.169 0.105E-03  
0.357E-02 0.384E-02 0.741E-02 0.375E-06 0.403E-06 0.778E-06 0.105E-03

6.086 0.179E-04 0.192E-04 0.370E-04 0.166E-06 0.372E-04 16.728 0.105E-03  
0.121E-01 0.130E-01 0.250E-01 0.127E-05 0.136E-05 0.263E-05 0.105E-03

6.136 0.384E-04 0.412E-04 0.797E-04 0.472E-06 0.401E-04 16.795 0.105E-03  
0.304E-01 0.326E-01 0.630E-01 0.319E-05 0.342E-05 0.661E-05 0.105E-03

6.166 0.706E-04 0.758E-04 0.146E-03 0.128E-05 0.148E-03 16.800 0.105E-03  
0.640E-01 0.687E-01 0.133E+00 0.672E-05 0.721E-05 0.139E-04 0.105E-03

6.236 0.668E-04 0.712E-04 0.138E-03 -0.488E-05 0.131E-03 16.585 0.105E-03  
0.958E-01 0.103E+00 0.198E+00 0.101E-04 0.102E-04 0.210E-04 0.105E-03

6.261 -0.186E-03 -0.202E-03 -0.388E-03 -0.128E-03 -0.516E-03 12.524 0.105E-03  
0.514E-01 0.546E-01 0.106E+00 0.540E-05 0.573E-05 0.111E-04 0.105E-03

6.267 -0.246E-03 -0.266E-03 -0.512E-03 0.000E+00 -0.512E-03 12.524 0.105E-03  
0.368E-01 0.388E-01 0.756E-01 0.387E-05 0.407E-05 0.754E-05 0.105E-03

6.273 -0.288E-03 -0.310E-03 -0.598E-03 0.501E-04 -0.548E-03 13.632 0.105E-03  
0.197E-01 0.203E-01 0.400E-01 0.207E-05 0.214E-05 0.420E-05 0.105E-03

6.280 -0.233E-03 -0.251E-03 -0.484E-03 0.573E-04 -0.426E-03 19.959 0.105E-03  
0.581E-01 0.542E-01 0.112E-01 0.610E-06 0.570E-06 0.118E-05 0.105E-03

NO CONVERGENCE AT THIS TIME STEP T= 6.280

RESTART

6.280 0.614E-07 -0.614E-07 0.102E-19 0.395E-35 0.102E-19 19.959 0.000E+00  
0.175E-34 0.171E-34 0.350E-34 0.000E+00 0.000E+00 0.368E-38 0.105E-03

6.330 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 17.200 0.000E+00  
0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00

6.380 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 17.200 0.000E+00  
0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00

6.430 0.151E-05 0.163E-05 0.314E-05 -0.103E-06 0.304E-05 16.646 0.105E-03  
0.721E-03 0.774E-03 0.150E-02 0.757E-07 0.813E-07 0.157E-06 0.105E-03

6.480 0.599E-05 0.643E-05 0.124E-04 0.199E-07 0.124E-04 16.669 0.105E-03  
0.357E-02 0.384E-02 0.741E-02 0.375E-06 0.403E-06 0.778E-06 0.105E-03

6.530 0.179E-04 0.192E-04 0.370E-04 0.166E-06 0.372E-04 16.728 0.105E-03  
0.121E-01 0.130E-01 0.250E-01 0.127E-05 0.136E-05 0.263E-05 0.105E-03

6.580 0.384E-04 0.412E-04 0.797E-04 0.472E-06 0.401E-04 16.795 0.105E-03  
0.304E-01 0.326E-01 0.630E-01 0.319E-05 0.342E-05 0.661E-05 0.105E-03

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 6.630 | 0.699E-04 | 0.749E-04 | 0.145E-04 | 0.116E-05 | 0.146E-03 | 16.274    | 0.105E-03 |
|       | 0.630E-01 | 0.103E-01 | 0.132E+00 | 0.668E-05 | 0.717E-05 | 0.139E-04 | 0.105E-03 |

|       |           |           |           |            |           |           |           |
|-------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 6.640 | 0.693E-04 | 0.739E-04 | 0.143E-03 | -0.613E-05 | 0.137E-03 | 16.611    | 0.105E-03 |
|       | 0.966E-01 | 0.123E+00 | 0.200E+00 | 0.101E-04  | 0.109E-04 | 0.210E-04 | 0.105E-03 |

|       |            |            |            |            |            |           |           |
|-------|------------|------------|------------|------------|------------|-----------|-----------|
| 6.705 | -0.163E-03 | -0.177E-03 | -0.341E-03 | -0.131E-03 | -0.472E-03 | 12.853    | 0.105E-03 |
|       | 0.577E-01  | 0.613E-01  | 0.119E+00  | 0.600E-05  | 0.644E-05  | 0.125E-04 | 0.105E-03 |

|       |            |            |            |           |            |           |           |
|-------|------------|------------|------------|-----------|------------|-----------|-----------|
| 6.730 | -0.205E-03 | -0.220E-03 | -0.425E-03 | 0.136E-04 | -0.412E-03 | 15.836    | 0.105E-03 |
|       | 0.893E-02  | 0.843E-02  | 0.178E-01  | 0.939E-06 | 0.927E-06  | 0.187E-05 | 0.105E-03 |

NO CONVERGENCE AT THIS TIME STEP T= 6.730

RESTART

|       |           |            |            |           |            |           |           |
|-------|-----------|------------|------------|-----------|------------|-----------|-----------|
| 6.730 | 0.216E-06 | -0.216E-06 | -0.339E-20 | 0.000E+00 | -0.339E-20 | 15.836    | 0.000E+00 |
|       | 0.140E-34 | 0.141E-34  | 0.281E-34  | 0.000E+00 | 0.000E+00  | 0.296E-38 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 6.780 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 6.830 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

|       |           |           |           |            |           |           |           |
|-------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 6.860 | 0.151E-05 | 0.163E-05 | 0.314E-05 | -0.103E-06 | 0.304E-05 | 16.646    | 0.105E-03 |
|       | 0.721E-03 | 0.774E-03 | 0.150E-02 | 0.757E-07  | 0.813E-07 | 0.157E-06 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 6.930 | 0.599E-05 | 0.643E-05 | 0.124E-04 | 0.199E-07 | 0.124E-04 | 16.669    | 0.105E-03 |
|       | 0.357E-02 | 0.384E-02 | 0.741E-02 | 0.375E-06 | 0.403E-06 | 0.778E-06 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 6.940 | 0.179E-04 | 0.192E-04 | 0.370E-04 | 0.166E-06 | 0.372E-04 | 17.728    | 0.105E-03 |
|       | 0.121E-01 | 0.139E-01 | 0.250E-01 | 0.127E-05 | 0.136E-05 | 0.263E-05 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 7.030 | 0.384E-04 | 0.412E-04 | 0.797E-04 | 0.472E-06 | 0.401E-04 | 16.795    | 0.105E-03 |
|       | 0.304E-01 | 0.326E-01 | 0.630E-01 | 0.319E-05 | 0.342E-05 | 0.661E-05 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 7.080 | 0.699E-04 | 0.749E-04 | 0.145E-03 | 0.116E-05 | 0.146E-03 | 16.874    | 0.105E-03 |
|       | 0.630E-01 | 0.683E-01 | 0.132E+00 | 0.668E-05 | 0.717E-05 | 0.139E-04 | 0.105E-03 |

|       |           |           |           |            |           |           |           |
|-------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 7.130 | 0.748E-04 | 0.798E-04 | 0.155E-03 | -0.506E-05 | 0.150E-03 | 16.656    | 0.105E-03 |
|       | 0.992E-01 | 0.106E+00 | 0.205E+00 | 0.104E-04  | 0.112E-04 | 0.214E-04 | 0.105E-03 |

|       |            |            |            |            |            |           |           |
|-------|------------|------------|------------|------------|------------|-----------|-----------|
| 7.155 | -0.111E-03 | -0.120E-03 | -0.231E-03 | -0.125E-03 | -0.356E-03 | 13.619    | 0.105E-03 |
|       | 0.729E-01  | 0.777E-01  | 0.151E+00  | 0.766E-05  | 0.816E-05  | 0.158E-04 | 0.105E-03 |

|       |            |            |            |           |            |           |           |
|-------|------------|------------|------------|-----------|------------|-----------|-----------|
| 7.180 | -0.232E-03 | -0.250E-03 | -0.402E-03 | 0.970E-05 | -0.472E-03 | 14.584    | 0.105E-03 |
|       | 0.177E-01  | 0.107E-01  | 0.359E-01  | 0.186E-05 | 0.191E-05  | 0.378E-05 | 0.105E-03 |

|       |            |            |            |           |            |           |           |
|-------|------------|------------|------------|-----------|------------|-----------|-----------|
| 7.186 | -0.194E-03 | -0.209E-03 | -0.404E-03 | 0.435E-04 | -0.360E-03 | 18.903    | 0.105E-03 |
|       | 0.610E-02  | 0.574E-02  | 0.119E-01  | 0.650E-06 | 0.603E-06  | 0.125E-05 | 0.105E-03 |

NO CONVERGENCE AT THIS TIME STEP T= 7.186

RESTART

|       |           |            |           |           |           |           |           |
|-------|-----------|------------|-----------|-----------|-----------|-----------|-----------|
| 7.186 | 0.282E-06 | -0.212E-06 | 0.678E-20 | 0.414E-35 | 0.678E-20 | 18.903    | 0.000E+00 |
|       | 0.192E-34 | 0.181E-34  | 0.374E-34 | 0.000E+00 | 0.000E+00 | 0.352E-38 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 7.236 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 7.246 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

|       |           |           |           |            |           |           |           |
|-------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 7.336 | 0.151E-05 | 0.163E-05 | 0.314E-05 | -0.103E-06 | 0.304E-05 | 16.646    | 0.105E-03 |
|       | 0.721E-03 | 0.774E-03 | 0.150E-02 | 0.757E-07  | 0.813E-07 | 0.147E-06 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 7.386 | 0.599E-05 | 0.643E-05 | 0.124E-04 | 0.199E-07 | 0.124E-04 | 16.669    | 0.105E-03 |
|       | 0.357E-02 | 0.384E-02 | 0.741E-02 | 0.375E-06 | 0.403E-06 | 0.776E-06 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 7.436 | 0.179E-04 | 0.192E-04 | 0.370E-04 | 0.166E-06 | 0.372E-04 | 16.728    | 0.105E-03 |
|       | 0.121E-01 | 0.140E-01 | 0.250E-01 | 0.127E-05 | 0.136E-05 | 0.263E-05 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 7.486 | 0.384E-04 | 0.412E-04 | 0.797E-04 | 0.472E-06 | 0.801E-04 | 16.795    | 0.105E-03 |
|       | 0.304E-01 | 0.326E-01 | 0.630E-01 | 0.319E-05 | 0.342E-05 | 0.661E-05 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 7.536 | 0.699E-04 | 0.749E-04 | 0.144E-03 | 0.116E-05 | 0.146E-03 | 16.874    | 0.105E-03 |
|       | 0.636E-01 | 0.683E-01 | 0.132E+00 | 0.668E-05 | 0.717E-05 | 0.139E-04 | 0.105E-03 |

|       |           |           |           |            |           |           |           |
|-------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 7.586 | 0.750E-04 | 0.801E-04 | 0.155E-03 | -0.504E-05 | 0.150E-03 | 16.658    | 0.105E-03 |
|       | 0.993E-01 | 0.100E+00 | 0.206E+00 | 0.104E-04  | 0.112E-04 | 0.216E-04 | 0.105E-03 |

|       |            |            |            |            |            |           |           |
|-------|------------|------------|------------|------------|------------|-----------|-----------|
| 7.636 | -0.111E-04 | -0.132E-04 | -0.243E-04 | -0.168E-04 | -0.411E-04 | 15.927    | 0.105E-03 |
|       | 0.940E-01  | 0.100E+00  | 0.194E+00  | 0.988E-05  | 0.105E-04  | 0.264E-04 | 0.105E-03 |

|       |            |            |            |            |            |           |           |
|-------|------------|------------|------------|------------|------------|-----------|-----------|
| 7.686 | -0.178E-03 | -0.192E-03 | -0.370E-03 | -0.585E-04 | -0.429E-03 | 13.899    | 0.105E-03 |
|       | 0.517E-01  | 0.543E-01  | 0.106E+00  | 0.544E-05  | 0.571E-05  | 0.111E-04 | 0.105E-03 |

|       |            |            |            |           |            |           |           |
|-------|------------|------------|------------|-----------|------------|-----------|-----------|
| 7.711 | -0.100E-03 | -0.107E-03 | -0.207E-03 | 0.291E-05 | -0.204E-03 | 17.142    | 0.105E-03 |
|       | 0.413E-02  | 0.359E-02  | 0.773E-02  | 0.434E-06 | 0.377E-06  | 0.812E-06 | 0.105E-03 |

|       |            |            |            |           |            |           |           |
|-------|------------|------------|------------|-----------|------------|-----------|-----------|
| 7.717 | -0.562E-04 | -0.594E-04 | -0.116E-03 | 0.157E-05 | -0.114E-03 | 19.494    | 0.105E-03 |
|       | 0.787E-03  | 0.566E-04  | 0.844E-03  | 0.827E-07 | 0.594E-08  | 0.847E-07 | 0.105E-03 |

NO CONVERGENCE AT THIS TIME STEP T= 7.717

RESTART

|       |            |           |           |           |           |           |           |
|-------|------------|-----------|-----------|-----------|-----------|-----------|-----------|
| 7.717 | -0.463E-06 | 0.463E-06 | 0.847E-21 | 0.242E-34 | 0.847E-21 | 19.494    | 0.105E-03 |
|       | 0.302E-33  | 0.230E-34 | 0.325E-33 | 0.317E-37 | 0.000E+00 | 0.342E-37 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 7.767 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 7.817 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
|       | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |

|       |           |           |           |            |           |           |           |
|-------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 7.867 | 0.151E-05 | 0.163E-05 | 0.314E-05 | -0.103E-06 | 0.304E-05 | 16.646    | 0.105E-03 |
|       | 0.721E-03 | 0.774E-03 | 0.150E-02 | 0.757E-07  | 0.813E-07 | 0.117E-06 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 7.917 | 0.599E-05 | 0.643E-05 | 0.124E-04 | 0.199E-07 | 0.124E-04 | 16.669    | 0.105E-03 |
|       | 0.357E-02 | 0.384E-02 | 0.741E-02 | 0.375E-06 | 0.403E-06 | 0.778E-06 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 7.967 | 0.179E-04 | 0.192E-04 | 0.370E-04 | 0.166E-06 | 0.372E-04 | 16.728    | 0.105E-03 |
|       | 0.121E-01 | 0.130E-01 | 0.250E-01 | 0.127E-05 | 0.136E-05 | 0.263E-05 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 8.017 | 0.384E-04 | 0.412E-04 | 0.707E-04 | 0.472E-06 | 0.402E-04 | 16.795    | 0.105E-03 |
|       | 0.304E-01 | 0.326E-01 | 0.630E-01 | 0.319E-05 | 0.342E-05 | 0.661E-05 | 0.105E-03 |

|       |           |           |           |           |           |           |           |
|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 8.067 | 0.699E-04 | 0.750E-04 | 0.145E-03 | 0.117E-05 | 0.146E-03 | 16.874    | 0.105E-03 |
|       | 0.636E-01 | 0.683E-01 | 0.132E+00 | 0.669E-05 | 0.717E-05 | 0.139E-04 | 0.105E-03 |

|       |           |           |           |            |           |           |           |
|-------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 8.117 | 0.758E-04 | 0.809E-04 | 0.157E-03 | -0.493E-05 | 0.152E-03 | 16.664    | 0.105E-03 |
|       | 0.997E-01 | 0.107E+00 | 0.206E+00 | 0.105E-04  | 0.112E-04 | 0.217E-04 | 0.105E-03 |

|       |           |           |           |            |           |           |           |
|-------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 8.142 | 0.293E-04 | 0.306E-04 | 0.599E-04 | -0.439E-04 | 0.160E-04 | 15.860    | 0.105E-03 |
|       | 0.107E+00 | 0.114E+00 | 0.221E+00 | 0.112E-04  | 0.120E-04 | 0.232E-04 | 0.105E-03 |

|       |            |            |            |           |            |           |           |
|-------|------------|------------|------------|-----------|------------|-----------|-----------|
| 8.192 | -0.237E-04 | -0.233E-04 | -0.441E-04 | 0.827E-05 | -0.358E-04 | 16.190    | 0.105E-03 |
|       | 0.968E-01  | 0.103E+00  | 0.200E+00  | 0.102E-04 | 0.108E-04  | 0.210E-04 | 0.105E-03 |

|       |            |            |            |            |            |           |           |
|-------|------------|------------|------------|------------|------------|-----------|-----------|
| 8.217 | -0.189E-03 | -0.204E-03 | -0.393E-03 | -0.669E-04 | -0.460E-03 | 13.881    | 0.105E-03 |
|       | 0.519E-01  | 0.544E-01  | 0.106E+00  | 0.545E-05  | 0.571E-05  | 0.112E-04 | 0.105E-03 |

|       |            |            |            |           |            |           |           |
|-------|------------|------------|------------|-----------|------------|-----------|-----------|
| 8.224 | -0.228E-03 | -0.246E-03 | -0.474E-03 | 0.000E+00 | -0.474E-03 | 13.881    | 0.105E-03 |
|       | 0.383E-01  | 0.397E-01  | 0.780E-01  | 0.403E-05 | 0.417E-05  | 0.820E-05 | 0.105E-03 |

B.230 -0.253E-03 -0.272E-03 -0.525E-03 0.443E-04 -0.481E-03 14.798 0.105E-03  
0.233E-01 0.225E-01 0.468E-01 0.247E-05 0.247E-05 0.452E-05 0.105E-03

B.236 -0.230E-03 -0.247E-03 -0.477E-03 0.503E-04 -0.427E-03 17.905 0.105E-03  
0.964E-02 0.880E-02 0.184E-01 0.101E-05 0.924E-06 0.194E-05 0.105E-03

NO CONVERGENCE AT THIS TIME STEP T= 8.236

RESTART

B.236 0.174E-06 -0.174E-06 0.678E-28 0.649E-35 0.678E-20 17.905 0.105E-03  
0.293E-34 0.272E-34 0.565E-34 0.308E-38 0.000E+00 0.544E-38 0.105E-03

B.246 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 17.200 0.000E+00  
0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00

B.336 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 17.200 0.000E+00  
0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00

B.386 0.151E-05 0.163E-05 0.314E-05 -0.103E-06 0.304E-15 16.646 0.105E-03  
0.721E-03 0.774E-03 0.150E-02 0.757E-07 0.813E-07 0.157E-06 0.105E-03

B.476 0.599E-05 0.643E-05 0.124E-04 0.199E-07 0.124E-04 16.669 0.105E-03  
0.357E-02 0.364E-02 0.741E-02 0.375E-06 0.403E-06 0.778E-06 0.105E-03

B.486 0.179E-04 0.192E-04 0.371E-04 0.166E-06 0.372E-04 16.728 0.105E-03  
0.121E-01 0.130E-01 0.250E-01 0.127E-05 0.136E-05 0.203E-05 0.105E-03

B.536 0.384E-04 0.412E-04 0.797E-04 0.472E-06 0.802E-04 16.795 0.105E-03  
0.304E-01 0.326E-01 0.630E-01 0.514E-05 0.342E-05 0.661E-05 0.105E-03

B.586 0.699E-04 0.750E-04 0.145E-03 0.117E-05 0.146E-03 16.874 0.105E-03  
0.637E-01 0.683E-01 0.132E+00 0.669E-05 0.717E-05 0.139E-04 0.105E-03

B.626 0.758E-04 0.809E-04 0.157E-03 -0.493E-05 0.152E-03 16.664 0.105E-03  
0.997E-01 0.107E+00 0.206E+00 0.105E-04 0.112E-04 0.217E-04 0.105E-03

B.661 0.294E-04 0.307E-04 0.601E-04 -0.439E-04 0.162E-04 15.861 0.105E-03  
0.107E+00 0.114E+00 0.221E+00 0.112E-04 0.120E-04 0.232E-04 0.105E-03

B.711 -0.206E-04 -0.232E-04 -0.437E-04 0.826E-05 -0.355E-04 16.191 0.105E-03  
0.965E-01 0.103E+00 0.200E+00 0.102E-04 0.108E-04 0.210E-04 0.105E-03

B.736 -0.189E-03 -0.204E-03 -0.393E-03 -0.671E-04 -0.460E-05 13.881 0.105E-03  
0.526E-01 0.545E-01 0.107E+00 0.547E-05 0.572E-05 0.112E-04 0.105E-03



-217-

|           |            |            |            |            |            |           |           |
|-----------|------------|------------|------------|------------|------------|-----------|-----------|
| 9.255     | -0.188E-03 | -0.203E-03 | -0.391E-03 | -0.674E-04 | -0.459E-03 | 13.884    | 0.105E-03 |
| 0.523E-01 | 0.548E-01  | 0.107E+00  | 0.550E-05  | 0.576E-05  | 0.117E-04  | 0.105E-03 |           |

|           |            |            |            |           |            |           |           |
|-----------|------------|------------|------------|-----------|------------|-----------|-----------|
| 9.261     | -0.225E-03 | -0.243E-03 | -0.469E-03 | 0.109E-04 | -0.458E-03 | 14.012    | 0.105E-03 |
| 0.387E-01 | 0.404E-01  | 0.793E-01  | 0.409E-05  | 0.424E-05 | 0.833E-05  | 0.105E-03 |           |

|           |            |            |            |           |            |           |           |
|-----------|------------|------------|------------|-----------|------------|-----------|-----------|
| 9.267     | -0.250E-03 | -0.269E-03 | -0.519E-03 | 0.399E-04 | -0.479E-03 | 14.011    | 0.105E-03 |
| 0.241E-01 | 0.243E-01  | 0.404E-01  | 0.253E-05  | 0.256E-05 | 0.509E-05  | 0.105E-03 |           |

|           |            |            |            |           |            |           |           |
|-----------|------------|------------|------------|-----------|------------|-----------|-----------|
| 9.274     | -0.227E-03 | -0.244E-03 | -0.471E-03 | 0.540E-04 | -0.416E-03 | 17.921    | 0.105E-03 |
| 0.106E-01 | 0.982E-02  | 0.204E-01  | 0.111E-05  | 0.103E-05 | 0.214E-05  | 0.105E-03 |           |

NO CONVERGENCE AT THIS TIME STEP T= 9.274

PESTART

|           |           |            |           |           |           |           |           |
|-----------|-----------|------------|-----------|-----------|-----------|-----------|-----------|
| 9.274     | 0.182E-06 | -0.182E-06 | 0.339E-20 | 0.000E+00 | 0.339E-20 | 17.921    | 0.000E+00 |
| 0.151E-34 | 0.148E-34 | 0.307E-34  | 0.000E+00 | 0.000E+00 | 0.323E-38 | 0.105E-03 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 9.324     | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
| 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 9.374     | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
| 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |           |

|           |           |           |           |            |           |           |           |
|-----------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 9.424     | 0.151E-05 | 0.163E-05 | 0.314E-05 | -0.103E-06 | 0.304E-05 | 16.641    | 0.105E-03 |
| 0.721E-03 | 0.774E-03 | 0.150E-02 | 0.757E-07 | 0.813E-07  | 0.157E-06 | 0.105E-03 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 9.474     | 0.599E-05 | 0.643E-05 | 0.124E-04 | 0.199E-07 | 0.124E-04 | 16.669    | 0.105E-03 |
| 0.357E-02 | 0.384E-02 | 0.741E-02 | 0.375E-06 | 0.403E-06 | 0.778E-06 | 0.105E-03 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 9.524     | 0.179E-04 | 0.192E-04 | 0.371E-04 | 0.166E-06 | 0.372E-04 | 16.728    | 0.105E-03 |
| 0.121E-01 | 0.130E-01 | 0.250E-01 | 0.127E-05 | 0.130E-05 | 0.263E-05 | 0.105E-03 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 9.574     | 0.384E-04 | 0.412E-04 | 0.797E-04 | 0.472E-06 | 0.402E-04 | 16.795    | 0.105E-03 |
| 0.304E-01 | 0.326E-01 | 0.630E-01 | 0.319E-05 | 0.342E-05 | 0.661E-05 | 0.105E-03 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 9.624     | 0.699E-04 | 0.750E-04 | 0.145E-03 | 0.117E-05 | 0.146E-03 | 16.874    | 0.105E-03 |
| 0.636E-01 | 0.683E-01 | 0.132E+00 | 0.664E-05 | 0.717E-05 | 0.139E-04 | 0.105E-03 |           |

|           |           |           |           |            |           |           |           |
|-----------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 9.674     | 0.761E-04 | 0.813E-04 | 0.157E-03 | -0.487E-05 | 0.152E-03 | 16.666    | 0.105E-03 |
| 0.998E-01 | 0.107E+00 | 0.207E+00 | 0.105E-04 | 0.112E-04  | 0.217E-04 | 0.105E-03 |           |

|           |           |           |           |            |           |           |           |
|-----------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 9.699     | 0.304E-04 | 0.318E-04 | 0.622E-04 | -0.436E-04 | 0.186E-04 | 15.872    | 0.105E-03 |
| 0.107E+00 | 0.115E+00 | 0.222E+00 | 0.113E-04 | 0.120E-04  | 0.233E-04 | 0.105E-03 |           |

9.749 -0.193E-04 -0.218E-04 -0.410E-04 0.809E-05 -0.329E-04 16.193 0.105E-03  
0.975E-01 0.104E+00 0.202E+00 0.103E-04 0.109E-04 0.212E-04 0.105E-03

9.774 -0.181E-03 -0.196E-03 -0.377E-03 -0.665E-04 -0.443E-03 13.983 0.105E-03  
0.54E-01 0.576E-01 0.112E+00 0.577E-05 0.604E-05 0.118E-04 0.105E-03

9.799 -0.183E-03 -0.197E-03 -0.380E-03 0.127E-04 -0.367E-03 16.460 0.105E-03  
0.113E-01 0.107E-01 0.220E-01 0.119E-05 0.112E-05 0.231E-05 0.105E-03

NO CONVERGENCE AT THIS TIME STEP T= 9.799

RESTART

9.799 0.166E-06 -0.166E-06 0.678E-20 0.000E+00 0.676E-20 16.463 0.000E+00  
0.164E-34 0.159E-34 0.328E-34 0.000E+00 0.000E+00 0.345E-38 0.105E-03

9.845 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 17.200 0.000E+00  
0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00

9.899 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 17.203 0.000E+00  
0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00

9.949 0.151E-05 0.163E-05 0.314E-05 -0.103E-06 0.304E-05 16.646 0.105E-03  
0.721E-03 0.774E-03 0.150E-02 0.757E-07 0.813E-07 0.157E-06 0.105E-03

9.999 0.599E-05 0.643E-05 0.124E-04 0.199E-07 0.124E-04 16.669 0.105E-03  
0.357E-02 0.384E-02 0.741E-02 0.375E-06 0.403E-06 0.778E-06 0.105E-03

10.049 0.179E-04 0.192E-04 0.371E-04 0.166E-06 0.372E-04 16.728 0.105E-03  
0.121E-01 0.130E-01 0.250E-01 0.127E-05 0.136E-05 0.243E-05 0.105E-03

10.099 0.384E-04 0.412E-04 0.797E-04 0.472E-06 0.802E-04 16.795 0.105E-03  
0.364E-01 0.326E-01 0.630E-01 0.319E-05 0.342E-05 0.661E-05 0.105E-03

10.149 0.699E-04 0.756E-04 0.144E-03 0.117E-05 0.146E-03 16.874 0.105E-03  
0.633E-01 0.683E-01 0.132E+00 0.669E-05 0.717E-05 0.139E-04 0.105E-03

10.199 0.764E-04 0.815E-04 0.158E-03 -0.483E-05 0.153E-03 16.668 0.105E-03  
0.100E+00 0.107E+00 0.207E+00 0.105E-04 0.112E-04 0.218E-04 0.105E-03

10.274 0.320E-04 0.335E-04 0.655E-04 -0.44E-04 0.231E-04 15.894 0.105E-03  
0.108E+00 0.115E+00 0.223E+00 0.113E-04 0.121E-04 0.234E-04 0.105E-03

10.274 -0.178E-04 -0.202E-04 -0.380E-04 0.753E-05 -0.305E-04 16.192 0.105E-03  
0.991E-01 0.105E+00 0.205E+00 0.104E-04 0.111E-04 0.215E-04 0.105E-03

10.299 -0.174E-03 -0.189E-03 -0.363E-03 -0.670E-04 -0.430E-03 14.065 0.105E-03  
0.574E-01 0.605E-01 0.118E+00 0.606E-05 0.636E-05 0.114E-04 0.105E-03

10.324 -0.191E-03 -0.205E-03 -0.396E-03 0.130E-04 -0.383E-03 16.235 0.105E-03  
0.123E-01 0.117E-01 0.240E-01 0.129E-05 0.123E-05 0.242E-05 0.105E-03

NO CONVERGENCE AT THIS TIME STEP T=10.324

RESTART

10.324 0.201E-06 -0.201E-06 0.339E-20 0.430E-35 0.339E-20 16.235 0.000E+00  
0.193E-34 0.185E-34 0.379E-34 0.000E+00 0.000E+00 0.398E-38 0.105E-03

10.374 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 17.200 0.000E+00  
0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00

10.424 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 17.200 0.000E+00  
0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00

10.474 0.151E-05 0.163E-05 0.314E-05 -0.103E-07 0.304E-05 16.646 0.105E-03  
0.721E-03 0.774E-03 0.150E-02 0.757E-07 0.813E-07 0.157E-06 0.105E-03

10.524 0.559E-05 0.643E-05 0.124E-04 0.194E-07 0.124E-04 16.669 0.105E-03  
0.357E-02 0.384E-02 0.741E-02 0.375E-06 0.403E-06 0.778E-06 0.105E-03

10.574 0.179E-04 0.192E-04 0.371E-04 0.166E-06 0.372E-04 16.728 0.105E-03  
0.121E-01 0.130E-01 0.250E-01 0.127E-05 0.136E-05 0.263E-05 0.105E-03

10.624 0.384E-04 0.412E-04 0.797E-04 0.472E-06 0.802E-04 16.795 0.105E-03  
0.304E-01 0.326E-01 0.630E-01 0.319E-05 0.342E-05 0.661E-05 0.105E-03

10.674 0.699E-04 0.750E-04 0.145E-03 0.117E-05 0.146E-03 16.874 0.105E-03  
0.636E-01 0.683E-01 0.132E+00 0.669E-05 0.717E-05 0.139E-04 0.105E-03

10.699 0.924E-04 0.100E-03 0.193E-03 0.550E-05 0.159E-03 17.002 0.105E-03  
0.858E-01 0.921E-01 0.178E+00 0.902E-05 0.967E-05 0.187E-04 0.105E-03

10.724 0.576E-04 0.611E-04 0.119E-03 -0.501E-04 0.686E-04 16.046 0.105E-03  
0.995E-01 0.107E+00 0.206E+00 0.105E-04 0.112E-04 0.217E-04 0.105E-03

10.774 -0.457E-06 -0.148E-05 -0.194E-05 0.217E-05 0.235E-06 16.129 0.105E-03  
0.995E-01 0.105E+00 0.205E+00 0.104E-04 0.111E-04 0.216E-04 0.105E-03

10.799 -0.159E-03 -0.173E-03 -0.332E-03 -0.714E-04 -0.404E-03 14.028 0.105E-03  
0.614E-01 0.648E-01 0.126E+00 0.645E-05 0.681E-05 0.133E-04 0.105E-03

|           |            |            |            |           |            |           |           |
|-----------|------------|------------|------------|-----------|------------|-----------|-----------|
| 10.824    | -0.199E-03 | -0.214E-03 | -0.413E-03 | 0.138E-04 | -0.400E-03 | 15.877    | 0.105E-03 |
| 0.141E-01 | 0.139E-01  | 0.280E-01  | 0.148E-05  | 0.146E-05 | 0.294E-05  | 0.105E-03 |           |

|           |            |            |            |           |            |           |           |
|-----------|------------|------------|------------|-----------|------------|-----------|-----------|
| 10.830    | -0.149E-03 | -0.161E-03 | -0.310E-03 | 0.299E-04 | -0.280E-03 | 19.746    | 0.105E-03 |
| 0.524E-02 | 0.433E-02  | 0.956E-02  | 0.550E-06  | 0.455E-06 | 0.100E-05  | 0.105E-03 |           |

NO CONVERGENCE AT THIS TIME STEP T=10.830

RESTART

|           |           |            |           |           |           |           |           |
|-----------|-----------|------------|-----------|-----------|-----------|-----------|-----------|
| 10.830    | 0.142E-06 | -0.142E-06 | 0.339E-20 | 0.617E-35 | 0.339E-20 | 19.746    | 0.105E-03 |
| 0.321E-34 | 0.273E-34 | 0.594E-34  | 0.537E-38 | 0.000E+00 | 0.624E-38 | 0.105E-03 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 10.880    | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
| 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 10.930    | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 17.200    | 0.000E+00 |
| 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 | 0.000E+00 |           |

|           |           |           |           |            |           |           |           |
|-----------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 10.980    | 0.151E-04 | 0.163E-05 | 0.314E-05 | -0.103E-06 | 0.304E-05 | 16.646    | 0.105E-03 |
| 0.721E-03 | 0.774E-03 | 0.150E-02 | 0.757E-07 | 0.813E-07  | 0.157E-06 | 0.105E-03 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 11.030    | 0.599E-05 | 0.643E-05 | 0.124E-04 | 0.199E-07 | 0.124E-04 | 16.669    | 0.105E-03 |
| 0.357E-02 | 0.364E-02 | 0.741E-02 | 0.375E-06 | 0.403E-06 | 0.71E-06  | 0.105E-03 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 11.080    | 0.179E-04 | 0.192E-04 | 0.371E-04 | 0.166E-06 | 0.372E-04 | 16.728    | 0.105E-03 |
| 0.121E-01 | 0.130E-01 | 0.250E-01 | 0.127E-05 | 0.136E-05 | 0.263E-05 | 0.105E-03 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 11.130    | 0.384E-04 | 0.412E-04 | 0.797E-04 | 0.472E-06 | 0.402E-04 | 16.705    | 0.105E-03 |
| 0.304E-01 | 0.326E-01 | 0.630E-01 | 0.319E-05 | 0.342E-05 | 0.671E-05 | 0.105E-03 |           |

|          |           |           |           |           |           |           |           |
|----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 11.180   | 0.699E-04 | 0.750E-04 | 0.145E-03 | 0.117E-05 | 0.146E-03 | 16.874    | 0.105E-03 |
| 0.63E-01 | 0.683E-01 | 0.132E+00 | 0.669E-05 | 0.717E-05 | 0.139E-04 | 0.105E-03 |           |

|           |           |           |           |           |           |           |           |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| 11.205    | 0.934E-04 | 0.100E-03 | 0.193E-03 | 0.550E-05 | 0.199E-03 | 17.003    | 0.105E-03 |
| 0.858E-01 | 0.921E-01 | 0.178E+00 | 0.902E-05 | 0.947E-05 | 0.187E-04 | 0.105E-03 |           |

|           |           |           |           |            |           |           |           |
|-----------|-----------|-----------|-----------|------------|-----------|-----------|-----------|
| 11.230    | 0.575E-04 | 0.611E-04 | 0.119E-03 | -0.502E-04 | 0.683E-04 | 16.045    | 0.105E-03 |
| 0.995E-01 | 0.107E+00 | 0.206E+00 | 0.105E-04 | 0.112E-04  | 0.217E-04 | 0.105E-03 |           |

|          |            |            |            |           |            |           |           |
|----------|------------|------------|------------|-----------|------------|-----------|-----------|
| 11.280   | -0.643E-06 | -0.168E-05 | -0.232E-05 | 0.218E-05 | -0.144E-06 | 16.128    | 0.105E-03 |
| 0.99E-01 | 0.106E+00  | 0.205E+00  | 0.104E-04  | 0.111E-04 | 0.215E-04  | 0.105E-03 |           |

|           |            |            |            |            |            |           |           |
|-----------|------------|------------|------------|------------|------------|-----------|-----------|
| 11.305    | -0.159E-03 | -0.173E-03 | -0.332E-03 | -0.712E-04 | -0.403E-03 | 14.033    | 0.105E-03 |
| 0.613E-01 | 0.647E-01  | 0.126E+00  | 0.644E-05  | 0.660E-05  | 0.132E-04  | 0.105E-03 |           |

11.330 -0.199E-03 -0.214E-03 -0.414E-03 0.130E-04 -0.401E-03 15.867 0.105E-03  
0.137E-01 0.137E-01 0.276E-01 0.146E-05 0.144E-05 0.290E-05 0.105E-03

11.336 -0.148E-03 -0.159E-03 -0.307E-03 0.301E-04 -0.277E-03 19.871 0.105E-03  
0.512E-02 0.421E-02 0.934E-02 0.539E-06 0.443E-06 0.942E-06 0.105E-03

11.337 -0.139E-03 -0.150E-03 -0.289E-03 0.487E-04 -0.240E-03 21.057 0.105E-03  
0.409E-02 0.310E-02 0.719E-02 0.430E-06 0.325E-06 0.775E-06 0.105E-03

NO CONVERGENCE AT THIS TIME STEP T=11.337

RESTART

11.337 0.136E-06 -0.134E-06 0.339E-20 0.425E-35 0.339E-20 21.057 0.000E+00  
0.241E-34 0.184E-34 0.425E-34 0.000E+00 0.000E+00 0.446E-38 0.105E-03

11.387 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 17.200 0.000E+00  
0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00

11.437 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 17.200 0.000E+00  
0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00

11.487 0.151E-05 0.163E-05 0.314E-05 -0.103E-06 0.324E-05 16.646 0.105E-03  
0.721E-03 0.774E-03 0.150E-02 0.757E-07 0.813E-07 0.147E-06 0.105E-03

11.537 0.599E-05 0.643E-05 0.124E-04 0.199E-07 0.124E-04 16.669 0.105E-03  
0.357E-02 0.384E-02 0.741E-02 0.375E-06 0.403E-06 0.770E-06 0.105E-03

11.587 0.179E-04 0.192E-04 0.371E-04 0.166E-06 0.372E-04 16.728 0.105E-03  
0.121E-01 0.130E-01 0.250E-01 0.127E-05 0.134E-05 0.243E-05 0.105E-03

11.637 0.384E-04 0.412E-04 0.797E-04 0.472E-06 0.802E-04 16.795 0.105E-03  
0.304E-01 0.376E-01 0.630E-01 0.319E-05 0.342E-05 0.661E-05 0.105E-03

11.687 0.699E-04 0.750E-04 0.145E-03 0.117E-05 0.146E-03 16.874 0.105E-03  
0.630E-01 0.683E-01 0.132E+00 0.669E-05 0.717E-05 0.139E-04 0.105E-03

11.712 0.934E-04 0.100E-03 0.193E-03 0.553E-05 0.199E-03 17.003 0.105E-03  
0.859E-01 0.921E-01 0.178E+00 0.902E-05 0.967E-05 0.187E-04 0.105E-03

11.737 0.733E-04 0.780E-04 0.151E-03 -0.349E-04 0.116E-03 16.302 0.105E-03  
0.103E+00 0.111E+00 0.214E+00 0.109E-04 0.116E-04 0.225E-04 0.105E-03

11.762 0.222E-04 0.229E-04 0.451E-04 -0.289E-04 0.163E-04 15.784 0.105E-03  
0.109E+00 0.116E+00 0.225E+00 0.114E-04 0.122E-04 0.236E-04 0.105E-03

11.812 -0.272E-04 -0.304E-04 -0.576E-04 0.102E-04 -0.474E-04 16.194 0.105E-03  
 0.951E-01 0.102E+00 0.197E+00 0.101E-04 0.107E-04 0.207E-04 0.105E-03

11.837 -0.190E-03 -0.205E-03 -0.395E-03 -0.622E-04 -0.457E-03 13.968 0.105E-03  
 0.501E-01 0.528E-01 0.103E+00 0.531E-05 0.554E-05 0.108E-04 0.105E-03

11.887 -0.973E-04 -0.103E-03 -0.201E-03 0.288E-05 -0.198E-03 17.249 0.105E-03  
 0.422E-02 0.357E-02 0.779E-02 0.443E-06 0.375E-06 0.818E-06 0.105E-03

NO CONVERGENCE AT THIS TIME STEP T=11.887

RESTART

11.887 -0.546E-06 0.546E-06 0.508E-20 0.458E-35 0.508E-20 17.249 0.000E+00  
 0.251E-34 0.226E-34 0.471E-34 0.000E+00 0.000E+00 0.445E-34 0.105E-03

11.927 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 17.200 0.000E+00  
 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00

11.947 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 17.200 0.000E+00  
 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00

12.037 0.151E-05 0.163E-05 0.314E-05 -0.103E-06 0.304E-05 16.646 0.105E-03  
 0.771E-03 0.774E-03 0.150E-02 0.757E-07 0.813E-07 0.117E-06 0.105E-03

12.087 0.599E-05 0.643E-05 0.124E-04 0.199E-07 0.124E-04 16.669 0.105E-03  
 0.357E-02 0.364E-02 0.741E-02 0.375E-06 0.403E-06 0.778E-06 0.105E-03

12.137 0.179E-04 0.192E-04 0.371E-04 0.166E-06 0.372E-04 16.728 0.105E-03  
 0.121E-01 0.130E-01 0.250E-01 0.127E-05 0.136E-05 0.263E-05 0.105E-03

12.187 0.384E-04 0.412E-04 0.797E-04 0.472E-06 0.802E-04 16.795 0.105E-03  
 0.304E-01 0.326E-01 0.630E-01 0.319E-05 0.342E-05 0.661E-05 0.105E-03

TRANSIENT TEMPERATURE PROFILES

0.000 225.000 140.000 140.000 140.000 140.000  
 140.000 140.000 140.000

0.050 218.468 140.120 140.000 140.000 140.000  
 140.000 140.000 140.000

0.100 218.468 140.514 140.001 140.000 140.000  
 140.000 140.000 140.000

0.150 218.473 141.678 140.008 140.000 140.000  
 140.000

|         |                  |                    |                    |         |         |         |
|---------|------------------|--------------------|--------------------|---------|---------|---------|
| 140.000 | 140.000          | 140.000            |                    |         |         |         |
| 140.000 | 0.200<br>140.000 | 218.513<br>140.000 | 144.128<br>140.000 | 140.062 | 140.000 | 140.000 |
| 140.000 | 0.250<br>140.000 | 218.736<br>140.000 | 148.491<br>140.000 | 140.300 | 140.004 | 140.000 |
| 140.000 | 0.275<br>140.000 | 183.149<br>140.000 | 147.737<br>134.477 | 140.273 | 140.004 | 140.000 |
| 140.000 | 0.281<br>139.885 | 179.659<br>133.310 | 147.581<br>133.310 | 140.267 | 140.003 | 140.000 |
| 140.000 | 0.281<br>139.885 | 205.917<br>133.310 | 147.581<br>133.310 | 140.267 | 140.003 | 140.000 |
| 140.000 | 0.331<br>139.885 | 220.161<br>133.310 | 147.581<br>133.310 | 140.267 | 140.003 | 140.000 |
| 140.000 | 0.381<br>139.885 | 218.468<br>133.317 | 147.683<br>133.317 | 140.277 | 140.004 | 140.000 |
| 140.000 | 0.431<br>139.885 | 218.468<br>133.342 | 148.039<br>133.342 | 140.315 | 140.005 | 140.000 |
| 140.000 | 0.481<br>139.887 | 218.473<br>133.415 | 149.091<br>133.415 | 140.430 | 140.010 | 140.000 |
| 140.000 | 0.531<br>139.891 | 218.513<br>133.570 | 151.305<br>133.570 | 140.706 | 140.023 | 140.000 |
| 140.000 | 0.581<br>139.897 | 218.737<br>133.848 | 155.253<br>133.848 | 141.329 | 140.063 | 140.000 |
| 139.981 | 0.606<br>139.356 | 188.752<br>129.261 | 154.099<br>129.261 | 141.224 | 140.058 | 140.000 |
| 139.989 | 0.607<br>139.359 | 187.570<br>129.271 | 154.052<br>129.271 | 141.220 | 140.058 | 140.000 |
| 139.989 | 0.607<br>139.359 | 197.656<br>129.071 | 154.052<br>129.071 | 141.220 | 140.058 | 140.000 |
| 139.989 | 0.657<br>139.359 | 220.161<br>129.071 | 154.052<br>129.071 | 141.220 | 140.058 | 140.000 |



|         |       |         |         |         |         |         |         |
|---------|-------|---------|---------|---------|---------|---------|---------|
| 139.989 | 0.707 | 218.468 | 154.145 | 141.238 | 140.060 | 140.002 | 140.000 |
|         |       | 139.310 | 129.082 |         |         |         |         |
| 139.989 | 0.757 | 218.468 | 154.469 | 141.303 | 140.066 | 140.002 | 140.000 |
|         |       | 139.313 | 129.120 |         |         |         |         |
| 139.990 | 0.807 | 218.473 | 155.425 | 141.500 | 140.084 | 140.003 | 140.000 |
|         |       | 139.372 | 129.235 |         |         |         |         |
| 139.970 | 0.857 | 218.513 | 157.437 | 141.944 | 140.129 | 140.006 | 140.000 |
|         |       | 139.392 | 129.478 |         |         |         |         |
| 139.990 | 0.907 | 218.737 | 161.029 | 142.855 | 140.236 | 140.013 | 140.000 |
|         |       | 139.427 | 129.915 |         |         |         |         |
| 139.980 | 0.942 | 193.132 | 150.729 | 142.668 | 140.220 | 140.012 | 140.000 |
|         |       | 138.747 | 126.163 |         |         |         |         |
| 139.922 | 0.938 | 189.011 | 159.326 | 142.610 | 140.215 | 140.012 | 139.999 |
|         |       | 138.450 | 124.992 |         |         |         |         |
| 139.922 | 0.938 | 200.277 | 159.326 | 142.610 | 140.215 | 140.012 | 139.999 |
|         |       | 138.450 | 124.992 |         |         |         |         |
| 139.922 | 0.988 | 220.161 | 159.326 | 142.610 | 140.215 | 140.012 | 139.999 |
|         |       | 138.450 | 124.992 |         |         |         |         |
| 139.922 | 1.038 | 218.468 | 159.412 | 142.634 | 140.218 | 140.012 | 139.999 |
|         |       | 138.452 | 125.007 |         |         |         |         |
| 139.922 | 1.088 | 218.468 | 159.709 | 142.718 | 140.231 | 140.013 | 139.999 |
|         |       | 138.459 | 125.057 |         |         |         |         |
| 139.923 | 1.138 | 218.473 | 160.586 | 142.972 | 140.268 | 140.016 | 139.999 |
|         |       | 138.461 | 125.208 |         |         |         |         |
| 139.976 | 1.188 | 218.513 | 162.435 | 143.534 | 140.354 | 140.024 | 139.999 |
|         |       | 138.527 | 125.525 |         |         |         |         |
| 139.930 | 1.238 | 218.737 | 165.737 | 144.647 | 140.541 | 140.044 | 140.001 |
|         |       | 138.609 | 126.100 |         |         |         |         |
| 139.934 | 1.288 | 217.973 | 171.205 | 145.825 | 140.771 | 140.071 | 140.003 |
|         |       | 138.683 | 126.624 |         |         |         |         |

|         |                  |                    |         |         |         |         |         |
|---------|------------------|--------------------|---------|---------|---------|---------|---------|
| 139.762 | 1.313<br>137.028 | 172.765<br>119.776 | 162.785 | 145.132 | 140.675 | 140.062 | 139.994 |
| 139.762 | 1.313<br>137.028 | 187.776<br>119.766 | 162.785 | 145.132 | 140.675 | 140.062 | 139.994 |
| 139.762 | 1.363<br>137.028 | 220.161<br>119.766 | 162.785 | 145.132 | 140.675 | 140.062 | 139.994 |
| 139.763 | 1.413<br>137.032 | 218.468<br>119.784 | 162.866 | 145.156 | 140.681 | 140.063 | 139.994 |
| 139.764 | 1.463<br>137.046 | 218.468<br>119.849 | 163.145 | 145.245 | 140.704 | 140.066 | 139.994 |
| 139.777 | 1.513<br>137.066 | 218.473<br>120.042 | 163.971 | 145.513 | 140.771 | 140.076 | 139.995 |
| 139.775 | 1.563<br>137.172 | 218.513<br>120.450 | 165.712 | 146.102 | 140.923 | 140.098 | 139.998 |
| 139.784 | 1.613<br>137.325 | 218.738<br>121.189 | 168.623 | 147.258 | 141.228 | 140.146 | 140.004 |
| 139.755 | 1.638<br>137.407 | 219.000<br>121.588 | 170.471 | 147.970 | 141.427 | 140.182 | 140.008 |
| 139.565 | 1.663<br>135.885 | 186.446<br>117.144 | 168.307 | 147.340 | 141.307 | 140.165 | 139.988 |
| 139.449 | 1.670<br>135.295 | 183.892<br>115.796 | 167.647 | 147.151 | 141.271 | 140.160 | 139.975 |
| 139.449 | 1.670<br>135.295 | 195.742<br>115.796 | 167.647 | 147.151 | 141.271 | 140.160 | 139.975 |
| 139.449 | 1.720<br>135.295 | 220.161<br>115.796 | 167.647 | 147.151 | 141.271 | 140.160 | 139.975 |
| 139.450 | 1.770<br>135.301 | 218.468<br>115.817 | 167.721 | 147.186 | 141.280 | 140.161 | 139.975 |
| 139.453 | 1.820<br>135.322 | 218.468<br>115.890 | 167.976 | 147.283 | 141.309 | 140.167 | 139.976 |

|         |                  |                    |         |         |         |         |         |
|---------|------------------|--------------------|---------|---------|---------|---------|---------|
| 139.461 | 1.870<br>135.384 | 218.473<br>116.108 | 168.730 | 147.592 | 141.399 | 140.184 | 139.979 |
| 139.477 | 1.920<br>135.514 | 218.513<br>116.570 | 170.319 | 148.267 | 141.596 | 140.223 | 139.985 |
| 139.507 | 1.970<br>135.748 | 218.738<br>117.467 | 173.161 | 149.568 | 141.990 | 140.304 | 139.999 |
| 139.535 | 2.020<br>135.982 | 217.984<br>118.191 | 178.270 | 150.912 | 142.421 | 140.480 | 140.017 |
| 139.043 | 2.045<br>132.761 | 180.382<br>112.787 | 170.245 | 149.860 | 142.171 | 140.352 | 139.957 |
| 138.921 | 2.051<br>133.617 | 178.904<br>111.515 | 169.589 | 149.613 | 142.113 | 140.340 | 139.929 |
| 138.921 | 2.051<br>133.087 | 200.281<br>111.515 | 169.589 | 149.613 | 142.113 | 140.340 | 139.929 |
| 138.921 | 2.101<br>133.087 | 220.161<br>111.515 | 169.589 | 149.613 | 142.113 | 140.340 | 139.929 |
| 138.923 | 2.151<br>133.095 | 218.468<br>111.537 | 169.661 | 149.641 | 142.123 | 140.342 | 139.930 |
| 138.928 | 2.201<br>133.125 | 218.468<br>111.619 | 169.906 | 149.742 | 142.161 | 140.351 | 139.932 |
| 138.943 | 2.251<br>133.211 | 218.473<br>111.860 | 170.632 | 150.043 | 142.274 | 140.378 | 139.938 |
| 138.975 | 2.301<br>133.305 | 218.513<br>112.372 | 172.161 | 150.701 | 142.523 | 140.439 | 139.952 |
| 139.032 | 2.351<br>133.704 | 218.738<br>113.302 | 174.897 | 151.968 | 143.005 | 140.562 | 139.981 |
| 139.079 | 2.370<br>133.584 | 219.144<br>114.053 | 177.045 | 153.091 | 143.445 | 140.682 | 140.009 |
| 130.715 | 2.401<br>132.500 | 193.942<br>111.156 | 175.333 | 152.402 | 143.247 | 140.634 | 139.943 |
|         | 2.407            | 190.934            | 174.744 | 152.167 | 143.180 | 140.616 | 139.911 |

|         |                  |                    |         |         |         |         |         |
|---------|------------------|--------------------|---------|---------|---------|---------|---------|
| 138.556 | 132.010          | 110.170            |         |         |         |         |         |
| 138.353 | 2.414<br>131.332 | 182.264<br>1.9.001 | 174.043 | 151.888 | 143.100 | 140.594 | 139.869 |
| 138.158 | 2.420<br>130.710 | 186.456<br>167.979 | 173.426 | 151.643 | 143.031 | 140.574 | 139.827 |
| 138.158 | 2.420<br>130.710 | 208.216<br>167.979 | 173.426 | 151.643 | 143.031 | 140.574 | 139.827 |
| 138.158 | 2.470<br>130.710 | 220.161<br>167.979 | 173.426 | 151.643 | 143.031 | 140.574 | 139.827 |
| 138.160 | 2.520<br>130.721 | 218.468<br>178.093 | 173.492 | 151.674 | 143.043 | 140.577 | 139.828 |
| 138.169 | 2.570<br>130.758 | 218.468<br>178.088 | 173.719 | 151.784 | 143.086 | 140.590 | 139.832 |
| 138.143 | 2.620<br>130.869 | 218.474<br>168.342 | 174.387 | 152.111 | 143.216 | 140.627 | 139.843 |
| 138.246 | 2.670<br>131.103 | 218.513<br>168.883 | 175.797 | 152.824 | 143.500 | 140.710 | 139.868 |
| 138.342 | 2.720<br>131.525 | 218.739<br>169.867 | 178.319 | 154.180 | 144.051 | 140.874 | 139.918 |
| 138.358 | 2.745<br>131.768 | 219.020<br>110.447 | 179.763 | 155.043 | 144.413 | 140.988 | 139.952 |
| 137.996 | 2.770<br>130.474 | 197.384<br>168.150 | 178.263 | 154.197 | 144.205 | 140.925 | 139.858 |
| 137.333 | 2.795<br>128.498 | 189.697<br>164.953 | 176.150 | 153.495 | 143.915 | 140.831 | 139.693 |
| 137.330 | 2.795<br>128.498 | 205.041<br>164.953 | 176.150 | 153.495 | 143.915 | 140.831 | 139.693 |
| 137.330 | 2.845<br>128.498 | 220.161<br>164.953 | 176.150 | 153.495 | 143.915 | 140.831 | 139.693 |
| 137.333 | 2.895<br>128.510 | 218.468<br>164.978 | 176.212 | 153.527 | 143.928 | 140.835 | 139.695 |

|         |       |         |         |         |         |         |         |
|---------|-------|---------|---------|---------|---------|---------|---------|
| 137.345 | 2.945 | 218.468 | 176.425 | 153.641 | 143.976 | 140.851 | 139.700 |
|         |       | 128.555 | 105.067 |         |         |         |         |
| 137.350 | 2.995 | 218.473 | 177.053 | 153.982 | 144.121 | 140.897 | 139.717 |
|         |       | 128.686 | 105.330 |         |         |         |         |
| 137.455 | 3.045 | 218.513 | 178.377 | 154.719 | 144.436 | 141.000 | 139.755 |
|         |       | 128.964 | 105.890 |         |         |         |         |
| 137.591 | 3.095 | 218.735 | 180.748 | 156.117 | 145.044 | 141.203 | 139.829 |
|         |       | 129.406 | 106.913 |         |         |         |         |
| 137.719 | 3.145 | 218.734 | 185.441 | 157.528 | 145.678 | 141.423 | 139.908 |
|         |       | 129.921 | 107.882 |         |         |         |         |
| 136.947 | 3.170 | 189.203 | 179.150 | 156.363 | 145.256 | 141.273 | 139.690 |
|         |       | 127.744 | 104.319 |         |         |         |         |
| 136.646 | 3.176 | 187.693 | 178.406 | 155.990 | 145.126 | 141.221 | 139.601 |
|         |       | 126.979 | 103.234 |         |         |         |         |
| 136.190 | 3.201 | 186.386 | 177.348 | 155.478 | 144.942 | 141.145 | 139.461 |
|         |       | 125.859 | 101.704 |         |         |         |         |
| 136.150 | 3.201 | 211.620 | 177.348 | 155.478 | 144.942 | 141.145 | 139.461 |
|         |       | 125.859 | 101.704 |         |         |         |         |
| 136.190 | 3.251 | 220.161 | 177.348 | 155.478 | 144.942 | 141.145 | 139.461 |
|         |       | 125.859 | 101.704 |         |         |         |         |
| 136.195 | 3.301 | 218.468 | 177.408 | 155.509 | 144.957 | 141.150 | 139.464 |
|         |       | 125.673 | 101.730 |         |         |         |         |
| 136.211 | 3.351 | 218.468 | 177.615 | 155.619 | 145.010 | 141.169 | 139.472 |
|         |       | 125.925 | 101.821 |         |         |         |         |
| 136.260 | 3.401 | 218.473 | 178.225 | 155.947 | 145.168 | 141.227 | 139.498 |
|         |       | 126.079 | 102.091 |         |         |         |         |
| 136.363 | 3.451 | 218.513 | 179.512 | 156.660 | 145.513 | 141.353 | 139.553 |
|         |       | 126.405 | 102.666 |         |         |         |         |
| 136.552 | 3.501 | 218.739 | 181.817 | 158.010 | 146.172 | 141.599 | 139.659 |
|         |       | 126.993 | 103.718 |         |         |         |         |

|         |                  |                    |         |         |         |         |         |
|---------|------------------|--------------------|---------|---------|---------|---------|---------|
| 136.728 | 3.551<br>127.534 | 218.404<br>134.706 | 186.408 | 159.358 | 146.842 | 141.857 | 139.769 |
| 135.869 | 3.576<br>125.401 | 191.173<br>101.573 | 180.814 | 158.188 | 146.376 | 141.662 | 139.485 |
| 135.533 | 3.582<br>124.638 | 189.332<br>100.575 | 180.090 | 157.810 | 146.225 | 141.593 | 139.369 |
| 135.156 | 3.589<br>123.605 | 187.520<br>99.521  | 179.319 | 157.409 | 146.065 | 141.516 | 139.236 |
| 135.156 | 3.589<br>123.805 | 201.112<br>99.521  | 179.319 | 157.409 | 146.065 | 141.516 | 139.236 |
| 135.156 | 3.639<br>123.805 | 220.161<br>99.521  | 179.319 | 157.409 | 146.065 | 141.516 | 139.236 |
| 135.102 | 3.689<br>123.821 | 218.464<br>99.547  | 179.376 | 157.440 | 146.081 | 141.522 | 139.239 |
| 135.112 | 3.739<br>123.878 | 218.464<br>99.638  | 179.573 | 157.550 | 146.138 | 141.545 | 139.251 |
| 135.243 | 3.789<br>124.047 | 218.472<br>99.910  | 180.154 | 157.879 | 146.308 | 141.614 | 139.285 |
| 135.372 | 3.839<br>124.405 | 218.513<br>100.469 | 181.379 | 158.591 | 146.678 | 141.764 | 139.360 |
| 135.608 | 3.689<br>125.653 | 218.734<br>101.549 | 183.574 | 159.936 | 147.302 | 142.054 | 139.502 |
| 135.833 | 3.939<br>125.672 | 218.300<br>102.566 | 188.125 | 161.301 | 148.107 | 142.361 | 139.649 |
| 134.939 | 3.964<br>123.633 | 192.790<br>99.762  | 182.722 | 160.143 | 147.602 | 142.123 | 139.314 |
| 133.990 | 3.989<br>121.630 | 189.766<br>97.259  | 180.827 | 159.090 | 147.142 | 141.887 | 138.947 |
| 133.990 | 3.989<br>121.630 | 207.268<br>97.259  | 180.827 | 159.090 | 147.142 | 141.887 | 138.947 |

|         |                  |                    |                    |         |         |         |         |
|---------|------------------|--------------------|--------------------|---------|---------|---------|---------|
| 133.990 | 4.039<br>121.620 | 220.141<br>218.468 | 180.827<br>97.259  | 159.090 | 147.142 | 141.887 | 138.947 |
| 133.937 | 4.089<br>121.647 | 218.468<br>218.468 | 180.882<br>97.285  | 159.121 | 147.159 | 141.895 | 138.951 |
| 134.022 | 4.139<br>121.700 | 218.468<br>218.468 | 181.071<br>97.376  | 159.230 | 147.219 | 141.921 | 138.966 |
| 134.096 | 4.189<br>121.893 | 218.473<br>218.473 | 181.630<br>97.649  | 159.556 | 147.399 | 142.000 | 139.010 |
| 134.253 | 4.239<br>122.283 | 218.413<br>218.413 | 182.809<br>98.231  | 160.262 | 147.787 | 142.173 | 139.105 |
| 134.526 | 4.289<br>122.957 | 218.727<br>218.727 | 184.819<br>99.246  | 161.532 | 148.490 | 142.489 | 139.278 |
| 134.801 | 4.339<br>123.626 | 218.468<br>218.468 | 189.318<br>100.273 | 162.877 | 149.243 | 142.836 | 139.464 |
| 132.939 | 4.389<br>119.735 | 189.817<br>189.817 | 174.136<br>95.241  | 160.605 | 148.176 | 142.274 | 138.687 |
| 132.939 | 4.389<br>119.735 | 203.419<br>203.419 | 179.136<br>95.241  | 160.605 | 148.176 | 142.274 | 138.687 |
| 132.939 | 4.439<br>119.735 | 220.161<br>220.161 | 179.136<br>95.241  | 160.605 | 148.176 | 142.274 | 138.687 |
| 132.947 | 4.489<br>119.733 | 218.468<br>218.468 | 179.194<br>95.267  | 160.631 | 148.193 | 142.282 | 138.692 |
| 132.976 | 4.539<br>119.820 | 218.468<br>218.468 | 179.392<br>95.359  | 160.725 | 148.256 | 142.312 | 138.710 |
| 133.062 | 4.589<br>120.016 | 218.473<br>218.473 | 179.975<br>95.633  | 161.004 | 148.442 | 142.401 | 138.764 |
| 133.244 | 4.639<br>120.433 | 218.513<br>218.513 | 181.207<br>96.218  | 161.610 | 148.844 | 142.594 | 138.880 |
| 133.577 | 4.689<br>121.191 | 218.744<br>218.744 | 183.411<br>97.291  | 162.769 | 149.598 | 142.963 | 139.099 |
|         | 4.739            | 218.317            | 187.963            | 163.956 | 150.356 | 143.345 | 139.322 |

|         |                  |                   |         |         |         |                    |
|---------|------------------|-------------------|---------|---------|---------|--------------------|
| 133.895 | 121.963          | 98.322            |         |         |         |                    |
| 132.837 | 4.764<br>119.827 | 192.700<br>95.792 | 182.823 | 162.758 | 149.738 | 142.991<br>138.844 |
| 132.439 | 4.770<br>119.088 | 190.944<br>94.966 | 182.206 | 162.358 | 149.531 | 142.863<br>138.659 |
| 131.997 | 4.776<br>118.289 | 189.602<br>94.098 | 181.549 | 161.933 | 149.310 | 142.724<br>138.453 |
| 131.637 | 4.783<br>117.655 | 188.734<br>93.427 | 181.035 | 161.602 | 149.137 | 142.612<br>138.284 |
| 131.637 | 4.783<br>117.655 | 213.086<br>93.427 | 181.035 | 161.602 | 149.137 | 142.612<br>138.284 |
| 131.637 | 4.833<br>117.655 | 229.161<br>93.427 | 181.035 | 161.602 | 149.137 | 142.612<br>138.284 |
| 131.647 | 4.663<br>117.674 | 218.441<br>93.453 | 181.090 | 161.630 | 149.155 | 142.621<br>138.290 |
| 131.640 | 4.933<br>117.745 | 218.478<br>93.544 | 161.278 | 161.728 | 149.218 | 142.654<br>138.312 |
| 131.779 | 4.983<br>117.953 | 218.475<br>93.815 | 181.833 | 162.020 | 149.405 | 142.752<br>138.377 |
| 131.900 | 5.033<br>118.365 | 218.513<br>94.395 | 183.005 | 162.653 | 149.808 | 142.965<br>138.517 |
| 132.358 | 5.083<br>119.161 | 218.727<br>95.408 | 185.004 | 163.799 | 150.531 | 143.350<br>138.767 |
| 132.729 | 5.133<br>119.926 | 218.435<br>96.441 | 189.505 | 165.029 | 151.301 | 143.767<br>139.033 |
| 130.609 | 5.183<br>116.037 | 190.005<br>91.915 | 179.463 | 162.755 | 150.053 | 142.983<br>137.989 |
| 130.566 | 5.183<br>115.865 | 189.863<br>91.844 | 179.613 | 162.718 | 150.032 | 142.968<br>137.967 |
| 130.523 | 5.184<br>115.895 | 189.726<br>91.774 | 179.564 | 162.681 | 150.011 | 142.953<br>137.945 |



|         |                  |                   |         |         |         |         |         |
|---------|------------------|-------------------|---------|---------|---------|---------|---------|
| 130.479 | 5.185<br>115.873 | 189.588<br>91.703 | 179.514 | 162.643 | 149.990 | 142.938 | 137.923 |
| 130.438 | 5.186<br>115.754 | 189.459<br>91.635 | 179.466 | 162.607 | 149.970 | 142.924 | 137.902 |
| 130.438 | 5.186<br>115.754 | 212.001<br>91.635 | 179.466 | 162.607 | 149.970 | 142.924 | 137.902 |
| 130.438 | 5.236<br>115.754 | 220.161<br>91.635 | 179.466 | 162.607 | 149.970 | 142.924 | 137.902 |
| 130.449 | 5.286<br>115.775 | 218.468<br>91.661 | 179.523 | 162.631 | 149.988 | 142.934 | 137.909 |
| 130.416 | 5.336<br>115.849 | 218.466<br>91.752 | 179.719 | 162.716 | 150.052 | 142.969 | 137.934 |
| 130.597 | 5.386<br>116.067 | 218.473<br>92.022 | 180.298 | 162.970 | 150.241 | 143.075 | 138.010 |
| 130.854 | 5.436<br>116.522 | 218.512<br>92.599 | 181.519 | 163.524 | 150.648 | 143.304 | 138.172 |
| 131.268 | 5.486<br>117.377 | 218.739<br>93.660 | 183.705 | 164.587 | 151.409 | 143.738 | 138.475 |
| 131.605 | 5.536<br>118.183 | 218.281<br>94.688 | 188.257 | 165.693 | 152.171 | 144.182 | 138.779 |
| 130.505 | 5.561<br>116.120 | 192.888<br>92.415 | 183.223 | 164.511 | 151.473 | 143.710 | 138.159 |
| 130.069 | 5.567<br>115.400 | 191.250<br>91.678 | 182.656 | 164.116 | 151.238 | 143.542 | 137.927 |
| 129.568 | 5.573<br>114.630 | 189.913<br>90.898 | 182.046 | 163.693 | 150.985 | 143.357 | 137.670 |
| 129.264 | 5.580<br>114.021 | 189.693<br>90.303 | 181.577 | 163.367 | 150.789 | 143.211 | 137.462 |
| 129.264 | 5.580<br>114.021 | 213.399<br>90.303 | 181.577 | 163.367 | 150.789 | 143.211 | 137.462 |

|         |                  |                    |                   |         |         |         |         |
|---------|------------------|--------------------|-------------------|---------|---------|---------|---------|
| 129.204 | 5.630<br>114.021 | 220.161<br>118.468 | 181.577<br>90.303 | 163.367 | 150.789 | 143.211 | 137.462 |
| 129.215 | 5.680<br>114.042 | 218.468<br>114.042 | 181.631<br>90.329 | 163.393 | 150.807 | 143.222 | 137.470 |
| 129.257 | 5.730<br>114.119 | 218.468<br>114.119 | 181.816<br>90.418 | 163.445 | 150.870 | 143.260 | 137.499 |
| 129.380 | 5.780<br>114.345 | 218.473<br>114.345 | 182.364<br>90.684 | 163.759 | 151.059 | 143.374 | 137.585 |
| 129.643 | 5.830<br>114.826 | 218.513<br>114.826 | 183.519<br>91.251 | 164.354 | 151.465 | 143.620 | 137.770 |
| 130.190 | 5.880<br>115.600 | 218.727<br>115.600 | 185.489<br>92.247 | 165.433 | 152.191 | 144.062 | 138.160 |
| 130.519 | 5.930<br>116.576 | 218.361<br>116.576 | 189.996<br>43.276 | 166.608 | 152.967 | 144.538 | 138.449 |
| 129.491 | 5.755<br>114.726 | 195.546<br>114.726 | 185.584<br>91.363 | 165.563 | 152.321 | 144.071 | 137.845 |
| 128.175 | 5.980<br>112.611 | 192.052<br>112.611 | 183.771<br>89.234 | 164.364 | 151.574 | 143.508 | 137.089 |
| 128.155 | 5.980<br>112.611 | 206.965<br>112.611 | 183.771<br>89.234 | 164.374 | 151.574 | 143.508 | 137.089 |
| 128.155 | 6.030<br>112.611 | 220.161<br>112.611 | 183.771<br>89.234 | 164.364 | 151.574 | 143.508 | 137.089 |
| 128.167 | 6.080<br>112.633 | 218.468<br>112.633 | 183.823<br>49.258 | 164.391 | 151.592 | 143.519 | 137.098 |
| 128.212 | 6.130<br>112.711 | 218.468<br>112.711 | 183.927<br>89.346 | 164.489 | 151.656 | 143.560 | 137.130 |
| 128.345 | 6.180<br>112.942 | 218.473<br>112.942 | 184.512<br>89.608 | 164.780 | 151.848 | 143.681 | 137.226 |
| 128.629 | 6.230<br>113.435 | 218.513<br>113.435 | 185.598<br>90.168 | 165.412 | 152.262 | 143.942 | 137.433 |

|         |                  |                   |         |         |         |         |         |
|---------|------------------|-------------------|---------|---------|---------|---------|---------|
| 129.125 | 6.280<br>114.291 | 218.727<br>91.151 | 187.453 | 166.549 | 153.003 | 144.411 | 137.759 |
| 129.631 | 6.330<br>115.155 | 218.501<br>92.162 | 191.826 | 167.766 | 153.792 | 144.911 | 138.125 |
| 128.820 | 6.355<br>113.867 | 200.405<br>90.811 | 188.834 | 166.983 | 153.294 | 144.534 | 137.705 |
| 127.245 | 6.380<br>111.516 | 194.294<br>88.455 | 186.607 | 167.588 | 152.401 | 143.838 | 136.799 |
| 126.958 | 6.386<br>111.023 | 194.251<br>87.999 | 186.157 | 165.306 | 152.218 | 143.687 | 136.596 |
| 126.918 | 6.386<br>111.023 | 213.529<br>87.999 | 186.157 | 165.306 | 152.218 | 143.687 | 136.596 |
| 127.958 | 6.436<br>111.023 | 220.161<br>87.999 | 186.157 | 165.306 | 152.218 | 143.687 | 136.596 |
| 126.571 | 6.486<br>111.046 | 218.468<br>88.023 | 196.205 | 165.535 | 152.236 | 143.700 | 136.606 |
| 127.020 | 6.536<br>111.120 | 218.468<br>88.110 | 196.368 | 165.440 | 152.302 | 143.742 | 136.642 |
| 127.164 | 6.586<br>111.302 | 218.473<br>88.368 | 196.847 | 165.753 | 152.499 | 143.870 | 136.748 |
| 127.470 | 6.636<br>111.809 | 218.513<br>88.919 | 187.859 | 166.420 | 152.923 | 144.146 | 136.976 |
| 126.006 | 6.686<br>112.748 | 218.726<br>89.890 | 189.587 | 167.636 | 153.684 | 144.641 | 137.380 |
| 128.559 | 6.736<br>113.648 | 218.507<br>90.900 | 193.873 | 168.930 | 154.506 | 145.174 | 137.808 |
| 128.277 | 6.786<br>113.218 | 213.112<br>90.462 | 193.268 | 168.657 | 154.330 | 145.035 | 137.633 |
| 127.034 | 6.811<br>111.340 | 200.092<br>88.577 | 191.237 | 167.475 | 153.563 | 144.424 | 136.861 |
|         | 6.661            | 198.137           | 189.150 | 166.253 | 152.760 | 143.760 | 135.998 |

|         |         |         |         |         |         |         |
|---------|---------|---------|---------|---------|---------|---------|
| 125.656 | 109.341 | 86.695  |         |         |         |         |
| 6.867   | 197.934 | 149.010 | 166.170 | 152.705 | 143.712 | 135.935 |
| 125.556 | 109.202 | 86.572  |         |         |         |         |
| 6.867   | 215.926 | 184.010 | 166.170 | 152.705 | 143.712 | 135.935 |
| 125.556 | 109.202 | 86.572  |         |         |         |         |
| 6.917   | 220.161 | 189.010 | 166.170 | 152.705 | 143.712 | 135.935 |
| 125.556 | 109.202 | 86.572  |         |         |         |         |
| 6.967   | 218.468 | 189.054 | 166.203 | 152.724 | 143.725 | 135.946 |
| 125.571 | 109.215 | 86.596  |         |         |         |         |
| 7.317   | 218.468 | 189.202 | 166.318 | 152.792 | 143.770 | 135.985 |
| 125.623 | 109.308 | 86.681  |         |         |         |         |
| 7.067   | 218.473 | 189.639 | 166.659 | 152.994 | 143.905 | 136.101 |
| 125.778 | 109.551 | 86.935  |         |         |         |         |
| 7.117   | 218.513 | 140.561 | 167.395 | 153.431 | 144.196 | 136.351 |
| 126.108 | 110.070 | 87.478  |         |         |         |         |
| 7.167   | 218.728 | 192.138 | 168.702 | 154.219 | 144.717 | 136.793 |
| 126.686 | 110.975 | 88.434  |         |         |         |         |
| 7.217   | 218.525 | 196.326 | 170.105 | 155.086 | 145.286 | 137.268 |
| 127.251 | 111.916 | 89.446  |         |         |         |         |
| 7.242   | 215.988 | 196.466 | 170.436 | 155.276 | 145.409 | 137.369 |
| 127.417 | 112.110 | 89.658  |         |         |         |         |
| 7.292   | 215.988 | 196.359 | 170.234 | 155.144 | 145.303 | 137.237 |
| 127.213 | 111.811 | 89.362  |         |         |         |         |
| 7.317   | 199.594 | 140.886 | 168.914 | 154.283 | 144.597 | 136.360 |
| 125.866 | 109.847 | 87.436  |         |         |         |         |
| 7.324   | 198.213 | 190.264 | 168.500 | 154.009 | 144.364 | 136.063 |
| 125.413 | 109.214 | 86.854  |         |         |         |         |
| 7.350   | 197.001 | 189.625 | 168.075 | 153.726 | 144.120 | 135.750 |
| 124.937 | 108.557 | 86.262  |         |         |         |         |
| 7.336   | 196.288 | 189.076 | 167.709 | 153.481 | 143.907 | 135.474 |
| 124.519 | 107.988 | 85.760  |         |         |         |         |

|         |                  |                   |                   |         |         |         |         |
|---------|------------------|-------------------|-------------------|---------|---------|---------|---------|
| 124.519 | 7.336<br>107.988 | 212.515<br>85.760 | 189.076<br>85.760 | 167.709 | 153.481 | 143.907 | 135.474 |
| 124.519 | 7.386<br>107.968 | 220.161<br>85.760 | 185.076<br>85.760 | 167.709 | 153.481 | 143.907 | 135.474 |
| 124.535 | 7.436<br>108.012 | 218.468<br>85.784 | 189.119<br>85.784 | 167.739 | 153.501 | 143.920 | 135.486 |
| 124.550 | 7.486<br>108.095 | 218.468<br>85.868 | 189.267<br>85.868 | 167.846 | 153.573 | 143.968 | 135.529 |
| 124.753 | 7.536<br>108.341 | 218.473<br>86.117 | 189.703<br>86.117 | 168.166 | 153.786 | 144.112 | 135.655 |
| 125.102 | 7.586<br>108.816 | 218.513<br>86.650 | 190.024<br>86.650 | 168.856 | 154.246 | 144.421 | 135.925 |
| 125.713 | 7.636<br>109.782 | 218.728<br>87.590 | 192.197<br>87.590 | 170.084 | 155.070 | 144.976 | 136.405 |
| 126.353 | 7.686<br>110.736 | 218.525<br>88.587 | 196.383<br>88.587 | 171.428 | 155.970 | 145.580 | 136.918 |
| 126.487 | 7.711<br>110.935 | 215.992<br>88.798 | 196.523<br>88.798 | 171.725 | 156.165 | 145.712 | 137.028 |
| 126.261 | 7.761<br>110.640 | 215.992<br>88.511 | 196.432<br>88.511 | 171.518 | 156.027 | 145.597 | 136.888 |
| 124.913 | 7.786<br>108.700 | 199.671<br>86.642 | 191.075<br>86.642 | 170.164 | 155.115 | 144.835 | 135.961 |
| 124.455 | 7.792<br>108.083 | 198.310<br>86.377 | 190.485<br>86.377 | 169.739 | 154.824 | 144.585 | 135.649 |
| 123.977 | 7.799<br>107.439 | 197.209<br>85.505 | 189.878<br>85.505 | 169.303 | 154.525 | 144.323 | 135.321 |
| 123.550 | 7.805<br>106.873 | 196.419<br>85.011 | 189.347<br>85.011 | 168.921 | 154.262 | 144.091 | 135.028 |
| 123.550 | 7.805<br>106.873 | 212.572<br>85.011 | 189.347<br>85.011 | 168.921 | 154.262 | 144.091 | 135.028 |

|         |                  |                    |                   |         |         |         |         |
|---------|------------------|--------------------|-------------------|---------|---------|---------|---------|
| 123.550 | 7.855<br>106.873 | 220.161<br>218.468 | 189.347<br>85.011 | 168.921 | 154.262 | 144.091 | 135.028 |
| 123.566 | 7.905<br>106.856 | 218.468<br>106.856 | 189.390<br>85.034 | 168.950 | 154.282 | 144.105 | 135.041 |
| 123.623 | 7.955<br>106.900 | 218.468<br>106.900 | 189.536<br>85.117 | 169.053 | 154.356 | 144.156 | 135.087 |
| 123.795 | 8.005<br>107.229 | 218.473<br>107.229 | 189.969<br>85.362 | 169.359 | 154.576 | 144.309 | 135.222 |
| 124.110 | 8.055<br>107.719 | 218.513<br>107.719 | 190.881<br>85.886 | 170.018 | 155.049 | 144.637 | 135.513 |
| 124.801 | 8.105<br>108.664 | 218.728<br>108.664 | 192.440<br>86.812 | 171.195 | 155.893 | 145.225 | 136.028 |
| 125.474 | 8.155<br>109.651 | 218.526<br>109.651 | 196.616<br>87.796 | 172.469 | 156.811 | 145.865 | 136.579 |
| 125.620 | 8.188<br>109.858 | 215.988<br>109.858 | 196.756<br>88.011 | 172.786 | 157.016 | 146.008 | 136.701 |
| 125.410 | 8.236<br>109.508 | 215.940<br>109.508 | 196.674<br>87.731 | 172.577 | 156.870 | 145.884 | 136.554 |
| 124.028 | 8.255<br>107.662 | 199.907<br>107.662 | 191.408<br>85.916 | 171.206 | 155.911 | 145.070 | 135.581 |
| 123.566 | 8.261<br>107.049 | 198.557<br>107.049 | 190.838<br>85.368 | 170.775 | 155.606 | 144.803 | 135.256 |
| 123.066 | 8.267<br>106.410 | 197.476<br>106.410 | 190.255<br>84.815 | 170.334 | 155.292 | 144.525 | 134.916 |
| 122.600 | 8.274<br>105.867 | 196.708<br>105.867 | 189.746<br>84.340 | 169.949 | 155.017 | 144.280 | 134.614 |
| 122.600 | 8.274<br>105.867 | 212.702<br>105.867 | 189.746<br>84.340 | 169.949 | 155.017 | 144.280 | 134.614 |
| 122.666 | 8.324<br>105.867 | 220.161<br>105.867 | 189.746<br>84.340 | 169.949 | 155.017 | 144.280 | 134.614 |

|         |                  |                   |         |         |         |         |         |
|---------|------------------|-------------------|---------|---------|---------|---------|---------|
| 122.677 | 8.374<br>105.851 | 218.468<br>84.363 | 189.789 | 169.977 | 155.038 | 144.295 | 134.627 |
| 122.737 | 8.424<br>105.975 | 218.468<br>84.444 | 189.933 | 170.077 | 155.113 | 144.349 | 134.676 |
| 122.916 | 8.474<br>106.275 | 218.473<br>84.685 | 190.360 | 170.374 | 155.336 | 144.510 | 134.820 |
| 123.297 | 8.524<br>106.759 | 218.513<br>85.207 | 191.259 | 171.013 | 155.017 | 144.856 | 135.130 |
| 123.974 | 8.574<br>107.653 | 218.728<br>86.114 | 192.797 | 172.156 | 156.675 | 145.475 | 135.679 |
| 124.668 | 8.624<br>108.671 | 218.533<br>87.087 | 196.959 | 173.396 | 157.505 | 146.148 | 136.268 |
| 124.820 | 8.649<br>108.880 | 216.076<br>87.299 | 197.099 | 173.705 | 157.812 | 146.298 | 136.397 |
| 124.617 | 8.699<br>108.591 | 216.026<br>87.074 | 197.074 | 173.492 | 157.658 | 146.165 | 136.242 |
| 123.240 | 8.724<br>106.750 | 200.424<br>85.295 | 191.991 | 172.140 | 156.677 | 145.318 | 135.249 |
| 121.887 | 8.749<br>104.990 | 197.849<br>83.739 | 190.362 | 170.872 | 155.745 | 144.492 | 134.264 |
| 121.847 | 8.749<br>104.990 | 210.377<br>83.739 | 190.362 | 170.872 | 155.745 | 144.492 | 134.264 |
| 121.867 | 8.799<br>104.990 | 220.161<br>83.739 | 190.362 | 170.872 | 155.745 | 144.492 | 134.264 |
| 121.965 | 8.849<br>105.014 | 218.468<br>83.761 | 190.404 | 170.899 | 155.767 | 144.508 | 134.278 |
| 121.967 | 8.899<br>105.099 | 218.468<br>83.841 | 190.545 | 170.998 | 155.843 | 144.565 | 134.330 |
| 122.152 | 8.949<br>105.351 | 218.473<br>84.079 | 190.963 | 171.290 | 156.069 | 144.733 | 134.483 |
|         | 8.999            | 218.513           | 191.843 | 171.919 | 156.556 | 145.096 | 134.811 |

|         |                  |                   |         |         |         |         |         |
|---------|------------------|-------------------|---------|---------|---------|---------|---------|
| 122.546 | 105.089          | 84.590            |         |         |         |         |         |
| 123.238 | 9.049<br>106.879 | 218.728<br>85.491 | 193.348 | 173.044 | 157.423 | 145.743 | 135.391 |
| 123.971 | 9.099<br>107.818 | 218.539<br>86.456 | 197.489 | 174.268 | 158.365 | 146.447 | 136.015 |
| 124.129 | 9.124<br>108.636 | 216.099<br>86.666 | 197.626 | 174.572 | 158.573 | 146.603 | 136.152 |
| 123.915 | 9.174<br>107.746 | 216.099<br>86.460 | 197.560 | 174.359 | 158.414 | 146.464 | 135.592 |
| 122.582 | 9.199<br>105.986 | 201.214<br>84.766 | 192.826 | 173.045 | 157.429 | 145.601 | 134.997 |
| 121.184 | 9.224<br>104.159 | 198.712<br>83.203 | 191.160 | 171.729 | 156.433 | 144.708 | 133.951 |
| 121.184 | 9.224<br>104.199 | 210.183<br>83.203 | 191.160 | 171.729 | 156.433 | 144.708 | 133.951 |
| 121.184 | 9.274<br>104.179 | 220.161<br>83.203 | 191.160 | 171.729 | 156.433 | 144.708 | 133.951 |
| 121.202 | 9.324<br>104.223 | 218.464<br>83.225 | 191.201 | 171.757 | 156.454 | 144.724 | 133.966 |
| 121.202 | 9.374<br>104.308 | 218.468<br>83.305 | 191.338 | 171.855 | 156.531 | 144.783 | 134.020 |
| 121.457 | 9.424<br>104.562 | 218.473<br>83.540 | 191.743 | 172.146 | 156.760 | 144.959 | 134.181 |
| 121.864 | 9.474<br>105.152 | 218.513<br>84.045 | 192.598 | 172.773 | 157.253 | 145.336 | 134.526 |
| 122.579 | 9.524<br>106.048 | 218.728<br>84.936 | 194.061 | 173.892 | 158.129 | 146.089 | 135.136 |
| 123.181 | 9.549<br>106.841 | 219.109<br>85.696 | 195.244 | 174.859 | 158.885 | 146.590 | 135.658 |
| 123.587 | 9.574<br>107.373 | 216.585<br>86.212 | 197.063 | 175.523 | 159.405 | 146.991 | 136.014 |



|         |                   |                   |         |         |         |         |         |
|---------|-------------------|-------------------|---------|---------|---------|---------|---------|
| 123.670 | 9.624<br>107.491  | 216.586<br>86.328 | 197.261 | 175.680 | 159.522 | 147.081 | 136.093 |
| 122.458 | 9.649<br>105.897  | 201.531<br>84.840 | 193.134 | 174.462 | 158.585 | 146.253 | 135.158 |
| 120.949 | 9.674<br>104.042  | 198.608<br>83.199 | 191.489 | 173.064 | 157.498 | 145.276 | 134.039 |
| 120.721 | 9.680<br>103.659  | 198.158<br>82.913 | 191.186 | 172.808 | 157.298 | 145.091 | 133.825 |
| 120.721 | 9.680<br>103.659  | 216.436<br>82.913 | 191.186 | 172.808 | 157.298 | 145.091 | 133.825 |
| 120.721 | 9.730<br>103.699  | 226.161<br>82.913 | 191.186 | 172.808 | 157.298 | 145.091 | 133.825 |
| 120.759 | 9.780<br>103.723  | 218.468<br>82.935 | 191.227 | 172.834 | 157.320 | 145.108 | 133.841 |
| 120.805 | 9.830<br>103.809  | 218.468<br>83.013 | 191.364 | 172.926 | 157.398 | 145.170 | 133.898 |
| 121.091 | 9.880<br>104.013  | 218.473<br>83.246 | 191.769 | 173.202 | 157.630 | 145.352 | 134.006 |
| 121.419 | 9.930<br>104.605  | 218.513<br>83.746 | 192.624 | 173.796 | 158.128 | 145.745 | 134.427 |
| 122.153 | 9.980<br>105.554  | 218.726<br>84.629 | 194.085 | 174.859 | 159.012 | 146.444 | 135.066 |
| 122.773 | 10.005<br>106.311 | 219.109<br>85.382 | 195.268 | 175.782 | 159.773 | 147.048 | 135.612 |
| 123.152 | 10.030<br>106.887 | 216.581<br>85.895 | 197.089 | 176.417 | 160.295 | 147.463 | 135.985 |
| 123.266 | 10.060<br>107.007 | 216.581<br>86.012 | 197.268 | 176.570 | 160.414 | 147.557 | 136.070 |
| 122.064 | 10.105<br>105.430 | 201.556<br>84.547 | 193.232 | 175.357 | 159.449 | 146.695 | 135.110 |

|         |         |         |         |         |         |         |
|---------|---------|---------|---------|---------|---------|---------|
| 10.130  | 198.182 | 191.665 | 173.962 | 158.331 | 145.679 | 133.967 |
| 120.606 | 103.600 | 82.943  |         |         |         |         |
| 10.136  | 198.243 | 191.377 | 173.708 | 158.125 | 145.489 | 133.749 |
| 120.329 | 103.263 | 82.653  |         |         |         |         |
| 10.137  | 198.182 | 191.339 | 173.674 | 158.098 | 145.464 | 133.720 |
| 120.252 | 103.219 | 82.616  |         |         |         |         |
| 10.137  | 218.590 | 191.339 | 173.674 | 158.098 | 145.464 | 133.720 |
| 120.292 | 103.219 | 82.616  |         |         |         |         |
| 10.187  | 220.161 | 191.339 | 173.674 | 158.098 | 145.464 | 133.720 |
| 120.292 | 103.219 | 82.616  |         |         |         |         |
| 10.237  | 218.468 | 191.380 | 173.699 | 158.120 | 145.481 | 133.737 |
| 120.311 | 103.243 | 82.638  |         |         |         |         |
| 10.287  | 218.468 | 191.416 | 173.788 | 158.198 | 145.545 | 133.796 |
| 120.379 | 103.329 | 82.716  |         |         |         |         |
| 10.337  | 218.473 | 191.919 | 174.053 | 158.431 | 145.734 | 133.971 |
| 120.579 | 103.584 | 82.947  |         |         |         |         |
| 10.387  | 218.513 | 192.768 | 174.625 | 158.931 | 146.140 | 134.348 |
| 121.618 | 104.128 | 83.442  |         |         |         |         |
| 10.437  | 218.728 | 194.222 | 175.649 | 159.817 | 146.862 | 135.113 |
| 121.711 | 105.081 | 84.318  |         |         |         |         |
| 10.462  | 219.111 | 195.403 | 176.544 | 160.580 | 147.487 | 135.584 |
| 122.399 | 105.884 | 85.068  |         |         |         |         |
| 10.487  | 217.297 | 196.693 | 177.026 | 160.988 | 147.821 | 135.888 |
| 122.726 | 106.306 | 85.467  |         |         |         |         |
| 10.512  | 215.743 | 197.633 | 177.194 | 161.123 | 147.932 | 135.989 |
| 122.847 | 106.445 | 85.599  |         |         |         |         |
| 10.562  | 215.743 | 196.928 | 176.900 | 160.882 | 147.714 | 135.749 |
| 122.548 | 106.064 | 85.249  |         |         |         |         |
| 10.587  | 199.908 | 191.846 | 175.490 | 159.723 | 146.661 | 134.587 |
| 121.097 | 104.232 | 83.582  |         |         |         |         |

|         |                   |                   |         |         |         |         |         |
|---------|-------------------|-------------------|---------|---------|---------|---------|---------|
| 119.657 | 10.637<br>102.469 | 198.431<br>82.071 | 190.449 | 174.144 | 158.608 | 145.630 | 133.435 |
| 119.657 | 10.637<br>102.469 | 212.106<br>82.071 | 190.449 | 174.144 | 158.608 | 145.630 | 133.435 |
| 119.657 | 10.687<br>102.469 | 220.161<br>82.071 | 190.449 | 174.144 | 158.608 | 145.630 | 133.435 |
| 119.676 | 10.737<br>102.493 | 218.468<br>82.093 | 190.491 | 174.167 | 158.630 | 145.648 | 133.452 |
| 119.745 | 10.787<br>102.519 | 218.468<br>82.179 | 190.632 | 174.249 | 158.708 | 145.713 | 133.514 |
| 119.951 | 10.837<br>102.876 | 218.473<br>82.399 | 191.048 | 174.494 | 158.940 | 145.908 | 133.696 |
| 120.351 | 10.887<br>103.363 | 218.513<br>82.889 | 191.925 | 175.023 | 159.438 | 146.325 | 134.087 |

## APPENDIX F

### A COMPARISON OF FLOSS TO THE SAS COMPUTER CODE

#### F.1 THE SAS Code

Argonne National Laboratory developed the first SAS computer code, SAS1A, in 1970. The code has undergone virtually continuous revision and updating since then, and is currently in its fourth generation, with SAS4A. The code is a one dimensional, multichannel code, for the purpose of studying accidents involving sodium voiding in the LMFBR. It contains calculational modules for transient and steady state thermalhydraulics, both in single phase and two phase flow. In addition, it has the means to consider fuel and clad melting and motion, fission gas release, and other factors present during postulated LMFBR accidents. The code is structured so as to be able to follow an entire reactor accident from the initiation phase through until gross fuel motion and reactor disassembly begin. Other codes, such as VENUS, can then use the SAS results to predict the events during the core disruptive phase of the accident.

The current SAS model can handle multiple bubbles in a single channel, and multiple channels across the core. However, each bundle is considered as a unit which behaves one-dimensionally. Therefore, although corewide incoheren-

cies in voiding behavior can be tracked, multi-dimensional bubble behavior across a single bundle cannot be considered. Due to its versatility, the SAS code is one of the most widely used tools in the United States LMFBR accident analysis program.

## F.2 Comparing FLOSS to SAS

Since the FLOSS code also uses a one-dimensional thermal-hydrodynamic model to calculate conditions during a transient, it is not surprising to find that the equations used in both codes are quite similar. The technique used to track the solution of the transient was derived from one of the reports used in the development of the original SAS code, as well. Though the intent of this project was not to reproduce SAS, the system of solution for both codes is basically similar.

The major differences between SAS and FLOSS are in scope and in the handling of the heat transfer during condensation. The scope of SAS is far greater than that of FLOSS; in fact, the FLOSS code would comprise no more than two or three modules in the entire SAS code. This is due to the assumption made when the project was begun that FLOSS would eventually become a module in a larger, system-scale code. The second difference is more fundamental. The SAS code contains only a single input for a constant

heat transfer coefficient. In the manual consulted (32) this value was set at approximately  $11000 \text{ BTU/hr-ft}^2\text{°F}$ , which falls in the range suggested by Barry and Balzhiser (33). However, there is no methodology presented for describing the changes in condensation heat transfer which have been documented here. The FLOSS code accomplishes this change in heat transfer by slightly changing the initial temperature profile, thereby causing a step change in heat transfer coefficient. The high value of the coefficient causes the code to underpredict experimental results. However, the failure of SAS to consider this phenomenon may lead to overprediction of experimental results causing an unrealistically conservative solution. Table F.1, presented on the next page, spotlights some of the areas where further research is needed to improve the predictive abilities of SAS.

The entire question of multidimensional effects in sodium boiling is another area with which neither FLOSS nor SAS are capable of dealing. As mentioned in Chapter 6, this, as well as several other questions, remain to be resolved in further research.

Table F.1 Comparison of FLOSS to SAS

| <u>Issue</u>                                      | <u>Water (FLOSS)</u>   | <u>SAS</u>                                       | <u>Recommendations for Sodium work</u>  |
|---|--|--|---|
| Initial Temperature Profile in Unheated Zone      | Experimentally determined, except for small saturated zone at start of unheated zone | As calculated during initial stages of transient | A physically realistic and accurate temperature profile is necessary to adequately characterize the flow behavior. This factor is one of the prime determinants of how the flow will behave. It is essential that any simulation which purports to chart the best estimate of the oscillation take account of the importance of this factor, and calculate an accurate temperature profile history as well.                   |
| Initial Temperature Profile in Core (Heated Zone) | Not considered   | As calculated                                    | The identical comment as above is applicable here, as well. This profile will also influence flow behavior, especially if it is steep. Investigation is needed to determine whether the sodium condensation coefficient behaves like the water coefficient. A mechanistic model for $h_{con}$ versus time over the period of an oscillation, accounting for interfacial breakup and augmentation of heat transfer, is needed. |
| Condensation Heat Transfer                        | Step change from zero to values approximating those present during bubble collapse   | Constant   |   |

Table F.1 Comparison of FLOSS TO SAS (Cont.)

| <u>Issue</u>                      | <u>Water(FLOSS)</u>                             | <u>SAS</u>                                      | <u>Recommendations for Sodium Work</u>  |
|-----------------------------------|---|---|---|
| Loop Dynamics                     | Present implicit in model                       | Present in later versions of SAS                | The characteristics of the external loop can have a significant effect on flow oscillatory behavior.  |
| Comparison of Simulants to Sodium | --  | --  | Investigation into the relevance of simulant behavior to sodium behavior is clearly needed.   |
| Non-condensable gas               | Implicit in choice of heat transfer coefficient | Implicit in choice of heat transfer coefficient | While work has been done regarding condensation in liquid metals, the presence of non-condensibles in sodium systems provides both a mechanism for nucleation and a retarding factor in condensation. Work is needed to provide accurate models for the effect of these noncondensibles on heat transfer. This is especially relevant if fission gases are released into the coolant. |