

NOTICE

MN ONLY

PORTIONS OF THIS REPORT ARE ILLEGIBLE. It has been reproduced from the best available copy to permit the broadest possible availability.

LOFT TECHNICAL REPORT LTR 1118-1  
JUNE 6, 1978

MASTER

DRY SCRAM EVALUATION

MASTER

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

Prepared by  
Todd Shipyards  
per S-7133

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED EB



**EG&G** Idaho, Inc.



IDAHO NATIONAL ENGINEERING LABORATORY

**DEPARTMENT OF ENERGY**

IDAHO OPERATIONS OFFICE UNDER CONTRACT EY-76-C-07-1570

## DISCLAIMER

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**



LOFT TECHNICAL REPORT  
LOFT PROGRAM

FORM EG&G-229  
(Rev. 12-76)

TITLE Dry Scram Evaluation		REPORT NO. LTR 1118-1
AUTHOR Prepared by Todd Shipyards per S-71:33	GWA NO.	
PERFORMING ORGANIZATION Requesting organization LOFT	DATE 6-6-78	
LOFT APPROVAL 5-10-78 H. Ben [Signature] 5/11/78	[Signature]	
FE&OB Mgr. [Signature]	LESD Mgr. [Signature]	PSB Mgr. [Signature]
P&CSB Mgr. [Signature]		RSB Mgr.

SUMMARY

The purpose of this LTR is to present the analysis performed by Todd Shipyards concerning the ability of the LOFT CRDMs to withstand a dry scram.

A "dry scram" could result <sup>in</sup> the CRDM components yielding; however, it would probably not render the CRDMs inoperable. It also concluded that a dry scram is highly unlikely based on a typical LOFT depressurization curve and the temperature of the fluid in the upper pressure housing. At the time of scram, the fluid in the upper pressure housing will not flash to steam owing to the pressure-temperature relationship existing during the scram cycle.

This analysis was originally Appendix C-5 to LOFT CDD 1.1.1.8B.

APPENDIX C-5

DRY SCRAM EVALUATION

1. INTRODUCTION

This appendix presents data relative to the selected CRDMs to withstand a dry scram.

2. CONCLUSIONS

Based on the analysis performed by Todd Shipyards, a "dry scram" could result in yielding of the CRDM components; however, it would probably not damage the CRDM to the extent that it would be inoperable. It is also concluded that a dry scram is highly unlikely based on a typical LOFT depressurization curve and the temperature of the fluid in the upper pressure housing at the time of scram. The fluid in the upper pressure housing will not flash to steam owing to its pressure-temperature relationship existing during the scram cycle.

# TODD

Nuclear Division: P. O. Box 1600 • Galveston, Texas 77550 • SH 4-5331 (713)

SHIPYARDS CORPORATION

RECEIVED APR 5 1971

IDAHO NUCLEAR CORP.

A. E. C. CONTRACT NO. AT(10-1)-1230

P. O. NO. 5 1133

April 1, 1971

SPEC. NO.

EQUIP. ITEM NO.

C. S. NO. 020201

Idaho Nuclear Corporation  
Post Office Box 1845  
Idaho Falls, Idaho 84301

ATTENTION: Supplier Data Control - CF-689

ATTACHMENT: Analysis by Dr. C. D. Michaelopoulos of Dynamic  
Stresses During Dry Scram


SUBJECT: Report on Evaluation of Dry Scram - Subcontract S-7133

Todd Shipyards Corporation has evaluated the condition of scrambling the control and without any water in the buffer piston area. This report is being submitted separately from the ASME Section III Code Analysis because it does not concern a pressure boundary.

The shock wave stresses have been calculated to be 150,000 psi in the leadscrew threaded joint that holds the buffer piston. During a "dry scram" this stress is equal to the yield stress for the 17-4 PH leadscrew.

Based on this analysis, it is concluded that the "dry scram" should be avoided. During the blowdown transient, the drives should be motored down in the same manner as the "capsize insertion" for the N.S. SAVANNAH.

Very truly yours,



E. L. Jackson, Jr.,  
Project Manager

ELJ:11h:98:71

Attachment

cc: Mr. R. N. Moore  
Dr. C. D. Michaelopoulos  
Miss P. A. Jackson

## DYNAMIC STRESSES DEVELOPED DURING DRY-SCRAM CONDITIONS

In dry-scrum conditions, the lead-screw assembly plus the control rod are in free fall. The maximum height,  $h$ , through which the assembly falls is 65 inches (5.41 ft). Thus, the impact velocity  $v_0$  is given by

$$v_0 = \sqrt{2gh}$$

$$= \sqrt{2(32.2)(5.41)}$$

or

$$v_0 \hat{=} 18.6 \text{ ft/sec.}$$

This is the velocity with which the buffer piston strikes the upper end of the motor tube. For the lead screw,  $E = 28.5 \times 10^6$  psi,  $\gamma = 0.28$  lb/in<sup>3</sup>. The acoustic velocity (velocity of propagation of a stress wave) in the lead screw,  $c$ , is

$$c = \sqrt{E/\rho}, \quad \rho = \frac{\gamma}{g} = \left(\frac{0.28}{386}\right) \frac{\text{lb sec}^2}{\text{in}^2}$$

$$= \sqrt{\frac{28.5 \times 10^6}{(0.28)/(386)}}$$

$$= 198,000 \text{ in./sec}$$

or  $c = 16,500 \text{ ft/sec.}$

From one-dimensional wave propagation theory:

if a prismatic bar moving with a uniform (rigid body) velocity  $v_0$  is suddenly stopped at one end, a stress wave develops at that end and travels down the bar with velocity  $c$ . The magnitude of this stress wave  $\sigma_0$  is given by

$$\sigma_0 = c \rho v_0 = \frac{v_0}{c} E$$

For  $v_0 = 18.6$  ft/sec,

$$\sigma_0 = \frac{18.6}{16,500} (28.5 \times 10^6)$$

$$\underline{\underline{\sigma_0 = 32,200 \text{ psi}}}$$

This would be the stress (tensile) if the buffer piston hit a rigid stop and it represents the maximum possible stress that can be developed in the lead screw (if it is assumed uniform - no threads). Note that the lower end is "free" that is the tensile wave will reflect as a compressive stress wave.

Using a stress concentration factor of 4.5 for the threaded connection to the buffer piston, the maximum stress in the lead screw during dry-screw conditions is:

$$\underline{\underline{\sigma_{\max} \cong 150,000 \text{ psi}}}$$



This is a conservative answer, since the motor tube is not rigid. Taking into account the elasticity of the motor tube, the system can be idealized as shown in the accompanying figure.

The magnitudes of the stress waves (tensile in the lead screw and compressive in the motor tube) are given by \*

$$\sigma_1 = \frac{c_1 \rho_1 V_0}{KQ + 1}$$

$$\sigma_2 = \frac{KQ c_2 \rho_2 V_0}{KQ + 1}$$

where the subscripts 1 and 2 refer to the lead screw and motor tube, respectively, and

$$K = A_1 / A_2, \quad Q = c_1 \rho_1 / c_2 \rho_2.$$

For the motor tube,  $E = 29.2 \times 10^6$  psi and  $\rho_2 = \rho_1 = (0.280 / 386) \frac{\text{lb sec}^2}{\text{in}^2}$ . Thus,


$$c_2 = \sqrt{\frac{29.2 \times 10^6}{(0.280) / (386)}} \approx 201,000 \text{ in/sec}$$

or

$$c_2 = 16,800 \text{ ft/sec}$$

Since

$$Q = \frac{c_1 \rho_1}{c_2 \rho_2} = \frac{16,500}{16,800} = 0.98 \approx 1.0$$



the above formulas simplify to

$$\sigma_1 \cong \frac{A_2}{A_1 + A_2} (c_1 p_1 v_0)$$

$$\sigma_2 \cong \frac{A_1}{A_1 + A_2} (c_2 p_2 v_0)$$

The cross-sectional areas are

$$A_1 = \frac{\pi}{4} [(1.576)^2 - (1.092)^2]$$

$$\cong 1.005 \text{ in}^2$$

$$A_2 = \frac{\pi}{4} [(4.375)^2 - (2.455)^2]$$

$$\cong 10.4 \text{ in}^2$$

Substituting in the above expressions for the stresses,

$$\sigma_1 = \frac{10.4}{11.4} (32,200)$$

or

$$\underline{\underline{\sigma_1 = 29,400 \text{ psi}}}$$

and

$$\sigma_2 \cong \frac{1.00}{11.4} (32,200)$$

or

$$\underline{\underline{\sigma_2 = 2,800 \text{ psi}}}$$

Note that the motor tube was considered fixed at the lower end since it is attached to the reactor. Actual stress in the tube is about  $2\sigma_2 = 5,600$  psi due to the reflected compressive wave

\* M. F. Spotts, "Mechanical Design Analysis,"  
Prentice-Hall, Inc., 2<sup>nd</sup> Printing, pp 357-360.