BNL--48523

RENEWABLE ENERGY FOR AMERICA'S CITIES:
ADVANCED COMMUNITY ENERGY SYSTEMS
PROPOSED RESEARCH, DEVELOPMENT AND
DEMONSTRATION PROGRAM

DE93 009538

Thomas C. J. Gleason*
Guest Research Engineer

January 1993

Energy Efficiency & Conservation Division
Department of Applied Science
Brookhaven National Laboratory
Upton, New York 11973

*In Washington, D.C. area: (301) 907-0811

This work was performed under the auspices of the U.S. Department of Energy
Washington, D.C. Under Contract No. DE-AC02-76CH00016

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors, or their employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency, contractor, or subcontractor thereof.

INTRODUCTORY NOTE

Advanced community energy systems (ACES) technologies were initially analyzed for the USDOE by the author of this paper in BNL report: "Cogeneration and Beyond: The Need and Opportunity for High Efficiency, Renewable Energy Systems." This paper elaborates upon that report by making recommendations for research, development and demonstration (R,D&D) projects in technical areas covered in the initial report.

EXECUTIVE SUMMARY

Advanced Community Energy Systems (ACES) supply groups of buildings, communities or cities with hot or chilled water for building space heating, domestic hot water or air conditioning. The energy is supplied via a network of insulated, underground pipes linking central sources of supply with buildings. ACES employ very efficient conversion technologies--such as cogeneration, heat pumps, and heat activated chillers--and renewable energy sources such as solar energy, winter cold, wind, and surface and subsurface warm and cold waters.

ACES technologies are the most promising near-term means by which cities can rapidly make the transition from their present dependence on fossil fuel supply systems to an economically and environmentally sustainable reliance on very high efficiency and renewable energy supply systems. ACES have the potential to effect a rapid and cost-effective "solarization" of America's cities by supplying most heating and air-conditioning requirements from renewable sources.

The benefits of ACES technology include the following:

- o efficiency 290% greater than conventional energy supply systems
- o fuel savings of 70% when compared with conventional supply systems
- o drastic reduction in local and global air pollution
- o elimination of CFCs used in building air conditioning and heating
- o rapid and thoroughgoing "solarization" of existing cities
- o potential to supply 4 Quads or \$20 billion worth of energy per year
- o potential for \$14 billion in annual energy savings
- o tens of thousands of new jobs in manufacturing and construction in urban areas

In order to capture these benefits for American cities it will be necessary for the U.S. Department of Energy to establish a new ACES Technology R,D&D Program. This new program will cost \$10 million per year for 5 years for a total of \$50 million. The following pages detail the key technologies and plans for their development under the proposed ACES R,D&D Program.

Brookhaven National Laboratory has had extensive involvement in the technical areas critical to the success of ACES technology. If DOE decides to make the substantial commitment required to resolve the energy supply and related economic and environmental problems which beset America's cities then BNL is prepared to assume the role of lead DOE laboratory for the ACES program. In this role BNL will work closely with private industry and other DOE laboratories with significant expertise in technical fields critical to the success of ACES technology. BNL and the author of this report are ready to elaborate upon any of the elements in the following R,D&D program plan at the request of the DOE.

Although BNL wishes to assume the role of lead DOE laboratory for the ACES R,D&D Program it does not pretend to have an institutional monopoly on expertise in ACES technology. Quite to the contrary, there are several other DOE labs, research institutions and private companies which have expertise in critical ACES technologies which should be involved in the ACES R,D&D program. For example, Oak Ridge National Laboratory has done pioneering work and maintains a significant capability in the field of heat activated chilling technology. Argonne National Laboratory has done much of the most important work in advanced thermal

distribution fluids such as friction reduction additives and phase change materials. The U.S. Army Corps of Engineers has two laboratories with extensive knowledge of district heating and cooling systems on military bases. Lawrence Berkeley Lab has done important work in radiative cooling technology. Several industry associations also have important expertise and contributions to make including the American Physical Plant Association (colleges and universities), the International District Heating and Cooling Association (utilities), the American Gas Association, the Solar Energy Industries Association, the American Council for an Energy Efficient Economy and the International Institute for Energy Conservation. In addition, there are many private companies and technical consultants with very important capabilities in critical technical fields which deserve to be involved in the development of the new ACES technologies.

In all of these cases, BNL proposes to work in a collegial manner with these and other institutions and private firms to develop the strongest possible ACES program which emphasizes developing the hard-won expertise already in place rather than attempting to "reinvent the wheel." However, there is a simultaneous need to articulate a vision and to implement that vision on an on-going basis from the formulation of detailed, R,D&D plans through their implementation, completion and integration with other technologies. BNL has assembled under its wing the technical capability to undertake the development of a number of critical ACES technologies at or through BNL such as cogeneration and community-scale renewable heating and cooling systems and related technologies.

More importantly, it is the vision articulated in this proposal and related BNL work which forms the glue critical to making the proposed program a coherent one by focusing all efforts sharply on the ultimate goal. That goal is the development of new, very-high-efficiency and renewable energy supply systems which ultimately will constitute the means by which America will cost-effectively "solarize" its urban areas and thereby contribute significantly to their economic revitalization and environmental restoration. That vision, the commitment to this goal, and the willingness and capability of bringing together diverse institutions and expertise in the service of that goal are the primary reasons for considering BNL for the role of lead DOE lab for the development of ACES technology. Nonetheless, even if BNL is not chosen to assume this role, it is critical that a new ACES R,D&D program be established by the DOE for the sake of the economic, environmental and energy future of America's cities.

TABLE OF CONTENTS

<u>TOPIC</u>	<u>PAGE</u>
Introductory Note	iii
Executive Summary	iv
Introduction to ACES Technology	1
Energy Efficiency and Environmental Impact of ACES Technology	1
Market Potential	2
Impact on Urban Economies	2
Current Status of ACES Technology	3
ACES Research, Development and Demonstration Requirements	4
The National Economic Opportunities of ACES Technology	4
 <u>TECHNICAL APPENDICES</u>	
Appendix 1: Energy Efficiency of ACES & Conventional Systems . . .	7
Appendix 2: ACES Comparative Efficiency and Fuel Savings	12
Appendix 3: Energy & Monetary Savings From ACES	16
Appendix 4: ACES Technology R,D&D Program Outline	18
Appendix 5: ACES Technology R,D&D Project Descriptions	20
Market Potential & Penetration Analysis & R,D&D Program	
Planning	21
Cogeneration Technology For the Buildings Sector	23
Heat Activated Chillers for Use with Small Scale Cogeneration .	25
Heat Activated Water Distillation Technology	30
Renewably Energized Community Heating & Cooling Systems	32
Ammonia Vapor Compression Technology for Building Air	
Conditioning	36
Large Scale, Low Temperature Cogeneration & District Heating . .	38
Community Scale Thermal Distribution & End Use System	41

ADVANCED COMMUNITY ENERGY SYSTEMS (ACES)
TECHNOLOGY R,D&D PROGRAM RECOMMENDATIONS

Introduction to ACES Technology

The first purpose of this paper is to describe ACES technologies and their potential impact on the environment, the U.S. energy supply system and economy. The second purpose is to recommend an R,D&D program to the U.S. Department of Energy which has as its goal the rapid development of the most promising of the new technologies.

ACES supply thermal energy to groups of buildings, communities and cities in the form of hot or chilled water for building space heating, domestic hot water or air conditioning. The energy is supplied via a network of insulated, underground pipes linking central sources of supply with buildings. ACES, by definition, employ very high energy efficiency conversion technologies such as cogeneration, heat pumps, and heat activated chillers. These systems also use renewable energy sources such as solar energy, winter cold, wind, and surface and subsurface warm and cold waters.

ACES compose a new generation of community-scale building heating and air conditioning supply technologies. These new systems can effect a rapid and economical conversion of existing cities to energy supply by very efficient energy conversion systems and renewable energy systems. ACES technologies are the most promising near term means by which cities can make the transition from our present damaging dependence on fossil fuel supply systems to an economically and environmentally sustainable reliance on very high efficiency and renewable energy supply systems. When fully developed to serve an urban area, ACES will constitute a new utility system which can attain a level of energy efficiency, economy and reliance on renewable energy sources not possible with currently available energy supply systems.

Energy Efficiency and Environmental Impact of ACES Technology

The new ACES technologies exhibit energy efficiency levels which are approximately 290% greater than the energy efficiencies characteristic of typical conventional heating and cooling systems (see Appendices 1 & 2). ACES have the potential to achieve fuel savings of approximately 70% compared with conventional supply methods (see Appendices 1 & 2). Such dramatic energy efficiency improvements and fuel savings are technically achievable and necessary for both environmental and economic reasons.

With respect to the environment, we know from the U.N. Intergovernmental Panel on Climate Change that the industrialized countries need to achieve an overall reduction of carbon dioxide emissions of up to 80% if we are to stabilize the trend toward global warming or the "Greenhouse Effect" over the next 40 years. This drastic reduction in carbon dioxide emissions by the industrialized countries will be necessary because over the next 40 years the population of the globe will be doubling. The widespread implementation of ACES technologies coupled with end use energy efficiency improvements have the potential to achieve such levels of carbon dioxide emissions reductions in the U.S. residential and commercial buildings sector.

Moreover, the new generation of ACES technologies employs either environmentally benign refrigerants or substitute sources of environmental heat or cold for present air conditioning and heat pump systems which use freon (CFC) refrigerants. The emission of CFCs into the atmosphere has been identified as the cause of the stratospheric ozone depletion crisis. The new "drop-in" refrigerants which have been developed to substitute for CFCs are problematic in one or more of the following ways: toxicity, cost, efficiency and/or implementation. ACES technology offers an effective, near term solution to the very difficult and pressing problem of phasing out our use of CFCs in a way that is technically viable, energy efficient, market driven and rapid.

Market Potential

There are strong indications that ACES technology has a very significant market potential. In 1990 the U.S. consumed 80 Quadrillion Btus (Quads) and the nation's energy bill was \$400 billion. Total energy consumption in the residential and commercial buildings sector in 1990 was 29 Quads and the cost was \$145 billion. New ACES technology has the potential to supply 25% of the space heating, air conditioning and domestic hot water to American buildings, roughly 4 Quads/year. This estimate of market potential is based on extrapolations from studies of closely related technology and experience (see Appendix 3).

If ACES technologies penetrate the market to the extent of supplying 4 Quads per year, then the current annual value of the energy provided would be \$20 billion. The average ACES technology can save approximately 70% of the energy required by conventional heating and cooling supply technology. By supplying a 4 Quad market share ACES could save \$14 billion worth of primary energy per year as well as all of the attendant economic, environmental and social costs which such energy use entails.

Impact on Urban Economies

The locus of these savings is as important as their magnitude. The bulk of the savings that stand to be generated by ACES will be in the most densely populated urban areas. This is because relatively high building and thermal energy demand densities are a prerequisite for the economic viability of ACES. Thus, the new ACES technology will have its greatest economic impact precisely where it is needed most--in America's economically depressed cities.

A large portion of the cost of constructing ACES utilities is in the form of labor costs. Labor will be needed for manufacturing system components, constructing renewable energy collection and storage systems, excavating trenches in city streets, installing underground heating and cooling distribution piping networks, and converting buildings to supply by the new community systems. The labor required to construct ACES utility systems is mostly for low and moderately skilled workers in the manufacturing and construction industries. Moreover, much of this labor will be required within the cities which are to be served by these systems. Thus, the potential exists to create tens of thousands of jobs for urban residents in the manufacture and construction of a critical new urban energy utility. The likely duration of construction period for implementing ACES systems in urban areas throughout the U.S. is 20 years.

In addition, the economic impact of ACES will continue well beyond the manufacturing and construction period. For three to five decades after implementation, the energy efficiency and economy of the new utility supply systems will continue to bolster the productivity of the local economy and increase the level of prosperity of the communities which the new ACES technologies serve.

Those new community energy supply systems which are closest to commercial viability promise to be very competitive with existing fossil fuel supply systems. One important, nearly commercial ACES technology is small, natural-gas fired cogeneration employing a double effect absorption chiller to convert engine waste heat into high value air conditioning. The electricity produced by the cogenerator is employed to power an ammonia chiller. This system attains a thermal coefficient of performance (COP) of at least 3.0 operating as a non-CFC, gas-fired air conditioner (see Appendix 1, Case 4(b)).

When compared with a typical conventional electric chiller which obtains an average overall thermal COP of 1.5 (see Appendix 1, Case 2(c)), the cogeneration/ammonia chilling/absorption chilling case is approximately 100% more efficient and saves 50% of the energy used by the conventional system. These efficiency and energy saving advantages translate into a compelling economic argument for the replacement of old systems with new. Small, high-efficiency natural-gas fired cogeneration systems with double effect absorption chillers can obtain paybacks of 2 to 5 years in most U.S. markets.

The addition to the cogeneration and absorption system of an ammonia chiller redesigned from industrial specifications to commercial specifications has been estimated to have a payback for the combined system of 3 to 6 years. This new ACES technology could be ready for commercialization within 3 years given appropriately targeted levels of R,D&D. There is good indication that most of the new ACES technologies, although more capital intensive than current heating and cooling supply systems, will also be competitive with those existing systems. Thus, they can be expected to be implemented by the private sector without public subsidy beyond the cost of research, development and demonstration.

Current Status of ACES Technology

However, the U.S. has much to do before the significant economic and environmental potential of the new generation of ACES technology can be realized by American cities. Regrettably, the DOE R&D programs that supported the development of these technologies in the late 1970s were first drastically cut by 90% and then eliminated altogether over the last decade. Most of the progress in this field has been achieved in Western Europe, where governments supported the development of advanced community energy systems throughout the 1980s. There has also been some progress in the U.S., but these achievements are largely the result of efforts expended by the private sector and state governments.

At present a number of European countries have developed community scale, renewably energized heating and cooling systems nearly to commercialization. Thus, it is likely that the first solar heated cities in the industrialized world will not be located in the sunny and warm American South and Southwest, but in cloudy and cold Sweden and Denmark.

The European countries at the forefront of the development of new ACES technologies have also been the leaders in the development of the previous generation of community energy systems, which are known as "cogeneration and district heating" systems. Several of these countries extensively employ cogeneration and district heating to great advantage in the energy efficiency and economy of building heating supply. For example, Denmark supplies 50% of its buildings using this technology, Sweden 40%, Finland 30% and (formerly West) Germany 20%. Although current cogeneration and district heating technology can nearly double the efficiency of building heating compared with individual building boilers, new ACES technology can increase energy supply efficiency by approximately 250% for both heating and cooling compared with conventional systems. All of the European countries mentioned maintain significant R,D&D programs in ACES technology. Moreover, several of these countries are in the process of commercializing the first of the new systems.

Although much progress has been made by the Europeans in the development of ACES technology, the new systems are designed to fit European economic, energy supply, climatic and urban physical characteristics and thus are not readily transferable to the U.S. as presently designed. However, the U.S. has the opportunity to learn from important European experience in this field and modify technology as needed to fit American conditions.

ACES Technology Research, Development and Demonstration Requirements

In order to employ the new technology in the U.S., it will first be necessary to adapt the work of the Europeans in this field to the energy, economic, climatic and physical realities of American cities. For example, it will be particularly necessary to develop new systems for community-scale air conditioning supply which is not employed in Europe.

The U.S. must initiate an ACES technology R,D&D program that is equal to the task. It has been estimated that such a program will cost \$10 million per year for 5 years for a total of \$50 million (see Appendix 4). Significant results in the form of commercially available ACES technology can be expected within a few years. If the goal is to acquire an entire range of technology which could be used by cities in virtually all regions of the U.S. to attain levels of energy efficiency and reliance on renewable energy sources which qualify as sustainable over the long term, then it will be necessary to undertake the comprehensive R,D&D program outlined in Appendix 4.

The National Economic Opportunity Represented By ACES Technology

The impact of new ACES technology on American economic productivity promises to be so large that there could be serious consequences for not embarking upon such a strategy. The energy efficiency, fuel saving, environmental impact mitigation and economic benefits of ACES are so great that if the U.S. does not develop the technology it is likely that others will do it for us--at a price. We could find ourselves having to pay for expensive imports of similar technology that has been developed and manufactured by other countries with active ACES technology R,D&D programs such as Japan, Germany, Sweden, Finland and Denmark. This very outcome has already happened with one ACES technology, absorption chilling. As a result of America's lack of R,D&D in absorption chilling

technology, the Japanese have already taken over this important market which was formerly dominated by American manufacturers. If this is allowed to occur with ACES technologies, the impact of new ACES technology on the American economy will be significantly blunted because these systems will not be manufactured in America. Moreover, the U.S. will also forego the benefits of exporting billions of dollars of ACES to other nations as well as the many spin off technologies which ACES R&D will doubtlessly generate. To obtain the full impact of new ACES technology we will have to develop our own technology tailored to our own needs and conditions.

The potential for increased energy efficiency, energy savings and economic productivity from ACES technology is so significant that it is ignored only at our peril. Without increased economic productivity in the urban areas that could be served by the new ACES utilities, we can expect further economic stagnation. However, with such systems in place, the monetary savings generated will provide the investment capital for a whole host of further investments, economic productivity gains and increases in the prosperity of some of America's most economically deprived and threatened citizens. The cities served by ACES utilities will also gain the additional economic advantage of being greatly insulated against increases in the price of energy which can certainly be expected over the 30- to 50-year lifetime of the new energy supply infrastructure.

The experience of other countries with related technology and the potential exhibited by ACES make it apparent that these systems should be included as a major component in any effort to revive America's urban economies. By making our cities more efficient in their use of energy, we will make the American economy more productive, reduce oil imports, improve the international balance of payments, and make our economy more competitive in the international marketplace. ACES technologies can make the infrastructure that supports our urban economies much more efficient, productive, environmentally compatible and capable of stimulating and sustaining economic growth. A prerequisite for tapping this potential is the establishment of an ACES technology R,D&D program equal to the task of putting all of America's cities on the path to a sustainable energy and economic future.

TECHNICAL APPENDICES

ADVANCED COMMUNITY ENERGY SYSTEMS

R,D&D PROGRAM RECOMMENDATIONS

APPENDIX 1

EFFICIENCY OF ADVANCED COMMUNITY ENERGY SYSTEMS TECHNOLOGIES COMPARED WITH CONVENTIONAL SYSTEMS

System Type	Description of Application	Overall System Efficiency/ "Thermal" COP*
(Examples of Conventional Systems)		
1. Gas/Oil-Fired Boiler	Supplies heat at 80% efficiency	0.8
2. Steam Turbine Power Plant	33% (0.33) power generating efficiency	
	a) electricity used for electric resistance heating efficiency (100%)= (1.0 COP X 0.33) =	0.3
	b) electricity used for air source heat pump (Mid Atlantic location) (2.2 COP X 0.33) =	0.7
	c) electricity used to drive an electric chiller using freon or "drop-in" refrigerants with good efficiency supplying air conditioning to a commercial building (4.5 COP X 0.33) =	1.5
	c) electricity used for best available conventional electric chiller using "drop-in" refrigerants as a substitute for CFCs (6.0 COP X 0.33)=	2.0
(Examples of ACES Technology)		
3. Small Scale (50-500 kw) Gas/Oil-Fired Cogeneration	42% (0.42) power generating efficiency, 54% heat recovery (24% water jacket, 30% exhaust heat) for overall prime mover efficiency of 96%	
	a) electricity used for electric heat pump/chiller (3.0 X 0.42) = 1.26, heat used for space heating or domestic hot water (DHW) = 0.54 + 1.26 =	1.8
	b) electricity used for ammonia-based electric chiller (6.0 X .42) = 2.52, heat used for space heating or DHW = 0.54 + 2.52 =	3.1

Appendix 1 (continued)

System Type	Description	Efficiency/ "Thermal" COP
4. Small Scale/Dual Fueled Cogeneration & Heat Activated Chiller Technology	<p>42% (0.42) power generating efficiency, 54% heat recovery, for an overall prime mover efficiency of 96%; electricity used to power ammonia vapor compression chiller, (6.0 COP X 0.42) = 2.52 + heat activated chiller efficiency using the 54% of the energy available from the cogenerator as waste heat, 24% from water jacket, 30% from exhaust heat.</p> <p>a) single effect absorption chiller (ac) (0.65 COP) using waste heat from engine water jacket, $0.65 \times .24 = 0.156$; plus use of 70% engine exhaust heat (30% of energy input) = $0.7 \times 0.3 \times 0.65 = 0.136$; DHW from 15% exhaust heat = $0.15 \times 0.30 =$ $0.045 + 0.136 + 0.156 + 2.52 =$</p> <p>b) double effect ac (1.34 COP) uses 70% of exhaust gas (30% of energy input) at 1.34 COP = $0.7 \times 0.3 \times 1.34 = 0.28$; also uses all water jacket heat = $0.24 \times 1.34 = 0.32$; DHW produced from 15% of exhaust gas = $.15 \times 0.3 = 0.045$ $0.28 + 0.32 + 0.045 + 2.52 =$</p> <p>c) triple effect ac, 1.8 COP, uses 30% of waste heat from engine exhaust (0.30 of energy input) = $1.8 \times 0.3 \times 0.3 = 0.162$; double effect cycle uses 40% of exhaust heat = $(1.34 \times 0.3 \times 0.4) = 0.161$; double effect cycle uses water jacket heat $0.24 \times$ $1.34 = 0.32$; DHW from exhaust heat: $0.15 \times$ $0.3 = 0.045 + 0.32 + 0.161 + 0.162 + 2.52 =$</p> <p>d) Jet refrigeration system efficiency, 0.5 COP operating off exhaust gas, 0.30 of total energy input, of which 0.7 is usable ($0.5 \times 0.3 \times 0.7$) = 0.105 COP; water jacket heat ($0.24 \times 0.5 = 0.120$; DHW from exhaust ($0.15 \times 0.30 = 0.045$; $0.045 + 0.120 + 0.105 + 2.52 =$</p>	<p>2.8</p> <p>3.2</p> <p>3.2</p> <p>2.8</p>

Appendix 1 (continued)

System Type	System Description	Efficiency/ "Thermal" COP
5. Large Scale Steam Turbine Cogeneration Retrofit to Low Temperature District Heating	Obtain cogenerated heat from power plant condenser water at 120F; distribute in uninsulated pipes to buildings which either use 120F water directly for heating or use multi-stage heat pumps. Cooling obtained from natural cycle cooling systems and/or ammonia central plant refrigeration.	3.0- 5.0
6. Direct Urban Cooling Using Cold Ocean Waters	Honolulu Ocean Water Cooling System (proposed) 40F water obtained from deep ocean several miles from shore, pumped through undersea & on shore pipeline to supply building air conditioning (75% fuel savings compared with existing electric ac--estimated to have an overall system COP of 1.5)	6.0
7. Natural Cycle Cooling System (spray pond)	System captures winter cold as chilled water & stored in large ponds or aquifers from winter to summer or collected at night for use during the day. Chilled water is then used in specially "tuned" refrigeration systems designed to utilize a wide range of chilled water temperatures at high efficiency and used directly in urban cooling applications or as source of pre-cooling for an electric chiller and/or cogeneration/ammonia chilling/absorption system.	5.0- 7.5
8. Central Solar Heating With Seasonal Storage (Modified Solar Pond)	Solar pond with floating insulation and plastic/metallic foil solar collectors collects solar heat year round and stores heat from summer to winter in pond water. Heat from pond can be used directly as a source for a community heating system or may employ a heat pump, with a cogenerator to boost temperatures to usable levels in winter.	5.0- 7.5

Appendix 1 (continued)

System Type	System Description	Efficiency (COP)
9. Natural Cycle Cooling System (ice/spray pond) (northern location)	System captures winter cold by spraying water into cold winter air, making ice which is collected in large piles which are stored from winter to summer to supply communities and entire urban areas with building air conditioning via ice slurry thermal distribution.	5.0- 10.0

* Note: "C.O.P." is the abbreviation for "coefficient of performance" which is a measure of the efficiency of an energy conversion system. In this case it represents the ratio of delivered energy to primary energy consumed. Thus, COP as it is used here refers to the "overall" energy efficiency of the energy production and distribution system or the "thermal COP" rather than the more narrow meaning usually assigned the term which refers to the electrical COP. The electrical COP measures the ratio of delivered energy to electrical energy consumed. Hence, it masks inefficiencies in electrical generation and distribution processes. The thermal COP accounts for these inefficiencies and results in a more accurate view of overall energy supply system efficiency.

The thermal COP calculations in the foregoing table reduce all energy inputs to heat or cold which enables the efficiency of each system to be compared on the basis of heating or cooling supply efficiency. Using thermal COP, the efficiency of a 80% efficient boiler becomes 0.8 COP and the efficiency of an small residential air-source electric heat pump located in the Mid Atlantic region with a seasonal electrical COP of 1.9 is converted to a thermal COP of 0.63 when the average efficiency of electrical generation and distribution (33%) is taken into account.

Levels of efficiency greatly in excess of 100% or 1.0 COP are possible because advanced energy conversion systems are designed to use a minimal amount of primary energy and to capture a maximum amount of energy from environmental sources. This primary energy is used to increase or decrease the temperature of heat or cold collected from the environment by relatively small amounts to levels required by buildings for space heating, air conditioning or domestic hot water supply. Another way to minimize the use of primary energy is to employ a cascade of thermal energy among energy conversion systems in a way in which the waste heat of one component system serves as the thermal energy input to another energy conversion system. An example of this type of system would be a cogeneration system in which the cogenerated heat serves as the input to a heat activated chiller.

The more heating or cooling an energy supply system is able to obtain from the environment while minimizing the use of fossil fuels, or the more energy that can be cascaded among energy conversion processes, the greater the efficiency or COP of the process. The highest levels of energy efficiency are obtained not only by maximizing the amount of energy in the form of heating or cooling obtained from the environment but also by minimizing the qualitative requirements (temperature) of the end use application. The closer supply and end use

temperatures are, the higher the efficiency, assuming that appropriate supply systems which maximize environmental thermal energy and minimize primary energy are used.

The systems considered in the accompanying chart are by no means exhaustive. Rather, there are many very promising hybrid systems which have not been considered. Numerous hybrid systems could be designed by mixing and matching systems included in Appendix 1 in ways which make sense in terms of efficiency, economy or environment.

In addition, the above table does not include an exhaustive analysis of the full efficiency of some systems. For example, the amount of thermal energy which can be obtained by running absorption chillers in reverse as heat transformers for the production of space heat in winter has not been included. The use of an absorption chiller in this manner would considerably boost the energy efficiency of cogeneration/absorption chillers when employed in the heating mode with a Central Solar Heating Plant with Seasonal Storage (CSHPSS) as a heat source. Given these caveats, the systems which have been included in Table 1 are considered to be the most important by many leading American and European experts.

APPENDIX 2

ACES VS. CONVENTIONAL HEATING AND COOLING SUPPLY SYSTEMS: ENERGY EFFICIENCY IMPROVEMENTS AND FUEL SAVINGS

The energy efficiency improvements and fuel savings which can result from the substitution of ACES for conventional heating and cooling systems are calculated as follows.

I. Air Conditioning Supply

ACES # 1 consists of a small (100 kw dual fueled (gas/oil) diesel engine cogeneration system (42% electrical generating efficiency) powering an electric ammonia chiller (6.0 COP) with a double effect absorption chiller with a COP of 1.34 operating off cogenerated waste heat. This system is estimated to have a COP of 3.2. (see Appendix 1, Case 4(b))

ACES # 2 consists of a Natural Cycle Cooling System (NCCS) employing a spray pond which supplies water at a temperature of 50F to a "tuned" ammonia chiller designed for high efficiency operation using a wide range of pre-cooling temperatures. Normal COP of 6.0 ammonia chiller from ACES #1 is at least doubled to 12.0. Power for the ammonia chiller is supplied from a cogenerator operating at a 42% electrical generating efficiency and employing a double effect absorption chiller (COP 1.34) operating off cogenerated waste heat. During late fall, winter and early spring operation the system can supply air conditioning directly, by-passing the chiller entirely and using power only for spraying and pumping. The energy efficiency of this near term NCCS is estimated to be 6.0 COP.

The conventional system is an electric air conditioner with an electrical COP of 4.5 supplied with power from the 33% efficient electrical grid. Thus, the overall efficiency of this system is a COP of 1.5. This energy efficiency level is midway between a residential air source electric air conditioning system with a COP of 1.0 overall (electric COP 3.0 X 0.33 electrical generating system efficiency) and a state-of-the-art electric chiller with an overall COP of 2.0 (electric COP 6.0 X 0.33 electric generating system efficiency). Thus, a COP of 1.5 is assumed to be fairly typical.

Air Conditioning Case # 1

A) ACES # 1: COP 3.2

B) Conventional Electric AC System: COP 1.5

Energy Efficiency Improvement:

$$\frac{A - B}{B} = \text{energy efficiency improvement}$$

$$\frac{3.2 - 1.5}{1.5} = \frac{1.7}{1.5} = 1.13 \text{ or}$$

113% energy efficiency improvement

An equivalent way of expressing this efficiency improvement is to calculate the percentage of fuel saved by the new technology. This calculation is performed as follows:

Fuel Savings

$$\frac{\frac{1}{B} - \frac{1}{A}}{\frac{1}{B}} = \frac{\frac{1}{1.5} - \frac{1}{3.2}}{\frac{1}{1.5}} = \frac{0.667 - 0.3125}{0.667} = \frac{0.355}{0.667} = 0.5322 \text{ or}$$

53% fuel savings

Case # 2

A) ACES # 2: COP 6.0

B) Conventional Electric AC System: COP 1.5

Energy Efficiency Improvement:

$$\frac{A - B}{B} = \text{energy efficiency improvement}$$

$$\frac{6.0 - 1.5}{1.5} = \frac{4.5}{1.5} = 3.00 \text{ or}$$

300% energy efficiency improvement

Fuel Savings

$$\frac{\frac{1}{B} - \frac{1}{A}}{\frac{1}{B}} = \frac{\frac{1}{1.5} - \frac{1}{6.0}}{\frac{1}{1.5}} = \frac{0.667 - 0.167}{0.667} = \frac{0.50}{0.667} = 0.7496 \text{ or}$$

75% fuel savings

II. Space Heating Supply

ACES # 1 consists of an advanced small scale cogeneration system with a 42% electrical generating efficiency supplying power to an ammonia heat pump with a COP of 3.0 operating off sewage water (60F) and recovering 0.54 of cogenerated heat for use in space heating. The overall COP of this system is a 1.8 COP.

ACES # 2 consists of a Central Solar Heating Plant With Seasonal Storage (CSHPSS) ("chips") which supplies low temperature heat at about 100F to an ammonia heat pump with a COP of 10.0 which is supplied with power from a cogeneration system operating at 42% electrical generating efficiency (0.42 X 10.0 = 4.20 COP). Waste heat from the cogenerator is also supplied (54% of cogeneration energy system input = + 0.54 COP). In addition, the system is assumed to operate at much higher temperatures, directly supplying heat to end uses and by-passing the heat pump during the late spring, summer and early fall. The overall energy efficiency of this near term CSHPSS is estimated to be 5.0 COP.

The conventional Heating Supply system is assumed to have an energy efficiency of 0.72 COP. A heating boiler of good efficiency has a COP of 0.8. An air source heat pump operating in the Mid Atlantic States will have a seasonal electrical COP of 1.9 and thus will have an overall COP of 0.63. A COP of 0.72 is assumed to be an average heating system efficiency.

Space Heating Case # 1

A) ACES # 1: 1.8 COP

B) Conventional electric heat pump and heating boiler 0.72 COP

Energy Efficiency Improvement:

$$\frac{A - B}{B} = \text{energy efficiency improvement}$$

$$\frac{1.8 - 0.72}{0.72} = \frac{1.08}{0.72} = 1.50 \text{ or}$$

150% energy efficiency improvement

Fuel Savings

$$\frac{\frac{1}{B} - \frac{1}{A}}{\frac{1}{B}} = \frac{\frac{1}{0.72} - \frac{1}{1.8}}{\frac{1}{0.72}} = \frac{1.39 - 0.556}{1.39} = \frac{0.834}{1.39} = 0.60 \text{ or}$$

60% fuel savings

Space Heating Case # 2

A) ACES # 2: 5.0 COP

B) Conventional electric heat pump and heating boiler 0.72 COP

Energy Efficiency Improvement:

$$\frac{A - B}{B} = \text{energy efficiency improvement}$$

$$\frac{5.0 - 0.72}{0.72} = \frac{4.28}{0.72} = 5.94 \text{ or}$$

594% energy efficiency improvement

Fuel Savings

$$\frac{\frac{1}{B} - \frac{1}{A}}{\frac{1}{B}} = \frac{\frac{1}{0.72} - \frac{1}{5.0}}{\frac{1}{0.72}} = \frac{1.39 - 0.20}{1.39} = \frac{1.19}{1.39} = 0.856 \text{ or}$$

86% fuel savings

Average ACES cooling system efficiency improvement:	206%
Average ACES cooling system fuel saving improvement:	64%
Average ACES heating system efficiency improvement:	372%
Average ACES heating system fuel saving improvement:	73%
Average ACES cooling & heating system efficiency improvement:	289%
Average ACES cooling & heating system fuel saving improvement:	68.5%

As a result of the foregoing analysis, an average ACES efficiency improvement of 290% will be used to describe the impact of ACES on building energy efficiency. The average fuel saving for both heating and cooling ACES will be assumed to be 70% for purposes of calculating overall energy savings from ACES. It should be noted that the ACES technologies used as examples for comparative purposes in the above calculations are near term ACES, that is, ACES which can be developed to commercial viability well within the time and funding specified by the proposed ACES R,D&D program, i.e. 5 years and \$50 million. However, it is likely that more time and money would produce even better results.

APPENDIX 3

ENERGY AND MONETARY SAVINGS FROM ADVANCED COMMUNITY ENERGY SYSTEMS

U.S. Energy Consumption 1990: 80 Quadrillion Btus.....80 Quads
Average U.S. Energy Cost \$5/MMBtu, \$5 billion/Quad
Total U.S. Energy Costs, 1990:.....\$400 billion
Building Sector Energy Consumption:.....29 Quads
Building Sector Energy Costs.....\$145 billion

Residential Building Sector Energy Consumption

a) Space Heating.....6.28 Quads
b) Space Cooling.....1.74
c) Domestic Hot Water.....2.69
d) Electricity for Appliances & Lighting.....6.74
Total Consumption.....18.00 Quads

Space heating, domestic hot water and space cooling
can be supplied via ACES technology to residential
buildings. The total market for these services
in 1990 was (a+b+c=)..... 10.7 Quads

Commercial Building Sector Energy Consumption

a) Space Heating... ..3.28 Quads
b) Space Cooling.....2.38
c) Domestic Hot Water.....0.19
d) Lighting.....3.50
e) Other Electric.....1.70
Total Consumption.....11.00 Quads

Space heating, domestic hot water and space cooling
can be supplied via ACES technology to commercial
buildings. The total market for these services
in 1990 was (a+b+c=).....5.85 Quads

The total residential and commercial building
sector demand for space heating, domestic hot water
and space cooling in 1990 was.....16.55 Quads

If the potential residential and commercial
thermal energy market penetration by ACES
technology in the U.S. reaches 25% then
ACES technology can supply.....4.13 Quads
4 Quads of energy production annually is
valued at \$5 Billion/Quad or.....\$20 billion

The annual value of the energy savings (assuming
a 70% fuel savings due to
ACES technology is (\$20 billion X 0.70).....\$14 billion

Appendix 3 (Notes)

Note: Although no comprehensive studies of the market potential or penetration of new ACES technology have been conducted for U.S. markets, there are several important clues to this question which were used to derive a "ballpark" estimate of that potential to illustrate the benefits of ACES technology. First, there is the experience of several Western European countries with the ACES predecessor technology-- cogeneration and district heating. Such systems supply 50% of Denmark's buildings with heat. In Sweden the figure is 40%; Finland, 30%; and (West) Germany, 20%. The population-weighted average of the market penetration of cogeneration and district heating in these countries averages 25% of the total potential market in all of these countries for residential and commercial building heating.

Another indicator of ACES market potential is a 1980 study of the market potential of cogeneration and district heating in the United States. (Teotia, A.P.S., et. al., "Cogeneration Energy Systems Show Promising Market Potential In Residential and Commercial Sector Over Next 25 Years", Argonne National Laboratory, 1980.) This study estimated the market potential at 6.6 Quads for cogenerated power and heat to the U.S. residential and commercial building energy market. In 1990 the supply of 6.6 Quads to the American residential and commercial building heating and cooling markets constitutes 40% of a market for 16.5 Quads of thermal energy.

Since the technical characteristics of ACES and cogeneration and district heating and cooling technology are similar in many respects, and the energy efficiency and economic advantages are much greater with ACES than with cogeneration and district heating and cooling, it would seem that a level of technical market potential for ACES in the vicinity of 40% of the building thermal energy market would not be unreasonable. However, the actual level of market penetration of cogeneration and district heating in those Western European countries reviewed above may be a better gauge of what is actually attainable. Thus, a figure of 25% for the market potential for ACES technology in the U.S. might be a more realistic estimate.

The task of quantifying the economic benefits of ACES technology is beyond the scope of this paper. The market potential of this technology appears to be so great that an exhaustive analysis of that potential should be given a high priority before a new ACES Technology R,D&D program is initiated. The task of estimating economic benefits should be considered integral to the task of more precisely determining the market potential and penetration of ACES technology. It is strongly recommended that the procedures for more precisely determining technical market potential and economic market penetration for ACES technology be those identified in the report: "District Heating and Cooling: Market Potential and Penetration Methodology", Final Report, by Philip D. Metz and Jack Gleason, Brookhaven National Laboratory, March, 1986 (BNL 51999).

APPENDIX 4

ADVANCED COMMUNITY ENERGY SYSTEMS TECHNOLOGY RESEARCH, DEVELOPMENT AND DEMONSTRATION PROGRAM OUTLINE

In Appendix 4, the most important new ACES technologies are listed and the amount of time and funding required to develop and demonstrate these technologies is noted.

System	R&D Task	Period	Funding
ACES Market Research & R,D&D Program Planning	Conduct Market Potential & Penetration Study;	1/2 year	\$0.15m
	Formulate Detailed R,D&D plan for each ACES technology. Conduct updated market analyses and technology assessments as needed.	5 years	\$0.35m
Cogeneration	Small scale (50-500kw), 42% electrical efficiency, dual fueled, turbocharged, aftercooled, low NOx emissions, complete electronic control and artificial intelligence.	2 years	\$2.0m
Absorption Chilling	Single effect, COP 0.65;	1 year	\$1.5m
	double effect, COP 1.26; &	2 years	\$1.5m
	triple effect, COP 1.80, all designed to use low cost plastic film/metallic foil heat exchangers & all integrated with high efficiency cogenerator.	3 years	\$3.0m
Jet Refrigeration	COP 0.6, designed to use cogenerated waste heat	3 years	\$3.0m
Heat Activated Water Distillation	Low cost, high efficiency multi-effect distiller powered by cogenerated waste heat or solar heat. Redesigned to use low cost plastics.	2 years	\$2.0m
Natural Cycle Cooling Systems (ice & spray ponds)	Build & test commercial scale systems; develop advanced thin film plastic/metallic foil solar collectors; integrate with cogen. systems and related ammonia heat pump and chiller technology.	3 years	\$7.5m

Appendix 4 (continued)

System	Description	Period	Funding
Central Solar Heating, Seasonal Storage & Ammonia Heat Pumps	Build & test prototypes; develop advanced thin film plastic/metallic foil solar collectors; integrate with cogen. systems and related ammonia heat pump technology.	3 years	\$7.5m
Solar Absorption Chilling	Design, build & test prototypes, and commercial scale systems using single effect absorption technology	2 years	\$2.5m
Integrated Renewable Energy Systems	Design, build & test commercial scale systems integrating a full spectrum of renewable and high energy efficiency ACES technologies.	2 years	\$2.5m
Ammonia Vapor Compression, Chilling & Heat Pumping	Adapt Industrial Equipment to building ac requirements & integrate with cogeneration & sources of environmental cold and solar heat.	2 years	\$2.5m
Large Scale, Low Temperature Cogen. & District Heating	Study numerous utility steam turbine power plants & estimate low temp. cogen. conversion costs; refine building retrofit strategies; design, implement & test 1 case.	4 years	\$5.0m
District Heating & Cooling Distribution & End Use Systems	Develop, test & commercialize low cost, uninsulated piping systems; innovative building system conversion methods; new distribution media & additives & in-situ pipe inspection & repair system.	4 years	\$9.0m
Total.....		5 years.....	\$50.0m

APPENDIX 5

ACES TECHNOLOGY R,D&D PROJECT DESCRIPTIONS

1. Market Potential & Penetration Analysis & R,D&D Program Planning
2. Cogeneration Technology For The Buildings Sector
3. Heat Activated Chillers For Use With Small Scale Cogeneration
4. Heat Activated Water Distillation Technology
5. Renewably Energized Community Heating & Cooling Systems
6. Ammonia Vapor Compression Technology for Building Air Conditioning
7. Large Scale, Low Temperature Cogeneration & District Heating
8. Community Scale Thermal Distribution & End Use Systems

ADVANCED COMMUNITY ENERGY SYSTEMS R,D&D PROGRAM IN
MARKET POTENTIAL AND PENETRATION ANALYSIS AND R,D&D PROGRAM PLANNING

An essential component of a successful technology development program is a multi-year R,D&D Program Plan based upon an analysis of technical opportunities balanced with an analysis of market conditions. The goal of the Market Potential and Penetration Analysis and R,D&D Program Planning Project for Advanced Community Energy Systems (ACES) will be to identify those technologies which have the greatest potential in terms of their energy efficiency, environmental benefit, economic competitiveness and institutional feasibility. Detailed profiles of both existing and theoretical systems will be assembled and the degree of technical difficulty and cost of development to the stage of commercial viability will be determined. Particular attention will be paid to an analysis of the energy efficiency of new ACES systems and the R,D&D activities undertaken in ACES abroad, particularly in western Europe and Japan which have made great strides in recent years in developing ACES technologies. Communities located in markets which are climatically and physically representative of diverse types in the U.S. will also be selected and analyzed. ACES technologies which appear to have the greatest potential will be analyzed in the context of the selected communities and climates to determine which community types, climatic regions and technologies offer the best matches.

The analysis of market potential will proceed on the basis of the above analysis to determine that part of the total space conditioning market where a given system is both technically feasible and has lowest delivered energy cost. This will provide a "best-on-best" estimate of the ACES potential in the absence of any non-economic impediments. A delivered energy cost for each ACES will be computed for each community type or "market segment." Market segments where the ACES technology has the lowest cost will be the basis of an analysis of market potential. Only those technologies with significant levels of market potential will be analyzed for market penetration.

Market penetration is defined as "what is likely to happen," i.e. how many potential customers will actually purchase the technology. The first task in this analysis is to compile an information base of the real impediments to ACES technologies. These impediments include, in addition to cost, such factors as regulatory barriers and institutional barriers. The analysis will also take note of significant market and regulatory factors which constitute opportunities to propel certain ACES technologies rapidly into the marketplace.

The most appropriate market penetration model for the proposed analysis is the consumer preference model. It is the only model which can provide an information base of the impediments and opportunities for ACES technologies in the U.S. Consumer preference models forecast market penetration by determining consumer preferences or attitudes toward product attributes, e.g. cost, efficiency, environmental intrusion, size, safety, and converting these preferences into predictions of behavior. These models are widely and successfully used in commercial market research. In recent years they have been used by EPRI for analyzing a variety of energy technologies. They can provide valuable guidance in formulating detailed ACES Technology R,D&D plans by identifying those technologies which are probable winners and losers. As a result the R,D&D Plan can be focused sharply on those technologies which have a high probability of technical and market success.

The proposed project is a necessary first analytical step at the outset of the proposed 5 year, \$50 million ACES Technology R,D,&D Program which is proposed by BNL to the DOE. It will result in a significantly more effective program than would otherwise be possible. It will enable the technologies which are developed in the ACES program to be explicitly designed to meet the needs of actual market segments. As a result, there will be a high degree of confidence that the technologies developed in the laboratory will experience a high degree of success in the marketplace.

This project will have an initial phase of 6 months duration and a continuing overview role for the duration of the program. Total cost is \$500,000.

Bibliography:

Metz, Philip D. and Jack Gleason, "District Heating and Cooling: Market Potential and Penetration Methodology: Final Report" for USDOE by Dept. of Applied Sciences, Brookhaven National Lab., BNL 51999, (Mar. 1986).

Metz, Philip D., Jack Gleason, et. al., "District Heating and Cooling Technology Selection and Characterization: Final Report", for USDOE by Dept. of Applied Sciences, Brookhaven National Lab., BNL 52001, (Mar. 1986).

Gleason, Thomas C. J., "Cogeneration and Beyond: The Need and Opportunity For High Efficiency, Renewable Community Energy Systems", for USDOE and Energy Efficiency and Conservation Div., Dept. of Applied Science, Brookhaven National Lab., June, 1992.

ADVANCED COMMUNITY ENERGY SYSTEMS R,D&D PROGRAM IN
COGENERATION TECHNOLOGY FOR THE BUILDINGS SECTOR

Cogeneration is the simultaneous production of electricity and heat from a single energy conversion process. The energy efficiency of cogeneration processes can be very high in comparison to typical electric generating plants or conventional heating and cooling systems. This is because cogenerated heat is recovered and either used directly in building heating or converted into air conditioning. Efficiency advantages of 100% and fuel savings of 50% drive the economic competitiveness of the new generation of building sector cogeneration technology proposed for development by BNL.

Over the last decade cogeneration boomed in the industrial and independent-power sectors because of the Public Utilities Regulatory Powers Act (PURPA), with over 25,000 MW of cogeneration capacity installed. The boom in cogeneration has left all but untouched the largest potential market for cogeneration--the building sector heating and cooling market--which is at least as large. However, several technical factors have prevented the penetration of cogeneration into the buildings sector.

The first factor is the scale of technology encouraged by the PURPA law. These systems have tended to be much larger (from several tens to hundreds of megawatts) than the building sector can accommodate at this time. The most appropriate scale of cogeneration for the buildings sector is for individual units in the range of 50 to 500 kw and combinations of such units up to several megawatts. In this size range the most appropriate type of cogeneration system is the diesel engine fueled by either oil or natural gas or by a combination of gas and oil.

The initial technical task for this project is to modify diesel engine technology for building heating and cooling service by developing a dual-fuel engine of low horsepower (100 to 200 HP) with multi-fuel (gas and oil) capability and a high electrical conversion efficiency (42%). A dual-fuel engine utilizing a mixture of 20% diesel and 80% natural gas can operate with very high efficiency. By utilizing the diesel compression ignition, rather than a high voltage spark ignition, the most troublesome component of the internal combustion engine is eliminated. These types of multi-fuel engines have been built in the past, but only in very large sizes. The time is ripe to develop a smaller version of such an engine utilizing the same principles of combustion for use in building heating and cooling.

The proposed cogenerator forms the highly efficient mechanical heart of a new line of advanced, energy-efficient, low-cost gas-fired air-conditioning systems. When a cogenerator of this type (42% electrical efficiency) is used to power a 6.0 COP electric ammonia chiller, and a advanced heat activated, multi-effect chiller uses the cogenerated heat, a very high overall efficiency of over 3.0 COP results. In such a case the system operates essentially as a high efficiency gas-fired air conditioner. In comparison, an electric chiller with a COP of 5.0 that is supplied with electricity from a 30% efficient power plant has an overall COP of 1.5. In such a case the gas-fired cogeneration/air conditioning system is 100% more efficient and saves 50% of the energy required by the electric air conditioner.

Current cogeneration technology of the proposed type and scale suffers from two practical problems--expensive installation and excessive maintenance. The problems of installation can be resolved by placing the cogenerator in vertical configuration. The problem of maintenance is addressed by using technologies for predictive maintenance such as prolific use of on-board sensors, artificial intelligence data processing and data collection and monitoring via telephone. These techniques permit the conversion of normal periodic maintenance scheduling to more exact and cost-effective predictive maintenance procedures.

One of the primary impediments to widespread use of cogeneration technology in the buildings sector is the lack of appropriate heat-activated chilling technology. Therefore, BNL has proposed an R,D&D program for this technology for use with small scale cogeneration technology for the building sector.

The problems of environmental pollution will be addressed by constructing water-cooled, proximal port exhaust heat exchangers by which the water vapor in the fuel can be induced to condense, thereby trapping the pollutant gases in a manner more efficient than the normal scrubbing techniques.

The BNL Advanced Community Energy Systems (ACES) R,D&D program in cogeneration technology for the buildings sector will cost \$2 million and take 2 years to complete. An advanced cogeneration system marked by very high levels of efficiency and reliability and very low cost and low pollution will then be made commercially available. This equipment will serve as the heart of the new generation of gas fired, heat activated air conditioning and refrigeration technology which will be developed in other concurrent, closely related BNL ACES R,D&D projects.

Bibliography:

Andrews, John A., P. Aalto, T.C.J. Gleason and A.J. Skalafuris, "Modular Cogeneration In District Heating and Cooling Systems", for U.S. Department of Energy, Office of Buildings and Community Systems, by Department of Applied Science, Brookhaven National Laboratory Report # 52133, December, 1987.

Gleason, Thomas C. J., "Cogeneration and Beyond: The Need and Opportunity For High Efficiency, Renewable Community Energy Systems", for Energy Efficiency and Conservation Division, Department of Applied Science, Brookhaven National Laboratory, June, 1992.

ADVANCED COMMUNITY ENERGY SYSTEMS R,D&D PROGRAM IN
HEAT ACTIVATED CHILLERS FOR USE WITH SMALL-SCALE COGENERATION

Advanced heat-activated air conditioning technologies offer the United States the opportunity to simultaneously regain the competitive advantage with Japan in the domestic and international air conditioning market; use abundant domestic supplies of natural gas in a highly efficient manner; and contribute substantially to a resolution of such pressing environmental problems as global warming, stratospheric ozone depletion and local air pollution.

Both the U.S. and international markets for heat-activated chilling equipment are dominated by Japanese manufacturers of single- and double-effect absorption technologies. However, there are significant technical opportunities to greatly improve the energy efficiency and economy of absorption chiller technology as well as to develop other innovative heat activated cooling technologies. These new technologies will enable American manufacturers to beat the Japanese competition on both performance and price. In the process, the U.S. will recapture a market in which it was once the world leader. That market is worth \$250 million in annual sales and it could grow much larger given the new technology proposed for development by BNL.

In addition to the Japanese work, an extensive body of research has been performed in this country, among others by GRI and ORNL. This work will provide a solid basis for the development proposed here, which will require the following additional elements:

- o Air cooling in single-effect chillers for small-scale cogeneration applications.
- o Jet refrigeration as another low-cost alternative for small-scale applications in both cogeneration and mobile chilling.
- o Reduction in heat exchanger costs through development and application of thin-film heat-exchanger technology.
- o Vigorous advancement of pioneering work by ORNL in triple-effect absorption technology, with particular attention to its potential for cost reduction.
- o Integration of these advanced thermally activated cooling technologies with small-scale cogeneration.

The new absorption chilling technologies proposed by BNL will use America's abundant resources of natural gas in a highly efficient manner. When such systems are supplied with heat from a small dual-fuel cogenerator with an electrical generating efficiency of 42% coupled with an electric ammonia chiller with a COP of 6.0, they attain an average efficiency in terms of Coefficient of Performance or COP of 3.0. This compares very favorably with the average overall (generation + utilization) efficiency of electric air conditioning which is liberally estimated to be a 1.5 COP. This 100% efficiency advantage results in a 50% fuel savings and a comparable reduction in air pollution when advanced cogeneration/absorption chilling systems are substituted for conventional electric air conditioning. Furthermore, absorption chillers and other heat activated

systems do not use CFCs and thus also contribute to a resolution of the stratospheric ozone depletion crisis.

In addition to being designed for very high levels of energy efficiency and very low levels of environmental impact, the new line of heat-activated air conditioning technologies will also be very low cost. Low costs will be achieved in the following manner. Initially, very-high-efficiency versions of each of the four heat-activated air conditioning systems will be developed using conventional tubing for heat exchangers. Heat-exchanger tubing constitutes the major cost in heat-activated chillers. Therefore, the second design phase will consist of the substitution of very low-cost, high-efficiency, thin-film, polymer and metallic foil heat exchangers wherever possible for conventional heat-exchanger tubing. This will result in substantial improvements in cost over the initial designs. This final design iteration is essential since thin-film/foil heat-exchanger technology is very inexpensive and the heat exchanger tubing used in conventional chiller designs is the most expensive component of the system. The result of this substitution should be a cogeneration and heat-activated chilling system which is competitive with Japanese absorption systems and electric chillers.

Brookhaven National Laboratory has pioneered the development of thin-film/foil heat-exchanger technology, which constitutes one of the most significant developments in heat-exchanger technology in decades. The correct application of this new heat-exchanger technology promises to make the new generation of high-efficiency cogeneration and heat activated chilling systems very competitive. As a result, the new high-efficiency, gas-fired, CFC-free air conditioning systems will be able to penetrate the market without any financial or regulatory subsidies. The new systems will simply make it more profitable to be efficient and dispense with the use CFCs than not. The energy efficiency and environmental improvements of advanced cogeneration and heat-activated chilling systems will then be market driven rather than regulation or subsidy driven. This should result in accelerated market penetration and more rapid environmental improvements including the phaseout of CFCs. The following pages outline the R,D&D tasks required to develop the four proposed heat-activated building air conditioning systems.

Single-Effect, Air-Cooled Absorption Chiller

No air-cooled absorption machine is presently on the market. This is despite the fact that most potential small-scale absorption chilling applications for building air conditioning do not have cooling towers, since they are too costly to build for such small applications. Therefore, an air-cooled single effect absorber integrated with a cogenerator has the potential to open up a very large market for gas-fired air conditioning which is presently dominated exclusively by electric vapor compression air conditioning systems employing CFCs.

The design goal for the air-cooled, single-effect absorption chiller is for a system of 20 tons of refrigeration capacity supplied with all of its heat from a small dual-fueled diesel-engine cogeneration system. The new cogeneration/air cooled absorption chiller will attain a COP of 0.65, resulting in a system which is significantly more energy-efficient than a comparable 0.65 COP directly fuel-fired Japanese single-effect absorption chiller. The overall energy efficiency of the new system including the new single-effect absorption system operating from cogenerated waste heat can be as high as a COP of 2.85 assuming that the

cogenerator has an electrical conversion efficiency of 42% which is used to drive an ammonia electric vapor-compression air conditioner with a coefficient of performance (COP) of 6.0. It will take 1 year and \$1.5 million to fully develop, integrate and test the new system with cogeneration. This will be sufficient time and funding to develop 2 X 20 ton systems which will be integrated with 2 X 60 kw cogenerators.

Double Effect Absorption Chiller

The second heat-activated chiller project is the development of a double-effect unit of higher coefficient of performance than any presently on the market today. Present Japanese direct fuel fired models obtain efficiencies of 1.1 COP. The double-effect absorption chiller proposed by BNL will be designed to efficiently use cogenerated heat. The double-effect system will require a water-cooled tower and will attain a higher COP of 1.34, as compared with a COP 1.1 of the best Japanese units. The American double-effect absorption system using cogenerated waste heat and in conjunction with a 42% electrically efficient cogenerator and an electric ammonia chiller with a COP of 6.0 will attain an overall system efficiency of 3.16 COP vs the Japanese directly fuel-fired double-effect absorption chiller efficiency of 1.1 COP.

The project design goal will be to develop a machine with approximately 35 tons of refrigeration capacity to use the heat from a 60 kw cogeneration system. This project will cost \$1.5 million and take 2 years. The project will result in the development of a competitive commercial system.

Triple-Effect Absorption Chiller

The third absorption chiller R,D&D project will be to develop a triple-effect dual-loop design of an absorption chiller with a COP of at least 1.8 and perhaps as high as 2.0. The advantage of the triple-effect dual-loop design is that it is constructed as a double-effect system which has an extra internal loop so that the heat-transfer surface required, which principally determines cost, would be no greater than the heat-transfer surface required for a double-effect machine. Thus, the triple-effect absorption chiller should be more cost-effective than the double-effect design, and when combined with cogeneration should make the system competitive with both Japanese absorption chillers and state-of-the-art electric air conditioning.

The proposed research aims principally to discover by chemical analysis several candidate refrigerants which are both effective as well as without environmental impact. When combined with a high-efficiency gas-fired cogenerator and ammonia electric chiller, the combined cogeneration and triple-effect absorption chilling system can obtain an energy efficiency of 3.2 COP. The development program for the triple effect absorption chiller will cost \$3 million and take 3 years.

Jet Refrigeration

Jet refrigeration is a heat activated air conditioning technology for use in automotive air conditioning and truck refrigeration due to its potentially very small size, weight and cost. A jet-refrigeration system can both eliminate

CFCs and improve vehicle efficiency since the device would operate off engine waste heat and not use additional power from the engine.

Most automobile air-conditioning systems use the CFC refrigerant R-22 which is one of the primary culprits in the depletion of the ozone layer. Moreover, automotive air conditioners are driven by electricity, which uses energy in addition to that which is required by the car for producing motive power. The substitution of a jet-refrigeration system driven by engine waste heat for electric CFC air conditioning could improve the automobile efficiency by 5 to 10% assuming that the automobile engine is 100 hp and 20% efficient while the electric chiller is driven by a 1 to 2 hp motor. In the case of trucks it would eliminate the very inefficient small gasoline-engine driven systems used to cool refrigerated trailers.

Jet refrigeration is a cooling technique which relies on an aerodynamic effect called the Bernoulli effect or "chimney effect". The Bernoulli Effect explains the lift of airplane wings and the draw of smoke from chimneys in high winds. By creating a high-velocity stream of air past an orifice connected to a tank of refrigerant (the evaporator) the pressure is induced to fall in the tank below the theoretical vapor pressure for that temperature. As a result the refrigerant in the tank will evaporate and cool until its temperature corresponds to the lower vapor pressure which was induced by the "chimney effect" of the high velocity gas streaming over the mouth of the orifice. To harness this effect, engine waste heat is used to create a high-velocity gas that in turn creates a Bernoulli effect in the refrigerant evaporator inducing cooling.

Promising BNL research has shown that a number of innovations in the nozzle of the jet can be implemented which can improve its performance. There has been no basic advance in the design of the jet-refrigeration nozzle since its employment over a century ago by the railway industry. The calculations indicate that a two-fold improvement in efficiency may be obtained by designing an optimal supersonic aerodynamic nozzle operating at Mach one as the basis for a new jet refrigeration system.

BNL research has indicated that an efficiency of 0.5 COP is possible for a jet-refrigeration system operating off engine waste heat. The manufacturing cost of the very simple jet-refrigeration technology promises to be trivial compared with the cost of complex electric rotating compressor technology--several dollars vs several hundred dollars per ton of refrigeration capacity. The jet-refrigeration device of the future may well consist of a small plastic aerodynamic nozzle (with no moving parts) which can be held in the hand. This jet device would employ environmentally benign refrigerants such as ammonia, alcohol or sodium hydroxide. Other applications are in converting district heating systems into district cooling systems with a simple end-use retrofit to jet refrigeration, and in cogeneration where the combined efficiency of the cogeneration, ammonia chilling and jet refrigeration system can reach a COP of 2.79. The project will cost \$3.0 million and take 3 years.

The total heat activated chilling technology R,D&D program will take 4 years and cost \$9 million.

Bibliography:

Andrews, J. W., P. Aalto, T.C.J. Gleason and A.J. Skalafuris, "Modular Cogeneration In District Heating and Cooling Systems", for USDOE, Office of Buildings and Community Systems, by Department of Applied Science, BNL Report # 52133, Dec., 1987.

Biermann, W., "Water Cooled Absorption Chillers For Solar Applications", ASHRAE Trans. 85, Part I, 1979.

Biermann, W.J., "Air Cooled Absorption Chillers For Solar Cooling Applications", DOE Contract EG-77-C-03-1587, September, 1982.

DeVault, R.C., "Triple Effect Absorption Chiller Utilizing Two Refrigeration Cycles", U.S. Patent 4,732,008.

Leigh, Richard W., et. al., "Cost Reductions in Absorption Chillers, Final Report (June 1984-May 1985), BNL 38345, Brookhaven National Laboratory, May 1986.

Leigh, Richard W., et. al., "Cost Reductions in Absorption Chillers, Phase 2, Final Report (June 1986-June 1988) BNL 42502, Brookhaven National Laboratory, February, 1989.

Skalafuris, A.J., "Innovative Thermal Cooling Cycles For Use In Cogeneration", Brookhaven National Lab., BNL-45271, August, 1990.

Gleason, Thomas C. J., "Cogeneration and Beyond: The Need and Opportunity For High Efficiency, Renewable Community Energy Systems", for Energy Efficiency & Cons. Div., BNL, June, 1992.

ADVANCED COMMUNITY ENERGY SYSTEMS R,D&D PROGRAM IN
HEAT ACTIVATED WATER DISTILLATION TECHNOLOGY

After the use of cogenerated waste heat for absorption chilling the next most important application of cogenerated heat is in heat activated multi-stage flash water distillation. Because distillation of water utilizes low temperature heat, as low as 120F, the process is very energy efficient and thus ideal for supply by cogenerated heat. Three high priority applications for this technology are the concentration of liquid industrial and hazardous waste; the production of potable water for communities; and disaster relief.

Cogeneration and water distillation/concentration technology can be used to cost effectively clean up large volumes of industrial and hazardous wastes. This can be accomplished by producing distilled water from wastes, concentrating wastes (up to 650,000 ppm) and reducing waste volumes drastically.

Communities in arid coastal, island or desert environments face severe constraints and very high costs due to the lack of low cost, high quality potable water. High efficiency cogeneration and distillation technology can supply large volumes of very low cost, high quality potable water to these communities from very low quality polluted or even waste water sources.

Another application is in disaster relief for communities cut off from essential services. A small cogeneration plant with an ammonia chiller, absorption chiller and multi-stage flash distillation plant fueled by trucked in propane, diesel oil or compressed natural gas is all that is required to economically provide a full array of the emergency services required by a community suffering from a significant man-made or natural disaster. These services include electric power, refrigeration, air conditioning, space heat, hot water, steam and potable water.

Although existing multistage flash distillation technology is very energy efficient when coupled with cogeneration it is also expensive. High capital costs will continue to limit market penetration unless the technology is developed further. The principal cost of current desalination equipment is for Cupro-Nickel materials which withstand corrosion for 20-30 years. BNL seeks to replace expensive Cupro-Nickel components wherever possible with low cost, corrosion and temperature-resistant plastics. The result will be a low cost, high efficiency cogeneration/distillation system which can produce large volumes of very pure distilled water at very low cost.

The new distiller/concentrator will employ fiberglass-reinforced PVC materials in cyclonic flash chambers for the multi-stage low temperature flash evaporators. Titanium tubes will be used in a new modular condenser design. Since a multi-stage flash distillation plant is the technological inverse of a multistage absorption chiller it should also be possible to employ thin film polymer and metallic foil heat exchangers developed by BNL for certain components of the distillation system. The resulting system promises to be very low cost, lightweight, free from corrosion and long lived.

The distiller/concentrator will operate at very high vacuum with a maximum top temperature of 140F and a bottom temperature of 85F to 100F depending on the wet bulb temperature. The energy requirements of the new flash distillation

system will be 1 MBtu/hr which will be used to operate a quadruple effect distiller with a nine stage flash evaporator in the third effect. The plant will be small enough (10,000 GPD) for it to be truck mounted with a small cogeneration system, ammonia electric and heat activated chiller systems proposed for development by BNL.

The final stage of the project will be to integrate the new distillation technology with modified solar pond technology developed in BNL's proposed central solar heating plant with seasonal storage project (CSHPSS) and a small photovoltaic power system. The result will be a low cost solar heat driven water distillation system which can supply very low cost, high quality water to communities located anywhere there is land, sun and saline or poor quality water.

The BNL ACES R,D&D program in advanced multi-stage flash distillation technology will cost \$2 million and take 2 years to complete. At the conclusion of this program BNL will make available advanced, commercial, heat-driven, low cost water distillation systems for use in community potable water production and industrial and hazardous waste concentration.

Bibliography:

Williamson, W.R., "Cost Effective Sea Water Desalination: Technology Development Proposal", Triton Int'l., June, 1992.

Leigh, R.W., "Cost Reductions In Absorption Chillers, Phase 2", Final Report, BNL-42502, Brookhaven National Lab., January, 1990.

ADVANCED COMMUNITY ENERGY SYSTEMS R,D&D PROGRAM IN RENEWABLY ENERGIZED COMMUNITY HEATING AND COOLING SYSTEMS

The energy flows of heat and cold in the natural environment represent a huge and virtually untapped renewable energy resource base which could cost-effectively supply communities with most of their heating and cooling needs. The energy systems most appropriate to tap these resources are community-scale systems designed to capture and store winter and nighttime cold and solar heat such as ice ponds, spray ponds, radiative cooling ponds, central solar heating plants with seasonal storage, solar heat-activated chilling as well as combinations of these and other ACES technologies. The new ACES technologies have the potential to supply cities with most of their heating and cooling supplies from renewable energy sources, thereby, in effect, achieving a rapid and thoroughgoing "solarization" of American cities.

The environmental impacts of this substitution of renewable energy sources for fossil fuels on a widespread, large-scale basis are potentially very dramatic. The new renewable ACES technologies can be from 5 to 10 times more energy-efficient than conventional methods of heating and air conditioning, thereby reducing fossil-fueled energy consumption for building heating and cooling to a fraction of current levels. In the process, the local and global environmental impacts of this energy use will similarly be dramatically reduced. Since the new ACES technologies substitute natural sources of heating and cooling either directly or with the aid of heat pumps and chillers using ammonia refrigerants they have the potential to eliminate the use of CFCs and CFC "drop in" substitutes for use in building heating and cooling. The following paragraphs outline new technologies which should be the focus of R,D&D projects in renewably energized ACES.

Central Solar Heating Plants With Seasonal Storage

Central Solar Heating Plants With Seasonal Storage (CSHPSS) (pronounced "chips") constitute a solar ACES designed to maximize solar input to a communities heat supply and minimize cost. This is accomplished through the use of seasonal heat storage in excavated modified solar ponds, bedrock, clay or aquifers. Seasonal storage permits solar collectors to operate at maximum efficiency throughout the year, thereby collecting 2-3 times more energy than is possible with individual building solar collection systems using daily storage. It is also facilitated by exploiting economies of scale in both solar collection and seasonal heat storage, which can reduce the cost of delivered energy from CSHPSS systems to levels which are competitive with conventional heating supply methods. Such systems can meet nearly 100% of winter loads, even in communities located at far northern latitudes, regardless of winter weather patterns.

More than 30 CSHPSS have been built and evaluated worldwide. Plants large enough to serve communities of 500 dwellings have been built and operated reliably, efficiently, and without interruption for more than a decade. Sweden is on the verge of a large-scale commercialization of CSHPSS which could result in the development of 25 such systems costing \$40 million each over the next decade. CSHPSS projects achieve very high levels of energy efficiency with typical COPs between 5.0 to 10.0. Although the U.S. has participated in CSHPSS R&D programs of the International Energy Agency it does not now participate, and no CSHPSS demonstration projects have been constructed in the U.S. If this persists the

first solar communities will not be located in the warm and sunny suburbs of the American southwest but rather in the cold and cloudy cities of Sweden, Denmark and Germany.

The primary need for a USDOE R,D&D ACES Program in CSHPSS technology is for the construction of large scale projects through which it will be possible to acquire a domestic technology base. In addition, it will also be necessary to develop large scale solar arrays for modified solar ponds which are very low in cost. Plastic and metallic foil collectors under development by BNL are appropriate for such an application as are several other designs for inexpensive plastic collectors which horizontally float atop solar ponds both capturing solar energy and providing insulation for the modified solar pond in which the hot water produced by the collector array is stored. Different seasonal storage techniques also need to be demonstrated such as heat storage in water pits and duct storage in earth and rock. It will also be necessary to adapt ammonia refrigeration technology to perform heat pumping tasks in conjunction with CSHPSS systems. The total time and funding required to undertake the necessary R,D&D in CSHPSS is 3 years and \$7.5 million.

Natural Cycle Cooling Systems

Natural Cycle Cooling Systems (NCCS) are an ACES technology which can supply building air conditioning from cold winter air at extraordinarily high levels of energy efficiency and at costs competitive with conventional methods. The type of NCCS varies by climate. In cold climates with a relatively large number of hours of below-freezing temperatures, ice ponds or a combination of ice ponds and spray ponds are appropriate. Ice ponds make ice by spraying atomized droplets of water into cold winter air. The droplets cool and form ice crystals which fall into a basin in which large ice piles can be accumulated over the course of a winter season. A combined ice pond/spray pond developed by NOVA for NYSERDA used less than 10% of the energy required by commercial electric air conditioning systems to produce an equivalent amount of cooling.

In regions which do not have winters with a sufficient number of hours below freezing to justify ice ponds, spray ponds will be more viable. Spray ponds use cold air to directly cool a fine spray of water. If the cold air is insufficiently low in temperature to freeze the water spray, the droplets fall as chilled water. This process can cool large volumes of water to within 3F of the wet-bulb temperature. In this way, abundant supplies of chilled water can be produced in winter and stored in aquifers. Spray ponds tested at Texas A&M University have produced large amounts of 45F water for injection into aquifers at high recovery rates. Water at 45F is sufficient to supply an ACES/district cooling system with its cooling supply requirements at a fraction of the energy consumption of conventional systems.

Another NCCS technology for use in ACES is radiative cooling. Radiative cooling is the means by which the earth loses heat to space. Infrared heat transfer due to radiation can be used as a source of natural cooling in arid areas such as the American southwest where humidity is very low (5-15%) and the effects of nocturnal radiative cooling on ambient temperature are at a maximum. The only type of radiative cooling system in recent use is the roof pond for individual-building applications. However, this technology could be significantly improved by applying selective glazings and emissive materials with very

high levels of reflectivity and transparency. New selective glazings have the potential to permit effective radiative cooling during the day as well as at night. The use of new materials can result in radiative cooling systems which can achieve reductions in temperatures of chilled water far below ambient levels (as much as 15C/27F below ambient under clear-sky conditions). Radiative cooling ACES are attractive for the cities of the American southwest where they offer a potentially inexpensive and environmentally benign source of building air conditioning.

Several different types of ice ponds, spray ponds and radiative cooling systems need to be designed and tested for different U.S. regions. This task will take 3 years and cost \$7.5 million.

Solar Absorption Air Conditioning

Another renewable ACES cooling technology which should be developed is solar absorption chilling which can employ solar collectors which supply heat above 230F. Single, double or triple effect absorption chillers as well as jet refrigeration systems developed for use with cogeneration can be modified to supply cooling from solar heat. Solar collectors are available which can produce heat at temperatures required for absorption chillers. Attractive combinations of solar collectors and absorption chillers need to be identified, tested and demonstrated for use in an ACES. The chillers used will be the high-efficiency, low-cost absorption chillers developed in BNL's Heat Activated Chilling Technology R,D&D Program. This task will take 2 years and cost \$2.5 million.

Integrated, Renewable ACES

Since ambient temperatures vary considerably so will the temperatures of the chilled water produced by spray ponds. Similarly, weather conditions will also affect radiative cooling temperature outputs. Conventional chillers are not designed to utilize chilled water inputs that vary widely in temperature but rather are designed to use water at relatively constant temperature. As a result, when conventional chillers are supplied with chilled water at a wide range of temperatures below conventional supply temperature levels, the efficiency with which the chillers use the variable-temperature water does not reflect the efficiency improvement which is possible from using the lower-temperature water. In order to make chillers operate at optimal levels of energy efficiency with varying supply temperatures it will be necessary to modify chillers (and heat pumps) to use a much wider range of cooling and heating input temperatures. If ACES technologies are to remain CFC-free then it will be necessary to modify ammonia refrigeration technology to utilize a wide temperature range of both chilled water from spray ponds and warm water from CSHPSS in an optimally efficient manner.

Since in many cases an ACES will be required to supply space heating, domestic hot water and air conditioning to communities, the ammonia chiller/heat pump will have to achieve an optimal efficiency operating in an integrated mode with ice ponds, spray ponds and CSHPSS in a single design. Higher temperature solar collectors than would be employed in a CSHPSS will be necessary to drive heat activated chilling systems which also may be part of a renewably energized ACES. It may also be advantageous to integrate small gas fired cogeneration

systems to provide the power to run the electric ammonia chiller/heat pump as well as to provide supplemental supplies of heat.

R,D&D 's necessary for optimal integration of these various heat and cold production and storage systems. This will entail significant development of electronic controls and computer software to achieve thermodynamically optimal and cost effective management of thermal energy cascades among the various systems. The development of integrated renewable ACES will take 2 years and cost \$2.5 million.

The ACES program in renewable community heating and cooling systems will take 5 years and cost \$20 million. This effort will result in the development of renewable ACES for each U.S. region.

Bibliography:

Andrews, J.W., et. al., "Development of Low Cost Polymer Film Solar Collectors: Annual Report", BNL 51693, Brookhaven National Lab., 1983.

Bankston, C.A., "The Status and Potential of Central Solar Heating Plants With Seasonal Storage: An International Report", in Advances In Solar Energy, Vol 4, Karl W. Boer (ed), Plenum Publishing Corp., 1989.

Breger, D.S., "Community Scale Systems: Seasonal Thermal Energy Storage and Central Solar Heating Plants With Seasonal Storage", in George Lof, (ed) Active Solar Systems, Vol 6: Solar Heat Technologies: Fundamentals and Applications, M.I.T. Press, Cambridge, MA, Jan. 1993.

Clark, Gene, "Passive/Hybrid Comfort Cooling By Thermal Radiation", (Dept. of Physics, Trinity University, San Antonio, Texas).

Gleason, Thomas C. J. "Cogeneration and Beyond: The Need and Opportunity For High Efficiency, Renewable Community Energy Systems" for Energy Efficiency & Cons. Div., Brookhaven National Laboratory, June, 1992.

Huszagh, D. and Willhelm, W.G., "Polymer Film Solar Collector Development: FY 1985 Report", BNL 38345, Brookhaven National Laboratory, 1985.

Illum, K., "Energy Systems and the Environmental and Economic Costs of Heat Supply to Buildings: The SESAM Model", Dept. of Development & Planning, Ecology & Energy Group, Aalborg Univ., Denmark, 1992.

Taylor, Dr. Theodore B., "Ice Ponds for Process Cooling, Air Conditioning and Desalination", 1984.

Taylor, Dr. Theodore B., "Heat Pump Assisted Solar Heating Systems With & Without Annual Cycle Heat Storage" NYSERDA: STEPS, Inc., 1991.

Taylor, Dr. Theodore B., "Opportunities For Reducing Energy Consumption & Costs of Industrial Refrigeration Systems In North Carolina", for North Carolina Alternative Energy Corp, April, 1987.

ADVANCED COMMUNITY ENERGY SYSTEMS RD&D PROGRAM IN AMMONIA VAPOR
COMPRESSION TECHNOLOGY FOR BUILDING AIR CONDITIONING

The United States is faced with a great environmental and economic challenge in phasing out the use of ozone-destroying CFC refrigerants and developing environmentally benign substitutes. The "drop in" refrigerants on which current CFC phaseout plans are based are deficient in a number of ways. Many still have an appreciable, if diminished, effect on the ozone layer; others have significant toxicity problems for human health; others degrade the energy efficiency and derate the capacity of existing equipment thereby increasing costs as well as collateral local and global environmental damage. However, there is one refrigerant which has the potential to overcome all of these problems. That refrigerant is ammonia.

Currently, ammonia is extensively used as a refrigerant in the industrial sector, where it is the standard. Ammonia is also extensively used as a fertilizer and exhibits no harmful environmental impacts when used correctly for this purpose. Although ammonia is classified as "toxic" it should only be considered toxic in the case of a catastrophic release inside an air-tight building. Thus, the use of ammonia technology for building air conditioning is entirely acceptable if it occurs in an industrial setting. The use of ammonia air conditioning would thus be acceptable if it is sited in a separate central plant supplying district cooling (and heating) to buildings.

Ammonia refrigeration equipment employed in the industrial sector has reached high levels of reliability, safety and energy efficiency. Industrial ammonia equipment is designed for heavy-duty, round-the-clock operation in refrigeration applications such as the food processing industry. However, the type of construction required for industrial refrigeration equipment results in capital costs higher than the costs of commercial air conditioning equipment. The high cost of this oversized equipment limits the market penetration of ammonia into the commercial building air conditioning market.

If cost-effective ammonia chilling technology were developed for the commercial building air conditioning markets, the benefits to the nation would be considerable. The most important benefit would be a cost-effective alternative to CFC refrigerants. This would speed up the phaseout of CFCs and make "drop in" refrigerants less critical. Another important benefit is energy efficiency. The "drop in" refrigerants degrade the energy-efficiency of chillers. This results in more local and global pollution due to the additional fuel which must be burned. Ammonia refrigeration technology is more energy-efficient than CFC refrigeration technology and thus reduces air pollution from electrical generation for air conditioning.

Little research has been done in ammonia air conditioning systems on evaporators for water chilling, which is a necessary prerequisite for the implementation of ammonia for building air conditioning. Most ammonia applications are for food storage refrigeration where the refrigeration system cools air, not water. The design problems of evaporators for liquid chilling are different from evaporators for cooling air. In addition, most water chillers for CFC refrigerants use copper tubes with internal fins to improve heat transfer. These cannot be used with ammonia because it corrodes copper. In order to make ammonia refrigeration

cost-competitive with CFCs, a technology R,D&D program is necessary to overcome these technical problems.

BNL proposes to develop a low-cost ammonia water chiller. As a way of reducing the potential hazards of ammonia, BNL proposes to design the equipment for the minimum charge of refrigerant so that if there were a leak, the minimum amount of ammonia would be released. The goal of this program is to have a prototype of an advanced ammonia chiller design running in two years after the start of the program.

The R,D&D program outlined above will be implemented as a cooperative effort between Brookhaven National Laboratory and industrial companies in the refrigeration equipment manufacturing business. That cooperative effort will result in the development, testing and commercialization of an ammonia air conditioning system for the buildings sector. Key goals will be to:

- Design lower cost compressors with better part load efficiency;
- Improve the design of evaporative condensers to improve heat transfer and lower cost;
- Design ammonia evaporators for liquid chilling for lower cost; and
- Package equipment for lower installed cost.

One technology which may be applied in the design of ammonia vapor compression chillers for lower cost and higher efficiency is the thin film polymer and metallic foil heat exchanger technology developed at Brookhaven National Laboratory. This technology will be applied wherever feasible in the redesign of ammonia chilling technology for commercial district cooling applications.

The project will be completed in 2 years and cost \$2.5 million.

Bibliography:

Timmerman, Robert W., P.E., "New Orleans District Cooling System Assessment Program: Report on Ammonia District Cooling", Report to the USDOE, March 1990.

Leigh, R.W. et. al., "Cost Reductions In Absorption Chillers", Phase 2: Final Report, BNL 42502, Brookhaven National Laboratory, Feb., 1989.

ADVANCED COMMUNITY ENERGY SYSTEMS R,D&D PROGRAM IN
LARGE SCALE, LOW TEMPERATURE COGENERATION AND DISTRICT HEATING

The potential for cogeneration and district heating from existing utility power plants in the northern United States has been estimated by several studies to be relatively great--in one account at least the equivalent of 600,000 barrels of oil saved per day or 1.3 Quads per year. Yet, numerous attempts to realize this potential have failed. This is largely due to the fact that the focus has been on the wrong technology: conventional, Western European style power plant cogeneration and district heating. This technology converts utility power plants to high temperature cogeneration to supply heat at temperatures between 200F and 300F, through insulated steel pipes to communities, industries and cities. Its lack of success is due to a number of technical and economic factors:

- high cost of insulated underground steel pipelines;
- low load factor resulting in high fixed costs per unit of heat;
- relatively low energy efficiency (COPs usually under about 1.5);
- power plant cogeneration retrofit for high temperature heat output results in expensive and permanent derating of turbine capacity;
- U.S. buildings need cooling which is not efficient or economical from European power plant cogeneration retrofit methods.

A new system for power plant cogeneration retrofit and combined district heating and district cooling has been developed to address these problems. That system combines low backpressure steam turbine cogeneration, low temperature district heating and the supply of district cooling from either electric ammonia chilling or natural cycle cooling systems. Low backpressure steam turbine retrofit takes advantage of the fact that U.S. power plant steam turbines can operate at a 133F condensing temperature, allowing the condenser to heat water to 120F even though the power plant usually puts out much colder water. The condenser requires only minor modifications to be interfaced with a 120F district heating system.

The modifications to the turbine result in reducing electrical generation efficiency when operating in a cogeneration mode by an average of 8.5%. Thus, for each unit of electricity sacrificed 6 units of heat are obtained. However, when the plant is not cogenerating in summer it goes back to normal generation efficiency, i.e., there is no permanent derate. It is also feasible to obtain 90F water from power plants that use cooling towers in winter without any modifications to the power plant or losses of generation efficiency. In such a case the district heating system would operate at 90F.

A district heating system distributing 90-120F water can use a very low cost distribution system consisting of uninsulated plastic pipes instead of expensive insulated steel pipes. Since the distribution piping is the major capital cost for a district heating and cooling system this amounts to a substantial saving. Many air conditioned buildings can use 120F water directly for heating and others can do so with modifications. In cases where water temperature is too low to heat a building a heat pump can be used to raise the temperature to required levels.

The low-temperature cogeneration and district heating system is much more energy efficient than conventional methods of power plant cogeneration and district heating because it produces, distributes and uses low-temperature, 120F water. If buildings can use the 120F water directly for heating the energy efficiency of the entire system will be 5.0 to 10.0. If buildings require heat pumps the COP will be between 1.5 to 3.0. The average energy efficiency of the overall cogeneration and district heating system using 120F water is estimated to be between a COP of 3.0 and 5.0. This compares with European-style steam-turbine cogeneration/district heating systems supplying heat at temperatures up to 250F which usually have COPs under about 1.5.

To obtain district cooling supplies the system relies not on power plant cogeneration but on either electric vapor compression ammonia chilling or natural cycle cooling systems (NCCS). The ammonia chiller could be located at the power-plant site and could use power-plant cooling water to significantly improve efficiency over conventional methods of individual-building air conditioning since it will have a COP of about 6.0. The NCCS would also employ the power-plant site. NCCS such as ice ponds, spray ponds and radiative cooling are more energy efficient than central ammonia-chilling since they will have COPs ranging from 5.0 to 10.0. Potentially, the ammonia chilling system could utilize pre-cooled water from an NCCS to boost its efficiency. Both of these methods have the added advantage of being able to eliminate inefficient, CFC-based building air conditioning systems.

Although a version of the new low backpressure cogeneration and low-temperature district heating system has been in operation for 10 years at a combined-cycle power plant owned by the Massachusetts Municipal Wholesale Electric Company, a significant R,D&D program is required to develop and demonstrate it for large-scale application. Numerous utility power plants of varying size and design need to be studied to achieve precise estimates of current cogeneration conversion costs. Regulatory issues need to be considered; piping costs estimated; building retrofit options studied; and technology gaps identified. Although most of the hardware required is available off the shelf some building retrofit options will need refinement. Finally, it will be important to conduct a case study to design a power plant cogeneration retrofit and district heating and cooling system. The system will have to be large enough to prove the concept but small enough to be installed in a few years. The project will incorporate private and utility as well as federal participation. The federal role could be limited to providing the technology through the proposed R,D&D project and guaranteeing loans.

The project will take 4 years and cost \$5.0 million.

Bibliography:

Timmerman, Robert W., P.E., "Utilization of Power Plant Waste Heat For Heating", Proceedings of the Conference on Waste Heat Management and Utilization, p 5C-157, May 9-11, 1976.

Timmerman, Robert W., P.E., "Utilizing Power Plant Waste Heat", "Heating, Piping and Air Conditioning", p. 91, May, 1978.

Timmerman, Robert W., P.E., "Ocean Grove District Heating System, Vol. 2", Final Report to USDOE Small Scale Technology Program, June, 1983.

ADVANCED COMMUNITY ENERGY SYSTEMS R,D&D PROGRAM IN
COMMUNITY-SCALE THERMAL DISTRIBUTION AND END-USE SYSTEMS

A prerequisite for achieving cost-effective and highly energy-efficient advanced community energy systems (ACES) is the development of new community-scale heating and cooling distribution and end-use technologies to serve groups of buildings, communities, or entire cities. Current distribution and end use technology is too costly and otherwise not appropriately designed for ACES technology. In addition, there are significant technical opportunities for greatly improving the cost-effectiveness of community-scale thermal-distribution technology. Since distribution and end-use systems promise to be the major cost (perhaps as much as 50%) in future ACES, attention should be directed to achieving much lower cost, much more energy-efficient thermal distribution than is possible with current technology.

The key objectives of the proposed distribution technology R,D&D program are to develop distribution and end-use technologies that can accomplish the following: 1) increase overall energy efficiency, 2) reduce pipe sizes, 3) reduce distribution-system capital costs, 4) reduce pumping costs, and/or 5) increase capacities of existing piping systems. Technologies that can accomplish one or more of these objectives include low-cost, uninsulated plastic pipe for low-temperature hot-water distribution; innovative techniques for converting steam end-use systems to hot-water and hot water to low-temperature hot-water and forced air; innovative distribution-system routing strategies; friction-reduction additives (FRAs); lower temperature supply water; ice slurries; phase-change materials (PCM) for both heating and cooling media; and distributed storage. By combining some of these technologies, substantial reductions in distribution-system capital and energy costs can be obtained.

Some problems associated with advanced fluids have yet to be successfully addressed. One of the primary problems is with heat transfer to end-user systems. It will be necessary to develop end-user heat exchangers that have enhanced heat-transfer capability and are compatible with the new advanced distribution fluids. One candidate for such a task is the thin-film heat exchanger technology developed at BNL. Another high priority end-use technology is vacuum steam radiator technology, which permits the low-cost conversion of steam building heating systems to hot water, thereby also permitting the use of more cost-effective hot-water district heating rather than obsolete steam district heating.

The development of ice-slurry district cooling is especially critical to the success of future ACES supplying cooling since ice-slurry distribution technology drastically reduces the capital cost and increases the energy-efficiency of ACES systems, paving the way for such highly energy-efficient technologies as natural-cycle cooling systems. It may also be possible to employ ice-slurry technology in a pulsing district heating and cooling system which would supply all thermal services to buildings via only a two-pipe distribution system rather than the conventional four pipes, thereby achieving drastic reductions in capital cost.

One technical obstacle to economical ice-slurry thermal distribution concerns the production of ice from either vapor compression or heat-activated chillers. Current technologies for ice production and collection have proven to be either high cost or technically problematic. A thin-membrane heat exchanger under

development at BNL appears to exhibit the potential for resolving both cost and performance problems. Preliminary tests of this device showed that it produced very thin sections of ice fragile enough to be pumped through a pipe in millimeter-sized pieces offering little resistance and therefore requiring little additional pumping power compared to chilled water. The thin-film heat exchanger technology needs to be adapted for use with ammonia chillers for ice production.

Consideration also needs to be given to the configuration of thermal-distribution systems. Long transmission lines and redundancy need to be eliminated, since piping costs will be the major cost of ACES. One advantage of small systems is that they eliminate the need for extensive thermal transmission systems and instead employ very small distribution line lengths sufficient to link together several buildings, groups of buildings or urban blocks. Advanced gas-fired engine cogeneration, ammonia chilling and absorption chilling systems are very energy-efficient in small-scale applications and thus can dispense with lengthy distribution lines. In addition, systems serving smaller areas have smaller diameter distribution pipes which can be more easily installed in streets as well as through basements and over rooftops.

Hub-and-spoke distribution system configurations can be used instead of the traditional linear design. Instead of locating the thermal source in a corner of the service area, the hub-and-spoke option would locate the thermal source at the center of the service area. Distribution lines would radiate from the plant like spokes on a wheel rather than like branches off a tree trunk. The hub-and-spoke system would grow by sending out small feeders to service satellite loads. As the satellite grows new block-scale cogeneration capacity can be added to serve new and expanding loads. The costs and benefits of this and other distribution designs need to be optimized for a wide variety of conditions.

In addition to the opportunity to develop new distribution technologies, there are also significant technical opportunities for greatly improving the cost-effectiveness of existing systems that use obsolete district heating and cooling technology. There are thousands of such district heating and cooling systems in the United States serving military bases, college campuses and central cities. These systems supply about 1% of the energy consumed in the U.S.

The federal government is by far the largest owner and operator of old and deteriorated DHC capacity in the U.S. Most of these systems are in disrepair, employ outdated equipment, and are very inefficient. If a way is not found to significantly upgrade the energy efficiency and economic performance of these systems then they will eventually be abandoned in favor of individual-building HVAC systems. In the process a very important opportunity will have been lost--the opportunity to drastically improve the energy efficiency and economy of these systems through the application of advanced community energy systems (ACES) technology and transform these systems into models of efficient, environmentally beneficial and economical community energy supply.

The first technological prerequisite for realizing this potential is the development of a system for economical in-situ pipe inspection and repair systems (ISPIRS). The proposed system will consist of highly sophisticated robotic pipe inspection and repair equipment mounted on a skid which can be pulled through an underground pipe and perform its inspection and repair tasks from inside the pipe without the need for costly and disruptive excavation. A system such as this can

drastically reduce the cost of detecting faults in DHC distribution systems as well as the costs of repairing defects by an order of magnitude under currently available options.

Existing options are limited to educated guesswork in detection of most defects and to complete excavation and replacement of entire lengths of pipe in the case of pipe and insulation repairs. An economical means of pipe and insulation "repair" does not exist today since the current method involves excavation of at least an entire length of pipe and replacement with a new length of the same size (usually 30' lengths) in order to fix a pipe or insulation defect which might only be several inches to several feet in length or diameter. The ISPIRS would make possible the systematic, rapid, reliable and cost effective in-situ inspection and repair of DHC pipes. Pipe repairs completed by ISPIRS will cost approximately one-tenth as much as the only available conventional technique--pipe replacement. The following equipment will be tested for use in the ISPIRS:

- A computerized, remotely controlled version of the Remote Field Eddy Current (RFEC) probe. RFEC probes can reveal pipe defects such as cracks, corrosion, pin hole leaks and pipe stretch.
- A remotely, laser-controlled automatic welding assembly to repair holes, cracks, thin walls and seal flanges in pipes.
- A centrifugal spray assembly that is remotely controlled, and travels through a pipe spraying high-strength ferro compounds in a centrifugal pattern to seal pipe walls that have defects.
- Electromagnetic acoustic technique (EMAT) combined with RFEC and remote automatic welding system to make through-wall measurements of the pipe to determine remaining pipe life and monitor and control thick-section welds made by the remote automatic welding technique. The accuracy of this system in defect measurements is as low as +/- 5% between actual defect extent and indicated.
- A turret drill assembly containing special drills, thread cutters, injector nozzles, controls, and computer software used to drill through pipe walls and inject insulation to the outside pipe wall to reinsulate underground pipes with deteriorated insulation.

The ISPIRS development and testing project will take 18 months and cost \$0.5 million. It will result in the development of a high performance, low cost means of rehabilitating underground DHC piping systems.

The entire ACES Thermal Distribution and End Use Technology R,D&D program will take 4 years and cost \$9 million.

Bibliography:

Andrews, J.W., et. al., "Ice-Making Heat Exchanger Evaluation and Test Plan", BNL-43844, Brookhaven National Laboratory, January, 1990.

Dodd, James, "Remote Controlled In-Situ Pipe Inspection and Repair System For District Heating and Cooling Systems", proposal to Community Systems Branch, Office of Buildings and Community systems, USDOE, January, 1991.

Gleason, Thomas C. J., "Cogeneration and Beyond: The Need and Opportunity For High Efficiency, Renewable Community Energy Systems", Energy Efficiency and Conservation Division, Department of Applied Science, Brookhaven National Laboratory, Upton, N.Y., June 1992.

Leigh, Richard W., "Design, Construction and Testing of a Flexible Polymer Film Ice Maker", Proceedings of the 1991 Annual Meeting of the International District Heating and Cooling Association, S.F. CA, 1991.

Leigh, Richard W., "Economic Assessment of Thin Film Polymer Ice Maker", Brookhaven National Laboratory, July, 1992.

USDOE, "District Heating and Cooling Program: A Decade of Accomplishments: 1982-1992", District Heating and Cooling Program, Utility Systems Division, Office of Energy Management, Office of Utility Technologies, Conservation and Renewable Energy, USDOE, October, 1992.

END

**DATE
FILMED**

6 / 8 / 93