108
11/4/80

No. Stock

SEPTEMBER 1980

PPPL-1711

UC-20d

MASTER

NUCLEAR RADIATION ANALYSIS FOR TFTR

BY

LONG-POE KU

PLASMA PHYSICS LABORATORY

PRINCETON UNIVERSITY
PRINCETON, NEW JERSEY

This work was supported by the U.S. Department of Energy Contract No. DE-AC02-76-CMC 3073. Reproduction, translation, publication, use and disposal, in whole or in part, by or for the United States government is permitted.

Nuclear Radiation Analysis for TFTR

Long-Poe Ku

Plasma Physics Laboratory

Princeton University

Princeton, NJ 08544

DISCLAIMER

This book was prepared as an account of work sponsored by agencies of the United States Government. It is the property of the United States Government and may not be reproduced, stored in a retrieval system, or transmitted, in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage or retrieval system, without permission in writing from the United States Government. The views and conclusions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

2/29

ABSTRACT

A multi-dimensional analysis of the radiation problems was performed for TFTR using the system established at PPPL. Simple, clean geometries were first used to establish the expected reference level. Different calculational models were compared. The characteristics of streaming and activation were then studied. It is shown that the objectives set forth for the TFTR shielding design are not entirely satisfied, based on our calculation. Using the results of this study as a baseline, a review of the shielding for TFTR and its upgrade, TFM, has been initiated with the objective of a shielding design modified to satisfy both modes of operation.

Table of Contents

	<u>Page</u>
Abstract	1
1.0 Introduction	1
2.0 Shielding Layout and Design Objectives	3
2.1 Shielding Layout	3
2.2 Design Objectives	4
3.0 Description of the Analysis System	6
3.1 Cross Section Data	6
3.2 Transport Calculation	12
3.3 Analysis of Radiation Fields	16
4.0 Sources of Radiation	19
5.0 D-T Analysis	21
5.1 Radiation Level in the Test Cell	21
5.1.1 Description of Calculational Models	21
5.1.2 Comparison of Particle Fluxes Using Different Models	24
5.1.3 Neutron and Gamma Ray Fluxes in the Test Cell	32
5.1.4 Dose Responses and Distribution in the Test Cell	32
5.1.5 Radiation Damage Data and Igloo Heating	46
5.2 Radiation Level in the Inner Basement Area	46
5.2.1 Description of Calculational Models	46
5.2.2 Comparison of Particle Fluxes Using Different Models	50
5.2.3 Neutron and Gamma Ray Flux Distribution in the Inner Basement Area	50
5.2.4 Dose Response Distribution in the Inner Basement Area	56
5.3 Radiation Level in the Outer Basement Area	56
5.3.1 Description of the Calculational Model	56
5.3.2 Neutron and Gamma Ray Flux Distribution in the Outer Basement Area	62
5.3.3 Distribution of Dose Responses in the Outer Basement Area	62
5.4 Biological Dose Within TFTR Site	63
5.4.1 Description of Calculational Models	63
5.4.2 Biological Dose within TFTR Site	74

Table of Contents

(Continued)

	<u>Page</u>
6.0 D-D Analysis	81
6.1 Radiation Level in the Test Cell	81
6.1.1 Comparison of Particle Fluxes Using Different Models	81
6.1.2 Neutron and Gamma Ray Fluxes in the Test Cell	82
6.1.3 Dose Responses and Distribution in the Test Cell	94
6.2 Biological Dose at Site Boundary	94
7.0 Penetrations	102
7.1 General Penetration Characteristics through the Igloo Shield	102
7.1.1 Description of Model and Source Term	102
7.1.2 Adequacy of the Model and the Method	105
7.1.3 Penetration Characteristics with Different Hole Sizes	106
7.2 Penetration through NBI Port	116
7.2.1 Model and Method of Analysis	116
7.2.2 Biological Dose due to the Presence of the Injector	120
7.2.3 Nuclear Heating to the Injector Components	120
7.3 Penetration through TVPS Port	129
7.3.1 Description of the Calculational Model	129
7.3.2 Neutron and Gamma Ray Fluxes around the TVPS	129
7.4 Penetration Characteristics through 6' Machine Substructure	140
7.4.1 Penetration Models	140
7.4.2 Streaming Pattern for 12 - Co-linear Diagnostic Tubes in the Substructure	144
8.0 Analysis of Induced Activity	151
8.1 General Activation Characteristics	151
8.1.1 Induced Activity for Pulsed TFTR Operation	151
8.1.2 Characteristics of Induced Activity in the TFTR	153
8.2 Biological Dose Rate from Neutron Activated Objects	163
8.2.1 Activation Dose Rate from Isolated Objects in the Test Cell	163
8.2.2 Activation Dose Rates from Isolated Objects in the Basement Area	172
8.2.3 The Effect of Object Size, Distance and Material Composition on the Dose Rate	183

Table of Contents

(Continued)

	<u>Page</u>
8.2.4 Characterisites of the Activation Dose Rate from SS-305, Al and Cu Objects	191
8.3 Reference Radiation Field in the Test Cell	193
8.3.1 Method of Calculating Reference Radiation Field	193
8.3.2 Decay Dose Level in the Test Cell	197
8.4 Induced Activity from NBI	202
8.5 Air Activation	202
8.5.1 Method of Calculation	207
8.5.2 The Activity Concentration in Air for DT Pulsing	211
9.0 Summary and Conclusion	214
Acknowledgment	215
References	

1.0 INTRODUCTION

The radiation analysis is an integral part of the TFTR system design. The study not only checks the adequacy of the shield design, but also provides necessary information for the post-operational maintenance and for the experimental and diagnostic design. The only available document on the TFTR radiation analysis is the early Westinghouse report TME-022.⁽¹⁾ The design has been changed significantly since then, the data in TME-022 are obsolete. There were scattered works done in the period of 1975-1978 by the Ebasco Company. A systematic study of the radiation problem was initiated at the Laboratory only in 1978. The preliminary study terminated in the summer of 1979. Many internal memoranda were issued during that period, but a formal report has not been written.

The shielding design for TFTR has undergone extensive review. Some changes have been made, and some other changes are expected to follow. It is felt that this is an appropriate time to group the available data together as a single document so that the information may be collectively used as a design reference. The purpose of this report is thus to demonstrate the in-house analysis capability and to present the radiation analysis results reflecting the design of that period.

The general approach for the TFTR radiation analysis was to establish the upper bound of radiation level both for DD and DT operation in the TFTR site. Simple, clean geometries were used in the first place. Different calculational models were compared. The major penetration problems were then briefly addressed. Some specific shield designs for the penetrations were also studied. Lastly, the general activation problem was looked at for a number of selected cases. The activation calculations depend, to a much larger degree, on the pulsing scenario, maintenance scheduling and the details of the environment. The establishment of post-operational permissible working time zone maps for different situations should be done only when the design is finalized.

It must be emphasized that this report by no means is a final and complete analysis. Missing from the study are the minor streaming problem such as the offset gaps presented in the concrete blocks and the sensitivity study, to mention just two. The problem of heterogeneity of the shield and structural materials and better modeling of the system are waiting to be examined.

In the following presentation, Chapter 2 describes the shielding layout and design objectives. The design, as noted before, was as of 1978. The analysis system established at the Laboratory is then described in Chapter 3. The sources of radiation are discussed in Chapter 4. Chapter 5 and 6 are the discussion of the background analysis for DT and DD operation respectively. The streaming study is presented in Chapter 7 and the activation study is presented in Chapter 8. The neutronic analysis for the NBI (Neutral Beam Injector) System was subcontracted to ORNL. A brief summary of their work is also given. The summary and conclusion are given in Chapter 9. An assessment of the design adequacy is made and some future directions are briefly discussed.

2.0 SHIELDING LAYOUT & DESIGN OBJECTIVES

2.1 Shielding Layout

The basic shielding for the TFTR is provided by the building wall and floor structures themselves. The wall is made of ordinary concrete, 4' thick on the sides and a sloped roof going from 3.5' at the test cell center to 4.3' on the side. The floor or so called machine substructure is 6' of borated limestone concrete (PPPL Spec. 308). The test cell floor is 3' of concrete with the top 1' of borated limestone concrete and bottom 2' of unborated limestone concrete. In addition, there is a 1' auxiliary wall made of borated ordinary concrete covering from the test cell floor to the elevation of 23' 6" on all sides. In the test cell where the areas are not covered by the auxiliary wall, 1 cm of borated plaster board is attached. Down in the basement there is 1' of ordinary concrete located at 20.16' from the machine center which divides the basement into inner and outer sections.

During DT pulsing, an additional 26" of borated limestone concrete in the shape of staggered blocks encloses the machine. In the analysis we term this enclosure the "igloo".

Penetrations are going through the igloo for the vacuum pumping system and neutral beam injection lines. These major penetrations are almost all clustered on the south side of 180°. At the time this analysis was carried out, each TVPS was enclosed by an 18" borated limestone concrete shield except the bottom where the supporting structures attach to the floor. Each NBI is enclosed by 2' of borated limestone concrete on the back and 1' of the same concrete on the sides.

Note that only the general configuration of the machine shielding has been described here. The details are very complicated. In particular, the igloo blocks are arranged in such a way that a port may be opened by removing some of the shielding. Columns and lintel structures are designed to ensure the overall shielding integrity. A composite drawing of the TFTR shielding system is not available at this time.

2.2 Design Objectives⁽²⁾

Limits have been specified by the Federal Government on the permissible radiation exposure that may be delivered to individuals. The Government also suggests that the radiation level for a shielding design should be "as low as reasonably achievable (ALARA)". The radiation exposure limits for the TFTR shielding design follow these guidelines.

A comparison of the permissible and the design objectives for the exposure level in the TFTR environment is given below:

<u>Area</u>	<u>Permissible</u>	<u>Design Objective</u>
Site Boundary	500 mr/yr to an individual	10 mr/yr
Controlled Area	170 mr/yr to average population	
Test Cell Outer Wall Surface	5 rem/yr	1 rem/yr

<u>Area</u>	<u>Permissible</u>	<u>Design Objective</u>
Maintenance and Service	2.5 mr/hr continuous exposure 100 mr/wk 3 rem/quarter 5 rem/yr including all sources	50mr/hr on the surface of the igloo 1 hr after operation 1 rem/yr
Airborne Radioactive Nuclide Concentration	1 p Ci/cc for N 2 p Ci/cc for Ar (Infinite cloud assumption)	$\sum C_i / (MPC)^{1/2}$ 1 hr after operation

It is seen that the design objectives for TFTR are very conservative to ensure adequate protection for the workers and the public at large. The objectives serve as the baseline of evaluation of shielding adequacy.

3.0 DESCRIPTION OF THE ANALYSIS SYSTEM

The analysis system may be divided into three distinct but closely related modules: the cross section module, the transport module, and the analysis module. Each module contains a library of data and/or computer programs, the operation is highly automated. The analysis system established over the years at the Laboratory and used for the TFTR radiation study will be described briefly in this chapter.

3.1 Cross Section Data

The cross section library consists of the basic data sets and the working data sets. For convenience, the cross sections for transport calculations and reaction calculations are maintained separately. As a general practice, the energy space was divided into groups, the particle motion was treated collectively within each group with some characteristic group constants.

The working data sets are coarse group structures derived from basic data libraries. A schematic drawing is illustrated in Figure 3.1 showing the derivation and processing of the cross sections. A 34 group (23n,11γ) structure has been used for most of the prompt transport calculations, and a 16 group structure has been used for decay gamma transport calculations. The group structures are given in Table 3.1. The 34 group constants were obtained by collapsing the DLC/37D⁽³⁾ data set with a spectrum of 14 MeV neutron penetrating through an infinite slab of concrete, the thermal temperature has also been adjusted to 300⁰ K. The 16 group constants were derived from the DLC/41B⁽⁴⁾ data set using constant weighting.

In addition to the element cross section data (microscopic), a material cross section (macroscopic) data set was also maintained for commonly used materials in the TFTR environment. The atomic densities for those materials are presented in Table 3.2. Of special interest here is the choice of igloo wall concrete. It is a custom blend of 97% pure limestone aggregate and low impurity cement (PPPL Specification 398 and 345). The 5% by weight of water has been used as a baseline.

Figure 3.1

Cross Section Module Structure

TABLE 3.1

A. 34 ENERGY GROUP STRUCTURE (23n-11 γ) FOR INSTANTANEOUS
RADIATION TRANSPORT CALCULATION

NEUTRON			GAMMA-RAY		
Grp.	Energy Range		Grp.	Energy Range	
	MeV			MeV	
1	1.3499+1	1.4918+1*	1	12 - 14	
2	1.2214+1	1.3499+1	2	8 - 12	
3	1.1052+1	1.2214+1	3	7 - 8	
4	1.0000+1	1.1052+1	4	6 - 7	
5	9.0484+0	1.0000+1	5	5 - 6	
6	7.4082+0	9.0484+0	6	4 - 5	
7	6.0653+0	7.4082+0	7	3 - 4	
8	4.9659+0	6.0653+0	8	2 - 3	
9	4.0657+0	4.9659+0	9	1 - 2	
10	3.3287+0	4.0657+0	10	0.2 - 1	
11	2.7253+0	3.3287+0	11	< 0.2	
12	2.2313+0	2.7253+0			
13	1.8268+0	2.2313+0			
14	1.0026+0	1.8268+0			
15	5.5023-1	1.0026+0			
16	2.0242-1	5.5023-1			
17	4.0868-2	2.0242-1			
18	3.3546-3	4.0868-2			
19	2.7557-4	3.3546-3			
20	2.2603-5	2.7557-4			
21	1.8554-6	2.2603-5			
22	4.1400-7	1.8554-6			
23	THERMAL				

*Read as 1.4918×10^1

B. 16-GROUP STRUCTURE FOR DECAY
GAMMA RAY TRANSPORT CALCULATION

<u>Group</u>	<u>Energy Boundary (MeV)</u>
1	14.0 - 5.0
2	5.0 - 4.0
3	4.0 - 3.5
4	3.5 - 3.0
5	3.0 - 2.5
6	2.5 - 2.0
7	2.0 - 1.5
8	1.5 - 1.0
9	1.0 - 0.8
10	0.8 - 0.6
11	0.6 - 0.4
12	0.4 - 0.2
13	0.2 - 0.1
14	0.1 - 0.06
15	0.06 - 0.03
16	0.03 - 0.01

TABLE 3.2 NUCLEAR DENSITIES
Atom/ cm-barn

(1) SS-304	Fe	6.132-2
	Ni	6.793-3
	Cr	1.738-2
	Mn	1.188-3
(2) SS-305	Cr	1.674-2
	Mn	1.761-3
	Fe	5.890-2
	Ni	9.064-3
	Si	1.722-3
(3) Nitronic-33	Si	1.662-3
	Cr	1.616-2
	Mn	1.105-2
	Fe	5.434-2
	Ni	2.386-3
(4) TF Coil*	H	4.397-3
	B	3.432-4
	C	1.840-3
	O	4.998-3
	Al	2.340-4
	Si	1.178-3
	Ca	4.212-4
	Cu	7.215-2
(5) Plaster Board	Ca	3.375-3
	S	3.368-3
	O	3.154-2
	H	2.432-2
	B	3.761-3
(6) Limestone Concrete **	H	8.246-3
	B	1.097-3
	C	1.052-2
	O	4.322-2
	Na	1.310-5
	Mg	1.882-4
	Al	2.634-4
	Si	1.091-3
	K	1.386-5
	Ca	1.308-2
	Fe	1.499-4
	Ba	1.245-4

Table 3.2 cont'd.

(7) Ordinary Concrete Type 4	H	7.830-3
	O	4.385-2
	Na	1.048-3
	Mg	1.486-4
	Al	2.389-3
	Si	1.580-2
	S	5.635-5
	K	6.932-4
	Ca	2.915-3
	Fe	3.127-4
(8) Borated Ordinary Concrete**	H	7.830-3
	B	1.058-3
	O	4.396-2
	Na	9.955-4
	Mg	1.486-4
	Al	2.366-3
	Si	1.507-2
	S	5.635-5
	K	6.778-4
	Ca	2.975-3
	Fe	2.912-4
	Ba	1.184-4
(9) Air	N	4.200-5
	O	1.130-5
	A	2.540-7
(10) Soil	H	1.600-2
	O	2.700-2
	Fe	2.000-3
	Si	9.000-3
(11) Fiberglass	C	2.190-2
	O	2.659-2
	Fe	2.895-3
	B	2.488-3
	H	3.906-2
	Si	8.995-3
	K	8.550-5
	Na	8.235-4
(12) Ti-Al-V Alloy	Al	6.642-3
	V	2.345-3
	Ti	4.860-2

* Based on 85% v/o of Cu
 3% v/o of H₂O
 12% v/o 65-35 Glass-Resin

** 0.8% w/o of B in Boron Frits

One comparison was made to assess the possible errors introduced by the use of the 34 group structure. An identical TFTR test cell problem was run using the BUGLE data set.⁽⁵⁾ The BUGLE set is particularly good for concrete calculation, and the concrete constitutes the major slowing down medium for neutrons in TFTR. The maximum difference observed due to the difference in the data sets was 20%.⁽⁶⁾

3.2 Transport Calculation

The particle density at a given moment is a function of energy, the spatial vector and the velocity vector, the rate of density change depends on the rate that the particles are "produced" and the rate that the particles are "removed". The particles at a particular point in phase space may be produced by either the external source or the "in-scattering" from another part of the phase space. The particles are removed by the scattering, absorption and streaming processes. The conservation principle results in a balance equation, the Boltzmann transport equation, which fully describes the particle motion in phase space.

The static particle density described by the Boltzmann equation in a seven dimensional space generally does not lend itself to analytic solutions. Numerical solutions are available and some approximations are usually used. The most commonly used technique is to use multigrouping for the energy space, finite difference for the spatial differentiation and some sort of discretization for the angular variable. The so called multigroup S_n or multigroup discrete ordinates solution is such a technique, n being the order of discretization.⁽⁷⁾ The choice of the discrete angle and the weight associated with it is a subtle point in this technique. General formulas for generating the required angle and weight are available.⁽⁸⁾ Though the details are beyond the scope of this report, suffice it to say here that the complete symmetry quadrature satisfying even moment solution has been used for 1-D calculations and half-symmetry quadrature has been used for 2-D calculations in the analysis.

The numerical technique could in principle be able to solve three dimensional problems. Yet the limitation on the computing capability severely restricts the use of such method. The geometry is usually confined to either 1 dimensional or 2 dimensional, taking advantage of some system symmetry. This symmetry condition is not fully satisfied for TFTR because the structures are in toroidal and poloidal shapes, a single axis of symmetry does not exist. Some simplifications were unavoidably involved where this technique was employed to study the radiation problem in TFTR. Further, the accuracy of the finite difference solution depends on the spatial mesh size used. As finer mesh sizes are used, a more accurate solution would be expected, but at the expense of increased computational time and storage requirements. The maximum spatial mesh used for 1D calculations here was 2 cm and that used for 2D calculations was 5 cm in the direction of primary particle flow. The mesh size used for 2D in the direction perpendicular to or nearly perpendicular to the primary particle flow direction was fairly coarse. Something like 50 cm has been used in the concrete. It is felt that the way the meshes are arranged is reasonable and the sizes chosen are a satisfactory compromise.

In addition to the above approximation, the scattering function which is angular dependent was expanded into Legendre polynomials. Only a limited number of terms were retained for the use in the calculation. This is generally referred as P_n approximation where terms greater than n are ignored. In this analysis we have used P_3 truncation.

One consequence of discretization of the angle is that the calculation fails to describe the "true" particle flux at a certain direction, though the local average would be correct. This situation is particularly severe when localized source and strong absorbers are present or details of streaming through penetrations are desired. There are ways to mitigate this ray effect. Use of analytic tracing to compute the uncollided flux distribution is one way of reducing this effect. This feature has been used extensively along with 2D calculations.

An alternative method of solving particle transport is to use random sampling and to follow, in a more or less analogue way, the particle collision histories. The so called Monte Carlo technique⁽⁹⁾ has the advantage of geometrical flexibility, but suffers the disadvantage of statistical uncertainties. Further, calculation by Monte Carlo usually leads to results at only a selected number of points. The full map is expensive to obtain. Monte Carlo has been used primarily for the streaming and site boundary dose calculations. The source term in the Monte Carlo calculation may be derived from other types of calculations. The coupling of discrete-ordinates and Monte Carlo is a particularly powerful tool for study in many situations.

The neutron flux may be coupled with activation cross sections to generate the decay gamma source distributions. This source then can be used for decay gamma-ray transport calculations by either the discrete ordinates or Monte Carlo technique. The program REBATE,⁽¹⁰⁾ originated at Ebaseo and modified by PPPL, has been designed for this purpose.

The computer programs employed for this study are those which have been used extensively in the nuclear community. ANISN⁽¹¹⁾ and DOT 3.5⁽¹²⁾ are the code names for Sn 1D and 2D calculations. MORSE-CG⁽¹³⁾, a multigroup Monte Carlo code, is the primary tool for random sampling calculations. The utilization of the transport codes is illustrated in Figure 3.2.

Figure 3.2

Transport Calculation Module Structure

3.3 Analysis of Radiation Fields

The fluxes computed by the transport codes are used to derive radiation field quantities. This is achieved by combining the response cross section libraries and the fluxes, processed by the utility programs library. In addition to flux spectra and flux maps, other field quantities of interest are the fluence, the biological dose rate, the physical absorbed dose, the damage data and the activity.

The biological dose (or dose equivalent) is a measure of radiation damage to the human body. The unit used here is mrem/pulse or mrem/hr. The biological response depends not only on the amount of energy deposited on the tissue by the radiation, but also on the type of radiation. For comparison, the background level around Princeton area is about 170 mrem/yr. Each X-ray check-up delivers about 40 mrem. The biological dose at the TFTR site boundary has been estimated to be on the order of 10 mrem/yr. The response function was derived from ANS Standard 6.1.1-1977.⁽¹⁴⁾

The absorbed dose is the energy that the radiation gives off to a given material. For a given radiation field intensity, the dose response would be different for different materials. Thus one speaks of dose for Si or C, etc. The absorption response is difficult to calculate. Usually the total kinetic energy transfer to the material, the KERMA factor, is used instead. The difference between the KERMA and absorbed dose is small.⁽¹⁵⁾ The unit for physical dose used in the study is Gy/pulse which is equivalent to 1 J/Kg of energy deposition during a pulse. In terms of another commonly used unit, rad, the conversion is 1 Gy = 100 rad. The response function library was based on MACKLIB,⁽¹⁶⁾ DLC/37D and other sources.

The measure of damage is generally in terms of absorbed dose, the fluence, the number of primary knock on atoms (the pka) or the amount of gaseous atoms produced in part per million (ppm). The damage cross section library established at PPPL contains all these responses. The data were based on RECOIL⁽¹⁷⁾ and ENDF/B-V.

Finally, the activity data are needed for activation studies. Both the activity density such as p Ci/cc and the specific activity such as Ci/gm of material were used in the analysis. Curie (Ci) is a measure of disintegration rate, $1 \text{ Ci} = 3.7 \times 10^{10}$ disintegrations per second. Notice that the activity is a measure of rate of disintegration, which says nothing about the mode of disintegration nor about the energy of disintegration. The activity response library was largely based on the MONTAGE⁽¹⁸⁾ data set with additional data derived from the Alley & Lester⁽¹⁹⁾ library and the ENDF/B-IV.

The interrelations of the analysis procedures are shown in Figure 3.3.

Figure 3.3

Analysis Module Structure

4.0 SOURCES OF RADIATION

The primary sources of radiation during the TFTR operation may be divided into two major categories, the X-rays and the uncharged particles from fusion reactions. In all phases of operation, X-rays will be produced as a result of charge particle motion in the plasmas. This source of radiation is important, in terms of radiation protection, only in the hydrogen plasma scheme where no other major radiations are produced. The contribution of this source to the personal dose has not been analyzed in this report; it is an apparent problem we shall address in the future.

The uncharged particles will emerge in the deuterium operation and the tritium operation. The D-D reactions produce 2.5 MeV neutrons and some tritons which in turn react with deuterons and produce 14 MeV neutrons. The DT reactions produce 14 MeV neutrons. The 14 MeV neutrons are very penetrating in that the collision probability with materials of this energy is lower than that of lower energies and the scattering will tend to be in the forward direction. Consequently, much attention has been paid to establish radiation fields due to this source.

The source strength will depend on the actual operating scheme. In the analysis, we have assumed that 3.5×10^{18} neutrons will be produced uniformly in a DT pulse which is equivalent to 20 MW of fusion power, and that 2.5×10^{16} neutrons will be produced uniformly in a DD pulse (equivalent to 22 kW fusion power) plus 2% of DT burn during the pulse. The maximum number of DT pulses allowed are 1000 per year for a total of 4 years. The maximum number of DD pulses allowed are 10,000 per year for a total of 4 years. The DT reaction neutrons have been assumed to emit uniformly in the range of 13.5 - 14.9 MeV. The DD reaction neutrons have been assumed to emit uniformly in the range of 2.2 - 2.7 MeV. The time delay of DT reaction within a DD pulse has been ignored. The 2% of DT reaction has been assumed to take place uniformly within a DD discharge. Each pulse is 0.5 second and pulses are 300 seconds apart.

The He nucleus resulting from the DT reaction will be in a highly excited state. Subsequent decay may be via several different channels. In addition to the well-known neutron channel, there is a gamma-ray decay channel in which the gamma-rays will carry off 17 MeV energy. The channel width of this gamma-decay, however, is only 1/5000 of that of the neutron decay. Some estimates indicated that this source of radiation is of minor concern in the TFTR environment. (20)

The primary source distribution will vary according to the scheme used (weak compression, strong compression, etc.). In the analysis, we have assumed a uniform source with circular cross section. The major and minor radius are 2.65 m and 0.75 m respectively. More detailed analyses will be performed to determine quantitatively the sensitivity of the analysis to the variations of the source distribution.

Besides the primary source, the interaction of neutrons with surrounding materials will generate secondary sources. Of particular importance are the secondary neutrons and the secondary gamma rays, both emissions taking place instantaneously as the collision occurs, and the gamma rays due to transmutation. The latter source will persist after the termination of the operation and will decay with some characteristic time constant. The secondary source will have a broad spatial distribution throughout the TFTR. Unlike the primary source, the intensities of the secondary emissions depend on the surrounding materials, and, in some cases, they are controllable.

5.0 D-T ANALYSIS⁽⁶⁾

In this chapter, we present the analysis of the radiation levels through the TFTR site during 20 MW DT pulsing. No penetrations have been assumed. Further, many simplifications in geometry have been involved and certain symmetry conditions have been used. Such a "clean" geometry analysis is useful to establish the reference radiation field. The data here are applicable to the areas away from major streaming paths and/or scattering centers.

5.1 Radiation Level in the Test Cell

5.1.1 Description of calculational models

Three calculational models have been used.

- (1) 1-D cylindrical model,
- (2) 2-D toroidal model,
- (3) 2-D poloidal model.

The 1-D model assumes the torus as an infinitely long cylinder. The igloo shield, auxiliary wall and test cell wall are regarded as concentric cylindrical shells centered at the plasma center line. A schematic drawing of the model is shown in Figure 5.1. The 1-D model has been used primarily for parametric studies and for comparison. The 2-D toroidal model is a (R, Z) geometry; the rotational symmetry is about the machine center line. The vacuum vessel, igloo, floor, roof, plaster board and walls are included in this study. This model gives a better geometric representation. However, poloidal continuous objects will not be accounted for, especially the TF coils which cover nearly half of the outer surface surrounding the torous vessel. A schematic drawing of this model is given in Figure 5.2.

Figure 5.1 Schematic Representation of One-Dimensional Test Cell Model.
Unit: Centimeter

Figure 5.2

Schematic Representation of Two-Dimensional Toroidal Test Cell Model

The 2-D poloidal model is also a (R, Z) geometry, but the rotational symmetry is along the plasma center line (thus it is a poloidal geometry). The vacuum vessel, TF coils, igloo shield and the wall are included. The toroidal effect will not be seen in this model, yet at least some of the TF coil effect will be taken into account. It is thought that, near the machine, this representation would better predict particle transport. The configuration used is given in Figure 5.3. Notice that in all the models, a good deal of simplification has been involved. The lintel and columns in the igloo blocks, the PF coils, the central column, the coil and vessel supporting structures all have been ignored. The computational requirement would be too great if the details were to be included.

The discrete ordinates method of solving particle transport has been employed in the calculation. In addition, in the toroidal model, ray tracing was used in the first place to generate uncollided neutron flux and their down scattering probability distribution. The source region was divided into 36 subregions, the source for each region being treated as a ring. Further, the integration over the ring source was approximated by the Gaussian quadrature technique of the 8th order. The error introduced in the azimuthal angle discretization has been estimated to be less than 10%. In all cases, P3-S8 calculations have been used.

5.1.2 Comparison of Particle Fluxes Using Different Models

Comparisons of the neutron and gamma-ray fluxes computed by the three different models are presented in Table 5.1, 5.2 and 5.3. The comparisons are made for the locations at the vacuum vessel and at 0.5 meters from both surfaces of the igloo wall. Further, some radiation quantities are compared at 0.5 meters from the auxiliary wall; the data are given in Table 5.4. All the results are those at the plasma midplane.

Figure 5.3 Schematic Representation of Two-Dimensional Poloidal Test Cell Model

TABLE 5.1

COMPARISON OF GROUP FLUXES COMPUTED BY VARIOUS MODELS
AT VACUUM VESSEL LOCATION

Group	1-D	2-D (Toroidal)	2-D (Poloidal)
A. Neutron			
1	8.7+12	7.3+12	8.9+12
2	3.1+11	2.3+11	3.4+11
3	1.3+11	1.0+11	8.4+10
4	1.5+11	1.3+11	1.3+11
5	1.4+11	1.2+11	1.6+11
6	2.5+11	2.1+11	2.7+11
7	2.8+11	2.3+11	2.3+11
8	2.5+11	2.0+11	2.1+11
9	2.8+11	2.3+11	2.6+11
10	3.2+11	2.6+11	3.3+11
11	4.2+11	3.4+11	4.1+11
12	5.7+11	4.7+11	5.6+11
13	5.9+11	4.8+11	7.2+11
14	2.6+12	1.6+12	3.2+12
15	1.9+12	1.5+12	4.5+12
16	1.8+12	1.4+12	5.0+12
17	1.4+12	1.1+12	3.9+12
18	1.2+12	9.6+11	1.9+12
19	8.7+11	7.1+11	5.4+11
20	7.2+11	5.8+11	4.8+11
21	3.9+11	3.2+11	2.3+11
22	1.0+11	8.1+10	5.0+10
23	1.7+10	1.3+10	6.1+9
B. Gamma-Ray			
1	4.8+7	3.8+7	2.6+7
2	9.8+10	8.1+10	1.2+11
3	1.3+11	1.1+11	1.5+11
4	2.9+11	2.3+11	2.3+11
5	2.1+11	1.7+11	2.6+11
6	3.7+11	3.0+11	3.9+11
7	7.1+11	5.8+11	7.5+11
8	9.4+11	7.8+11	1.1+12
9	2.2+12	1.8+12	2.8+12
10	6.0+12	4.9+12	7.8+12
11	6.2+11	5.0+11	7.2+11

TABLE 5.2
COMPARISON OF GROUP FLUXES COMPUTED BY VARIOUS MODELS
AT 0.5m INSIDE THE IGLOO WALL

<u>Group</u>	<u>1-D</u>	<u>2-D (Toroidal)</u>	<u>2-D (Poloidal)</u>	
			<u>Between</u>	<u>Behind</u>
A. Neutron				
1	3.3+12	2.5+12	7.3+11	3.8+11
2	2.3+11	1.5+11	5.0+10	3.9+10
3	1.4+11	1.2+11	2.9+10	2.6+10
4	1.1+11	8.2+10	2.4+10	1.9+10
5	7.9+10	6.0+10	2.1+10	1.5+10
6	1.6+11	1.2+11	4.1+10	3.1+10
7	2.4+11	1.9+11	5.3+10	4.4+10
8	2.1+11	1.7+11	4.8+10	4.0+10
9	2.2+11	1.7+11	5.3+10	4.3+10
10	2.2+11	1.7+11	6.0+10	4.7+10
11	3.3+11	2.6+11	8.9+10	7.3+10
12	4.6+11	3.6+11	1.3+11	1.1+11
13	4.0+11	3.1+11	1.4+11	1.1+11
14	1.3+12	9.8+11	6.2+11	5.0+11
15	1.3+12	1.1+12	1.0+12	8.8+11
16	1.4+12	1.1+12	1.5+12	1.4+12
17	1.3+12	1.0+12	1.6+12	1.5+12
18	1.2+12	9.6+11	1.4+12	1.3+12
19	9.2+11	7.4+11	7.8+11	7.9+11
20	7.3+11	5.8+11	6.2+11	6.2+11
21	4.0+11	3.3+11	3.2+11	3.2+11
22	1.1+11	8.5+10	7.7+10	7.7+10
23	2.3+10	1.8+10	1.4+10	1.4+10
B. Gamma-Ray				
1	9.1+7	7.6+7	1.8+7	2.0+7
2	4.3+10	3.2+10	1.2+10	1.6+10
3	9.7+10	7.7+10	4.7+10	4.9+10
4	2.8+11	2.2+11	6.1+10	6.8+10
5	1.0+11	8.0+10	3.6+10	4.4+10
6	2.5+11	2.0+11	5.8+10	7.1+10
7	4.6+11	3.7+11	1.0+11	1.3+11
8	4.7+11	3.6+11	1.2+11	1.6+11
9	9.0+11	6.7+11	2.4+11	3.4+11
10	3.8+12	3.0+12	1.5+12	1.8+12
11	1.3+12	1.0+12	4.8+11	5.1+11

TABLE 5.3
COMPARISON OF GROUP FLUXES COMPUTED BY VARIOUS MODELS
0.5m OUTSIDE THE IGLOO WALL

<u>Group</u>	<u>1-D</u>	<u>2-D (Toroidal)</u>	<u>2-D (Poloidal)</u>	
			<u>Between</u>	<u>Behind</u>
A. Neutron				
1	2.2+9	3.0+9	6.0+8	5.6+8
2	1.2+9	1.6+9	3.2+8	3.2+8
3	5.7+8	6.9+8	1.5+8	1.5+8
4	4.8+8	5.6+8	1.2+8	1.2+8
5	3.8+8	4.4+8	1.0+8	1.0+8
6	7.3+8	8.4+8	1.9+8	1.9+8
7	1.3+9	1.5+9	3.4+8	3.4+8
8	1.4+9	1.6+9	3.6+8	3.7+8
9	1.4+9	1.5+9	3.5+8	3.5+8
10	8.6+8	8.9+8	2.3+8	2.3+8
11	1.5+9	1.6+9	4.0+8	4.0+8
12	3.0+9	3.2+9	7.9+8	7.9+8
13	2.0+9	2.0+9	5.2+8	5.2+8
14	4.5+9	4.2+9	1.2+9	1.2+9
15	4.2+9	3.8+9	1.2+9	1.2+9
16	4.5+9	3.7+9	1.3+9	1.4+9
17	5.7+9	4.4+9	1.8+9	1.8+9
18	6.6+9	5.1+9	2.4+9	2.4+9
19	6.0+9	4.5+9	2.3+9	2.4+9
20	5.3+9	3.9+9	2.1+9	2.1+9
21	3.2+9	2.3+9	1.3+9	1.3+9
22	8.6+8	6.0+8	3.5+8	3.5+8
23	2.0+8	1.2+8	8.8+7	8.8+7
B. Gamma-Ray				
1	1.1+6	1.2+6	3.0+5	2.9+5
2	3.5+8	3.9+8	1.4+8	1.0+8
3	8.5+8	9.8+8	3.1+8	2.9+8
4	2.5+9	2.9+9	7.1+8	7.2+8
5	1.2+9	1.3+9	3.9+8	3.5+8
6	2.3+9	2.6+9	6.7+8	6.3+8
7	3.8+9	4.4+9	1.1+9	1.1+9
8	3.7+9	4.2+9	1.1+9	1.1+9
9	6.6+9	7.3+9	1.9+9	1.9+9
10	2.4+10	2.4+10	8.4+9	8.5+9
11	1.0+10	7.1+9	3.6+9	3.6+9

TABLE 5.4

COMPARISON OF SOME RADIATION QUANTITIES FROM DIFFERENT MODELS
AT 0.5m INSIDE THE AUXILIARY WALL

	<u>1-D</u>	<u>1-D (corrected)</u>	<u>2-D (Toroidal)</u>	<u>2-D (Poloidal)</u>
Total Neutron Flux	3.0+10	1.5+10	1.1+10	1.1+10
14 MeV Neutron Flux	4.5+8	2.3+8	2.5+10	1.5+8
Total Gamma-Ray Flux	2.5+10	1.2+10	1.0+10	9.0+9
Dose Equivalent, Neutron	2.3+5	1.2+5	9.2+4	7.2+4
Dose Equivalent, Gamma	5.5+3	2.8+3	2.6+3	2.0+3

Note:

Flux Unit (Particles/cm²/sec)

Dose Equivalent Unit (mr/pulse)

Several observations may be made: (a) Infinitely long cylindrical geometry is a reasonable approximation to the toroidal geometry near the source, the fluxes predicted by the 1-D model is 20% to 30% higher than those predicted by the 2-D toroidal model. The flux, however, is a non-directional quantity which does not indicate the effect of the angular distribution. Using simple ray tracing, one could find, at the plasma mid-plane, the radial current computed by the toroidal model is higher than that computed by the infinite cylinder approximation. It is for this reason that the fluxes, the group 1 flux in particular, outside the igloo shield, computed by the toroidal model is higher than those computed by the 1-D model.

(b) The presence of TF coils introduces an additional scattering medium, consequently the spectra obtained by the 2D poloidal model will be somewhat different in shape from those computed by the TF coil-absent models. The neutron fluxes at the vacuum vessel in the vicinity of 1 MeV for the poloidal model are about a factor of 2 to 3 higher than the TF coil-absent model, whereas the low energy neutron fluxes are about a factor of 2 lower. While the lower low energy neutron flux when the TF coils are present is the result of coil attenuation, we are obviously seeing here the contribution to the flux from the 14 MeV neutrons inelastically back-scattered from the coils (presumably from the steel casing). Further, the inelastic scatterings also generate many gamma-rays, so that the gamma-ray fluxes are also higher.

Away from the coils, the shielding effect of the coils becomes apparent. Comparison of the result computed by the 1D and 2D poloidal models where the only difference in the geometry is the presence of the coils in the latter, shows that the TF coils provide at least a factor of 4 reduction in high energy neutron flux just inside the igloo and a factor of 3 reduction just outside the igloo; the radial current behaves much in the same way. Furthermore, multiple collisions of the particles with the 26" of igloo concrete ease the flux fluctuation in the areas directly behind the coils and in-between the coils. It is interesting to note, in passing, that in this particular design, the fluxes behind the coil at some locations are higher than those in-between the coils (Actually, one could show geometrically, that at some location a detector behind the coil may see a larger source volume than the one in-between the coils does).

(c) Near the test cell wall, the infinitely long cylindrical model would over-estimate the radiation quantities geometrically. By equating the cylindrical source neutron current to the spherical source neutron current, an approximate correction factor may be derived. The corrected data has also been given on Table 5.4. Reasonably good agreement in results between 1D and 2D toroidal geometries are obtained. In general, the radiation quantities calculated by the toroidal geometry without the TF coils being modeled could be a factor of 2 too high near the test cell wall (due to the geometrical factor).

5.1.3 Neutron and Gamma Ray Fluxes in the Test Cell

The neutron and gamma-ray flux spectra at the plasma midplane and at:

- (a) the TF coil outer edge, between coils, and
- (b) 8 meters from the machine center line are given in Figure 5.4, and 5.5. Figure 5.4 is based on the 2-D poloidal model calculation and Figure 5.5 is based on the 2-D toroidal model calculation. The spectra are plotted in units of particles/cm²/sec per unit lethargy where lethargy is defined as the logarithm of E_g/E_{g+1} , with E_g , E_{g+1} being the upper and lower energy boundary of the gth group. The flux per unit lethargy shows "true" energy dependent behavior. For instance, the little peak at 2.3 MeV in the neutron flux spectrum 8 m from the machine center corresponds to the cross section dip in oxygen, a major constituent of concrete.

The spatial distributions of the total neutron and total gamma-ray fluxes are presented in Figure 5.6 and 5.7 based on the 2D poloidal model and in Figures 5.8 and 5.9 based on the 2D toroidal model. Further, the 14 MeV flux distribution is shown in Figure 5.10 based on the 2D toroidal model. As a general rule, 1 foot of concrete approximately reduces the fluxes by an order of magnitude. The lifetime DT neutron fluence within the igloo is about 5×10^{16} . Within the test cell, the lifetime DT fluence is 5×10^{13} .

5.1.4 Dose Responses and Distribution in the Test Cell

The total biological dose map within the test cell is illustrated in Figure 5.11. The dose is on the order of 10^5 mr/pulse. This extremely high dose excludes any access to in the test cell during.

The biological dose at the outer surface of the test cell wall is presented in Figure 5.12. The total dose in the vicinity of the plasma midplane amounts to 0.4 to 0.6 mr/pulse, or equivalently 0.4 to 0.6 rem/year (assuming 1000 pulses per year); nearly half of the dose is from gamma-rays. At the height where the auxiliary wall disappears, the dose takes a sharp increase, reaching a maximum of 2 mr/pulse at 9 meters from the ground. At still higher elevation, the dose decreases due to the geometrical factor.

The design objective specifies that the yearly dose at the outer test cell wall surface shall be less than 1 rem. This objective appears to be met at the elevation where people would usually stand. However, the access should be controlled and restricted since any pulsing scheme in excess of 5 pulses per hour would deliver more than 2.5 mr/hour of dose, the continuous exposure limit usually assumed for radiation workers.

The physical dose map for carbon, silicon, tissue and SS-304 are illustrated in Figure 5.13. The data are in units of Gy/pulse and are based on the 2D toroidal model. The fractional contributions due to gamma-rays alone are given in the parenthesis. The average dose in the test cell is about 0.1 Gy/pulse, equivalent to a life time dose of 40,000 rads (DT alone). The life time dose inside the igloo will be in the order of 10^7 rads (DT alone). The gamma-ray dose contributes at least half of the total dose.

Figure 5.4 (a) Neutron Flux Spectrum at TF Coil Outer Edge, between Coils

Figure 5.4 (b) Gamma-Ray Flux Spectrum at TF Coil Outer Edge, between Coils

Figure 5.5 (a) Neutron Flux Spectrum at 8 m from Machine Center, Plasma Midplane

Figure 5.5 (b) Gamma-Ray Flux Spectrum at 8 m from Machine Center, Plasma Midplane

Figure 5.6

Total Neutron Flux Distribution in the Test Cell, 2D Poloidal Model

a. 1.2×10^{13}	f. 1×10^{12}
b. 8×10^{12}	g. 1×10^{11}
c. 5×10^{12}	h. 2×10^{10}
d. 3×10^{12}	i. 1.5×10^{10}
e. 2×10^{12}	j. 1.2×10^{10}

Figure 5.7 Total Gamma-Ray Flux Distribution in the Test Cell, 2D Poloidal Model

Figure 5.8 Total Neutron Flux Distribution in the Test Cell, 2D Toroidal Model

Figure 5.9 Total Gamma-Ray Flux Distribution in the Test Cell, 2D Toroidal Model

a. 1×10^{13}	e. 1×10^{10}	i. 2×10^8	m. 1×10^6
b. 5×10^{12}	f. 2×10^9	j. 1×10^8	n. 1×10^5
c. 1×10^{12}	g. 1×10^9	k. 5×10^7	o. 1×10^4
d. 1×10^{11}	h. 5×10^8	l. 1×10^7	p. 1×10^3

Figure 5.10 14 Me V Neutron Flux Distribution in the Test Cell, 2D Toroidal Model

Figure 5.11 Total Biological Dose Distribution in the Test Cell, 2D Toroidal Model

Figure 5.12 Biological Dose Distribution on the Outer Surface of the Test Cell Wall

Figure 5.13 Physical Dose Distribution in the Test Cell, Toroidal Model. The Fractional Contributions due to Gamma-Rays Are Given in the Parentheses.

5.1.5 Radiation Damage Data and Igloo Heating

Some of the data relevant to the radiation damage evaluation are given in Table 5.5. The responses have been computed for the vacuum vessel, a Mo limiter, the TF coil casing, Cu, E-glass and the epoxy in the TF coils.

The instantaneous nuclear heating profile through the igloo concrete is given in Figure 5.14. The temperature profile is presented in Figure 5.15. The calculation here assumes that the igloo may be treated as an infinite slab with a constant ambient temperature maintained on both surfaces. The specific heat has been assumed to be 0.156 Btu/lb/°F and the conductivity has been assumed to be 0.5 Btu/hr/ft/°F in the case of without rebar (1.5 Btu/hr/ft/°F with rebar). It is seen that the maximum temperature increment is $2^{\circ} - 4^{\circ}$ after 96 consecutive pulses.

5.2 Radiation Level in the Inner Basement Area⁽²¹⁾

5.2.1 Description of Calculational Models

Two cases have been studied:

- (a) 1-D Cylindrical Model,
- (b) 2-D Toroidal Model.

The 1-D model assumes the torus is an infinitely long cylinder and the vacuum vessel, machine substructure concrete and basement floor are infinitely long concentric cylindrical shells. Thus the basement area is completely shielded by the 6' of concrete. A schematic drawing of this model is given in Figure 5.16. The one dimensional analysis provides reasonably good results when all the streaming paths are adequately shielded by the concrete or by similar materials.

TABLE 5.5

DATA RELEVANT TO THE RADIATION DAMAGE EVALUATION

		Neutron Fluence (n/cm ² /pulse)	Gamma Fluence (γ /cm ² /pulse)	Neutron Kerma (rad/pulse)	Gamma Kerma (rad/pulse)	Displacement dpa/pulse	Gas Production He H (appm/pulse)	
Vacuum Vessel (SS-304)		1.6+13	7.4+12	3.0+3	4.1+3	2.2-8	2.5-7	8.4-7
No Limiter		1.7+13	7.6+12	3.4+2	5.0+3	1.6-8	6.7-8	2.2-7
TF Casing (Nitronic)	front center	1.5+13	7.0+12	1.5+3	3.6+3	1.5-8	1.2-7	4.2-7
	side center	7.0+12	2.6+12	4.0+2	1.4+3	6.7-9	3.0-8	1.0-7
TF Cu	Max.	1.2+13	4.5+12	5.1+2	2.5+3	8.8-9	3.2-8	1.9-7
	front center	1.1+13	3.8+12	4.0+2	2.3+3	7.1-9	2.2-8	1.3-7
E-Glass in TF	Max.	1.2+13	4.2+12	3.4+3	2.2+3	----	3.7-6	1.8-7
	Ave.	5.2+12	1.7+12	1.7+3	9.5+2	----	2.0-6	4.4-8
Epoxy	Max.	1.2+13	4.2+12	1.6+4	2.3+3	-----	----	----
	Ave.	5.2+12	1.7+12	5.1+3	9.6+2	--	----	----

Figure 5.14 Instantaneous Nuclear Heating Profile in the Igloo Wall

Figure 5.15 Temperature Profile in the Igloo Wall, k = Heat Conductivity

The 2D Model is a (R, Z) geometry with the line of symmetry along the machine center. A schematic drawing is illustrated in Figure 5.17. Note that the center column and the elevated shield plug have been included in the model. Being a toroidal geometry, however, the TF coils are unable to be included.

The discrete ordinates method with S_8 quadrature order has been employed for the analyses.

5.2.2 Comparison of Particle Fluxes Using Different Models

The fluxes computed by the 1D and 2D models are compared in Table 5.6 for the location just below the substructure shield. Three radial positions are given for the 2D data (a) center column, (b) 2m from the machine center and (c) 5 m from machine center. Directly under the plasma, neutron fluxes with energy greater than 10 MeV are unaffected by the hollow center column and the elevated shield plug. The streaming through the center column, however, is very significant for the rest of the neutron energies and for the gamma rays. For low energy neutrons, a difference of 2 to 3 orders of magnitude may be observed directly under the plasma.

5.2.3 Neutron and Gamma-ray Flux Distribution in the Inner Basement Area

The neutron and gamma-ray flux spectra at the middle of the inner basement area are illustrated in Figure 5.18. The data here have been based on a 2D calculation. The low energy neutrons ($E < 100$ keV) are the predominant component in the neutron population.

Figure 5.16 Schematic Representation of One-Dimensional Inner Basement Model, Unit = Meter

Figure 5.17 Schematic Representation of Two-Dimensional Inner Basement Model, Unit = Meter

TABLE 5.6
COMPARISON OF GROUP FLUX UNDERNEATH THE SUBSTRUCTURE

<u>GROUP</u>	<u>A</u>	<u>B</u>	<u>ANISN</u>	<u>C</u>
Neutron				
1	4.5+7	1.7+4	1.7+4	6.7+3
2	6.5+7	2.1+4	2.1+4	1.1+4
3	4.2+7	1.8+4	1.4+4	1.1+4
4	2.9+7	3.2+4	1.7+4	1.4+4
5	2.3+7	3.7+4	1.6+4	1.6+4
6	5.6+7	6.8+4	2.9+4	3.2+4
7	7.0+7	1.4+5	6.6+4	5.8+4
8	7.8+7	1.9+5	8.1+4	8.6+4
9	8.6+7	2.4+5	7.8+4	1.1+5
10	8.1+7	2.0+5	4.8+4	1.0+5
11	1.1+8	3.7+5	8.3+4	1.8+5
12	1.7+8	7.3+5	2.0+5	3.4+5
13	1.8+8	5.5+5	1.3+5	2.7+5
14	8.8+8	2.7+6	3.1+5	1.4+6
15	1.3+8	4.7+6	3.0+5	2.5+6
16	2.9+9	1.1+7	3.4+5	6.0+6
17	5.2+9	2.3+7	4.2+5	1.3+7
18	7.3+9	3.9+7	5.0+5	2.1+7
19	7.4+9	4.8+7	4.7+5	2.6+7
20	7.2+9	5.3+7	4.3+5	3.0+7
21	5.0+9	4.4+7	2.9+5	2.6+7
22	1.7+9	1.8+7	1.0+5	1.1+7
23	7.1+8	1.8+7	8.5+4	1.4+7
Gamma-Ray				
1	1.0+5	9.3+2	6.7+2	3.3+2
2	1.1+8	4.3+5	2.4+5	1.8+5
3	2.4+8	1.2+6	3.7+5	7.4+5
4	2.4+8	2.2+6	8.0+5	1.3+6
5	2.1+8	1.6+6	6.6+5	9.1+5
6	2.7+8	2.9+6	9.2+5	1.9+6
7	3.2+8	3.7+6	1.3+6	2.4+6
8	4.9+8	5.1+6	1.3+6	3.6+6
9	9.5+8	7.2+6	2.4+6	4.5+6
10	2.0+10	1.0+8	7.3+6	7.3+7
11	7.8+9	6.8+7	3.0+6	4.2+7

Note: A: Center column
 B: 2" from machine center line
 C: 5" from machine center line

Figure 5.18 (a) Neutron Flux Spectrum at the Middle of the Inner Basement Area, 2D Model

Figure 5.18 (b) Gamma-Ray Flux Spectrum at the Middle of the Inner Basement Area, 2D Model

The spatial distributions of the total neutron and total gamma-ray fluxes are shown in Figure 5.19 and 5.20. It may be observed that the peak of the flux contour gradually shifts outward as the distance from the base shield increases. Thus we observe here the wall scattering of the particles going through the central void.

5.2.4 Dose Response Distribution in the Inner Basement Area

The biological dose distribution is shown in Figure 5.21. When the center column is left open, the biological dose would be in the range of 10^3 mr/pulse to 400 mr/pulse, ignoring the TF coil shielding. Access to this area should not be allowed even though a short stay is possible if it is absolutely necessary. In comparison, when the basement is completely shielded by 6' of concrete, the biological dose at the floor will be 20 mr/pulse.

The physical dose distribution for silicon is shown in Figure 5.22. Some additional physical dose for the materials of interests are given in Table 5.7. It may be noticed that, except for tissue, the overwhelming portion of the dose is from gamma-rays. The lifetime dose for any material will not exceed 2×10^4 rads.

5.3 Radiation Level in the Outer Basement Area

5.3.1 Description of the Calculational Model

A 2D (R, Z) model has been used for the analysis. A schematic drawing is presented in Figure 5.23. The energy and spatial dependent source particles coming from the top side and from the inner radial side were derived from the test cell and inner basement analysis.

Figure 5.19

Total Neutron Flux Distribution in the Inner Basement, (0, 0)
 at Machine Center and at the Bottom of the Substructure

Figure 5.20 Total Gamma-Ray Flux Distribution in the Inner Basement

Figure 5.21 Total Biological Dose Distribution in the Inner Basement

Figure 5.22 Total Si Dose Distribution in the Inner Basement

TABLE 5.7

PHYSICAL DOSES AT VARIOUS LOCATIONS IN THE INNER BASEMENT AREA
(Gy/pulse)

<u>material</u>		0.5m < Base Shield			0.5m > Floor		
		1	2	3	1	2	3
C	n	3.8-3	4.5-5	1.8-5	7.5-5	9.2-5	2.5-5
	γ	1.3-2	3.0-4	1.7-4	5.0-4	5.0-4	2.2-4
Al	n	1.5-3	3.7-5	2.8-5	6.8-5	7.1-5	3.8-5
	γ	1.3-2	3.1-4	1.8-4	5.3-4	5.3-4	2.3-4
Tissue	n	2.9-2	2.3-4	1.3-4	6.2-4	7.5-4	2.3-4
	γ	1.4-2	3.3-4	1.9-4	5.5-4	5.5-4	2.4-4
Si	n	1.0-3	1.0-5	2.9-6	1.9-5	2.3-5	5.6-6
	γ	1.4-2	3.3-4	1.9-4	5.5-4	5.5-4	2.4-4
Fe	n	3.5-4	2.9-6	1.2-6	6.3-6	7.6-6	1.8-6
	γ	1.7-2	1.9-4	2.4-4	6.9-4	6.9-4	3.0-4

Note: Point 1 Under Center Column
Point 2 Plasma Center Line
Point 3 6m from Machine Center

Again, the discrete ordinates method with S_8 quadrature order has been used for the calculation. Since the sources are obtained from 2D test cell and inner basement calculation, the TF coil shielding effect will not be accounted for, but the central column void effect will be included.

5.3.2 Neutron and Gamma-Ray Flux Distribution in the Outer Basement Area⁽²²⁾

The neutron and gamma ray flux spectra at:

- (a) the center of the basement (6 m below plasma midplane, 11 m from machine center),
- (b) the upper left corner,
- (c) the lower left corner,
- (d) the lower right corner

are given in Table 5.8. The flux spectra at the center of the basement are plotted in Figure 5.24(a) and 5.24(b) for neutrons and gamma-ray respectively. The thermal neutrons are now the dominant component in the neutron population.

The spatial distributions of the fluxes for 14 MeV neutrons, total neutrons and total gamma rays are shown in Figure 5.25, 5.26 and 5.27. One may observe that the 14 MeV neutrons in the outer basement area are mainly those penetrating through the igloo and test cell floor near the basement wall area.

5.3.3 Distributions of Dose Responses in the Outer Basement Area

The spatial distribution of the biological dose is illustrated in Figure 5.28. The yearly biological dose in this area will be on the order of 30 rem. Access to this area during pulsing again should be controlled.

The spatial distribution of the silicon dose is given in Figure 5.29. Some comparisons of the physical dose of interest are also presented in Table 5.9. Again the gamma-ray dose is the major contributor to the total dose.

5.4 Biological Dose Within TFTR Site⁽²³⁾

5.4.1 Description of Calculational Models

The biological dose outside the test cell during TFTR operation has been calculated using either the Monte Carlo technique or the analytic method. For distances greater than 75 meters (from the machine center), particles leaking from the test cell wall and roof computed by the 2D toroidal model were sampled; and their subsequent collision histories were followed. It has been assumed that:

- (a) the ground is flat and the elevation is the same as that of the test cell floor,
- (b) air density remains a constant,
- (c) shielding provided by the mock up building, field coil power conversion building, the trees etc. may be ignored.

A schematic drawing of the model is given in Figure 5.30.

The biological dose at various locations within the 75 meter radius has been computed by the analytic methods. The skyshine contributions were estimated using the Lindenbaum's⁽²⁴⁾ and Clark's⁽²⁵⁾ formula for neutrons and gamma rays respectively. The direct contributions from leakage particles were estimated by simple geometrical attenuations. The formula used for the calculation are listed in Table 5.10.

Figure 5.23 Schematic Representation of Two-Dimensional (r, z) Outer Basement Model, $(0, 0)$ at Machine Center and at Plasma Midplane

TABLE 5.8
COMPARISON OF GROUP FLUX AT VARIOUS LOCATIONS
IN THE OUTER BASEMENT AREA

<u>Group</u>	<u>L1</u>	<u>L2</u>	<u>L3</u>	<u>L4</u>
A. Neutron				
1	2.4+3	7.0+3	1.2+3	5.6+2
2	4.6+3	1.3+4	3.9+3	1.3+3
3	3.6+3	9.5+3	3.4+3	1.2+3
4	5.0+3	1.2+4	4.5+3	1.6+3
5	5.4+3	1.3+4	4.8+3	1.8+3
6	9.8+3	2.4+4	9.0+3	3.5+3
7	2.1+4	5.0+4	1.8+4	7.2+3
8	2.7+4	6.5+4	2.5+4	1.0+4
9	3.1+4	7.4+4	2.9+4	1.3+4
10	2.0+4	5.0+4	2.0+4	9.4+3
11	4.1+4	9.8+4	4.0+4	1.8+4
12	1.1+5	2.6+5	1.0+5	4.7+4
13	4.4+4	1.4+5	5.9+4	2.9+4
14	1.6+5	3.5+5	1.6+5	8.4+4
15	1.6+5	3.4+5	1.7+5	9.3+4
16	1.8+5	3.8+5	1.8+5	1.1+5
17	2.7+5	5.4+5	3.1+5	1.7+5
18	3.7+5	7.0+5	4.6+5	2.2+5
19	4.3+5	7.5+5	5.7+5	2.6+5
20	5.7+5	9.7+5	8.7+5	3.3+5
21	7.3+5	1.2+6	1.2+6	4.2+5
22	5.1+5	8.1+5	8.9+5	2.9+5
23	1.3+7	2.0+7	2.0+7	9.1+6
B. Gamma-Ray				
1	1.5+2	3.7+2	7.7+1	6.2+1
2	6.4+4	1.6+5	8.5+4	2.9+4
3	3.5+5	6.7+5	5.4+5	1.7+5
4	5.2+5	1.0+6	7.4+5	2.4+5
5	3.9+5	7.5+5	5.5+5	1.8+5
6	8.5+5	1.6+6	1.3+6	4.1+5
7	1.1+6	2.0+6	1.6+6	5.2+5
8	1.6+6	2.8+6	2.4+6	7.7+5
9	2.0+6	3.8+6	2.9+6	9.3+5
10	6.5+6	1.2+7	9.4+6	3.9+6
11	4.6+6	7.7+6	5.9+6	3.2+6

Note: L1: Center, 11m from machine center line, 6m below plasma midplane
 L2: Upper left corner
 L3: Lower left corner
 L4: Lower right corner

Figure 5.24 (a) Neutron Flux Spectrum at Outer Basement Center

Figure 5.24 (b) Gamma-Ray Flux Spectrum at Outer Basement Center

Figure 5.25 14 Me V Neutron Flux Distribution in the Outer Basement

Figure 5.26 Total Neutron Flux Distribution in the Outer Basement

Figure 5.27 Total Gamma-Ray Flux Distribution in the Outer Basement

Figure 5.28 Total Biological Dose Distribution in the Outer Basement

Figure 5.29 Total Si Dose Distribution in the Outer Basement

TABLE 5.9
COMPARISON OF FLUENCES AND PHYSICAL DOSES
AT VARIOUS LOCATIONS IN THE OUTER BASEMENT AREA

	<u>L1</u>	<u>L2</u>	<u>L3</u>	<u>L4</u>
Fluence (part./cm ² /pulse)				
n	8.5+6	1.4+7	1.3+7	5.6+6
γ	9.0+6	1.6+7	1.3+7	5.2+6
Dose Equivalent (mr/pulse)				
n	2.3+1	4.5+1	2.7+1	1.3+1
γ	5.4+0	1.0+1	7.9+0	2.8+0
C Kerma (Gy/pulse)				
n	1.7-6	4.0-6	1.7-6	8.2-7
γ	4.4-5	8.3-5	6.5-5	2.2-5
Tissue Kerma (Gy/pulse)				
n	1.3-5	2.9-5	1.3-5	6.5-6
γ	4.9-5	9.1-5	7.2-5	2.5-5
Si Kerma (Gy/pulse)				
n	4.7-7	1.1-6	4.5-7	2.1-7
γ	4.8-5	9.0-5	7.1-5	2.4-5
SS-304 Kerma (Gy/pulse)				
n	1.8-7	4.3-7	1.8-7	8.0-8
γ	5.5-5	1.0-4	7.9-5	2.8-5

Note: L1: Center, 11m from machine center line, 6m below plasma midplane
L2: Upper left corner
L3: Lower left corner
L4: Lower right corner

Notice that, since the leakage current from the 2D toroidal model calculation has been used, the TF coil shielding will not be accounted for in the site boundary analysis.

5.4.2 Biological Dose Through TFTR Site

The Monte Carlo calculational results are presented in Table 5.10 and Figure 5.31. The doses within the 75 meter radius and at the proposed site boundary (125 meters from the machine center line) are given in Table 5.10. It may be observed that:

- (a) within the range of Monte Carlo calculation, the direct contribution (particles leaking from test cell and reaching the detector without suffering a single collision) accounts for roughly half of the total dose.
- (b) direct gamma-ray contribution to the gamma-ray dose is larger than the direct neutron contribution to the neutron dose. Yet the total neutron dose ranges from twice to about the same as the gamma-ray dose from 75 m to 250 m, indicating that neutron scattering from the air and ground bears more importance to the dose than the gamma-ray scattering does.
- (c) The leakage from the test cell roof contributes at most one tenth of the total dose even at an elevation of 8 meters from the ground.
- (d) The total dose at the site boundary and at 1 meter above the ground is 0.01 mr/pulse or equivalently 10 mr/year (assume 1,000 pulses per year). The dose exceeds the design objective of 5 mr/yr (assume that 5 mr/yr is allocated to radioactive nuclide release) by a factor of 2. If all the major penetrations are adequately shielded, the TF coil shielding will provide about a factor 2 reduction in the dose. Thus, the site boundary dose is expected to barely meet the design objective.
- (e) The total dose at 8 meters above the ground is marginally higher than that at ground level for distances greater than 70 meters, even though there is a factor of 4 difference right outside the wall.

(f) In the Monte Carlo calculation, fairly high water content was assumed for the earth. There are indications that the fast neutron dose due to ground reflection will be increased if the hydrogen content of the soil is reduced. However, no statistically significant difference has been seen in the total dose even if the water content in the soil is cut in half.

(g) The total biological dose at most locations outside the test cell wall will be less than 0.5 rem/yr. For distances greater than 50 meters, the total dose (not near the processed cooling water basement) will be not only less than 500 mr/yr, but also less than 2 mr/hr (and thus less than 100 mrem for a normal work week) even if the fastest pulsing scheme is assumed (12 pulses/hour, 96 pulses/day).

- ① Building
- ② Air
- ③ Soil
- ④ Leakage Source From
Test Cell

Figure 5.30 Schematic Representation of the Model for Site-Boundary Dose Analysis, Unit = Meter

Figure 5.31 Biological Dose Rate as a Function of Distance from TFTR Center, the Vertical Bars Indicate the Standard Errors Associated with the Monte Carlo Calculation

TABLE 5.10

FORMULA USED FOR SKYSHINE CALCULATIONS

(A) Direct Dose

$$D(r) = D_w \left(\frac{r_w}{r} \right)^2 e^{-\Sigma_t (r-r_w)}$$

D_w = Dose rate at wall surface

r_w = radius of test cell wall surface

Σ_t = air attenuation coefficient
 $= 7.5 \times 10^{-5} \text{ cm}^{-1}$

(B) Neutron Skyshine (Lindenbaum method)

$$D(r) = \frac{c \cdot q \cdot K}{4 \pi D r} e^{-k_0 r}$$

q = neutron emission rate from wall surface

K = fraction of neutrons contributing to the scattered
 flux = 0.9

$$k_0 = \sqrt{3 \Sigma_a \Sigma_s (1 - 2/3A)}$$

$$\approx 4.1 \times 10^{-5} \text{ cm}^{-1}$$

Σ_a = absorption cross section for air

Σ_s = scattering cross section for air

A = atomic number

D = diffusion coefficient in air
 $= 5 \times 10^3 \text{ cm}^2$

c = flux to dose conversion

(C) γ - Skyshine (Clark Method)

$$D_\infty = D_w \left(\frac{r_w}{r} \right)^2 \left[\frac{B(\mu r) - 1}{B(\mu r_w) - 1} \right] e^{-\mu(r-r_w)}$$

D_w = dose rate on the wall surface

B = dose buildup factor

μ = attenuation coefficient
 $= 7.4 \times 10^{-5} \text{ cm}^{-1}$

$$D_{\text{sky}} = \frac{1}{2} D_\infty K' G(w)$$

K' = correction factor; experimentally determined

$G(w)$ = visible fraction of the sky

TABLE 5.11

BIOLOGICAL DOSE AT DISTANCES GREATER
THAN 75 m

A. 1 m Above Ground

a. Neutron Dose

R (m)	Direct	Side Total	Roof	Total (Side & Roof)
75	1.33-2 ± 0.08*	2.83-2 ± 0.24	8.49-4 ± 0.43	2.92-2 ± 0.24
125	2.86-3 ± 0.09	5.70-3 ± 0.09	3.35-4 ± 0.20	6.04-3 ± 0.09
150	1.62-3 ± 0.09	4.14-3 ± 0.16	2.39-4 ± 0.33	4.38-3 ± 0.15
200	5.85-4 ± 0.09	1.69-3 ± 0.19	1.06-4 ± 0.27	1.80-3 ± 0.18
250	2.52-4 ± 0.09	7.38-4 ± 0.17	4.10-5 ± 0.15	7.79-4 ± 0.17

b. Gamma-Ray Dose

R (m)	Direct	Side Total	Roof	Total (Side & Roof)
75	1.07-2 ± 0.03	1.43-2 ± 0.05	1.80-4 ± 0.08	1.45-2 ± 0.05
125	2.81-3 ± 0.03	3.73-3 ± 0.04	1.45-4 ± 0.15	3.88-3 ± 0.04
150	1.71-3 ± 0.03	2.41-3 ± 0.04	1.00-4 ± 0.16	2.51-3 ± 0.04
200	7.62-4 ± 0.03	1.23-3 ± 0.05	8.75-5 ± 0.44	1.32-3 ± 0.06
250	3.95-4 ± 0.03	7.30-4 ± 0.11	2.45-5 ± 0.03	7.55-4 ± 0.11

c. Combined (Neutron + Gamma)

R (m)	Direct	Side Total	Roof	Total (Side & Roof)
75	2.40-2 ± 0.05	4.27-2 ± 0.16	1.03-3 ± 0.37	4.37-2 ± 0.16
125	5.67-3 ± 0.05	9.40-3 ± 0.16	4.81-4 ± 0.15	9.88-3 ± 0.06
150	3.33-3 ± 0.05	6.55-3 ± 0.10	3.39-4 ± 0.27	6.89-3 ± 0.10
200	1.35-3 ± 0.04	2.91-3 ± 0.11	1.92-4 ± 0.24	3.10-3 ± 0.11
250	6.46-4 ± 0.04	1.46-3 ± 0.09	6.54-5 ± 0.10	1.53-3 ± 0.09

B. 8 m Above Ground

a. Combined (Neutron + Gamma)

R (m)	Direct	Side Total	Roof	Total (Side & Roof)
75	2.59-2 ± 0.05	4.29-2 ± 0.08	1.05-3 ± 0.16	4.40-2 ± 0.08
125	6.03-3 ± 0.05	1.08-2 ± 0.05	5.63-4 ± 0.15	1.14-2 ± 0.05
150	3.54-3 ± 0.04	7.30-3 ± 0.08	4.72-4 ± 0.36	7.77-3 ± 0.09
200	1.44-3 ± 0.04	3.52-3 ± 0.17	2.26-4 ± 0.23	3.75-3 ± 0.17
250	6.98-4 ± 0.04	1.63-3 ± 0.09	8.78-5 ± 0.18	1.64-3 ± 0.09

* Fractional Standard Error

TABLE 5.12

BIOLOGICAL DOSE (mr/pulse) AT VARIOUS LOCATIONS IN FTR SITE, 20 MW DT

Location	R(m)	Direct	Skyshine	Total	Others
Test Cell West*	25	0.32	0.24	0.344	(1) 0.01 mr/yr (2) 5 mr/yr
Test Cell Corner, Mock-up Room Center	33	0.18	0.019	0.199	
Mock-up Room North	42	0.11	0.014	0.124	
Electrical Station North-East (4)	47	0.05	0.007	0.057	(3) 12 mr/yr
Hot Cell East (5)	44	---	0.003	0.003	(3) 3 r/yr
N.B.P.C. Bldg. East-South (4)	54	0.034	0.011	0.195 ⁽⁶⁾	(7) 0.15 mr/pulse (3) 10 mr/yr
F.C.P.C. Bldg. Center West-South	71	0.040	0.008	0.088	(7) 0.04 mr/pulse
Capacitor Yard South	87	0.016	0.006	0.022	
Site Boundary West	125	0.006	0.006	0.011	(2) 0.1 mr/yr

Note:

* Reference north: perpendicular to the test cell north wall.

1. Activation dose, assume 1000 consecutive pulses shot early in a year, igloo remained in place afterwards.
2. Activation dose, assume 1000 consecutive pulses shot early in a year, igloo removed afterwards.
3. Activation dose, assume 1000 consecutive pulses shot early in a year, major activated objects moved into hot cell afterwards.
4. Shielding provided by the 4' hot cell north (or south) wall considered.
5. Shielding provided by the 3' hot cell east wall considered.
6. Dose from activated water flowing through chiller included.
7. Dose from activation TF coil cooling water flowing through chiller in water processing building.
8. No allowance has been made for radiation shielding provided by the walls or roofs of the Mock-up Assembly room, Neutral Beam Power Conversion building and the Field Coil Power Conversion building. All objects inside these buildings and the equipment in the Field Coil and Neutral Beam Power Conversion yards are ignored.

6.0 DD-ANALYSIS

In this chapter, we present the results of the analysis of the radiation levels in the TFTR site during deuterium plasma operation. This analysis was done in much the same way as that for the DT operation. The major difference is that the igloo will not be installed in the DD pulsing.

6.1 Radiation Level in the Test Cell⁽²⁶⁾

6.1.1 Comparison of Particle Fluxes Using Different Models

Comparisons of the flux spectra at

(a) the vacuum vessel, and

(b) 2.3 m from the plasma center line are given in Table 6.1 and 6.2. Comparisons of some integral radiation quantities at 0.5 m inside the auxiliary wall are given in Table 6.3. The fluxes are those at the plasma midplane.

Comparison of flux spectra between the 1-D and 2-D toroidal cases reveals the geometrical effect; and comparison of flux spectra between the 1-D and 2-D poloidal cases indicates the effect of the TF coils on the particle transport.

Without the back scattering from the igloo concrete, the differences between the 1-D and 2-D toroidal results at the vacuum vessel are reduced except for the thermal neutron flux. The differences between the 1-D and 2-D poloidal results, on the other hand, are greatly enhanced at approximately 1 MeV. As expected, the presence of the TF coils blocks partially the source particle streaming paths and softens the neutron spectrum as a consequence. As with DT case, the TF coils provide at least a factor of 4-5 reduction in high energy neutron fluxes near the coils. Notice that without the igloo, the secondary gamma ray spectra at some energies at 2.3 meter from plasma center line for the 2-D poloidal case are higher than those for the 1-D case.

Comparison of the data at 0.5 m from the auxiliary wall again shows that the 1-D model overestimates the radiation quantities geometrically by about a factor of 2. However, lacking the attenuation by the igloo concrete, the TF coil shielding factor for fast neutrons is now about 2 (in comparison with the 3 for the DT case), corresponding to the area ratio that is not covered by the TF coils.

6.12 Neutron and Gamma Ray Fluxes in the Test Cell

The neutron and gamma ray flux spectra at the plasma midplane and at :

- (a) TF coil outer edge and between coils, and
- (b) 8 meters from the machine center are illustrated in Figure 6.1 - 6.2. As in the DT analysis, (a) is the result of the 2D poloidal model calculation and (b) is the result of 2D toroidal model calculation.

The spatial distribution of the total neutron and gamma ray fluxes are shown in Figure 6.3 and 6.4 for the 2D poloidal model and in Figure 6.7, 6.8 for the 2D toroidal model.

Notice that, without the igloo, the variations in the spatial distribution of the neutron and gamma ray fluxes when the TF coils are present are clearly observable. At 1 meter from the TF coils the fluxes behind the coils are slightly higher than those in-between the coils. Yet at about 4 meters away from the coils, the situation is reversed. The space between TF coils behaves much like the penetration gap. The wall scattering of the TF coils apparently contributes to this unexpected variation.

TABLE 6.1
COMPARISON OF GROUP FLUXES COMPUTED BY DIFFERENT MODELS
AT THE VACUUM VESSEL

<u>Group</u>	<u>1-D</u>	<u>2-D (Toroidal)</u>	<u>2-D (Poloidal)</u>
<u>A. Neutron</u>			
1	1.3+9	1.1+9	1.3+9
2	3.1+7	3.0+7	4.9+7
3	9.2+6	8.9+6	1.2+7
4	1.3+7	1.3+7	1.9+7
5	1.4+7	1.4+7	2.3+7
6	2.3+7	2.3+7	3.8+7
7	2.1+7	2.1+7	3.2+7
8	1.9+7	1.9+7	3.0+7
9	2.2+7	2.2+7	3.6+7
10	2.6+7	2.6+7	4.6+7
11	3.0+7	3.1+7	5.8+7
12	7.0+10	6.0+10	7.7+10
13	5.5+9	5.9+9	9.8+9
14	1.3+10	1.4+10	3.4+10
15	5.2+9	5.9+9	2.8+10
16	3.2+9	3.6+9	2.7+10
17	2.3+9	2.2+9	1.8+10
18	1.9+9	1.5+9	5.8+9
19	1.4+9	1.1+9	9.8+8
20	1.2+9	8.7+8	8.9+8
21	6.6+8	5.0+8	4.2+8
22	1.8+8	1.4+8	9.5+7
23	3.6+7	1.9+7	1.2+7
<u>B. Gamma-ray</u>			
1	2.8+4	9.2+3	6.9+3
2	3.5+7	3.5+7	9.2+7
3	5.7+7	5.6+7	2.7+8
4	4.1+7	4.7+7	1.4+8
5	4.2+7	4.5+7	1.6+8
6	5.8+7	6.8+7	1.9+8
7	9.9+7	1.1+8	2.9+8
8	2.1+8	2.3+8	5.3+8
9	2.3+9	2.3+9	4.2+9
10	1.4+10	1.4+10	2.8+10
11	1.5+9	1.4+9	2.7+9

TABLE 6.2

COMPARISON OF GROUP FLUXES COMPUTED BY DIFFERENT MODELS

AT 2.3 METERS FROM MACHINE CENTER LINE

			<u>2-D (Poloidal)</u>	
<u>Group</u>	<u>1-D</u>	<u>2-D (Toroidal)</u>	<u>Between</u>	<u>Behind</u>
A. <u>Neutron</u>				
1	4.9+8	3.5+8	1.0+8	5.1+7
2	1.4+7	1.0+7	4.7+6	3.0+6
3	6.1+6	4.9+6	1.7+6	1.2+6
4	5.7+6	5.0+6	1.9+6	1.2+6
5	5.0+6	4.3+6	2.1+6	1.2+6
6	8.6+6	7.8+6	3.6+6	2.2+6
7	1.0+7	9.1+6	3.6+6	2.4+6
8	9.4+6	7.9+6	3.5+6	2.3+6
9	1.1+7	8.7+6	4.2+6	2.8+6
10	1.2+7	9.6+6	5.2+6	3.4+6
11	1.4+7	1.2+7	6.9+6	4.7+6
12	2.5+10	1.9+10	6.2+9	2.9+9
13	2.8+9	2.3+9	1.1+9	7.0+8
14	5.6+9	5.0+9	3.9+9	2.6+9
15	2.8+9	2.6+9	4.1+9	3.0+9
16	2.2+9	1.9+9	4.7+9	3.7+9
17	2.1+9	1.5+9	4.1+9	3.4+9
18	1.9+9	1.3+9	2.6+9	2.4+9
19	1.5+9	9.5+8	1.2+9	1.2+9
20	1.2+9	7.6+8	1.0+9	1.0+9
21	6.8+8	4.6+8	5.3+8	5.3+8
22	1.9+8	1.3+8	1.4+8	1.4+8
23	4.8+7	2.2+7	2.9+7	2.9+7
B. <u>Gamma-ray</u>				
1	4.5+4	1.5+4	8.9+3	8.2+3
2	1.2+7	1.1+7	1.6+7	1.2+7
3	2.1+7	2.4+7	8.0+7	8.2+7
4	2.1+7	2.9+7	3.2+7	3.1+7
5	1.8+7	2.1+7	4.0+7	3.8+7
6	2.6+7	4.0+7	3.7+7	3.4+7
7	4.2+7	5.8+7	5.2+7	4.5+7
8	8.4+7	1.0+8	8.6+7	6.9+7
9	8.1+8	6.4+8	4.3+8	2.9+8
10	4.9+9	4.3+9	3.6+9	2.4+9
11	1.6+9	1.1+9	9.0+8	7.9+8

TABLE 6.3
COMPARISON OF FLUXES AND DOSE EQUIVALENT
0.5 m FROM REMOVABLE WALL

	<u>1-D</u>	<u>2-D (Toroidal)</u>	<u>2-D (Poloidal)</u>
Total Neutron Flux	1.9+10	7.5+9	1.3+10
Total Gamma-ray Flux	4.0+9	2.2+9	2.5+9
D.E. n (mr/pulse)	1.9+5	7.0+4	8.8+4
D.E. γ (mr/pulse)	6.1+2	3.5+2	3.8+2

Figure 6.1 (a) Neutron Flux Spectrum at TF Coil Outer Edge, between Coils

Figure 6.1 (b) Gamma-Ray Flux Spectrum at TF Coil
Outer Edge, between Coils

Figure 6.2 (a) Neutron Flux Spectrum at 8 m from Machine Center, Plasma Midplane

Figure 6.2 (b) Gamma-Ray Flux Spectrum at 8 m from
Machine Center, Plasma Midplane

Figure 6.3

Total Neutron Flux Distribution in the Test Cell, 2D Poloidal Model

a. 3×10^{10}	e. 4×10^9
b. 2×10^{10}	f. 3×10^9
c. 1×10^{10}	g. 2×10^9
d. 7×10^9	

Figure 6.4 Total Gamma-Ray Flux Distribution in the Test Cell, 2D Poloidal Model

Figure 6.5

Total Neutron Flux Distribution in the Test C-11, 2D Toroidal Model

Figure 6.6 Total Gamma-Ray Flux Distribution in the Test Cell, 2D Toroidal Model

6.1.3 Dose Responses and Distribution in the Test Cell

The biological dose map in units of mr/pulse is shown in Figure 6.7. The vertical variation of the dose equivalent along the test cell wall outer surface is presented in Figure 6.8. At the height that people would usually stand outside the test cell, the dose equivalent is 0.13 mr/pulse, or 1.3 rem/yr if a nominal 10,000 pulses per year schedule is assumed. As in the DT case, at heights greater than 7 meters the disappearance of the auxiliary wall gives rise to a rapid increase in the biological dose, the maximum being 1.0 mr/pulse or 10 rem/yr. Presumably, the shielding effect of the TF coils would give a factor of 2 reduction. Still, the design objectives of 1 rem/yr will not be satisfied along the entire test cell wall. Within the test cell, each pulse would deliver at least 10^4 mrem, too high to allow any access during machine operation.

The total physical dose map for carbon, silicon, tissue and SS-304 are given in Figure 6.9. The fractional contributions from gamma rays are indicated in the parenthesis on these plots. Notice that, while the absolute magnitudes of the gamma-ray dose are about the same ($D \propto Z/A$), for the materials shown, the neutron doses are not. For a given neutron energy, the light nucleus gets more recoil energy than the heavier ones, hence the higher neutron dose response. Also notice that the gamma-ray dose contribution is much less compared to the DT case. The yearly dose near the machine will be in the order of 10^5 - 10^6 rads.

6.2 Biological Dose at Site Boundary⁽²⁷⁾

The biological dose at several locations in the TFTR site ($R=125$ M) are given in Table 6.4. The graphic presentation is shown in Figure 6.10. The data were based on the Monte Carlo calculation. The leakage particle current from the test cell wall was derived from 2D toroidal analysis.

The gamma-rays play a more important role than the neutrons in contributing the dose equivalent, especially at large distances. The total yearly dose at the site boundary will be in the 47-64 mrem range with 99.7% of chance at 1 meter above the ground. The shielding provided by the TF coils would give roughly a factor of 2 reduction to the dose. Thus the site boundary dose would likely be in the 24 to 30 mr/yr range. This is 2 or 3 times higher than the permissible level (10 mr/yr, assuming that the radioactive gas contribution is negligible).

Without the igloo, the building wall alone will not provide adequate shielding insofar as meeting the design objectives is concerned.

Figure 6.7

Total Biological Dose Distribution in the Test Cell, 2D Toroidal Model

Figure 6.8

Biological Dose Distribution at the Outer Surface of the Test Cell Wall

Figure 6.9

The Physical Dose Distribution in the Test Cell, 2D Toroidal Model.

The Fractional Contributions due to Gamma-Rays Are Given in the Parentheses.

TABLE 6.4

BIOLOGICAL DOSE AT VARIOUS LOCATIONS GREATER THAN 75 mA. 1 m Above Grounda. Neutron Dose

R (m)	Side		Roof	Total (Roof & Side)
	Direct	Total		
75	3.57-3+0.18*	9.48-3+0.22	4.19-4+0.40	9.90-3+0.22
125	9.19-4+0.12	2.04-3+0.13	1.73-4+0.23	2.21-3+0.12
150	3.71-4+0.19	1.10-3+0.24	1.14-4+0.25	1.22-3+0.22
200	1.32-4+0.16	4.10-4+0.23	4.89-5+0.26	4.59-4+0.21
250	5.43-5+0.17	1.67-4+0.26	2.08-5+0.30	1.88-4+0.23

b. Gamma-Ray Dose

R (m)	Side		Roof	Total (Roof & Side)
	Direct	Total		
75	9.09-3+0.04	1.34-2+0.07	2.41-4+0.34	1.37-2+0.07
125	2.36-3+0.04	3.22-3+0.04	1.28-4+0.26	3.35-3+0.04
150	1.48-3+0.04	2.11-3+0.04	6.14-5+0.10	2.17-3+0.04
200	6.61-4+0.04	1.09-3+0.08	3.59-5+0.10	1.12-3+0.08
250	3.42-4+0.04	5.89-4+0.07	2.20-5+0.07	6.10-4+0.06

c. Combined (Neutron & Gamma)

R (m)	Side		Roof	Total (Roof & Side)
	Direct	Total		
75	1.27-2+0.06	2.29-2+0.09	6.60-4+0.26	2.36-2+0.09
125	3.28-3+0.03	5.26-3+0.05	3.01-4+0.20	5.56-3+0.05
150	1.85-3+0.05	3.21-3+0.09	1.75-4+0.16	3.38-3+0.08
200	7.93-4+0.04	1.50-3+0.10	8.48-5+0.16	1.58-3+0.10
250	3.96-4+0.04	7.56-4+0.08	4.28-5+0.16	8.00-4+0.08

B. 8 m Above Grounda. Combined Neutron & Gamma)

R (m)	Side		Roof	Total (Roof & Side)
	Direct	Total		
75	1.29-2+0.06	2.53-2+0.10	7.31-4+0.27	2.60-2+0.10
125	3.07-3+0.05	6.19-3+0.05	3.47-4+0.17	6.54-3+0.05
150	1.83-3+0.05	3.63-3+0.09	3.03-4+0.34	3.93-3+0.09
200	7.82-4+0.04	1.66-3+0.10	1.15-4+0.21	1.78-3+0.10
250	3.90-4+0.04	7.99-4+0.09	5.63-5+0.16	8.55-4+0.09

Figure 6.10 Biological Dose Rate as a Function of Distance from TFTR Center. The Vertical Bars Indicate the Standard Errors Associated with the Monte Carlo Calculation

GEOMETRICAL MODEL FOR PENETRATION STUDY

Figure 7.1

Schematic Representation of the Model for Igloo Wall Penetration Study

7.0 PENETRATIONS

Penetrations or streaming paths are inevitably present in most radiation shielding designs. There is no exception in the TFTR shielding environment. Many major penetrations are provided through the igloo shield for coolant paths, neutral particle heating injections and vacuum pumping lines. Further, diagnostic ports are designed for experiments in the igloo and diagnostic pipes are designed in the inner basement. The streaming radiation must be added on top of the reference radiation field in order to make the overall picture realistic.

In this chapter, we present some analysis of isolated individual penetrations during DT operation. The studies are still preliminary. It is hoped that the analysis here will provide some sort of general characteristic of the streaming pattern, and provide useful information for the current design phase.

7.1 General Penetration Characteristics Through the Igloo Shield⁽²⁸⁾

7.1.1 Description of Model and Source Term

A single straight through penetration usually has certain symmetry. Unfortunately this symmetry line usually does not correspond to the symmetry line of the machine. The generally available computation capability only allows for one symmetry. Consequently appropriate definition of the source term and the model are important in the streaming calculation. In the discussion of the general characteristic of penetrations, we chose to use the discrete ordinates method of solving the particle transport so that a broad spectrum covering a wide range of locations would be available. The line of symmetry is taken to be that of the penetration, and the geometry is so defined that the calculation would give true results near the streaming path. The general geometry used is shown in Figure 7.1.

Figure 7.2 Source Neutron Angular Distribution Used for Igloo Wall Penetration Study, μ Is the Cosine of the Angle with Respect to the Penetration Center Line

Notice that the test cell wall has been partially included, whereas the floor or roof have not. The reflection from the floor and roof may be accounted for by suitably chosen albedos. The TF coils have not been modelled. The symmetry is one problem, and in order to make the analysis comparable to the reference analysis, the omission of the TF coils seems desirable.

The source has been taken to be a 2 meter radius disk located at about 40 cm behind the vessel. For the source radius less than 75 cm, the density was calculated by:

$$S(r \leq 75 \text{ cm}) = \frac{S_t}{4\pi^2 R r_p}$$

where

S_t = total fusion neutrons 7×10^{18}

R = major radius

r_p = plasma minor radius

For a radius greater than 75 cm, some areas may not see the source neutrons whereas some of the areas can only see part of the source neutrons. Thus, a weighted source strength was computed to account for the geometrical effect. The consequence of this is that the source at a particular radius would be uniformly smeared.

The angular distribution of the source particle on the proposed source plane is not isotropic. Using ray tracing of the actual toroidal source, the angular distribution with respect to the line of symmetry was derived. The distribution is illustrated in Figure 7.2. It can be seen that the source distribution is somewhat like a cosine function.

The uncollided streaming source then was sampled directly from the source disk. The scattering component was calculated by the 2D discrete ordinates code DOT.

7.1.2 Adequacy of the Model and the Method

Two computations have been carried out with 6" diameter penetration hole in the igloo (r/l approximately 10%). The first one used a S_8 quadrature order in the discrete ordinate calculation. The second one used a highly biased 63 angle quadrature set. Since the essence of the discrete ordinates method is to follow a limited number of discrete directions of particle flow, use of low quadrature may not adequately describe the particle streaming behavior. Though the direct sampling of the uncollided flux distribution eliminates the so called ray-effect for the first collision flux, the ray-effect may still persist for multiple collision fluxes. The study using biased quadrature set would indicate the deficiency caused by the discrete nature of the method used. The 63 angular quadrature set was based on a S_8 half-symmetric set, but replacing the level toward the forward streaming direction by 12 new levels, each containing 3 directions. The 12 new levels were taken from the roots of the 64th order of Legendre polynomial.

The uncollided flux and the top group flux as a function of distance from the igloo outer surface (plasma midplane) is given in Figure 7.3. The fluxes at 1.5 m from the igloo and as a function of radial distance (the vertical distance in toroidal geometry) is given in Figure 7.4. The reference level has also been included for comparison.

Use of a biased quadrature set gave 30% higher 14 MeV flux at the plasma midplane than that of the S_8 calculation. In view of the simplicity of the model used and the computational time requirement, it seems that the S_8 quadrature would be adequate for the analysis here.

Away from the penetration, the fluxes computed by the streaming model converge to the reference level computed by completely different models. Thus, the source representation and modeling of the penetration are satisfactory.

Finally, at approximately 30 cm from the axis of the penetration and 2 m from the igloo, the total 14 MeV flux is about the sum of uncollided 14 MeV flux and the reference flux. The penetration introduced by the 6" hole, therefore, is limited to a narrow region for the high energy particles.

7.1.3 Penetration Characteristics with Different Hole Sizes

Using the model just described, 3 hole sizes were investigated, namely 3", 6" and 18" penetrations. The spatial flux maps for 14 MeV neutrons, neutrons with energy greater than 5 MeV, neutrons with energy between 5 MeV and 200 keV, neutrons with energy below 200 keV and total gamma-rays are presented in Figure 7.5, 7.6 and 7.7. The SI KERMA rates for neutrons and gamma rays are given in Figure 7.8.

The ratio of the neutron flux at the exit mouth to the total neutron flux at the entrance has been further plotted in Figure 7.9 as a function of penetration size. The ratio of the flux or dose at the exit mouth to that at the entrance is illustrated in Figure 7.10 as a function of r^2/l^2 where r is the radius of a penetration and l is the thickness of the igloo wall (26").

It may be observed that the streaming of high energy neutrons are very pronounced. The larger the penetration size, the more the streaming is high energy particles and the streaming spreads into a broader region. For example, for a 3" hole, only 8% of the neutron flux at the streaming center is greater than 5 MeV, but for an 18" hole, the corresponding fraction would be 50%.

The spatial distributions of the fluxes also show the importance of corner scattering and wall scattering. For small penetration or for 14 MeV virgin neutrons, the peak of the flux contour is along the penetration center line. However, for large penetrations and for low energy neutrons or gamma rays, the peaks in the contour shift away from the center line. If a full plot is made, the corner and wall scattering would give double peaks. Such wall scattering effect has also been observed in the center column streaming and the test cell analysis with TF coil present.

In Figure 7.25, the $(1 + r^2/l^2)$ curve has also been included. The difference between this curve to that of the 14 MeV virgin neutrons indicates the wall component (going through the wall without suffering a collision). As expected for a small hole, the wall component is more important. It may be interesting to note that for a small r/l ratio, the scattering factor of 10 used in Rockwell for fission neutrons⁽²⁹⁾ is also applicable for fusion neutrons provided that one is only concerned about the total fluxes. For large holes, the factor of 10 would be too conservative since the scattering component is not as important as the streaming component.

Figure 7.3

Comparison of 14 Me V Neutron Flux Streaming
Through a 6" Diameter Hole in the Igloo Wall
Using Biased and Un-biased Quadrature Sets,
Penetration Center Line

Figure 7.4 Comparison of 14 Me V Neutron Flux as a Function of Distance from the Plasma Midplane, 6" Diameter Hole in the Igloo Wall

Unit = n or $\delta/\text{cm}^2/\text{sec}$

Figure 7.5

Flux Distribution in the Test Cell for 3" Diameter Penetration in the Igloo Wall

Figure 7.6

Flux Distribution in the Test Cell for 6" Diameter Penetration
in the Igloo Wall

Figure 7.7 Flux Distribution in the Test Cell for 18" Diameter Penetration in the Igloo Wall

Figure 7.8 Si Dose Distribution in the Test Cell for 3", 6" and 18" Diameter Penetration in the Igloo Wall

Figure 7.9

Ratio of Neutron Flux at Exit Mouth to the Total Neutron Flux at Entrance Mouth as a Function of the Size of Penetration in the Igloo Wall. Igloo Wall Thickness (l) = 26".

Figure 7.10 Exit to Entrance Flux and Si Dose Ratio as a Function of r^2/l^2 , where r = Penetration Radius, l = Igloo Wall Thickness, $z=2$.

7.2 Penetration Through NBI Port

The neutral beam injector system analysis was performed by ORNL. The details of their calculations were published in the ANS journals. (30, 31) Only a brief summary of the analysis will be given here.

7.2.1 Model and Method of Analysis

Two dimensional calculations have been used for the biological dose rate estimate. Both two dimensional and three dimensional calculations have been used for the nuclear heating study. The geometries for the 2-D dose rate analyses are given in Figure 7.11. The geometries for 3D heating calculation are shown in Figure 7.12.

Two separate calculations were carried out for the dose rate estimation, one without injectors and one with a single injector. Without the injector, the model was similar to the toroidal test cell model used in Chapter 5 except that the geometry has been assumed to be reflective symmetry with respect to the plasma midplane and that a fictitious central yoke made of SS-316 with reduced density was present. The model with an injector present was symmetric with respect to the penetration center line. Only those portions of the structures that were radially greater than the igloo wall outer surface were included. The source for this case is a disk 2 m in radius placed 0.15m in front of the igloo wall. The distribution of the source leaking from the igloo was a synthesis of the distribution of the direct streaming 14 MeV neutrons, of the perturbed neutrons and the gamma rays near the injector port and of the unperturbed neutrons and gamma rays away from the port.

The streaming 14 MeV neutrons were sampled isotropically from a 0.7 m radius disk placed at the intersection of the plasma major axis and the axis of injection (tangential injection used). The igloo was regarded as a black absorber except the duct opening which was a void. The perturbed and unperturbed sources were sampled from the leakage spectra from the igloo wall. A reduced model which included only the igloo portion of the test cell model was used to generate these sources. The perturbed portion assumed that the duct opening was a toroidally continuous gap, whereas the unperturbed source assumed a solid igloo enclosure. The calculation was performed by the discrete ordinates technique with $P_3 S_8$ approximation. The cross section data were a (35 n, 21 γ) group set derived from DLC-41.

The model for the 2-D heating calculation was similar to the injector model for dose rate estimate except that the concrete shield for the injector was not included. In the 3D calculation, a detailed representation of the cryopanel, the bending magnet, the calorimeter and the injector guns were made. The source definition of these calculations was the same as that used for the injector dose rate analysis.

In all the calculations, a strong post compression source distribution with a minor radius of 0.4 m was used rather than a uniform 0.75 m radius source distribution. This represents the worst case for the 14 MeV neutrons streaming through the injector duct. Also SS-316 was used for the vessel wall which was incorrect.

Figure 7.11 Schematic Representations of the Two-Dimensional Models for NBI Neutronics Calculations

Figure 7.12 Schematic Representations of the Three-Dimensional Model for NBI Neutronics Calculations

7.2.2 Biological Dose Due to the Presence of the Injector

The biological dose rates as a function of distance along the test cell roof is shown in Figure 7.13. The "shielded injector" shows the contributions to the dose rates from radiation streaming through beam injector with concrete shielding about the injector.

The maximum additional dose equivalent contributed by the shielded injector is approximately 0.08 mr/pulse. Compared to the background level of approximately 0.4 mr/pulse. The streaming effect due to a single shielded injector is insignificant. However, the TFR is designed to operate with multiple injectors, all of them located on the same side of the reactor. Ignoring the interference among the injectors, the upper limit due to the streaming effect would be the background level plus the contributions from the streaming radiation of all the injectors. With four injectors operating, the maximum level on the roof is expected to be approximately 1 mr/pulse.

The dose rate on the side of the test cell as a function of distance above the injector center line is shown in Figure 7.14. The streaming effect is significant only within the 3 meter diameter disk centered at the injector axis on the test cell wall outer surface. The maximum incremental dose is approximately 0.05 mr/pulse. This is about 1/10 of the background dose expected at the injector axis. With multiple injector operation, the incremental dose is not multiplicative. that is that the total incremental dose is not the multiple of the dose from a single injector contribution. The shadow zone of streaming will not overlap on the test cell wall surface.

7.2.3 Nuclear Heating Rate for the Injector Components

The nuclear heating rate in units of watts/cc at a few selected locations are given in Table 7.1.

The detector locations are:

- (C) at the top of the injector structure
- (D) in the face of the bending magnet
- (G) at the mouth of the neutralizer tube.

In addition, the heating rates in the cryopanel are illustrated in Figure 7.15. Both the two dimensional and three dimensional results are given. Three entries are given for the 3D calculation corresponding to the heating rates for the streaming radiation, from the radiation leaking through the igloo wall, and the sum of these. The MORSE/DOT ratios indicate the range of agreement from the two calculations.

The maximum heating rate to any material will be on the order of 10^{-3} watts/cc. The total heat load to the cryopanel is expected to be approximately 35 watts. The heating problem is not significant. Assuming absolute adiabatic condition, the temperature increment will on the order of 2×10^{-4} °C for a single pulse. The calorimeter provides some shielding for the cryopanel between 70 cm to 130cm measured from the front end of the panel. The bending magnet provides some additional shielding for the cryopanel for distance greater than 2.7 meters.

The heating calculation did not include the concrete shield surrounding the injector. The back scattered radiation would make an additional contribution to the energy deposition. It has been estimated that the increase in heating due to the addition of concrete housing is insignificant.⁽³²⁾

Figure 7.13 Biological Dose Rate on the Test Cell Roof as a Function of Distance from the Center of the Roof

Figure 7.14 Biological Dose Rate Outside the Test Cell Wall as a Function of Distance from the Injector Center Line to the Roof

TABLE 7.1

NUCLEAR HEATING DATA FOR
THE NBI PENETRATION, 20 MW DT

A. Nuclear Heating Rates in the Injector Structure at
Detector Location C

Type 316 Stainless Steel			
Method of Calculation	Nuclear Heating Rates (W/cm^3)		
	Neutron	Gamma Ray	Total
Three-dimen- sional (MORSE)			
Injector port	2.12×10^{-4} (0.049)	6.20×10^{-4} (0.123)	8.32×10^{-4} (0.086)
Igloo wall	1.00×10^{-4} (0.483)	4.01×10^{-4} (0.393)	5.01×10^{-4} (0.339)
Total	3.12×10^{-4} (0.485)	1.02×10^{-3} (0.412)	1.33×10^{-3} (0.350)
Two- dimensional (DOT)			
	2.21×10^{-4}	1.02×10^{-3}	1.24×10^{-3}
MORSE/DOT ratios	0.07 - 2.1	0.6 - 1.4	0.7 - 1.4

5. Nuclear Heating Rates at the Front of the
Bending Magnet at Detector Location D

Method of Calculation	Nuclear Heating Rates (W/cm ³)		
	Neutron	Gamma Ray	Total
Three- Dimensional (MORSE)			
Injector port	8.28×10^{-4} (0.224)	7.13×10^{-4} (0.066)	1.54×10^{-3} (0.065)
Igloo wall	1.18×10^{-5} (0.254)	8.40×10^{-5} (0.597)	9.58×10^{-5} (0.480)
Total	8.39×10^{-4} (0.291)	7.47×10^{-4} (0.504)	1.64×10^{-3} (0.484)
Two- dimensional (DOT)	7.14×10^{-4}	8.62×10^{-4}	1.57×10^{-3}
MORSE/DOT ratios	0.83 - 1.51	0.46 - 1.40	0.54 - 1.55

C. Nuclear Heating Rates in the Injector Gun
at Detector Location G

Type 316 Stainless Steel			
Method of Calculation	Nuclear Heating Rates (W/cm ²)		
	Neutron	Gamma Ray	Total
Three-dimensional (MORSE)			
Injector port	4.05×10^{-4} (0.092)	5.42×10^{-5} (0.103)	4.49×10^{-4} (0.077)
Igloo wall	1.81×10^{-6} (0.149)	1.89×10^{-5} (0.197)	2.07×10^{-5} (0.180)
Total	4.07×10^{-4} (0.175)	7.31×10^{-5} (0.222)	6.66×10^{-4} (0.196)
Two-dimensional (DOT)	5.94×10^{-4}	3.10×10^{-4}	9.04×10^{-4}
MORSE/DOT ratios	0.57 - 0.81	0.18 - 0.29	0.60 - 0.74

Figure 7.15 (a) Nuclear Heating Rates as a Function of Distance in the NBI Cryopanel. Top: Zeolite, Bottom: Al

Figure 7.15 (b) Nuclear Heating Rates as a Function of Distance in the NBI Cryopanel. Top: SS-316, Bottom: Cu

7.3 Penetration Through TVPS Port⁽³³⁾

7.3.1 Description of the Calculational Model

The geometrical model used for the TVPS analysis is the same as that for the general penetration except that the penetration is shielded by 18" of limestone concrete. The pump line is $\frac{1}{2}$ " thick steel. A model used for the analysis is shown in Figure 7.16. Notice that in reality, at the end of the pumping line, there is a 90° bend. This feature has not been modeled in this analysis.

Again, a 2 meter radius source located 40 cm behind the vacuum vessel has been used. The source strength and the angular distribution have been generated by ray-tracing and adjusted geometrically.

7.3.2 Neutron and Gamma-Ray Fluxes Around the TVPS

The neutron and gamma-ray flux spectra at:

1. just outside the igloo and outside the pump shield
2. near the end of the pumping duct and at the center line of penetration, and
3. 0.5 m behind the back of the pump shield near the penetration center line are given in Table 7.2. The entries under the label TVPS are the data obtained in this analysis. The entries under the label "background" are the flux obtained previously using a toroidal geometry.

The spatial distributions of the 14 MeV neutron flux, total neutron flux, total gamma ray flux and the total biological dose rate are given in Figure 7.17, 7.18, 7.19 and 7.20.

Figure 7.16 Schematic Representation of the TVPS Model

TABLE 7.2

COMPARISON OF NEUTRON AND GAMMA RAY FLUXES
AT VARIOUS LOCATIONS AROUND TVPS, 20 MW DT
(A) JUST OUTSIDE THE IGLOO - 15cm FROM SIDE SHIELD

<u>Group</u>	<u>TVPS</u>	<u>Background</u>	
		<u>Plasma Mid-plane</u>	<u>1.5m from Mid-plane</u>
<u>a. Neutron</u>			
1	2.1 + 9	3.0 + 9	1.9 + 9
2	1.3 + 9	1.6 + 9	1.2 + 9
3	5.8 + 8	6.9 + 8	5.3 + 8
4	4.6 + 8	5.6 + 8	4.4 + 8
5	3.5 + 8	4.4 + 8	3.4 + 8
6	7.0 + 8	8.4 + 8	6.5 + 8
7	1.3 + 9	1.5 + 9	1.2 + 9
8	1.4 + 9	1.6 + 9	1.3 + 9
9	1.3 + 9	1.5 + 9	1.2 + 9
10	8.5 + 8	8.9 + 8	7.3 + 8
11	1.5 + 9	1.6 + 9	1.3 + 9
12	2.9 + 9	3.2 + 9	2.6 + 9
13	1.9 + 9	2.0 + 9	1.7 + 9
14	4.3 + 9	4.2 + 9	3.6 + 9
15	4.0 + 9	3.8 + 9	3.2 + 9
16	4.1 + 9	3.7 + 9	3.2 + 9
17	4.8 + 9	4.4 + 9	3.9 + 9
18	5.5 + 9	5.0 + 9	4.5 + 9
19	4.8 + 9	4.5 + 9	4.0 + 9
20	4.2 + 9	3.9 + 9	3.4 + 9
21	2.4 + 9	2.3 + 9	2.0 + 9
22	6.1 + 8	6.0 + 8	5.4 + 8
23	1.1 + 8	1.2 + 8	1.0 + 8
<u>b. Gamma-ray</u>			
1	9.8 + 5	1.2 + 6	1.0 + 6
2	2.6 + 8	3.9 + 8	3.0 + 8
3	7.2 + 8	9.8 + 8	8.1 + 8
4	2.2 + 9	2.9 + 9	2.6 + 9
5	9.4 + 8	1.3 + 9	1.1 + 9
6	1.9 + 9	2.6 + 9	2.1 + 9
7	3.4 + 9	4.4 + 9	3.6 + 9
8	3.1 + 9	4.1 + 9	3.4 + 9
9	5.9 + 9	7.3 + 9	6.1 + 9
10	2.4 + 10	2.3 + 10	2.0 + 10
11	6.2 + 9	7.0 + 9	6.3 + 9

TABLE 7.2
(B) END OF THE PUMPING LINE

<u>Group</u>	<u>TVPS</u>	<u>Background</u>
<u>a. Neutron</u>		
1	2.0 + 10	7.6 + 8
2	8.5 + 8	3.6 + 8
3	2.7 + 8	1.6 + 8
4	3.1 + 8	1.4 + 8
5	3.1 + 8	1.1 + 8
6	5.7 + 8	2.1 + 8
7	6.2 + 8	3.8 + 8
8	5.6 + 8	3.9 + 8
9	6.2 + 8	3.7 + 8
10	7.0 + 8	2.4 + 8
11	9.6 + 8	4.3 + 8
12	1.3 + 9	8.3 + 8
13	1.4 + 9	5.4 + 8
14	5.2 + 9	1.3 + 9
15	5.9 + 9	1.3 + 9
16	6.4 + 9	1.4 + 9
17	5.6 + 9	1.7 + 9
18	4.4 + 9	1.9 + 9
19	3.1 + 9	1.8 + 9
20	2.7 + 9	1.6 + 9
21	1.5 + 9	9.7 + 8
22	3.8 + 8	2.8 + 8
23	5.7 + 7	5.3 + 7
<u>b. Gamma-ray</u>		
1	9.4 + 4	4.0 + 5
2	1.7 + 8	9.8 + 7
3	2.8 + 8	2.7 + 8
4	5.0 + 8	7.8 + 8
5	3.7 + 8	3.5 + 8
6	6.5 + 8	6.8 + 8
7	1.3 + 9	1.1 + 9
8	1.8 + 9	1.1 + 9
9	4.7 + 9	1.9 + 9
10	1.5 + 10	7.2 + 9
11	4.0 + 8	3.6 + 9

TABLE 7.2

(C) 0.5m BEHIND THE BACK SHIELD

<u>Group</u>	<u>TVPS</u>	<u>Background</u>
<u>a. Neutron</u>		
1	1.4 + 8	5.6 + 8
2	3.9 + 7	2.8 + 8
3	1.3 + 7	1.3 + 8
4	1.0 + 7	1.1 + 8
5	8.0 + 6	8.7 + 7
6	1.6 + 7	1.6 + 8
7	2.7 + 7	2.9 + 8
8	2.6 + 7	3.1 + 8
9	2.3 + 7	3.0 + 8
10	1.6 + 7	2.0 + 8
11	2.8 + 7	3.5 + 8
12	4.9 + 7	6.7 + 8
13	3.1 + 7	4.5 + 8
14	6.9 + 7	1.1 + 9
15	6.4 + 7	1.1 + 9
16	6.8 + 7	1.2 + 9
17	8.1 + 7	1.5 + 9
18	9.1 + 7	1.7 + 9
19	8.0 + 7	1.6 + 9
20	6.8 + 7	1.4 + 9
21	4.0 + 7	8.7 + 8
22	1.0 + 7	2.5 + 8
23	2.1 + 6	5.0 + 7
<u>b. Gamma-ray</u>		
1	1.6 + 4	3.4 + 5
2	4.3 + 6	7.3 + 7
3	1.3 + 7	2.1 + 8
4	4.0 + 7	6.1 + 8
5	1.4 + 7	2.7 + 8
6	2.3 + 7	5.3 + 8
7	5.9 + 7	8.8 + 8
8	5.3 + 7	8.5 + 8
9	9.7 + 7	1.5 + 9
10	4.1 + 8	6.1 + 9
11	9.4 + 7	3.3 + 9

Figure 7.17 14 Me V Neutron Flux Distribution in the Vicinity of TVPS

Figure 7.18 Total Neutron Flux Distribution in the Vicinity of TVPS

Figure 7.19 Total Gamma Ray Flux Distribution in the Vicinity of TVPS

Figure 7.20 Total Biological Dose Distribution in the Vicinity of TVPS

It has been shown that the magnitude of the flux or any of its associated physical quantities varies vertically (with respect to the plasma midplane). With the line of symmetry along the axis of the pump line in the TVPS model, the characteristics of vertical variation is lost. The results here may be regarded as the average values.

A top view of a single pump is shown in Figure 7.21. The dash line configuration is the TVPS Model. In general, one may write the flux ϕ at a given point near the pumping system as:

$$\phi = \phi_p + \phi_u$$

where

ϕ_p = flux calculated by the TVPS model

ϕ_u = flux contribution from those particles unaccounted for by the TVPS model. Further, $\phi_u \sim f \phi_B$

where

ϕ_B = background flux

f = fraction of the background flux that would contribute to a detector.

Within the shield box, or outside the shield box but near the igloo. (Table 7.2), $f \ll 1$, so that the fluxes obtained here represent the "true" values. This is evidenced in Table 7.2 that the fluxes from the TVPS and toroidal models agree well. On the other hand, outside the shield box but away from the igloo, $f \leq 1$, $\phi_B \gg \phi_p$ so that $\phi \sim \phi_B + \phi_p$ except for the 14 MeV neutrons for which $\phi \sim \phi_p$. Thus the fluxes calculated in this situation may be regarded as "incremental".

Behind the shield box, the biological dose increment is 10%. The back shield thickness is adequate. On the other hand, judging from the dose map, reducing the side shield from 1.5' to 1' will increase the increment dose by about a factor of 3; which is then about 10-15% of that of the background. This thickness seems to be acceptable.

CONTRIBUTIONS TO THE DETECTOR RESPONSE

Figure 7.21

Schematic Drawing Showing the Relative Importance of the Streaming Flux to the Total Flux. At A $\phi_p < \phi < \phi_u$ At B $\phi < \phi_p + \phi_u \approx \phi_u$ At C $\phi \approx \phi_p$ where ϕ_p and ϕ_u are Perturbed and Unperturbed Flux Respectively

7.4 Penetration Characteristics Through 6' Machine Substructure⁽³⁴⁾

7.4.1 Penetration Models

The penetrations through the 6' of substructure concrete and into basement area are small ones, usually several of them cluster together. These small tubes are used for plasma diagnostics. The arrangement of the streaming paths compels one to use three dimensional calculations in order to model the configuration properly. One typical case is that of 12 colinear tubes placed in between the coils. The analysis of this arrangement will be presented in this section.

A two dimensional poloidal model calculation similar to the one used in the test cell analysis was first carried out to generate the surface source just outside the TF coils. Particles were then sampled from this surface and the collision histories were followed through the substructure by the Monte Carlo Technique. The geometries and the spatial axis orientation are illustrated in Figure 7.22. Notice that the radius to length ratio for a single penetration is only 1.7% and the smallest space between penetrations is only approximately 7 cm.

The surface source was generated by a 2D discrete-ordinates calculation ($P_3 S_8$). The effect of the tubes has been ignored in this calculation. When the Monte Carlo game was played, the source particle angular distribution was sampled uniformly in each of the solid angle subtended by the discrete rays in the discrete-ordinates calculation. Some physically impossible situation may arise from this sampling scheme. Figure 7.23 clearly shows the reason.

Figure 7.22 (a) Schematic Representation of the Model for Diagnostic Penetration Study, Perspective View

X-Y PLANE

Figure 7.22 (b) Schematic Representation of the Model for Diagnostic Penetration Study, x - y Plane

Figure 7.23 Schematic Drawing Showing the Problem of Coupling Sn and Monte Carlo Calculation

This situation has been observed for the 14 MeV streaming fluxes in the end holes. No remedy has been attempted in the present study.

7.4.2 Streaming Pattern for 12 Co-Linear Diagnostic Tubes in the Substructure

The particle fluxes leaving the source surface and reaching the detector without suffering a single collision (labeled as uncollided) at 0.5 m below the base shield and at the hole center line are plotted in Figure 7.24.a, 7.24.b and 7.24.c. On the same graphs, the data for 0.5 m above basement floor have also been illustrated. Further, a few collided fluxes and two background fluxes are presented for comparison. The background flux labeled as "background 1" is the flux level when all the streaming paths are blocked by the concrete including the center column region, the one labeled "background 2" is that expected when the center column left unshielded.

It can be observed that there is little interference among the streamings for the fluxes at 0.5 m below the base shield. There are "constructive" interferences for the fluxes at 0.5 m above the floor. In general, for this penetration problem about 40% of the neutron fluxes are the 14 MeV component, whereas for the background case, the 14 MeV fluxes are less than 1% of the total. On the other hand for the penetration problem, 15% of the fluxes are below 3 keV. The fraction is 50% for the background fluxes if the center column is shielded and the corresponding fraction is 30% if the center column is not shielded. Thus the diagnostic penetration effect is exclusively on the high energy particles.

Figure 7.24 (a) The Streaming Pattern of the Flux through 12-Co-Linear Diagnostic Tubes in the Substructure, 14 Me V Neutrons, x-y Plane, z=0. The Shaded Area Indicates the Standard Error Associated with the Monte Carlo Calculation

Figure 7.24

(b)

The Streaming Pattern of the Flux Through 12 Co-Linear Diagnostic Tubes in the Substructure, Total Neutrons, x-y Plane, z=0.

A Indicates the Data at 0.5 m below Substructure; B Indicates the Data at 0.5 m above the Basement Floor.

Figure 7.24 (c) The Streaming Pattern of the Flux through 12 Co-Linear Diagnostic Tubes in the Substructure, Total Gamma Rays, x-y Plane, $z=0$.

The flux profile, as a function of distance from the penetration center line, is given in Figure 7.25 at 0.50 m above the floor. It is seen that beyond 0.4 meters, the fluxes are negligible in comparison with the background fluxes. Based on the available data, one could draw a "penetration-affected" zone. This area, if projected on the basement floor, is a rectangle with an approximate dimension of 2.6m x 1.0 m. (Figure 7.26) Thus even though the streaming neutron fluxes, especially the 14 MeV neutrons are several order of magnitudes higher than the background, the effect nevertheless is only confined in a limited region.

Figure 7.25

The Streaming Flux as a Function of Distance from the Center Line of the Diagnostic Tube Penetrations, y - z Plane, $x=0$.

-150-

Figure 7.26

Schematic Representation of the Perturbation Area on the Basement Floor due to the 12 Co-Linear Diagnostic Penetrations in the Substructure.

8.0 ANALYSIS OF INDUCED ACTIVITY

8.1 General Activation Characteristics

8.1.1 Induced Activity for Pulsed TFTR Operation

The passage of neutrons through materials transforms some *stable nuclides into unstable ones foreign to the original atomic society*. The transmutation not only introduces impurities in the original material but the radioactive nuclides will emit radiation after operation is terminated. The decay of the radioactive nucleus generally involves β -ray emission or internal conversion accompanied by gamma ray or x-ray emission. The β rays are short ranged, its damage to the human body external to the radioactive material will be small in comparison to the damage posed by the gamma-rays. Consequently when the activation "dose" is calculated, the β component will generally be ignored.

The induced activity is particularly important in the DT operation in the test cell area because the bulk of the neutrons will be energetic enough to induce threshold reactions, such as (n,p) (n, α) (n,2n), all are potential sources of activation radioactivity. In contrast, in fission or DD fusion reaction environment the thermal capture is generally the important source of induced radioactivity.

The induced activity is controllable, it may be reduced either by careful selection of materials or by clever shaping of the spectrum. The choice of low trace element concrete for the igloo shield is a typical example of the first in the TFTR design. In some cases, one may also reduce the activity density by changing the "effective" half-life.

At a given time, the concentration of a radioactive nuclide depends on the rate of its being produced and the rate of its being removed. For a pulsed machine, the behavior of the induced activity is a function of pulsing scheme, i.e. the pulse length, time between pulses and the number of pulses. With a long decay chain, the solution is quite complicated. Fortunately, only the first two generations in the decay sequence are important in the study here. In fact, most activities are from the 1st generation. It can be shown⁽³⁵⁾, for two generation decay, the activity density of a single isotope A_i , is

$$A_i = R_i \tau_i \omega_i + \beta R_{i-1} \tau_{i-1} \omega_{i-1} \frac{\lambda_{i-1}}{\lambda_{i-1} - \lambda_i} - \tau_{i-1} \omega_{i-1} \frac{\lambda_i}{\lambda_{i-1} - \lambda_i}$$

where

$i = 1$ or 2 , decay sequence

R_i = production rate

$$= \int N \sigma \phi \, dE$$

N = parent density

σ = reaction cross section

ϕ = neutron flux

λ = decay constant

τ = irradiation history time function

ω_i = cooling time function = $e^{-\lambda t}$

β = fraction of 1st generation that decays into second generation

For a regular pulsing sequence

$$i = (1 - e^{-\lambda_i t_p}) \frac{1 - e^{-\lambda_{i-1} t_c}}{1 - e^{-\lambda_i t_c}} \frac{1 - e^{-\lambda_i m t_g}}{1 - e^{-\lambda_i t_g}}$$

where

t_p = pulse length

t_c = cycle length

t_g = group period

n = no. of pulses in a group

m = no. of groups

A plot of the irradiation history function $\tau(n/m)$ as a function of $t_{1/2}$, the half-life, is presented in Figure 8.1 (4 pages). The plots assumed that:

$t_p = 0.5$ sec.

$t_c = 300$ sec.

$t_g = 1$ d where applicable.

Various combinations of n/m , i.e. the number of pulses and the number of groups, of interest, are given. For half lives greater than t_g :

$$\tau = t_p \cdot m \cdot n$$

so that only the product of nm governs the behavior regardless of whether the pulsing scheme is nm pulses in one group or n pulse in m groups or m pulses in n group. For $t_{1/2} \ll t_g$, $\tau = (1 - e^{-\lambda t_p})$ so that pulsing scheme has no impact. For $t_{1/2} \ll t_p \ll t_g$, $\tau = n(1 - e^{-\lambda t_p})$, so that a single group features the behavior of n . Notice that in all these cases, the only pulse parameter entered into play is the pulse length.

In addition to the natural decay, some of the radioactive nuclides may be removed by the neutron induced reaction. The effective decay constant is

$$\lambda_{eff} = \lambda_{nat} + f \cdot \sigma_a \phi$$

σ_a = absorption cross section.

In general, for $t_{1/2} \ll 10^4$ years, $f \sigma_a \phi$ is much less than λ_{nat} , so that $\lambda_{eff} \approx \lambda_{nat}$.

8.1.2 Characteristics of Induced Activity in the TFTR

The specific activities as a function of cooling time are given in Figure 8.2 and 8.3 for Al, Cr, Mn, Fe, Ni and Cu, located at the vessel and 1 m from the igloo. The data are those after 100 consecutive DT pulses. The corresponding data at the vessel for DD operation are given in Figure 8.4.

The curves illustrate the general production and decay characteristics of the induced activity for commonly used materials in the TFTR environment.

Even though many reactions have been considered, only a limited amount of nuclides could dominate the decay activity at a given time, as evidenced from the figures. In general, short lived isotopes quickly decay away, a transition then occurs a few hours after operation, the long lived isotopes then take control after about a week of cooling. The dominant isotopes at various stages of the decay process are shown in Table 8.1.

The dominant isotopes for a given material at a given time, though not greatly different for the different spectrum in the DT case, the mode of their production may be quite different. The ^{51}Cr isotope, for example is the major contributor to the activity for Cr material, 90% of the concentration is for the $^{52}\text{Cr}(n,2n)^{51}\text{Cr}$ reaction near the vessel while outside the igloo, nearly all the concentration of this isotope is due to the $^{50}\text{Cr}(n,\gamma)^{51}\text{Cr}$ reaction. Similarly, outside the igloo, 80% of the shutdown activity in Cu is ^{64}Cu from $^{63}\text{Cu}(n\gamma)^{64}\text{Cu}$ reaction whereas the ^{64}Cu from the $^{65}\text{Cu}(n,2n)^{64}\text{Cu}$ reaction contributes the shutdown activity near the vessel.

The ^{60}Co inventory due to the Ni and Cu material would be very high. It was estimated that the ^{60}Co inventory in the vessel alone would amount to something like 120 mCi after 4000 pulses of DT operation. There has been concern about using a small amount of cobalt in the scattered structure material. Comparing the large quantity of Ni and Cu used, the increase of ^{60}Co inventory from the use of Co would be insignificant.

Figure 8.1

Irradiation History Time Function for Induced Activity. The Curves are Given in Terms of m/n , where m = No. of Pulses in a Group of Discharges, n = No. of Groups, Pulse Length = 0.5 sec., Cycle Length = 5 min., Group Length = 1 day.

Figure 8.2

The Specific Activity as a Function of Cooling Time for Al, Cr, Mn, Fe, Ni and Cu After 100 DT Pulses at Vacuum Vessel Location.

Figure 8.3

The Specific Activity as a Function of Cooling Time for Al, Cr, Mn, Fe, Ni and Cu after 100 DT Pulses at 1 m from the Igloo Wall, Plasma Midplane

Figure 8.4

The Specific Activity as a Function of Cooling Time for Al, Cr, Mn, Fe, Ni and Cu After 100 DD Pulses (with 2% DT) at Vacuum Vessel Location

TABLE 3.1

DOMINANT RADIOACTIVE NUCLIDES AT VARIOUS COOLING TIME FOR Al, Cr, Mn, Fe, Ni and Cu.

Cooling Time/ Element	$t < 1$ hr	$1\text{hr} < t < 1\text{d}$	$1\text{d} < t < 1\text{wk}$	$t > 2\text{wks}$ and long range
Al	Mg - 27 Na - 24	Na - 24	Na - 24	-----
Cr	V - 52 Cr - 51	Cr - 51	Cr - 51	Cr - 51 V - 49
Mn	Cr - 55 (fast spectrum) Mn - 56	Mn - 54 Mn - 56	Mn - 54	Mn - 54
Fe	Mn - 57 Mn - 56	Mn - 56	Fe - 55, Cr - 51 Fe - 59 (thermal)	Fe - 55 Mn - 54
Ni	Co - 64 Ni - 57	Ni - 57 Co - 58	Co - 58	Co - 58 Co - 60
Cu	Cu - 62 Cu - 64 (thermal)	Cu - 64	Cu - 64	Cu - 60

It should be mentioned here that the specific activity is the disintegration per gram of material, regardless of the type of disintegration and of the disintegration energy. Thus one cannot translate the specific activity into biological dose without taking those factors into account.

8.2 Biological Dose Rate from Neutron Activated Objects⁽³⁶⁾

8.2.1 Activation Dose Rates from Isolated Objects in the Test Cell

The contact dose rates from the vacuum vessel are given in Figure 8.5 and 8.6 for DT and DD operation respectively. The data were based on the 1D neutron transport calculation, and the vessel has been assumed to be an infinite slab.

The biological dose rates from neutron activated objects after DT pulsing have been computed for Al, SS-305 and Cu at various locations in the test cell area. The objects are isolated materials, either as an infinite slab or as a sphere. The radiation field has been assumed unperturbed by the presence of these objects. Analytic integration (Code DRAPKI) has been used to derive the decay dose rate, the formula and attenuation data used are taken from the "Photon Shielding Manual".⁽³⁷⁾ Further, the reactions resulting in a very long half life or a very short half life ($t_{1/2} < 10$ m or > 50 yrs) were omitted. The data are computed as a function of m/n where m is the number of pulses in a group and n is the number of groups. Each pulse is $\frac{1}{2}$ seconds long, the pulse repetition time is 5 minutes, and 10 groups of discharges are evenly spaced in a year.

The contact dose rates from activated SS-305, Al and Cu slabs at a representative location in the igloo (4.2m from the machine center, 0.9m above the plasma midplane) are given in Figure 8.7, 8.8 and 8.9. Similar data for 10" radius spheres are given in Figure 8.10, 8.11 and 8.12. Only the results for DT operation are given.

Figure 8.5 Contact Dose Rate as a Function of Cooling Time for Vacuum Vessel After DT Pulsing. The Data Are Given as a Function of m/n . Where m Is the Number of Pulses in One Group and n Is the Number of Groups. For details, see the text.

Figure 8.6

Contact Dose Rate as a Function of Cooling Time for Vacuum Vessel after DD Pulsing.

Figure 8.7

Contact Dose Rate as a Function of Cooling Time
for 0.5" SS-305 Slab Located at 4.2 m from Machine
Center and 0.9 m above Plasma Midplane after 20
MW DT Pulsing

Figure 8.8 Contact Dose Rate as a Function of Cooling Time for 0.5" Al Slab Located at 4.2 m from Machine Center and 0.9 m above Plasma Midplane after 20 MW DT Pulsing

Figure 8.9 Contact Dose Rate as a Function of Cooling Time for 0.5" Cu Slab Located at 4.2 m from Machine Center and 0.9 m above Plasma Midplane after 20 MW DT Pulsing

Figure 8.10

Contact Dose Rate as a Function of Cooling Time for 10" Radius SS-305 Sphere Located at 4.2 m from Machine Center and 0.9 m above Plasma Midplane after 20 MW DT Pulsing

Figure 8.11 Contact Dose Rate as a Function of Cooling Time for 10" Radius Al Sphere Located at 4.2 m from Machine Center and 0.9 m above Plasma Midplane after 20 MW DT Pulsing

Figure 8.12

Contact Dose Rate as a Function of Cooling Time
for 10" Radius Cu Sphere Located at 4.2 m from
Machine Center and 0.9 m above Plasma Midplane
after 20 MW DT Pulsing

The contact dose rates from activated SS-305, and Al objects at 1m from the igloo outer surface and at the plasma midplane are given in Figure 8.13, 8.14, 8.15 and 8.16 after DT pulsing. Again the data for $\frac{1}{2}$ " slabs and 10" spheres are illustrated. The normalized contact dose rates from activated objects at various locations in the test cell are given in Table 8.2. The dose rates from an object located at the representative location have been taken as the normalization reference. For different pulsing schemes, objects with different sizes and at different cooling times, the relative dose rates will be different slightly. Calculations showed however, that the ratios agree within 15%. The data shown in Table 8.2 were based on the calculation for a 10" radius sphere with the operational scenario of one group of 100 pulses with 1 day of cooling. Using Table 8.2 and Figures 8.13-8.16, the contact dose rates may be estimated for any location in the test cell.

8.2.2 Activation Dose Rates from Isolated Objects in the Basement Area

The contact dose rates from activated 10" radius spheres of SS-305, Al and Cu located at the machine center and 0.5m above the basement floor are illustrated in Figure 8.17, 8.18 and 8.19. Only DT pulse has been considered. The calculation was based on the 2D inner basement model, consequently the center column is a void region.

The contact dose rates at some other locations in the inner basement relative to those for the objects at the representative location are shown in Table 8.3. Combining the table and the figures, the contact dose rates from an activated object located anywhere in the inner basement area may be estimated.

Figure 8.13 Contact Dose Rate as a Function of Cooling Time for 0.5" SS-305 Slab Located at 1 m from Igloo Wall and Plasma Midplane after 20 MW DT Pulsing

Figure 8.14 Contact Dose Rate as a Function of Cooling Time for 0.5" Al Slab Located at 1 m from Igloo Wall and Plasma Midplane after 20 MW DT Pulsing

Figure 8.15 Contact Dose Rate as a Function of Cooling Time for 10" Radius SS-305 Sphere Located at 1 m from Igloo Wall and Plasma Midplane after 20 MW DT Pulsing

Figure 8.16 Contact Dose Rate as a Function of Cooling Time for 10" Radius Al Sphere Located at 1 m from Igloo Wall and Plasma Midplane after 20 MW I/T Pulsing

TABLE 8.2
RELATIVE CONTACT DOSE RATES FROM
ACTIVATED OBJECTS LOCATED IN THE TEST CELL, 20 MW DT

<u>LOCATION</u>	<u>SS-305</u>	<u>A1</u>
1. Plasma midplane 1m from igloo surface	1.0	1.0
2. Plasma midplane 0.3m from removable wall	0.17	0.13
3. 5m above plasma midplane 1m from igloo surface	0.18	0.12
4. 5m above plasma midplane 0.5m from removable wall	0.12	0.08
5. 3m below plasma midplane 1m from igloo surface	0.31	0.25
6. 3m below plasma midplane 0.5m from removable wall	0.18	0.15
7. 5m above plasma midplane machine center	1.14	1.11
8. 5m above plasma midplane 2.65m from machine center line	1.04	1.02

Figure 8.17

Contact Dose Rate as a Function of Cooling Time
for 10" Radius SS-305 Sphere Located at Machine
Center and 0.5 m above Basement Floor

Figure 8.18 Contact Dose Rate as a Function of Cooling Time for 10" Radius Al Sphere Located at Machine Center and 0.5 m above Basement Floor

Figure 8.19

Contact Dose Rate as a Function of Cooling Time
for 10" Radius Cu Sphere Located at Machine
Center and 0.5 m above Basement Floor

Figure 8.20 Contact Dose Rate as a Function of Cooling Time for 10" Radius SS-305 Sphere Located at Outer Basement Center after DT Pulsing

TABLE 8.3

RELATIVE CONTACT DOSE RATES FROM

ACTIVATED OBJECTS LOCATED IN THE INNER BASEMENT, 20 MW DT

<u>LOCATION</u>	<u>SS-305</u>	<u>Al</u>	<u>Cu</u>
1. Machine Center 0.5m above floor	1.0	1.0	1.0
2. 2.65 from machine center 0.5m above floor	0.57	0.22	0.53
3. 5.9m from machine center 0.5m above floor	0.50	0.07	0.44
4. Machine center 0.5m below base shield	5.10	48.4	8.03
5. 2.65m from machine center 0.5m below base shield	0.39	0.09	0.37
6. 5.9m from machine center 0.5m below base shield	0.39	0.03	0.35

The dose rates from activated SS-305 located at the outer basement center are given in Figure 8.20. Only the data for the 10" radius sphere and for DT pulsing are illustrated here.

The relative contact dose rates at some locations in the outer basement area to those at the center are given in Table 8.4. Again use of the table and figure allows one to estimate the dose rate from SS-305 objects anywhere in the outer basement area.

8.2.3 The Effect of Object Size, Distance and Material Composition on the Dose Rate

The relative contact dose rate as a function of the size (thickness or radius) of an activated SS-305 object is shown in Figure 8.21. The data for Al and Cu objects are given in Figure 8.22 and 8.23 respectively. Both the contact dose rates from a slab object and a spherical object have been normalized to the contact dose rate from a 10" radius spherical object. The dose rates depend slightly (10%) on the pulsing scheme, the location of the object and the cooling time. The data presented here are based on the dose rate at the representative location in the test cell with 1 day of cooling after a group of 100 consecutive pulses.

The relative dose rate as a function of distance from activated SS-305, Cu and Al spherical objects are illustrated in Figure 8.24 and 8.25. The relation again depends slightly on the location, pulsing scheme and cooling time.

Using the figures in this section along with the tables and figures in the previous sections, the dose rate at any given distance from an activated object of any size, located anywhere, at any cooling time, after any number of pulses may be estimated.

Figure 8.21 Relative Contact Dose Rate as a Function of Object Size for SS-305. The Normalization Reference Is 10" Sphere, 1 m from Igloo, 100 DT Pulses, 1 Day of Cooling

TABLE 8.4
RELATIVE CONTACT DOSE :
ACTIVATED OBJECTS LOCATED IN THE OU

<u>LOCATION</u>	<u>SS-305</u>
1. 6m from dividing wall 3m above floor	1.0
2. 0.1m from dividing wall 0.5m above floor	1.70
3. 0.1m from dividing wall 6.3m above floor	1.72
4. 10.8m from dividing wall 0.5m above floor	0.77

Figure 8.22 Relative Contact Dose Rate as a Function of Object Size for Al. The Normalization Reference is 10" Sphere, 1 m from Igloo, 100 DT Pulses, 1 Day of Cooling

Figure 8.23 Relative Contact Dose Rate as a Function of Object Size for Cu. The Normalization Reference Is 10" Sphere, 1 m from Igloo, 100 DT Pulses, 1 Day of Cooling

Figure 8.24

Relative Dose Rate as a Function of Distance (Radius) from the Surface of a SS-305 or Cu Sphere. The Normalization Reference Is the Same as That for Figure 8.21.

Figure 8.25

Relative Dose Rate as a Function of Distance (Radius) from the Surface of an Al Sphere. The Normalization Reference Is the Same as That for Figure 8.21

Figure 8.26 Decay Biological Dose Distribution in the Test Cell after 100 DT Discharges and 1 Hour of Cooling, 2 D Toroidal Model

In the calculation of the dose rate for steel objects, we have assumed the steel being SS-305. Knowing the dominant nuclides at a given cooling time, however, the dose rate from other kinds of steel may be estimated from the SS-305 data by comparing the relative parent nuclide densities. Following is an arbitrarily chosen example (SS-305 vs nitronic 33):

a. relative densities (N (nitronic-33)/N(SS-305))

Ni 0.263

Fe 0.423

Mn 6.275

b. comparison of predicted and calculated dose rates.

Cooling Time/ Material	SS-305	Nitronic - 33	
		Predicted	Calculated
0.0	3.04+5	3.0+5	3.2+5
1 hr	2.33+5	2.3+5	2.4+5
1 dy	1.60+3	9.3+2	9.7+2
1 wk	4.15+2	2.4+2	2.6+2
2 wks	3.50+2	2.2+2	2.4+2
½ yr	9.22+1	1.0+2	1.2+2

8.2.4 Characteristics of the Activation Dose Rate from SS-305, Al and Cu Objects

The characteristics of the activation dose rate follows closely that of the specific activity. For a steel object the shutdown dose rate is mainly attributable to ⁵⁶Mn, which decays rapidly. In the intermediate time span ⁵⁸Co and ⁵⁷Ni are the major contributors with growing importance of the ⁵⁸Co contribution as time goes on. After a year, ⁵⁴Mn would come into play and eventually ⁶⁰Co is the only dominant isotope.

Since the ^{58}Co which is the result of the $^{58}\text{Ni} (n,p) ^{58}\text{Co}$ reaction is the most important isotope that contributes to the dose during the time of expected access and since there are many steel objects around TFTR, the accuracy of predicting the ^{58}Co concentration is very important. The ^{58}Co could be the direct product of the $^{58}\text{Ni} (n,p)$ reaction, and it could also be the decay daughter of ^{58m}Co , which has a 9 hour half-life. ^{58m}Co is produced also by the $^{58}\text{Ni} (n,p)$ reaction. Discrepancies in the cross sections leading to these two different states exist in the available library. The calculation here assumed that all the reactions lead to ^{58}Co rather to distinguish ^{58m}Co and ^{58}Co .

For Al, the only important contributor to the dose is the ^{24}Na . Because the ^{24}Na half-life is only 15 hours, Al is the best material to use if the hands-on maintenance is expected after a few days of waiting.

The ^{60}Co in the Cu object deserves some attention. ^{60}Co is a strong gamma emitter and the extremely long half life keeps the dose from ^{60}Co nearly a constant within a sensible amount of time for maintenance. After a week of waiting, ^{60}Co is the only contributor to the activation dose from a Cu object.

8.3 Reference Radiation Field in the Test Cell⁽³⁸⁾

8.3.1 Method of Calculating Background Radiation Field

In addition to the local activated materials, the test cell walls and floor would be activated also. The doses coming from these sources depend to a significantly less degree on the geometrical factor. Further the radiation would come from all directions, so that it would be hard to shield against. Knowing this background dose level, thus, is essential from a maintenance point of view.

The models used for prompt radiation calculations have also been used to establish the background decay gamma dose level. The prompt neutron fluxes, combined with the reaction cross sections, were used to generate a source distribution. Discrete-ordinates method then again was used to calculate the decay gamma flux level. A 16 group structure was used which takes great care of the energies which were below 2 MeV.

8.3.2 Decay Dose Level in the Test Cell

The decay dose level 1 hour after 100 consecutive 0.5 second DT pulses in the test cell has been calculated for the toroidal test cell model and poloidal TF coil model. Note that only the vessel activation has been considered in addition to the concrete activation in the toroidal model calculation. The dose maps are illustrated in Figure 8.26 and 8.27.

At 1 hour after shutdown, the dose level within the test cell would be something like 100 mr/hr. Maintenance at this time should proceed with great precaution. Including the TF coils does not significantly reduce the dose level because the coil, while providing shielding for the dose from the vessel, gets activated themselves. Since the isotope which contributes to the dose in the concrete is mainly ^{24}Na , even after 1 day 1/3 of the dose would remain. The dose rate is about 30 mr/hr near the igloo wall after 100 consecutive full power DT discharges and with 1 day of cooling. The dose rate with 1 week of cooling is about 0.5 mr/hr.

The above discussion was based on 100 consecutive DT pulses. The worst case that could happen during DT operation is that 1,000 discharges are made in one group. It is estimated that the activation dose level within the test cell under this extreme condition will be a factor of 2 higher than that of the 100-pulse operation after 1 hour of cooling. The factors after 1 day and 1 week of cooling are 4 and 10 respectively. Scheduling for post-operational service may be commenced after a week of waiting without excessive requirement of portable shields.

Lacking the igloo shield during DD operation, the vacuum vessel and the TF coils will be the major sources contributing to the activation dose. It has been estimated that the dose rate near the machine will be on the order of 200 mr/hr 1 hour after 100 DD discharges. The dose rate drops down to 10 mr/hr after 1 day. For 1,000 and 10,000 discharges, the dose rates after 1 day of waiting will be greatly increased even though the dose rates after 1 hour of waiting are not much higher compared to the 100 discharge case due to the saturation of short half-life isotopes. The dose rate is something like 30 mr/hr after 1,000 DD discharges near the machine. This will be increased to 50 mr/hr if 10,000 discharges are made. Because the main sources of activation are the steel objects, the dose rate will decay slowly after 1 day. Thus, maintenance work cannot be done without portable shield protection or remote handling mechanisms after more than 100 consecutive DD discharges.

RADIUS (m)		
a. 7×10^5	e. 8×10^4	i. 1×10^2
b. 5×10^5	f. 5×10^4	j. 5×10^1
c. 2×10^5	g. 1×10^4	k. 4×10^2
d. 1×10^5	h. 1×10^3	l. 3×10^1

Figure 8.27

Decay Biological Dose Distribution in the Test
Cell after 100 D⁺ Discharges and 1 Hour of
Cooling, 2 D Poloidal Model

Figure 8.28 Schematic Representation of the Locations where the Induced Gamma Ray Dose were Presented in Table 8.5

The "real" dose level would depend on the local environment. The dose from other objects should be summed up on top of the reference level. Further, any streaming must also be considered.

8.4 Induced Activity from NBI

The calculation of the induced activity was carried out by first computing the decay gamma source distribution using the prompt flux obtained in the streaming calculation. The transport of the photons then was calculated by the Monte Carlo technique. The same geometries were used in both the prompt and the delayed gamma transport calculation. Essentially all nuclei with a lifetime between 10 minutes and 50 years were considered. The details of the analysis was published in the ANS journal.⁽³⁹⁾

Three different operational scenarios were studied, i.e. 100 discharges repeated every 5 minutes, 100 discharges as above each day for 10 consecutive days, and 100 discharges repeated every 40 days. For each scenario, three cooling times, i.e. 1 hour, 1 day and 1 week were analyzed. The data are presented in Table 8.5. The reference locations are indicated on Figure 8.28. The entries labeled without injector were the activation due to the test cell alone, the dose rates are comparable to the study presented in section 8.3. The entries labeled "injector contribution" were the activation dose rates from the injector components.

Figure 8.29 Activity Density of Airborne Radioactive Nuclides as a Function of Cooling Time, No Ventilation Assumed

TABLE 8.5
ACTIVATION DOSE RATES FROM NBI,
20 MW DT, Unit = Mr/mr,
Pulse Length = 0.5 Sec.
Time Between Pulses = 5 min.

A. 100 Pulses in 1 Day

Position	1 h After Last Pulse		1 day After Last Pulse		1 Week after Last Pulse	
	Test Cell Without Injector	Injector Contribution	Test Cell Without Injector	Injector Contribution	Test Cell Without Injector	Injector Contribution
*	**					
A	1.5+2 + .11	7.8-3 + .19	2.9+1 + .14	2.6-3 + .20	2.1-1 + .10	5.7-6 + .20
B	5.2+1 + .10	8.5-2 + .40	1.1+1 + .14	8.4-3 + .23	6.6-2 + .07	5.1-5 + .27
C	5.0+1 + .17	1.6+0 + .	1.0+1 + .16	2.8-2 + .12	6.8-2 + .10	1.2-3 + .27
D	4.7+1 + .16	2.6+2 + .07	1.2+1 + .24	7.4-0 + .28	8.9-2 + .12	3.4-1 + .04
E	7.6+1 + .11	1.7+1 + .17	1.4+1 + .15	6.8-1 + .44	1.7-1 + .07	2.6-2 + .09
F	4.2+1 + .17	1.8+2 + .08	8.8+0 + .23	2.3+0 + .08	9.3-2 + .17	2.3-1 + .04
G	2.2+1 + .19	4.6+1 + .04	6.0+0 + .18	4.2-1 + .04	4.1-2 + .19	7.2-2 + .01
H	2.6+1 + .26	4.6-1 + .09	6.9+0 + .28	8.3-2 + .09	3.4-2 + .24	9.2-4 + .08
I	1.5+1 + .14	1.4-1 + .87	3.5+0 + .14	4.6-2 + .90	2.9-2 + .45	7.9-5 + .65
J	3.6-3 + .31	9.2-4 + .17	1.2-3 + .32	3.2-4 + .17	1.8-6 + .27	4.1-7 + .17
K	5.5-2 + .13	8.2-4 + .21	1.9-2 + .13	2.8-4 + .21	2.7-5 + .12	3.9-7 + .19
L	8.2-3 + .30	2.4-3 + .14	2.7-3 + .29	8.2-4 + .14	3.1-6 + .21	1.1-6 + .14

* See Figure 8.28

** Fractional Standard Error

TABLE 8.5

B. 1000 Pulses, 100 Pulses on Each of Ten Consecutive Days

Position	1 h After Last Pulse		1 day After Last Pulse		1 Week after Last Pulse	
	Test Cell Without Injector	Injector Contribution	Test Cell Without Injector	Injector Contribution	Test Cell Without Injector	Injector Contribution
A	1.9+2 + .11	1.1-2 + .20	4.7+1 + .14	3.8-3 + .20	8.8-1 + .11	2.4-5 + .29
B	6.8+1 + .11	9.7-2 + .34	1.7+1 + .13	1.3-2 + .22	2.8-1 + .09	3.9-4 + .35
C	6.5+1 + .15	1.6+0 + .17	1.6+1 + .15	5.1-2 + .10	3.2-1 + .12	1.0-2 + .30
D	6.5+1 + .17	2.8+2 + .07	1.9+1 + .22	1.3+1 + .22	4.4-1 + .18	2.7+0 + .05
E	9.9+1 + .11	1.8+1 + .17	2.4+1 + .14	1.2+0 + .36	7.7-1 + .08	2.3-1 + .09
F	5.6+1 + .17	1.9+2 + .08	1.4+1 + .22	5.3+0 + .04	4.5-1 + .18	1.9+0 + .05
G	3.1+1 + .17	4.7+1 + .04	9.5+0 + .16	1.3+0 + .02	1.7-1 + .24	5.9-1 + .01
H	3.6+1 + .26	5.9-1 + .09	1.1+1 + .28	1.4-1 + .08	1.4-1 + .27	4.2-3 + .17
I	2.0+1 + .13	2.0-1 + .88	5.6+0 + .15	6.8-2 + .90	1.3-1 + .50	1.8-4 + .43
J	5.3-3 + .31	1.4-3 + .17	1.8-3 + .32	4.7-4 + .17	5.0-6 + .20	7.6-7 + .15
K	8.2-2 + .13	1.2-3 + .21	2.8-2 + .13	4.2-4 + .21	6.4-5 + .10	9.0-7 + .13
L	1.2-2 + .29	3.6-3 + .14	3.9-3 + .28	1.2-3 + .15	6.4-6 + .26	1.9-6 + .12

TABLE 8.5

C. 1000 Pulses, 100 Pulses in Each Day of Operation,
40 Days Between Days of Operation

Position	1 h After Last Pulse		1 day After Last Pulse		1 Week after Last Pulse	
	Test Cell Without Injector	Injector Contribution	Test Cell Without Injector	Injector Contribution	Test Cell Without Injector	Injector Contribution
A	1.5+2 + .11	7.8-3 + .19	2.9+1 + .14	2.6-3 + .20	2.3-1 + .10	8.3-6 + .25
B	5.2+1 + .10	6.5+2 + .40	1.1+1 + .14	8.5-3 + .23	7.1-2 + .06	1.5-4 + .33
C	5.0+1 + .17	1.6+0 + .17	1.0+1 + .16	3.0-2 + .11	7.3-2 + .10	3.2-3 + .30
D	4.7+1 + .16	2.6+2 + .07	1.2+1 + .23	6.1+0 + .26	1.2-1 + .19	9.2-1 + .05
E	7.6+1 + .11	1.7+1 + .17	1.4+1 + .15	7.3-1 + .41	1.9-1 + .06	7.9-2 + .08
F	4.2+1 + .17	1.8+2 + .08	8.8+0 + .23	2.7+0 + .07	9.6-2 + .16	6.4-1 + .04
G	2.2+1 + .19	4.6+1 + .04	6.0+0 + .17	5.6-1 + .02	4.5-2 + .18	2.0-1 + .01
H	2.6+1 + .26	4.6-1 + .09	6.9+0 + .23	8.3-2 + .09	3.6-2 + .22	1.1-3 + .15
I	1.5+1 + .14	1.4-1 + .87	3.5+0 + .14	4.6-2 + .90	3.2-2 + .40	8.0-5 + .64
J	3.6-3 + .31	9.2-4 + .17	1.2-3 + .32	3.2-4 + .17	2.1-6 + .24	4.3-7 + .17
K	5.5-2 + .13	8.2-4 + .21	1.9-2 + .13	2.8-4 + .21	3.0-5 + .11	4.4-7 + .16
L	8.2-3 + .30	2.4-3 + .14	2.7-3 + .29	8.2-4 + .14	3.4-6 + .20	1.1-6 + .14

As expected, the largest contributor to the activation dose is the bending magnet, a chunk of Fe. The Mn-56 induced in Fe will decay away quickly so that after one day of waiting, the maximum dose rate within the injector is only 5 mr/hr. In comparison, the dose rate from the building walls and the igloo will be 20-30 mr/hr. Thus, the problem of service to the NBI is the wall activation rather than the injector activation itself. In all the cases, with the injector shield remaining intact after pulsing, the dose contribution from the injector components at locations external to the injector shield box is one order of magnitude lower than the dose from the building structures.

8.5 Air Activation⁽⁴⁰⁾

8.5.1 Method of Calculation

The air activation is of concern here because it causes internal exposure to the human body. The DOE sets forth a limit for the maximum permissible concentrations for the radioactive isotopes in air. The important radioisotopes which could be present after TFTR shutdown are N-13, N-16 and Ar-41. The MPC's are 1 pCi/cc, 1 pCi/cc and 2pCi/cc respectively (based on an infinite cloud model). Among the three isotopes, the first two result from fast neutron reactions and the third is the result of thermal reaction. N-16 is of least concern primarily because of its very short half-life (7.1 seconds).

The activity density of a radioactive isotope in air would depend not only on the time of decay, but also on the rate that the air is being diluted or exchanged. Taking the test cell air as an example, the air within the igloo is exchanged with that in the test cell and the air within the test cell is exchanged with outside environment. The effective decay of a nuclide would therefore depend on the exchange rate in addition to its natural decay rate.

$$V \frac{dN}{dt} = -L + G$$

where

V = total volume

L = rate of loss

G = rate of gain

The rate of loss and gain can be written as:

$$L = \lambda NV + v_o N$$

$$G = RV + v_i N'$$

where

λ = decay constant

v_o = outflow rate

R = rate of production

v_i = in-flow rate

N' = nuclide concentration in the inflow reservoir.

Notice that the rate of gain and loss are approximate. The equal sign holds only when the nuclide concentration is uniform throughout the entire volume of consideration. Also some implicit assumptions have been made in the above equation, namely the free air volume at any given moment is a constant and the parent density remains unchanged. In the following discussion the in-flow and out-flow rate will be assumed equal.

If one assumes that the inflow air is non-contaminated, then

$$dN/dt = -\lambda_{eff} N + R$$

where the effective decay constant

$$\lambda_{eff} = \lambda + u_0/V$$

Immediately after n pulses, the activity of a particular radioactive nuclide is

$$A_0 = R \frac{1 - e^{-\lambda_{eff} t_p}}{1 - e^{-\lambda_{eff} T_p}} \times (1 - e^{-\lambda_{eff} n T_p}) \times \frac{\lambda}{\lambda_{eff}}$$

where

t_p = pulse length (0.5 sec)

T_p = time elapsed between pulses (300 sec)

The activity at time t elapsed after the last pulse, $A(t)$, is

$$A(t) = A_0 e^{-\lambda_{eff} t}$$

If $u_0 = 0.0$, i.e., the static condition, then $\lambda_{eff} = \lambda$.

This particular case has been used for the calculations in the basement area.

For two component case, such as the inter change of air between igloo and test cell, the test cell and out side environment

$$V_i \frac{dN_i}{dt} = -\lambda N_i V_i - u_{it} N_i + u_{it} N_t + R_i V_i$$

$$V_t \frac{dN_t}{dt} = -\lambda N_t V_t - u_{it} N_t - u_{to} N_t + u_{it} N_i + R_t V_t$$

where

i = index for igloo

t = index for test cell

u_{it} = flow rate of air from igloo to test cell or from test cell to igloo

u_{to} = flow rate of air from test to environment or vice versa

$$\text{Let } L_i = \frac{u_{it}}{V_i}$$

$$L_t = \frac{u_{it}}{V_t}$$

$$L_0 = \frac{U_{t0}}{V_t}$$

$$\lambda_i = \lambda + L_i$$

$$\lambda_t = \lambda + L_t + L_0$$

The general solutions, in the case of $L_t \neq 0$, are

$$N_i(t) = a_{1t} \frac{m_1 + \lambda_t}{L_t} e^{m_1 t} + a_{2t} \frac{m_2 + \lambda_t}{L_t} e^{m_2 t} + R_i,$$

$$N_t(t) = a_{1t} e^{m_1 t} + a_{2t} e^{m_2 t} + R_t,$$

where

$$m_1 = \frac{1}{2} \left\{ -(\lambda_i + \lambda_t) + \sqrt{(\lambda_i - \lambda_t)^2 + 4 L_i L_t} \right\}$$

$$m_2 = \frac{1}{2} \left\{ -(\lambda_i + \lambda_t) - \sqrt{(\lambda_i - \lambda_t)^2 + 4 L_i L_t} \right\}$$

$$R_i' = \frac{\lambda_t R_i + L_i R_t}{\lambda_t \lambda_i - L_i L_t}$$

$$R_t' = \frac{\lambda_i R_t + L_t R_i}{\lambda_t \lambda_i - L_i L_t}$$

a_{1t}, a_{2t} will be determined by the initial condition.

Similar results to the one component case after n pulses may be derived, but they are very complicated. If, however, one assumes that there is no ventilation during the pulsing, and the venting system is turned on immediately after the last pulse, then the activities A_i, A_t at time t elapsed after the last pulse will be

$$A_i(t) = a_1 \frac{m_1 + \lambda_t}{L_t} e^{m_1 t} + a_2 \frac{m_2 + \lambda_t}{L_t} e^{m_2 t}$$

$$A_t(t) = a_1 e^{m_1 t} + a_2 e^{m_2 t}$$

$$a_1 = \frac{L_t}{m_1 - m_2} A_{i0} - \frac{m_2 + \lambda_t}{m_1 - m_2} A_{t0}$$

$$\alpha_2 = \frac{-Lt}{m_1 - m_2} A_{io} + \frac{m_1 + \lambda t}{m_1 - m_2} A_{to}$$

A_{io} , A_{to} are the average activities of the nuclide immediately after the last pulse in the igloo and the test cell.

It is interesting to consider a special case, $v_{to}=0$, i.e., the interflow of the air takes place only between the igloo and the test cell.

$$m_1 = -\lambda, \quad m_2 = -\lambda - Li - Lt$$

$$\alpha_1 = \frac{Lt A_{io} + Li A_{to}}{Li + Lt} = \frac{Vi A_{io} + Vt A_{to}}{Vi + Vt} = \bar{A}$$

$$\alpha_2 = - \frac{Lt}{Li + Li} (A_{io} - A_{to})$$

where

$\bar{A}$ = instantaneously mixed activity for the nuclide

and

$$A_i(t) = \bar{A} e^{-\lambda t} + \frac{Vi}{Vi + Vt} (A_{to} - A_{io}) e^{-(\lambda + Li + Lt)t}$$

The second term decays much faster than the $e^{-\lambda t}$ first term, so that when $t \gg 1$. $A_i \sim A_t \sim \bar{A} e^{-\lambda t}$ and the equilibrium condition is attained. Yet the "true" equilibrium condition will never be reached, particularly when $Lo \neq 0$.

8.5.2 The Activity Concentration in Air for DT Pulsing

The air activation rate has been computed based on the 2D toroidal model. The streaming effect was not considered and the presence of objects within the areas ignored. The free air volumes for the igloo, test cell and basements are:

Igloo	$3.707 \times 10^2 \text{ m}^3$
Test Cell	$1.485 \times 10^4 \text{ m}^3$
Inner Basement	$7.004 \times 10^2 \text{ m}^3$
Outer Basement	$5.100 \times 10^3 \text{ m}^3$

The data immediately after the last pulse for the static condition are given in Table 8.6. In the basement area, the MPC's can be met under any pulsing scheme considered here. No ventilation is needed.

The time dependence of the activity levels in the test cell are given in Figure 8.29 assuming the saturation condition. It is seen that the most difficult requirements to meet are the Ar-41 and N-13 in the igloo. The activities of N-13, and Ar-41 under various ventilation conditions in the test cell are given in Figure 8.30 and 8.31. Again the saturation values have been used. Assuming a 10,000 cfm ventilation rate for the igloo air, the MPC's will be met within an hour after machine shutdown only when the test cell air ventilation rate is greater or equal to 20,000 cfm.

TABLE 8.6

ACTIVITIES OF N-13, N-16, Ar-41
 IMMEDIATELY AFTER LAST PULSE, 20 MW DT

(pCi/cc)

<u>Pulse/Group</u>	<u>igloo</u>	<u>Test Cell</u>	<u>Mixed</u> ⁽¹⁾	<u>Inner Basement</u>	<u>Outer Basement</u>
A. N-13					
1/1	1.51+4 ⁽²⁾	2.16+0	3.50+2	3.93-3	1.77-5
10/1	4.99+4	7.16+0	1.16+3	1.30-2	5.85-5
100/1	5.15+4	7.39+0	1.19+3	1.34-2	6.04-5
1000/1	5.15+4	7.39+0	1.19+3	1.34-2	6.04-5
100/10 ⁽³⁾	5.15+4	7.39+0	1.19+3	1.34-2	6.04-5
100/40 ⁽³⁾	5.15+4	7.39+0	1.19+3	1.34-2	6.04-5
B. N-16					
--- ⁽⁴⁾	2.24+6	3.91+2	5.20+4	9.08-1	4.75-3
C. Ar-41					
1/1	3.33+0	7.22-3	8.40-2	1.91-2	2.35-3
10/1	2.90+1	6.29-2	7.31-1	1.67-1	2.05-2
100/1	1.03+2	2.23-1	2.60+0	5.90-1	7.23-2
1000/1	1.07+2	2.32-1	2.70+0	6.16-1	7.55-2
100/10 ⁽³⁾	1.03+2	2.23-1	2.60+0	5.90-1	7.23-2
100/40 ⁽³⁾	1.03+2	2.23-1	2.60+0	5.90-1	7.23-2

1. Instantaneous mixing for the air in the igloo and test cell

$$\bar{A} = \frac{V_i A_i + V_t A_t}{V_i + V_t}$$

2. Read 1.51×10^4
 3. 10 groups of 100 pulses evenly spread over a year
 4. For all the pulsing schemes considered here

Figure 8.30

Activity Density of N-13 as a
Function of Cooling Time, Igloo
Ventilation Rate = 10,000 cfm,
Test Cell Air Ventilation Rate =
Variable

Figure 8.31

Activity Density of Ar-41 as a
Function of Cooling Time, Igloo
Ventilation Rate = 10,000 cfm,
Test Cell Air Ventilation Rate =
Variable

9.0 SUMMARY AND CONCLUSION

A comparison of the permissible radiation level, the design objectives and the calculated radiation levels is given in Table 9.1. Even though a full power operation has been assumed in the analysis, which is considered to be highly conservative, nonetheless, one ought to expect the best and the worst. The current shielding, to say the least, is not over-designed. In particular, the igloo wall should be considered for DD operation. Further, there is little room left for the TFTR upgrade which is now under vigorous pursuit. Thus *the radiation problem should be examined with more attention and great care.*

The instantaneous biological dose delivered during DT and DD pulsing in the test cell will be too high to permit any access. The instantaneous biological dose in the basement area during DT pulsing will also be high enough not to allow uncontrolled access. Outside the test cell wall, the maximum yearly dose will be on the order of 1 rem. Restricted stay could be permitted but careful monitoring is needed to guarantee that a worker will not receive a dose in excess of the government guidelines for a short term exposure limit. The site boundary dose will be on the order of 10 mrem per year.

The shielding provided for the major penetrations are adequate to eliminate any particular hot spot. The activation dose from the building walls will be on the order of 100 mr/hr 1 hour after 100 DT pulses (10 mr/hr after 10 DT shots), and on the order of 20-30 mrem/hr after 1 day of cooling.

The analysis here is not a scoping study, nor is it a final report. It is our hope that this study would fill the gap between these two ends and provide useful input for the TFTR system design. Many inadequacies in the analysis are recognized. Perhaps the most interesting yet the most intriguing problem is the penetrations, both major and minor ones, both for instantaneous flux levels and for activation, with different arrangements, and the folding of the *streaming radiation to the reference field.*

The cross section libraries need to be updated, the error bounds of the calculations need to be established. Most of all, better modeling to account for the complicated arrangement of the machine components is a challenging task which lies ahead.

TABLE 9.1 Radiation Levels - Permitted, Desired, Anticipated
During Normal Operational and Post Operational Period

Location Unit			On Site-Off Site Boundary (125 m)	Controlled Area Test Cell Wall Surface	Activation on Igloo Side Surface 1 d operation 1 hr cooling	Air Activation Ventilation rate: 10000 cfm Igloo, 15000 cfm Test Cell, 1 hr Cooling
Permissible (a)			mrem/yr < 500 to Individual < 170 to average population	rem/yr < 5	ureg/hr ≤ 0.5 mrem/hr for continuous exposure ≤ 100 mrem/yr and ≤ 5 r/yr including ex- posure during operation	pCi/cc N: 1.0 Ar = 2.0
Design Objective			(j) 10	1	50 (e)	N = 1.0 Ar = 2.0
(b) DT	Average, Elevation =Plasma	Calculated, (a) TF Coils not modelled	10 ± 0.6 ^(e,f)	0.5	125 ^(h)	N-13: 2.4 Ar - 41: 0.24
	Mid- plane	Estimated if TF Coils included	5	0.3	20 ^(h)	
	Range of Variation along Vertical Direction of the Surface, TF Coils not modelled		10 ± 0.6 -11.4 ± 0.6	0.4 - 2.0	30 - 125	
(c) DD	Average, Elevation =Plasma	Calculated, (a) TF Coils not modelled	56 ± 3.0 ^(e,f)	1.2	20 - 40 ⁽ⁱ⁾	
	Mid- plane	if TF Coils Included	28	0.6		
	Range of Vertical Variation TF Coils not modelled		56 ± 3.0 - 65 ± 3.3	1.1 - 10.0		

NOTE:

- (a) For permissible and design levels, see IM-R-005, 2A2-2 Rev. 1. For calculated levels, see PE-M-3019, PE-M-3111, PE-M-3283, PE-M-3505, PE-M-3589, PE-M-3613.
 (b) 20 MW power, 0.5 sec/pulse, 1 pulse/5 min. 96 pulses/day, 1,000 pulses/yr.
 (c) 22 kW power, 2% DT, 0.5 sec/pulse, 1 pulse/5 min., 96 pulses/day, 10,000 pulses/yr. Igloo absent.
 (d) Including gaseous radioactive materials released
 (e) Radioactive material release not included.
 (f) $\bar{X} \pm \sigma$, the mean and standard error associated with the Monte Carlo calculation
 (g) From all sources.
 (h) Equipment activation not included
 (i) ...

Acknowledgement

The author wishes to express his sincere thanks to G.V. Sheffield and J.T. Giarrusso for their constant encouragement and administrative help during the course of this work. Delightful discussions with K.M. Young, J. Kolibal, C. Pierce and H. Howe are also deeply appreciated. This work was supported by the Department of Energy Contract DE-AC02-76-CH0-3073.

References

1. J.E. Faulkner, G. Gibson and J. Jedruck, "TFTR Nuclear Radiation Analysis," WFPS-TME-022, Nov. (1975)
2. G.V. Sheffield, J.T. Giarrusso and H. Wexler, "The General Requirements Sections of the TFTR System Descriptions," PH-R-005, 2A2-2, Rev. 1, Dec. (1977)
3. "Coupled (100 n, 21 γ) Cross Sections for EPR Calculations," DLC 37/D RSIC
4. "Vitamin-C, 171 Neutron, 36 Gamma-Ray Group Cross Section Library in AMPX Interface Format for Fusion Neutronics Studies," DLC-41/B, RSIC (1978)
5. "BUGLE, Coupled 45 Neutron, 16 Gamma P3 Cross Sections," DLC-47, RSIC
6. L.P. Ku, "Re-analysis of Radiation Level in the Test Cell during DT Operation," PE-M-3019, Sept. (1978)
7. B.G. Carlson and K.D. Lathrop, "Transport Theory - the Method of Discrete Ordinates," in "Computing Methods in Reactor Physics," H. Greenspan ed., Gordon & Breach, 1968
8. "DOQDP, Discrete Ordinates Quadrature Generator," PSR-110, RSIC Collection
9. M.H. Kalos, et. al., "Monte Carlo Methods in Reactor Computations," in "Computing Methods in Reactor Physics," H. Greenspan ed., Gordon & Breach, 1968
10. "REBATE, Calculation of Decay Gamma Source Strength for 1 or 2 Dimensional Gamma Transport Calculation," Ebasco Company of N.Y. (1979)
11. W.W. Engle, Jr., "ANISN - A One Dimension Discrete Ordinates Transport Code with Anisotropic Scattering," CCC-254, RSIC (1973)
12. W.A. Rhoades and F.R. Mynatt, "DOT 3.5, A Two Dimensional Discrete Ordinates Transport Code," CCC-276, RSIC
13. E.A. Straker, et. al. "MORSE-CG, A General Purpose Monte Carlo Multigroup Neutron and Gamma-Ray Transport Code with Combinational Geometry," CCC-203, RSIC
14. ANSI/ANS, 6.1.1, 1977, N-666
15. N.M. Shaeffer, "Reactor Shielding for Nuclear Engineers," TID-25951 (1973)

16. M.A. Abdou, C.W. Maynard and R.Q. Wright, "Mack - A Computer Program to Calculate Neutron Energy Release Parameters (Fluence-to-Kerma Factors) and Multigroup Neutron Reaction Cross Sections from Nuclear Data in ENDF Format," ORNL/TM-3994, ORNL (1973)
17. "RECOIL, Multigroup Primary Recoil Spectra, Displacement Rates and Gas Production Rates for Radiation Damage Studies," DLC-55, RSIC
18. "MONTAGE, 100 Neutron Activation Cross Section Data for Fusion Reactor Structure and Coolant Materials," DLC-33, RSIC
19. Alley and Lesler, "Semi-empirical Neutron Induced Reaction Cross Sections," UCRL-50484. The tabulated data also from PDS-40
20. L.P. Ku, "Do We Really Have to Worry about 17 Me V Prompt Gamma Rays?" PE-M-3652, (1979)
21. L.P. Ku, "Radiation Analysis for the Inner Basement," PE-M-2643 (1978)
22. L.P. Ku, "Radiation Analysis for Outer Basement Area during 20 MW DT Pulsing," PE-M-3091 (1978)
23. L.P. Ku, "Biological Dose in the TFTR Site from 20 MW DT Pulsing," PE-M-3111 (1978)
24. S.J. Lindenbaum, "Skyshine," Conference on Shielding of High-Energy Accelerators, April 11 to 13, 1975, TID-7545, pp 101-109
25. R.T. Clarke, "Photon Fields Near Earth-Air Interface," Engineering Compendium on Radiation Shielding, H.G. Jaeger, Ed., Vol. 1, pp 255-258
26. L.P. Ku, "Radiation Level in the Test Cell during DD Operation," PE-M-3589 (1979)
27. L.P. Ku, "Site Boundary Dose during DD Pulsing," PE-M-3616 (1979)
28. L.P. Ku, Unpublished
29. T. Rockwell, "Reactor Shielding Design Manual," TID-7004, NTIS (1956)
30. R.T. Santoro, et. al., "Two and Three Dimensional Neutronics Calculations for the TFTR Neutral Beam Injectors," NSE 70, 225-242 (1979)
31. R.T. Santoro, et. al., "Shielding Calculations for the TFTR Neutral Beam Injectors," Nuclear Technology 47. 412-420 (1980)
32. R. Asmilliar, Private Communication
33. L.P. Ku, "Radiation Analysis for the TVPS," PE-M-3518 (1978)

34. L.P. Ku, Unpublished
35. L.P. Ku, "Additional Activation Calculation," PE-M-3881 (1979)
36. L.P. Ku, "Biological Dose Rates from Neutron Activated Objects," PE-M-3316 (1978)
37. A. Fodoraro, "Photon Shielding Manual," Penn. State University Bookstore
38. L.P. Ku, "Background Activation Dose Rate," PE-M-3505 (1979)
39. R.G. Alsmiller, Jr., et. al., "Dose Rates from Induced Activity in the TFTR Test Cell," Nuclear Technology 48, 187-195 (1980)
40. L.P. Ku, "Air Activation, A Re-Visit," PE-M-3283 (1978)