Table of Contents

	<u>PAGE</u>
Description	5
Reliability & Maintenance	17
Analytical Program	21
Performance Analysis	23
Performance Results	27
Recommendations	55
Significance of the Anderson Quin Cycle	57
References	59
Appendix A	61
Anderson Quin Cycle Volumetric Performance	
Appendix B	69
Anderson Quin Cycle Massflow Projections	
Appendix C	81
The Refrigerated Gas and Vapor Turbine Cycle	
Appendix D	93
The Anderson Quin Cycle	
Appendix E	107
Effects of Power Generation on the Carbon Cycle	

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Table of Contents (cont.)

DIAGRAMS PAGE

1	The Anderson Quin Cycle Layout	31
2	The Refrigeration Diagram	32
3	The Refrigeration T-H Diagram	33

TABLES

1	Gas Turbine Characteristics - 2000° F. Turbine Temperature	34
2	Gas Turbine Characteristics - 2400° F. Turbine Temperature	35
3	Steam Turbine Analysis Results	36
4	Vapor Turbine Analysis Results	37
5	Anderson Quin Cycle Component Performance Summary	38
6	Inlet Airflow Derivatives	39
7	Gas Turbine Heat Balance	40
8	Flue Gas Heat Balance	41

FIGURES

1.0	Compressor Discharge Temperature vs Compressor Pressure Ratio	42
1.1	Refrigeration Work vs Air Wet Bulb Temperature	43
1.2	Combustor Energy Input vs Compressor Pressure Ratio	44
1.3	Refrigerated Inlet Effects on Power Turbine	45
2.0	Parasitic Flow Effect on Performance @ Constant Turbine Bulk Metal Temperature . . .	46
2.1	Turbine Inlet Temperature Effects on Performance	47
3.0	HP Steam Turbine Optimization Analysis - P/P=8, 12, 16	48
3.1	HP Steam Turbine Optimization Analysis - P/P=20, 24	49
3.2	HP Steam Turbine Optimization Analysis - P/P=28	50
3.3	Steam Turbine Specific Energy vs Steam/Inlet Air Massflow Ratio	51
4.0	Flue Gas Temperature Analysis vs Compressor Pressure Ratio	52
5.0	Vapor Turbine Specific Energy vs Isobutane/Inlet Air Massflow Ratio	53

The Anderson Quin Cycle

U.S. Department of Energy
Grant # DE-FG01-91CE15535

Final Report

March 19, 1993

By: J. Hilbert Anderson
William M. Bilbow

The objective of this study was to make a more refined evaluation of the Anderson Quin Cycle based on most recent information on the performance of various elements that will be used in the Anderson Quin Cycle.

My original estimate of the work plan for evaluating and optimizing the Anderson Quin Cycle called for 7000 man hours of work. Since this grant was limited to 2150 man hours, we could not expect to achieve all the objectives within the allotted period of work. However, the most relevant program objectives have been completed as reported here. The analysis generally confirms the results originally estimated in my paper on the subject. (Ref.2) Further optimizations should show even higher efficiencies.

The Anderson Quin Cycle (US Patent applied for) basically consists of 5 elements in the power cycle. The first element is a refrigeration system to cool and clean the inlet air before it enters the compressor that supplies air for the gas turbine. The second element is a gas turbine consisting of a compressor, combustor, and turbine. The third element is a steam boiler and steam turbine system using the heat from the exhaust gas out of the gas turbine. The fourth element is a vapor turbine cycle, which utilizes the condensed heat from the exhaust of the steam turbine and the exhaust gas heat leaving the steam boiler to operate a vapor turbine cycle which utilizes another fluid than water, in this case isobutane.

The fifth element consists of a gas cooler and heat pump system, which removes the heat from the exhaust gas to lower its temperature essentially to atmospheric temperature, and

at the same time permits treatment of the exhaust gas to remove acid components such as sulfur dioxide and nitrogen oxides.

Current industry accepted component characteristics were incorporated in the performance analysis of the overall cycle, ensuring accurate and meaningful operating predictions. The characteristics and performance of each of the elements follows:

REFRIGERATION SYSTEM

Based on the original study entitled "The Refrigerated Gas and Vapor Turbine Cycle", we selected a refrigerated inlet temperature of approximately -60° F. (400° R) as a desirable compressor intake temperature. There is some possibility that even lower temperatures should be used, but this temperature is very desirable because lower temperatures would tend to cause additional operating problems due to the condensation of CO₂ at a temperature of -69° F. It is also practical to refrigerate to -60° F. using a single refrigerant such as R-22. It should be noted that the basic efficiency of a gas turbine cycle is related directly to the ratio of the turbine inlet temperature to that of the air inlet temperature to the compressor. As a practical matter, it is somewhat easier to lower the air inlet temperature than it is to raise the turbine inlet temperature. Gas turbines are often used as "peaking" machines today. One of the weaknesses of the gas turbine simple cycle is that it produces 10% to 20% less power at 2% to 5% lower efficiency in the summer than in the winter, and usually peak power is required from utilities in the summer. By refrigerating the inlet to a low temperature this permits high output in the summer as well as in the winter.

I selected R-22 as a refrigerant of choice for this study. R-22 is the most common refrigerant used in household refrigerators and air conditioners today. While it is a hydrochlorofluorocarbon, it is generally acceptable today because the effect on the ozone layer depletion is estimated to be approximately only 5% of the effect generated by other common chlorofluorocarbon refrigerants. It has a specific advantage in that a single refrigerant can be used all the way from -60° F. to condensing temperatures above 100° F.

Ammonia could be used as an alternative refrigerant, but is not as well adapted to high capacity centrifugal refrigeration in the small steps desirable in this refrigeration process.

Hydrocarbons such as propane, propylene, and ethylene could also be used as refrigerants. The disadvantage of using the hydrocarbons is that two refrigerants must be used, simply because the practice of using hydrocarbons at pressures below atmosphere raises safety issues.

To minimize the power requirements for refrigeration, it is absolutely necessary to use multistage refrigeration cycles. Such a cycle (U.S. Patent Pending) is shown diagrammatically on drawing 33-B-2 on Page 32. On the drawing the air coolers are shown at the bottom with the air going in at the left at 73° F. and successively being cooled down to -50° F. at the last finned air cooler on the right.

The system shown uses 6 two stage centrifugal compressors designated C1 through C6. Compressors C5 and C6 discharge to condensers which could be either air cooled or water cooled. The elements between the air coolers and the compressors are flash chambers and intercoolers used in the cycle.

The thermodynamic cycle diagram is shown on Page 33. This pressure enthalpy chart for R-22 shows the successive stages in the refrigeration cycle going from -56° F. to a final condensing temperature of 100° F. The resulting energy required for refrigeration and btu per pound of air cooled versus air wet bulb temperature is shown in Figure 1.1 on Page 43. Performance is based on acceptable temperature differences in standard finned air coolers and on acceptable demonstrated refrigeration compressor efficiencies.

Since the air must pass through a series of finned coolers as shown on the drawing where 12 coolers are shown in series, then the pressure drop on the air must be considered, as it affects the cycle efficiency. Calculations based on reasonable velocities of air through the coolers indicate that the pressure drop through this whole system would actually be as low or somewhat lower than the usual pressure drop encountered with air inlet filters used on gas turbines. In this particular case water condenses out of the air, wetting the coolers, and this acts as an effective cleaning process so that the air entering the gas turbine at the final low temperature should be completely free of dirt particles. They will all have been washed out by the liquid film on the surfaces of the finned air coolers. Passing the air through a succession of refrigerated coolers acts as a noise suppressor, and with this system it seems assured that noise filters would not be needed at the inlet to the turbine system.

The refrigeration system needs to be adaptable to work during the winter as well as during the summer, and therefore, must be capable of adjustment in the refrigeration effect. This can normally be done by several methods. If motor driven compressors are used at constant speed, then the compressors are furnished with adjustable inlet vanes which permit a wide variation in compressor head. This enables the head to match the requirements for the refrigeration system. If compressors are driven by turbines, as they might well be, then the centrifugal compressor speed can be adjusted to match the required head required by the refrigeration system. At large variations in head it is also possible simply to stop one or more of the compressors and have the remaining compressors take over the refrigeration load. Modern design centrifugal refrigeration compressors can successfully and reliably operate over a wide range of capacity and heads. This is well established refrigeration practice.

AIR COMPRESSOR

The air compressor required for low temperature air can be designed for a given pressure ratio either with fewer stages, or at lower tip speeds than are required for a high temperature inlet at the same pressure ratio. Alternatively, a higher pressure ratio can be developed with a given number of stages and tip speeds. Depending on the design of the compressor the speed may be limited by the Mach number limitation on the design of the first stages. This opens the possibility to eliminate one or two of the first stages of the compressor and use fewer stages to develop the required pressure ratio for the system. This could also solve the problem, if discharge pressure in the compressor casing is a limiting factor.

One of the characteristics of the refrigeration system is that the air entering the compressor will be completely clean and free of foreign particles. This should eliminate fouling and deterioration of performance of the compressor. Since the density of cold air is higher than the density of normal atmospheric air, at a given tip speed the bending stresses on compressor blades would be higher than with atmospheric air inlet. However, since the temperature is significantly lower, the compressor blades should not exhibit a serious fatigue strength problem.

A typical compressor operating at higher and variable inlet temperature may lose two points in efficiency caused by blade tip rubbing. With the refrigerated system the inlet

temperature to the compressor will always be essentially the same. This should insure better long term operation, and should insure that tighter running clearances can be maintained. This will assure long time high efficiency operation of the air compressor.

THE COMBUSTOR

The immediate effect of the Anderson Quin Cycle on the combustor design is caused by the fact that much cooler air is available for cooling the walls. Since the inlet air is cooler more heat can be added to reach a given combustor discharge temperature. This means that for a given turbine inlet temperature, the walls of the combustor can be kept cooler, and life and maintenance of the combustor can be improved.

As an alternative higher combustion temperatures can be allowed because of the availability of cooler cooling air.

Higher burning temperatures normally mean an increase in the quantity of nitrogen oxides generated in the combustion process. However, since the Anderson Quin Cycle reduces gas exhaust temperature down to atmospheric temperatures by direct contact with water, then the nitrogen oxides can be effectively removed at the end of the cycle. It will therefore not be necessary to limit combustion temperatures because of nitrogen oxide generation. In many combustors temperature is limited by injecting water into the burning process. While this reduces burning temperature and generation of nitrogen oxides, it also increases CO in the gas. It will not be necessary with the Anderson Quin Cycle.

In the Anderson Quin Cycle it is possible to utilize high quantities of water injection, with the water heated very close to the boiling point before injection by the exhaust heat from the exhaust heat boiler. This then points to the desirability of injecting water down stream of the combustion process, for example by using water cooled walls before injecting the water. This permits a great increase in combustion heat and can utilize more fuel in the process to the extent that complete combustion to nearly stoichiometric conditions can be achieved. This would obviously necessitate changes in combustor design, principally to make them longer to allow transfer of heat from the higher temperature combustor gas to convert the injected water into steam.

It is well known that water injection into the combustor can increase power output from the cycle. In the cycle using steam in the combustion gas to increase power output the efficiency is reduced, partly because the pressure ratio is too low for the most efficient steam cycle, and partly because the latent heat of vaporization of water is lost. In the Anderson Quin Cycle the latent heat of the steam is recovered. This makes water or steam injection more practical.

The additional effect of introducing enough water into the combustor to allow nearly stoichiometric combustion means that there will be less oxygen in the gas flowing through the turbine and less oxygen in the gas entering the exhaust steam boiler. This should reduce the possibilities of corrosion in the turbine blading and in the boiler.

THE TURBINE

In the gas turbine, if turbine inlet temperatures are kept to present acceptable values such as 2400° F., then the turbine blading will actually run at lower temperatures because, if the same quantity of cooling air is used, the cooling air is much cooler. Therefore the blade and stator temperatures will be maintained lower, so that the turbine should have longer life. As an alternative the turbine could be designed for less cooling air at the same inlet temperature, or the turbine inlet temperature could be increased to achieve higher efficiency.

The match between compressor volumetric flow rates and turbine volumetric flow rates will be different in the Anderson Quin Cycle than in the ordinary gas turbine cycle. This will be particularly so if the maximum amount of water injection is used.

As an immediate objective for using the Anderson Quin Cycle the match between turbine and compressor can be improved by simply removing one or several stages at the inlet of the compressor. This will reduce the volumetric capacity of the compressor for a given mass flow. The mass flow through the turbine would then be approximately the same as with a cycle using atmospheric air inlet.

THE BOILER

The boiler designed for utilizing turbine exhaust gas to generate steam would be essentially no different from the boiler designs now being used. On a practical basis, if water injection is used to a large extent, then the exhaust gas will have less oxygen in it and more steam. This should normally not affect boiler design greatly, except in the sense that there should be less corrosion due to oxygen attack in the boiler.

GAS PROPERTIES

In our analysis of the Anderson Quin Cycle we decided that it should be quite important to develop a computer program which recognized the various possible constituents in the gas or gas and steam composition passing through the turbine and the boiler. This required a considerable effort. Normally gas turbine manufacturers have not needed to be very careful about the accuracy of the specific heat and properties of the gas as they pass through the turbine and boiler.

In the Anderson Quin Cycle we are dealing with considerable variation of potential composition of the combustion gases, and we felt that this should be taken into account in our analysis in order to make it as thorough as possible.

Through considerable research we have now developed computer programs which do evaluate the gas properties as they vary with composition and with the ratio of air to fuel burned in the cycle. Since the air fuel ratio can be varied quite widely in the Anderson Quin Cycle we feel that this is an important accomplishment in making better cycle analysis possible.

STEAM TURBINE

In the Anderson Quin Cycle the steam turbine exhaust is above atmospheric pressure. This has a significant effect on the design of the steam turbine. The first significant effect is that the volumetric expansion ratio through the turbine for this cycle is much lower than that through the ordinary steam cycle. For example, if the steam turbine exhausts at 115 degrees F. condensing temperature the volume ratio through the turbine is typically as high

as 362 or more. If, on the other hand it expands to 227° F. then the volume ratio is reduced to 34.2. At high volume ratios of expansion the turbine efficiency cannot be high throughout the turbine. Therefore the turbine efficiency suffers. At lower expansion ratios high turbine efficiencies are immediately obtainable. In a typical case efficiency would be 4 points higher.

The next effect is that with much lower expansion ratios through the turbine the turbine can be designed to have no water released in low pressure stages. This eliminates the usual wear problem on steam turbines, which is caused by water droplets condensing in the low stages. As a rule of thumb one percent of water condensing in the low stages decreases the stage efficiency by one percent.

With the smaller expansion ratio on the turbine the turbine rotors can be shorter, and the extremely long blades required for condensing turbines will not be needed. This means that a much shorter rotor with a more rugged design and lower tip speeds can be used. This unquestionably will increase the life of the steam turbine.

In the usual condensing steam turbine, there is such a high volume ratio throughout the turbine that the first stages require partial admission. At the much lower volume ratios required for the turbine in the Anderson Quin Cycle, the first stages can use a much higher percentage of admission than is the usual case in a condensing turbine. This means that better control and better part load efficiency can be achieved in these turbines.

In the steam turbine the exhaust pressure is above atmosphere. This then means that there will be no air leakage into the turbine to cause corrosion and to require air removal from the feed water. This in turn means that less water treatment is required for the water in the steam turbine cycle.

CONDENSER BOILER

In the condenser boiler where steam is condensed at above atmospheric pressure and isobutane is boiled there is no part of the boiler operating in a vacuum. This means that there is no air in leakage, and it also means that leaks in the tubes are much easier to detect. One of the typical problems with steam condensers operating at a vacuum is that vacuum leaks at the tube joints are very difficult to isolate.

The specific volume of steam at 227° F. condensing temperature is less than one tenth that of steam condensing at 115° F. This means that the condenser for the turbine in the Anderson Quin Cycle will be much smaller than a typical steam condenser condensing steam at temperatures such as 115° F. The higher steam density and lower specific volume also means that there are less energy losses due to pressure drop in flow across the tubes.

In the condenser boiler with condensing steam on one side of the tubes and boiling isobutane on the other, very high heat transfer coefficients are possible and efficiency of heat transfer will be excellent. For example, we have calculated that a very conveniently achievable temperature difference between steam and isobutane will be 5° F. or less. In ordinary steam condensers operating at a vacuum leaks are very difficult to locate, whereas in the isobutane boiler leaks are relatively easily located.

VAPOR TURBINE

In my original study and paper on the Anderson Quin Cycle, I used R-22 as a working fluid for the vapor turbine cycle. In the present study we used isobutane as a working fluid.

I first proposed isobutane as a working fluid for a vapor turbine cycle in geothermal plants in 1969. We used isobutane in the world's first vapor turbine cycle geothermal plant, which has been in operation since 1981. Since that time a number of other successful isobutane vapor cycle plants have been successfully used in geothermal power plants.

Isobutane has better thermodynamic characteristics than R-22 in that at the temperature levels required in the Anderson Quin Cycle, the cycle efficiencies are higher.

Isobutane is a relatively simple hydrocarbon, which is non-corrosive, stable at operating temperatures, and is both miscible and compatible with oil. This makes it quite practical to design turbines with internal lubrication, tight mechanical seals, and also internal bearings and gears.

Isobutane operates above atmospheric pressure down to the lowest condensing temperature that is likely to occur in an Anderson Quin Cycle system. This assures that no air will leak into the system.

The low thermodynamic heads required across an isobutane turbine permit the use of only one or several stages in the turbine. This means that the turbine construction can be very simple and rugged, and tip speeds are very moderate. This in turn means that stresses are low, and ordinary materials can be used inside the turbine.

The specific volume of isobutane is much lower than that of steam at a given temperature, which means that the physical size of an isobutane turbine is very much smaller than that of a steam turbine operating over the same temperature range. Since single stage turbines can be used or at the most up to three stages, then control of the isobutane turbine is easily accomplished with variable inlet nozzles. Variable inlet nozzles provide much better part load efficiency than the type of inlet valve controls used on steam turbines. Variable inlet nozzles also have low inertia, and can be operated very rapidly in case of a required shut down.

Experience in the geothermal power plants indicates that isobutane turbines are essentially as reliable and trouble free as are ordinary refrigerant compressors. Typically they require virtually no maintenance over long periods of time.

Isobutane turbines have regularly achieved efficiencies of 85 to 88%. With newer designs we can confidently be assured of efficiencies well above 90%.

AIR COOLED CONDENSER

Because isobutane has so much smaller exhaust volume than steam, this makes it practical to use air cooled condensers. This avoids the two steps in heat transfer required when steam is condensed in a water cooled condenser, and the water in turn must be cooled by a cooling tower. It is completely practical to maintain a lower condensing temperature with an air cooled isobutane condenser than is practical with a steam condenser, and this increases power output and cycle efficiency.

Since water is an increasingly scarce commodity, and very often the lack of water dictates the design and location of a power plant, the use of air cooled condensers in the Anderson Quin Cycle provides a very important advantage.

GAS COOLER

The gas cooler cools the gas to essentially atmospheric temperature in direct contact with water. This means that the water in the exhaust is completely condensed and recovered in the gas cooler. By recovering the water and the heat of condensation, the cycle efficiency is improved. The gas cooler cools the gas to a low enough temperature so that nitrogen oxides become more soluble, and can be removed by chemical treatment and converted into fertilizer. This permits much greater freedom in designing the combustor for operation at very high burning temperatures where nitrogen oxides are generated. This becomes an important advantage for the Anderson Quin Cycle using the gas cooler.

Cooling gas to approximately atmospheric temperature eliminates the need for a high stack. It also eliminates the possibility of stack corrosion since there would be no condensation of the vapors in the stack itself. This also eliminates the plume of fog usually leaving a stack.

HEAT PUMP

Heat pumps are used to reduce the stack exhaust temperature and transfer the heat of vaporization of the water in the exhaust into the vapor turbine cycle, thereby improving overall cycle efficiency slightly.

GAS TREATMENT

By cooling the gas essentially to atmospheric temperature the nitrogen oxides or sulfur dioxides which are present in the exhaust gas can be effectively dissolved and treatment can convert them into liquid fertilizer. The gas cooler with direct intimate contact with water also washes out all dust that is generated in the combustion process.

This gas treatment process makes it possible to operate the combustor at a higher burning temperature since nitrogen oxide can be effectively removed at the exhaust end of the system. Therefore controlling the combustion process to reduce generation of nitrogen oxides no longer becomes important.

WATER INJECTION

Water injection down stream of the combustion process in the combustor makes it possible to increase the power output by a large factor. The heat recovery process from the exhaust gas provides heat to heat the water being pumped into the injector up nearly to the boiling point, thereby utilizing the exhaust heat as part of this steam cycle. The heat of condensation of the steam is collected at the exhaust and utilized. The vapor turbine cycle and the heat pump permit the utilization of the heat of condensation of steam in the combustion gases.

In normal combined cycles for gas turbines where water is injected the power is increased but the efficiency necessarily decreases, because the injected water is lost, and the heat of condensation is also lost. In the Anderson Quin Cycle, the water is recovered, and the heat of condensation is recovered, so that both high power output and reasonably high efficiency are attainable.

RELIABILITY AND MAINTENANCE

The Anderson Quin Cycle is obviously much more complex than the usual combined gas and steam turbine cycle. From this one might assume that reliability and maintenance could suffer because of complexity. However, when the various characteristics of this cycle are analyzed it becomes apparent that many factors will contribute to better reliability and less maintenance than are characteristic for the ordinary gas turbine cycle. Following are some of the factors that need to be considered as far as maintenance is concerned.

The combustor in the Anderson Quin Cycle operates cooler for a given turbine inlet temperature than it does with the ordinary turbine cycle. The reason for this is that the cooler air from the compressor can more effectively cool the housing of the combustor than is possible with the very hot cooling air available in the ordinary cycle.

The compressor runs cooler. At a given pressure ratio the discharge temperature and the temperature through the blades of the compressor is much lower with the Anderson Quin Cycle than with a compressor which takes in air at atmospheric temperatures. The problems of stresses and fatigue in the compressor blading will be reduced. It also can mean that lower cost blade materials can be used. It also means that smaller operating clearances can be maintained than is normally possible with a compressor which has a very hot discharge.

The compressor stays clean. With a refrigerated air inlet the air is cooled and washed through many stages of cooling. The air entering the compressor should be completely free of dust particles or dirt which coats the blades and reduces compressor efficiency.

In the steam turbine cycle there will be no oxygen in the water simply because the steam is kept above atmospheric pressure throughout the cycle. Oxygen is a typical cause of corrosion in boilers and steam turbines, and also is costly to remove from the water in deaeration systems. The absence of oxygen in the water in the steam turbine cycle also reduces the amount of water treatment required for the water entering the boiler.

No water is condensed in the steam turbine in the Anderson Quin Cycle. This becomes an important factor for reducing wear of the low stage blades in the steam turbine.

Water impact on the blades is the principle cause of wear in steam turbines. This will be eliminated with the Anderson Quin Cycle.

Steam turbine rotors will become shorter with lower tip speeds. This will tend to reduce the vibration problems common in steam turbines. The mechanical operation of the steam turbine will therefore be much less sensitive to upsets, and will generally operate with less maintenance problems.

Less leakage problems in the condenser. Since the pressure on the steam side and the isobutane side of the condenser are both above atmospheric pressure, then the problem of detecting leakage in the condensers becomes much less of a nuisance. Vacuum leaks are difficult to find and control.

No vacuum pumps are required in the steam turbine cycle, simply because the pressure is above atmosphere in all parts of the cycle. Steam jets and vacuum pumps are typically a high maintenance item, and also create losses that will not occur in the steam cycle that operates above atmospheric pressure.

Since the steam operates above atmospheric pressure no critical hot well pumps are required to operate at high vacuum. Hot well pumps are frequently a source of air leakage into the system.

In the isobutane turbine there should be no corrosion whatsoever, because isobutane is a non-corrosive fluid, compatible with oil. Experience has shown that maintenance of these turbines is minimal.

The fact that the exhaust gas is cooled to below atmospheric temperature means that this eliminates the problem of stack corrosion, and also reduces the need for a high exhaust stack. It also eliminates the plume of fog usually emitted from stacks.

The refrigerant cycle is designed with multiple compressors, and they are normally all maintenance free. However, one of the refrigerant compressors could be stopped for repair at any time while the cycle continues to operate.

Although the cycle appears to be complicated, the shut down or repair of any part of the cycle except for the gas turbine is not critical to its operation. Any one of the elements can be shut down without shutting down the whole system.

THE ANALYTICAL PROGRAM

In my original paper on the Anderson Quin Cycle I necessarily made rather simple assumptions, as follows:

- 85% polytropic efficiency of compression.
- 85% polytropic efficiency of gas turbines.
- conservative efficiencies for the refrigeration cycle.
- turbine inlet temperature of 2000° F.
- air properties for the combustion products.
- no cooling air passed from the compressor directly into the turbine.
- no pressure drop in the refrigeration system, the combustor, or the boiler.

In this refined analysis we have assumed the following more accurate and current performance characteristics for all of the elements in the system.

- 88% compressor isentropic efficiency.
- 2000° F. and 2400° F. turbine inlet temperature, while present day turbines are operating up to 2400° F. turbine inlet temperature.
- 90% high pressure turbine isentropic efficiency.
- 90% power turbine isentropic efficiency.
- typical values of cooling air by-passed from the compressor for turbine cooling.
- 90% steam turbine isentropic efficiency (HP and LP).
- 90% vapor turbine isentropic efficiency.
- A program was developed to analyze the effects of the composition of flue gas on the thermodynamic properties of the flue gas. This required considerable time and effort, but was necessary for a more accurate evaluation of the cycle.

- In the present analysis, typical "ISO" conditions at the inlet to the system were assumed, namely 59° F. and 52° F. wet bulb temperature corresponding to 60% relative humidity. As an important attribute of this program, a reasonably accurate aero-thermal program was developed that defines the properties of combustion gases as a function of their chemical analysis and uses classical thermal dynamics for heat and evaluate balance, as well as mass continuity. Such a program has not been readily available, and the availability of this program now makes it possible to more accurately estimate the performance of combined cycles.

PERFORMANCE ANALYSIS

The Anderson Quin Cycle is applicable to virtually any gas turbine configuration, but a single spool design consisting of a compressor, combustor, and turbine driving the compressor was selected for establishing the performance comparisons presented in this report. Engine operating lines from a pressure ratio of 8 to 28 were analyzed, covering a spectrum of existing gas turbine systems, with each data point representing the design point for that respective gas turbine configuration. Consistent with industry standards, all thermal efficiency analysis is based on the lower heating value of the fuel.

In the industry, axial inlets with a total pressure loss of 3 to 6 inches of water are used for hot end drives, while voluted radial inlets with a loss of 4 to 12 inches of water are found in cold end drive applications. Most of the loss results from the foreign-object-damage protection systems, known as FOD screens.

Icing is another operational issue for existing gas turbines. Under atmospheric conditions, ice can form when the static wet bulb temperature drops below freezing. The lowest static temperature occurs at the highest Mach number which is usually at the FOD screen. Ice forming on the screen reduces the effective flow path area, increases the pressure loss and results in a higher pressure differential across the screen. At this point the gas turbine performance would be adversely affected by the change in pressure recovery. However, screen distress caused by the pressure differential, or ice shedding from the screen would pose an imminent hazard to the gas turbine mechanical integrity. Therefore, the FOD screen pressure differential is monitored, and if screen blockage or ice formation is suspected, the gas turbine is taken offline. The Anderson Quin Cycle refrigerated inlet system provides dry/clean air to the gas turbine inlet by precipitating most of the airborne particles relieving the FOD screen specifications, substantially improving pressure recovery and eliminating the threat of ice formation. For this reason, a clean inlet is assumed in all data.

The compressor isentropic efficiency is 88%, consistent with aero derivative engines. Non-chargeable parasitic flow is extracted at the compressor discharge, and the chargeable parasitic flow is extracted at a compressor stage required to ensure positive back-flow margin. The term "chargeable" refers to the flow not available for work in a turbine, and is therefore

a "chargeable" performance loss for that respective turbine. "Non-chargeable" refers to the flow reinjected before the turbine and therefore available for turbine work.

Current gas turbine configurations nominally require five to 12 percent chargeable and as much as 20% non-chargeable parasitic flow to maintain an adequate bulk metal temperature in the turbine components. The bulk metal temperature is related to the gas path flow and temperature, along with the parasitic flow and temperatures. With the inlet refrigerated to -60° F. , the temperature of the parasitic flow is reduced by approximately 300° F. relative to a standard day (See figure 1.0). Assuming nominal film cooling effectiveness, the flow requirements are reduced to 5% chargeable and 5% non-chargeable for the same bulk metal temperatures. For consistency, the same parasitic flows were assumed throughout the performance analysis. Because a relatively low level of parasitic flow was used in the performance data, the power turbine output reference from which all Anderson Quin Cycle performance analysis are calculated is optimistic by approximately 30%. For an example, refer to Table 2 with a pressure ratio of 8 and inlet temperature of 400° R. (-60° F.). The power turbine output is 199.2 BTU/lbm of inlet air. When the same gas turbine model is run with 10% chargeable and 20% non-chargeable flow, the deliverable power is 153 BTU/lbm. Therefore, the parasitic reduction to maintain constant bulk metal temperature results in a 30% net power improvement from 153 to 199.2 BTU/lbm, and a corresponding thermal efficiency improvement from .272 to .357. The performance improvement is evident at all operating lines as shown in Figure 2.0.

The gas turbine combustor performance consists of 99% efficiency and one percent total pressure loss. The available flow to the combustor inlet is 90% of the compressor inlet flow since 10% of the flow is extracted in the compressor for parasitic cooling. Aero derivative gas turbines operate at turbine inlet temperatures of approximately 2400° F. , while industrial gas turbines operate nominally as high as 2000° F. For this reason, baseline gas turbine data at 2000° F. is presented in Table 1, and 2400° F. in Table 2. The remaining Anderson Quin Cycle analyses and comparisons are based on a turbine inlet temperature of 2400° F. The turbine nozzle, positioned between the combustor discharge and the high pressure turbine inlet, is cooled by the non-chargeable parasitic flow, which is then mixed with the combustor discharge flow. The resulting gas path flow is in excess of 95% of the compressor inlet flow.

The high pressure turbine isentropic efficiency is assumed to be 90%, and the power required to drive the high pressure compressor is extracted from the high pressure turbine. The remaining parasitic flow, while used to cool the turbine blades, rotor, and other metal surfaces in the turbine assembly, is fully mixed with the gas path before the HP turbine exit. Because the gas turbine fuel to air ratio is approximately 2%, the resulting flow at the high pressure turbine discharge now is 102% of the compressor inlet flow.

The power turbine extracts exhaust energy and expands from the high pressure turbine exit to a pressure of 15 psia. The power turbine isentropic efficiency is 90%, which is conservative in comparison to the 91-94% turbine manufacturers' claims.

The analysis for the steam and vapor turbine cycles uses the flue gas products of the gas turbine with an inlet temperature of -60° F . The flue gas leaving the power turbine is used to superheat steam in the steam boiler. Table 3 shows the results of the steam turbine analysis for gas turbine pressure ratios from 8 to 28. For steam turbine optimization, two steam turbines were used, resulting in a net steam turbine output in excess of 30% over a single high expansion steam turbine. The steam superheat temperature was increased to 10° F . below the flue gas temperature, but was limited to 1000° F . for cases in which the flue gas was higher than 1010° F . ($p/p=8$ and 12). The high pressure steam turbine discharges to 200 psia, and the inlet pressure was then optimized for ideal expansion, resulting in saturated vapor at the high pressure turbine exit.

The steam is superheated again and mixed with additional superheated flow to a temperature for ideal expansion through the low pressure steam turbine. The total flow is then expanded through the low pressure steam turbine to saturated vapor at 20 psi absolute. A further analysis should be made, using 3 or more stages of steam inlet pressures, since this would increase the steam cycle efficiency.

The isobutane in the vapor turbine cycle is heated by both the latent heat of the condensing steam from the steam turbines and the residual flue gas energy. The vapor turbine analysis is presented in Table 4. The temperature of the saturated vapor steam was 227° F ., therefore the maximum isobutane temperature was 222° F . for a pinch point temperature difference of 5° F . The latent heat of the saturated steam is 960 BTU's per/lb of steam, which is given off to boil the isobutane resulting in saturated liquid water delivered

to the boiler feed pump, and superheated isobutane at the vapor turbine inlet. Additional energy is extracted from the flue gas to maximize the isobutane, and the resulting isobutane flow rate. Energy is removed from the flue gas to within 10°F. of the isobutane temperature at the feed pump discharge, resulting in a flue gas temperature of 88° F. The net power from the vapor turbine is 35 BTU's/lbm of inlet air at an engine pressure ratio of 8, lapsing to 25 BTU's/lbm of inlet air at a gas turbine pressure ratio of 28.

The component summaries are presented in Table 5. Note that the thermal efficiency of the Anderson Quin Cycle is as high as 62.9% at a pressure ratio of 28. All of the data presented up to this point is based on a unit of inlet air flow with standard atmospheric properties. Table 6 shows projected performance for inlet flows of 200, 300, 400 and 500 lbm/sec. As an example, on a 90° F. day with a gas turbine pressure ratio of 28 and an inlet air flow of 300 lb/per second the power turbine output is 73,729 HP. With nominal parasitics of 10% chargeable and 20% non-chargeable, the predicted power turbine output is approximately 51,954 HP. Refrigerating the inlet to -60° F. boosts the net power turbine output for the same pressure ratio to 99,706 HP. The steam turbine further increases the net power to 112,513 HP, and with a vapor turbine the total power output is 122,972 HP.

PERFORMANCE RESULTS

Refrigeration

The refrigerated inlet in the Anderson Quin Cycle dramatically reduces the compressor power thus enabling a considerably greater amount of heat input in the combustor for the same turbine temperatures. Referring to Figure 1.0 at a compression ratio of 28, refrigerating the inlet from 90° F. to -60° F. reduces the compressor discharge temperature from 1484° R. to 1079° R., for a net reduction of 405° F. Therefore 1° F. at the inlet is worth 2.7° F. at the compressor discharge. In terms of specific energy, the power into the compressor has been reduced from 254 BTU/lbm on a 90° F. day down to 179 BTU/lbm with a refrigerated inlet of -60° F. As a result the duty on the high pressure turbine to drive that compressor has been reduced an equivalent amount, and the residual energy savings is now available for the power turbine. The cost on a unit energy basis to refrigerate the inlet is 6.4 BTU/lbm of inlet flow.

The net energy available to the power turbine is more dramatically increased at the higher pressure ratios than at the lower pressure ratios as shown in Figure 1.3. Lines of constant pressure ratio are shown by the dashed lines. At a pressure ratio of 28 the compressor discharge temperature is 1484° R. with a net power turbine specific energy of 173.7 BTU/lbm of inlet air, lapsing to a compressor discharge temperature of 1079° R. and a net power turbine specific energy of 234.9 BTU/lbm of inlet air with an inlet temperature of -60° F. The energy balance now has been shifted from the high pressure turbine to the power turbine while the flue gas temperature exiting the power turbine is essentially the same with 1277° R. on a 90° F. inlet to 1279° R. with a -60° F. inlet for a difference of only 2° F. With the compressor discharge temperature being reduced by 300 to 400° F. for the operating range presented in this report, the heat input margin is increased for the same turbine inlet temperature.

A comparison of combustor energy input on both a 90° F. inlet and -60° F. inlet is shown in Figure 1.2. For a compressor pressure ratio of 28 on a 90° F. inlet the available combustor energy input is approximately 360 BTU/lbm of inlet air and on a refrigerated -60° F. inlet 461 BTU/lbm of inlet air.

The bulk metal temperature in the high pressure and low pressure turbines is a critical design issue in a gas turbine. The cooling flow required to maintain a given bulk metal temperature is extracted in the compressor as described under performance analysis. Because the parasitic or cooling flow is considerably cooler with the Anderson Quin Cycle, less flow is required with the same turbine gas path temperature to maintain the same constant bulk metal temperature. As a nominal estimate the chargeable flow for this study was reduced from 10% for a current gas turbine to 5% with the refrigerated inlet of the Anderson Quin Cycle, and the nominal 20% non-chargeable flow was reduced to 5%. At a turbine inlet temperature of 2400° F., the performance effects of the reduced parasitics are shown in Figure 2.0. At a compressor pressure ratio of 28 with nominal gas turbine parasitics, the net specific energy is approximately 122 BTU/lbm and a thermal efficiency of 34%, while with reduced parasitics as in the Anderson Quin Cycle, the net specific energy is 235 BTU/lbm and a thermal efficiency of 52%. For consistency, all further reference to simple cycle performance will be based upon the reduced parasitic levels.

The study was intended to cover a spectrum of existing gas turbines, therefore turbine inlet temperatures of both 2000° F. and 2400° F. are presented in this report. Many industrial gas turbines which were introduced into service prior to 1990 have turbine temperature limits of 2000° F. or less while more recent turbine design enhancements have pushed the turbine temperature limit to approximately 2400° F. All further comparisons and results assume a turbine inlet temperature of 2400° F.

High Pressure Steam Turbine With Ideal Expansion

In existing steam turbine configurations, the quality of the exiting steam is usually below 100% resulting in condensation and degraded performance of the last stages of the turbine. With the Anderson Quin Cycle the steam flow rate is adjusted such that ideal expansion occurs and the exit quality is at 100% saturated vapor. Figure 3.0 shows the steam turbine optimization for gas turbine pressure ratios of 8 and 12. Steam turbine optimization summary corresponding to a gas turbine pressure ratio of 8 or 12, the ideal inlet conditions are 2756 psia and 1000° F. expanding to saturated vapor at a pressure of 200 psia. The second optimization summary shows ideal conditions at the steam turbine inlet of 2711 psia and 995° F. again expanding to saturated vapor at a pressure of 200 psia.

Subsequent optimization summaries for pressure ratios of 16 and 20 are presented in Figure 3.1 while a pressure ratio of 28 is presented in Figure 3.2.

A detailed steam turbine analysis summary is presented in Table 3. Note that the pump work for both the high and low pressure turbine has been accounted for in the results. As shown in Table 3 the steam turbine power output is greater at the lower pressure ratios. At gas turbine compressor pressure ratio of 8 the steam turbine output is almost 81 BTU/lbm of inlet air lapsing to 30 BTU/lbm of inlet air at a gas turbine compressor pressure ratio of 28. The reason this occurs is because the power turbine exit enthalpy is considerably higher at the lower pressure ratios than at the higher pressure ratios as illustrated in Figure 4.0.

The bottom of the steam turbine cycle is consistently the same regardless of the flue gas temperature available to the steam boiler, because the steam turbine discharges to a constant pressure of 20 psia. The total steam to flue gas mass ratio is approximately 19% at a pressure ratio of 8 lapsing to approximately 10% at a gas turbine compressor pressure ratio of 28 and a corresponding flue gas temperature of 279° F. at the lower pressure ratio lapsing to 329° F. at the high pressure ratio. At this point with the refrigerated inlet and the steam turbine, the Anderson Quin Cycle has increased the combined cycle efficiency to almost 58% at a pressure ratio of 28 and over 50% throughout the gas turbine compressor pressure ratio range in this study, in comparison to the simple cycle efficiency with nominal parasitics of 26 to 34% with a 90° F. inlet. The corresponding combined cycle power output has increased by 123% at low pressure ratios and 117% at the high pressure ratios.

Vapor Turbine Results

As described in the performance analysis section the isobutane will be heated by 2 sources, the first is the latent heat of the steam which is discharging from the low pressure steam turbine and the second is the flue gas energy available exiting the low pressure steam boiler and entering the isobutane boiler. The steam saturation temperature at a pressure of 20 psia is 227° F., and with an approach point margin of 5° F., the isobutane temperature is 222° F. The latent heat in the steam will be removed in this first isobutane boiler such that saturated liquid water is delivered to the boiler feed pump. The remaining energy rejected by the flue gas to the isobutane will bring the flue gas temperature down to 88° F.

with a pinch point margin of 10° F. The mass ratio of isobutane to flue gas is optimized such that heat balance is maintained and ideal expansion is achieved through the vapor turbine. Equating this in terms of the gas turbine inlet mass flow, the isobutane to inlet air flow ratio is 1.3 at the low pressure ratios and approximately .9 at the higher pressure ratios resulting in a net power output of 35 BTU/lbm of inlet air lapsing to approximately 25 BTU/lbm of inlet air respectively. The combined cycle efficiency has now achieved 62.9% at a gas turbine compression ratio of 28 and 57.3% at a gas turbine pressure ratio of 8, corresponding to a net deliverable power increase of 137% and 151% respectively.

Overall Performance

Conservation of mass and energy was necessary for an accurate assessment of the performance of this combined cycle system. Tables 7 and 8 also show a composite of the heat balance for the heat transfer elements in the Anderson Quin Cycle.

Commercial aeroderivative engines today operate at a 3500 ft cruising altitude and Mach numbers of .6 to .7 which corresponds to approximately -50° F. so the thermal stresses associated with the Anderson Quin Cycle are not beyond the existing gas turbine operation. A consideration for further study is to investigate the aero stresses on the compressor associated with the denser air. The compressor operates on a volumetric basis and the air density is inversely propositional to the temperature. Therefore the mass flow per unit volume increases as a function of the density and the resulting compressor mass flow would increase. The aero stresses on the blades increase with massflow and either reducing the operating line or reducing the pumping capacity of the compressor could be required to relax the stresses.

Overall combined cycle performance of the Anderson Quin Cycle on a volumetric basis is presented in Appendix A, and massflow projections for existing gas turbine comparisons presented in Appendix B. The gas turbine operates on a volumetric basis, and therefore is more representative of the performance improvements to be realized with the Anderson Quin Cycle.

The Anderson Quin Cycle (As Reported)

The thermal efficiency of the above system is 62%, while the Bottoming Cycle will increase it further.

DRG 33-B-2

882
11/5/9.
P.14

The gas turbine component and overall performance data presented here were developed using the Mathematical Model "Gas-2000F-3A". The data is based on a unit of inlet airflow with standard atmospheric properties. Therefore, Enthalpy is present in BTU/Lbm(Inlet air), while HP is in Horsepower-Sec/Lbm(Inlet air).

Turbine Inlet Temperature: 2000°F

Assumptions	
Inlet Loss	Clean
Compressor Efficiency	0.88
Combustor Efficiency	0.99
Turbine Efficiency	0.9
Power Turbine Efficiency	0.9
Steam Turbine Efficiency	0.9
Vapor Turbine Efficiency	0.9
Combustor Pressure Loss	1%
Chargeable Parasitic Flow	5%
Non-Charg. Parasitic Flow	5%

Gas Turbine		COMPRESSOR				COMBUSTOR				TURBINE				POWER TURBINE						
T/R	P/P	Hi	ΔH	He	Te °R	ΔH/#ca	He	ΔH/#da	Te °R	Hi	ΔH	He	Te °R	ΔH	He	ΔH.refr.	ΔH.net	Te °R	HP	Eff.
400	8	84.6	92	176	753	478	655	430.2	2460	638	90	525	2019	158	367	6.4	151.6	1466	214.5	0.3524
	12	84.6	116	201	846	453	655	407.7	2460	638	114	502	1942	172	330	6.4	165.6	1335	234.3	0.4062
	16	84.6	136	221	919	434	655	390.6	2460	638	133	484	1878	178	306	6.4	171.6	1247	242.8	0.4393
	20	84.6	152	237	980	418	655	376.2	2460	638	150	468	1825	180	288	6.4	173.6	1184	245.6	0.4615
	24	84.6	167	251	1032	403	655	362.7	2460	638	164	455	1778	180	275	6.4	173.6	1134	245.6	0.4786
	28	84.6	179	264	1079	391	655	351.9	2460	638	176	443	1736	179	264	6.4	172.6	1093	244.2	0.4905
450	8	97.5	104	201	847	453	655	407.7	2460	638	102	514	1984	147	367	0	147	1467	208	0.3606
	12	97.5	132	229	952	425	655	382.5	2460	638	130	488	1893	158	330	0	158	1333	223.5	0.4131
	16	97.5	154	252	1034	403	655	362.7	2460	638	151	467	1821	162	305	0	162	1246	229.2	0.4467
	20	97.5	173	270	1102	384	655	345.6	2460	638	170	449	1759	161	288	0	161	1182	227.8	0.4659
	24	97.5	189	287	1161	368	655	331.2	2460	638	186	434	1706	159	275	0	159	1132	225	0.4801
	28	97.5	204	301	1214	354	655	318.6	2460	638	200	420	1658	157	264	0	157	1092	222.1	0.4928
500	8	110.3	116	227	941	428	655	385.2	2460	638	114	503	1946	136	367	0	136	1467	192.4	0.3531
	12	110.3	148	258	1058	396	655	356.4	2460	638	145	474	1844	145	329	0	145	1333	205.2	0.4068
	16	110.3	173	283	1149	372	655	334.8	2460	638	170	450	1762	145	305	0	145	1245	205.2	0.4331
	20	110.3	194	304	1225	351	655	315.9	2460	638	191	430	1692	142	288	0	142	1182	200.9	0.4495
	24	110.3	212	322	1290	332	655	298.8	2460	638	209	413	1631	138	275	0	138	1133	195.3	0.4618
	28	110.3	228	339	1349	316	655	284.4	2460	638	225	397	1577	134	264	0	134	1093	189.6	0.4712
550	8	123.1	129	252	1036	402	655	361.8	2460	638	127	492	1907	125	367	0	125	1466	176.9	0.3455
	12	123.1	164	287	1163	367	655	330.3	2460	638	161	459	1793	129	329	0	129	1332	182.5	0.3906
	16	123.1	192	315	1264	340	655	306	2460	638	189	433	1701	127	305	0	127	1245	179.7	0.4150
	20	123.1	215	338	1347	316	655	284.4	2460	638	212	411	1623	122	288	0	122	1183	172.6	0.4290
	24	123.1	235	358	1419	296	655	266.4	2460	638	232	391	1555	116	275	0	116	1134	164.1	0.4354
	28	123.1	254	377	1484	278	655	250.2	2460	638	250	374	1493	110	265	0	110	1095	155.6	0.4396

The gas turbine component and overall performance data presented here were developed using the Mathematical Model "Gas-2400F-3A". The data is based on a unit of Inlet airflow with standard atmospheric properties. Therefore, Enthalpy is present in BTU/Lbm(inlet air), while HP is in Horsepower*Sec/Lbm(Inlet air).

Turbine Inlet Temperature: 2400°F

Assumptions	
Inlet Loss	Clean
Compressor Efficiency	0.88
Combustor Efficiency	0.99
Turbine Efficiency	0.9
Power Turbine Efficiency	0.9
Steam Turbine Efficiency	0.9
Vapor Turbine Efficiency	0.9
Combustor Pressure Loss	1%
Chargeable Parasitic Flow	5%
Non-Charg. Parasitic Flow	5%

Gas Turbine		COMPRESSOR				COMBUSTOR				TURBINE				POWER TURBINE						
T/R	P/P	Hi	ΔH	He	Te °R	ΔH/#cal	He	ΔH/#da	Te °R	Hi	ΔH	He	Te °R	ΔH	He	ΔH.refr.	ΔH.net	Te °R	HP	Eff.
400	8	84.6	92	176	753	599.5	775.9	539.6	2860	755.9	90	638	2404	199.2	438.8	6.4	192.8	1722	272.8	0.3573
	12	84.6	116	201	846	574.8	775.9	517.3	2860	755.9	114	614.9	2315	219.7	395.3	6.4	213.3	1569	301.7	0.4122
	16	84.6	136	221	919	555.3	775.9	499.8	2860	755.9	134	596.7	2244	230.6	366	6.4	224.2	1465	317.2	0.4486
	20	84.6	152	237	980	538.9	775.9	485	2860	755.9	150	581.4	2188	237.6	343.8	6.4	231.2	1385	327.1	0.4767
	24	84.6	167	251	1032	524.6	775.9	472.1	2860	755.9	165	568	2148	240.2	327.8	6.4	233.8	1327	330.8	0.4952
	28	84.6	179	264	1079	511.8	775.9	460.6	2860	755.9	177	555	2112	241.3	314.7	6.4	234.9	1279	332.4	0.5100
450	8	97.5	104	201	847	574.5	775.9	517.1	2860	755.9	102	627.2	2363	188.6	438.6	0	188.6	1722	266.8	0.3648
	12	97.5	132	229	952	546.4	775.9	491.8	2860	755.9	130	601	2261	206.4	394.6	0	206.4	1566	292	0.4197
	16	97.5	154	252	1034	524.2	775.9	471.8	2860	755.9	152	580.2	2185	216.7	363.5	0	216.7	1456	306.6	0.4593
	20	97.5	173	270	1102	505.5	775.9	455	2860	755.9	171	562.6	2132	219.8	342.8	0	219.8	1381	311	0.4831
	24	97.5	189	287	1161	489.3	775.9	440.4	2860	755.9	187	547.4	2086	220.8	326.6	0	220.8	1323	312.4	0.5014
	28	97.5	204	301	1214	474.8	775.9	427.3	2860	755.9	202	533.8	2045	219.6	314.2	0	219.6	1277	310.7	0.5139
500	8	110.3	116	227	941	549.2	775.9	494.3	2860	755.9	114	616.2	2320	177.9	438.3	0	177.9	1721	251.7	0.3599
	12	110.3	148	258	1058	517.7	775.9	465.9	2860	755.9	146	586.7	2205	195	391.7	0	195	1556	275.9	0.4185
	16	110.3	173	283	1149	492.8	775.9	443.5	2860	755.9	171	563.3	2134	200.6	362.7	0	200.6	1453	283.8	0.4523
	20	110.3	194	304	1225	471.8	775.9	424.6	2860	755.9	192	543.6	2075	201.7	341.9	0	201.7	1378	285.4	0.4750
	24	110.3	212	322	1290	453.5	775.9	408.2	2860	755.9	210	526.4	2023	199.4	327	0	199.4	1324	282.1	0.4885
	28	110.3	228	339	1349	437.2	775.9	393.5	2860	755.9	226	511	1973	196.6	314.4	0	196.6	1278	278.2	0.4996
550	8	123.1	129	252	1036	523.7	775.9	471.3	2860	755.9	127	604.9	2276	166.8	438.1	0	166.8	1720	236	0.3539
	12	123.1	164	287	1163	488.7	775.9	439.8	2860	755.9	162	572.1	2160	181.3	390.8	0	181.3	1553	256.5	0.4122
	16	123.1	192	315	1264	461	775.9	414.9	2860	755.9	190	546	2082	184	362	0	184	1450	260.3	0.4435
	20	123.1	215	338	1347	437.7	775.9	393.9	2860	755.9	213	524.1	2016	181.4	342.7	0	181.4	1381	256.7	0.4605
	24	123.1	235	358	1419	417.4	775.9	375.7	2860	755.9	233	505	1952	177.9	327	0	177.9	1324	251.7	0.4736
	28	123.1	254	377	1484	399.2	775.9	359.3	2860	755.9	252	487.7	1893	173.7	314	0	173.7	1277	245.8	0.4835

TABLE 2

Steam Turbine Analysis

Gas Turbine Pressure Ratio		8	12	16	20	24	28
<u>HP Steam Turbine</u>							
P1	Psia	2,756.0	2,756.0	2,711.0	2,063.0	1,677.0	1,404.0
Temp - HPT Inlet Superheat	°F	1,000.0	1,000.0	995.0	915.0	857.0	809.0
Enthalpy - HPT Inlet Superheat	Btu/#s	1,449.9	1,449.9	1,451.0	1,416.8	1,393.9	1,374.8
Temp - HPT Inlet Saturation	°F	682.0	682.0	680.1	640.2	611.3	587.6
Enthalpy - Saturated Liquid	Btu/#s	764.0	764.0	757.7	679.0	633.5	599.2
Enthalpy - Saturated Vapor	Btu/#s	1,060.0	1,060.0	1,066.8	1,130.3	1,163.4	1,173.2
P2	Psia	200.0	200.0	200.0	200.0	200.0	200.0
Temp - HPT Exit	°F	381.8	381.8	381.8	381.8	381.8	381.8
Enthalpy - HPT Exit Superheat	Btu/#s	1,198.4	1,198.4	1,198.4	1,198.4	1,198.4	1,198.4
Temp - HPT Exit Saturation	°F	381.8	381.8	381.8	381.8	381.8	381.8
Enthalpy - Saturated Liquid	Btu/#s	355.4	355.4	355.4	355.4	355.4	355.4
Enthalpy - Saturated Vapor	Btu/#s	1,198.4	1,198.4	1,198.4	1,198.4	1,198.4	1,198.4
Δ Enthalpy (HP Turbine)	Btu/#s	251.5	251.5	252.6	218.4	195.5	176.4
<u>LP Steam Turbine</u>							
P1	Psia	200.0	200.0	200.0	200.0	200.0	200.0
Temp - HPT Inlet Superheat	°F	650.3	650.3	650.3	650.3	650.3	650.3
Enthalpy - HPT Inlet Superheat	Btu/#s	1,348.0	1,348.0	1,348.0	1,348.0	1,348.0	1,348.0
Temp - HPT Inlet Saturation	°F	381.8	381.8	381.8	381.8	381.8	381.8
Enthalpy - Saturated Liquid	Btu/#s	355.4	355.4	355.4	355.4	355.4	355.4
Enthalpy - Saturated Vapor	Btu/#s	1,198.4	1,198.4	1,198.4	1,198.4	1,198.4	1,198.4
P2	Psia	20.0	20.0	20.0	20.0	20.0	20.0
Temp - HPT Exit	°F	227.0	227.0	227.0	227.0	227.0	227.0
Enthalpy - HPT Exit Superheat	Btu/#s	1,156.0	1,156.0	1,156.0	1,156.0	1,156.0	1,156.0
Temp - HPT Exit Saturation	°F	227.0	227.0	227.0	227.0	227.0	227.0
Enthalpy - Saturated Liquid	Btu/#s	196.1	196.1	196.1	196.1	196.1	196.1
Enthalpy - Saturated Vapor	Btu/#s	1,156.0	1,156.0	1,156.0	1,156.0	1,156.0	1,156.0
Δ Enthalpy (LP Turbine)	Btu/#s	192.0	192.0	192.0	192.0	192.0	192.0
<u>Flue Gas Analysis</u>							
Temp - HP Steam Boiler Inlet	°F	1,262.0	1,109.0	1,005.0	925.0	867.0	819.0
Temp - HP Steam Boiler Exit	°F	692.0	692.0	690.1	650.2	621.3	597.6
Temp - LP Steam Boiler Exit	°F	391.8	391.8	391.8	391.8	391.8	391.8
ΔH.flue gas (HP Steam Boiler)	Btu/#s	151.6	110.9	83.8	73.1	65.4	58.9
ΔH.flue gas (LP Steam Boiler)	Btu/#s	79.9	79.9	79.3	68.7	61.0	54.7
<u>Simultaneous Eq's</u>							
A1		835.5	835.5	842.9	887.4	910.0	925.2
A2		408.6	408.6	402.3	323.6	278.1	243.8
Ax1		149.6	149.6	149.6	149.6	149.6	149.6
Ax2		843.0	843.0	843.0	843.0	843.0	843.0
Factor		2.0448	2.0448	2.0952	2.7423	3.2722	3.7945
#LP-steam(Added)/#-Flue Gas		0.0074	0.0333	0.0510	0.0534	0.0515	0.0488
#HP-steam/#-Flue Gas		0.1801	0.1268	0.0903	0.0734	0.0634	0.0558
#LP-steam/#-Flue Gas		0.1876	0.1601	0.1413	0.1267	0.1149	0.1046
HPT Specific Energy (Gross)	Btu/#a	46.21	32.53	23.27	16.35	12.63	10.03
LPT Specific Energy (Gross)	Btu/#a	36.73	31.35	27.68	24.82	22.50	20.48
Pump work #1	Btu/#a	1.95	1.38	0.96	0.59	0.42	0.31
Pump work #2	Btu/#a	0.01	0.02	0.04	0.04	0.04	0.03
<u>Results</u>							
Net Specific Energy	Btu/#a	80.98	62.48	49.95	40.53	34.68	30.17
Te.flue gas °F	°F	279.48	295.94	307.15	315.90	323.01	329.17

TABLE 3

Vapor Turbine Analysis

Gas Turbine Pressure Ratio		8.00	12.00	16.00	20.00	24.00	28.00
Steam Latent Heat	Btu/#s	960.00	960.00	960.00	960.00	960.00	960.00
Steam/Flue Gas Mass Ratio		0.1876	0.1601	0.1413	0.1267	0.1149	0.1046
Flue Gas/Inlet Air Mass Ratio		1.0200	1.0200	1.0200	1.0200	1.0200	1.0200
Specific Heat of Flue Gas	Btu/#fg	0.2660	0.2660	0.2660	0.2660	0.2660	0.2660
Flue Gas Source Temp	°F	279.48	295.94	307.15	315.90	323.01	329.17
Isobutane Temp after Feedpump	°F	78.00	78.00	78.00	78.00	78.00	78.00
Isobutane Enthalpy after Feedpump	Btu/#IC4	62.96	62.96	62.96	62.96	62.96	62.96
Flue Gas Exit Temp	°F	88.00	88.00	88.00	88.00	88.00	88.00
Vapor Turbine Inlet Enthalpy	Btu/#IC4	244.45	244.45	244.45	244.45	244.45	244.45
Vapor Turbine Exit Enthalpy	Btu/#IC4	212.68	212.68	212.68	212.68	212.68	212.68
#-Isobutane/#-Inlet Air		1.2982	1.1745	1.0902	1.0245	0.9711	0.9247
Results							
Gross Ideal Power	Btu/#a	41.24	37.31	34.64	32.55	30.85	29.38
Efficiency		0.90	0.90	0.90	0.90	0.90	0.90
Gross Power	Btu/#a	37.12	33.58	31.17	29.29	27.77	26.44
Feedpump work	Btu/#a	1.80	1.80	1.80	1.80	1.80	1.80
Net Power	Btu/#a	35.32	31.78	29.37	27.49	25.97	24.64

TABLE 4

The gas turbine component and overall performance data presented here were developed using the Mathematical Model "Gas-2400F-3A". The data is based on a unit of inlet airflow with standard atmospheric properties. Therefore, Enthalpy is presented in BTU/Lbm(Inlet air), while HP is in Horsepower-Sec/Lbm(Inlet air).

Turbine Inlet Temperature: 2400°F

Assumptions	
Inlet Loss	Clean
Compressor Efficiency	0.88
Combustor Efficiency	0.99
Turbine Efficiency	0.9
Power Turbine Efficiency	0.9
Steam Turbine Efficiency	0.9
Vapor Turbine Efficiency	0.9
Combustor Pressure Loss	1%
Chargeable Parasitic Flow	5%
Non-Charg. Parasitic Flow	5%

Gas Turbine		POWER TURBINE							Steam Turbine					Vapor Turbine				
TR	P/P	ΔH	He	ΔH.refr.	ΔH.net	Te °R	HP	Eff.	ΔH	ΔHn	Eff.	TeR	ΔH	ΔHn	Eff.	TeR		
400	8	199.2	438.8	6.4	192.8	1722	272.8	0.3573	80.98	273.8	0.507	739.5	35.32	309.1	0.5729	548.0		
	12	219.7	395.3	6.4	213.3	1569	301.7	0.4122	62.48	275.7	0.533	755.9	31.78	307.5	0.5944	548.0		
	16	230.6	366	6.4	224.2	1465	317.2	0.4486	49.95	274.2	0.549	767.2	29.37	303.5	0.6073	548.0		
	20	237.6	343.8	6.4	231.2	1385	327.1	0.4767	40.53	271.7	0.56	775.9	27.49	299.2	0.6169	548.0		
	24	240.2	327.8	6.4	233.8	1327	330.8	0.4952	34.68	268.5	0.569	783	25.97	294.4	0.6236	548.0		
	28	241.3	314.7	6.4	234.9	1279	332.4	0.5100	30.17	265.1	0.575	789.2	24.64	289.7	0.6290	548.0		
550	8	166.8	438.1	0	166.8	1720	236	0.3539										
	12	181.3	390.8	0	181.3	1553	256.5	0.4122										
	16	184	362	0	184	1450	260.3	0.4435										
	20	181.4	342.7	0	181.4	1381	256.7	0.4605										
	24	177.9	327	0	177.9	1324	251.7	0.4736										
	28	173.7	314	0	173.7	1277	245.8	0.4835										

TABLE 5

Inlet Airflow Derivatives

20% Non-Chargeable, 10% Chargeable

(Current Gas Turbines)

Power Turbine (+90°F)			Power Output (HP)			
P/P	ΔBtu/Lbm	ΔHP•Sec/Lbm	200 Lbm/sec	300 Lbm/sec	400 Lbm/sec	500 Lbm/sec
8	123	174	34,891	52,336	69,781	87,227
12	132	187	37,466	56,199	74,932	93,665
16	133	189	37,749	56,623	75,498	94,372
20	131	186	37,155	55,732	74,309	92,886
24	127	180	36,051	54,076	72,102	90,127
28	122	173	34,636	51,954	69,272	86,590

5% Non-Chargeable, 5% Chargeable

Power Turbine (+90°F)			Power Output (HP)			
P/P	ΔBtu/Lbm	ΔHP•Sec/Lbm	200 Lbm/sec	300 Lbm/sec	400 Lbm/sec	500 Lbm/sec
8	167	236	47,200	70,800	94,400	118,000
12	181	257	51,303	76,955	102,607	128,258
16	184	260	52,067	78,101	104,135	130,168
20	181	257	51,332	76,997	102,663	128,329
24	178	252	50,341	75,512	100,682	125,853
28	174	246	49,153	73,729	98,305	122,882

5% Non-Chargeable, 5% Chargeable

Power Turbine (-60°F)			Power Output (HP)			
P/P	ΔBtu/Lbm	ΔHP•Sec/Lbm	200 Lbm/sec	300 Lbm/sec	400 Lbm/sec	500 Lbm/sec
8	193	273	54,557	81,836	109,115	136,394
12	213	302	60,347	90,521	120,694	150,868
16	224	317	63,443	95,164	126,886	158,607
20	231	327	65,424	98,136	130,847	163,559
24	234	331	66,159	99,239	132,319	165,399
28	235	332	66,471	99,706	132,941	166,177

5% Non-Chargeable, 5% Chargeable

Steam Turbine (-60°F)			Power Output (HP)			
P/P	ΔBtu/Lbm	ΔHP•Sec/Lbm	200 Lbm/sec	300 Lbm/sec	400 Lbm/sec	500 Lbm/sec
8	274	387	77,474	116,211	154,948	193,685
12	276	390	78,027	117,040	156,054	195,067
16	274	388	77,578	116,367	155,156	193,945
20	272	384	76,894	115,341	153,788	192,235
24	268	380	75,972	113,958	151,943	189,929
28	265	375	75,009	112,513	150,017	187,521

5% Non-Chargeable, 5% Chargeable

Vapor Turbine (-60°F)			Power Output (HP)			
P/P	ΔBtu/Lbm	ΔHP•Sec/Lbm	200 Lbm/sec	300 Lbm/sec	400 Lbm/sec	500 Lbm/sec
8	309	437	87,468	131,202	174,936	218,670
12	308	435	87,020	130,530	174,041	217,551
16	304	429	85,890	128,834	171,779	214,724
20	299	423	84,674	127,011	169,348	211,685
24	294	417	83,319	124,979	166,639	208,299
28	290	410	81,981	122,972	163,963	204,954

TABLE 6

Gas Turbine Heat Balance

P/P = 12

	Primary Flow				Secondary Flow		
	Flow Lbm/Sec	Temp °F	Enthalpy Btu/Lbm	Power Btu/Sec	Flow Lbm/Sec	Temp °F	Enthalpy Btu/Lbm
<u>Compressor</u>							
Gas Path (Inlet)	1	-60	84.6	0.0			
Interstage	0.95	314	181.8	97.2			
Gas Path (Exit)	0.9	386	201.0	115.4			
<u>Combustor</u>							
Gas Path (Inlet)	0.9	386	201.0				
Gas Path (Exit)	0.92	2400	775.9	" 1 "			
<u>Mixed Product</u>	0.97	2335	755.9				
<u>HP Turbine Inlet</u>							
Gas Path (Inlet)	0.97	2335	755.9	733.2			
Comp. Power				-115.4			
Gas Path (Exit)	0.97	****	636.9	617.8			
<u>Mixed Product</u>	1.02	1855	614.9				
<u>Gross Turbine Power</u>				219.6			
Refrigerated Inlet				-6.4			
<u>Net Turbine Power</u>				213.2			
<u>Gas Turbine Exhaust</u>	1.02	1109	395.3				

Notes:

" 1 " The Heat input of 574.9 (775.9-201) is based on a per pound of combustion air, which translates to 517.3 BTU/# of compressor inlet air.

The thermal efficiency for the above heat balance is as follows:

Thermal Eff. = Net Power Out / Total Heat in

Thermal Eff. = 213.2 / 517.3 = .412

TABLE 7

P/P = 12

Page 41

Refrigerated Inlet Effects

Figure 1.0

WNB-2400-PLT.6.0

Figure 1.1

Refrigerated Inlet Effects

Figure 1.2

Refrigerated Inlet Effects on Power Turbine

WMB-2400-PLT.8.0

Figure 1.3

Parasitic Flow Effects Constant Turbine Bulk Metal Temperature

WMB-2400-PLT.9.0

Figure 2.0

Turbine Inlet Temperature Analysis Power Turbine Only

WMB-XXXX-Plt.1.0

Figure 2.1

SUMMARY				
GIVEN:	INLET	EXIT	INLET	EXIT
PRESSURE (PSIA)	2756	200		
TEMP. (DEGF)	900			
TURB. EF. (%)	90			
	IDEAL	RESULTS	ACTUAL	
PRESSURE (PSIA)	2756	200		
TEMP. (DEGF)	999.9664	381.7903		
TURB. EF. (%)	100		90	
ENTHALPY	1449.932	1170.47	1449.932	1198.41
ENTROPY	1.512086	1.512086	1.512086	1.5452
QUALITY	100	91.46678	100	99.9997
DELTA H (BTU/LBM)	279.4616		251.5154	

ANOTHER CASE (Y/N)?

SUMMARY				
GIVEN:	INLET	EXIT	INLET	EXIT
PRESSURE (PSIA)	2711	200		
TEMP. (DEGF)	990			
TURB. EF. (%)	90			
	IDEAL	RESULTS	ACTUAL	
PRESSURE (PSIA)	2711	200		
TEMP. (DEGF)	994.9749	381.7903		
TURB. EF. (%)	100		90	
ENTHALPY	1447.989	1170.672	1447.989	1198.41
ENTROPY	1.512326	1.512326	1.512326	1.5452
QUALITY	100	96.47199	100	99.998
DELTA H (BTU/LBM)	277.3168		249.5851	

ANOTHER CASE (Y/N)?

Figure 3.0

SUMMARY				
GIVEN:	INLET	EXIT	INLET	EXIT
PRESSURE (PSIA)	2063	200		
TEMP. (DEGF)	910			
TURB. EF. (%)	90			
	IDEAL	RESULTS	ACTUAL	
PRESSURE (PSIA)	2063	200		
TEMP. (DEGF)	914.8743	381.7903		
TURB. EF. (%)	100		90	
ENTHALPY	1416.758	1174.142	1416.758	1198.403
ENTROPY	1.516448	1.516448	1.516448	1.545278
QUALITY	100	96.87856	100	99.99818
DELTA H (BTU/LBM):	242.6162		218.3546	

ANOTHER CASE (Y/N)?

SUMMARY				
GIVEN:	INLET	EXIT	INLET	EXIT
PRESSURE (PSIA)	1677	200		
TEMP. (DEGF)	850			
TURB. EF. (%)	90			
	IDEAL	RESULTS	ACTUAL	
PRESSURE (PSIA)	1677	200		
TEMP. (DEGF)	856.8516	381.7903		
TURB. EF. (%)	100		90	
ENTHALPY	1393.893	1176.674	1393.893	1198.396
ENTROPY	1.519458	1.519458	1.519458	1.54527
QUALITY	100	97.06898	100	99.99734
DELTA H (BTU/LBM):	217.2185		195.4967	

ANOTHER CASE (Y/N)?

Figure 3.1

SUMMARY					
GIVEN:		INLET	EXIT	INLET	EXIT
PRESSURE (PSIA)		1404	200		
TEMP. (DEGF)		805			
TURB. EF. (%)			90		
		IDEAL	RESULTS		ACTUAL
PRESSURE (PSIA)		1404	200		
TEMP. (DEGF)		808.932	381.7903		
TURB. EF. (%)		100		90	
ENTHALPY		1374.865	1178.799	1374.865	1198.406
ENTROPY		1.521983	1.521983	1.521983	1.545281
QUALITY		100	97.46564	100	99.99848
DELTA H (BTU/LBM)			196.0656		176.459

ANOTHER CASE (Y/N)?

Figure 3.2

Steam Turbine Analysis

WMB-2400-PLT.11.0

Figure 3.3

Flue Gas Temperature Analysis

Vapor Turbine Analysis

Figure 5.0

RECOMMENDATIONS

1. Investigate the possibilities for applying the Anderson Quin Cycle to a specific simple cycle turbine. Although present day turbines are not generally suited to operate at inlet temperatures as low as -60° F. , and are not designed to achieve maximum efficiencies at these conditions, the first step appears to be to find out whether some of these turbines can at least take advantage of operation to a reasonably low refrigerated temperature.
2. The performance analysis should be made for the cycle at ambient air temperature of 90° F. The improvement in performance over other cycles should be more dramatic at summer conditions, when gas turbine output is normally lowest.
3. Proceed with a detailed design of turbines suitable for optimization of the Anderson Quin Cycle. This involves compressor, turbine, and combustor design. For example the volumetric flow to the gas turbine in relation to the volumetric flow through the compressor will change considerably. Probably the most immediate approach would be to reduce or eliminate one or several stages from the inlet to the compressor, thereby reducing the inlet flow to match the mass flow of the turbine at the operating temperature.
4. Evaluate the design changes required for large quantities of water injection. Injecting large quantities of water makes the Anderson Quin Cycle power output considerably higher.
5. Design refinement of exhaust gas heat recovery in the gas coolers, heat transfer systems, etc. In the present study, we did not have sufficient time to optimize the gas cooler and heat pump system. This was shown in the original paper to increase cycle efficiency slightly, as well as recover more water from the exhaust gas. We also have now discovered a method for removing nitrogen oxides from the gas and converting them to useful fertilizer. This requires further detailed investigation.

6. Optimization of cost by refinement of the heat transfer system typically in the water and isobutane heaters, the boiler condenser, and on air cooled condensing systems should be done.
7. In our analysis, we did not have the time to evaluate the most refined and efficient steam turbine cycles that can be applied to the Anderson Quin Cycles. It is possible to improve the steam turbine cycles by incorporating various degrees of staging of the cycles and of using reheat. These are typical of modern steam power cycles, but there was not sufficient time to make these refinements in the present study.
8. Investigate the possible increase in burning temperature in the combustor. Since nitrogen oxides can now be removed in the exhaust system, it becomes feasible to raise the burning temperature. Also, since compressor discharge air is much lower in temperature in the Anderson Quin Cycle it is possible to consider more cooling of the walls of the combustor, thereby permitting higher operating temperatures. Repeat the performance analysis based on the higher turbine inlet temperature.
9. More exploratory work needs to be done for the removal of nitrogen oxides from the exhaust gas. This process appears to be straight forward and very promising, but actual demonstration systems should be built. This evaluation is important in the sense that it determines whether or not the Anderson Quin Cycle can be immediately useful, and can remove nitrogen oxides more effectively than other systems.
10. Since the water injected into the combustor is condensed and recovered at the cold end of the cycle, it is advisable to evaluate the necessary water treatment needed to permit reinjection of this water into the combustor.
11. A cost estimate for a typical Anderson Quin Cycle power plant should be made. The great increase in power output should assure good economics for the cycle.

SIGNIFICANCE OF THE ANDERSON QUIN CYCLE

In the February issue of "Electric Light and Power" an article indicated that the natural gas supply in the United States is virtually inexhaustible. More specifically the article states that there is a 70 year supply at current usage rate. If, as indicated, the Anderson Quin Cycle achieves efficiencies of 62% compared to the present 52% for combined cycles, then this 70 years should obviously be increased to 83 years. This of course assumes that all of the natural gas is used for electric power generation with gas turbine systems.

The next step is to consider the effect on home heating. If we can generate electric power at efficiencies of 62% from natural gas, then it becomes logical to use the natural gas to generate electricity, and in turn use electrically operated heat pumps to heat homes, rather than to burn natural gas to heat our homes.

A simple example will show why this is a logical step. If natural gas heat is converted to electricity at an efficiency of 62%, and then the electricity is used in the heat pump at an average coefficient of performance of two, then the ratio of the heat input to a home to the heat available from natural gas = $.62 \times 2 = 1.24$. In other words a home heated by a heat pump would then have a coefficient of performance of 1.24 times the heat available from burning natural gas. If we heat homes by direct combustion of natural gas at an efficiency of 80%, then the system using the Anderson Quin Cycle and an electric heat pump produces 1.24 over .8 or 1.55 times as much heat for each unit of natural gas as that produced by burning the natural gas directly in the home.

Another important aspect of using the Anderson Quin Cycle is the fact that this conserves water. Water is an increasingly rare commodity, and often a limiting factor for the location of power generation plants. The Anderson Quin Cycle recovers water from the system, and uses air cooled condensers. This eliminates the need for a large water supply for a power plant.

It should also be noted that the Anderson Quin Cycle will release far less carbon into the atmosphere than any other fuel burning cycle except for hydrogen. Hydrogen would also be an ideal fuel for the Anderson Quin Cycle.

At 62% thermal efficiency, with methane fuel the Anderson Quin Cycle would discharge 69,000 metric tons of carbon per year from a 100 MW power plant. As shown in Ref.4 this is only 32% of the carbon discharged from a coal fired power plant.

It is now largely the consensus of scientists that carbon dioxide in the atmosphere is the most important factor in generating what could be a disastrous change in climate. This could be one of the most important benefits of the Anderson Quin Cycle.

Recent successful gas turbine operation (Ref. 5) with direct burning of wood chips opens tremendous opportunities for using biomass as an energy source. The Anderson Quin Cycle will not only improve the efficiency of such power plants, but also permits effective removal of harmful combustion products.

We acknowledge and appreciate the comments and helpful data provided by several gas turbine manufacturers, such as Solar Turbines, General Electric, Pratt and Whitney, and ABB. These comments were useful in more clearly defining problems and operating conditions for typical gas turbines.

REFERENCES

1. **The Refrigerated Gas and Vapor Turbine Cycle**
By: Anderson and Laucks - ASME Paper 87-GT-152

2. **The Anderson Quin Cycle**
By: J. H. Anderson - Feb. 1989

3. **Gas Supplies Called Virtually Inexhaustible**
Electric Light and Power Magazine - Feb. 1993

4. **Effects of Power Generation on the Carbon Cycle**
By: J. H. Anderson - Sept. 1990

5. **"1993 Technology Report, International Gas Turbine Institute**
Aerospace Research Corporation Report
By: J. T. Hamrick

6. **Waste Heat Boiler Deskbook**
By: V. Ganapathy, 1991

APENDIX A

Anderson Quin Cycle Volumetric Performance

Quin Cycle Volumetric Analysis

Quin Cycle Volumetric Analysis

Quin Cycle Volumetric Analysis

Quin Cycle Volumetric Analysis

Quin Cycle Volumetric Analysis

Quin Cycle Volumetric Analysis

APENDIX B

Anderson Quin Cycle Massflow Projections

Inlet Airflow Derivatives 200 Lbm/Sec

Inlet Airflow Derivatives 300 Lbm/Sec

Inlet Airflow Derivatives 400 Lbm/Sec

Inlet Airflow Derivatives 500 Lbm/Sec

Inlet Airflow Derivatives
200 Lbm/Sec

Inlet Airflow Derivatives 300 Lbm/Sec

Inlet Airflow Derivatives 400 Lbm/Sec

Inlet Airflow Derivatives 500 Lbm/Sec

Inlet Airflow Derivatives -60°F Inlet

reprint + preprints removed.

END

**DATE
FILMED**

4 / 19 / 93