DOE/MC/11076--3199

DE93 000238

**Study of the Combustion of
Low Rank Coal in a Fluidized Bed**

Topical Report

**Ronal Glaser
R.W. Grimes**

September 1991

Work Performed Under Contract No.: DE-FC21-86MC11076

For
U.S. Department of Energy
Office of Fossil Energy
Morgantown Energy Technology Center
Morgantown, West Virginia

By
University of Wyoming
Western Research Institute
Laramie, Wyoming

MASTER

do
DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831; prices available from (615)576-8401, FTS 626-8401.

Available to the public from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

**Study of the Combustion of
Low Rank Coal in a Fluidized Bed**

Topical Report

**Ronal Glaser
R.W. Grimes**

Work Performed Under Contract No.: DE-FC21-86MC11076

**For
U.S. Department of Energy
Office of Fossil Energy
Morgantown Energy Technology Center
P.O. Box 880
Morgantown, West Virginia 26507-0880**

**By
University of Wyoming
Western Research Institute
P.O. Box 3395
University Station
Laramie, Wyoming 82071**

September 1991

TABLE OF CONTENTS

	<u>Page</u>
LIST OF TABLES AND FIGURES.....	iii
EXECUTIVE SUMMARY.....	iv
INTRODUCTION.....	1
EXPERIMENTAL	2
Equipment.....	2
Instrumentation and Data Acquisition.....	4
Procedure.....	6
RESULTS	8
DISCUSSION	12
CONCLUSIONS	17
ACKNOWLEDGEMENTS.....	18
DISCLAIMER.....	18
REFERENCES	19

LIST OF TABLES AND FIGURES

<u>Table</u>	<u>Page</u>
1. Combustion Run Summary.....	8
2. Combustion Run Summary--Baffled Beds.....	10
3. Proximate Analyses.....	11
4. Ultimate Analyses.....	12
5. Feed Coal Size.....	14
6. Fraction of Coal Consumed in Fluid Bed.....	14

<u>Figure</u>	<u>Page</u>
1. Fluidized Bed Combustor Design.....	3
2. Fluidized Bed Combustor System.....	5
3. Baffle Types.....	7

EXECUTIVE SUMMARY

This report describes the results of preliminary combustion tests performed with Eagle Butte Coal in a bubbling, fluidized-bed combustion system. The system was designed for the combustion of low-rank coals and industrial wastes. The work, as proposed, was aimed at not only the evaluation of co-firing of waste material with coal, but also at developing modifications to first generation bubbling bed designs to improve the combustion performance during co-firing. However, the funding for the work was redirected and the combustion tests were suspended soon after the shakedown testing was completed. Consequently, this report describes the results of the tests completed prior to the redirection of the effort and funding.

A total of 33 combustion tests were performed in a 6-inch diameter fluidized-bed combustor. Oxygen concentrations were measured at two points in the system; the vent line and at the interface between the fluid bed and the freeboard. These measurements provided a measure of the amount of conversion of coal within the fluidized bed compared to the conversion in the freeboard region. Typically, 75 to 80% of the conversion occurred within the bed. Several experiments were performed in which special bed internals were placed in the bed. The internals were designed to reduce bubble size in the bed thus increasing the surface area of the bubbles and hence promoting oxygen diffusion into the emulsion phase. Temperature measurements indicated that when internals were present in the bed, a plug-flow component was added to the normally backmixed fluid-bed flow field. The data from combustion tests performed with the bed internals are insufficient to clearly establish whether an increase in the volumetric heat release rate was achieved.

Since the effort and funding were redirected, no co-firing tests were performed.

INTRODUCTION

The United States Department of Energy (DOE) Office of Fossil Energy is supporting the development of environmentally acceptable means of using coal and coal-derived fuels to reduce United States dependence on foreign oil. Fluidized-bed combustion (FBC) of coal has been recognized as a viable technology for displacing reliance on oil. The goal of the DOE FBC program is to establish an engineering technology base that can be used to build and operate coal-fired FBC systems in the utility, industrial, and commercial sectors.

In the past decade, the FBC technology has matured enough that at present, a number of boiler manufacturers are offering commercially guaranteed, first-generation, large utility and industrial size atmospheric pressure fluidized-bed combustion (AFBC) units. To resolve the remaining technical issues and to potentially broaden the market sector served by AFBC, DOE is pursuing advanced concepts (second generation AFBC). This second-generation AFBC technology will serve small industrial, commercial, and larger residential applications.

The nation consumes a large quantity of energy in tens of thousands of small commercial, institutional, and light industrial installations. These small installations (less than 50,000 lb/hr steam) meet the needs of a wide variety of users. The cost differential between petroleum derived fuels and coal together with significant advances in AFBC design and operation, will make AFBC in smaller applications very competitive.

In order to facilitate the development of AFBC technology, to meet the needs of this sector, DOE has formulated several goals. For the second generation AFBC systems these goals have recently been published (Botros 1990), and are listed below:

- decreased capital and operating costs 20 to 30% lower than that of conventional or first-generation AFBC technology; economically competitive with oil and gas units
- two-year payback on capital investment compared with oil-fired units (cheaper fuel off-setting higher investment and operating cost)
- compliance with existing and proposed industrial pollution standards
- increased volumetric heat release rate above 500,000 Btu/hr/ft³
- simplified fuel feeding to handle as-received coal with minimum preparation
- increased boiler thermal efficiency to 90+%
- rapid start-up with an improved turndown ratio approaching 4:1
- sufficient automation to require only one operator per shift
- extended fuel flexibility range

For special AFBC application (boilers producing less than 50,000 lb/hr steam):

- economically competitive with oil- and gas-fired units
- payback of 3 to 4 years or less for commercial and institutional units compared with oil firing
- payback of 4 years or less for residential units compared with oil firing
- total packaged system
- load following and rapid start-up
- coal-based fuel
- environmental acceptability
- high reliability and low maintenance

Capital and operating cost competitiveness can in part be achieved by increasing the volumetric heat release rate within the bed area. Increased heat release rates reduce the size of the unit thus making the technology attractive for small scale users.

A test project was funded by DOE at Western Research Institute (WRI) to explore the possibility of co-firing industrial wastes with coal. One segment of this program was to investigate the use of bed internals to increase the volumetric heat release rate. The rationale behind the concept was that appropriately designed internals, when placed in the bed will reduce the size of the bubbles, thus increasing mixing and bubble surface area for oxygen diffusion. Internals also offer a means for increasing the residence time of the fuel particles in the bed, thus increasing the fraction of heat release in the bed (fines utilization and co-firing).

EXPERIMENTAL

A series of combustion tests was conducted in WRI's 6-inch diameter bubbling AFBC unit. The coal used was obtained from Eagle Butte Mine in the Powder River Basin, near Gillette, Wyoming.

Equipment

The WRI fluidized-bed combustor is a modular unit consisting of a series of alumina-bubble-castable, refractory-lined, 8-inch-diameter, 16-inch high, mild steel, spool pieces (Figure 1). This sectional design allows for easy maintenance and modification. Although the current test program called for atmospheric operation, the unit is designed to operate at pressures up to 200 psi. The distributor, made from 3/16-inch-thick stainless steel plate is a simple perforated plate design, with 3/32-inch-diameter holes drilled with a one-inch pitch. A typical combustion bed without baffles is 8 inches deep unexpanded and is composed of silica sand particles approximately 1/16-inch in diameter.

Figure 1. Fluidized Bed Combustor Design

Type 316 stainless steel, water-cooled tubes are immersed in the bed to control temperature. The 16-inch high bed spool piece allows stable fluidized beds up to 16 inches deep with the appropriate bed internals. Two more spool pieces, plus a flange with an end-cap welded to it make the freeboard section. A 1.5-inch collar is welded to the exhaust gas piping at the center of the end-cap to allow the installation of an internal 4-inch fly-ash recycle cyclone.

Air is fed to the combustor from a rotary blower through a manually operated control valve into the wind box at the base of the unit (Figure 2). Coal is fed to the unit from a lockhopper using a variable-speed feed screw. The flue gas leaves the combustor at the top and enters a 4-inch diameter tangential cyclone for coarse particle removal. The gas then passes through an air-cooled heat exchanger to the bag filters, for particulate clean-up and is then vented to the atmosphere.

Instrumentation and Data Acquisition

Temperatures are measured at the inlet and outlet of each unit operation in the system and at several points in the bed and freeboard using standard type-K chromel-alumel thermocouple junctions.

Absolute pressure is measured using a gauge and transducer at the air inlet. Differential pressures are measured across the distributor plate, fluid bed, and bag filters using transducers. The fluid-bed differential pressure is also monitored with a water manometer.

The total air delivery to the combustor is measured using a calibrated mass-flow meter with a linear range from 0-50 scfm. Sweep air to the coal feeder is measured with a rotameter with a range of 0-3 scfm.

Oxygen meters are employed to monitor the oxygen content in the gas at the bed-freeboard interface and in the flue gases leaving the bag filters.

Solids flows are not measured continuously. An approximate feed rate is set based upon a predetermined calibration curve for the variable speed screw. Actual full-run amounts of fly ash, bed ash, bag filter ash, and coal fed are determined after each test by before and after weights.

The cooling-water flow rate is measured using a rotameter.

Temperatures, transducer outputs, air flow rate, and oxygen concentrations are displayed on a computer screen every minute and recorded every five minutes using a PC-based, data-acquisition system. Hard-copy printouts are produced every hour. Gas chromatographic analysis results from samples taken at the freeboard-bed interface and the vent are recorded in the log book.

Figure 2. Fluidized Bed Combustor System

Procedure

A typical run consisted of the following steps: ignition, warm up, steady state, and shutdown. The day preceding each test, sufficient minus 1/8-inch coal was spread out on plywood sheets at uniform depth of 1/2 inch to allow free moisture to evaporate and to ensure trouble-free operation of the feed system. The next morning, when the coal hopper was filled, a sample was placed in a sealed container, and the weight of coal delivered to the hopper was recorded. The coal feed sample was submitted for proximate and ultimate analyses.

Ignition was accomplished using a methanol burner system. The exhaust of the burner feeds into the windbox. The methanol was ignited with a nichrome resistance element. Initially, a low air flow and alcohol rate were used to develop a stable flame in the air delivery piping. When the piping exceeded the ignition point of the methanol, typically about thirty minutes, the fuel and air flows were increased. The bag filters were bypassed during this procedure. When the temperature of the silica sand in the fluid bed reached about 1000°F (540°C), the alcohol feed was stopped, and coal feed was initiated and the air flow was adjusted to the desired rate. The exhaust was directed through the bag filters as soon as the coal feed was started. Typically, one hour was required to reach steady-state operation while firing coal.

The tests were typically two hours long at continuous steady-state operating conditions. Shut-down procedures involved the stopping of coal feed while the air flow was maintained for about an hour to accelerate cooling of the unit.

After cooling overnight, the coal feed hopper was emptied, and the unused coal weight was recorded. The actual amount of coal used and the average feed rate were determined from the difference between this weight and the original weight charged to the hopper. The cyclone ash tank and the bag filters were weighed. Samples were taken for proximate and ultimate analyses. In the first few tests, the ash drain was also weighed and sampled, but the accumulation of ash in the bed was so miniscule that use of the bed drain was discontinued.

A total of thirty-three tests were conducted. Tests 1-18 were used to check out various subsystems. Tests 19-25 employed no bed internals, while test 26-33 were conducted using two different types of baffles installed in the bed region of the combustor (Figure 3).

TYPE A BAFFLES

TYPE B BAFFLES

Figure 3. Baffle Types

RESULTS

Table 1 displays the conditions and other pertinent data for tests 19-25. Recall that these tests were conducted without the use of any bed internals. It should also be noted that no cooling water was applied in these tests. The internal ash-recycle cyclone was also not installed during the tests.

Table 1. Combustion Run Summary

Run #	19	20	21	22	23	24	25
Coal Feed Rate, lb/hr	6.6	5.1	10.5	7.9	8.0	7.9	6.7
Weight-Based Conversion, %	90.8	93.1	86.3	89.2	85.7	89.2	94.2
Carbon Balance Conversion, %	91.2	92.8	84.6	83.4	93.1	90.2	92.2
Ash Balance Conversion, %	88.0	88.3	82.0	n/a	90.6	90.0	n/a
Air Rate, scfm	14.4	11.2	14.5	14.4	11.9	13.6	12.0
Bed Temperature, °F	1788	1574	1865	1653	1619	1494	1686
Oxygen Concentration Fluid Bed, %	7.2	7.6	6.1	5.9	5.9	6.9	9.2
Oxygen Concentration Vent, %	3.3	5.3	0.6	0.8	1.9	3.0	1.3
Bed Oxygen-Use Ratio	0.78	0.85	0.73	0.80	0.80	0.79	0.60
Volumetric Heat Release Rate, kBtu/ft ³ /hr	309	277	436		373	373	

n/a = not available

The coal feed rates listed in Table 1 were determined by dividing the weight of the coal fed by the elapsed time. The table displays coal conversion values calculated by two different methods. The weight-based conversions were determined from the weight of material collected after a test run, whereas the ash balance conversions are based upon an ash balance and are independent of any collection efficiencies. Therefore, the ash balance conversion serves as a cross check of the efficiency of the collection system. All of the conversions are reported on an as-received basis. Moisture and ash free conversions are typically five to six percent higher. The air rate, bed temperature, and oxygen concentrations are the time-averaged values for the steady-state period of each run.

The bed oxygen-use ratio is the oxygen consumed in the bed divided by the total oxygen consumed. This ratio provides an index of the percentage of coal consumed in the bed. A more accurate method, which accounts for the change in stoichiometry that occurs with conversion, requires a full gas analysis of the bed gas and vent gas. The heat of combustion of most fuels, referenced to the amount of oxygen consumed, varies little; therefore, the error incurred in determining the partitioning of heat release between the freeboard and the bed is small.

The volumetric heat release rate is estimated by correcting the heating value of the coal consumed to account for the actual moisture content as fed. The product of the oxygen-use ratio, corrected heating value, and the coal feed rate provides an estimate of the heat release rate in the bed. The volumetric heat release rate is then determined by dividing the heat release rate by the bed volume.

Table 2 summarizes the runs made with baffles installed in the bed. No cooling water was used in this set of experiments. The water cooled gas sampling probe was not working properly for this series of runs, so oxygen concentration values are not reported for this series. A temperature excursion was experienced in run 28 that destroyed the type A baffles (Figure 3). Removal of the melted baffles between runs 28 and 29 resulted in damage to the alumina bubble castable refractory (Greencast 97L, 85 lb/ft³, 3300°F/1816°C duty rating). This refractory lining was replaced with a 60 lb/ft³ castable (A.P. Green VSL50, 2300°F/1260°C duty rating). The higher temperatures recorded in runs 29, 30, and 31 are caused by the superior insulating ability of the new refractory lining. Run 31 was operated without baffles in the bed. Glazing and corrosion of the VSL50 was apparent after run 31, so the refractory lining was replaced with a tabular alumina castable (Greencast 94 plus, 158 lb/ft³, 3400°F/1871°C duty rating) with much poorer insulating abilities than the previously employed refractory lining materials.

Tables 3 and 4 summarize the proximate and ultimate analyses performed on the feed and ash stream samples. The carbon and ash balances in Table 1 are based upon these analyses.

Table 2. Combustion Run Summary--Baffled Beds

Run #	26	27	28	29	30	31	32	33
Coal Rate, lb/hr	7.7	9.2	8.1	8.3	7.3	7.2	8.5	6.5
Air Rate, scfm	17.6	12.9	15.2	15.2	15.2	15.0	14.8	10.9
Temperature, °F								
TC2	1731	1087	1196	1808	1863	1914	1567	1521
TC3	1733	1107	1406	1850	1908	1934	1612	1574
TC4	1733	1204	1965	1860	1914	1929	1639	1614
TC5	1727	1547	2219	1881	1937	1932	1652	1631
Carbon Conversion, %	78.8	74	86	93	87	94	91	90
Baffle Type	None	A	A	B	B	None	B	B
Refractory Type	97-L	97-L	97-L	VSL50	VSL50	VSL50	94+	94+

Table 3. Proximate Analyses, wt %

Run #	Sample	Moisture	Volatiles	Ash	Fixed Carbon
19	Feed	18.4	41.7	5.5	52.8
19	Ash	2.4	10.6	45.9	43.6
20	Feed	15.5	41.2	6.3	52.6
20	Ash	3.2	12.1	53.9	34.0
21	Feed	18.8	42.3	6.1	51.6
21	Ash	1.4	9.6	34.6	54.4
22	Feed	14.0	36.4	7.1	46.3
22	Ash	1.3	8.6	40.7	49.4
23	Feed	16.3	34.5	4.9	44.3
23	Ash	2.1	13.5	52.0	32.3
24	Feed	17.8	34.5	4.5	43.2
24	Ash	2.3	9.6	43.5	44.5
25	Feed	13.3	39.0	4.7	43.0
25	Ash	2.7	9.9	47.3	40.1
26	Feed	10.2	39.4	4.8	45.6
26	Ash	2.3	10.9	24.7	62.1
27	Feed	18.5	35.9	4.6	40.9
27	Ash	8.5	13.7	21.3	56.5
28	Feed	11.1	39.1	4.9	44.9
28	Ash	5.3	11.7	41.6	41.4
29	Feed	10.9	38.9	5.0	45.3
29	Ash	5.6	12.7	47.7	35.5
30	Feed	7.7	40.3	5.3	46.7
30	Ash	6.6	17.9	34.3	41.3
31	Feed	10.7	39.2	5.1	45.0
31	Ash	4.3	12.2	49.5	34.0
32	Feed	18.7	36.6	4.8	39.9
32	Ash	1.9	14.0	44.4	39.7
33	Feed	20.1	35.3	5.2	39.2
33	Ash	5.4	11.7	35.3	47.4

Table 4. Ultimate Analyses, wt % (Moisture Free)

Run #	Sample	Carbon	Hydrogen	Nitrogen	Sulfur
19	Feed	65.5	4.3	1.0	0.4
19	Ash	48.0	0.8	0.6	0.6
20	Feed	66.2	4.3	1.0	0.4
20	Ash	40.4	1.0	0.5	0.6
21	Feed	64.9	4.2	0.9	0.4
21	Ash	56.4	1.0	0.4	0.6
22	Feed	54.7	4.0	0.6	0.4
22	Ash	51.8	0.9	0.6	0.6
23	Feed	53.7	3.9	0.8	0.3
23	Ash	39.3	1.5	0.5	0.5
24	Feed	51.9	3.9	0.7	0.3
24	Ash	49.3	1.2	0.5	0.6
25	Feed	57.1	5.2	0.7	0.3
25	Ash	45.0	0.9	0.4	0.7
26	Feed	59.7	4.5	0.4	0.3
26	Ash	64.9	1.1	0.8	1.6
27	Feed	54.8	5.0	0.5	0.4
27	Ash	65.8	1.7	0.8	1.7
28	Feed	52.0	1.2	0.5	0.7
28	Ash	n/a	n/a	n/a	n/a
29	Feed	59.6	3.9	0.4	0.4
29	Ash	43.4	0.1	0.4	0.7
30	Feed	60.7	5.1	0.7	0.4
30	Ash	48.2	2.1	0.4	0.6
31	Feed	59.4	5.0	0.7	0.4
31	Ash	33.9	1.3	0.3	0.5
32	Feed	54.0	5.0	0.6	0.4
32	Ash	46.1	1.4	0.5	0.6
33	Feed	53.5	5.3	0.5	0.5
33	Ash	35.7	1.3	0.4	2.3

n/a = not available

DISCUSSION

The 6-inch fluid-bed combustion system is working well. The weight based conversions, calculated from material balance, agree well with the conversions determined by ash balance, indicating that the particulate recovery system is working well. The volumetric heat release rates for the bed are simply a

function of the coal feed rate. The fraction of coal consumed in the bed, as indicated by the fraction of oxygen consumed, decreases with the increasing air flow rate. Because of the importance of this ratio in the proper design of heat transfer surfaces for the freeboard and bed, the factors responsible for the heat partitioning between the bed and the freeboard were examined. It was discovered that the particle size distribution of the feed coal (Table 5), and the gas velocity, are the primary factors that determine what fraction of the coal is consumed in the bed. The phenomenon controlling the bed consumption fraction is entrainment. This can be clearly demonstrated by comparing the weight fraction of the coal that was not consumed in the bed to the weight fraction of the coal that one would expect to be entrained (Table 6). It is assumed that the stoichiometry for combustion in the bed and the freeboard are essentially identical, so the fraction of coal consumed in the bed is identical to the fraction of oxygen consumed in the bed (Table 1). The bed oxygen use ratio is determined from oxygen concentration measurements at the freeboard-bed interface and the vent according to:

$$X_{O_2} = (21 - Y_b)/(21 - Y_v) \quad (1)$$

X_{O_2} = the fraction of total oxygen used that was consumed in fluid bed

Y_b = volume % oxygen in gases leaving the fluid bed

Y_v = volume % oxygen in the vent gas

To estimate the amount of coal entrained from the bed requires an estimate of the particle size that would be entrained from the bed using Stokes' law:

$$d_e = \sqrt{18V\mu/g\rho\phi} \quad (2)$$

where

d_e = entrainment diameter

μ = gas viscosity

g = acceleration of gravity

ρ = density of the char particle

V = gas velocity

ϕ = shape factor

Table 5. Feed Coal Size

Screen, Mesh ^a	Sample, wt % Retained				Average
	A	B	C	D	
6	0	0	1.1	1.2	0.6
8	0.6	5.0	6.0	5.7	4.3
20	42.5	33.0	48.1	48.1	42.9
40	29.6	25.3	24.3	23.7	25.7
70	16.8	19.3	11.2	10.9	14.6
100	4.6	5.6	2.8	2.9	4.0
140	2.3	4.5	2.0	2.1	2.7
200	1.0	1.8	0.8	1.0	1.2
Pan	2.6	5.5	3.6	4.2	4.0

^a U.S. Standard

Table 6. Fraction of Coal Consumed in Fluid Bed

Run #	Air Rate, scfm	Estimated from Equation 3, dimensionless fraction	As Determined from Oxygen Concentration Measurements, dimensionless fraction
19	14.4	0.75	0.78
20	11.2	0.82	0.85
21	14.5	0.73	0.73
22	14.4	0.76	0.80
23	11.9	0.81	0.80
24	13.6	0.79	0.79

When a large particle enters the bed, it will burn down to the entrainment diameter and enter the freeboard. In this analysis, mechanical breakup of the particles was not considered. From the feed coal particle size distribution, the weight of coal in each size range that will eventually leave the bed and be carried away into the freeboard can be estimated from the cube of the entrainment diameter divided by the mean particle size in that range multiplied by the weight fraction for that size range. If the diameter ratio exceeds one, that is, if the feed particles are smaller than the entrainment diameter, it is

assumed all of the coal in that range leaves the bed. However, it is further assumed that the volatile matter from these particles is consumed in the bed, so the weight fractions from the screen analysis, which are based upon as received coal, are corrected for volatile loss in the bed. Since this comparison is essentially a comparison against oxygen consumption, no correction for moisture is needed. The sum over all size ranges in the coal feed, subtracted from 1, yields the weight fraction of coal that would be expected to be burned in the bed:

$$X_B = 1 - (1 - X_{vm}) \cdot \left(\sum_{i=1}^n C_i X_i + \sum_{i=1}^m X_i \right) \quad (3)$$

$$C_i = (d_e / d_{m,i})^3 \quad (4)$$

where

X_B = mass fraction of feed consumed in the bed

$d_{m,i}$ = mean particle diameter for range i

X_i = mass fraction of particles in range i of feed

n = ending index for size ranges where $d_{m,i} > d_e$

m = smallest particle size range

X_{vm} = mass fraction of volatile matter in feed coal

C_i = weight fraction correction for burning

The amount of coal expected to be burned in the bed based upon Stokes' law agrees well with the amount inferred from the oxygen concentration readings. A much higher conversion of this coal in the bed would be possible in the bed if the fines were removed. Alternatively, this analysis indicates that fuel feeds to fluid-bed combustion systems can be sized to match existing heat transfer configurations when changing fuel sources. In larger units, it may become important to consider mechanical size reduction of the larger particles to accurately predict the amount of coal consumed in the bed, only if a significant number of these fragments approach the entrainment diameter. Estimates of the fraction of coal burned in deeper beds may also require an accounting of the amount of burning occurring during the average transit time of particles smaller than the entrainment diameter predicted by Stokes' law.

The combustion system has performed well during the shakedown testing. Very high coal conversions, typically greater than 90%, have been obtained for the Eagle Butte coal without fly ash reinjection. A high percentage of the coal conversion occurred in the bed. These high conversions, compared with higher rank coals, are not surprising when we consider the much higher reactivity of the low-rank Western coals. This phenomenon was also reported by Hajicek (1985). To maintain stable fluidization, a 9-inch-high bed was employed in our studies to keep the height-to-diameter ratio below 1:5. Larger diameter units can use deeper beds, and higher conversions can be expected.

The introduction of baffles in the fluid bed was intended to increase the heat release rate by controlling bubble size. Two baffle geometries were tried. The "venetian blind" geometry (Figure 3a), strongly affected the solids flow pattern as evidenced by the large difference in bed temperatures shown in Table 2, experiments 27 and 28. Temperature differences as great as 1000°F (555°C) were noted between thermocouples 2 and 5. Thermocouple 2 is located 3 inches above the distributor plate, with thermocouples 2 through 5 spaced 2 inches apart. The vertical distance between thermocouples 2 and 5 is 6 inches. The unbaffled bed exhibits a strikingly more uniform temperature, with only an 18°F (10°C) difference in the same thermocouples. The vertically arranged baffles (Figure 3b) still exhibit a plug flow component to the solids mixing flow field, but not nearly as much as the venetian blind geometry. Experiments 29, 30, 32, and 33 showed temperature differences of 73 to 100°F (40 to 55°C) between thermocouples 2 and 5. These observations suggest that a plug flow component can be imposed upon the backmixed solids flow field of fluidized beds by using a baffling system. Furthermore, the magnitude of the plugflow component can be regulated by adjusting the angle of the baffles with respect to the gas flow direction. While this result may have limited application in combustion systems, potential use of this observation can be imagined in gasification and drying applications, as well as a host of gas-solid contacting reactors. Baffles can be used to transform the traditionally backmixed fluid bed into a truly counter current fluidized reactor system, whose solids dispersion can be controlled online by adjusting the baffle angle.

Because of the changes in refractory lining and the difficulties experienced with the oxygen measurements at the bed-freeboard interface, a direct comparison of the heat release between an open bed and a baffled bed can only be made by comparing runs 30 and 31. There is no apparent improvement in coal conversion in the baffled bed. In fact, the data indicates that the open bed performed better, with a carbon conversion 7% higher (94% compared to 87%, Table 2).

CONCLUSIONS

Even though the test series completed before the redirection of this work was primarily shakedown testing, several conclusions may be inferred from the experimental observations:

- Carbon conversions of 80 to 94% can be expected from Eagle Butte Coal in a 9-inch-deep bubbling fluid bed system with out recycling the elutriated char. Higher conversions would occur in a deeper bed.
- The fraction of coal consumed in the bed can be predicted by the application of Stokes' law to the feed particle size distribution to determine what percentage of the feed will be elutriated into the free board. The calculation must account for those fine particles in the feed that are elutriated immediately, and those larger particles that eventually burn down to a smaller diameter that are also elutriated.
- Baffles in the bubbling bed impart a plug flow component to the solids flow field. The magnitude of the plug flow character is dependant on the angle of the baffles with respect to the gas flow.
- Baffles do not appear to improve the volumetric heat release in the bed when compared to a fluid bed containing no internals.

ACKNOWLEDGEMENT

The authors express appreciation to the United States Department of Energy for funding of this work under Cooperative Agreement Number DE-FC21-86MC11076.

DISCLAIMER

Mention of specific brand names or models of equipment is for information only and does not imply endorsement of any particular brand.

REFERENCES

Botros, D.E., 1990, Fluidized-Bed Combustion Technology Status Report. Morgantown, WV, DOE Report DOE/METC-90/0269.

Hajicek, D.R., 1985, Performance Of Low-Rank Coal In Atmospheric Fluidized Bed Combustion. Grand Forks, ND, DOE Report DOE/FE/60181-1869.

END

**DATE
FILMED**

4 / 14 / 93