DOE/PC/90169--T7

COAL DESULFURIZATION IN A ROTARY KILN COMBUSTOR

Received by OSTI
JAN 20 1993

Grant No: DE-FG22-90PC90169
Grant Recipient: BCR National Laboratory
Grant Date: April 16, 1990 through October 15, 1991
Principal Investigator: James T. Cobb, Jr.
Contracting Officer's
Technical Officer: Douglas Gyorke
Reporting Period: March 15, 1990 - July 31, 1991

FINAL REPORT
(BCRNL Letter Report L-1665)

September 11, 1992

Submitted to:

U.S. Department of Energy
Pittsburgh Energy Technology Center
Pittsburgh, PA

BCR National Laboratory
500 William Pitt Way
Pittsburgh, PA 15238

U.S. DOE Patent Clearance is not required prior
to publication of this document

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

COAL DESULFURIZATION IN A ROTARY KILN COMBUSTOR

DE93 005086

Grant No: DE-FG22-90PC90169
Grant Recipient: BCR National Laboratory
Grant Date: April 16, 1990 through October 15, 1991
Principal Investigator: James T. Cobb, Jr.
Contracting Officer's
Technical Officer: Douglas Gyorke
Reporting Period: March 15, 1990 - July 31, 1991

FINAL REPORT
(BCRNL Letter Report L-1665)

September 11, 1992

Submitted to:

U.S. Department of Energy
Pittsburgh Energy Technology Center
Pittsburgh, PA

BCR National Laboratory
500 William Pitt Way
Pittsburgh, PA 15238

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

U.S. DOE Patent Clearance is not required prior
to publication of this document

MASTER
DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

COAL DESULFURIZATION IN A ROTARY KILN COMBUSTOR

TABLE OF CONTENTS

	<u>Page</u>
1.0 ABSTRACT.....	1
2.0 PROJECT OVERVIEW.....	2
2.1 Introduction.....	2
2.2 Project Summary.....	3
2.2.1 Humphrey Charcoal Rotary Kiln.....	3
2.2.2 Combustion Tests in the PEDCO Reactor....	4
2.2.3 Assessment and Conclusions.....	7
3.0 COMBUSTION TESTS IN THE PEDCO ROTATING CASCADING-BED BOILER.....	9
3.1 Introduction.....	9
3.2 The PEDCO Rotary Kiln Boiler Facility.....	10
3.3 Anthracite Culm Test Fuels.....	12
3.3.1 Sample Analysis.....	12
3.3.2 TGA Test Results.....	16
3.4 Test Procedures and General Observations.....	18
3.4.1 Jeddo and Emerald Culm Tests, March 1991	18
3.4.1.1 Results and Discussion of March Tests.....	20
3.4.2 Frackville Culm Tests, July 1991.....	26
3.5 Conclusions.....	29

APPENDICES

	<u>Page</u>
APPENDIX A. Humphrey Charcoal Rotary Kiln Test Program.	30
APPENDIX B. Chronology of PEDCO Rotary Kiln Tests.....	34
APPENDIX C. Combustion Calculations for Bituminous Coal and Jeddo Anthracite Culm.....	41
APPENDIX D. "Development and Operating Data for the PEDCO Rotary Combustion System".....	45
APPENDIX E. General Aspects of Rotary Combustors.....	58
APPENDIX F. Relevant Rotary Kiln Literature.....	63

*conf paper
cycled
separately
dtd*

FIGURES

	<u>Page</u>
Figure 1. PEDCO Rotating Cascading-Bed Boiler System.....	11
Figure 2. TGA Burning Profiles.....	17

TABLES

Table 1. Comparison of Humphrey Kiln and PEDCO Rotary Cascading-Bed Boiler.....	13
Table 2. Feed Sample Analysis.....	14
Table 3. Feed Sample Size Analysis.....	15
Table 4. Process Parameters Monitored.....	19
Table 5. Data from March 7, 1991.....	21
Table 6. Data from July 16-17, 1991.....	28

BCR NATIONAL LABORATORY

Final Report

COAL DESULFURIZATION IN A ROTARY KILN COMBUSTOR

1.0 ABSTRACT

The purpose of this project was to demonstrate the combustion of coal and coal wastes in a rotary kiln reactor with limestone addition for sulfur control. The rationale for the project was the perception that rotary systems could bring several advantages to combustion of these fuels, and may thus offer an alternative to fluid-bed boilers.

Towards this end, an existing wood pyrolysis kiln (the Humphrey Charcoal kiln) was to be suitably refurbished and retrofitted with a specially designed version of a patented air distributor provided by Universal Energy, Inc. (UEI).

As the project progressed beyond the initial stages, a number of issues were raised regarding the feasibility and the possible advantages of burning coals in a rotary kiln combustor and, in particular, the suitability of the Humphrey Charcoal kiln as a combustor. Instead, an opportunity arose to conduct combustion tests in the PEDCO Rotary Cascading-Bed Boiler (RCBB) commercial demonstration unit at the North American Rayon CO. (NARCO) in Elizabethton, TN. The tests focused on anthracite culm and had two objectives: (a) determine the feasibility of burning anthracite culms in a rotary kiln boiler and (b) obtain input for any further work involving the Humphrey Charcoal kiln combustor.

A number of tests were conducted at the PEDCO unit. The last one was conducted on anthracite culm procured directly from the feed bin of a commercial circulating fluid-bed boiler. The results were disappointing; it was difficult to maintain sustained combustion even when large quantities of supplemental fuel were used. Combustion efficiency was poor, around 60 percent.

The results suggest that the rotary kiln boiler, as designed, is ill-suited with respect to low-grade, hard to burn solid fuels, such as anthracite culm. Indeed, data from combustion of bituminous coal in the PEDCO unit suggest that with respect to coal in general, the rotary kiln boiler appears inferior to the circulating fluid bed boiler. The rotary kiln has an "open structure" which earmarks it for mass burn applications involving bulky and "gooey" fuels and wastes. The open structure can readily accommodate unconventional fuels such as sludges and tires.

Based on the PEDCO results, testing the combustion of anthracite culm in the Humphrey Charcoal rotary kiln combustor did

not appear to be warranted. We do not believe the Humphrey system, in conjunction with the UEI air distributor, as it existed, offered any advantages in solid/gas contact and mixing which would improve the results experienced in the PEDCO unit.

2.0 PROJECT OVERVIEW

2.1 Introduction

In the recent past, rotary kiln combustors have become increasingly popular for waste incineration. The principle advantage of the rotary kiln combustor is a capability to accept a wide variety of feedstocks in various forms (solids or liquids) with minimal prehandling.

This program was conceived from the idea that a rotary kiln, equipped with suitable air injection, would offer a number of potential advantages for the combustion of coal and coal wastes as well. The expected advantages included simple design, easy operation and maintenance, good and efficient sulfur capture by injection of limestone into the kiln, and particulate emissions that would be lower than levels typically experienced in fluid-bed systems. These advantages were to be realized through the use of a patented air distributor conceived and offered by UEI. The air distributor system was said to have been installed and operated successfully in a number of kiln systems which incinerate other kinds of wastes. In a way, the proposed developments offered the potential of a system that would provide an alternative to the atmospheric and circulating fluid bed boilers in the combustion of coals and coal wastes.

The program was formulated to achieve the following objectives:

- (1) Prove the feasibility of burning high-sulfur bituminous coal and anthracite refuse, with limestone injection for sulfur emissions control, in a rotary kiln fitted with a UEI air distributor;
- (2) Determine the emission levels of SO_x and NO_x , and specifically to identify the Ca:S ratios required to meet New Source Performance Standards;
- (3) Evaluate the technical and economic merits of a commercial rotary kiln combustor in comparison to fluidized bed combustors for anthracite refuse; and
- (4) Ascertain the need for further work, including additional combustion tests, prior to commercial application, and to recommend accordingly a detailed program towards this end.

The project work plan defined four phases:

- Phase 1: Facility Preparation, Commissioning, and Shakedown Tests -- make necessary modifications to the Humphrey Charcoal kiln and obtain data to determine basic feasibility of the project.
- Phase 2: Test Program -- conduct tests to address the program objectives.
- Phase 3: Data Collection, Reduction and Analysis -- data analysis, including heat and mass balances and determination of kiln operating parameters on environmental emissions.
- Phase 4: Assessment of Commercial Application -- complete a site-specific conceptual design and cost estimate for a commercial rotary kiln installation in eastern Pennsylvania.

The remainder of this overview section provides a brief project summary and presents key conclusions. The bulk of the report primarily addresses project activities involving the combustion test program conducted at PEDCO's RCBB demonstration unit. Data and information from these tests are included in Appendix B (test chronology), Appendix C (combustion calculations), and Appendix D, (additional information on the PEDCO system). Appendix A discusses the original test program at Humphrey Charcoal Co., while Appendices E and F discuss various aspects of kiln technology and their application.

2.2 Project Summary

2.2.1 The Humphrey Charcoal Rotary Kiln

In the process of developing the program, a rotary kiln believed to be suitable for conducting the tests, was located at the Humphrey Charcoal Co, in Brookville, PA . The kiln, originally built in 1981, was intended to carbonize 100 tons per day of wood waste to produce process heat, gas, and carbon products, primarily charcoal. The kiln, which had not been operated for some time, was made available to the program. The kiln was to be refurbished and equipped with the UEI air injection system for combustion of high sulfur coal and anthracite culm (waste).

As work progressed during the early part of the program, and the rotary kiln combustion process became better defined, a number of issues were raised regarding the feasibility and the advantages of burning coal in a rotary kiln and, in particular, regarding the suitability of the Humphrey Charcoal system. Details

of the Humphrey Charcoal portion of the program are included as Appendix A. Proceeding with further retrofit and operation of the Humphrey kiln would have entailed not only excessive expense, but many uncertainties. Instead we sought an opportunity to test the combustion of coal or coal wastes in another existing and operating rotating kiln configuration in order to resolve some of the issues relating to the combustion process itself. The opportunity presented itself at the PEDCO's Rotary Cascading Bed Boiler noted above.

2.2.2 Combustion Tests In The PEDCO Reactor

PEDCO, Inc., of Cincinnati, OH has developed the rotary kiln boiler system, which is an extension of their basic rotary reactor technology. The PEDCO rotary reactor for coal combustion was initially built and tested in 1986 at the Hudepohl Brewing Company's Gest Street plant in Cincinnati, OH. After completing the test program at Hudepohl, this commercial scale unit was modified and reinstalled as the centerpiece of the Industrial Energy Project at the North American Rayon Co. (NARCO) plant at Elizabethton, TN. Based on discussions with PEDCO personnel, we understood that in its new location, the unit incorporated several changes as a result of previous experience, and the impression was gained that it might provide efficient combustion of any solid fuel. The rationale for the tests at PEDCO arose from the process analysis which had posted red flags on the feasibility of burning low-grade, hard-to-burn fuels like anthracite culms, in the Humphrey Charcoal rotary kiln combustor. The PEDCO unit afforded a unique opportunity to obtain actual operating data at minimal cost. The tests had essentially two related objectives: (a) to obtain basic data on the combustion of anthracite culm in a rotary kiln boiler, and (b) based upon the test results, determine the best way to proceed with our own planned program using the Humphrey Charcoal kiln in Brookville, PA.

In January 1991, approval was solicited and obtained from the project sponsors to conduct a test burning anthracite culm in the PEDCO rotary kiln boiler at the NARCO plant. In March of 1991, two Pennsylvania anthracite culm fuels were tested: a so-called Jeddo culm with an average heating value of 7,000 Btu/lb, and a relatively poorer culm, the "Emerald" culm, with an average heating value of 5,000 Btu/lb. (It should be noted that some of the fluid-bed facilities in Pennsylvania burn anthracite culms with heating values below 4,000 Btu/lb.) During the course of testing, an attempt was also made to burn a blend of the Emerald culm with bituminous coal in 75/25 percent proportions.

As it turned out, our tests demonstrated the PEDCO unit was not configured properly for the combustion of anthracite culm.

As a result, it proved difficult to achieve a sustained period of steady-state combustion operation, and combustion efficiencies were low even when supplemental fuel was used to aid combustion of the culm.

Although the NARCO system was intended to burn a variety of fuels, the anthracite culm demonstrated two shortcomings of the current system. First, the heat-transfer tube bundle could not be easily modified to reduce steam production. Even when the internal deflector was adjusted to minimize steam production, excessive heat was removed through the tube bundle so it was difficult to maintain combustion temperatures in the kiln.

Secondly, the system was not able to handle the large quantities of ash produced by the culm. Normally, most of the ash leaves the kiln as fly ash. The bottom ash is directed to the rear breaching where it is recycled to the front of the kiln. The kiln is not equipped with a means of withdrawing substantial quantities of bottom ash during operation. Thus, the bed inventory built up to the point that the load became excessive for the kiln hydraulic drive system.

In addition to these problems, the initial test was also hampered by the use of a wet (13 percent moisture) and coarse (up to 2-inch topsize) feed material; and insufficient use of supplemental fuel resulting in low kiln temperatures.

The results of the tests raised a number of serious issues:

- (1) Can the PEDCO unit, specifically, be modified to provide efficient combustion of anthracite culm?
- (2) Can a rotary-type kiln, in general, be configured to afford efficient combustion of poor-grade, hard-to-burn fuels in general, and anthracite culm in particular?
- (3) Can the Humphrey unit, incorporating the UEI air distributor, be configured in a manner affording efficient combustion of anthracite culms? Will it have any particular advantage over the configuration considered under (1) and (2) above?
- (4) In light of all these, can a rotary kiln system have any significant advantages over the circulating fluid bed in combustion of hard-to-burn, low-grade fuels like anthracite culm?

These were the issues that were addressed in deciding how best to proceed with the program. At this point the options were as follows:

- (1) Modify the PEDCO unit, as needed, to undertake combustion of anthracite culm.
- (2) Proceed to modify the Humphrey kiln based on the lessons acquired to date, and proceed with the program.
- (3) Proceed to modify the Humphrey kiln but change focus of fuels from hard-to-burn, low-grade solid fuels, to wastes like plastics, tires, wet organic sludges, etc.
- (4) Abort the program.

Subsequently, discussions with PEDCO personnel suggested that certain modifications could significantly aid combustion of the anthracite culm. These included changes in the ash-handling equipment, the ability to "blind" some of the heat-transfer surface, the use of supplemental fuel during start-up, and preparation of the feed (drying and sizing to smaller particles). The decision was made to conduct an additional test after the changes were made. Unfortunately, other changes to the unit worked against these modifications and thwarted combustion of the anthracite culm. These additional changes included a reduction in the inlet (feed end) opening of the internal solids recirculation chute and an increase in the size of the opening to the last (boiler tube) section of the recirculation chute.

A second test series was conducted in July 1991, involving a third anthracite culm, the Frackville culm. The culm procured for this test was taken directly from the feed for a commercial fluid bed boiler in Pennsylvania which routinely burns anthracite culm. This culm contained 3,018 Btu/lb, but more importantly, it contained less moisture and was much finer than the previous culms.

Because of their contradictory aspects, the changes made to the system, between March and July 1991, did not produce any significant improvement. Large amounts of supplementary fuel were still needed to maintain combustion which was not stable. Despite high excess air, combustion efficiency of the culm was very poor. There was 25 percent carbon in the bottom ash and 30 percent in the fly ash. Indeed, even in the previous test, when a mixture of bituminous coal and the Jeddo anthracite (75 and 25 percent by weight, respectively) was processed, carbon in the fly ash was 29 percent. Bottom ash was not withdrawn during this operation. Sulfur capture by the addition of limestone was not attempted in any of these tests.

Based on the PEDCO results, testing the combustion of anthracite culm in the Humphrey Charcoal rotary kiln combustor was decided not to be warranted. We do not believe the Humphrey system, in conjunction with the UEI air distributor, as it existed, offered any advantages in solid/gas contact and mixing which would improve the results experienced in the PEDCO unit.

2.2.3 Assessment and Conclusions

At the outset of this project, several advantages were held for the combustion of coal and coal wastes in a rotary kiln system. These included: simple design, easy operation and maintenance, efficient combustion, good control of emissions, and a capability to process a broad range of fuels of various types. Indeed, it was implied and often so stated that the rotary kiln may provide an alternative to fluid bed boilers burning coals and coal wastes, and there were those who went as far as to perceive even a clear advantage on the part of the rotary device. The underlying aim of this project was to explore and demonstrate the capability of the kiln regarding combustion of coal products.

Fluid-bed boilers, especially those operating in the Circulating Fluid Bed (CFB) mode, have made an impressive market penetration since the first unit went on stream in Finland in 1979. Today, there are over 200 units in commercial operation or under construction. Their size spans smaller industrial installations to utility size units approaching 200 MW in electric generating capacity. They consume various fuels, but their chief merit lies in processing low-grade, hard-to-burn fuels, such as anthracite culm. Many of the CFB boilers put into commercial operation by Independent Power Producers under the PURPA ACT, fire waste coals. In Pennsylvania, there are a number of commercial units burning anthracite culm. The CFB boiler enjoys a good industrial record for reliability and availability.

To afford efficient combustion of low-grade, hard-to-burn fuels like anthracite, the furnace of the CFB boiler runs at temperatures around 1650°F which is somewhat higher than the average temperatures employed when more reactive coals are burned. Care needs to be taken to reduce the size of the culm to less than 1/4-inch (when bituminous coal or lignite are burned the top size is larger). The Pennsylvania CFB boilers burning anthracite culms typically achieve combustion efficiencies in the range of 90-95 percent. The corresponding efficiency for the more reactive coals, such as bituminous coal and lignite, is much higher. The level of carbon in the bottom ash is typically 2-3 percent. In the fly ash it is around 15 percent. The split of bottom and fly ash is typically 50/50 by weight.

The underlying characteristic of the CFB boiler which accounts for its excellent commercial record and performance (when operating as designed) is excellent solid mixing (especially at the bottom zone) and good gas (air) solid contact. It was particularly attractive therefore to test the combustion of anthracite culm in the PEDCO RCBB demonstration unit. The PEDCO designers appreciated the need for good solid mixing and good solid/gas contact and have attempted to achieve these by means of proprietary systems of fixed internals.

Apparently these means are not sufficient to produce the kind of turbulent, intense, and uniform mixing and contact that is achieved in the CFB boiler. In combustion tests of anthracite culm, stable combustion was not achieved even when supplementary fuels were used. Indeed, in the last tests we took pains to provide a feed directly from a commercial CFB unit so as to eliminate any uncertainty with respect to the size and nature of the fuel. This did not alter the results.

In addition, carbon combustion efficiency was disastrously low -- around 60 percent. Based on data we observed obtained when burning bituminous coal, it is our impression that even when bituminous coal is burned, the carbon efficiency is below 90 percent--all this with excess air much higher than the approximately 20 percent typically employed in CFB boilers.

Even if one ascribes some of these results to the difficulties that often arise when an experimental program involving a new fuel is attempted, it is difficult to conceive any advantages the rotary kiln boiler may have over the CFB boiler. Based on the quantity of air used in the experiments noted above, the axial gas velocity in the kiln is around 3-4 ft/sec. It is around 15-17 ft/sec in the CFB furnace, with a clear capacity advantage.

Based on all of these, we feel with respect to low-grade, hard-to-burn solid fuels, the rotary kiln boiler is ill suited. With respect to coal in general, the rotary kiln boiler is inferior to the CFB boiler.

The rotary kiln may be well suited to processing of other wastes. The "open" design of the kiln earmarks it for applications involving mass burn of bulky and "goosey" fuels and wastes. That open geometry suggests a capability to accommodate unconventional fuels including, for example, sludges and tires. Catalogs of recent uses of rotary kilns include almost exclusively applications of this kind.

3.0 COMBUSTION TESTS IN THE PEDCO ROTATING CASCADING-BED BOILER

3.1 Introduction

The PEDCO rotary kiln boiler or cascading bed boiler, was initially built and tested in 1986 at the Hudepohl Brewing Company's Gest Street plant in Cincinnati, OH. Following the closing of the plant, the unit was removed and more recently this commercial-scale unit was modified and reinstalled as the centerpiece of the Industrial Energy Project at the North American Rayon Co. (NARCO) plant at Elizabethton, TN.

On November 1, 1990, BCRNL personnel met with representatives of PEDCO and Zurn Industries, Inc., of Erie, PA (a licensee) to exchange information on rotary kiln technology. The discussion included details of the PEDCO cascading bed boiler and their operating experience, staged air injection, the role of limestone in scavenging acid gases, and the use of secondary combustors as part of the kiln system. It was pointed out that as a result of the testing at the Hudepohl Brewing Co., and prior to being installed at NARCO, several significant design improvements were made to the unit and it was completely refurbished. Personnel responsible for the unit felt that it was extremely flexible and could burn just about any solid fuel.

During this initial meeting it was learned that one of the purposes of the Industrial Energy Project was to make the kiln available to outside parties for combustion testing of just about any non-hazardous solid or liquid fuels. The use of the PEDCO facility presented an excellent opportunity to obtain, at a very moderate cost, actual operating data as input for the conceptual design of the Humphrey Charcoal kiln. At that time the process analysis for the Humphrey Charcoal kiln had posted red flags on the feasibility of burning low-grade, hard-to-burn fuels like anthracite culm, in that rotary kiln combustor. There was also uncertainty regarding the system, such as the need for a secondary combustor. In addition, the air permit for system modifications, issued by the Pennsylvania Department of Environmental Resources, required the installation of an expensive particulate collection system not currently part of the Humphrey facility. The results from tests in the PEDCO kiln could be used to develop a better estimate of the expected performance of the unit at Humphrey Charcoal and to guide the preparation of the test program there.

In January 1991, PEDA and PETC approval were solicited and obtained to conduct a test burning anthracite culm in the PEDCO rotary kiln reactor at North American Rayon. The tests had essentially two related objectives: (a) to obtain basic data on the combustion of anthracite culm in a rotary kiln boiler, and (b) based upon the test results, determine the best way to proceed with

our own planned program at the Humphrey Charcoal kiln in Brookville, Pennsylvania. Work at Humphrey Charcoal was put on hold pending the outcome of the PEDCO tests. Specific test conditions were worked out with plant operating personnel and arrangements were made to ship the anthracite culm from PA to TN.

3.2 The PEDCO Rotary Kiln Boiler Facility

The primary operational parameters of the PEDCO rotary kiln boiler, Figure 1, are as follows:

Dimensions:

Internal diameter.....	5.5 ft.
Overall length.....	25.0 ft.
Temperature, max.....	1650° F
Rotary speed.....	16 rpm
Steam rate.....	10,000 lbs/hr

Additional published information on the kiln is included in Appendix D.

The kiln rotation is set to achieve a cascading action that maximizes gas/solids contact. Internal lifters are installed on the inner lining of the kiln so material is carried higher before falling or cascading back into the bed. The fuel and combustion air enter the kiln at the same end, concurrently, while the ash is removed at the opposite end. The heat transfer tube bundle is mounted at the ash discharge end, with the tubes protruding into the kiln. There are two ash recycle systems--an internal and external system. The internal ash recycle system consists of a transport tube, in the form of an "Archimedean spiral", mounted on the inner wall of the kiln. Ash is transported from the discharge end back to the feed end through the tube. Externally, both fly ash and bottom ash can be recycled to the feed end or directed to a dumpster for disposal.

It should be noted that the majority of the solid material that leaves the kiln is in the form of fly ash. When the kiln burns the NARCO bituminous coal, all of the ash is in the form of fly ash, and in fact, it is necessary to periodically add sand to maintain bed inventory.

An internal deflector, mounted near the centerline of the kiln towards the ash discharge end, is used to direct material towards the feed end of the kiln which reduces the flow of hot solids over the tube bundle and, therefore, reduces steam production.

The kiln is driven by a hydraulic motor connected through a chain to a large tooth sprocket on the kiln. The kiln rotational speed is controlled by regulating the flow of hydraulic fluid through a remote pump and reservoir.

Figure 1. PEDCO Rotating Cascading-Bed Boiler System
(Reproduced from "POWER" Feb. 1991)

As a result of the initial tests conducted at Hudepohl Brewing Co, a number of changes were made when the kiln was installed at NARCO. Modifications included: changes in the tube bundle to increase steam production and the method of attaching the bundle to the kiln, enlarging the internal transport tube to increase the ash recycle rate, installing the internal deflector to control solids flow, and providing for fly ash recycle. Most of these changes were directed at improving the combustion efficiency of the system.

It should be noted that substantial differences exist between the PEDCO system and that envisioned at Humphrey Charcoal Co., a comparison is shown in Table 1. Not only are there basic design differences, but also equipment differences. However, it was believed that if the anthracite culm would not support combustion in the PEDCO kiln, there was virtually no hope of sustaining combustion in the Humphrey system that resulted from the Phase I design efforts. However if the PEDCO tests were positive, the results would provide valuable insights that could be incorporated into the design and operation of the Humphrey Charcoal system.

3.3 Anthracite Culm Test Fuels

3.3.1 Sample Analysis

Three different Pennsylvania anthracite culms were tested in the PEDCO rotary reactor. In addition, during the course of testing, a blend of the Emerald culm (75 percent by weight) with a bituminous coal supplied by NARCO (25 percent by weight) was also burned. Fuel analyses are shown in Table 2. Two of the fuels were tested in March 1991, while the third was tested in July 1991. The two tested in March were identified as the Jeddo culm, an anthracite culm rated at 7,000 Btu/lb with a nominal 2-inch topsize, and the Emerald culm which was approximately 5,000 Btu/lb with a nominal 1/2-inch topsize. The moisture content of both culms was high, approximately 10 percent for the Jeddo culm and 13 percent for the Emerald culm. This was primarily a result of the shipment being stored outside and early spring rains which occurred just prior to testing. For comparison, the moisture content of the standard NARCO bituminous coal, also stored outside during the tests, was 8.3 percent. There was also considerable variation in sample analysis for different samples of the same fuel. This is fairly typical for anthracite culms.

The third culm, tested in July, was obtained from a fluidized bed facility located in eastern Pennsylvania and was identified as the Frackville culm. Fuel analysis is shown in Table 2. This culm was much finer than the earlier fuels, 1/4-inch topsize, with a lower Btu content, 3,018 Btu/lb. (It should be noted that some of the fluid-bed facilities in Pennsylvania routinely burn anthracite culms with heating values below 4,000 Btu per lb.) The Frackville culm also contained less moisture than the

earlier culms, 4.1 percent, which resulted in fewer feeding problems and should have aided the combustion process.

Size consist data for the various fuels burned are shown in Table 3. The Jeddo culm was by far the coarsest culm tested, having 48.7 percent +1/2-inch material and a topsize of approximately 2-inches. The Emerald culm was finer, only 2.4 percent +1/2-inch. The Frackville culm was even finer; the material had already been crushed to feed a fluidized bed unit. The topsize was approximately 1/4-inch with 13.9 percent +5/32-inch. For comparison, the NARCO bituminous coal is also included in Table 3. The bituminous coal is obviously much coarser than any of the anthracite culms.

**TABLE 1. COMPARISON OF HUMPHREY KILN AND PEDCO
ROTARY CASCADING BED BOILER**

HUMPHREY KILN

1. Low rotational speed (3-4 rpm)
2. Gas/solids mixing encouraged by turbulence from airflow distributor
3. Refractory lined
4. No heat-removal system (spray cooling)
5. No ash recycle systems
6. Countercurrent feed/airflow

PEDCO ROTARY CASCADING BED BOILER

1. High rotational speed (16 rpm)
2. Gas/solids mixing encouraged by use of mechanical lifters and high rotational speed
3. Steel lined
4. Heat removal through steam production
5. Bottom ash and fly ash recycle systems
6. Concurrent feed/airflow

TABLE 2. FEED SAMPLE ANALYSIS

Feed Material	Date/Time	Moisture, As Received	Dry Basis			
			Ash	Volatile Matter, %	Sulfur, %	Calorific Value, Btu/lb
Blend (25% NARCO/75% Emerald)	3/7/12:13 1:02 2:58 4:40	13.7	46.6	14.0	0.69	7410
		18.3	48.7			6972
		13.8	42.0			8338
		11.4	41.6			<u>8348</u> 7767
Jeddo Culm	Pile Sample 3-5/4:41	9.9	44.6	8.2	0.58	7174
		11.4	50.4			<u>6350</u> 7378
Emerald Culm	Truck Sample 3-5/1:07	3.6	56.1	7.0	0.49	4293
		13.1	49.3			<u>5781</u> 5000
NARCO Coal	3-5/8:41	8.3	13.6	35.0	1.30	12754
Frackville Culm		4.1	67.3	7.6	0.36	3018

TABLE 3. FEED SAMPLE SIZE ANALYSIS

Size	NARC Coal	Cumulative Weight Percent Retained			
		Blend (25% NARC/ 75% Emerald)	Emerald Culm	Jeddo Culm	Frackville Culm
+2"	--	2.6	--	--	--
+1"	23.5	12.2	--	--	--
+1/2"	44.2	31.9	2.4	48.7	--
+1/4"	64.8	47.2	9.7	77.7	--
+5/32"	--	--	--	--	13.9
+8 M	82.5	63.2	42.3	97.6	32.6
+16 M	87.7	75.4	61.5	90.2	52.9
+30 M	92.0	88.6	80.3	94.2	78.2
+50 M	95.1	95.7	90.9	97.5	92.1
+100 M	96.9	97.8	94.3	98.8	97.3
+200 M	98.0	98.8	96.9	99.4	99.0
+325 M	98.6	99.2	97.8	99.5	99.4

3.3.2 TGA Test Results

Burning profile tests were conducted to assess the combustion characteristics of the anthracite culms. The test, developed by Babcock and Wilcox, gives an indication of the combustion characteristics of a solid fuel. A thermogravimetric analyzer, TGA, is used to measure the rate of weight loss as a function of increasing temperature, from ambient to 1000°C. The test provides information on the initial temperature at which oxidation begins, the rate of oxidation as the temperature is increased and the temperature at which the process is completed. Specifically, interpretation of the profile provides information on the "ease of ignition" and the intensity of combustion. The test is most useful in making comparisons between a fuel with known combustion properties and one that is unknown. Through such comparisons, coals with similar TGA profiles would be expected to perform in a similar way in a boiler.

Tests were conducted with a typical anthracite coal, the Emerald and Jeddo culms, the NARCO bituminous coal, and a blend of the NARCO coal and Emerald culm. The weight loss curves are shown in Figure 2 for the anthracite and bituminous coals, the Emerald culm, and the blend. These curves are representative of the results obtained. If one compares the anthracite and bituminous coal, the slopes of the lines are very similar, meaning that the samples burned at about the same rate. However the bituminous coal began oxidizing at about 400°C whereas the anthracite did not begin until 550°C. The bituminous coal was completely oxidized at about 825°C, compared to the anthracite at 950°C. Finally, the anthracite coal weight loss was greater than the bituminous, meaning the anthracite had a lower ash content. There are several significant facts regarding results for the Emerald culm and blend. The curve for the Emerald culm is not nearly as steep as either the bituminous or even the anthracite coal; the culm burns at a much slower rate. The slope of the line for the blend is also very similar to the culm; even with 25 percent bituminous coal in the blend the combustion rate is still very similar to the Emerald culm. The initial oxidation temperature for the culm and blend, approximately 450°C, was higher than for the bituminous coal but less than the anthracite. Whereas the final temperature was very similar to the anthracite, 950°C. These results demonstrate that the anthracite culm burns at a much slower rate than bituminous or even anthracite coal, from which it is derived. The lower combustion rate can be easily explained by the low volatile matter content of the culm. Whereas, up to 40 percent of the heating value in bituminous coal can be contained in the volatiles, and these are easily combusted at kiln operating temperature, 1650°F, anthracite culm contains less than 10 percent volatile matter and the bulk of the heating value is contained in the much slower burning carbon.

Figure 2. TGA Burning Profiles Comparing Bituminous Coal, Anthracite Coal, Anthracite Culm and a Blend of Bituminous Coal and Anthracite Culm

Thus, conditions suitable for the combustion of bituminous coal may not be adequate to burn anthracite culm or even a blend containing some nominal percentage of bituminous coal.

3.4 Test Procedures and General Observations

The PEDCO rotary kiln boiler facility is equipped with a number of process condition monitors, the data from which are transmitted to a recorder and computer. The parameters measured are shown in Table 4. During a test, readings were hand recorded approximately every one-half hour. Printed transcripts of the computer data and chart recordings were also obtained.

Material samples were collected as follows:

- (1) coal feed
- (2) limestone feed
- (3) bottom ash (from rear breaching)
- (4) bottom ash (from discharge to dumpster)
- (5) fly ash (from discharge to dumpster)

Selected samples were analyzed for carbon content and total combustible content, loss-on-ignition or LOI test.

Originally, the tests were to begin by achieving steady state combustion with the NARCO coal. The feed hopper would then be emptied and filled with enough anthracite culm to run for two hours. Since the culm has a much lower heating value than the coal, as the culm began to flow into the kiln, the feed rate was to be increased to maintain combustion temperature. At this point operational adjustments would be made to achieve steady state.

As a result of the tests conducted in March, these procedures were modified. Ash handling problems precluded allowing the kiln to operate on coal with a normal bed load. The bed inventory was minimized prior to feeding the culm. Secondly, the transition from coal to culm was made by first feeding a blend of the coal and culm. Finally, provisions were made to introduce supplemental fuel in order to maintain combustion temperatures after introducing culm into the kiln.

3.4.1 Jeddo and Emerald Culm Tests, March 1991

A detailed chronology of the tests conducted on March 5 and 7, 1991 is given in Appendix B, "Chronology of PEDCO Rotary Kiln Tests."

TABLE 4. PROCESS PARAMETERS MONITORED

1. Combustion chamber temperature, °F kiln exit
2. Combustion chamber temperature, °F
3. Combustion chamber temperature, °F
4. Combustion chamber temperature, °F kiln entrance
5. Air temperature, superheater exit, °F
6. Air temperture, boiler outlet, °F
7. Bag filter temperature, °F
8. Air temperature, economizer inlet, °F
9. Superheater steam temperature, °F
10. Boiler steam flow, lb/hr
11. Cumulative coal feed weight, lb
12. Cumulative limestone feed weight, lb
13. Drive system, hydraulic pressure, psig
14. Boiler outlet steam pressure, psia
15. Steam drum water level, inches
16. Fan outlet air flow, percent
17. Boiler steam flow differential pressure, psid
18. Kiln rotational speed, rpm
19. Saturated steam temperature, °F
20. Circulating water pump differential pressure, psid
21. Flue gas oxygen, percent
22. Flue gas carbon dioxide, percent
23. Flue gas carbon monoxide, ppm
24. Flue gas nitrogen oxide, ppm
25. Flue gas sulfur dioxide, ppm
26. Flue gas opacity, percent
27. Cumulative steam flow, lb
28. Air temperature, Kentube outlet, °F
29. Bag filter differential pressure, psid
30. Cumbustion air temperature, °F
31. Parallel alarm channel for Item 15, inches
32. Air inlet temperature, °F

Prior to feeding anthracite culm, stable combustion was achieved with the NARCO bituminous coal. The feed hopper was emptied and the Emerald culm was loaded into the hopper. Thus there was a transition period during which the bed inventory was built up burning bituminous coal prior to feeding the culm. Difficulties were immediately encountered in maintaining temperature and achieving stable combustion. After several hours it was decided to feed the higher Btu Jeddo culm. Again, stable combustion could not be achieved and the test run was terminated approximately 10 hours after the start. During much of this time, gas and oil were used as supplemental fuel in an effort to maintain temperature and promote combustion of the culm.

After reviewing results of these tests, several operational changes were suggested, and it was decided to test a blend of the NARCO bituminous coal and the low-Btu Emerald culm. The bituminous coal was selected in order to provide additional volatiles, and in combination with the low-Btu culm resulted in a fuel with approximately the same Btu rating as the Jeddo culm, but with a higher volatile matter content.

Prior to feeding the bituminous coal/anthracite culm blend, the bed inventory was kept as low as possible, which allowed the system to absorb a significant quantity of material before overloading the hydraulic drive system. This approach also permitted minimizing steam production by pushing solids to the front of the kiln. Again, stable combustion could not be achieved. Supplemental fuel was initially required to maintain temperature. After a time the temperature appeared to stabilize and the supplemental fuel was shut off. However what actually happened was a large inventory of carbon had built up in the bed, and a period of uncontrolled combustion followed, until the carbon burned out and the temperature declined. Bottom ash and fly ash analyses are shown in Table 5.

3.4.1.1 Results and Discussion of March Tests

Since a sustained period of combustion was not achieved with any of the fuels, it was difficult to determine combustion or thermal efficiency. This was partly due to several operational problems that were a result of using the high-ash anthracite culm. First, the amount of ash produced by the culm overwhelmed the system. The first test was started using the existing bed inventory built up during combustion of bituminous coal. In retrospect, the first test should not have been started with a full bed inventory from a previous run. Since the NARCO kiln is not equipped with a means for dumping hot bottom ash, the bed inventory began to increase as soon as the high-ash culm was fed into the kiln, and in a very short period of time, the hydraulic drive system could not handle the load. Since the ash

TABLE 5. DATA FROM MARCH 7, 1991

<u>TIME</u>	<u>COMMENTS</u>	<u>FEED MATERIALS</u>			<u>Percent LOI</u>	
		<u>AR Moist.%</u>	<u>Btu</u>	<u>% LOI</u>	<u>Bottom Ash</u>	<u>Fly-Ash</u>
8:40 AM	NARC Coal	15.1	12,746	85.6	--	--
8:52		--	--	--	--	29.0
10:45	Feeding Blend (25% NARC Coal 75% Emerald)					
11:46		--	--	--	--	20.1
11:55		--	--	--	11.1	--
12:13 PM	Gas Cofire	13.7	7,410	53.4	--	--
12:40						
1:02		18.3	6,972	51.3	--	--
1:50		--	--	--	43.4	--
1:57		--	--	--	--	26.9
2:51	Gas Off					
2:58		13.8	8,338	58.0	--	--
3:00	Feed Off, Temp. increasing					
3:10		--	--	--	42.8	--
3:45		--	--	--	--	39.7
3:48		--	--	--	25.9	--
4:16	Feed On					
4:30		--	--	--	18.0	--
4:40		11.4	8,348	58.4	--	--
5:00	Gas Cofire	--	--	--	33.2	--
5:42		--	--	--	40.0	--
5:55		--	--	--	--	30.2

could not be removed fast enough, the bed inventory increased. As the kiln load increased, the rotational speed decreased. In order to maintain kiln speed, the hydraulic pressure would have had to be increased beyond the capacity of the system. Since the hydraulic pressure could not be increased to maintain kiln speed as the load in the kiln increased, the kiln rotation decreased. The lower kiln speed meant less mixing of the gas and fuel, and a decline in the combustion rate and kiln temperatures. The combustion process was then further hindered by the declining temperatures. Since the culm is less reactive than bituminous coal, it requires a longer residence time in order to achieve a reasonable carbon burnout. Because of the ash-handling problems, we were not able to build up a bed of culm ash and provide sufficient residence time and combustion temperatures.

Under these conditions, a very low combustion efficiency would be expected, since we were trying to push material out the back of the kiln as fast as we were feeding it in the front. In contrast to the experience with the anthracite culm, when the unit is operating on bituminous coal, sand is periodically added to the kiln to maintain bed inventory.

A second problem encountered during the tests was that there was no way of severely restricting steam production, in order to reduce the amount of heat removed from the kiln. Once again, since the culm is difficult to burn, when the wet culm material began to flow into the kiln the temperature would start to drop; combustion was not rapid enough to offset the amount of heat removed through the steam tube bundle. Normally steam production is controlled by moving more solids to the front of the kiln. In effect this restricts the flow of solids over the tube bundle, reduces steam production, and the flow of solids out of the kiln. However, with the high ash culm, this only aggravated the ash buildup in the kiln and further reduced the kiln rpm, which in turn further decreased combustion and increased the hydraulic pressure required to maintain the rotating speed.

Notwithstanding high excess air which was used in burning the anthracite culm, stable combustion could not be achieved, and the proportions of unburned carbon in the bottom and fly ash were high (25 and 30 percent respectively). As noted before, we can ascribe these results to the inherently low reactivity of the culm, and the insufficient conditions that the kiln afforded; namely, the difficulty in handling the large quantity of ash, and the cooling effect of the steam coils. On the other hand, although the bituminous coal does burn stably, the quantity of unburned carbon in the fly ash turned out to be just as high as in the case of the anthracite culm (29 percent), and this, too, was achieved when the unit was fired with high excess air.

In spite of the problems noted above and the lack of a stable combustion period, an analysis was attempted using the data for the Jeddo culm, and as a comparison, a stable combustion period with the NARCO bituminous coal. These analyses are shown in Appendix C. It is important to note that although we show a combustion efficiency of 66 percent for the Jeddo culm, this is not to say that even with the proper changes, this fuel can be burned in the rotary kiln.

In order to gain a better insight into the operation of the PEDCO unit, a material and heat balance was calculated using data generated from burning the bituminous coal NARCO normally uses. The operating period chosen was just prior to the culm test runs on March 5, 1991. The efficiency was first estimated using a method called the ASME PTC 4.1 short form method.

As can be seen from the data in Appendix C, the calculated thermal efficiency was low at 71.35 percent. This would be considered very low for a coal fired boiler. The main reason for the low efficiency is the very high fuel loss in the ash refuse, 11.68 percent. In normal power plant practice, anything above 1 percent loss of fuel in the ash would be considered excessive. The fuel (carbon) in the ash was determined from the LOI test. The carbon content was estimated to be 29 percent.

Using the NARCO data, however, the input/output efficiency was calculated to be 87.51 percent. This calculation is also shown in Appendix C. This is of course impossible since there was an 11.68 percent loss in the ash alone. Thus, some of the input/output data must have been in error. The coal and limestone feeders can easily be checked simply by weighing the belt feeder output over a set time period, and in fact this is done frequently by the NARCO personnel. The steam flow orifice, however, was a prime suspect since a calibration data sheet was not available. Therefore, in order to get a reasonable heat and material balance for our calculations, the steam flow was reduced 18.47 percent from the instrument reading to 3480.5 pounds per hour. The final heat, material, and carbon balances are given in Appendix C.

Using the data generated in the heat and material balance with bituminous coal, a theoretical heat and material balance was developed for Jeddo anthracite culm. For this study it was assumed that the bottom ash would contain 25 percent carbon, and the fly ash 30 percent carbon. Because of the very high ash content of the culm, the calculated fuel loss in the ash was also very high, 33.5 percent. The calculated thermal efficiency was correspondingly very low, 55.02 percent. The heat and material balance as well as the carbon balance for the Jeddo culm are also shown in Appendix C. It must be emphasized that these were theoretical calculations, and that combustion of the anthracite culm was never achieved, primarily due to the low reactivity of the carbon in the culm.

The PEDCO unit is not ideally designed for good thermal efficiency on solid fuels, especially low volatile solid fuels. It appears that most of the steam is generated by the tube bank, installed inside the kiln, which receives its heat directly from hot ash cascading over the tube surface. The gases from the kiln pass over a superheater, then convection generating tubes, and finally economizer tubes. At a particular bed temperature, the steam generation is therefore relatively fixed according to the characteristics of the in-kiln tube bundle and the cascading ash. In order to match the heat absorption of the kiln tube bundle, the carbon in the bed must increase to a level such that the bed heat generation matches the heat absorption. Thus, in an attempt to increase steam generation, the carbon content of the bed has also been increased resulting in poor thermal efficiency.

It should be noted in Appendix C that the heat generation of the bed with bituminous coal is on the order of 1,400,000 Btu/hr/1000 lbs of bed. This rate is with 29 percent carbon in the bed. For comparison, in a typical circulating fluid-bed boiler, the heat generation is on the order of 1,000,000 Btu/hr/1000 lbs of bed which is achieved with only 3 to 8 percent carbon in the bed. The gas/solids contact in a fluid bed boiler is also obviously much better than in the PEDCO unit.

Unstable temperature control is another negative side effect of operating with such a high carbon content in the bed. At low carbon content levels in the bed, the heat release is primarily dependent on the fuel feed rate. However, at high carbon levels in the bed, the heat release is more dependent on the carbon content of the bed. Thus, an unstable condition results due to a positive temperature coefficient in the reaction between the bed carbon and oxygen. This instability was proven during the March 7 test when, without feeding fuel, the kiln temperature increased to 1791°F, compared to the desired control temperature of 1600°F.

These test results raised more questions than what they answered regarding the test program at Humphrey Charcoal Co. The PEDCO rotary reactor at NARCO appeared to have several distinct operational advantages over the Humphrey unit that must be considered when evaluating the Humphrey conceptual design. These included: the amount of gas/solids mixing in the "high" rpm PEDCO unit versus the mixing achieved with the low rpm/air injector Humphrey kiln; the amount of internal and external recycle required for good carbon burnout compared to none planned for the Humphrey unit; the fact that almost all of the ash leaves the PEDCO unit as fly ash, whereas, in the Humphrey unit, it was anticipated that most of the ash would be bottom ash with minimal fly ash; and the importance of balancing heat removal with the combustion process to achieve steady-state operation. All of these factors must be considered, both individually and collectively, as they relate to each other.

The March tests raised some basic questions regarding the feasibility of the kiln for combustion of solid fuels. This is not to say that rotary reactors, in general, and the PEDCO, in particular, could not afford efficient combustion of these fuels; but the conditions and configurations that are needed towards this end must be carefully assessed. At this point the items that were of greatest concern to us and that we were attempting to address were as follows:

- (1) Could the PEDCO unit, specifically, be modified to provide efficient combustion of anthracite culm?
- (2) Could a rotary-type kiln, in general, be configured to afford efficient combustion of poor-grade, hard-to-burn fuels in general, and anthracite culm in particular?
- (3) Could the Humphrey unit, incorporating the UEI air distributor, be configured in a manner affording efficient combustion of anthracite culms? Would it have any particular advantage over the configurations considered under (1) and (2) above?
- (4) In light of all these, could a rotary-type reactor have any significant advantages over the circulating fluid bed in combustion of hard-to-burn, low-grade fuels like anthracite culm?

In light of the PEDCO tests a number of internal discussions were also held to address the following issues:

- * The role of the UEI air distributor.
- * The ability of anthracite culm to burn acceptably in a kiln combustor.
- * The range of natural properties of anthracite culm.
- * The range of feedstocks, configurations and conditions for acceptable operation of a kiln combustor.

The initial tests conducted in March demonstrated that the PEDCO unit was not properly configured for the combustion of anthracite culm; therefore it was not possible to achieve a sustained period of steady-state combustion.

Subsequent discussions with PEDCO identified several issues that could have an impact on the capability to burn anthracite culm; specifically, questions were raised concerning the specifications of the anthracite culm itself and some relating to the equipment. PEDCO was planning some changes in the rotary boiler itself which, in addition to suggested operational changes, they felt, could go a long way towards improving the combustion of anthracite culm. The modifications included changes in the ash-handling equipment, the ability to "blind" some of the heat-transfer surface, the use of supplemental fuel during start-up, and the preparation of the feed (drying and sizing to smaller particles).

The anthracite culm delivered to PEDCO was wet, (with more than 10 percent moisture), and coarser than feed material routinely used for fluidized-bed boilers. It was felt that using finer fuel and ensuring that it was largely dry, would aid the combustion of anthracite culm.

Equipment changes focused on providing better recycle of ash, both internally as well as external recycle of ash leaving the system. Steam production capability was also increased. The specific changes included: (1) installing a cyclone in the fly ash line to the baghouse in order to recycle fly ash to the kiln, (2) enlarging the bottom ash recycle line to increase the bottom ash recycle rate, and (3) reducing the inlet opening on the feed end of the internal solids recirculation chute and increasing the size of the opening to the last (boiler tube) section of the recirculation chute. The last modification was intended to increase the flow of hot solids to the rear boiler tube section, and therefore, increase steam production.

Increasing the recycle of fly ash and bottom ash would aid in the combustion of the anthracite culm, but the increase in steam production increased heat removal from the kiln which proved detrimental for culm combustion. However it was the prospect of using a drier, finer anthracite culm that was the most compelling reason to conduct additional tests. It was possible that if the feed material had been dry and finer sized, sustained combustion could have been achieved. Accordingly, the decision was made to conduct an additional campaign of tests that would incorporate these changes.

3.4.2 Frackville Culm Tests, July 1991

The additional tests, conducted on July 16 and 17, 1991, involved an anthracite culm that was obtained from a fluidized-bed boiler facility in eastern Pennsylvania. The "Frackville" culm had a heating value of 3,018 Btu/lb and came with a top size of 1/4-inch. A chronology of the tests is included in Appendix B.

Initially, the bed inventory was kept at minimum level in order to allow the culm to accumulate in the kiln, without causing problems with the hydraulic drive unit. The test was started by feeding a 50/50 blend of culm and bituminous coal for approximately two hours. Once the feed hopper was emptied, the Frackville culm was loaded and fed at the rate of 1,000 lb/hr (3,500,000 Btu/hr). Within 15 minutes the kiln temperature began to drop and supplemental fuel was required. Natural gas was fed at the rate of 1,400,000 Btu/hr while No. 2 fuel oil was fed at the rate of 10,000,000 Btu/hr. Over the course of the next several hours, a number of attempts were made to reduce the amount of supplemental fuel in conjunction with changes in the culm feed rate. Each attempt soon led to a decline in temperature. After several hours, the test was terminated. During the test, the steam rate varied from 6,257 to 7,664 lb/hr.

Subsequently, North American Rayon's operating personnel suggested two additional operational changes that might promote combustion: increasing the bed inventory and the kiln rotational speed. The bed inventory had been kept low because of the previous problems with the hydraulic drive system. It was decided that a larger bed inventory could act as a heat sink, holding more heat in the kiln. The larger bed inventory would be achieved by increasing the culm feed rate. The increase in speed would improve the gas/solids mixing. It was also agreed to increase the use of supplemental fuel in order to maintain the kiln temperature at 1700-1750°F, which is higher than normal. A test was run the following day incorporating these changes. The culm feed rate was 3,000 lb/hr (10,500,000 Btu/hr), while the natural gas and No. 2 fuel oil were each fed at the rate of 14,000,000 Btu/hr. The steam rate was 6,257 lb/hr. The results were the same as the previous day. Combustion without the use of supplemental fuel could not be sustained. Any attempt to reduce supplemental fuel resulted in a sharp drop in temperature.

Fly ash and bottom ash samples (see Table 6), as well as operating data were collected during the tests.

Changing the fuel and altering various operational procedures were intended to achieve sustained combustion. However, despite these changes sustained combustion could not be achieved without the use of large quantities of supplemental fuel. In the end, the July tests were destined to fail as a result of the modifications made to increase steam production. Based on bituminous coal runs made just prior to the July tests, steam generation was increased approximately 59 percent, from 4269 to 6772 pounds per hour. Since we could not achieve combustion at the lower steam rate, removing even more heat to support this large increase in steam production meant we could not achieve sustained combustion. This increase also meant a corresponding increase in

the bed carbon level to between 45 and 50 percent. This carbon level would be totally unacceptable in any steam or power plant operation.

TABLE 6. DATA FROM JULY 16-17, 1991

<u>Time</u>	<u>Percent LOI</u>	
	<u>Bottom Ash</u>	<u>Flyash</u>
<u>July 16</u>		
1:40 PM	6.4	22.8
3:17 PM	15.9	22.9
5:02 PM	12.2	29.3
<u>July 17</u>		
10:58 AM	20.7	28.6

If enough heat could be retained in the kiln, it might be possible to burn anthracite culm in the rotary kiln boiler. For example, based on the above data, in order to have any chance of burning anthracite culm, sufficient tubes would have to be removed from the PEDCO kiln tube bundle to reduce steam generation to something like 1000 to 1500 pounds per hour. This would, of course, mean that the unit would be uneconomical and could not compare favorably against any other current technology. It should be noted that the possibility of removing steam tubes was discussed with plant personnel, but because of the difficulty, was never seriously considered by them.

Based on these tests, we conclude that the PEDCO rotary kiln boiler, as configured, is ill suited for the combustion of hard-to-burn, low-grade solid fuels like anthracite culm.

3.5 Conclusions

At the outset of this project, we perceived several potential advantages for combustion in a rotary kiln. These included: simple design and easy maintenance and operation, efficient combustion, good control of emissions, and the capability to consume a broad range of fuels of various types. Given all these, the rotary kiln may be competitive and, perhaps in some instances, even superior to fluid-bed boilers. The "open" design of the tubular kiln suggested a capability to accommodate unconventional fuels, including sludge, solid waste, and tires. Indeed, there are many instances in which rotary kiln combustors have been used successfully towards these ends; but our goal was to study the combustion of anthracite culm. The results of our tests suggest that with respect to these low-grade, hard-to-burn fuels, the rotary kiln boiler may be ill-suited. As noted above, the "open geometry" of the kiln earmarks it for applications involving mass burn of bulky fuels and wastes.

APPENDIX A

HUMPHREY CHARCOAL ROTARY KILN TEST PROGRAM

The Humphrey Charcoal kiln was built in 1981 by the Industrial Boiler Company, Thomasville, Georgia. The unit was designed to carbonize 100 tons per day of wood waste to produce process heat, gas and carbon products (charcoal). It should be noted that the unit was never able to achieve the design production level. The kiln was operated for approximately five years until the price of charcoal, on the open market, fell below the cost of producing charcoal in the kiln.

The refractory lined kiln is 24 feet long with a diameter of 9 feet. The kiln was set at a fixed inclination of 1.5 degrees and normally operated at 1.5 rpm. At this speed and incline, material residence time was approximately 15 minutes. It was anticipated that the residence time would have to be at least doubled for coal combustion. When operating on sawdust, kiln combustion is controlled through feed rate and airflow. Airflow is increased to increase kiln temperature; the feed rate is increased to decrease kiln temperature. With sawdust, increasing the feed rate is really increasing the amount of moisture in the kiln which decreases combustion. The kiln was not equipped with any heat removal system. When producing charcoal, a duct from the stack diverted some of the exhaust gases for space heating purposes.

The operating temperature of the kiln, for coal combustion, was restricted to about 1600 F. Other work had shown that the most effective temperature for sulfur capture, through limestone utilization, is approximately 1600 F. Also, to prevent the formation of ash clinkers the kiln temperature would have to be maintained below about 1800 F. The fact that the kiln had no internal heat absorbing surfaces and the need to operate at 1600 F, placed a limit on the amount of heat that could be released in the kiln. Thus it was necessary to consider only fuels with minimal heating value.

The UEI air distributor was claimed to improve combustion, provide greater control of the combustion process, and minimize emissions. It was claimed that the air injector could control the degree of combustion taking place by regulating the amount of air supplied to four individual zones. The four zones were identified as: an initial drying zone, a devolatilizing zone, a fixed carbon combustion zone, and an ash-cooling zone. The length of these zones could be adjusted by regulating the air supply to each. The air distributor was also thought to control particulate emissions. The airflow entering the kiln is directed tangentially to the kiln wall. This swirling air pattern carries the airborne particulates towards the kiln wall, and minimizes the amount of particulate leaving the kiln.

As work proceeded during the early phases of the project, and details of the process were defined, a number of issues and questions were raised regarding basic operation and operability of the Humphrey kiln and the appropriateness of the equipment. The following summarizes specific items in two major areas; test equipment, and process analysis and design.

TEST EQUIPMENT

The original program was predicated on the fact that a substantial amount of equipment would not have to be purchased new. However, in the course of defining the combustion process it became apparent this was not the case and alternative approaches were developed. An equipment summary follows.

Rotary Kiln: It was anticipated that the kiln required new seals, a variable speed drive motor, and secondary air blower. Once work began, it was learned that a large portion of the internal refractory also had to be replaced.

Air Distributor: Fabrication of the UEI air injection system was completed. However in the process of confirming construction specifications, prior to shipment, a number of questions were raised. UEI never responded and as a result the unit was never shipped to Humphrey Charcoal Co.

Particulate Control System: Initially the particulate control system, required by the Pennsylvania Department of Environmental Resources, was to be comprised of refurbished used equipment. This included the baghouse, gas coolers, and induced draft fan. Unfortunately, it was discovered that the equipment, except for the baghouse, was either in very poor condition or of improper size and/or design for the process. Alternatives were investigated, but no decisions were made prior to the PEDCO tests.

PROCESS ANALYSIS AND DESIGN

As process development evolved, a number of issues were raised regarding the use of kilns for coal combustion, in particular the Humphrey kiln, and specific technical areas that had not previously been considered. Below we relate observations concerning the following issues:

- (1) Role of staged air injection in the combustion process.
- (2) Ability of anthracite culm to burn acceptably in a kiln combustor.
- (3) Range of operating parameters including configurations and conditions for acceptable operation of a kiln combustor.

Staged Air Injection: Contrary to claims, the UEI air distributor is not expected to provide much additional agitation of the bed. Mixing of the bed is derived from the rotation of the kiln and the rolling and tumbling of the bed. The staged injection of air is perceived to be the main role of the UEI air distributor. However, does the air injector provide sufficient gas/solids contact for combustion? Staged air injection appears to be most useful in controlling the temperature profile within the kiln which can reduce the amount of NO_x production from oxidation of gaseous N_2 . The oxidation environment can also be controlled by staged air injection at various points during solid fuel conversion. This allows fuel-bound nitrogen to pass through optimal situations to minimize the production of NO_x .

Some people claim to be well aware of the effectiveness of staged air injection for these purposes and its use in other types of combustors. It was reported that two companies, Bio-Energy and Callidus, specify it in rotary kiln combustors, based upon their observations of its apparent effectiveness in systems already in operation. For example, in early 1991 it was learned that both firms were collaborating with a major engineering contractor on developing a municipal solid waste incinerator complex in Rhode Island. In 1991 the project was nearing the letting of contracts to design and build two rotary kiln combustors with staged air injection.

Combustibility of Anthracite Culm: Because of the extremely low volatile matter content of the anthracite culm, there was a question of whether the culm could maintain a flame and sustain combustion. This was particularly of concern because of the low-rotational speed of the Humphrey kiln and the poor gas/solids contact afforded by the overall system.

Range of Operating Parameters: Bio-Energy and Callidus made the following points regarding the relative flow of air and solids, the oxygen level, and the range of feedstock for kiln combustors:

- Countercurrent operation is specified when wet material is fed, which needs extensive drying. It is also acceptable when the combustion conditions are well under control in an oxygen-deficient mode, such as pyrolysis or gasification.
- Concurrent operation is specified when volatile materials with high heating values are burned with excess oxygen. This mode prevents the concentration of the flame in the feed-entry/gas-exit region of the kiln, which can lead to incomplete conversion of the solid fuel.

- Where possible, it is always advisable to operate the kiln combustor in a gasification mode for temperature control and complete the combustion of the resulting fuel gases in a second burner unit.
- All types of solid fuels, from tires and plastic wastes to contaminated earth can be burned successfully in a rotary kiln combustor. Tires are especially attractive to provide a highly volatile component for co-combustion with a low volatile material or one with a low heating value.

In addition, concurrent flow of gas and fuel should be specified if long gas retention times are desired or the fuel has a large amount of volatiles.

It should be noted that the feed system for the Humphrey Charcoal kiln was countercurrent while the PEDCO unit was concurrent.

APPENDIX B

CHRONOLOGY OF PEDCO ROTARY KILN TESTS

March 5, 1991

At approximately 10:00 a.m., began feeding the Emerald anthracite culm (3500 Btu), feed rate approximately 425 lb/hr

10:24 a.m.	Increased the feed rate to 880 lb/hr
10:30 a.m.	Began dumping bottom ash to counter an increase in the hydraulic pressure (which reflected a decrease in kiln rpm)
10:35 a.m.	Culm feed rate 937 lb/hr, Limestone 64.4 lb/hr
10:36 a.m.	Increased feed rate to 995 lb/hr, steam rate (channel 10) 4240 lb/hr
10:54 a.m.	Temperature dropping fast, TY-1 (near exit of kiln) 1303°F, began co-firing with gas initially and shortly thereafter waste oil
10:57 a.m.	Culm feed rate reduced to 550 lb/hr
11:19 a.m.	Still co-firing with gas and oil, but the temperature continues to decline, TY-1 1458°F
11:30 a.m.	Cut the steam rate to keep heat in the kiln by pushing all the solids to the front of the kiln
11:54 a.m.	Gas was turned off and the oil was reduced to about a "quart-per-hour", the temperature appeared to stabilize, but then started dropping again
12:39 p.m.	Decided to attempt to burn the Jeddo culm (7000 Btu), continued to burn the Emerald culm, supplemented with 30-weight waste oil flowing in a stream approximately ½-inch diameter, combustion was stable with 50 percent ash recycle, TY-1 running approximately 1550°F
1:15 p.m.	Loading Jeddo culm into the hopper
1:21 p.m.	Feeding Jeddo culm, co-fired with oil
1:22 p.m.	Oil turned off, feed rate 809 lb/hr, limestone 49.5 lb/hr
1:30 p.m.	Temperatures falling TY-1 1606°F, increased feed to 1222 lb/hr, limestone 49.5 lb/hr

1:39 p.m. Temperatures continuing to fall TY-1 1495°F, began co-firing with oil, culm feed rate 1500 lb/hr, limestone 49.5 lb/hr

2:30 p.m. Feed rate reduced to 809 lb/hr

3:00 p.m. Feed rate reduced to 441 lb/hr because kiln rpm was dropping, hydraulic pressure increasing due to the build up of ash in the kiln

3:30 p.m. Reduced airflow to kiln by adjusting damper on ID fan (setting of 18), 18 rpm, culm feed rate 468 lb/hr, limestone 49.5 lb/hr, steam 6000 lb/hr

3:35 p.m. Limestone turned off to reduce flow of solids into the kiln, vane adjusted to keep solids to the front of the kiln to reduce steam production

3:48 p.m. Culm feed rate 800 lb/hr

3:50 p.m. Temperature dropping, TY-1 1430°F

3:51 p.m. Feed rate increased, up to 880 lb/hr, trying to maintain temperature

5:51 p.m. Dumped about 200 lb of bottom ash from kiln door

5:52 p.m. Flow of bottom ash to dumpster about 500 lb/hr, recycling about 50 percent of fly ash

5:54 p.m. Temperature dropped below 1400°F, began co-firing with oil to try to increase the temperature, also increased the feed rate to 1100 lb/hr

Note: Could not record data from Molytech at 5:15 p.m. and 5:45 p.m. because of problem with kiln speed, build up of ash

6:15 p.m. Temperature dropping again, culm feed shut off and began firing gas, feed on again at 6:30 p.m.

8:01 p.m. Removed about 300 lb bottom ash from the kiln door

8:20 p.m. Continued to co-fire gas, temperature bottomed out at 1278°F (TY-1) and increased to 1400°F, test terminated

The Jeddo culm remaining the hopper was burned, co-firing with gas, and the kiln was shut down to repair several new "hot spots" on the outer shell; at the same time the ash was removed from the kiln. The kiln was restarted with the baseline North American coal. In anticipation of our test on Thursday, the steam rate was kept low along with the coal feed rate and bed inventory.

March 7, 1991

10:45 a.m. Started feeding test fuel, a mixture of 25 percent North American coal (13,000 Btu) and 75 percent Emerald culm (3500 Btu); the blend was measured and mixed using a front-end loader, calculated Btu value 5875.

11:29 a.m. Began feeding test fuel to the kiln

11:38 a.m. Began taking bottom ash to the dumpster

11:55 a.m. Culm feed rate was ramped up to 1000 lb/hr, from 400 at the start

Note: The material is so wet you can make a ball of it; also sticking to the sides of the hopper

12:20 p.m. Limestone feed turned off to reduce flow of ash into the kiln

12:40 p.m. Temperature declining, TY-1 1507°F, began co-firing with gas

1:30 p.m. Continue to co-fire with gas, 6.0 scfm, 10 psi, 1590 Btu/scf, approximately 500,000 Btu/hr

1:45 p.m. Culm feed rate 1600 lb/hr, limestone turned on 16 lb/hr

2:30 p.m. Bottom ash flow rate checked , 404 lb/hr

2:51 p.m. TY-1 up to 1650°F, gas turned off

2:58 p.m. Steam DP gage reading 42

3:00 p.m. Temperatures beginning to increase rapidly, culm feed turned off

3:08 p.m. Temperatures increasing very rapidly, TY-1 1788°F directing material out of the bed to the rear to increase steam production, decreased air, steam DP gage reading 64 (steam rate lb/hr = 885 DP) 7080 lb/hr

March 7, 1991 (continued)

3:23 p.m. Steam DP gage reading 42 (5735 lb/hr)

Note: From 3:25 to 4:10 p.m., bed material was allowed to burn out, as it burned and the bed inventory was reduced, the rpm slowly increased (without adjusting the hydraulic pressure), as the rpm increased more bed material was burned.

4:10 p.m. TY-1 1666°F, rpm 16.2, and steam DP gage reading 41 (5666 lb/hr)

4:14 p.m. Feed turned on at rate of 900 lb/hr, 17 rpm, TY-1 at 1650°F, as soon as the feed was turned on the temperature began increasing so the feed was turned off

4:16 p.m. Feed turned on, 552 lb/hr, steam DP gage reading 38 (5455 lb/hr)

4:17 p.m. Feed rate decreased to 300 lb/hr, TY-1 1662°F, 18 rpm

Note: The fuel is obviously much dryer, can no longer make a ball

4:25 p.m. Feed rate increased to 1079 lb/hr, TY-1 1652°F, 18.8 rpm, steam DP gage reading 34 (5160 lb/hr)

4:38 p.m. Started recycling bottom ash to the kiln

4:40 p.m. Starting to lose temperature, so the ash recycle was turned off, temperature seemed to stabilize TY-1 1620°F

4:45 p.m. Feed rate 1662 lb/hr, TY-1 1626°F, 17.9 rpm, steam DP gage reading 30 (4847 lb/hr)

4:59 p.m. Gas co-firing to maintain temperature, rpm decreasing, adjusted hydraulic pressure to maintain speed as the bed inventory increases

5:20 p.m. Gas turned off

6:00 p.m. Baghouse dust rate 222 lb/hr

6:15 p.m. Bottom ash rate 600 lb/hr

6:20 p.m. Temperature began increasing again, feed turned off, steam production increased

Note: At this point, the test was concluded; the earlier temperature excursion was repeated. No fuel was fed for about one hour. After control was regained, the culm feed was re-established and it burned without gas until the hopper was empty, about 11:00 p.m.

GENERAL COMMENTS ON THE MARCH 1991 TEST

1. During the tests, the hydraulic pressure was continually being adjusted. The situation was probably exaggerated by the high ash content of our fuel and the continual increase in bed inventory.

2. At the start of testing on the 5th, unknown to us, our first problem was the bed inventory was too great, the ash level quickly increased and choked the system. PEDCO personnel later indicated they thought they could handle the ash, and were surprised they didn't. It was felt that if the bottom ash blower and piping were increased in size for both the recycle and dump, the system could handle the high-ash material.

3. On March 7, 1991, after the first temperature excursion, NARCO plant personnel felt that gas co-firing was needed only because at a critical point we encountered feed problems, sticking in the hopper, where the feed was very erratic for a period of 5 to 10 minutes.

4. A second batch of the 75/25 blend was prepared, placed in the hopper, and began feeding shortly after the first temperature excursion. This batch was prepared using dry North American coal and the tops off the piles of the Emerald culm. The material seemed to be drier coming out of the hopper.

5. Following the test of Tuesday, NARCO personnel reported that when the kiln was emptied they found many rocks that were too big to escape, thus the increase in hydraulic pressure. Following Thursday's test, they reported the ash looked very good and it was left in the kiln to act as the bed for startup the next day. It is believed the rocks came from the Jeddo culm, which was burned on Tuesday, but not on Thursday.

6. NARCO did try to recycle bottom ash twice on Thursday, the first time was after the first temperature excursion when the temperature immediately started to decline; the second was later in the evening and there was no change in the temperature.

7. The kiln temperatures TY-1, -2, -3, and -4 are related to kiln speed, but it is unclear how much is related to combustion and how much is due to the cascading material hitting the thermocouple.

8. For our purposes, ash removal was a problem because they have no good way of substantially reducing the bed inventory while the kiln is hot and running.

9. During the tests, limestone feed was erratic because the combustion problems overshadowed the need to obtain sulfur capture data on a material which contained very little sulfur.

July 16, 1991

The test was started by going from burning coal to burning a 50/50 blend of coal and Frackville culm to burning only culm.

1:00 p.m. Burning a 50/50 blend of bituminous coal and Frackville culm. Bed inventory low, hydraulic pressure 1300 psig, kiln speed 18 rpm, feed rate 800 lb/hr, temperature TY-1 1800 F

1:40 p.m. Bottom ash and fly ash samples taken for the 50/50 blend

1:45 p.m. Kiln temperature beginning to drop, kiln rpm reduced in an attempt to maintain temperature

2:00 p.m. Temperature TY-1 1596 F, began co-firing natural gas, between 2:00 and 2:30 p.m. TY-1 fluctuated between 1570-1610 F

2:33 p.m. Began feeding 100 percent Frackville culm, feed rate 3000 lb/hr, continued co-firing natural gas at the rate of 10 scfm (1,400,000 Btu/hr) and began co-firing oil

3:03 p.m. Feed turned off in an attempt to increase temperature, TY-1 1593 F

3:10 p.m. Started second drum of oil

3:32 p.m. Temperature TY-1 1691 F

4:00 p.m. Culm feed resumed, 1100 lb/hr, continued cofiring with oil but gas turned off

4:30 p.m. Oil turned off, culm feed rate maintained at 1100 lb/hr

4:36 p.m. Temperature began dropping, resumed co-firing with oil

4:51 p.m. Co-firing oil at the rate of 103 gallons per hour (10,000,000 Btu/hr)

5:12 p.m. Ran out of oil and temperature immediately began to fall

5:28 p.m. Resumed co-firing oil, culm feed rate 1500 lb/hr

5:45 p.m. Culm feed rate increased to 3500 lb/hr, temperature TY-1 1703 F

5:55 p.m. Temperature began dropping, culm feed turned off and temperature recovered, culm feed turned back on and within 5 minutes temperature began to fall, and test terminated.

July 17, 1991

NARCO operating personnel suggested two operational changes that they believed could enhance combustion of the culm: (1) increase the kiln speed, rpm, to increase mixing and gas/solid contact, and (2) increase kiln temperature by increasing the bed inventory which would act as a heat sink. Supplemental fuel would also be used to operate the kiln at higher than normal temperatures, 1700-1750 F.

The test was started with the Frackville culm, 3,000 lbs/hr feed rate, 2,000 psig hydraulic pressure, 19.9 rpm kiln speed, temperature TY-1 1700 F, and co-firing both gas and oil. After a short period the temperature declined to 1550 F at which time the culm feed was turned off and the test terminated.

APPENDIX C

COMBUSTION CALCULATIONS FOR BITUMINOUS COAL AND JEDDO ANTHRACITE CULM

SUMMARY OF RESULTS OF BITUMINOUS COAL RUN ON PEDCO RCBB
MARCH 5, 1991 - 1:00 A.M. TO 10:00 A.M.

Input Data

Coal feed rate	452.3 lb/hr
Limestone feed rate	44.2 lb/hr
Air feed rate	6759.9 lb/hr
Inlet air temperature	70.3° F
Excess air	76.4 %
Feed water temperature	244° F

Output Data

Flue gas flow, dry	6897 lb/hr
Flue gas analysis (dry)	
by volume, %	
CO ₂	9.77
O ₂	9.39
CO	0.004
N ₂	<u>80.836</u>
	100.000
Gas temperature leaving Economizer	380° F
Steam flow	4269 lb/hr
Steam temperature	508.2° F
Steam pressure	156.9 psia
Ash flow	148.3 lb/hr
Carbon in fly ash	29.0 %
Carbon combustion efficiency	86.3 %

Material Balance

Input, lb/hr

Coal Feed	452.3
Air (1475 scfm)	6759.9
Limestone	<u>44.2</u>
Total input	7256.4

Output, lb/hr

Dry flue gas	6897.0
Water in flue gas	210.4
Refuse	<u>148.3</u>
Total output	7255.7

Carbon Balance

Input, lb/hr

Coal feed	314.4
Limestone feed	<u>4.3</u>
Total input	318.7

Output, lb/hr

Carbon in ash	314.4
Flue gas	
CO ₂	272.5
CO	0.1
CaCO ₃ in ash	<u>1.9</u>
Total output	317.5

Heat Balance

Input

Coal 452.3 x 11810	5,342,000 Btu/hr
--------------------	------------------

Output

Steam (3480.5 lb/hr)	3,810,800 Btu/hr
----------------------	------------------

Losses, Btu/hr

Dry flue gas	519,800
Moisture in fuel	39,500
H ₂ in fuel	213,100
Carbon in fly ash	623,900
CO in flue gas	1,000
Sensible heat in fly ash	9,100
Radiation loss	<u>124,000</u>

Total losses 1,530,500

Total Output 5,341,300 Btu/hr

**PROJECTED RESULTS FOR OPERATION OF THE PEDCO RCBB ON
ANTHRACITE CULM
(Based on Experience of March 3-7, 1991 Test Runs)**

Input Data

Culm feed rate	1000 lb/hr
Limestone feed rate	-0-
Air feed rate	5068 lb/hr
Inlet air temperature	70°F
Excess air	80 %
Feed water temperature	244°F

Output Data

Flue Gas Analysis, dry %	
CO ₂	11.21 (includes SO ₂)
O ₂	9.35
N ₂	<u>79.44</u>
	100.00

Gas temperature leaving economizer	380°F
Steam flow	3480.5 lb/hr
Steam temperature	508.2°F
Steam pressure	156.9
Air flow	5286.5 lb/hr
Fly ash flow	237.0 lb/hr
Bottom ash flow	355.6 lb/hr
Total ash flow	592.6 lb/hr

Carbon in fly ash	30 %
Carbon in bottom ash	25 %
Carbon combustion efficiency	59.2 %

Material Balance

Input, lb/hr

Coal feed	1000.0
Air	<u>5068.0</u>
Total	<u>6068.0</u>

Output, lb/hr

Dry flue gas	5286.5
Water in flue gas	188.2
Fly ash	237.0
Bottom ash	<u>355.6</u>
Total	<u>6067.3</u>

Carbon Balance

Input, lb/hr

Carbon in coal	<u>392.6</u>
----------------	--------------

Output, lb/hr

Carbon in CO ₂ in flue gas	232.0
Carbon in fly ash	71.1
Carbon in bottom ash	<u>88.9</u>
Total	<u>392.0</u>

Heat Balance

Input, Btu/hr

Coal - 1000.0 x 6926	6,926,000
----------------------	-----------

Output, Btu/hr

Steam - 3480.5	3,810,800
----------------	-----------

Losses

Dry gas loss	392,000
Moisture in fuel	35,300
H ₂ in fuel	189,800
Combustibles in fly ash	1,031,300
Combustibles in bottom ash	1,288,900
Sensible heat in fly ash	13,900
Sensible heat in bottom ash	39,500
Radiation loss	<u>124,000</u>

Total losses 3,114,700

TOTAL OUTPUT 6,925,500

APPENDIX E

GENERAL ASPECTS OF ROTARY COMBUSTORS

The rotary kiln incinerator is the only incinerator system that can literally be used to burn any and all different types of wastes. This includes industrial, municipal and hazardous wastes with heating values ranging from 1000 to 15,000 Btu/lb. The rotary kiln has been used for the disposal of materials ranging from liquids and gases to sludges and solids; from liquids that are sprayed into the kiln to entire drums that are dropped in. It is this versatility that makes kilns the choice for those systems that must be capable of burning more than a single waste stream. Although kilns are primarily used for the incineration of solid wastes, liquid wastes are burned, even as auxiliary fuel. It is the flexibility of the kiln to accept a wide variety of sludges and solids that make it so popular. This is particularly true of large bulk solids and containerized waste that does not have to be rehandled. The only type of waste that creates problems in a kiln are aqueous organic sludges that become sticky when dry and form a ring around the kiln refractory.

A typical rotary kiln system consists of the feed system, air supply, the kiln, an afterburner, and the emissions control system. The emissions control system includes an induced draft fan, ash collection system, scrubber and baghouse. A waste heat boiler, to recover energy for steam or power production, may also be installed between the afterburner and the scrubber. If the combustion gases leaving the kiln have a high enough heating value no supplemental fuel is required for complete combustion in the afterburner. However, most systems do require the use of at least some supplemental fuel to complete combustion in the afterburner.

The "typical" rotary kiln incinerator is a horizontal cylinder with a length/diameter ratio between 2/1 and 5/1, lined with refractory, and rotating in the range of 0.75 to 2.5 rpm. The kiln is inclined and together with the rotational speed determines the residence time. The incline, or rake, will vary from 2 to 4 percent (0.25 to 0.5 in/ft of length). Waste is fed in at one end of the kiln (feed end is located at the elevated end of the kiln) and is burned out by the time it reaches the discharge or lower end. Typical heat release rates for a kiln vary from 15,000 to 30,000 Btu/(ft³ hr).

The physical size of the kiln depends on the design capacity; typically a kiln can range in size from one with an internal diameter of 4-5 feet and length up to 3-5 times the diameter to kilns with a diameter up to 8-9 feet and a length 3-4 times the diameter. A minimum size would be of the order of 4 feet diameter and 12-16 feet long. Based on a capacity of 12-18,000,000 Btu/hr, the kiln would be approximately 7 feet in diameter and 22 feet long. One of the largest kilns, located in Texas, is rated at 75,000,000 Btu/hr.

Physical size is also related to heat release and internal gas velocity. Gas velocity is important because the very fine ash generated when burning solids or sludges can easily be carried out of the kiln into the secondary combustor (afterburner) and particulate control system. Based on a heat release of 15,000 Btu/hr-ft³, an internal velocity of 12-15 fps, at operating temperature, would be reasonable. This would limit the L/D ratio to 3/1; an increase in the L/D ratio to 4/1 would mean the velocity would be increased by 1/3, resulting in excessive particulate carryover.

Kiln operating temperatures are determined by the waste to be burned, that is the temperature and residence time required to destroy hazardous components, and whether the kiln will be operated in the slagging or nonslagging mode. Typically values range from 1500 to 3000F. There is usually a temperature gradient through the kiln, with the highest temperature being 400-500F greater than the exit temperature.

The residence time of solid materials is controlled by the kiln rotational speed and the slope or rake of the kiln. The following equation can be used to estimate the solids residence time:

$$T = \frac{0.19 L}{NDS}$$

where T = retention time, min
L = kiln length, ft
N = kiln rotational velocity, rpm
D = kiln diameter, ft
S = kiln slope, ft/ft

The constant 0.19 is estimated from experimental data and varies. Other values are reported in the literature so that the residence time calculation is really only an estimate.

The residence time for liquids and volatiles is based on the internal gas velocity.

Most kilns are lined with a smooth refractory. For granular material, such as dirt or powders, internal vanes or paddles are sometimes added to enhance turbulence. Care must be taken since these baffles may actually retard the movement of material.

Regardless of the type of waste being burned, each kiln is supplied with an auxiliary fuel. There are four specific conditions which require the use of an auxiliary fuel:

Cold Start -- A temperature of 1300-1400°F must typically be reached before waste can be introduced to the kiln, the kiln is heated to operating temperature using the auxiliary fuel.

Controlled Shutdown - When the kiln is going to be shutdown, all waste material must be burned out at operating temperature, so auxiliary fuel is used to maintain combustion temperatures during the rampdown when waste is no longer being fed.

Feed Interruption - Auxiliary fuel is used to maintain combustion temperatures if there is an unscheduled interruption in the waste material feed.

Augment Waste Btu - A waste material must contain at least 4,500 Btu/lb to sustain combustion, auxiliary fuel is used if the waste material is unable to sustain combustion.

Typically, either oil or natural gas is used as the auxiliary fuel. Auxiliary fuel is used only to the extent necessary, so a good operation would use very little. The auxiliary fuel must be able to respond quickly, upon demand, to either increase or decrease the operating temperature.

The principal variations in kiln design include:

Gas flow in relation to waste flow, countercurrent or concurrent;

Ash handling, slagging or nonslagging mode; and

Lining of the kiln, refractory, or bare wall.

When gas flow through the kiln is in the same direction as the waste stream, the kiln is referred to as having concurrent flow. Countercurrent flow is when the waste stream and gas flow in opposite directions. Countercurrent flow is specified when the waste material contains a substantial amount of moisture, at least 30 percent. In this case the hot combustion gases exiting the kiln are able to dry the wet incoming feed material to promote more rapid ignition. If the wet material was fed into a concurrent kiln, the cool combustion gases in conjunction with the wet feed material would result in very cool entrance temperatures. In order to compensate for the low temperatures, a much longer kiln would be needed to insure complete burnout of the waste. Concurrent kilns are used when the waste contains light volatile fractions which will be released immediately upon entering the kiln. This early release of volatiles, despite lower feed end temperatures, provides greater residence time and therefore adequate burnout of the volatile fraction. In addition, if the volatile material was fed countercurrently, the rapidly released volatiles would become entrained in the exiting gases and enter the afterburner before they could be burned.

Kilns can be designed to operate in either a slagging or nonslagging mode. Very simply, if the kiln temperature is high enough, the ash will become molten. However, since each system involves unique design features, operating problems will occur if a nonslagging kiln is operated as a slagging kiln or vice versa. Each system has specific advantages and disadvantages; the system used is dependent on the projected use of the kiln.

Operationally, a slagging kiln would be favored particularly where the waste involves bulky containers, such as drums, or salt-laden wastes. Dropping drums into a nonslagging kiln can result in damage to the refractory lining, and localized heating can result in an explosion. Also, the drum may have a tendency to simply roll through the kiln resulting in insufficient residence time. Steps must be taken to insure sufficient residence time to accomplish complete burnout of the drum and contents. In a nonslagging kiln salt-laden wastes can cake or result in deposits building-up on the kiln walls. In a slagging kiln, the temperature is high enough to keep the salts molten and they simply run out with the molten ash.

Design and operating parameters for slagging and nonslagging kilns are summarized in the following Table.

PARAMETERS FOR SLAGGING AND NONSLAGGING KILNS

<u>Parameter</u>	<u>Comment</u>
Construction	More complex with slagging kiln.
Duty	Slagging kiln can accept salts and drums; nonslagging kiln is limited.
Temperature	Higher with slagging kiln.
Retention Time	Greater residence time required for nonslagging kiln.
Process Control	Thermal inertia or forgiveness in nonslagging kiln.
Emissions	Less particulate, greater NOx from slagging kiln.
Slag	Slagging kilns may require use of additives such as CaO, Al ₂ O ₃ , SiO ₂ , to maintain molten slag; dissolves drums and salts.

PARAMETERS FOR SLAGGING AND NONSLAGGING KILNS - Continued

<u>Parameter</u>	<u>Comment</u>
Ash	Wet and less leachable with slagging; wet or dry with nonslagging kiln.
Maintenance	More with slagging kiln.
Refractory	More critical with slagging kiln.

Advantages of the rotary kiln for waste incineration include:

Accepts a wide variety of feedstocks which can be burned simultaneously;

Minimal waste preprocessing required;

Varied feed mechanisms available to suit needs (rams, screw, gravity, direct injection of liquids, sludges);

High operating temperatures;

Uniform and continuous mixing of incoming feed;

Easy control of residence time; and

Better volatilization of unpumpable waste than stationary or fixed-hearth incinerators.

Disadvantages of the rotary kiln system include:

High maintenance and operating costs;

High particulate carryover because of turbulence of waste stream;

Afterburner normally required for destruction of volatiles;

Minimal ability to control conditions along the length of the kiln;

Requires a large amount of excess air (normally 100 to 150 percent of stoichiometric);

High temperature seals are difficult to maintain and pose potential hazard of uncontrolled emissions;

Significant amount of heat lost in the ash discharge; and

Abrasive or corrosive conditions within the kiln result in high maintenance costs for refractory lining.

APPENDIX F

RELEVANT ROTARY KILN LITERATURE

Introduction

Thermal treatment (pyrolysis) and combustion of solid materials are the two major processing functions carried out in rotary kilns. Common examples are:

- lime manufacture; [1,2]
- Portland cement manufacture; [3,4]
- decontamination of hydrocarbon-laden soils;
- destruction of hazardous wastes;
- volume reduction of municipal and industrial solid wastes.

Several applications have been developed, as well, for energy production. These include the raising of steam by general waste combustion (the O'Conner technology, for example) and the production of synthesis gas from the gasification of coal (the KILnGAS process, for example).

Energy for thermal treatment of materials in the rotary kiln can be provided by:

- external heating;
- combustion of primary fuel inside the kiln;
- combustion of portions of the treated solid inside the kiln;
- combustion of secondary fuel, along with portions of the treated solid, inside the kiln.

Energy, of course, is a direct product of the combustion of solid materials. For thermal treatment, No. 2 oil is the usual fuel of choice, if it is economically available. Natural gas, No. 6 oil, finely pulverized coal, and liquid chemical wastes are principal options. For combustion processing, the wastes themselves (such as municipal solid waste, or MSW, industrial waste, hazardous chemical waste and transuranic radioactive waste) provide all, or much of, the required calorific input. The remainder, if additional fuel is needed, is usually No. 2 oil, with natural gas and No. 6 oil as alternatives. [5]

Theodore and Reynolds point out [6] that:

"The rotary kiln incinerator is generally applicable to the destruction and ultimate disposal of any form of hazardous waste material that is combustible at all. Unlikely candidates [however include] . . . the general group of materials having a high inorganic content."

Accordingly, as the ash and moisture content of coal wastes, for example, increase, they pass a boundary dividing the region where a rotary kiln combustor would be selected from the region where another type of combustor would be chosen. The principal goal of the overall program, of which this project may be considered to be a portion, is the delineation of this boundary for coal and coal wastes as both primary fuel in direct combustion and secondary fuel in thermal treatment for rotary kiln systems. Of special interest are those coal and coal waste feeds with less extensive physical preparation than that required for finely pulverized coal fuels, such as are fed to lime and Portland cement calciners.

Crucial Parameters

Numerous parameters are crucial to the design and operation of a process as complex as a rotary kiln treater or combustor. [7] The typical heat rate of a rotary kiln incinerator is between 15,000 and 30,000 Btu/ft³·hr. [8] Thus, a rotary kiln combustor with a volume of 2000 ft³, being fed with a fuel containing 4000 Btu/lb, should be able to burn between 4 and 7 tons/hr of that fuel.

The mean solid residence time (T) may be adjusted by varying the rotational speed (N) and the kiln rake slope (S). [9] The following equation relates these variables:

$$T = C (L / D) / (S \cdot N)$$

where (L / D) is the internal length-to-diameter ratio of the kiln and C is a dimensional constant.

The gas residence time is a function of the composition, temperature and (usually to a slight degree) the pressure. The directional flow of the gas depends upon the nature of the feed. The general rules that govern the direction of the gas flow are:

- Use concurrent flow for combustion of solid wastes with higher volatility. If these feeds are introduced countercurrently, the rapidly released volatiles will become entrained in the exiting gases and will leave the kiln before they can be pyrolyzed or burned; and

- Use countercurrent flow for solid wastes with low heat content (high moisture and/or ash content). This will allow time for the hot combustion gases from the lower region of the kiln to heat and (if necessary) dry the solids for better burnout. If these are introduced concurrently, temperature control becomes very difficult. [10, 11]

Temperature Control

Two methods for temperature control have been devised, both of which have played a role in this project. The first is solids recycle, provided by the Archimedes spiral of the PEDCO unit. The principal purpose of this mechanism is to move hot solids up the slope of the kiln toward its cool upper end, where both high-volatile solid waste and air enter in a concurrently-fed configuration. [12] The second method for temperature control is the staging of air injection along the length of the barrel. This can be accomplished in one of two ways: [13]

- In the Westinghouse O'Conner waterwalled unit, air is injected through openings in the tube wall of the barrel;
- In the Universal Energy International refractory-lined unit, air is distributed through ports on a combustion air plenum, inserted throughout the length of the barrel.

Air staging can reduce the maximum temperature reached by the exhaust gas when internal heat transfer surface is present, thus reducing both the NO_x concentration and the severity of material degradation.

It could be argued that both methods of temperature control might be useful in providing a better environment for the combustion of a low-volatile, high-ash coal waste in a countercurrent rotary kiln combustor. The Archimedes spiral would increase the temperature at the upper end of the barrel to increase the rate of combustion in that region. The air distributor would move heated, oxygen-laden air through the unit (from back to front in an optimal configuration) to assist in the increased oxidation of the coal waste in the upper reach of the barrel.

Conversion of Fuels, Wastes and POHCs

Whether energy production is a major outcome of the operation of a rotary kiln incinerator, always of interest as an outcome is the conversion of the fuels and wastes being fed to the unit. In addition, if hazardous compounds are present in the feed to the kiln, the destruction and removal efficiency (DRE) of the principal organic hazardous constituents (POHCs) should set the values of the

crucial design and operational parameters of the system. [14-16] In most cases, the complexity of the flow patterns and temperature profiles of the gas and solid streams within the kiln, require that one (or a combination) of the following methods be employed during both design and operation to attain the requisite conversions of critical constituents:

- Mathematical model computations;
- Analysis of simulators and operating units.

Mathematical Modeling

A number of theoretical models for rotary kiln treaters have been developed in the past five years. The least fundamental of these appears to be what might be termed an expert system for evaluating the incinerability of any of a wide variety of hazardous waste streams. [17] Developed by Energy and Engineering Research Corporation of Irvine, California, the methodology uses a combination of experimental and theoretical experiences to determine the compatibility of the waste and the destruction system and to predict the performance of a full-scale unit. A similar model has been developed at the University of California at Los Angeles. [18] This is a linear programming model, which includes only mass and energy balances, based upon feed properties. Optimization is obtained using the SIMPLEX algorithm.

Predicting the heat transfer from the hot combustion gases to the cooler waste solids is a critical element of theoretical models. Oak Ridge National Laboratory has developed a comprehensive model with a number of state-of-the-art methods for predicting radiant transfer. [19] As part of its extensive modeling work, about which more will be said later, the University of Utah has developed a similar model to embed in its full simulation package. [20,21] The authors state that:

"...at the conditions examined, the model predicts that coflowing gas and solid streams result in higher average burden temperatures than do counterflowing streams. The moisture level of the feed is predicted to be a key operating parameter. [21] Predictions based on this model for typical operating conditions indicate that 10 percent by weight moisture can lower peak soil temperatures by 200 to 300K. Peak soil temperatures for coflowing solids are 200K lower than those obtained under counterflowing conditions." [20]

The Milan Polytechnic (Italy) is focusing upon modeling the rate of evaporation of volatile contaminants from solids, as a result of heat transfer from combustion gas. [22] Use of the model

allows the appropriate flowrates and feed conditions to be established, the temperature profile to be determined, and the kiln length to be set. [23] A similar, but much more comprehensive, modeling effort is being carried out by the Chemical and Mechanical Engineering Departments of the University of Utah in conjunction with Louisiana State University's Mechanical and Chemical Engineering Departments, the Louisiana Division of Dow Chemical USA, and the U.S. Environmental Protection Agency. The heat transfer portion of this program has already been mentioned. [20,21] Two rotary kiln configurations are being studied. One considers the destruction of carbon tetrachloride being volatilized from contaminated solid waste, using methane as the primary fuel. [24] An empirically specified release rate of volatile material from the bed is built into this version of the two-dimensional model. The other configurational study considers the additional volatilization of reactive hydrocarbon species from the solids in the kiln's bed. [25] The authors state that:

"The results [from the first study] are qualitatively compared with the measurements in a three dimensional kiln operating under similar conditions as the one in [the] study. In particular strong stratification of temperature and species concentration at the kiln exit is noted. This is validated by similar experimental observations. [24] Computational results [from the second study] show that hydrocarbons evolved from the bed may become caught in low temperature, high oxygen streams resulting in limited hydrocarbon destruction in the kiln. Highly nonuniform concentration profiles may result across the exit." [25]

Analysis of Operating Data

The Utah/LSU/Dow/EPA group, as suggested in the above quote, has instrumented and sampled Dow Chemical's industrial-scale rotary kiln at the Louisiana Division in Plaquemine, Louisiana. [26-28] This unit has a volume of approximately 2500 ft³ and can be fed with natural gas and liquids, organic contaminated water, sludges, and containers and bulk solids [26-28] and of toluene-laden sorbent packs. [28] The measurement program focused upon the quasi-steady incineration of carbon tetrachloride fed in liquid form. The authors report that:

"Gaseous components obtained from the lower region of the kiln exit indicated that significant non-uniformities may occur even during the quasi-steady processing . . . Variations [were observed] in temperature between that obtained from a permanent temperature sensor located near the rotary kiln exit and that fixed to the end of the kiln gas-sampling probe. In addition, . . . high oxygen . . . and low [carbon dioxide] mole fraction measurements [were] obtained from within the kiln [that] indicated

that the conditions sampled were not representative of those in a highly reactive combustion atmosphere. . . . The results presented [in these papers] demonstrate the complexity of the processes occurring within a kiln environment. A proper generalization of these results will require the development of a proven model. Such a model, currently under development [as indicated above], represents the ultimate goal of this work." [28]

As an assist toward model development, laboratory-scale desorption and kiln-simulator studies are being conducted at the University of Utah. [29]

The U.S. Environmental Protection Agency (EPA) has conducted a number of simulation, pilot and full scale testing of rotary kiln treatment of waste materials. Central to this work is the Incineration Research Facility (IRF) in Jefferson, Arkansas, operated by the Risk Reduction Engineering Laboratory, Office of Research and Development, in Cincinnati, Ohio. In this facility is a Rotary Kiln System which is available to third-party users who are interested in conducting cooperative research with EPA. [30] Examples of waste streams that have been decontaminated or destroyed in this system are:

- Toluene still-bottoms waste from trichlorophenol production, generated by the Vertac Chemical Company. This waste contained 37 ppm 2,3,7,8-TCDD as its POHC. A DRE of greater than 99.9999 percent was obtained with the system; [31]
- A surrogate Superfund soil bearing a wide range of chemical contaminants typically occurring at Superfund sites; [32]
- Three aqueous wastes from acrylonitrile production: bottom stream from the waste-water stripper, bottom stream from the acetonitrile column, and bottoms from the acetonitrile purification column; and [33]
- A clay absorbent, spiked with chlorides of hazardous trace elements (arsenic, lead, cadmium, chromium and barium) and non-hazardous trace elements (copper, magnesium, bismuth and strontium) in order to evaluate the partitioning of these trace elements in the residual streams from the kiln. [34]

The EPA also operates directly, or commissions, test programs in other units besides the ones at Plaquemine and Jefferson. For example, a rotary kiln incinerator simulator at EPA's Air and

Energy Engineering Research Laboratory at Research Triangle Park, North Carolina, examines the effects of changes in a number of operating parameters on incineration of various POHCs, the formation of products of incomplete combustion from them, and the transformation of trace metals. [35] At the other end of the spectrum, for example, is the comprehensive technical evaluation, conducted by Midwest Research Institute, of the performance of the hazardous waste combustion system in use at the Marine Shale Processors, Inc. facility in Amelia, Louisiana. [36]

Other countries have carried out technical evaluations of the pyrolysis and incineration of waste streams in rotary kilns. Two examples come, one from the Federal Republic of Germany (FRG) and the other from Canada. The FRG study encompasses the pyrolysis of contaminated soil in a pilot-plant at the Babcock Krauss Maffei Industrial Equipment Center in Garching, near Munich, and in a joint public/private demonstration plant in Unna-Bonen, near Dortmund, at a former coke oven site. Natural gas is burned to provide the indirect heat to the 2800 ft³ demonstration kiln, which operates at 750°C and has a design feed rate of seven tons per hour. The feed is soil with a moisture content of 21 percent, a volatile content of 5 percent, and a fixed carbon content of 5 percent. Decontamination efficiencies of 99.78 percent have been regularly achieved. [37]

The project in Canada, as described in the abstract of a report by Hardy BBT Ltd. was:

"...a source emission survey and study of the disposal of oily wastes A test burn was conducted of oily sand waste generated from Esso's Cold Lake facility. The primary objective was to evaluate the performance and environmental acceptability of rotary kiln incineration as a disposal method for oily wastes. During the emission survey, representative samples of the oily wastes from Esso's ecology pits were incinerated and the emissions of particulates, sulfur oxides, nitrogen oxides, hydrogen chloride and chlorine determined. Samples of the oily waste, residual ash and particulate emissions were collected and analyzed for characterization. Rotary kiln incineration of oily waste from the heavy oil industry shows promise. The combustion process works well, is controllable, and the residual ash generated has potential for appropriate landfill disposal. The incinerator does, however, require modification in design to comply with contaminant emission standards." [38]

The U.S. Department of Energy's principal focus to date on rotary kiln incinerators has been on low level chemical and transuranic hazardous waste materials. Four such studies over the past ten years are:

- Incineration of simulated transuranic waste materials in a 212 ft³ rotary kiln at the Colorado School of Mines Research Institute; [30]
- Shredding and incineration for volume reduction of simulated commercial transuranic wastes in three different pieces of equipment, including a test rotary kiln, at the Pacific Northwest Laboratory; [40]
- Incineration of low level chemical and transuranic hazardous waste in a 1400 ft³ rotary kiln at the Idaho National Engineering Laboratory; and [41]
- Impact analysis for a proposed rotary kiln incinerator system to decontaminate and treat radioactive and nonradioactive liquid waste generated by the Lawrence Livermore National Laboratory. [42]

Coal-Fired Units

The primary use for coal in rotary kiln operations has been in the production of Portland cement clinker. The presence of coal ash in the final solid material, cement clinker, from the kiln does not degrade the product, but blends very well with it.

During the past five years, the Germans have refocused strongly on pulverized coal as the fuel for cement kilns, because of the high cost of fuel oil on the European continent and the abundance of coal in the FRG. A comprehensive two-part review of the design and equipment requirements of both direct and indirect pulverized coal-fired rotary cement kilns appeared in 1987 in ZKG International. [43,44] Other reviews have focused upon:

- The properties, preparation and storage of coal dust and brown coal dust as low-cost substitutes for heavy fuel oil; [45]
- The handling, storage, feeding and firing of pulverized coal and the utilization of waste-derived fuels, even those containing hazardous substances, e.g., PCBs; [46]
- The use of low-grade, lumpy fuel materials, such as non-ground coal, as feed to the second firing system of rotary cement kilns; and [47]
- The problems encountered in using coarse lump fuels in secondary firing systems, such as SO₂ and NO_x emissions, exit gas energy losses, and coating build-ups in the kiln because of too high a sulfur or chloride content of the fuel. [48]

A similar review, but broader in scope, has come during this same time period from the German Democratic Republic (GDR). In it are:

[pointed]"... out commercial uses for dried sludge of coal fines, recovered from sedimentation ponds of brown coal processing plants. The dried coal sludge (41% coal moisture, 29% ash content, 12.5 MJ/kg calorific value) of 10 to 12 m deposit thickness is excavated and delivered to users by railway cars. Present commercial uses of this waste coal include: cocombustion in brown coal fired power plants (technological limit is 10% of total coal feed), combustion in small sectional boilers with pneumatic injection, combustion in tunnel furnaces of ceramic brick production, and combustion in cement producing rotary kilns. In the GDR, the ceramic brick industry is the only significant user of this waste coal." [49]

Two projects, one in the United States and the other in the United Kingdom, come the closest in scope to the project described in this report. The first project was reported by the Elgin-Butler Brick Company of Austin, Texas, which operates a rotary kiln at one of its plants near Elgin, Texas, 30 miles east of Austin. The paper reviews the company's "experiences in trying to use lignite as a fuel in converting [this] natural-gas-fired rotary kiln to one fired with lignite." [50] Because of the uniqueness of the Elgin-Butler Brick Co. application and the possible impact for our work, further information was obtained concerning the process. The company uses rotary kilns to dry clay to produce various types of brick. A program was undertaken to determine if lignite could be used as a fuel to replace some of the 2,500,000 cubic feet of gas used each day. The lignite was readily available as a by-product of the clay mining operation. Obviously the economics are very attractive if the lignite could replace the natural gas. The lignite contains 15 percent moisture, 25 percent ash, but has "high" volatiles. The heating value is 7,000 Btu/lb on an as-received basis.

The rotary kiln is 75 feet long, 3-4 feet in diameter, and the rotational speed is approximately 4 rpm. Each kiln uses 250,000 cubic feet of gas per day to process 100 tons of clay. They are currently using 24 tons per day of lignite which represents a savings of 30-35,000 Btu/day of natural gas.

During testing the lignite was fed to a Raymond IMP hammer mill to reduce the minus 4-inch feed product to 75 percent minus 4-10 mesh. The mill was swept with hot gases from the kiln to partially dry the lignite before it was fed into the kiln. Tests showed that the lignite had to be crushed to -100 mesh to really burn well and allow a reduction in the amount of natural gas. The lignite had to be crushed to -200 mesh before it would support combustion alone, without cofiring natural gas.

The second project was reported by the Abernant Colliery in the United Kingdom. The abstract of the colliery's paper speaks for itself:

"The washery at Abernant Colliery produces about 50,000 tons per annum of very fine tailings at a water content of 40-45% from a deep cone plant. Disposal of this material presents a considerable problem because there is a shortage of land suitable for lagoons, and the steepness of the local terrain makes tipping potentially hazardous. Current practice is to stabilize the tailings with cement before tipping. This treatment is expensive and hence there is a strong interest in alternative methods of stabilization or disposal. A comprehensive study of the tailings has been undertaken to assess their suitability for production of synthetic aggregate for use in concrete. Tests carried out have included plasticity, grain size analysis, chemical and mineralogical analysis. Thermal analysis in air and in nitrogen has enabled the firing range and the reactions taking place during firing to be established. Loss on ignition and corresponding calorific values have been determined on several samples. The relative contribution of dehydration, dehydroxylation and oxidative combustion reactions to the total ignition loss has been quantified. Heat calculations have shown that the tailings could provide sufficient energy to evaporate all water and maintain a bed temperature of 950-1000C in a well insulated combustion unit. Pilot scale trials have now been undertaken to convert pelletized tailings into fired aggregate in a novel design of rotary kiln. The effect of firing temperature on aggregate properties has been studied. The results have indicated that the tailings have high potential for conversion to a lightweight aggregate which would meet all the British Standard requirements for a lightweight aggregate for concrete." [51]

References

- [1] Boynton, R. S., "Lime and Limestone," in Encyclopedia of Chemical Technology, Third Edition, John Wiley & Sons, Inc., 1981, Volume 14, Pages 362-364.
- [2] Cunningham, W. A., I. Bjerle and J. J. McKetta, "Lime: Calcination Principles, European Practices, Plants in the United States, and Supply-Demand Relationships," in Encyclopedia of Chemical Processing and Design, Marcel Dekker, Inc., 1988, Volume 28, Pages 119-150.
- [3] Helmuth, R. A., et al., "Cement," in Encyclopedia of Chemical Technology, Third Edition, John Wiley & Sons, Inc., 1979, Volume 5, Pages 181-185.
- [4] Queen, D. M., Y. Hayashi and W. E. Kunze, "Cement: Economics and Cost, Industry in Japan, Portland, and Supply-Demand Relationships," in Encyclopedia of Chemical Processing and Design, Marcel Dekker, Inc., 1978, Volume 7, Pages 69-95.
- [5] Theodore, L., and J. Reynolds, Introduction to Hazardous Waste Incineration, John Wiley & Sons, Inc., 1987, Pages 178-185.
- [6] Ibid., Page 252.
- [7] Tillman, D. A., A. J. Rossi and K. M. Vick, "Rotary Incineration Systems for Solid Hazardous Wastes," Chemical Engineering Progress, 86 (7) July 1990, Pages 19-30.
- [8] Brunner, C. R., Handbook of Incineration Systems, McGraw-Hill, Inc., 1991, Pages 12.10-12.13.
- [9] Ibid., Page 12.8.
- [10] Ibid., Page 12.5.
- [11] Theodore, L., and J. Reynolds, op. cit., Page 250.
- [12] Long, W. H., and L. M. Reed, "Commercial Demonstration of the Pedco Rotary Cascading Bed Boiler (RCBB) -- A Mechanically Fluidized Bed Boiler," Proceedings of the Fifth Annual Pittsburgh Coal Conference, September 12-16, 1988, Pages 1011-1019.
- [13] Brunner, C. R., op. cit., Page 12.10.
- [14] Crumpler, E., and E. J. Martin, "Incineration of Hazardous Waste," in Hazardous Waste Management Engineering, Van Nostrand Reinhold, 1986, Pages 227-316.

- [15] Oppelt, E. T., "Hazardous Waste Destruction," Environmental Science and Technology, 20 (4) April 1986, Pages 312-318.
- [16] Freeman, H. M., et al., "Thermal Destruction of Hazardous Waste: A State-of-the-Art Review," Journal of Hazardous Materials, 14, 1987, Pages 103-117.
- [17] Seeker, W. R., W. D. Clark and D. W. Pershing, "Engineering Analysis of Hazardous Waste Incineration," Proceedings of HAZMACON 86, Pages 476-477.
- [18] Kirslis, S. J., and J. S. Watson, "Heat Transfer in a Rotary Kiln," presented at the Spring National Meeting of the American Institute of Chemical Engineers, April 2, 1989, 28 pages.
- [19] Behmanesh, N., V. Manousianthakis and D. T. Allen, "Optimizing the Throughput of Hazardous Waste Incinerators," AIChE Journal, 36 (11) 1990, Pages 1707-1714.
- [20] Silcox, G. D., and D. W. Pershing, "Heat Transfer Modeling in Rotary Kilns Burning Hazardous Industrial Wastes," presented at the Spring National Meeting of the American Institute of Chemical Engineers, March 6-10, 1988, 22 pages.
- [21] Silcox, G. D., and D. W. Pershing, "The Effects of Rotary Kiln Operating Conditions and Design on Burden Heating Rates and Determined by a Mathematical Model of Rotary Kiln Heat Transfer," Journal of the Air and Waste Management Association, 40 (3) 1990, Pages 337-344.
- [22] Ghezzi, U., and L. D. A. Ferri, "Theoretical Optimization of Rotary Kiln for Waste Incineration," Proceedings of the 8th Miami International Conference on Alternative Energy Sources, Volume 1-2, December 14-16, 1987, Pages 604-606.
- [23] Ghezzi, U., et al., "Analysis of Kiln Optimization for Waste Incineration," Proceedings of the 23rd Intersociety Conversion Engineering Conference, Volume 4, July 31-August 5, 1988, Pages 433-437.
- [24] Jang, D. S., and S. Acharya, "Two Dimensional Modeling of Waste Combustion in a Kiln," presented at the Spring National Meeting of the American Institute of Chemical Engineers, March 6-10, 1988, 23 pages.
- [25] Wormeck, J. J., and D. W. Pershing, "Computer Modeling of Combustion in a Rotary Kiln Incinerator," Proceedings of the 1988 National Heat Transfer Conference, ASME, Pages 97-101.

- [26] Cundy, V. A., et al., "Rotary Kiln Injection I. An Indepth Study -- Liquid Injection," JAPCA, 39 (1) 1989, Pages 63-75.
- [27] Cundy, V. A., et al., "Rotary Kiln Injection III. An Indepth Study -- Kiln Exit/Afterburner/Stack Train and Kiln Exit Pattern Factor Measurements During Liquid CCl₄ Processing," JAPCA, 39 (7) 1989, Pages 944-952.
- [28] Cundy, V. A., et al., "Rotary Kiln Incineration -- Combustion Chamber Dynamics," Journal of Hazardous Materials, 22 (2) November 1989, Pages 195-219.
- [29] Lighty, J. S., et al., "Rotary Kiln Injection II. Laboratory-Scale Desorption and Kiln-Simulator Studies -- Solids," JAPCA, 39 (2) 1989, Pages 187-193.
- [30] Thurnau, R. C., and C. R. Dempsey, "Incinerator Research Facility," Waste Management and Research, 8, 1990, 11 pages.
- [31] Waterland, L. R., et al., "Pilot-Scale Incineration of a Dioxin-Containing Material," presented at the Fall Meeting of the Western States Section, Combustion Institute, October 27, 1986, 16 pages.
- [32] Esposito, M. P., et al., "Incineration of a Chemically Contaminated Synthetic Soil Matrix (SSM) Using a Pilot-Scale Rotary-Kiln System," PB-89-124416, November 1986, 31 pages.
- [33] Krishnan, E. R., and R. J. Turner, "Evaluation of Incineration as an Alternative treatment Technology for Sludge Generated from Acrylonitrile Production," Proceedings of the 82nd Air and Waste Management Association Annual Meeting, Volume 2, June 23-30, 1989, 10 pages.
- [34] Carroll, G. J., et. al., "Partitioning of Metals in Rotary-Kiln Incineration," EPA-600/D-89/208, September 1989, 12 pages.
- [35] Hall, R. E., et al., "Ongoing Fundamental Hazardous-Waste-Incineration Research at EPA/RTP Facility," presented at the Incineration Conference, Knoxville, Tennessee, May 13-17, 1991, 17 pages.
- [36] Holloway, B., "Technical Evaluation of the Combustion System of the Marine Shale Processors, Inc. Facility in Amelia, Louisiana," EPA-68-91-7287, October 1990, 43 pages.
- [37] Schneider, D., and B. D. Beckstrom, "Cleanup of Contaminated Soils by Pyrolysis in an Indirectly Heated Rotary Kiln," Environmental Progress, 9 (3) August 1990, pages 165-168.

- [38] _____, "A Study of Rotary Kiln Incineration of Oily Sand Wastes," Hardy BBT Ltd. Report No. HBBT-EC90368, available through CANMET/TID, October 1986, 62 pages.
- [39] Pattengill, M. G., et al., "Rotary Kiln Incinerator Engineering Tests on Simulated Transuranic Wastes from the Idaho National Engineering Laboratory," Report No. EGG-2223, U.S. DOE Contract No: AC07-76ID01570, September 1982, 313 pages.
- [40] Oma, K. H., "Shredder and Incinerator Technology for Volume Reduction of Commercial Transuranic Wastes," Spectrum '86, Proceedings of the International Meeting on Low, Intermediate and High Level Waste Management -- Decontamination and Decommissioning," Niagara Falls, New York, September 14, 1986, Pages 1765-1778.
- [41] Drexler, R. L., "PREPP [Process Experimental Pilot Plant] Rotary Kiln Seals: Problem and Resolution," Report No. EGG-M-89466, U.S. DOE Contract No AC07-76ID01570, May 1990, 10 pages.
- [42] _____, "Lawrence Livermore National Laboratory Decontamination and Waste Treatment Facility: Documentation of Impact Analysis for Design Alternatives Presented in the draft Environmental Impact Statement," Report No. UCRL-21048, May 1988, 855 pages.
- [43] Mullinger, P. J., and B. G. Jenkins, "Rotary Kiln Coal Firing. Part I. Coal Grinding System," Zem.-Kalk-Gips, Ed. B, 40 (3) 1987, Pages 145-149.
- [44] Mullinger, P. J., and B. G. Jenkins, "Rotary Kiln Coal Firing. Part II. Burner Design," ZKG International, English Translation, 40 (5) 1987, Pages 259-264.
- [45] Schaefer, H. G., "Fuels for Rotary Kilns of the Cement Industry," Bergbau Energiewirtschaft, 39 (10) 1988, Pages 445-451.
- [46] Hochdahl, O., "Fuels and Heat Economics. Supply, Processing, Storage and Control of Fuels and Waste Fuels; Burners and Combustion Systems; Heat Recovery," ZKG, Edition B, 39 (2) 1986, Pages 57-66.
- [47] Fries, J. de, "Use of Secondary Fuels in the Cement Industry," Erzmetall, 38 (6) 1985, Pages 290-293.
- [48] Rosemann, H., "Effect of the Type and Point of Application of the Fuel on the Energy Consumption, Operating Behavior and Emission of Rotary Kiln Plants," ZKG, Edition B, 38 (6) 1988, Pages 231-236.

- [49] Zetzsche, K., "Waste Coal Fines -- A Waste Fuel and Its Utilization," Energieanwendung, 36 (4) July 1987, Pages 124-126.
- [50] Butler, J. R., and W. R. Kaiser, "Lignite-Fired Rotary Kiln," Proceedings of the Symposium on Gulf Coast Lignite: Geology, Utilization and Environmental Aspects, Austin, Texas, June 2, 1976, Pages 185-188.
- [51] Parks, L. F., "Production of Lightweight Aggregate from Washery Tailings at Abernant Colliery," Proceedings of the Symposium on the Reclamation, treatment and Utilization of Coal Mining Wastes," Durham, United Kingdom, September 10, 1984, Pages 40/14-40/16.

END

DATE
FILMED

21 4/93