280
248
10/23/78
25 copy to NTIS
DR. 633
DOE/NASA CONTRACTOR REPORT

MASTER

DOE/NASA CR-150802

INSTALLATION PACKAGE FOR SUNPAK™ SOLAR COLLECTORS

Prepared from material furnished by

Owens-Illinois, Inc.
P. O. Box 1035
Toledo, Ohio 43666

Under Contract NAS8-32259 with

National Aeronautics and Space Administration
George C. Marshall Space Flight Center, Alabama 35812

For the U. S. Department of Energy

U.S. Department of Energy

Solar Energy

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

NOTICE

This report was prepared to document work sponsored by the United States Government. Neither the United States nor its agents the United States Department of Energy, the United States National Aeronautics and Space Administration, nor any federal employees, nor any of their contractors, subcontractors or their employees, make any warranty, express or implied, or assume any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product or process disclosed, or represent that its use would not infringe privately owned rights.

1. REPORT NO. DOE/NASA 150802	2. GOVERNMENT ACCESSION NO.	3. RECIPIENT'S CATALOG NO.	
4. TITLE AND SUBTITLE Installation Package for Sunpak TM Solar Collectors		5. REPORT DATE September 1978	
		6. PERFORMING ORGANIZATION CODE	
7. AUTHOR(S)		8. PERFORMING ORGANIZATION REPORT #	
9. PERFORMING ORGANIZATION NAME AND ADDRESS Owens-Illinois, Inc. P.O. Box 1035 Toledo, Ohio 43666		10. WORK UNIT NO.	
		11. CONTRACT OR GRANT NO. NAS8-32259	
12. SPONSORING AGENCY NAME AND ADDRESS National Aeronautics and Space Administration Washington, D. C. 20546		13. TYPE OF REPORT & PERIOD COVERED Contractor Report	
		14. SPONSORING AGENCY CODE	
15. SUPPLEMENTARY NOTES This work was done under the technical supervision of Mr. John Caudle, George C. Marshall Space Flight Center, Alabama.			
16. ABSTRACT Owens-Illinois, Inc., has developed a subsystem (air/liquid vacuum collector) for use with solar combined heating and cooling subsystems. The Model SEC-601 collector is modular in design, is approximately twelve-feet-three-inches wide and is eight-feet-seven-inches high. The module contains 72 collector tube elements and weighs approximately 300 pounds. The Installation, Operating, and Maintenance Instructions, List of Materials and the Assembly Drawing are included in this package.			
17. KEY WORDS		18. DISTRIBUTION STATEMENT UC59c Unclassified-Unlimited WILLIAM A. BROOKSBANK, JR. Mgr, Solar Heating and Cooling Project Office	
19. SECURITY CLASSIF. (of this report) Unclassified	20. SECURITY CLASSIF. (of this page) Unclassified	21. NO. OF PAGES 11	22. PRICE NTIS

Table of Contents

	<u>Page</u>
1. Installation Instructions	1
2. Operating Instructions	6
3. Maintenance Instructions	9

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

NOTICE

PORTIONS OF THIS REPORT ARE ILLEGIBLE. It has been reproduced from the best available copy to permit the broadest possible availability.

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

Fig

1. Installation Instructions.

The SUNPAKTM SEC-601 air cooled collector is modular in design. The module is shipped to the distributor/installer as sub assemblies because of shipping volume and cost considerations. The module is partially preassembled at the factory and tested for mechanical integrity and air leakage flow rate prior to packaging for shipment.

The Model SEC-601 collector is twelve feet-two and three-fourth inches in width and eight feet-seven inches high. The module contains 72 collector tube elements mounted on four inch centers. The total module weight is 300 pounds and with the collector tube elements removed 80 pounds. The surface to which the collector module is mounted can deviate from a single plane surface by the order of 1" per 12' with no impact on collector thermal performance or service life. The module design has emphasized minimum air leakage, a characteristic of utmost importance in the attainment of high thermal performance of a solar energy system. The system installation should also emphasize a low level of air leakage for the same performance considerations.

The subassemblies received by the distributor/installer are:

1. Tube Assembly:P/N SK-3555
2. Return Tube: P/N SK-5089
3. Manifold Assembly: PN SK-5076
4. Rail Subassemblies (All angles etc., factory assembled)
5. Outboard Support Subassemblies (All possible parts factory assembled)
6. Tube Retainer (cushion factory assembled)
7. Hardware (just nuts and bolts - one size

The subassemblies or components provided by the distributor/installer include:

Alcoa - Bone white background.

Mounting screws for background.

Mounting hardware for collector.

Mating roof penetration.

The Model SEC 601 Collector module is designed for assembly (less collector tube elements) by the distributor/installer near the site of the collector installation. The assembly procedure starts with the placement of the five (5) T bars (P/N SK-5085) in parallel alignment on approximate three (3) feet centers per mounting diagram. The two(2)

tube end support units (P/N SK-5088) and the manifold (P/N SK-5076) are placed upon the T bars and secured in place by hardware; nut (P/N SK-5303) and bolt (P/N SK-5300), plain washer (P/N SK 5301) and lockwasher (P/N SK-5302). The holes are pre-drilled at the factory to insure the alignment of subassemblies. The completed manifold and support structure subassembly is shown in SK-5075.

The roof (installation) site of the collector is prepared for collector mounting by completing the roof penetrations to mate with the manifold transition ducts. The Alcoa Bone White K 2028-30 (or equivalent) diffuse reflecting backing screen is pre mounted in accordance with the recommendations of the supplier.

The completed manifold/support structure subassembly is lifted to the roof (installation site) and positioned to line up and insert the manifold transition ducts into the roof penetration ducts. After suitable positioning of the manifold transition elements, the module support structure is attached to the Alcoa Bone White (or equivalent) backing surface using Molly hardware (or equivalent). All roof penetrations are then sealed for weather tightness.

The collector module installation is completed by the insertion of the return tubes (P/N SK-5089) and the Tube Assemblies (P/N SK-3555) into the manifold (weather seal SK-5067). The Tube Retainer (P/N SK5103) is snapped into place to complete the assembly of the individual collector tube elements. The order of assembly of the tube elements is not critical.

Upon completion of the system ducting and installation of the air fan, it is recommended that the system be tested for air leakage. This may be accomplished by sealing off the duct which would normally connect to the fan inlet. A smoke bomb is ignited and the smoke effluent ingested into the fan inlet with the fan operating under essentially maximum pressurized conditions. Air leakage is detected visually. The smoke bomb, model K-30-Y Yellow Smoke Candle, manufactured by Kilgore Corp., Toone, TN produces a smoke which is yellowish in color and which leaves a yellow deposit on any surface scrubbed by the significant concentration of the smoke. It is suggested that the smoke bomb system test be conducted prior to the application of insulation to the ducting in order to pin point the location of any air leakage condition.

SECTION AA
CROSSSECTION ELEVATION SCALE 1:1

CHG.	DESCRIPTION	BY	DATE	MF
A	ROOF NUTS REVISED	AL	11/17/77	
B	RELEASED	AL	1/31/78	
C	DRG. UPDATE	AL	2/1/78	

TOLERANCE UNLESS OTHERWISE NOTED	2 PLACE DEC. ±	3 PLACE DEC. ±	ANGLES ±	CORNERS AND/OR EDGES BROKEN	UNLESS SPECIFIED, MACHINED SURFACE ROUGHNESS NOT TO EXCEED	DEFINITION OF SYMBOLS (Total Indicator Reading)	SCALE NOTED	INCHES	MATERIAL	HEAT TREAT	CASE DEPTH	HARDNESS	SUR. TREAT
						○ CONCENTRICITY							
						○ ROUNDNESS							
						— FLATNESS							
						— SYMMETRY							
						— PARALLEL							
						— PERPENDICULAR							

USED ON ASSEMBLY NO.

PROJECT NO. C-2370

DES'D 9/18/77

DR'N 1/1

CK'D 1/1

SOLAR COLLECTOR MODEL SEC-601

NUMBER SK-5075

SHEET 1 OF 1

SIZE D

OWENS-ILLINOIS

CORPORATE TECHNOLOGY TOLEDO, OHIO

72 TUBE SOLAR ENERGY COLLECTOR SYSTEM

Revised 3/10/78

				SK-5075	D	Solar Energy Collector System
72				SK-3555	C	Tube assembly
	1			SK-4348	B	Cover Tube
	1			SK-4349	B	Absorber Tube
	1			SK-2356	A	Vacuum Extension
	1			SK-3105	A	Tip-Off Protector
	1			SK-4305	A	Spring and Getter Assembly
		1		SK-4346	A	Getter
		3		SK-4347	A	Spring
	1			SK-5065	B	Seal-Tube
72				SK-5089	B	Return Tube Assembly
	1			SK-5090	B	Nut
72				SK-5145	A	"O" Ring 1-5/16" I.D. x .139" diameter
72				SK-5067	B	Seal Retainer
72				SK-5103	C	Retainer-Tube
	1			SK-4314	A	Cushion
5				SK-5085	C	Rail Assembly
	1			SK-5086	C	Rail
	2			SK-5087	B	Spacer
2				SK-5088	C	Support-Outboard
2				SK-5091	C	Stop-Manifold
15				SK-5168	A	Roof Pad
15				SK-5167	A	Roof Bracket
30				SK-5300	A	#10-32 x 1/2" lg. Pan Hd. Slotted - St. Stl.
30				SK-5301	A	#10 Plain Washer, St. Stl., .437 O.D. x .208 I.D. X .049 TK
20				SK-5302	A	#10 Spring Lockwasher St. Stl.
20				SK-5303	A	10-32 Hex. Nut St. Stl.
25				SK-5304	A	1/4-20 x 3/4" lg. Hex...Hd. Cap Scr. Alum.
25				SK-5305	A	1/4" Spring Lockwasher St. Stl.
25				SK-5306	A	1/4-20 Hex. Nut Alum.

[illegible]

2. Operating Instructions.

The SUNPAKTM Model SEC-601 air cooled collector is modular in design. A single module contains 72 collector tube elements. All collector tube elements are mounted into the manifold so as to induce a parallel air flow pattern in all collector tube elements. The pressure drop vs air flow rate for a single module is indicated in Figure 1. The pressure drop represents the difference in static pressure measured in the inlet and outlet transition sections between the manifold and the system air ducts. Thus, the air flow versus pressure drop information applies to any number of modules installed to constitute a large collector array providing the system ducting introduces no significant pressure drop due to flow in the ducting.

The Model SEC 601 air cooled collector is virtually free of limitations to operating conditions. The collector module has been tested under air flow rates and system operating pressures beyond any conceivable practical operating conditions. As in all solar thermal collectors, thermal performance is affected by the rate of flow of the cooling fluid. Thus, air mass flow rates below 6 LBS/Hr. FT.² are not recommended because of the attendant decrease in thermal performance which is observed. Similarly, air-mass flow rates above 20 LBS./Hr. FT.² are not usually recommended because of air pumping power requirements. It should be noted, however, that such flow rate recommendations are based on system considerations; no adverse conditions are imposed on the collector influencing safety, reliability, life, etc., by operation of the collector outside of the recommended conditions.

Each Module SEC-601 collector module contains two(2) thermocouple type temperature sensors. The junctions are located in the annulus of the collector tube element facing upward and located at the extreme left position of the module. These temperature sensors are provided for use in the system control logic. The collector module has been tested, under accelerated aging conditions, to an exit air temperature from the collector of 325°F. continuous air flow. Under extended conditions of stagnation (no fluid flow) at high levels of insolation, the collector tube elements can attain temperature levels equal to or exceeding 600°F. If air flow were initiated where the absorber tube glass temperature is at high temperature, a short term over

MODEL SEC 601
AIR COOLED COLLECTOR
AIR FLOW VS. PRESSURE DROP

COLLECTOR PRESSURE DROP ; INCHES, w.g.

FIGURE 1

temperature excursion could be observed in the collector exit air temperature as sensible heat is removed from the absorber tubes. Such an operating condition could subject a portion of the polyurethane foam to temperatures in excess of 325°F for a short time period. While no safety or long term reliability features of the collector are impacted, repeated exposure to the high temperature excursion conditions could cause a change in the insulating properties of the foam material and/or introduce minor air leakage paths. Such changes in the manifold properties could lead to a detectable reduction in the thermal performance of the module.

Thus, one of the two thermocouples (copper-constantan, Type T) is provided as an overtemperature sensor. When the sensed temperature exceeds 450°F, electric power to the fan should be deactivated to preclude the initiation of air flow. The collector is capable of withstanding extended periods of stagnation (no fluid flow) conditions without inducing any damage to the collector. In the event of failure of the control to prevent the initiation of flow after extended exposure to stagnation conditions, the inadvertent initiation of air flow will not cause damage to the collector tube elements due to thermal shock.

The second thermocouple is provided as a temperature sensor for use in the control strategy for the solar energy system. The user may consider such strategies as temperature off set or absolute temperature as potential conditions for the starting and/or stopping of air flow.

The optimum air mass flow rate for most solar energy systems is in the range of 8 to 12 LBS/HR.FT.² of collector area. Other air flow rates may be considered at the option of the user. While pressure drop-air flow relationships are available over a wide range of operating conditions, limited test time has precluded the investigation of the collector thermal performance as a function of air mass flow.

It is recommended that air filtration be provided in the solar thermal energy system having a minimum ASHRAE arrestance of 60 percent. Pressure drop through the filtration unit should be minimized (a maximum of 0.3 inches, w.g. at 150 SCFM is recommended) in order to control air pumping power requirements.

3. Maintenance Instructions.

The SUNPAKTM Model SEC-601 air cooled collector is designed for maintenance free operation over the design life (target; 20 years) of the collector. The results of accelerated aging and service life tests predict the attainment of the target design life. No routine maintenance procedures have been established or identified as required to date.

Spare Parts List:

No spare parts list for routine periodic replacement of components has been established or identified as required to date. Replacement parts will be ordered through the distributor/installer or directly from the manufacturer, Owens-Illinois, Inc., 1020 N. Westwood, Toledo, Ohio, 43606; Attention: Field Service Department.