AIM

Association for Information and Image Management

1100 Wayne Avenue, Suite 1100
Silver Spring, Maryland 20910

301/587-8202

Centimeter

Inches

MANUFACTURED TO AIM STANDARDS
BY APPLIED IMAGE, INC.

1 of 1

RECEIVED
MAR 19 1993
OSTI

**Cover Sheet for a Hanford
Historical Document
Released for Public Availability**

Released 1993

**Prepared for the U.S. Department of Energy
under Contract DE-AC06-76RLO 1830**

**Pacific Northwest Laboratory
Operated for the U.S. Department of Energy
by Battelle Memorial Institute**

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This is a **historical document** that is being released for public availability. This was made from the best available copy. Neither the United States Government nor any agency thereof, nor Battelle Memorial Institute, nor any of their employees, makes **any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights.** The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Date March 16, 1977

To DISTRIBUTION

From J.A. Glissmeyer

Subject CORRECTION TO PRELIMINARY EVALUATION OF THE GASEOUS EFFLUENT
SAMPLING SYSTEM OF THE 296-P-3 PORTABLE EXHAUSTER, BY-TANK FARM,
J.A. GLISSMEYER, L.C. SCHWENDIMAN TO DON CARRELL - MARCH 11, 1977

Internal Distribution
RL Conley
JA Glissmeyer
J Mishima
LCS/File
Letterbook
Record Copy

Please make the following correction to Equation 1 on page 8 of your
copies of the above report.

$$\text{Corrected SCFH} = \text{Reading SCFH} \sqrt{\frac{29.92 \text{ in. Hg}}{P \text{ in. Hg}} \times \frac{(460 + T)^{\circ} R}{530^{\circ} R}} \quad (1)$$

The divide sign was inadvertently omitted.

Very truly yours,

John A. Glissmeyer

J.A. Glissmeyer
Particulate & Gaseous Waste Research
ATMOSPHERIC SCIENCES DEPARTMENT

JAG:11c

cc: G.J. Bracken, ERDA/RL
L.E. Bruns, ARHCO
G.T. Dukelow, ARHCO
J.M. Haines, ARHCO
G.L. Hanson, ARHCO
W.R. Hodges, ARHCO
E.J. Kosiancic, ARHCO
H.A. Lee, ARHCO
D.L. Merrick, ARHCO
R.G. Oliver, ARHCO
J.V. Panesko, ARHCO
B.J. Saueressig, ARHCO
H.P. Shaw, ARHCO
A.T. White, ARHCO

RECEIVED

MAR 18 1977

OFFICE OF
J. V. PANESKO

MASTER

RECEIVED

MAR 15 1977

**OFFICE OF
J. V. PANESKO**

Battelle

Pacific Northwest Laboratories

Battelle Boulevard

Richland, Washington 99352

Telephone (509)

Telex 32-6345

March 11, 1977

Mr. Don Carrell
Atlantic Richfield Hanford Company
222-T Bldg., 200-W Area
Richland, Washington 99352

Dear Don:

Attached are your copies of the letter report, "Preliminary Evaluation of the Gaseous Effluent Sampling System of the 296-P-3 Portable Exhauster, BY-Tank Farm," which you requested. Please call Lysle Schwendiman or myself if we can clarify any points in the report.

Very truly yours,

John A. Glissmeyer

J.A. Glissmeyer
Particulate & Gaseous Waste Research
ATMOSPHERIC SCIENCES DEPARTMENT

JAG:llc

Enclosures

cc: G.J. Bracken, ERDA/RL
L.E. Bruns, ARHCO
G.T. Dukelow, ARHCO
J.M. Haines, ARHCO
G.L. Hanson, ARHCO
W.R. Hodges, ARHCO
E.J. Kosiancic, ARHCO
H.A. Lee, ARHCO
D.L. Merrick, ARHCO
R.G. Oliver, ARHCO
J.V. Panesko, ARHCO
B.J. Saueressig, ARHCO
H.P. Shaw, ARHCO
A.T. White, ARHCO

✓ → Gene: file

PRELIMINARY EVALUATION OF THE GASEOUS
EFFLUENT SAMPLING SYSTEM OF THE
296-P-3 PORTABLE EXHAUSTER,
BY-TANK FARM

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

by

J. A. Glissmeyer
L. C. Schwendiman

March 1977

Battelle
Pacific Northwest Laboratories
Richland, Washington 99352

MASTER

als
DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

CONTENTS

1.0 INTRODUCTION	1
2.0 SUMMARY.	2
3.0 DESCRIPTION OF SAMPLING SYSTEM	2
4.0 PRELIMINARY EVALUATION.	8
4.1 SAMPLE COLLECTION SYSTEM OPERATION	8
4.2 SAMPLING LOCATION.	9
4.3 SAMPLE COLLECTION SYSTEM PERFORMANCE	9
5.0 CONCLUSIONS	12
6.0 RECOMMENDATIONS FOR CORRECTIVE ACTION.	13
NOMENCLATURE.	15
REFERENCES	16
APPENDIX A - RADIOACTIVE GASEOUS DISCHARGES, TANK FARMS, ARH 222-2.3.12.	A-1
APPENDIX B - INTERIM RADIOACTIVE GASEOUS EFFLUENT SAMPLING AND MONITORING CRITERIA FOR ATLANTIC RICHFIELD HANFORD COMPANY FACILITIES, ARH-CD-498	B-1
APPENDIX C - CALCULATION OF EFFLUENT DEWPOINT.	C-1

PRELIMINARY EVALUATION OF THE GASEOUS EFFLUENT SAMPLING SYSTEM
OF THE 296-P-3 PORTABLE EXHAUSTER, BY-TANK FARM

1.0 INTRODUCTION

This evaluation of the 296-P-3 stack sampling system is part of a larger study, sponsored by ARHCO and conducted by Battelle-Northwest, of effluent airborne particulate sampling systems in ARHCO facilities. The 296-P-3 stack is similar to many portable exhauster units deployed in the tank farms. The objectives of this study are:

- Evaluate the compliance of the particulate sampling system with ARHCO's Interim Criteria for such systems by using sampling theory
- Make recommendations for corrective action which will lead to a particulate sampling system in compliance with the Interim Criteria
- The conclusions and recommendations are to be generally applicable to sampling systems of the same type as at the 296-P-3 stack.

This study is considered preliminary because no experiments have been conducted to verify the sampling system's performance.

The following report includes a brief summary, a detailed description and evaluation of the sampling system, conclusions and recommendations for corrective action. The appendices contain a copy of the Interim Criteria, the ARHCO Emergency Procedure regarding radioactive gaseous discharges from this facility and calculations.

2.0 SUMMARY

The airborne radioactive particulate effluent sampling system for the 296-P-3 portable tank farm exhauster (EDP code 65) was evaluated for compliance with ARHCO's Interim Criteria for such systems and other good sampling practices. The evaluation was not based on experimental findings but rather on observations of the system and on sampling theory. The existing sampling system has several deficiencies which are listed in the conclusions. Among these are poor sampling location, addition of bleed air to the sample airstream and unsatisfactory flowrate measurement. Extensive recommendations were given outlining the design effort for a replacement sampling system. Some of these recommendations included locating a new sampling probe on the stack and performance testing of the replacement system with a suitable validation technique. One recommendation for an interim improvement of the existing sampling system was shutting off the bleed air system. The recommendations were intended to be generally applicable to sampling systems at other portable exhausters similar to the 296-P-3.

3.0 DESCRIPTION OF SAMPLING SYSTEM

The 296-P-3 stack (EDP code 65) exhausts the filtered gaseous effluent from the 107, 108, 110 and 111 tanks at the BY-Tank Farm. The most likely radioactive constituents of the effluent particulates are beta-gamma and beta emitters such as cesium-137 and strontium-90.⁽¹⁾ The exhaust flowrate from each tank is measured separately and recent data⁽²⁾ show a combined airflow of 3933 CFM (see Appendix C). The ~~exhaust flowrate is measured from 60 ft to about 125 ft prior~~ to passing through the stages of HEPA filtration.^(3,4) The discharge flowrate is about 4400 CFM* (effluent conditions) with a dewpoint of approximately 40°F.**

*Correcting for the increase in temperature, the exhaust flowrate is $3933 \text{ CFM} \times \frac{(460 + 123)^{\circ}\text{R}}{(460 + 60)^{\circ}\text{R}}$ or 4400 CFM. The average velocity in the 24-in., 16 gauge stack is 1400 ft/min.

**The dewpoint is calculated from psychrometric data for each tank. The calculations are shown in Appendix C.

The 296-P-3 portable exhauster unit is shown in Figure 1. The effluent is sampled by an inventory sampling system only. The collected samples are not monitored constantly, but are changed once each working day and are analyzed in the 222-S Building Air Sample Counting Room. The air sampling system is shown in Figures 2 and 3 and diagrammed in Figure 4. The air sample is extracted through a single nozzle probe in the duct between the fan and the transition to the stack. Instrument air is added to the sample air just outside the duct. This bleed air can be heated but usually is not because the effluent temperature is high enough to prevent condensation.⁽¹⁾ The air sample is piped into the enclosure which is thermostatically heated to 80°F.⁽⁷⁾ The particulate sample is collected on a 47 mm diameter filter (Hollingsworth and Vose, HV-70) contained in an in-line filter holder. The usual flowmeter readings are 60 SCFH for the bleed air and 180 SCFH for the total sample. The assumed net sample flowrate is 120 SCFH or 2 CFM (effluent conditions). Table 1 lists the piping that the air sample passes through.

TABLE 1. Air Sampling Piping

Probe to In-Bleed:

One 90° Bend 3.25 in. radius	1/2" sch 40 pipe, 0.622 in. ID
12.75 in. Horizontal	" "

In-Bleed to Filter:

One 90° Bend 2.5 in. radius	" "
12 in. Horizontal	" "
7.5 in. Horizontal	3/4" plastic, 0.626 in. ID
3 in. "	1/4" sch 40 pipe, 0.364 in. ID
2 in. "	3/8" OD filterholder inlet, @ 0.3 in. ID

The electrical power to the sampler vacuum pump is tied into the same power supply as the exhaust fan. The exhauster unit is normally operating on the emergency power system which is considered uninterruptible.⁽⁸⁾

FIGURE 1. 296-P-3 Portable Exhauster Unit
PNL Neg. No. 7610920-1

FIGURE 2. 296-P-3 Stack Air Sampling Equipment, View 1
PNL Neg. No. 7610920-3

FIGURE 3. 296-P-3 Stack Air Sampling Equipment, View 2
PNL Neg. No. 7610920-2

FIGURE 4. Diagram of Air Sampling Equipment^(5,6)

4.0 PRELIMINARY EVALUATION

This preliminary evaluation of the 296-P-3 stack sampling system will focus on the areas considered deficient in light of ARHCO's Interim Criteria for Gaseous Effluent Sampling. Because these criteria will be referred to frequently, a copy is included in Appendix B. The portions of the sampling system that are considered satisfactory will be listed later in the conclusion.

4.1 SAMPLE COLLECTION SYSTEM OPERATION

There are three major deficiencies in the way the sample collection system is operated. The first of these is the improper measurement of sample flowrate. Neither the bleed air nor total sample flowmeters are instrumented with temperature and pressure gauges to correct the flowmeter readings for deviations from their calibrated gas conditions of 70°F, 29.92 in. Hg. The corrections would be the most significant for the total sample flowmeter which is located in the vacuum line. For the purpose of the rest of this report the corrected flowrates are estimated using Equation 1.

$$\text{Corrected SCFH} = \text{Reading SCFH} \sqrt{\frac{29.92 \text{ in. Hg}}{P \text{ in. Hg}}} \times \frac{(460 + T)^{\circ} R}{530^{\circ} R} \quad (1)$$

where P is the air pressure and T the temperature at the flowmeter. For the bleed air flowmeter the pressure is estimated to be 29.92 in. Hg and the temperature is assumed to be 80°F. The reading of 60 SCFH is then corrected to be 59.4 SCFH. For the total sample flowmeter the pressure and temperature are estimated to be 24.92 in. Hg and 80°F yielding a corrected flowrate of 163 SCFH. The net sample flowrate is then 103 SCFH or 1.72 SCFM. Adjusting the net sample flowrate to effluent conditions of 123°F yields an estimate of 1.9 CFM* which is nearly the same as ARCHO has assumed.

*Flow at effluent conditions = $1.72 \text{ SCFM} \times \frac{(460 + 123)^{\circ} R}{530^{\circ} R} = 1.9 \text{ CFM}.$

A second deficiency is the use of the air in-bleed. The air in-bleed serves no useful purpose because the effluent temperature is sufficiently high (if the heater does not fail) and the sampling line is short so that condensation in the sampling line is not likely. Furthermore, the additional flowrate from the air in-bleed contributes to the deposition of sampled particulates before they reach the filter. A thermostatically controlled heat trace would better serve the purpose of preventing condensation in the sampler if the effluent heater fails.

Finally, there is no alarm in a continuously occupied area to signal the loss of sampler vacuum. Presently, a loss of vacuum may go undetected for several hours during which no sample would be collected.

4.2 SAMPLING LOCATION

One factor determining whether the extracted particulate sample aliquot is representative of the effluent is the location of the sampling probe. Currently the probe has a single inlet located just a fraction of a duct diameter from the exhaust fan and stack transition (see Figure 2). The airflow is not likely to be well developed at that point and it is doubtful that the particulate concentration at the nozzle is truly an average for the effluent. (Without measuring the uniformity of particle concentration across the duct it can only be speculated that the concentration is not uniform.)

4.3 SAMPLE COLLECTION SYSTEM PERFORMANCE

As already pointed out, the particulate sample withdrawn from the 296-P-3 exhaustor is not likely to be representative of the effluent because of the poor sampling location. The particulate sample ultimately reaching the collection filter is probably even less representative because of anisokinetic sampling and particle deposition in the tubing and the filter holder.

The sample bias caused by anisokinetic sampling can be estimated based upon the flowrate assumptions already mentioned. The estimated biases in the sample caused by the subisokinetic extraction are listed in Table 2 for various monodispersed aerosols. The assumptions used in the calculations are also listed in the table and the calculational method is described in earlier reports.^(9,10)

TABLE 2. Subisokinetic Sampling Bias

Effluent Flowrate = 4400 CFM Sample Flowrate = 1.9 CFM
 Effluent Ave. Velocity = 1400 ft/min Sample Velocity = 900 ft/min
 Effluent Temperature = 123°F Probe Nozzle ID = 0.622 in.
 Duct ID = 24 in.

Particle Size, μm AED*	Concentration Bias
0.5	1.00
1.0	1.00
2.0	1.01
5.0	1.06
8.0	1.14
10.0	1.19

* AED refers to aerodynamic equivalent diameter, i.e., the diameter of a sphere with density of 1g/cm^3 .

The particulate sample bias caused by deposition in sampler piping is listed in Table 3. The calculational methods are detailed elsewhere^(9,10) and the assumptions employed are listed in the table. The fractional delivery of the particulates through the sampler piping is shown for both monodispersed and polydispersed aerosols with geometric mean diameters as listed. An air temperature equal to the effluent temperature was

TABLE 3. Fractional Delivery of Aerosols
Through Sample Transport Piping

Particle Size μmm , AED	Monodispersed Aerosols		Polydispersed Aerosols	
	Probe to Air In-Bleed	In-Bleed To Filter Holder	Total System	Total System
0.5	1.00	1.00	1.00	.99
1	1.00	.99	.99	.96
2	.99	.98	.97	.89
5	.96	.87	.83	.66
8	.89	.70	.62	.52
10	.83	.57	.47	.45
Flowrate, CFM	1.9	2.82		
Temperature, °F	123	90		

assumed for the piping from the probe to the air in-bleed. A lower air temperature was assumed for the rest of the piping because of mixing with the cooler bleed air and the exposure of the pipes to the ambient air.

The subisokinetic sampling bias and the total fractional delivery for monodispersed aerosols can be multiplied to give a rough estimate of the combined bias for various particle sizes as shown in Table 4.

TABLE 4. Combined Monodispersed
Aerosol Sampling Bias

<u>Particle Size</u> <u>μm, AED</u>	<u>Combined</u> <u>Fractional Bias</u>
0.5	1.00
1	.99
2	.98
5	.88
8	.71
10	.56

The bias values tabulated in Tables 2, 3 and 4 show the strong dependence of sample bias upon the particle sizes. Because there is no information on the particle sizes in the 296-P-3 effluent a firm prediction for sample bias cannot be given. It is important to remember that the calculated biases are based on several assumptions of flowrates and conditions and the effects of fittings and nozzle bluntness are ignored. Considering the sample biases due to anisokinetic sampling and particle losses along with the poor choice of sampling location, it is unlikely that collected samples are representative of 1-10 μm AED particulates within the constraints of Sampling Criterion No. 2 (Appendix B).

5.0 CONCLUSIONS

The following is a list of conclusions reached as a result of this preliminary evaluation of the 296-P-3 stack sampling system.

1. The collected radioactive particulate samples are not likely to be representative of the effluent to the extent required by the Interim Criteria. This is largely because of the poor sampling location and in part because of anisokinetic sample extraction and particle deposition.
2. The provisions for accurately measuring sample flowrate are unsatisfactory.
3. There are no visual or audible alarms in a continuously occupied area to indicate a loss of sampling system vacuum.
4. The availability of emergency electrical power is satisfactory.
5. The estimated size of the sample aliquot (as determined by sample flowrate and collection time) is satisfactory to collect enough radioactive particulates to permit accurate analysis of the required release concentration (Appendix B, Sampling Criterion No. 1) if the collected samples are assumed to be representative. An earlier report showed that a 24-hour sample flowrate of 0.55 CFM was the minimum required to collect a large enough sample for accurate analysis by routine methods. (11,p.14)
The estimated present flowrate of 1.9 CFM exceeds this minimum.
6. The hot air in-bleed system is inappropriate for this sampling system.

6.0 RECOMMENDATIONS FOR CORRECTIVE ACTION

The following is a list of recommendations which, if implemented, should result in a sampling system that will comply with the Interim Criteria. A new sampling system needs to be designed. The following should be elements of that design or must be considered before proceeding with the design work. These recommendations are intended to be generally applicable to portable exhaust systems similar to the 296-P-3 system. Some of these recommendations are also generally applicable to any sampling system and are taken verbatim from earlier reports. (11,12)

1. Consideration should be given to incorporating a sample monitoring system as part of the new sampling system. The sample monitoring system should be separate from the inventory sampling system and should meet the requirements of the Interim Criteria. Past experience on concentrations in the effluent and their rate of change should be taken into account in deciding if a monitor is required.
2. The sample collection system will need a new probe with knife edged nozzles which will sample isokinetically with a net sample flowrate in the 2-10 SCFM range. The probe should ideally be installed at least 10 stack diameters downstream and five stack diameters upstream of significant flow disturbances. The existing stack would have to be extended nearly twenty-one feet to achieve this. A suitable alternative may be to install flow straightening or profiling devices in the stack. The sampling probe can then be installed two to three feet upstream from the stack discharge. In any case, a velocity traverse should be conducted in the proposed sampling plane and the data used in the design of the new probe.
3. The sample collector should be in the stack or short coupled to it. There should be no more than two bends or 180° of total bend in the sample transport piping.
4. Control of condensation in sample transport piping should be accomplished by thermostatically controlled heat tracing if the effluent heater fails.
5. Provision should be made to periodically clean the sampling system piping to account for deposited radioactive particles.

6. The sampling system must be properly instrumented for the measurement and control of sample flowrates. The temperature and pressure conditions for the measurement of effluent flowrate, sample flowrate and the calculation of releases must be defined and, when these conditions differ, corrections must be applied to calculations and measurements. Commercially available mass flowmeters would be ideal for sample flow measurement and can be easily made part of a feedback control loop. If other flowmetering devices are used (e.g., rotameters) they should be properly instrumented to allow corrections to be made when they are used in conditions different from the calibration conditions. Consideration should be given to flow totalizers such as gas meters or flowrate recorders.
7. An audible and visual alarm in a continuously occupied area should be provided to indicate a loss of sample vacuum.
8. The personnel authorized to make adjustments in the sampling system operations must be thoroughly trained in the system's operation and design features.
9. Define what constitutes appropriate accuracy for the measurement of releases required in Sampling Criterion No. 1. The size of the sample aliquot required for that accuracy should then be reevaluated.
10. It is desirable to test sampling system performance and bias when suitable testing techniques become available.
11. The design and any future changes made in the sampling system should be documented for future reference.
12. The above recommendations require extensive design work. The following recommendations are for interim improvements to the existing sampling system and should somewhat lessen the bias of the sample:
 - a. shut-off the air in-bleed system and adjust the total sample flowrate to 1.9 CFM.
 - b. consider short coupling the filter holder to the duct.

NOMENCLATURE

AED - aerodynamic equivalent diameter
cm - centimeter
CFM - cubic feet per minute at effluent conditions
ft - feet
g - gram
ID - inside diameter
in - inch
in. Hg - inches of mercury pressure
lb - pound
min - minutes
mm - millimeter
OD - outside diameter
SCFH - standard cubic feet per hour @ 70°F, 29.92 in. Hg
SCFM - standard cubic feet per minute @ 70°F, 29.92 in. Hg
 μm - micro (10^{-6}) meters, microns
°F - degrees fahrenheit
°R - degrees rankine

REFERENCES

1. W. R. Hodges, Private Communications, ARHCO (February, 1977).
2. J. H. Palmer, Private Communications, ARHCO (November, 1976).
3. C. M. Walker, Private Communications, ARHCO (February, 1977).
4. Drawing H-2-35238, "Heating and Ventilating Exhaust Unit Details," ARHCO Engineering Files.
5. Drawing H-2-35725, "Exhaust Stack Dry Air Samplers Installation, 241-BY," ARHCO Engineering Files.
6. Drawing H-2-35721, "Exhaust Stack Dry Air Sampler," ARHCO Engineering Files.
7. W. T. Tyler, Private Communications, ARHCO (February, 1977).
8. H. L. Winters, Private Communications, ARHCO (February, 1977).
9. L. C. Schwendiman, G. E. Stegen, J. Mishima, J. A. Glissmeyer, Interim Report: An Analysis of the Gaseous Effluent Sampling System - 225-B, Waste Encapsulation and Storage Facility, Appendix, BNWL-B-408, Battelle-Northwest, Richland, WA, (April, 1975).
10. L. C. Schwendiman, G. E. Stegen, J. A. Glissmeyer, "Methods and Aids for Assessing Particle Losses in Sampling Lines." BNWL-SA-5138, presented to the American Industrial Hygiene Association, Minneapolis, MN, 1975.
11. J. A. Glissmeyer, L. C. Schwendiman, Preliminary Evaluation of the Gaseous Effluent Sampling System at the 296-A-12 Stack-244-AR Vault Vessel Vent, Report to D. J. Carrell, ARHCO, by Battelle, Pacific Northwest Laboratories, Richland, WA 99352, 1977.
12. J. A. Glissmeyer, L. C. Schwendiman, Preliminary Evaluation of the Gaseous Effluent Sampling System at the 296-A-17 Stack - A, AX, AY, Tank Farm, Report to D. J. Carrel, ARHCO, by Battelle, Pacific Northwest Laboratories, Richland, WA 99352, 1976.
13. J. H. Perry, editor, Chemical Engineer's Handbook. McGraw-Hill, New York, NY, p. 154, 4th ed. 1969.
14. R. E. Treybal, Mass Transfer Operations. McGraw-Hill, New York, N.Y., p. 187, 2nd ed. 1968.

APPENDIX A

RADIOACTIVE GASEOUS DISCHARGES, TANK FARMS, ARH 222-2.3.12

ISSUED BY THE MANAGER	SUBJECT	CLASSIFICATION	
Tank Farm Operations	RADIOACTIVE GASEOUS DISCHARGES TANK FARMS	ARH-222	
<p>A. <u>Introduction</u></p> <p>Gases discharged from the various Tank Farm stacks are monitored for radioactivity. Some of the emissions are measured and recorded continuously while others are monitored by periodic counts of air samples. Laboratory measurements are used for final determination and record all stack samples.</p> <p>Certain actions and notifications are required in the event of a significant discharge of radioactivity.</p> <p>B. <u>Gaseous Discharge-Radioactivity Level Determination</u></p> <p>First indication that a release of radioactive material to the atmosphere may have occurred will come from a monitoring instrument alarm or preliminary radiation instrument reading on a stack air sample.</p> <p>Operating supervision is to be notified at the first indication of an abnormal reading or alarm and will proceed to determine actions as outlined in section C, below.</p> <p>Table 1 and 2 attached provide some information to assist in preliminary evaluation of release levels.</p> <p>C. <u>Action Required</u></p> <p>1. <u>Supervisor's Responsibilities</u></p> <p>a. Upon receiving an alarm, the responsible supervisor will immediately notify radiation monitoring, then proceed to investigate or determine whether the alarm was due to high radioactivity or an instrument malfunction.</p> <p>b. The supervisor will request replacements of the air sample and an immediate count of the sample by radiation monitoring.</p>			
DATE ISSUED JUN 1 1976	SUPERSEDES ISSUE DATED 5-20-75	PAGE 1 OF 6	EMERGENCY PROCEDURE 2.3.12

EMERGENCY PROCEDURE

- c. The supervisor will notify his management if the alarm is found to be due to a radioactivity level that exceeds the levels described in section D, below.
- d. The supervisor will initiate an investigation to determine the source of radioactive emissions.
- e. The supervisor will keep management informed throughout the progress of his investigations. He will consult with management upon the course of action to resolve the problem. He will prepare a written report of the investigation and findings.

2. Radiation Monitoring Responsibilities

Radiation monitoring will provide assistance by changing air samples, counting samples and evaluating data.

3. Tank Farm Process Engineering

Operations Support Engineering will provide assistance as required during the investigation, isolation and resolution of problems.

4. Management Responsibilities

- a. Tank Farm Operations (TFO) management will provide guidance as required during the investigation, isolation and resolution of problems.
- b. The Manager, TFO will determine when environmental discharges warrant defining the situation as being in the emergency category.
- c. TFO Management will implement activities required of personnel under emergency conditions.
- d. The Manager, TFO will communicate all information to Departmental Management required under emergency conditions.

DATE ISSUED	SUPERSEDES ISSUE DATED	PAGE	EMERGENCY PROCEDURE
JUN 1 1976	5-20-75	2 OF 6	NO. 2.3.12

D. Situation Definitions and Action

1. Class I

Definition

Daily environmental discharge exceeds ten percent of the release level values specified in section 5 of Radiation Protection Standards and returns to less than ten percent within 48 hours. ARH-220 (see table 2, attached).

Action

Notify plant and department management. Investigate to determine the cause. Document investigation and conclusions.

2. Class II

Definition

Daily environmental discharge exceeds ten percent of the release level values in section 5 of Radiation Protection Standards for more than 48 hours.

Action

Notify plant, department and division management. Investigate to determine the cause. Document the investigation and conclusions.

3. Class III An Emergency

Definition

Environmental discharge exceeds the release level value in section 5 of Radiation Protection Standards.

Action

Notify plant, department, division management and the U. S. Energy Research and Development Administration. Promptly investigate to determine the cause and corrective action.

DATE ISSUED	SUPERSEDES ISSUE DATED	PAGE	EMERGENCY PROCEDURE
JUN 1 1976	5-20-75	3 OF 6	NO. 2.3.12

EMERGENCY PROCEDURE

4. Class IV An Emergency

Definition

Environmental discharge that exceeds ten times the release level values in section 5 of Radiation Protection Standards.

Action

Notify plant, department, division management and the U. S. Energy Research and Development Administration immediately. Investigate promptly to determine the cause and corrective actions. If control cannot be immediately established or the discharge has exceeded 100 times the release level values, the facility shall be shut down. Document the investigation and conclusions. Take positive action to prevent recurrence.

PREPARED BY J. E. Ferguson DATE 3-25-76

REVIEWED BY C. E. Hocking DATE 4-20-76
(TFO)

APPROVED BY E. J. Sauer DATE 5/18/76
(R/S)

APPROVED BY T. H. Nelson DATE 5-25-76
(MPP)

ISSUED BY J. Beal DATE 1 June 76
(MTFO)

DATE ISSUED	SUPERSEDES ISSUE DATED	PAGE	EMERGENCY PROCEDURE
JUN 1 1976	5-20-75	4 OF 6	NO. 2.3.12

TABLE I

CONVERSION FACTORS FOR
SELECTED TANK FARM STACKSCONVERSION FACTORS
for Ci emitted per sampling period

Stack Code Number	Ident.	Location	Filter Size inia.	Sample Flow Rate Cu. Ft/Min	Stack Flow Rate Cu. Ft/Min	EGM Ci per c/m	P11 Probe Ci per c/m	CP Ci per Mrads/hr at contact	Alpha Ci per d/m
6	91-F	291-S	4"	3	40,000	6×10^{-7}	1.5×10^{-7}	4×10^{-4}	6.0×10^{-9}
52	ARCS	244-AR	2"	1	20,000	9×10^{-7}	2.3×10^{-7}	6×10^{-4}	9×10^{-9}
58	ARVVS	AR-Vessel	2"	1	380	1.8×10^{-8}	4.5×10^{-9}	1.2×10^{-5}	1.8×10^{-10}
59	702-A	AXFS	2"	1	6,900	3×10^{-7}	8×10^{-8}	2×10^{-4}	3×10^{-9}

DATE ISSUED	SUPERSEDES ISSUE DATED	PAGE	EMERGENCY PROCEDURE
JUN 1 1976	5-20-75	5 OF 6	MO. 2.3.12

84-6000-086 (2-73)

TABLE 2

GASEOUS WASTES
(Ref. ARH-220)

Gaseous radioactive wastes (mists or gases) shall be controlled so that the amounts released will be kept as small as practicable and should not average greater than the following amounts:

<u>Radionuclide</u>	<u>AMOUNT IN CURIES PER WEEK</u>	
	<u>Released from 200-ft. Stack</u>	<u>Released from Shorter Stacks or Vents</u>
⁹⁰ Sr	0.1	0.01
¹³¹ I	0.03	0.003
Plutonium (total)	0.001	0.0001
Uranium (natural)	0.004	0.0004
Total of all others (excluding ³ H, ¹⁴ C, and noble gases)	0.5	0.05

In addition, the total amount of ¹³¹I released from all 200 Area sources shall not exceed 1 curies per calendar quarter.

DATE ISSUED: JUN 1 1978	SUPERSEDES ISSUE DATED: 5-20-75	PAGE 6 OF 6	EMERGENCY PROCEDURE NO. 2.3.12
----------------------------	------------------------------------	----------------	-----------------------------------

APPENDIX B

INTERIM RADIOACTIVE GASEOUS EFFLUENT SAMPLING AND
MONITORING CRITERIA FOR ATLANTIC RICHFIELD HANFORD
COMPANY FACILITIES, ARH-CD-498

INTERIM RADIOACTIVE
GASEOUS EFFLUENT SAMPLING AND MONITORING CRITERIA
FOR ATLANTIC RICHFIELD HANFORD COMPANY FACILITIES

INTRODUCTION

To ensure that gaseous radioactive releases to the environment are kept as low as practicable, it is necessary to sample all of the radioactive or potentially radioactive gaseous effluent streams in the 200 Areas. Specific gaseous effluent streams that have the potential for release of large quantities of radioactive materials must also be monitored by radiation detection instrumentation.

The criteria listed below are intended to be used as guidelines to aid in the design of new systems or the upgrading of existing systems. It is highly desirable that new or upgraded systems be able to meet or nearly approach as many of the following criteria as is practicable.

SAMPLING CRITERIA

The term "sampling" applies to the extraction, transport and collection of a sample of the radionuclides present in the gaseous effluent stream on a collection media suitable for subsequent laboratory analysis. Gaseous effluent sampling systems shall:

1. extract in a 24-hour period a representative fraction of the effluent stream such that an activity release at least as low as the concentration guides given in ERDA Appendix 0524, Annex A, Table II can be measured with appropriate accuracy upon subsequent laboratory analysis.*
2. be designed, fabricated, and operated so that the particles extracted and transported to the collector will be representative to the degree that particles 10 micrometers and smaller in the sample collected will be at least 90 percent of the 10 micrometer and smaller particles in the same volume of a truly representative sample. At least 90 percent of the radioactive gases withdrawn shall be collected on the media selected or delivered to the activity sensing chamber in flow through monitors.
3. operate in a continuous mode, except for short periods when the sample collection media is being changed, whenever the facility is exhausting to the atmosphere.
4. extract samples of particles and gases that are a representative aliquot of the actual effluent stream.

* If one half of the Class I Action Level in ARH-222, ARHCO Emergency Procedure 1.9 (or the Emergency Procedure that governs gaseous discharges for the specific facility) is less than the Table II concentration guides, use one half of the Class I Action Level from the appropriate Emergency Procedure as the basis for this criterion.

5. collect at least two samples, one of which will be designated and used exclusively as an inventory sample.
6. shall provide particulate and gaseous samples that have not been adversely affected by condensation of moisture.
7. be equipped with a vacuum system for sample extraction that has the same number of back-up power systems as the exhaust fans of the facility. The vacuum system shall be provided with an alarm that is activated upon the loss of vacuum.
8. provide an inventory sample which is an accurate aliquot, within a factor of two, of the absolute radioactive materials of the effluent stream. (Note: This statement relates only to the sample extraction and delivery capability, not to the accuracy of detection and measurement.)
9. provide inventory samples with less than 25 percent variation from the mean of several similar samplings at the 95 percent confidence level.
10. have at least an annual check to ensure that variation in effluent characteristics (particle size, mass activity concentrations, etc.) have not changed significantly.

MONITORING CRITERIA

The term "monitoring" applies to the use of radiation detection instrumentation to measure the amount of radioactivity collected by the collection media. Gaseous effluent monitoring systems shall:

1. monitor the samples collected (except for the designated inventory sample) as detailed in items 1-10 under Sampling Criteria. The monitoring system shall be able to detect an activity release at least as low as one half that required for the Class I Action Level listed in ARH-222, ARHCO Emergency Procedure 1.9 (or the Emergency Procedure that governs gaseous discharges for the specific facility).
2. detect the radiation from radionuclides in the effluent stream with appropriate sensitivity for the radiation emitted.
3. operate in a continuous mode, except for short periods while samples are being changed, whenever the facility is exhausting to the atmosphere.
4. be equipped with the same number of back-up power systems as the exhaust fans of the facility.
5. incorporate a permanent recorder to document the level of radioactivity measured by the radiation detection instrument.

11/14/75
DJC:bac

6. be provided with a "fail-safe" system that alarms when a malfunction occurs in the radiation detection instrument or upon loss of vacuum.
7. alarm at a pre-set "trip" point that is consistent with a Class II Action Level as specified in ARH-222, ARHCO Emergency Procedure 1.9 (or the Emergency Procedure that governs gaseous discharges for the specific facility).
8. be able to detect a Class II Action Level as specified in ARH-222, ARHCO Emergency Procedure 1.9 (or the Emergency Procedure that governs gaseous discharges for the specific facility) in less than 24 hours.
9. alarm visually and audibly in a continuously occupied area for both the "fail-safe" alarm(s) and the emergency alarm(s).
10. be equipped with sufficient range to detect activity levels up to 100 times the Class II Action Level in ARH-222, ARHCO Emergency Procedure 1.9 (or the Emergency Procedure that governs gaseous discharges for the specific facility).
11. have the radiation detection instrumentation calibrated on at least a quarterly basis.

APPENDIX C
CALCULATION OF EFFLUENT DEWPOINT

C. DEWPOINT OF COMBINED 296-P-3 EFFLUENT

The following are the flowrate and psychrometric data for the effluent from each tank served by the 296-P-3 exhaustor.

<u>i</u>	<u>Tank</u>	<u>Flow</u> <u>CFM(2)</u>	<u>% of Total</u> <u>Flow P_i</u>	<u>Psychrometric Data⁽³⁾</u>		<u>Absolute Humidity^(13,14)</u> <u>lb water/lb dry air Y_i</u>
				<u>Bulb Temperature °F</u> <u>Dry</u>	<u>Wet</u>	
1	107	1746	44.39	59	54	0.0075
2	108	157	3.99	58	54	0.0080
3	110	1295	32.93	57	45	0.0036
4	111	<u>735</u>	18.69	58	46	0.0037
Total		3933				

$$\text{Combined absolute humidity} = \hat{Y}_{\text{Total}} = \sum_{i=1}^4 P_i \hat{Y}_i = 0.0055 \text{ lb water/lb dry air}$$

From the psychrometric chart the dewpoint at $\hat{Y} = 0.0055$ is 40°F.

**DATE
FILMED**

7 / 22 / 93

END