

348
3/15/79

DR. 2337

DOE/NASA CONTRACTOR
REPORT

MASTER

DOE/NASA CR-150900

THERMAL PERFORMANCE EVALUATION OF MSFC HOT AIR COLLECTORS WITH VARIOUS FLOW CHANNEL DEPTHS

Prepared by

Wyle Laboratories
Solar Energy Systems Division
Huntsville, Alabama 35805


Under subcontract with

IBM Corporation, Federal Systems Division Huntsville, Alabama 35805

Contract NAS8-32036

National Aeronautics and Space Administration
George C. Marshall Space Flight Center, Alabama 35812

For the U. S. Department of Energy



U.S. Department of Energy



Solar Energy

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER


This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

NOTICE


This report was prepared to document work sponsored by the United States Government. Neither the United States nor its agents the United States Department of Energy, the United States National Aeronautics and Space Administration, nor any federal employees, nor any of their contractors, subcontractors or their employees, make any warranty, express or implied, or assume any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product or process disclosed, or represent that its use would not infringe privately owned rights.

1. REPORT NO. DOE/NASA CR-150900		2. GOVERNMENT ACCESSION NO.		3. RECIPIENT'S CATALOG NO.	
4. TITLE AND SUBTITLE Thermal Performance Evaluation of MSFC Hot Air Collectors with Various Flow Channel Depths				5. REPORT DATE January 1979	
				6. PERFORMING ORGANIZATION CODE	
7. AUTHOR(S)				8. PERFORMING ORGANIZATION REPORT #	
9. PERFORMING ORGANIZATION NAME AND ADDRESS Wyle Laboratories Solar Energy Systems Division Huntsville, Alabama 35805				10. WORK UNIT NO.	
				11. CONTRACT OR GRANT NO. NAS8-32036	
12. SPONSORING AGENCY NAME AND ADDRESS National Aeronautics and Space Administration Washington, D. C. 20546				13. TYPE OF REPORT & PERIOD COVERED Contractor Report	
				14. SPONSORING AGENCY CODE	
15. SUPPLEMENTARY NOTES This work was done under the technical management of Mr. Charles N. Thomas, George C. Marshall Space Flight Center, Alabama.					
16. ABSTRACT <p>This report presents the test procedures used and the results obtained during the evaluation test program on the MSFC air collector with flow channel depth of 3 in., 2 in., and 1 in., under simulated conditions <i>are presented.</i></p> <p>The MSFC hot air collector consists of a single glass cover with a non-selective coating absorber plate and using air as the heat transfer medium. The absorber panel consisted of a thin flat sheet of aluminum.</p>					
17. KEY WORDS			18. DISTRIBUTION STATEMENT UC-59c Unclassified-Unlimited  WILLIAM A. BROOKSBANK, JR. Mgr, Solar Heating and Cooling Project Office		
19. SECURITY CLASSIF. (of this report) Unclassified		20. SECURITY CLASSIF. (of this page) Unclassified		21. NO. OF PAGES 18	22. PRICE NTIS,

1. REPORT NO. DOE/NASA CR-150900		2. GOVERNMENT ACCESSION NO.		3. RECIPIENT'S CATALOG NO.	
4. TITLE AND SUBTITLE Thermal Performance Evaluation of MSFC Hot Air Collectors with Various Flow Channel Depths				5. REPORT DATE January 1979	
				6. PERFORMING ORGANIZATION CODE	
7. AUTHOR(S)				8. PERFORMING ORGANIZATION REPORT #	
9. PERFORMING ORGANIZATION NAME AND ADDRESS Wyle Laboratories Solar Energy Systems Division Huntsville, Alabama 35805				10. WORK UNIT NO.	
				11. CONTRACT OR GRANT NO. NAS8-32036	
				13. TYPE OF REPORT & PERIOD COVERED Contractor Report	
12. SPONSORING AGENCY NAME AND ADDRESS National Aeronautics and Space Administration Washington, D. C. 20546				14. SPONSORING AGENCY CODE	
15. SUPPLEMENTARY NOTES This work was done under the technical management of Mr. Charles N. Thomas, George C. Marshall Space Flight Center, Alabama.					
16. ABSTRACT This report presents the test procedures used and the results obtained during the evaluation test program on the MSFC air collector with flow channel depth of 3 in., 2 in., and 1 in., under simulated conditions. The MSFC hot air collector consists of a single glass cover with a non-selective coating absorber plate and using air as the heat transfer medium. The absorber panel consisted of a thin flat sheet of aluminum.					
17. KEY WORDS			18. DISTRIBUTION STATEMENT UC-59c Unclassified-Unlimited <i>William A. Brooksbank, Jr.</i> WILLIAM A. BROOKSBANK, JR. Mgr, Solar Heating and Cooling Project Office		
19. SECURITY CLASSIF. (of this report) Unclassified		20. SECURITY CLASSIF. (of this page) Unclassified		21. NO. OF PAGES 18	22. PRICE NTIS

TABLE OF CONTENTS

		<u>Page No.</u>
1.0	PURPOSE	1
2.0	REFERENCES	1
3.0	MANUFACTURER	1
4.0	SUMMARY	1
5.0	TEST CONDITIONS AND TEST EQUIPMENT	2
6.0	TEST REQUIREMENTS AND PROCEDURES	3
	6.1 Collector Thermal Performance Test	3
7.0	ANALYSIS	4
TABLE I	MSFC HOT AIR COLLECTOR EFFICIENCY TEST CONDITIONS	6
TABLE II	MSFC HOT AIR COLLECTOR THERMAL PERFORMANCE TEST DATA - 3" FLOW DEPTH	7
TABLE III	MSFC HOT AIR COLLECTOR THERMAL PERFORMANCE TEST DATA - 2" FLOW DEPTH	8
TABLE IV	MSFC HOT AIR COLLECTOR THERMAL PERFORMANCE TEST DATA - 1" FLOW DEPTH	9
TABLE V	MSFC HOT AIR COLLECTOR THERMAL PERFORMANCE TEST DATA - 1/2" FLOW DEPTH	10
TABLE VI	MSFC HOT AIR COLLECTOR PRESSURE DROP TEST - 2" FLOW DEPTH	11
Figure 1	MSFC Hot Air Collector Thermal Performance Test Data - 3 In. Flow Depth	12
Figure 2	MSFC Hot Air Collector Thermal Performance Test Data - 2 In. Flow Depth	13
Figure 3	MSFC Hot Air Collector Thermal Performance Test Data - 1 In. Flow Depth	14
Figure 4	MSFC Hot Air Collector Thermal Performance Test Data - 1/2 In. Flow Depth	15
Figure 5	MSFC Hot Air Collector Pressure Drop Test Data	16



1.0

PURPOSE

The purpose of this documentation is to present the test results obtained during the performance of an evaluation test program. The evaluation test program was conducted to determine the thermal performance data on the new generation of MSFC air collectors with a flow channel depth of 3 in., 2 in., 1 in. and 1/2 in. under simulated conditions. The test was conducted utilizing the MSFC Solar Simulator in accordance with the test requirements specified in References 2.1 and 2.2 and the procedures contained in Reference 2.3.

2.0

REFERENCES

- 2.1 ASHRAE 93-77 Method of Testing Solar Collectors Based on Thermal Performance
- 2.2 EP45 (77-115) Thermal Analysis and Development of the MSFC Air Collector
- 2.3 MTCP-DC-SHAC-416 MSFC Hot Air Collector Indoor Thermal Performance Test Procedure

3.0

MANUFACTURER

Marshall Space Flight Center
Huntsville, Alabama

3.1

DESCRIPTION OF TEST SPECIMEN

The MSFC hot air collector consists of a single glazed cover with a non-selective coating absorber plate and using air as the heat transfer medium. The collector frame is constructed with rigid urethane foam.

4.0

SUMMARY

This test program was conducted to evaluate the thermal performance of a new generation of MSFC air collector with various flow channel depths under simulated conditions. The test conditions and the thermal performance data obtained during the tests conducted on the simulator are listed in Tables II through VI, respectively. A graphic presentation of the data obtained is also presented in Figures 1 through 4 for thermal performance data and Figure 5 for pressure drop data.

5.0 TEST CONDITIONS AND TEST EQUIPMENT

5.1 Ambient Conditions

Unless otherwise specified herein, all tests shall be performed in the existing environment of Building 4619.

5.2 Instrumentation and Equipment

All test equipment and instrumentation used in the performance of this test program comply with the requirements of MSFC MMI 5300.4C, Metrology and Calibration. A listing of the equipment used in this test follows:

<u>Apparatus</u>	<u>Manufacturer/Model</u>	<u>Range/Accuracy</u>
Pyranometer	Eppley PSP	0-800 BTU/Ft ² ·Hr/+5%
Air Source	MSFC Supplied	30 - 200 SCFM
Wind Sensor	MSFC Supplied	0 - 60 MPH
Flow Sensor	Cox-Turbine C-L-32	20 - 250 ACFM ± 2%
Differential Pressure Sensor	MSFC Supplied	0 - 2 in. H ₂ O ± 5%
Thermocouples	MSFC Supplied/Type T	0 - 500°F ± 1.8°F

6.0 TEST REQUIREMENTS AND PROCEDURES

6.1 Collector Thermal Performance Test

6.1.1 Evaluation Requirements

Utilizing the MSFC Solar Simulator and the portable hot air loop, performance evaluation data were obtained at inlet temperatures of 100°F and 150°F with insolation rate of 250 BTU/Ft²·Hr and a wind speed of 7.5 MPH. The air flow rates were controlled to 30, 90 and 150 SCFM. The depth of flow channel inside the collector was adjusted to 3, 2, 1 and 1/2 inches. The test conditions are listed in Table I. The following data were recorded during the test:

1. Absorber surface temperature - 3 locations (°F)
2. Inlet air temperature (°F)
3. Outlet air temperature (°F)
4. Air flow rate (SCFM)
5. Collector differential pressure ("H₂O)
6. Insolation rate (BTU/Ft²·Hr)
7. Air flow channel depth (Inch)
8. Wind speed (MPH)

6.1.2 Test Procedure

1. Mount test specimen on test table at a 45° angle with respect to the floor.
2. Assure that simulator lamp array is adjusted to an angle of 45° with respect to the floor.
3. Insulate all ducts.
4. Connect instrumentation leads to data acquisition system.
5. Assure that data acquisition system is operational.
6. Establish required wind speed.
7. Start air flow loop and establish the required flow rate.
8. Establish the required inlet temperature.
9. Power up Solar Simulator and establish the required insolation rate.
10. Record data for a minimum of five minutes at three stabilized conditions.
11. Insert flow channel spacers as necessary to obtain specified flow channel depth and repeat Steps 7 through 10.
12. Upon completion of testing, power down Solar Simulator and air loop.
13. Inform data control group that simulator operation has terminated.

6.1.3 Results

The results obtained during these tests are contained in Figures 1 through 5 and Tables II through VI.

ANALYSIS

The analysis of the data contained in this report is in accordance with the National Bureau of Standards and ASHRAE recommended approach.

The efficiency of a collector is:

$$\eta = \frac{q_u/A}{I} = \frac{\dot{m} C_{tf} (t_{f,e} - t_{f,i})}{I} \quad (1)$$

where

- q_u = rate of useful energy extracted from the solar collector (BTU/hr)
 A = overall cross sectional area of collector (ft²)
 I = total solar energy incident upon the plant of the solar collector per unit time per unit area (BTU/Hr-ft²)
 \dot{m} = mass flow rate of the transfer fluid through the collector per unit cross-sectional area of the collector (Lb/Ft²-Hr)
 C_{tf} = specific heat of the transfer fluid (BTU/Lb °F)
 $t_{f,e}$ = temperature of the transfer fluid leaving the collector (°F)
 $t_{f,i}$ = temperature of the transfer fluid entering the collector (°F)

Rewriting equation (1) in terms of the collector area, we get:

$$\eta = \frac{(\dot{m}A) C_{tf}(t_{f,e}-t_{f,i})}{IA} = \frac{\dot{M} C_{tf}(t_{f,e}-t_{f,i})}{P_i} \quad (2)$$

Notice that

- P_i = IA = total power incident on the collector (BTU/Hr)
 \dot{M} = $\dot{m}A$ = total mass flow rate through the collector (Lb/Hr)

For an air collector system, the mass flow rate is obtained by multiplying the density of the air with the volume flow rate of the air through collector.

$$\dot{M} = \int_{tf} \dot{V} \quad (3)$$

where

- \int_{tf} = Density of the transfer fluid (Lb/Ft³)
 \dot{V} = Volume flow rate (SCFM) x 60

Since $\dot{M}C_{tf}(T_{f,e} - t_{f,i})$ = total power collected by the collector, the collector efficiency can be expressed in

$$\eta = \frac{P_{abs}}{P_{inc}} \quad (4)$$

where

P_{abs} = total absorbed power

P_{inc} = total incident power

The present collector efficiency is defined as

$$\eta_{eff} = \frac{\dot{M}C_{tf}(T_{f,e} - t_{f,i}) * 100}{P_i} \quad (5)$$

The efficiency calculations were made for all test data and are included in Tables II through V. Figures 1 through 4 present plots of efficiency versus the normalized factor for flow channel depths of 3 in., 2 in., 1 in., and 1/2 in., respectively.

TABLE I

MSFC HOT AIR COLLECTOR EFFICIENCY TEST CONDITIONS

		Test Designation			
Flow Channel Depth (Inches)	Inlet Temp. (°F)	Flow Rate CFM	30	90	150
3	100	1	2	3	
	150	4	5	6	
2	100	7	8	9	
	150	10	11	12	
1	100	13	14	15	
	150	16	17	18	
1/2	100	19	20	21	
	150	22	23	24	

Q = 250 BTU/Ft²·Hr

Wind = 7.5 MPH (from south)

Tilt Angle = 45°

TABLE II

MSFC HOT AIR COLLECTOR THERMAL PERFORMANCE TEST DATA - 3" FLOW DEPTH

North East Surface °F (6)	165	145	135	186	173	162				
South East Surface °F (5)	176	159	144	196	183	175				
South Surface °F (4)	167	151	138	195	183	175				
South West Surface °F (3)	167	143	130	194	178	169				
North West Surface °F (2)	175	154	143	199	183	175				
Ambient °F	85	85	86	84	83	82				
T _{in} °F	100.1	100.8	101.3	150.1	150.2	149.8				
T _{out} °F	126.4	117.6	113.2	166.9	158.0	155.6				
ΔT °F	26.3	16.8	11.9	16.8	7.6	5.8				
Solar Flux BTU/Hr·Ft ²	250	250	250	250	250	250				
Flow Rate SCFM	30	90	150	30	90	150				
Wind Speed MPH	7.5	7.5	7.5	7.5	7.5	7.5				
Efficiency %	18.9	36.3	42.8	12.1	16.8	20.9				
(T _i -T _a) / I °F·Hr·Ft ² /BTU	0.060	0.062	0.061	0.264	0.269	0.271				
ΔP in. H ₂ O	0.0092	0.0369	0.1015							

TABLE IV

MSFC HOT AIR COLLECTOR THERMAL PERFORMANCE TEST DATA - 1" FLOW DEPTH

North East Surface °F (6)	140	120	115	168	156	161	181	177		
South East Surface °F (5)	162	138	128	180	168	171	188	182		
South Surface °F (4)	168	145	137	180	173	174	189	185		
South West Surface °F (3)	142	116	107	166	151	155	178	171		
North West Surface °F (2)	150	125	118	170	157	162	179	174		
Ambient °F	81.0	81.6	82.2	82.0	83.6	85.4	79.5	80.5		
T _{in} °F	99.3	100.3	100.2	140.5	139.7	150.3	164.6	165.7		
T _{out} °F	136.3	124.2	116.8	161.1	153.2	157.4	171.4	169.0		
ΔT °F	37.0	23.9	116.6	20.6	13.5	7.1	6.8	3.3		
Solar Flux BTU/Hr·Ft ²	257	257	257	257	257	257	257	257		
Flow Rate SCFM	30	90	150	30	90	150	30	90		
Wind Speed MPH	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5		
Efficiency %	25.9	50.2	58.2	14.4	28.3	24.8	4.8	6.9		
(T _i -T _a) / I °F·Hr·Ft ² /BTU	0.071	0.0073	0.070	0.228	0.218	0.254	0.331	0.332		
ΔP in. H ₂ O	0.0369	0.1845	0.517							

TABLE V

MSFC HOT AIR COLLECTOR THERMAL PERFORMANCE TEST DATA - 1/2" FLOW DEPTH

North East Surface °F (6)	130	115	116	169	163	160	180	176	174	
South East Surface °F (5)	158	134	133	189	177	170	195	188	184	
South Surface °F (4)	155	139	137	187	187	174	195	193	188	
South West Surface °F (3)	151	125	126	187	174	171	193	185	182	
North West Surface °F (2)	165	154	137	190	184	178	195	194	188	
Ambient °F	86.4	81.3	87.5	88.1	82.5	83.1	83.7	84.9	84.7	
T _{in} °F	98.7	100.6	100.7	148.5	149.6	150.2	164.3	164.7	165.3	
T _{out} °F	146.3	127.5	123.1	167.3	162.6	156.2	178.1	170.1	166.7	
ΔT °F	47.6	26.9	22.4	18.8	13.0	6.0	13.8	5.4	1.4	
Solar Flux BTU/Hr·Ft ²	250	250	257	257	257	257	257	257	257	
Flow Rate SCFM	30	90	150	30	90	150	30	90	150	
Wind Speed MPH	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	
Efficiency %	34.3	58.1	78.5	13.2	27.3	21.0	9.7	11.4	5.0	
(T _i -T _a) / I °F·Hr·Ft ² /BTU	0.049	0.077	0.051	0.235	0.261	0.261	0.314	0.311	0.314	
ΔP in. H ₂ O	0.074	0.443	0.996							

TABLE VI

MSFC HOT AIR COLLECTOR PRESSURE DROP TEST DATA - 2" FLOW DEPTH

North East Surface °F (6)										
South East Surface °F (5)										
South Surface °F (4)										
South West Surface °F (3)										
North West Surface °F (2)										
Ambient °F										
T _{in} °F										
T _{out} °F										
ΔT °F										
Solar Flux BTU/Hr·Ft ²										
Flow Rate SCFM	28	59	96	135	154					
Wind Speed MPH										
Efficiency %										
(T _i -T _a) / I °F·Hr·Ft ² /BTU										
ΔP in. H ₂ O	0.0185	0.0461	0.1338	0.2214	0.2952					




Figure 1. MSFC Hot Air Collector Thermal Performance Test Data - 3 In. Flow Depth




Figure 2. MSFC Hot Air Collector Thermal Performance Test Data - 2 In. Flow Depth




Figure 3. MSFC Hot Air Collector Thermal Performance Test Data - 1 In. Flow Depth




Figure 4. MSFC Hot Air Collector Thermal Performance Test Data - 1/2 In. Flow Depth




Figure 5. MSFC Hot Air Collector Pressure Drop Test Data