DOE

MASTER

~~Please return to
Idaho National
Engineering Laboratory
Technical Library~~

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Energy Research and Development Administration, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

R-7741-4509

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy nor any of their employees nor any of their contractors subcontractors or their employees makes any warranty express or implied or assumes any legal liability or responsibility for the accuracy completeness or usefulness of any information apparatus product or process disclosed or represents that its use would not infringe privately owned rights.

EVALUATION OF SEISMIC CRITERIA USED IN DESIGN OF INEL FACILITIES

30 September 1977

Prepared for
Idaho National Engineering Laboratory
ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION
Idaho Falls, Idaho

AGBABIAN ASSOCIATES
El Segundo, California

DISTRIBUTION OF THIS REPORT IS UNLIMITED

RB
DOE

FOREWORD

This study has been conducted under Contract No. EY-77-C-07-1667 for the Idaho National Engineering Laboratory (INEL) of the Energy Research and Development Administration. It provides an independent evaluation of the seismic criteria currently used to design vital facilities at the INEL site. Technical monitor of the study for INEL was Mr. Paul Ruhter. Program manager and principal investigator for Agbabian Associates was George A. Young. Probabilistic, SHAKE and TRISAC computations and evaluations for the study were made by H.S. Ts'ao.

Four consulting geologists/seismologists were used to provide recommendations on the tectonic processes and seismic relationships associated with the INEL region. Recommended studies were also provided to improve the state of knowledge in these areas. These were, Drs. Richard W. Couch, Gregory A. Davis, William P. Leeman, and Robert B. Smith. Their services and the recommendations provided made valuable contributions to the study and are acknowledged. However, all statements and recommendations in this report should be interpreted to be the opinions of Agbabian Associates.

CONTENTS

<u>Chapter</u>		<u>Page</u>
1	INTRODUCTION AND REPORT SUMMARY.	1
	1.1 Introduction	1
	1.2 Problem Definition	5
	1.3 Report Summary	8
2	SIGNIFICANCE OF HOWE AND ARCO FAULTS	18
	2.1 Geologic History	19
	2.2 Historical Seismic Activity	26
	2.3 Tectonic Model	33
	2.4 Assessment of Seismic Hazard Associated with Howe and Arco Faults	36
3	EARTHQUAKE GROUND MOTION INTENSITY PREDICTION PROCEDURES	40
	3.1 Correlation between Fault Length and Earthquake Magnitude	41
	3.2 Correlation between Magnitude, Distance, and Horizontal Ground Acceleration	46
	3.3 Regional Correlation between Mercalli Intensity and Distance	53
	3.4 Correlations between Mercalli Intensity and Maximum Horizontal Ground Acceleration	61
	3.5 Prediction of Maximum Seismic Hazard by Alternate Deterministic Procedure	66
4	SITE TRANSMISSION CHARACTERISTICS	68
	4.1 Basic Factors Affecting Results	69
	4.2 Seismic Attenuation Studies	70
	4.3 Microseismic Data	71
	4.4 Electrical Resistivity Tests	71
	4.5 Earthquake Data	72
	4.6 Effect of Interbedded Alluvial Materials	75

CONTENTS (CONTINUED)

<u>Chapter</u>		<u>Page</u>
5	PROBABILISTIC ASSESSMENT OF THE SEISMIC HAZARD OF THE INEL SITE	76
	5.1 Source Areas of Seismic Events	78
	5.2 Recurrence Curves	87
	5.3 Selection of Maximum Earthquake Magnitude .	99
	5.4 Intensity Attenuation Relationships	102
	5.5 Calculation Procedure	102
	5.6 Computed Probabilities	103
	5.7 Conversion of Mercalli Intensities to Peak Ground Acceleration	108
6	SEISMIC DESIGN CRITERIA	109
	6.1 Background Discussion of Seismic Response Spectra	109
	6.2 Comparison of INEL and NRC Spectra	118
	6.3 Comparative SHAKE and TRISAC Free-Field Analyses	120
7	RECOMMENDED STUDIES	143
	REFERENCES	148

CHAPTER 1

INTRODUCTION AND REPORT SUMMARY

1.1 INTRODUCTION

This report provides the results of an independent evaluation of seismic studies that have been performed to establish the seismic acceleration levels and the response spectra used in the design of Idaho National Engineering Laboratory (INEL) vital facilities. The objectives of the studies reported are to provide the following:

- a. A comparison of the procedures used to define the seismic acceleration values and response spectra used in the design of INEL facilities with the requirements of the U.S. Nuclear Regulatory Commission (NRC)
- b. Recommendations for justifiable changes in the acceleration values and response spectra used as criteria in the design of INEL facilities
- c. Identification of studies that could provide justification for reducing the acceleration values and the response spectra currently being used
- d. An evaluation of acceleration values, both historical and potential values, on a probability basis to permit a risk assessment approach to the design of new facilities and facility modifications

Studies conducted to develop seismic criteria for the design of the Loss of Fluid Test (LOFT) reactor, and the New Waste Calcining Facility (NWCF) were selected by INEL as typical examples of investigative practice and of seismic criteria currently being used in the design of vital facilities at the INEL. A general location map of the INEL site and a map indicating the

relative location of the LOFT reactor and NWCF sites within the INEL site are provided in Figures 1 and 2, respectively. Reports provided by INEL relative to these two facilities that form the basis of this evaluation were the following:

- a. "Preliminary Seismic Risk Evaluation for the National Reactor Testing Station, Idaho," by Woodward Lundgren Associates, Oakland, CA, Jun 1971.
- b. "A Seismic Hazard Study for the LOFT Reactor Facility at the INEL, Idaho," Woodward-Clyde Consultants, Oakland, CA, Jun 1975.
- c. "LOFT SSE Definition and Seismic Analysis Methods," by V.W. Gorman and R.C. Guenzlar, TR-536-AM-46, Aerojet Nuclear Co., Oct 1974.
- d. "Chapter 3.0, Site Characteristics, New Waste Calcining Facility," Preliminary Safety Analysis Report, Allied Chemical Corporation, Idaho Falls, ID, Oct 1975.
- e. "Geological Investigation of Faulting Near the National Reactor Testing Station, Idaho," by Harold E. Malde, Open File Report, U.S. Geological Survey, 1971.
- f. "Preliminary Evaluation of Faults and Linear Features in the Arco Pass Area, Idaho," by Woodward-Clyde Consultants, San Francisco, 1977.

Other reports were provided by INEL relative to microseismic, seismic attenuation and electrical resistivity studies, which will be cited in Chapter 4.

FIGURE 1. GENERAL LOCATION MAP OF IDAHO NATIONAL ENGINEERING LABORATORY
(From Allied Chemical Corp., 1975)

FIGURE 2. GENERAL VICINITY MAP OF IDAHO NATIONAL ENGINEERING LABORATORY
(From Allied Chemical Corp., 1975)

1.2 PROBLEM DEFINITION

A careful review has been conducted of the above reports as well as the technical literature cited. Based on this review, the following major problem areas were defined and investigated to the extent possible within the scope of this contract to help meet the above objectives.

1.2.1 SIGNIFICANCE OF HOWE AND ARCO FAULTS

The investigations by Woodward-Clyde Associates (also Woodward-Lundgren Associates) provides the basis for the selection of the design earthquakes for both the LOFT reactor and NWCF sites. A deterministic procedure has been followed which is consistent with NRC requirements. The major seismic hazard for these facilities has been associated with the Howe and Arco scarp faults because of their length and proximity to the site. Field trenching by Malde (1971) has confirmed that movement has occurred on these faults within the last 30,000 years, possibly more recently than within the last 10,000 years, and movement within the last 4,000 years cannot be ruled out. Consistent with NRC requirements, these faults have been classified as capable faults. There is, however, a conspicuous anomaly, no measurable seismic activity has been historically associated with these faults. Because of this anomaly, and the dominating influence of these faults on the seismic criteria, the major problem considered in this evaluation and review was the significance of the Howe and Arco faults. This problem is reviewed in Chapter 2.

1.2.2 EARTHQUAKE GROUND MOTION INTENSITY PREDICTION PROCEDURES

The Woodward-Clyde investigations have used two correlations to predict maximum horizontal ground acceleration at the LOFT reactor site. The first involves a correlation between fault length (also length of after-shock zone) and earthquake magnitude to estimate the maximum potential earthquake magnitudes that should be assigned to the capable faults. There is a wide scatter in data used in this correlation. The maximum horizontal ground acceleration estimated to occur at the site was then estimated using a

correlation between acceleration, earthquake magnitude, and distance from the causative fault that is based on world data (Japanese, Peruvian, and San Fernando, California, earthquakes). The Allied Chemical study for the NWCF site utilizes comparable procedures.

The Woodward-Clyde Associates study indicates that the scope of their investigation did not permit developing a unique curve which includes regional and site factors. Therefore, a second problem area defined for investigation was to provide a review of these procedures, and an independent estimate of the maximum accelerations to be expected at the LOFT reactor and NWCF sites using attenuation relationships derived from observed attenuating characteristics of regional earthquakes. This investigation is provided in Chapter 3.

1.2.3 SITE TRANSMISSION CHARACTERISTICS

There is speculation that the Snake River Plains (SRP) may be separated from the basin and range structures to the north and south by perimeter faulting. It has been postulated that the perimeter faulting may have partially decoupled the plains from the surrounding earthquake producing zones. For example, the site characteristic study for the NWCF site states that decoupling of the plains was noted near the southern end for the Pocatello Valley earthquake of 27 March 1975. Also, in the vicinity of the LOFT reactor and NWCF sites, well borings indicate that alluvial materials are interspersed with basalt flows. Because of the difference in vertical impedance between these materials, the possibility of significant attenuation in strong earthquake ground motion has been hypothesized. Seismic attenuation, electrical resistivity, and limited microseismic studies have been provided in recent years in the SRP, and the adjoining areas, see Navarro (1975), King et al. (1977), Dahl, Johnson, and Price (1977), and Zohdy and Stanley (1973). Thus, the third problem area defined and investigated was whether the data that have been collected can be used to demonstrate that the SRP does have unique and significantly different transmission characteristics than is found in the surrounding region. The results of the investigation of this problem are provided in Chapter 4.

1.2.4 PROBABILISTIC ASSESSMENT OF SEISMIC HAZARD

The requirements for a statistical assessment of the seismic hazard associated with a proposed nuclear power plant site is not defined in the federal regulations, but is inferred by the high standards for safety and reliability required for containment and safe shutdown of the reactor during and following a major seismic event. The rational determination of the level of reliability achieved in the design of the safety related systems requires that the probability of experiencing the design earthquakes during the service life of the facility be calculated, see Kehrman (1975). Also, at INEL experimental reactors of short service life (5 to 10 years, usually) that operate 10 to 15% of the time are provided in contrast to commercial reactors that have a service life of 40 to 50 years and a plant use factor usually in excess of 80%. Thus, a rational determination of comparable seismic risk for the two completely dissimilar types of facilities can be provided only on a statistical basis. Therefore, the fourth problem area defined for this study was the development of a probabilistic assessment of the seismic hazard associated with the INEL site. The results of this investigation are provided in Chapter 5.

1.2.5 COMPARISON OF RESPONSE SPECTRA

A review of the procedures used to develop response spectra for the LOFT reactor and NWCF facilities was also included within the scope of this investigation. It includes a background discussion of response spectra that are in use, and a review of NRC requirements. This is followed by a comparison of the INEL procedures with NRC requirements. Since the response spectra are defined for free-field conditions (i.e., with no structure present) seismic analyses of the structure and equipment must be based on response spectra derived from the free-field criteria using soil/structure interaction models. At the INEL, the SHAKE and FLUSH computer codes have been used to provide these analyses. Since the SHAKE and FLUSH codes for some site conditions may give abnormal response in a narrow range of frequencies, comparative free-field

analyses were made of an INEL site using the SHAKE and a two-dimensional TRISAC model. The results of this investigation are provided in Chapter 6.

1.3 REPORT SUMMARY

This section provides the study results relative to the four objectives stated in Section 1.1.

1.3.1 OBJECTIVE 1: COMPARISON OF INEL SEISMIC CRITERIA PROCEDURES WITH NRC REQUIREMENTS

This report provides a comparison of procedures followed at the INEL in developing response spectra for the design of the LOFT reactor and NWCF facilities with NRC requirements. Since the procedures are slightly different for the two facilities the comparisons will be provided separately.

1.3.1.1 LOFT Reactor Facility

Seismic criteria for the LOFT reactor facility are based on the field investigative work of Woodward-Clyde Consultants (WCC, 1975). The approach that has been followed is in basic agreement with NRC requirements. However, the investigation is not as comprehensive as would be provided under NRC licensing requirements. Because of this, relatively conservative assumptions have been made about fault lengths assigned to range front faults to the northwest of the INEL site. Continuing studies have been directed towards providing better information on fault lengths associated with past individual seismic events on the Howe and Arco faults. These are the closest capable faults to the LOFT reactor site. Because the approach is basically an NRC deterministic approach, attention currently is focused on only these two fault systems.

The fault length-earthquake magnitude relationship used by WCC to assign earthquake magnitudes to the Howe and Arco faults is conventional and should be acceptable to NRC. Peak ground acceleration assigned to the bed-rock at the LOFT reactor site is based on WCC correlation curves between

earthquake magnitude, fault distance, and peak horizontal bedrock acceleration. These curves lie well above Schnabel and Seed (1973) average attenuation curves, and agree with Schnabel and Seed upper bound curves beyond distances of 30 mi. At distances less than 30 mi the WCC curves are below the Schnabel and Seed upper bound curves. We are in agreement with the WCC procedure and believe that it should be acceptable to NRC. Based on a magnitude of $6 \frac{3}{4}$ assigned to the Howe Fault, a peak horizontal bedrock acceleration of 0.34 g has been predicted for the LOFT reactor site. Unless other more hazardous fault conditions are discovered by later investigations, this value should meet NRC requirements.

Housner mean spectra have been scaled by spectral intensities to provide horizontal design response spectra at the LOFT reactor site that converge to 0.34 g at zero period. Vertical response has been assumed to be equal to two-thirds of the horizontal response. Currently, NRC accepts the use of mean plus one standard deviation spectra as defined in Regulatory Guide (RG) 1.60. For the same peak horizontal bedrock acceleration, the LOFT reactor site spectra gives about 60% of the response required by RG 1.60 in the 2 to 10 Hz range (5% damping), which is the frequency range most significant to nuclear power plant design. This comparison is provided in Chapter 6. Vertical response for frequencies above 2.5 Hz are only about 40% of those given by RG 1.60 procedures.

The design response spectra for the LOFT reactor facilities has been applied at the bedrock level which is conservative. Section 3.71 of the Standard Review Plan (USNRC, 1975) indicates that the design response spectra can be applied at either the ground surface, or at the bedrock level. Our alternate deterministic ground motion prediction for the LOFT reactor site resulted in a maximum ground *surface* acceleration of 0.40 g . Calculations using both the TRISAC and SHAKE codes indicate that an attenuation in excess of 30% of the ground surface spectra (between 3 and 30 Hz) results at the bedrock level. Because of the shallow overburden at this site, about 45 ft, it is doubtful that NRC would accept more than a 25% reduction (i.e., a peak

horizontal bedrock acceleration of 0.3 g). Therefore, based on present NRC practice, the seismic design criteria currently used for the LOFT reactor site would probably be considered deficient only because of the use of mean spectra.

Should the LOFT reactor facility be subject to NRC licensing review, additional geological investigations would probably be required as a result of inquiries that would be made. Additional investigations of the Howe and Arco fault systems to the northwest of the site would probably not lead to more conservative magnitude and maximum bedrock acceleration prediction than currently used (i.e., 0.34 g maximum bedrock acceleration). However, additional investigations on the SRP, and along its northwest boundary might not provide sufficient information to satisfy NRC inquiries, and more conservative criteria could result. The inquiries might arise relative to fissures that have been noted on maps by Witkind (1975) and by Greensfelder (1976) that appear to be in alignment with the Howe fault. Geological evidence of fissuring and basalt flows on the SRP within the past 2,000 years, with no historical seismic activity, is comparable to the geological evidence of movement on the Howe and Arco faults in the past 4,000 to 30,000 years, also with no historical seismic activity. Should the question be raised as to whether these two anomalies represent comparable seismic hazards, or perhaps represent the same seismic hazard, extensive investigations would be required to justify the present INEL position, which in effect assumes that no seismic hazard has its source on the SRP.

1.3.1.2 NWCF Site

Seismic design criteria for the NWCF site is based on the Allied Chemical Corporation (ACC, 1975) study which references the WCC (1975) report and procedures. However the ACC report indicates that consideration was also given to the largest magnitude earthquakes experienced in Nevada on basin and range structures, as well as fault displacement and fault length when selecting maximum earthquakes for the Howe and Arco faults. As a result, larger

magnitude earthquakes ($7 \frac{3}{4}$ vs. $6 \frac{3}{4}$) were assigned to the Howe and Arco faults. In our opinion, the magnitudes assigned in the WCC (1975) report better represent the seismic hazard of these faults and could be justified to NRC based on deterministic procedures.

The ACC (1975) report uses a magnitude-distance-bedrock acceleration attenuation relationship that is unconservative and would probably not be acceptable to NRC. However, because of the conservative magnitudes assigned in the NWCF site investigation, the peak bedrock acceleration selected for design can probably be justified to NRC based on a $6 \frac{3}{4}$ magnitude earthquake on the Arco fault system.

A review of the response spectra proposed for the NWCF site indicates that modified Newmark-Hall spectra have been used. The modified horizontal spectrum gives about 75% of the response of RG 1.60 spectrum at 5 Hz for 5% damping. Two-thirds of the horizontal response is recommended in the ACC report for vertical response. At frequencies between 2.5 and 15 Hz this will give only about 50% of the response indicated by present RG 1.60 vertical response spectra. Therefore, based on present NRC procedures, the seismic design criteria currently used for the NWCF site would probably be considered deficient. Also, similar to the LOFT reactor site, inquiries by NRC, should licensing be requested, would probably require additional geological and seismological investigations. Investigations relative to faults located off the SRP would probably not lead to more conservative magnitude and maximum bedrock acceleration assumptions than presently used. However, more conservative criteria could result from inquiries relative to fissures on the SRP. Extensive investigations would be required to justify the present INEL position, as noted previously in Section 1.3.1.1.

1.3.2 OBJECTIVE 2: RECOMMENDED JUSTIFIABLE CHANGES IN INEL SEISMIC DESIGN CRITERIA

Should INEL wish to conform to NRC licensing requirements, the procedures defined in WCC (1975) are recommended for assigning magnitudes to capable faults and for predicting maximum horizontal bedrock accelerations on the INEL site. Regulatory Guide 1.60 provisions should then be followed for defining horizontal response spectra. However, it is recommended that the vertical response be taken as two-thirds of the horizontal response at all frequencies, as recent studies (AA, 1977a and b), can be used to justify this reduction.

In our opinion, the present NRC deterministic procedure is not a rational approach for the INEL site. We recommend that the level of seismic risk selected for design be based on a probabilistic assessment of the seismic hazard associated with the site. We would recommend that the SSE be selected for future facilities from the results of the probabilistic assessment provided in Chapter 5, based on the service life of the facility, and a probability of 10^{-4} . Since commercial reactors have a plant use factor in excess of 0.8, but experimental reactors at INEL may have a plant use factor of less than 0.2, the reduced plant use factor can also be considered. However, in no case should a maximum horizontal bedrock acceleration of less than 0.1 g be used. Regulatory Guide 1.60 procedures should be used to define the horizontal response spectra. The vertical response should be taken as two-thirds of the horizontal response throughout the full range of frequencies.

Two estimates of the seismic hazard are provided in Chapter 5. The lower estimate is based on the historical record of seismic activity. The SRP and areas 50 to 70 mi in width on both the northwest and southeast sides of the SRP have no historical record of seismic activity. The second estimate assumes that capable faults in the Basin and Range Structure province to the northwest of the INEL site, which have no historical record of seismic activity, have the same seismicity as the average of the seismically active areas. This gives a more conservative estimate of the seismic hazard. Since conservatism should be exercised in design until the aseismic nature of the

SRP and the Basin and Range Structures province can be more adequately explained, the second, or more conservative, estimate of the seismic hazard is recommended for the more hazardous facilities. For less hazardous facilities, the lower level estimate can be used where justified. Additional discussion of the upper and lower level estimates follow in Section 1.3.4.

1.3.3 OBJECTIVE 3: STUDIES REQUIRED TO JUSTIFY REDUCED ACCELERATION VALUES AND RESPONSE SPECTRA

There are many related geological, geophysical, and seismological studies that are needed to provide a better understanding of the tectonic processes in the SRP and the surrounding region, before the lower bound estimate of the seismic hazard associated with the INEL site and given in Chapter 5 can be justified. These studies will be expensive and the INEL will perhaps want to integrate their needs with on-going programs being conducted by other government agencies and state universities. The studies recommended are based largely on the recommendations of our consultants and are as follows:

- a. Map the Crustal Structure of the SRP. Detailed reflection or long-line (>200 km) refraction studies should be made along the NE-SW axis of the Plains and two profiles should be run transverse to this axis. This study is needed to obtain knowledge on the velocity layering, attenuation, density layering, and physical properties of the crust, and to understand the tectonic origin of the SRP.
- b. Establish Semi-Permanent Seismograph Array. A 6 to 8 station telemetered seismograph array should be established around the northwest margin of the SRP. These stations should be mobile to move into active areas where necessary. Data should be RF or telephone telemetered to a central recording site for modern recording and analysis. Also, the existing INEL network should be updated and expanded to provide coverage of earthquakes up

to 100 mi from INEL. The data should be recorded and analyzed with modern techniques. The data should then be interpreted by scientists trained to integrate the data with other geophysical and geological data. This information is needed to provide a better interpretation of both small and large magnitude earthquakes that may occur in the future within a 100-mi radius of the INEL site.

- c. Modern Analyses of Seismic Data Taken by Combined Arrays. The data collected since 1972 from INEL, Tetonia-Bureau of Reclamation, U.S. Air Force, Ricks College, and the University of Utah should all be correlated and interpreted together. Much of the data have been analyzed by inaccurate graphical methods using limited velocity models, some have had only cursory examination and a total correlation has not been provided. This information could be used to develop a first estimate of local velocity models and provide a better interpretation of the local transmission characteristics.
- d. Trenching and Modern Age Dating of Faults. Additional trenching of faults in the Howe and Arco areas should be provided and accompanied with modern age dating of correlatable strata in order to establish recurrence intervals of faulting. However, this should be done with the objective of learning more about the history of faulting in this region than as an objective of providing a recurrence curve for the faults that could be used in ground motion prediction studies, as many faults would have to be treated to provide a meaningful data base for the latter, and the cost would be prohibitive. Other faults northwest and southeast of the SRP in areas having no historical seismic activity should also be investigated to determine if a broad area of capable faults with no historical seismic activity exists. Cooperative investigations with the USGS mapping projects of the SRP should be developed.

- e. Analyses of Quaternary Sedimentary Deposition and Landform Development across the Howe and Arco Faults. Field studies of this type are needed to support the trenching studies described above. Particular attention should be paid to the geomorphic relationships at the mapped ends of the Arco and Howe faults where the structures die out within or are buried beneath deposits of the Snake River Plains.
- f. Field Study of Rangefront Faults North of SRP. Maps by Witkind indicate that rangefront faults are offset by shorter north-south faults. The validity of this relationship and its possible cause and significance to the faulting history of this area should be evaluated.
- g. Low Sun-Angle Photography of the INEL Site. Study should be provided of the northwest-trending fractures or faults within the SRP that are in general alignment with the Howe fault. These features and their projected traces across the INEL should be studied both on the ground and with low sun-angle photography.
- h. Geodetic Leveling, Triangulation, and Trilateration. Repeated measurements along leveling profiles and repeated measurements over triangulation grids in the general region of INEL and the eastern SRP should be provided to detect temporal changes in elevation and distance. This information is needed to determine if the region is undergoing transverse or longitudinal tension, or whether it is in a mode of thermal contraction, or whether it is behaving nonelastically.
- i. Deep Drilling. Deep drilling along the projected axis of the Lemhi or Lost River ranges would provide much useful information on whether these ranges, or faults project beneath the SRP. However, such projects are very expensive and would be best performed in conjunction with deep well-drilling projects.

- j. Attenuating Characteristics of INEL Site Profile. Analyses using SHAKE and TRISAC codes indicate that the shallow soil layer at the INEL site has significant attenuating characteristics with depth. Strong motion recorders placed at the bedrock level and at the ground surface are needed to verify the analytical predictions since the attenuating characteristics of shallow soil profiles are presently under close scrutiny by NRC and the geotechnical profession. Field tests with explosives could also provide timely information as many years may elapse before strong earthquake ground motion would be recorded.
- k. Attenuating Characteristics of Interbedded Basalt and Alluvium Layers. The TRISAC model used to make two-dimensional ground motion calculations in this study could be used to determine whether alternating beds of alluvium and basalt, that supposedly exist below the INEL site, provide abnormal attenuation of ground motion. However, the depth, thickness, and lateral extent of such layers should be determined. Future drilling programs at the site should be planned with the need for this information in mind.

1.3.4 OBJECTIVE 4: PROBABILISTIC ASSESSMENT OF SEISMIC HAZARD OF INEL SITE

Three areas of historical seismic activity were identified that contribute the seismic hazard to the INEL site. These areas are centered roughly 80 to 150 mi from the INEL site and lie northwest, northeast, and southeast of the INEL site. An up to date (through 1975) record search of historical earthquakes was made and separate recurrence curves were developed for the three source areas. Maximum earthquakes of body wave magnitudes 7.1 to 7.5 were assigned to these areas, depending on both geologic and historical seismicity data. Mercalli Intensity-distance attenuation curves were used in the calculations. The seismic hazard at the INEL site was then predicted

in terms of Mercalli Intensity rather than in peak ground acceleration because of the higher confidence level associated with the former. Procedures for converting Mercalli Intensity to peak ground acceleration are also discussed.

The seismic hazard of the INEL site was defined by upper and lower level calculations. The lower level prediction does not assume the seismic hazard to be associated with the Basin and Range Structure province northwest of the INEL site which has no historical seismic record. The upper level estimate assumes seismic activity in the Basin and Range Structure province equivalent to the average historical seismicity of adjoining seismically active areas. Based on these assumptions, the lower level estimate of the seismic hazard at the INEL site having a probability of occurrence of 10^{-4} during a 50-year period is a Mercalli Intensity VII-VIII. This is equivalent to a ground *surface* acceleration of 0.1 g. For the upper level estimate, a Mercalli Intensity of VIII-IX is indicated, which is equivalent to a ground *surface* acceleration of 0.4 g. *Bedrock* accelerations for the two cases should be taken as 0.1 g and 0.3 g, respectively.

CHAPTER 2

SIGNIFICANCE OF HOWE AND ARCO FAULTS

Discussion in Section 1.2.1 of Chapter 1 indicates that currently the major seismic hazard for facilities located on the INEL site is associated with the Howe and Arco faults, because of their length, Recent activity, and close proximity to the site. It also notes that no measured seismic activity has been historically associated with these faults, but the period of historical record is short. Therefore, one of the major problem areas investigated in this study was to review known and hypothesized regional and local tectonic relationships that have contributed to the development of these faults as well as the Recent activity associated with them. The results of this investigation are provided in this chapter.

The approach followed has been to carefully review the studies that provide the basis for the seismic criteria currently defined for the LOFT reactor and NWCF sites, and pertinent literature cited in these studies. Consultative discussions were also held with four prominent geologists/seismologists actively engaged in seismic research in the western United States. A discussion was also held with a representative of the United States Geological Survey conducting field studies northwest of the Snake River Plains in areas pertinent to this investigation.

Based on this investigation, it is our conclusion that the studies conducted by Woodward-Clyde Consultants (WCC, 1971 and 1975) in support of seismic criteria studies for the LOFT reactor facilities represent competent investigations that have identified capable faults in a manner that is consistent with NRC requirements. Since the scope of their investigations have been limited, their conclusions have been necessarily conservative. Follow-on investigations (WCC, 1977) have been directed towards determining from field evidence whether the postulated magnitudes of potential earthquakes on the Howe and Arco faults can be logically reduced.

The documentation that has been prepared in support of the NWCF facilities by Allied Chemical Corporation (ACC, 1975) represents a comprehensive summary of the technical literature pertinent to the region and to this site and is current up to the date of the report. Taken collectively, the WCC and ACC reports provide a factual summary of the known geological and seismological factors that must be considered in the development of seismic criteria for facilities located on the INEL site. Because of the comprehensive nature of these reports, this chapter will present only a brief summary of the geologic history and of the regional and local seismic activity. It emphasizes tectonic relationships, and is provided to indicate the present state of knowledge, to update the tectonic model, and to provide background for our assessment of the seismic hazard that should be associated with these faults.

2.1 GEOLOGIC HISTORY

The rocks in the mountains surrounding the Snake River Plains have been characterized as being geologically old, and the prominent geologic structures as being relatively young, but the fault movements associated with these structures which are of concern to this study are recent (30,000 to 4,000 years before the present (BP), see Malde, 1971). More specifically, sedimentary processes began in this region more than 500 million years (my) ago and continued for roughly 300 my. Several orogenic episodes began midway through this depositional period, and continued up until 100 to 140 my BP, eventually terminating the depositional regimes. The Nevadan orogeny, for example, strongly affected the depositional system in western Idaho. The metamorphic and plutonic rocks of the Nevadan orogenic belt form the basement complex in this western region, including the Idaho batholith. In a similar manner, the Sevier orogeny terminated marine sedimentation in east central and southeastern Idaho about 100 my BP.

The volcanism and tectonism during this period was due to convergence of Pacific and North American plates (and the subduction of the former) which produced east-west crustal compressional stresses. This condition continued until approximately 20 my BP. The subduction of the oceanic plate resulted in the wide spread extrusion and intrusion of intermediate magmas in the Idaho region up until that time (Mid-Cenozoic). At this point in geologic history, there was a shift from compressional to tensional deformation which resulted from the annihilation of the west coast subduction zone and led to the formation of the San Andreas fault. Subsequent volcanic activity in the Great Basin and in the Snake River Plains (SRP) was of bimodal--basaltic and rhyolitic--type. The change in stress condition and the resulting volcanism and uplift has been described by Smith (1977) as follows:

Horizontal stresses in this regime were reoriented at ~20 m.y. B.P. to that of oblique convergence parallel to the San Andreas fault and relaxed the horizontal stress allowing crustal extension. Partial melting of the subducted slab represented by the ignimbrite flareup is hypothesized to have released material that rose through the mantle to form a laterally spreading diapir beneath the Great Basin. During the ignimbrite flareup ~43 m.y. B.P. high temperatures and partial melting are postulated to have begun uplift, thinning and distension of the lithosphere beneath the Great Basin. This process was probably accelerated by the change in regional stress from compression produced by northeast subduction at ~20 m.y. B.P. to east-west extension produced by oblique plate convergence. A thin crust, low upper mantle velocities, high heat flow and relatively high topography of the Great Basin probably reflect this major thermal event.

The dramatic frontal range faults characteristic of the basin and range structures to the south of the SRP are evident in Figure 3. A more detailed indication of local faulting that also shows the basin and range structures to the northwest of the SRP is shown in Figure 4. These major structures developed about 7 to 12 my BP. The horst-graben type structures have undergone partial erosion since that time. During this period (from 7 my BP), southern Idaho has consisted of a rugged mountain mass with the

FIGURE 3. GENERALIZED LATE MESOZOIC-CENOZOIC TECTONIC MAP OF INTERMOUNTAIN WEST TAKEN FROM KING'S TECTONIC MAP OF NORTH AMERICA (1969) AND FROM U.S. GEOL. SURVEY'S (1962) TECTONIC MAP OF UNITED STATES. STRIPPLED PATTERN = TERTIARY AND QUATERNARY VOLCANIC ROCKS; DOTS = GRANITIC PLUTONS; HEAVY LINES = PHYSIOGRAPHIC BOUNDARIES. LATE CENOZOIC AND QUATERNARY FAULTS SHOWN WITH HACHURES ON DOWNTOWN SIDE. (From Smith and Sbar, 1974)

FIGURE 4. MAP SHOWING TECTONIC PROVINCES AND FAULT LOCATIONS (From WCC, 1975)

Idaho Batholith on the west and basin and range structures exhibiting about 10,000 ft of relief on the east.

Smith (1977) points out that there was widespread volcanism in the Great Basin from ~43 to ~19 my BP. It began again at 15 my BP at the west end of the SRP as part of a progression of silicic volcanic centers that migrated northeastward to the Yellowstone Plateau where the latest rhyolites were erupted 0.6 my BP. The silicic volcanics moved along the axis of the SRP at rates of about 3 cm/yr (Armstrong, Leeman and Malde, 1975) and was followed by the development of the present low lying depression that constitutes the SRP.

The silicic volcanics in the SRP were later covered by olivine basalts. According to the WCC (1975) report, silicic rocks beneath the flat lying basalts in the region of the LOFT reactor site have been dated by Chase (1973) at about 10 my BP, but the overlying layer of more than 400 ft of basalt has been dated by Armstrong et al. (1975) between 2.3 and 0.7 my BP. However, volcanic flows on the SRP have continued to the present, with the last flows at the King's Bowl Rift being estimated to be as young as 2000 years BP.

Recent crustal deformation measurements across the Great Basin and the SRP indicate that general regional uplift with local subsidence in the SRP is continuing. The data (Smith, 1977) suggest contemporary arching of the west Central Great Basin relative to the Rocky Mountains of surprisingly high rates. The SRP, however, exhibits *relative* sinking and at a lower rate. This would indicate uplift and extension is continuing regionally and that downwarping on a relative basis is also continuing in the SRP. The extensional processes has lead to a general thinning of the earth's crust in the area of the Great Basin as indicated in Figure 5.

The processes which have led to the formation of the SRP are unknown. Smith (1977) has indicated that it may have resulted from the track of a mantle plume, a propagating lithospheric fracture or a propagating

FIGURE 5. MAP SHOWING CRUSTAL THICKNESS IN WESTERN UNITED STATES IN KILOMETERS (From Smith, 1977)

crust/mantle melting instability. Three resulting structural hypotheses for the SRP discussed rather completely in the ACC (1975) report are: (1) it is a simple downfaulted graben structure which has been inundated by flood basalts (Russell, 1902), (2) it is a huge downwarp which may have small fractures and faults at the boundaries, but probably has large fissures at the center of the SRP from which the basalt rose to cover the sinking horst and graben structures (Kirkham, 1931), and (3) it is a tensional rift zone (Hamilton, 1963).

Based on present knowledge, we accept the following statements provided by our consulting geologist (Davis, 1977) as the best interpretation that can be made at this time:

- a. Petrologic, structural, and geophysical data for the eastern SRP are at present insufficient to resolve the tectonic origin of the SRP and the nature of basement rocks and structure beneath the late Cenozoic cover of sedimentary and volcanic rocks.
- b. However, the eastern SRP is not believed to be a fault bounded graben, but rather an area of sagging or subsidence, related in some way to the accumulation of late Cenozoic volcanic rocks.
- c. Since the eastern Plain is not believed to be a tensional rift, the continental crust probably underlies all or most of the eastern SRP and the block faulted structures seen on both sides of the Plain probably continue beneath it, where it is buried by lavas and sediments.

Evidence that supports the above statements has been recently provided by Kuntz (1977). Kuntz has found that nearly all Pleistocene and Holocene basalt volcanoes in the eastern SRP represent rift controlled eruptions. The rift controlled vents delineate major rift zones which are oriented northwest to southeast normal to the longitudinal axis of the Plain.

Each rift zone having this orientation intersects the Plain margin at or near a range front fault or older structure in the mountains that flank the Plain. Kuntz further notes that these spatial relationships suggest that the rift zones are extensions of basin and range and older structures on to the Plain.

2.2 HISTORICAL SEISMIC ACTIVITY

Figure 6 provides an epicentral map of North and Central America which clearly identifies the very active seismic regions along the west coast, as well as a north-south area of epicenters that are identified as the Intermountain Seismic Belt (ISB). Figure 7 gives a more detailed location of the ISB relative to regional fault structures, and Figure 8 shows the general location of this zone in relation to other seismic zones of western United States. The ISB has been described by Smith and Sbar (1974) (see also Smith, 1977) as a belt approximately 90 mi in width that extends north from Arizona through Utah, eastern Idaho and western Wyoming, and then swings to the northwest through western Montana. This zone is about 1000 mi in length and is coincident with the boundary between the Basin and Range province and the Colorado Plateau-Middle Rocky Mountains in the south, and with the fault zones of the Northern Rocky Mountains in the north. A related seismic zone extends west into central Idaho north of the SRP. It is identified in Figure 8 as the Idaho Seismic Zone.

The seismic history of the ISB is adequately covered in the references cited above by Smith, and Smith and Sbar, and covered locally in the WCC (1975) and ACC (1975) reports. Also, discussion of the local seismicity through 1975 is provided in Chapter 5. Therefore, only essential factors will be noted here. An earthquake of magnitude 7.1 occurred in the ISB at Hebgen Lake in 1959 and more than 16 events of magnitude 6 or greater have been noted since 1850. Several have been associated with surface faulting. On a comparative basis, the seismic activity in the ISB is much less than in the west coast region, but it ranks as the next most active seismic region in the United States (not including Alaska).

FIGURE 6. INDEX MAP OF INTERMOUNTAIN SEISMIC BELT ON SEISMICITY OF NORTH AMERICA (From Smith and Sbar, 1974)

FIGURE 7. EPICENTERS FOR INTERMOUNTAIN SEISMIC BELT SHOWING ALL EARTHQUAKES REPORTED BY NATIONAL OCEANIC AND ATMOSPHERIC ADMINISTRATION (NOAA) OF ABOUT MAGNITUDE 3.0 OR GREATER FROM 1961 THROUGH 1970 (From Smith & Sbar, 1974)

NAME AND REFERENCES:

- (1) PUGET SOUND ZONE
- (2) IDAHO SEISMIC ZONE
- (3) INTERMOUNTAIN SEISMIC BELT
- (4) UNNAMED
- (5) NEVADA SEISMIC ZONE
- (6) SAN ANDREAS ZONE

FIGURE 8. INDEX MAP OF SEISMIC ZONES (From WCC, 1975)

Figure 9 provides the relative location of bodywave magnitude 4.2-4.7 earthquakes (epicentral intensity V) in the source areas pertinent to the INEL site. Prominent causative faults identified in Figure 4 are also indicated. Larger magnitude earthquakes are also plotted in Chapter 5 in Figure 32. The epicentral locations of these earthquakes are comparable to those noted in Figure 9. It is important to note the lack of historical seismic activity associated with the northwest trending faults (Howe and Arco faults are included in these) in close proximity to the INEL site. This will be discussed further in Section 2.4.

Smith (1977) notes that prior to 1960, the minimum magnitude locatable earthquakes in this region was about 3.5. Following the installation of the World Wide Standard Seismograph Network stations starting in 1960, the locatable magnitudes decreased to about 2.5 by 1970. This network accounts for much of the increase in reported seismic activity in this region in the past 17 years. A remaining factor is perhaps the aftershocks that have continued in the Hebgen Lake area following the magnitude 7.1 earthquake in 1959.

Smith estimates that the epicentral accuracy of older regional data is only about ± 10 mi (15 km) and for present regional data it is no better than about ± 5 mi (± 7 km). However, detailed surveys have been conducted in Utah which have located epicenters within $\pm 1/2$ mi (± 1 km). Based on careful studies, Smith (1977) concluded that many of the accurately located epicenters (± 1 km) *do not* coincide with mapped Cenozoic faults. This is an important consideration in view of the fact that NRC deterministic approaches utilize the location of existing capable faults to define the source of future epicenters. Actually existing capable faults and the historical earthquakes under these conditions should be used to locate potential *source areas*.

Smith (1977) also notes that focal depths cannot be accurately determined unless at least one recording station is within a hypocentral distance equal to one focal depth. Accurate data can only be obtained when six or more stations are available, and accurate velocity data are available. Figure 39 in Chapter 5 provides a histogram for ~1200 focal depths derived from detailed earthquake surveys using up to 15 stations with station spacings from 3 to 15 km. In source areas significant to the INEL site, a focal depth of about 5 mi is indicated. Smith notes that 97% of the focal depths are less than 10 mi (15 km). He concludes that these observations place a restriction on the limit of brittle deformation of the lithosphere in these source areas to depths of ~10 mi (15 km).

Couch has noted in personal discussions, that faults for larger magnitude earthquakes in the ISB probably penetrate below this depth, and probably have a different recurrence relationship than smaller magnitude earthquakes. Smith has also indicated that the recurrence interval of large magnitude earthquakes in the ISB is greater than for California (San Andreas) earthquakes. The recurrence interval for magnitude 7 earthquakes is estimated by both to be hundreds to thousands of years, as opposed to only a few hundred years along the San Andreas fault.

The historic earthquake pattern in the ISB also indicates that earthquake swarm activity is not uncommon. Circled areas in Figure 7 indicate locations of such activity. Earthquake swarms generally have no distinct main shock, but the events occur closely in time and space. Swarms are generally associated with midoceanic ridge crests, in regions of active volcanism and in association with geothermal features, see Smith and Sbar (1977). High heat flow has been associated with some of the swarms in the ISB, such as in the Helena, Montana, area. Nearly 2300 shocks were associated with the 1935 Helena earthquake swarm in a period of 14 months. The largest magnitude earthquakes experienced were 6.2 and 6.0.

2.3 TECTONIC MODEL

Figure 10 illustrates the tectonic model for western United States recently proposed by Smith (1977). This is an extension and improvement to the model proposed by Smith and Sbar (1974) and discussed in the ACC (1975). In the most recent model, principal displacement between the obliquely converging North American and Pacific plates continues to be assigned to the San Andreas, a right-lateral transform fault. However, some of the lateral motion between the plates is also assumed to be accommodated within a continental zone that extends nearly 1000 mi inland and consists of three intraplate lithospheric blocks which are characterized as being "slivers" between the obliquely converging North American and Pacific plates. These are designated as the Sierra Nevada, the Great Basin-High Lava Plains, and the Northern Rocky Mountains-Columbia Plateau subplates. The Colorado plateau is also identified as a fourth subplate which is to the east of the area of interest of this study. The intraplates are shown in Figure 10. Earthquake epicenters are located generally within the boundary region of the subplates except in the region of the SRP between the Great Basin and the Columbia Plateau subplates.

Figure 11 provides the direction of principal stress near the intraplate boundaries reported by Smith and used to infer the proposed tectonic model. These stress patterns are in general agreement with the type of faulting that has been associated with historical earthquakes. Normal faulting, for example, has resulted along the north-south faults along the Wasatch Front in Utah, and southeastern Idaho which is to the southeast of the eastern SRP, and significant strike-slip faulting has occurred along the ISB in Montana.

Smith postulates that an aesthenospheric melting anomaly, perhaps manifested by a mantle diapir, initially formed the lithospheric uplift coincident with the present areas of highest topography and contemporary uplift in the central and northern Great Basin. Volcanism of the SRP is then considered to be related to a northeast propagating lithospheric zone of fracture, or a transgressing melting anomaly that is now centered in the Yellowstone area, as previously noted.

FIGURE 10. MAP SHOWING TECTONIC MODEL FOR WESTERN UNITED STATES PROPOSED BY SMITH (Smith, 1977)

FIGURE 11. MAP SHOWING DIRECTIONS OF PRINCIPAL STRESS IN WESTERN UNITED STATES FROM FAULT PLANE SOLUTIONS (From Smith 1977)

Referring to Figures 10 and 11, it will be noted that the regions both to the north and south of the SRP, as well as the SRP, are indicated to be in an extensional state of stress. To the southeast of the SRP, the principal stress field is clearly defined to be *normal* to north-south trending faults, but to the northwest of the eastern portion of the SRP, the principal stress field is not really known, but is inferred to be normal to the axis of the SRP. This would be *parallel* rather than normal to the range front faults in close proximity to the site (i.e., the Howe and Arco faults). While there is some logic associated with assuming a tensile stress field normal to the axis of the SRP, the state of stress in this region is too complex to be inferred in the absence of fault plane solutions, and with little knowledge of the buried geologic structures in the SRP. This hypothesis leads to the concept that there is continental spreading or perhaps a northeast propagating lithospheric zone of fracture along the SRP. In contrast, the tensile stress field may be oriented differently in this area as indicated in the following communication from Davis (1977):

The much greater development of basin and range normal faulting south of the eastern Plain than to the north, strongly suggests that east-west or east-northeast west-southwest crustal dilation is greater south of the Plains than in areas to the north. The resulting differential dilation of areas south and north of the Plain should produce right-lateral deformation parallel to the axis of the Plain--either by diffuse strain or by strike-slip faulting along discrete zones. I am unaware of existing evidence for either deformational mode.

This would discount the concept of continental spreading in this zone, see Kunz (1977). However, fissuring and faulting could still occur in and adjacent to the SRP, and might also result from local downwarping.

2.4 ASSESSMENT OF SEISMIC HAZARD ASSOCIATED WITH HOWE AND ARCO FAULTS

The discussion in this chapter has provided a brief summary of the geologic and seismic history pertinent to the region surrounding the SRP, and of the postulated processes which may control seismic activity in this

general area. It is evident that information available at this time is not sufficient to determine the origin of the SRP, the nature and structure of the basement rock, nor to establish the state of crustal stress and the most probable cause of local faulting. However, there are certain observations that can be made and upon which reasonable postulations can be based.

First, referring to Figures 4 and 9 it should be noted that the historical seismic activity to the northwest of the INEL site has occurred on the southern and eastern flanks of the Idaho Batholith and well out of the SRP. This is an entirely different geologic province than the Basin and Range Structure province in which the very dramatic range front faults to the northwest of the INEL site are located. These faults have been treated deterministically as capable faults in past hazard assessment studies. The cause of earthquakes in the Idaho Batholith province are no doubt related to the plate stress field, but the cause is also probably related to discontinuities between the batholith and adjoining sedimentary rock formations, as well as to batholithic thermal relationships. There is, therefore, little reason to assume that the seismic energy release that has taken place in the Idaho Batholith province will be transferred suddenly in the future to the Basin and Range Structure province.

Second, there has been no historical seismic activity in an area about 150-mi wide that extends for nearly 300 mi along the axis of the SRP. This aseismic zone extends well beyond the SRP and encompasses an area quite large to have been seismically inactive for 80 years merely because of the random nature of seismic events. In contrast, the seismic activity has been confined to the major plate boundaries (and to the Idaho Batholith province). That is, to strike-slip faults along the Montana border to the north and to the northeast, and to normal faults to the south along the Wasatch front. The major cause of earthquakes within these two zones of the ISB would appear to be the northwest drift of this large plate, driven primarily by the oblique movement of the ocean plate along the San Andreas fault. Perhaps additional contributing factors are thermal effects which are causing significant regional uplift, and local, relative downwarping in the SRP area.

Third, trenching along the Howe and Arco faults (Malde, 1971) has indicated that movement has occurred along these faults between 4,000 and 30,000 years ago. Also, volcanic activity has occurred in the SRP as recent as 2,000 years ago. However, it has not been established that the movement on the Howe and Arco faults has been associated with large magnitude earthquakes rather than with periods of creep movement that could have included only small magnitude earthquakes. The possibility of creep movement in this region, which might include small magnitude earthquakes, is suggested because of rock temperatures. This could explain the aseismic nature of the SRP as well as the adjoining areas immediately to the north and south of the Plains which is indicated in the short historical seismic record. However, the period of record is short and no geological evidence supports or clearly contradicts this conclusion.

Geologic evidence of fissuring and basalt flows on the SRP within the past 2,000 years with no historical (80 years) seismicity is to some extent comparable to the geologic evidence of movement on the Howe and Arco faults in the past 4,000 to 30,000 years but with no historical (80 years) seismic activity. Prior investigations (WCC, 1975 and ACC, 1975) have dismissed the hazard of renewed volcanic activity on the SRP with the assumption that renewed activity will be preceded by months, or years, of microseismic activity which would be detected by the present INEL microseismic program. If this assumption is acceptable, then it is difficult to associate a significant seismic hazard to the nearby range front faults in the Basin and Range Structure province. Likewise, if a significant seismic hazard is associated with the nearby range front faults, then to be consistent it is difficult to conclude that future volcanic activity on the SRP poses no seismic hazard.

The seismic hazard associated with the SRP and the Basin and Range Structure provinces may be well represented by the seismic quiescence that has been experienced in these provinces for the past 80 years. If so, the seismic hazard could be assumed to be represented by the historical record. However, it is recommended that this be considered to be a lower bound estimate. For the design of important INEL facilities, a more conservative

estimate is recommended because of the extremely short historical record, and because the tectonic origin of the SRP, the nature of the basement rock, and its structure are all not known. For important INEL facilities, it is recommended that the seismic hazard of the Basin and Range Structure province be assumed to correspond to the average seismicity of the adjoining seismically active areas (i.e., the average of Areas A, B, and C indicated in Fig. 9). While no seismic hazard is currently recommended to have its source on the SRP, additional investigations are needed to justify this position. Continuing, long term geological and geophysical investigations are needed to explain the seismic anomalies of the SRP and the Basin and Range Structure provinces.

CHAPTER 3

EARTHQUAKE GROUND MOTION INTENSITY
PREDICTION PROCEDURES

Two correlations were used in the Woodward-Clyde Consultants (WCC, 1975) seismic hazard study for the LOFT reactor facilities to predict the maximum horizontal ground acceleration that might be experienced at this site from movement on capable faults. First, a correlation was provided between fault length and earthquake magnitude. This relationship was used to estimate the maximum potential earthquake magnitudes that should be assigned to the various capable faults. A second correlation between earthquake magnitude, distance from the capable fault, and bedrock acceleration was then used to predict the maximum horizontal bedrock acceleration that should be anticipated at the LOFT reactor facilities site from the assigned earthquake magnitudes. The maximum horizontal bedrock acceleration has then been used to scale design response spectra. The same general procedure was used to define seismic criteria for the NWCF site by the Allied Chemical Corporation (ACC, 1975).

The procedures described above are used in general practice. The major weaknesses of the method are that the relationships are based on meager data, and the data used generally do not incorporate the influence of regional, or local, geological characteristics. The objective of this chapter is to provide an independent check on the predictions for the LOFT reactor and NWCF sites using an alternate procedure that incorporates regional data where possible. However, because there is practically no regional or local strong motion acceleration data, in the final step of the alternate procedure, reliance will also have to be placed on a meager collection of west coast acceleration-intensity data. Therefore, the secondary objective of this chapter is to provide a background discussion of the conventional procedures, as well as of the alternate procedure, that identifies the uncertainties associated with the prediction of the intensity of strong earthquake ground motion to be expected at nuclear facility sites.

A background discussion of correlations between fault length and earthquake magnitude; earthquake magnitude, distance from the causative fault, and acceleration; Mercalli Intensity and distance; and Mercalli Intensity and acceleration follows. The chapter then concludes with an alternate deterministic prediction of the maximum horizontal ground acceleration that might be experienced at the LOFT reactor and NWCF sites, and a comparison with the predictions that have been made previously with conventional procedures.

3.1 CORRELATION BETWEEN FAULT LENGTH AND EARTHQUAKE MAGNITUDE

It is generally recognized that earthquakes are nearly always associated with movements of an earth crustal mass along a fault surface. Exceptions are earthquakes associated with volcanic activity. Faulting occurs when strains (stresses) in the earth's crust accumulate to the point that its rupture strength is exceeded. Richter (1958) has demonstrated that the magnitude of shallow earthquakes in California are related to the *vibratory* energy released ($\log_{10} E = 11.4 + 1.5M$, where E equals the energy in ergs, and M is the local magnitude). It follows, therefore, that there should be a relationship between the total energy released, the magnitude of the earthquake, the mass of the earth's crust translated along the fault, and the fault movement. It should also be evident that the relationship is not simple, since the state of stress in the crust at the time of faulting may be predominately tensile stress (normal faulting), compressive stress (thrust faulting), shear stress (strike-slip faulting), or a combination of shear stress with either tensile or compressive stress. It should also be apparent that the distance of fault movement which is usually neglected is also an important parameter. Thus, it should be expected that an empirical relationship between simply fault length, and earthquake magnitude would be poorly defined. This is the case. However, this correlation is further complicated by the fact that the relationships used are based on a relatively few earthquakes.

Correlations in use are based largely on the data provided by Bonilla (1967, 1970) whose data and curve are provided in Figure 12. Bonilla obviously recognized the limitations of the data, and used a curve which maximized fault length. It is significant to note that Bonilla provides only three data points for reverse (thrust) faulting, four for right normal faulting, and seven each for normal faulting and strike-slip faulting. Obviously, sufficient data are not available to provide a correlation based on type of faulting, but this is probably an important parameter. Ordinarily, it would be expected that the reverse thrust fault would require the least fault length for a given magnitude, and normal and right normal faulting would require the greatest. Strike-slip faulting should require an intermediate length. Only to a limited extent is this relationship evident from the data presented by Bonilla.

Line *B* in Figure 12 has been plotted from the work of Seed et al. (1969) who used the same data and made no differentiation between fault type. Line *B* is a mean curve for the Bonilla data. Greensfelder (1976) more recently used approximately the same data (one data point dropped and two added) to provide the mean and standard deviation curves shown in Figure 13. The mean curve in Figure 13 agrees essentially with Line *B* in Figure 12. Also, Greensfelder has not tried to consider the influence of the type of faulting on the correlation relationship.

In contrast to the Seed and Greensfelder curves, the WCC curve in Figure 14, which was used in the LOFT reactor site study, indicates a break in the scaling relationship at fault lengths of about 12 mi. The basic relationship in this figure is reported to be between length of aftershock fault zone and earthquake magnitude. A single point correlation is then provided between the aftershock and surface fault length curves using local data from the Hebgen Lake earthquake. The number of data points, however, within the same range of fault lengths considered by Seed, Greensfelder, and Bonilla, are not greatly different (30 vs. 21). A comparison between the Greensfelder and WCC curves for a magnitude of 6.75 is of interest. The Greensfelder curves indicate that the fault length for the 67% confidence interval ranges

57

FIGURE 12. COMPARISON OF EARTHQUAKE MAGNITUDE VERSUS FAULT RUPTURE LENGTH RELATIONSHIPS (From Bonilla, 1970 and Seed et al., 1969)

FIGURE 13. EARTHQUAKE MAGNITUDE VERSUS FAULT RUPTURE LENGTH
(From Greensfelder, 1976)

FIGURE 14. EARTHQUAKE MAGNITUDE VERSUS FAULT LENGTH RELATIONSHIPS
(from Woodward-Clyde, 1975)

— between 7 and 40 mi, as compared to 9 and 30 mi for the WCC curves. The reduction in scatter in the data is explained in the WCC report as being due to the fact that instrument determined fault lengths provide a better definition of the actual fault length. Unfortunately, these curves must be used to predict magnitudes for *surface determined* fault lengths that are being postulated several thousand years after the last fault movement--without instrumentation. Therefore, it is difficult to conclude that the accuracy of the prediction procedure can be improved greatly over that indicated by the Greensfelder curves. In other words the range in observed surface fault length that would produce a magnitude 6.75 earthquake on the Howe and Arco faults should be assumed to vary from 7 to 40 mi or by a factor of 5 to 6. This is obviously a crude procedure for predicting earthquake magnitude.

3.2 CORRELATION BETWEEN MAGNITUDE, DISTANCE, AND HORIZONTAL GROUND ACCELERATION

The first correlation between maximum horizontal ground acceleration, earthquake magnitude, and distance from the causative fault was provided by Housner (1965). These curves, which are shown in Figure 15a are for ground surface accelerations since nearly all existing records are monitored at the ground surface. At that time, far fewer records were available than at the present, so the confidence level in these curves must be considered marginal.

In 1969, Seed et al. published a comparable set of curves that related *bedrock* acceleration, earthquake magnitude, and distance from the causative fault. This was done in an attempt to eliminate the influence of soil conditions. This study considered correlations of Gutenberg and Richter, Benioff, Kanai, Housner, Esteva and Rosenblueth, and Blume, and the resulting curves were reported to be an average of these correlation studies. However, there were very few bedrock acceleration records available in 1969. There are also very few available today.

(a) Housner, 1965

(b) Schnabel and Seed, 1973

FIGURE 15. EARTHQUAKE MAGNITUDE-DISTANCE ACCELERATION RELATIONSHIPS

The Seed et al. (1969) correlation curves have not been shown as these curves were modified following the San Fernando earthquake of 1971 (Schnabel and Seed, 1973) to provide greatly increased acceleration values. The results of the 1973 study are indicated in Figure 15b. These curves have had wide use. However, the user should be aware that these curves are actually based on very little data recorded on rock. For example, Figure 16 indicates the data used to extrapolate the magnitude 6.6 and 7.6 curves. Referring to Figure 16a, the solid symbols were reported to indicate recorded rock site values. The open symbols represent bedrock values *computed* using the one-dimensional SHAKE code and a mathematical model of the overlying soil profile. One value which is obviously in error is the value indicated at 0.5 g at a distance of slightly over 6 mi from the causative fault. There were no recorded accelerations of 0.5 g in the San Fernando earthquake. Our interpretation of this value is that it is probably a bedrock value *computed* from the surface record of 8244 Orion Street which had a maximum ground surface acceleration of about 0.3 g. This site has a soil profile in excess of 600 ft. There was therefore only one recorded bedrock value closer than 17 mi and above 0.2 g in the magnitude 6.6 data used by Schnabel and Seed. The data for the magnitude 7.6 earthquake given in Figure 16b is practically nonexistent since there are only two recorded values, and these are more than 60 mi from the fault and resulted in peak accelerations of less than 0.05 g. Considering the simplicity of the SHAKE code, and the very meager data available on earthquake bedrock accelerations above magnitude 5.6, the Schnabel and Seed curves in Figure 15b must also be considered to be average curves of only marginal reliability. These curves, however, are used by many investigators with much greater precision than justified. It is particularly noted that the attenuation curves by Schnabel and Seed were presented with a scatter band, even though constructed with practically no data, see Figure 16, but the curves normally used, Figure 15b, are average curves.

(a) Accelerations in rock for earthquakes with magnitudes 6.6

(b) Acceleration in rock for earthquakes with magnitude 7.6

FIGURE 16. EARTHQUAKES MAGNITUDE, DISTANCE ACCELERATION RELATIONSHIPS (Schnabel and Seed, 1973)

The correlation between earthquake magnitude, distance, and acceleration used by WCC is provided in Figure 17. These curves have the same general characteristics as attenuation relationships proposed by Cloud and Perez (1971), and Donovan (1972). It is significant to note that except for a relatively few points, all data are more than 30 mi from the causative fault, and are for maximum horizontal accelerations of less than 0.2 g. The data base, therefore, is approximately the same as used by Schnabel and Seed, except Japanese and Peruvian data are also included. Extrapolation of these curves into regions of high acceleration and short fault distances is based on judgment, and not on factual data.

Figure 18 provides a comparison of the WCC and ACC scaling relationships for an earthquake magnitude of $6 \frac{3}{4}$ with those proposed by Housner, and Schnabel and Seed. The earlier Seed et al. (1969) relationship is also shown, as is the mean and upper bound curve given in Figure 15a by Schnabel and Seed. It should be noted that the Housner curve is for the ground surface while all of the remaining curves are for bedrock. For distances greater than 30 mi, the Schnabel and Seed upper bound curve, and the WCC curves are superimposed. For distances less than 30 mi, the Schnabel and Seed upper bound curve lies significantly above the WCC curve. This results from the strong influence of the San Fernando, 1971 earthquake on the Schnabel and Seed relationship. The San Fernando earthquake was a reverse thrust fault which produces a higher energy release per unit of fault area than normal and strike-slip faults. Since only normal and strike-slip faulting occurs in the region surrounding the Snake River Plains, in our opinion, the WCC relationship is the better upper bound estimate. Also, it should be noted that the ACC relationship used for the NWCF site is below the Schnabel and Seed average curve, and is difficult to justify.

FIGURE 17. EARTHQUAKE MAGNITUDE-DISTANCE-ACCELERATION RELATIONSHIPS
(from Woodward-Clyde, 1975)

FIGURE 18. COMPARISON OF ACCELERATION ATTENUATION CURVES FOR A MAGNITUDE 6.75 EARTHQUAKE

3.3 REGIONAL CORRELATION BETWEEN MERCALLI INTENSITY AND DISTANCE

Except in California, there are few earthquakes in the United States for which there are strong motion acceleration records available. As a result, information on the attenuation characteristics of strong earthquake ground motion for regions outside of California must be derived from Mercalli Intensity data from local or regional earthquakes, or California and worldwide data must be assumed to be transferable. This is the condition that exists in the INEL region. In order to provide an independent prediction for the INEL site, and to introduce some regional geological characteristics, intensity attenuation curves were developed for five earthquakes occurring in the active seismic regions to the north, northeast, and south of the INEL site. Isoseismal curves were used for the Helena, Montana, earthquake of 1935 (Fig. 19), the Hebgen Lake, Montana, earthquake of 17 August 1959 (Fig. 20), the Richmond, Utah, earthquake of 30 August 1962 (Fig. 21), the Tushar-Sevier fault earthquake in central Utah of 4 October 1967 (Fig. 22), and the Pocatello Valley earthquake of 27 March 1975 (Fig. 23). For this determination, the distance from the epicenters to the different isoseismal lines were scaled along a reference azimuth drawn from the epicenters to the INEL site. The resulting attenuation curves are plotted in Figure 24, normalized to the epicentral intensities. The Helena curves have also been converted from Rossi-Forrel Intensities to Mercalli Intensities.

Referring to Figure 24, the Hebgen Lake earthquake has been used to essentially provide the attenuation relationship for distances greater than about 50 mi, and the smaller magnitude earthquakes have provided the basis for attenuation for distances less than 50 mi. The actual scatter in data is not great. An average curve was then used for the characteristic shape of the attenuation relationship as only one curve exists for distances greater than 100 mi. The family of curves given in Figure 25 was then generated for different epicentral intensities. Reference should be made to Table 1 in Chapter 5 for the magnitudes equivalent to the various epicentral intensities.

FIGURE 19. ISOSEISMAL MAP OF HELENA MONTANA EARTHQUAKE OF OCTOBER 18, 1935 (Ulrich, 1936)

FIGURE 20. ISOSEISMAL MAP OF HEBGEN LAKE, MONTANA, EARTHQUAKE OF AUGUST 17, 1959 (Steinbrugge et al., 1962)

FIGURE 21. ISOSEISMAL MAP FOR RICHMOND, UTAH, EARTHQUAKE OF AUGUST 30, 1962 (USCGS, 1964)

FIGURE 22. ISOSEISMAL MAP FOR TUSHAR-SEVIER FAULT EARTHQUAKE IN CENTRAL UTAH, OCTOBER 4, 1967 (USCGS, 1967)

FIGURE 23. ISOSEISMALS FOR POCATELLO VALLEY EARTHQUAKE OF 28 MARCH 1975

FIGURE 24. NORMALIZED INTENSITY ATTENUATION CURVES FOR REGIONAL EARTHQUAKES
REGIONAL EARTHQUAKES

FIGURE 25. EARTHQUAKE INTENSITY ATTENUATION CURVES FOR INEL SITE

3.4 CORRELATIONS BETWEEN MERCALLI INTENSITY AND MAXIMUM HORIZONTAL GROUND ACCELERATION

There have been numerous published correlations between Mercalli Intensity and maximum horizontal ground acceleration. An example of several are shown in Figure 26, where more than an order of magnitude variation is indicated between the Newman and Cancani correlations. This disparity in results is partly due to different techniques used by the individual investigators, but perhaps it is mostly due to the fact the Mercalli Intensity is not solely a factor of peak horizontal ground acceleration. Mercalli Intensity is basically a damage rating system, particularly in the higher intensities, and is established by the observed damage to buildings, chimneys, bridges, and other man-made facilities. Therefore, the damage and the intensity rating assigned may be influenced by such factors as poor construction, poor foundation conditions, and the frequency content of the strong earthquake ground motion, all of which have little to do with the maximum horizontal ground acceleration. However crude correlations do exist between acceleration and Mercalli Intensity, and in the absence of acceleration records, correlations of this type are used.

The two most useful correlations for this study between maximum horizontal ground acceleration and Mercalli Intensity are those provided by Gutenberg and Richter (1942, 1956) and the most recent correlation by Trifunac and Brady (1975) which included the San Fernando 1971 earthquake records. The Gutenberg Richter (1942) relationship, a linear relationship on a semilog plot, was the most widely used correlation until the recent publication by Trifunac and Brady. However, in 1956 Gutenberg and Richter noted that the 1942 relationship "*fails for the higher intensities*" and indicated that the nonlinear relationship given in Figure 27 should be used. The Trifunac and Brady relationship also shown in Figure 27, is a linear plot, but a careful review of the data upon which it is based indicates that this relationship, in our opinion, is not valid for two reasons which are discussed in the next paragraphs.

FIGURE 26. EARTHQUAKE HORIZONTAL ACCELERATION VERSUS INTENSITY CORRELATIONS (SW/AA, 1975)

FIGURE 27. CORRELATIONS BETWEEN MERCALLI INTENSITY AND MAXIMUM HORIZONTAL GROUND ACCELERATION

First, Trifunac and Brady had sample sizes at Intensities V, VI, and VII of 66, 134, and 150 records, which statistically should be adequate. However, at Intensities IV and VIII, the samples consisted of only 6 and 12 records (3 and 6 stations), respectively. A single station, Pacoima Dam, was used for Intensity X. No other data were available above Intensity VIII. Based on this very meager data, the straight line relationship given in Figure 27 was extended through Intensity X. Actually, the data for Intensities V, VI, and VII indicate a definite nonlinear relationship (on a semilog plot) similar to that proposed by Gutenberg and Richter in 1956, and these are the only intensities for which there is adequate data.

Our second objection to the Trifunac and Brady relationship results from the manner in which the data are plotted. Our study indicates that the data for Intensity VII, for example, actually represents data for stations experiencing intensities equal to or greater than VII but less than VIII. Therefore, these data should be plotted as a full intensity increment, as shown in Figure 27, and not as a single point at Intensity VII as done by Trifunac and Brady. A curve has been drawn in Figure 27 using the midpoints of the full intensity increments that comes tangent to the Gutenberg and Richter 1956 curve at about Intensity VIII to IX. The proposed mean curve shown in Figure 27 is our best estimate of how the Trifunac and Brady data should be extrapolated into higher intensities. There is not a significant difference in the two mean curves (Trifunac and Brady, 1975, and proposed mean curve) at the lower intensities.

Mean plus one standard deviation ($\text{mean} + \sigma$) values for full intensity increments based on Trifunac and Brady data are also indicated in Figure 27. Because there are only three increments, and the deviation is quite erratic for the three increments, a mean plus 50% of the mean curve was drawn, which based on judgment, is our best estimate of an upper bound maximum acceleration curve. These two curves will be used in our independent predictions. However, at this point it should be evident, that while the independent prediction method starts with local attenuation data, the final correlation

between acceleration and intensity must be based on California data, and similar to magnitude, distance, and acceleration relationships, the correlation is based on little factual data.

It is of some interest to note that stations at Bozeman, Butte, and Helena, Montana, did record the Hebgen Lake earthquake. However, these stations were from 60 to 120 mi from the causative fault, and the maximum horizontal accelerations recorded were between 0.02 and 0.07 g. The distances to these stations were determined from Figure 20, and the Mercalli Intensity for these stations determined from the intensity attenuation curves (IX-X) given in Figure 25. The measured maximum accelerations at these stations were then plotted in Figure 27 based on these attenuated intensities. It will be noted that these values fall significantly below the Gutenberg and Richter, Trifunac and Brady (mean) and the proposed mean curves. This may imply that the correlation in the Idaho, Montana region may be equal to or less than the Gutenberg and Richter 1956 correlation curve, but unfortunately there are not sufficient records to justify this assumption.

The low acceleration level indicated by the Bozeman, Butte, and Helena earthquake records more likely points out the fact that a different maximum ground acceleration should be associated with an epicentral intensity, such as VII resulting from a small magnitude earthquake, than should be associated with an Intensity VII that lies 60 to 100 mi from the epicenter of a large magnitude earthquake. The maximum acceleration is associated with the higher frequency wave components, which attenuate with distance more rapidly than the lower frequency components. Thus, higher maximum accelerations should be associated with the epicentral Intensity VII. At distances of 60 to 100 mi, from the epicenter, for example, the observed damage that would lead to an Intensity VII classification might be the result of high velocities, rather than high accelerations. This would result from the fact that the maximum velocities are associated with lower frequency components of motion than the maximum accelerations. Therefore, the maximum velocities would not attenuate as rapidly as the maximum accelerations. This phenomena

was observed for the Kern County, California, earthquake of 1952, see Housner (1959). Therefore one should expect the accelerations indicated by the proposed mean plus 50% of mean curve in Figure 27 to be associated with close-in distances to the causative fault. The proposed mean curve would then be more applicable to attenuated intensities that are 50 mi or more from the epicenter, and even lower values of acceleration should be expected at greater distances. This variation in maximum acceleration for the same intensity will be considered further in Chapter 5.

It is important to note where the major uncertainty develops in a prediction procedure that uses the relationships given in Figures 25 and 27. The scatter in the intensity attenuation curves developed in Figures 24 and 25 is actually slight. However, the correlation between maximum horizontal ground acceleration and Mercalli Intensity is very uncertain when applied to the INEL region first because of limited data, and second because none of the data are from regional earthquakes. Therefore, the prediction of the maximum Mercalli Intensity that could be experienced at the INEL site can be done with greater confidence than the prediction of the maximum horizontal ground acceleration. This factor has been considered in the probability calculations given in Chapter 5.

3.5 PREDICTION OF MAXIMUM SEISMIC HAZARD BY ALTERNATE DETERMINISTIC PROCEDURE

The WCC (1975) report predicts a maximum earthquake magnitude of $6 \frac{3}{4}$ for the Howe fault at a distance of $8 \frac{1}{2}$ mi from the LOFT reactor site using the curves in Figure 14. A maximum horizontal bedrock acceleration of 0.37 g is then selected from Figure 17 based on an earthquake magnitude of $6 \frac{3}{4}$, and a distance of $8 \frac{1}{2}$ mi. It should also be noted that the selection of the fault length was based on significant investigation of the faulting (geologic) history. The ACC (1975) study for the NWCF site assigns maximum credible earthquakes of $6 \frac{3}{4}$ and $7 \frac{3}{4}$ to the Howe fault, and $6 \frac{1}{2}$ and $7 \frac{3}{4}$ to the Arco faults. The fault distance of 15 mi for the latter controls. The procedure for estimating the earthquake magnitudes in the ACC study is

indicated to be primarily a judgment decision, although fault *displacement* as well as fault length was also discussed. The maximum horizontal bedrock acceleration predicted for the NWCF site is based on an interpolation from attenuation curves that correspond to the magnitude $6 \frac{3}{4}$ curve in Figure 18. These curves indicate 0.14 g and 0.33 g respectively for the NWCF site. For reasons that are discussed in Chapter 5, we would assign a magnitude $6 \frac{3}{4}$ to each of these faults if we were to make deterministic predictions. An epicentral intensity of IX should be associated with a magnitude $6 \frac{3}{4}$ earthquake. For fault distances of $8 \frac{1}{2}$ and 15 mi, attenuated intensities can be selected from Figure 25. Using the mean plus 50% of mean curve in Figure 26 for the attenuated intensities selected from Figure 25 yields maximum horizontal *ground* accelerations of 0.40 g and 0.31 g for the LOFT reactor and NWCF sites, respectively. We would recommend rounding off these values of 0.4 g and 0.3 g, respectively, since no prediction procedure should work to a precision of 0.01 g. Assuming moderate attenuation in acceleration with depth at the INEL site, the above predictions confirm the WCC prediction for the LOFT reactor site. While the acceleration value for the NWCF site is in reasonable agreement with the ACC study, the two values are based on different magnitude earthquakes ($6 \frac{3}{4}$ vs. $7 \frac{3}{4}$). We would recommend the magnitude $6 \frac{3}{4}$ earthquake and different acceleration attenuation curves than used in the ACC study, but we are essentially in agreement with the maximum acceleration value derived.

The discussion in this chapter has demonstrated that ground motion prediction procedures in use today are based largely on judgment because there is very little factual data available at accelerations above 0.2 g and at distances closer than about 30 mi to the causative fault. Because of these uncertainties, probabilistic procedures should be used to supplement present deterministic procedures, as deterministic procedures lead to a cumulative series of conservative assumptions that can result in unrealistic, overly conservative, and uneconomical design criteria. The degree of conservatism can only be evaluated by probabilistic analysis. This will be discussed further in Chapter 5.

CHAPTER 4

SITE TRANSMISSION CHARACTERISTICS

The discussion in Chapter 3 has indicated that one of the major uncertainties in the prediction of strong earthquake ground motion is the regional and local attenuation characteristics with distance from the source. There is some speculation that the transmission characteristics (i.e., the attenuation characteristics) of the Snake River Plains (SRP) may be different from the surrounding region. Since the principal source areas of past earthquakes are located beyond the perimeter of the SRP, this difference in characteristics, if true, should be incorporated into ground motion prediction procedures. Since microseismic, seismic attenuation, and electrical resistivity studies have been conducted recently on sites within and adjacent to the SRP, Agbabian Associates was requested to determine whether the data that have been collected can be used to demonstrate that the SRP does have unique and significantly different transmission characteristics than is found in the surrounding region. This chapter summarizes the results of this investigation.

Two general factors were advanced that might influence the transmission characteristic of the SRP prior to the initiation of the study. First, there is speculation that the SRP may be separated from the basin and range structures to the north and south by perimeter faulting. It has been postulated, for example, that perimeter faulting may have partially decoupled the Plains from the surrounding earthquake source areas. The site characteristic study for the NWCF site (ACC, 1975) states on Page 3.6-150 that decoupling of the Plains was noted near the southern end of the Pocatello Valley earthquake of 27 March 1975. A second factor indicated was the possible effect of alluvial materials that may be interspersed with the basalt flows near the northwest side of the SRP. Well borings in the vicinity of the LOFT reactor and NWCF sites indicate that there are alternate layers of alluvial materials and basalt flows. Because of the difference in vertical impedance between these

materials, the possibility of significant attenuation in strong earthquake ground motion has been hypothesized. The approach that has been followed in our investigation has been to conduct an in-house review of the data available, and two consulting seismologists were also retained to review the material and provide opinions. The results of our investigations follows.

4.1 BASIC FACTORS AFFECTING RESULTS

Before considering the studies that have been conducted at the INEL site, it is well to note five major factors which greatly restrict the usefulness of the data collected for predicting site transmission characteristics for strong earthquake ground motion. First, it has been noted in Chapter 2, that very little is known about the subsurface geology at the INEL site. The petrologic, structural, and geophysical data are so inadequate that the origin of the Plains, the nature of the basement rock, and the structure is unknown. Second, the discussion in Chapter 3 has pointed out that there is very little strong earthquake ground motion that has been recorded at distances closer than 15 mi to the causative fault. Therefore, the frequency content and the intensity of the ground motion at the source, and the characteristics of the causative fault of most past earthquakes is not known, except in very general terms. In other words the input at the epicenter for existing earthquake records is not known. Third, the earthquake ground motion is transmitted laterally to the site through bedrock and is then transmitted vertically (inclined) to the surface. The transmission characteristics from the source to the site probably varies significantly depending on azimuth and distance from the source. Therefore, the signal reaching bedrock at the site is unknown. Fourth, earthquake ground motions at the design level are about 100 times greater in intensity than the strength of the signal considered in the studies that have been conducted at the INEL. The higher strength ground motions have a different frequency content and a different attenuation relationship than microseismic motions. A correlation relationship between the transmission characteristics for high strength versus low strength signals

is not available. Fifth, the studies that have been conducted at the INEL were generally not designed to provide the answers that are needed for this study, but were designed for other purposes, such as to locate epicenters of microearthquakes. Because of the five important factors noted above, little useful information on the transmission characteristics of the site can be derived from past seismic attenuation, microseismic, and electrical resistivity tests conducted at the INEL. Reliance must therefore be placed on the isoseismal patterns of past regional earthquakes and on known theoretical relationships. Comments pertaining to the individual field studies follows.

4.2 SEISMIC ATTENUATION STUDIES

Two reports were reviewed of field experiments conducted to measure seismic attenuation at the INEL site from small off-site earthquakes and from high explosives. These are reports by Navarro (1975) and by King et al. (1977). In our opinion, it is not possible to establish that the SRP has uniquely different seismic transmission characteristics from other regions based on the results of these tests primarily for reasons that have been set forth in Section 4.1 above. In the report by Navarro (1975) the primary source considered was explosives which produced peak accelerations that were of the order of 0.0001 g which is a factor of about 1/1000 of the design level earthquake. The reported high attenuation rates in velocity probably resulted from channeling of energy because of low velocity layers common to high heat flow regions, such as the Snake River Plains. However, at very low energy levels, $1/R^2$ attenuations would not be unusual, but would be highly unlikely in regions of complex geology for velocities, or accelerations, several orders of magnitude higher. Also, using an earthquake in the Kuril Islands as a source for measuring transmission characteristics on the INEL site versus transmission characteristics off the site is not a realistic source. Practically, all of the high frequency content motion (2 to 30 Hz) are missing from this very distant earthquake, as indicated in the results. These are the frequencies of interest to nuclear power plant design.

The report by King et al. (1977) provides measurements at the micro-seismic level of small magnitude, distant earthquakes at several stations on the INEL site, as well as a few stations off the site. The strength of the signal reaching bedrock at the various stations is not known. Because of the low strength of the signals, and for the reasons cited above in Section 4.1, meaningful assessments of transmission characteristics could not be made from these data.

4.3 MICROSEISMIC DATA

Reports reviewed providing microseismic data were by Dahl et al. (1974, 1976). These reports provide a description of an instrument network maintained at the INEL for detecting and locating microearthquakes in the source areas near the INEL site, as well as on the SRP. The data collected are serving this useful purpose. With more stations, and with modern processing, data of the type collected could be used to establish reliable local velocity models, and could reveal much useful information on the geophysical characteristics of the SRP. However, for the purpose the data are being collected, Gutenberg-Richter normal depth travel time curves are being used, and no local interpretations have been made.

The INEL should seriously consider expanding the microseismic data collecting network for the purpose of developing important geophysical information. This will require modern data processing techniques. Recommendations are provided in Chapter 7.

4.4 ELECTRICAL RESISTIVITY TESTS

An electrical resistivity study by Zohdy and Stanley (1973) was reviewed with interest because it provides some information on subsurface conditions on the SRP. However, studies of this type should be supported with exploratory borings and seismic refraction studies in order to permit a more comprehensive interpretation of the results.

4.5 EARTHQUAKE DATA

Since the primary area of interest is in strong earthquake ground motion attenuation characteristics, the isoseismal patterns of significant earthquakes in the source areas were reviewed to determine if abnormal attenuation characteristics were evident in the SRP. Earthquakes of particular importance are the Hebgen Lake 1959 and the Pocatello Valley 1975 earthquakes. Isoseismal maps for these earthquakes are shown in Figures 20 and 23 of Chapter 2. An examination of these isoseismal maps did not indicate abnormal attenuation characteristics relative to the INEL site. The question of possible decoupling of the SRP due to perimeter faulting was discussed with our consulting geologists and seismologists, and there was unanimous agreement that no decoupling is evident, nor should it be anticipated for future earthquakes.

To provide some insight on the possible acceleration-distance attenuation relationships applicable to the INEL site, a graphical correlation was made between the observed Mercalli Intensity attenuation pattern for the Hebgen Lake 1959 earthquake, and the observed accelerations 60 to 120 mi from the epicenter. Figure 28 has been constructed from the data in Figure 27. In Figure 28 it has been assumed that the maximum acceleration in the epicentral zone is given by the mean plus 50% of mean curve at Intensity IX-X. A curve was then drawn in Figure 28 starting at the mean plus 50% of mean curve that passed through the proposed mean curve between Intensity VII-VIII and correlated with the Butte and Bozeman acceleration data. The distance to the various intensities (and accelerations) were then determined from the intensity attenuation curve for this earthquake from Figure 24. The corresponding acceleration distances were then plotted in Figure 29, and compared with the Woodward Clyde attenuation curves for magnitude 6.0 and 7.5 earthquakes, which were taken from Figure 17. The Hebgen Lake 1959 earthquake has an assigned magnitude of 7.1. A favorable comparison results. A similar curve was then prepared for a magnitude 7.5 curve which will be discussed in Chapter 5. It was concluded that there is no evidence at this point to indicate that the SRP has site transmission characteristics that are uniquely different from the surrounding region.

FIGURE 28. GRAPHICAL DERIVATION OF ESTIMATED HEBGEN LAKE 1959 EARTHQUAKE ACCELERATION ATTENUATION CURVE FROM MERCALLI INTENSITY AND LONG DISTANCE ACCELERATION RECORDS

R-7741-4509

FIGURE 29. COMPARISON OF ESTIMATED HEBGEN LAKE ACCELERATION ATTENUATION RELATIONSHIP WITH WOODWARD-CLYDE RELATIONSHIPS

4.6 EFFECT OF INTERBEDDED ALLUVIAL MATERIALS

Geological sections derived from well logs located in the INEL site were reviewed from USGS Bulletin 1133-E. The well logs indicate that there are numerous thin alluvial layers separating basalt flows, and one well log indicates nearly 500 ft of alluvium at a depth of 1000 ft below the ground surface. This well hole terminated in basalt. Our postulation is that the dimensions of the soil layers, laterally as well as vertically, is small compared to the lateral and vertical dimensions of the SRP. When the dimensions of the inclusion (soil layers) is small compared to the wave lengths of the seismic waves, the inclusion will have little effect on the seismic signal (Wong and Trifunac, 1977). In other words, a particle in the inclusion will experience the same motions as a particle in the surrounding basalt. Keeping in mind that very little is known concerning the subsurface conditions at the INEL, it was concluded that no abnormal site transmission characteristics could be assigned to local regions in the INEL because of the possible presence of alluvial layers interspersed between alternate basalt flows. The effect of alluvial inclusions could be demonstrated using the TRISAC model discussed in Chapter 6 and indicated in Figure 44. However, the dimensions of the alluvial deposits would have to be assumed since the actual dimensions and depths are not known. Future studies of this type are recommended, should analytical demonstration of this effect be deemed desirable by INEL.

CHAPTER 5

PROBABILISTIC ASSESSMENT OF THE SEISMIC
HAZARD OF THE INEL SITE

The seismic and geologic siting criteria defined in 10 CFR 100, Appendix A for nuclear power plants is based on completely deterministic procedures. However, as pointed out in Chapter 1, the rational determination of the level of reliability achieved in the design of the safety related systems of nuclear power plants requires that the probability of experiencing the design earthquake environments during the service life of the facility also be determined. Unfortunately, a practice has developed generally whereby the design earthquakes are selected early in the design phase using completely deterministic procedures by geological and seismological engineers who are well aware of the uncertainties associated with the prediction procedures, and, later, during the design phase, a statistical assessment of the seismic hazard is then made by engineers from other disciplines who have little knowledge of these uncertainties. It should be evident that one of the requirements for the statistical assessment arises from the uncertainties associated with the prediction procedures. The statistical assessment should therefore be a part of the prediction process. It is envisioned that eventually NRC will make the statistical assessment a part of the site investigations criteria. In our opinion this will provide more consistent evaluation of the seismic hazard.

It has been pointed out in Chapter 3, that present deterministic NRC procedures lead to cumulative conservative assumptions that can result in seismic criteria that is unrealistic, overly conservative, and uneconomical. This results because there is no rational means of evaluating the level of conservatism in the seismic criteria, other than by a statistical process. Proceeding on the basis of the deterministic procedures defined in 10 CFR 100, Appendix A places major emphasis on the geologic evidence of past earthquakes. Proponents of statistical seismic assessment procedures, on the other hand, frequently place major emphasis on the history of seismic events, and may give little consideration to the geologic evidence of larger and more critical

earthquakes that may predate the historical record. The conditions at the INEL site are a good example. Here there is geologic evidence that significant faulting has occurred in Recent time in close proximity to the INEL site. However, the historical record, which is short, shows no significant earthquakes within a distance of 80 mi of the site. Obviously, the best approach is to consider both the geologic evidence and the seismic history, and use statistical procedures to evaluate the importance of the uncertainties associated with the predicted seismic environment. This is the procedure that will be demonstrated in this chapter.

There are five basic steps to the development of a probabilistic assessment of the seismic hazard associated with a given site. These have been enumerated in AA (1976a) as follows:

- a. A review of the geology and seismic history of the region is required to establish the locations of potential sources of seismic events.
- b. Development of a relationship between the earthquake recurrence rate and earthquake magnitude (or epicentral intensity) for each source area.
- c. Prediction of the maximum earthquake magnitude (or epicentral intensity) potentially possible in the source areas identified.
- d. Development of an earthquake intensity attenuation relationship with distance from the source.
- e. Calculations to establish the probability of occurrence of different intensity levels at the specific site from the various source areas during given periods (service life) of time.

The probabilistic assessment of the seismic hazard associated with the INEL site will be developed in this chapter following the above five step procedure.

5.1 SOURCE AREAS OF SEISMIC EVENTS

The first step in the seismic hazard assessment study requires a careful review of the geologic and seismic history of the region to establish the locations of potential sources of seismic events that could affect the INEL site. The geologic aspects of this review, and a general indication of the active seismic areas surrounding the INEL site has been provided in Chapter 2 and will not be repeated here. This phase of the investigation should be as comprehensive as required by the procedures defined in 10 CFR 100, Appendix A. However, a more detailed review is required of the seismic history than has been presented previously. A review of this part of the investigation follows in this section.

At the initiation of this study, reference was first made to a study by Couch and Deacon (S&W, 1972) which was made in support of a seismic criteria study for the service area of the Bonneville Power Administration (AA, 1973). The portion of the epicentral map prepared for that study, which is pertinent to the INEL site, has been reproduced in Figure 30. Three areas of principal seismic activity are indicated in this figure, which lie to the northwest, northeast, and southeast of the INEL site. In general the centers of these three areas are approximately 100 mi from the INEL site. These three areas were boxed-in by longitude and latitude coordinates, and an up-to-date record search for the three areas designated in the figure as NOAA Search Areas A, B, and C was requested from the National Oceanic and Atmospheric Administration (NOAA), U.S. Geological Survey (USGS) at Denver, Colorado. The data from these records were summarized into increments of intensity and body wave magnitude by decade, and are listed in Tables 1, 2, and 3. A summary of all data is then provided in Table 4.

FIGURE 30. LOCATION OF EARTHQUAKE EPICENTERS CONSIDERED BY COUCH
IN 1972 STUDY (S&W, 1972)

TABLE 1. DISTRIBUTION OF EARTHQUAKES IN AREA A BY MAGNITUDE
PER DECADE FROM 1876 THROUGH 1975

Ten-Year Period	m_b	?	3.6-4.1	4.2-4.7	4.8-5.3	5.4-5.9	6.0-6.5	6.6-7.1	7.2-7.7	Total Events
	MMI	?	IV	V	VI	VII	VIII	IX	X	
1876-1885										0
1886-1895										0
1896-1905				1	1					2
1906-1915				1	1					2
1916-1925										0
1926-1935	3									3
1936-1945	3				1					4
1946-1955	1	1	2	1			1			6
1956-1965	141	35	22	4	4	2		1		209
1966-1975	129	37	26	8	1					201
Total Events	277	73	52	16	5	3	0	1		427
Total 1959-75	268	72	48	12	5	2	0	1		408

96%

R-7741-4509

TABLE 2. DISTRIBUTION OF EARTHQUAKES IN AREA B BY MAGNITUDE
PER DECADE FROM 1876 THROUGH 1975

Ten-Year Period	m_b	?	3.6-4.1	4.2-4.7	4.8-5.3	5.4-5.9	6.0-6.5	6.6-7.1	7.2-7.7	Total Events
	MMI	?	IV	V	VI	VII	VIII	IX	X	
1876-1885										0
1886-1895										0
1896-1905										0
1906-1915										0
1916-1925				3						3
1926-1935										0
1936-1945	1					2				3
1946-1955	1									1
1956-1965	76	20	9	2						107
1966-1975	16	24	3	1						44
Total Events	94	44	15	3	2	0	0	0		158
Total 1959-75	90	43	11	3	0	0	0	0		147

92%

TABLE 3. DISTRIBUTION OF EARTHQUAKES IN AREA C BY MAGNITUDE
PER DECADE FROM 1876 THROUGH 1975

Ten-Year Period	m_b	?	3.6-4.1	4.2-4.7	4.8-5.3	5.4-5.9	6.0-6.5	6.6-7.1	7.2-7.7	Total Events
	MMI	?	IV	V	VI	VII	VIII	IX	X	
1876-1885					1					1
1886-1895										0
1896-1905										0
1906-1915				2		1				3
1916-1925				3						3
1926-1935	2				1					3
1936-1945										0
1946-1955	3				1					4
1956-1965	65	11	4	1						81
1966-1975	46	20	20				1			87
Total Events	116	31	29	4	1	1	0	0		182
Total 1959-75	110	30	24	1	0	1	0	0		166

90%

TABLE 4. DISTRIBUTION OF EARTHQUAKES IN COMBINED AREAS
OF A, B, AND C BY MAGNITUDE PER DECADE FROM
1876 THROUGH 1975

Ten-Year Period	m_b	?	3.6-4.1	4.2-4.7	4.8-5.3	5.4-5.9	6.0-6.5	6.6-7.1	7.2-7.7	Total Events
	MMI	?	IV	V	VI	VII	VIII	IX	X	
1876-1885					1					1
1886-1895										0
1896-1905				1	2					3
1906-1915				3	1	1				5
1916-1925				5						5
1926-1935	5			0	1					6
1936-1945	4			0	1	2				7
1946-1955	5	1		2	2		1			11
1956-1965	282	66	37	7	4	2		1		399
1966-1975	191	81	50	9	1	1				333
Total Events	487	148	95	24	8	4	0	1		767
Total 1959-75	468	145	83	16	5	3	0	1		721

94%

Initially, earthquakes were reported by epicentral Mercalli Intensities, but in recent years, sufficient instrumentation has become available to establish body wave magnitudes, m_b .^{*} Since most of the records are recent, the data will generally be expressed in terms of m_b , but a conversion between Mercalli Intensity and m_b was required to process the records. The conversion used is indicated in the heading of Tables 1 through 4. From an engineering standpoint, this investigation is primarily concerned with earthquakes having an m_b of 5 or greater (i.e., Mercalli Intensity VI or greater). Smaller magnitude earthquakes help define the seismically active areas, but quickly clutter epicentral maps to the point that the relative importance of larger magnitude earthquakes is obscured. For this reason, the data in Tables 1 through 4 was plotted in two separate figures. Figure 31 shows the location of magnitude 4.2-4.7 (Mercalli Intensity V) earthquakes. All larger magnitude earthquakes are plotted in Figure 32. Magnitudes smaller than 4.2, which include more than half of the reported earthquakes, are not plotted.

Examination of the epicentral maps in Figures 31 and 32 clearly indicates that based on the seismic history, Search Area A is by far the most active, seismically, of the three areas, and that all epicenters of magnitudes m_b equal to or greater than 4.2 are situated 80 mi or more from the principal facilities on the INEL site. If the investigator at this point fails to consider the geological evidence, which indicates that faults within 8 to 10 mi of the INEL site have experienced movement within the last 30,000 to 4,000 years, ground motion predictions for the site will result that may be unconservatively low. Reference should be made to Figure 9 in Chapter 2 for the location of these closer geologically capable faults.

The procedure that will be followed in the development of the probabilistic assessment of the seismic hazard for the INEL site will be first

^{*}Magnitudes will be expressed in body wave magnitudes in the remainder of this chapter unless otherwise noted.

FIGURE 31. LOCATION OF EARTHQUAKE EPICENTERS WITH MAGNITUDES BETWEEN 4.2 AND 4.7 IN NOAA RECORD SEARCH AREAS A, B AND C RELATIVE TO THE INEL SITE

86

to provide an assessment based only on the hazard indicated by the historically recorded earthquakes. An additional assessment will then be made in which recurrence rates will be assigned to the areas which include Recent geologically active but *historically inactive* capable faults. Only in this manner can the relative importance of these historically inactive fault areas be evaluated.

5.2 RECURRENCE CURVES

Since the seismic hazard associated with the INEL site is distributed to three source areas, separate curves are needed for each area to define the frequency of recurrence of earthquakes of different magnitude. The development of these curves requires careful study of the records and the exercise of considerable judgment. A brief account of the problems normally encountered is provided first as background discussion.

To satisfy statistical theory, earthquakes should theoretically have an equal probability of occurrence with respect to time and with respect to areal distribution within the source area. Over many hundreds or thousands of years these theoretical considerations may be satisfied. However over a short time period, both the time and areal distribution may be nonuniform. Therefore, considerable judgment must be exercised in the selection of the source area and in the development of the recurrence curve when the historical record is short.

The recurrence curve is actually a measure of the earthquake energy released, as well as the rate of energy release, within the source area. Assuming the occurrence of earthquakes to be a random process, it follows that for a short period of record an earthquake having a recurrence interval of 500 to 1000 years may have occurred, but generally it will not have been experienced. Therefore, the large magnitude events may appear as anomalies in a short period of records, or more likely will not appear, and will have to be predicted by extrapolation of the curve. Also, in the absence of an extensive instrument network, small magnitude earthquakes will be undetected and under reported. Recurrence curves that do not consider this possibility

will then over estimate the recurrence rate of large magnitude earthquakes. It follows, therefore, that the most reliable data is that for intermediate magnitude earthquakes. That is, those earthquakes that are large enough to attract notice, but of sufficient frequency, that they will have been experienced several times during the period of records.

Couch has demonstrated the condition discussed above in Figures 33 and 34. In Figure 33, instrument coverage and an adequate period of records has provided sufficient data for a consistent recurrence curve for the Gorda Basin, but lack of instrument coverage has resulted in deficient reporting for the small magnitude earthquakes in the region indicated in Figure 34. In this case, the recurrence curve has been drawn to fit the data for earthquake magnitudes greater than 5. Fitting the curve to all the data (i.e., including the low magnitude events) would obviously significantly increase the recurrence rate predicted for the larger magnitude earthquakes.

The size of the area considered for the development of the recurrence curves is also an important factor. For example, the average seismicity of a large area may be a better estimate of the average seismicity of one of its small subareas when the period of records is short, as an abnormally active or inactive period may have occurred in the small subarea during this short interval of time. For example, for 200 years prior to the Charleston, South Carolina, earthquake of 1886, there had been little seismic activity in the Charleston area. Following this earthquake, over 300 separate seismic events were experienced in a period of 30 years. During this period, the central and northwestern part of South Carolina was relatively seismically inactive. More recently, the seismic activity has increased in these areas and the Charleston activity has diminished (Bollinger, 1972).

An additional factor that must be considered, is the completeness of the historical record. Referring to Table 4, the first historical record of an earthquake in Areas A, B, and C was in 1876. However 94% of the earthquakes listed in the table have been recorded in the last 17 years. This does not mean that this region has been more active seismically in the last two decades, but indicates the effect of increased interest in recording

FIGURE 33. CUMULATIVE EARTHQUAKE RECURRENCE CURVE FOR GORDA BASIN BY COUCH (From S&W, 1972)

FIGURE 34. CUMULATIVE EARTHQUAKE RECURRENCE CURVE FOR IDAHO, MONTANA, AND WYOMING, EAST OF 113.5°W BY COUCH (From S&W, 1972)

earthquakes since 1960, as well as the low population density in this region, at least for the first 50 years of the 100-year period. Table 4 also demonstrates that earthquakes of magnitude 4.2 and greater are large enough to be detected without instrumentation (although the record may not be complete because of low population density 60 to 100 years ago), and that magnitudes greater than 6, although detectable without instruments, occur relatively infrequently. Therefore few have been recorded. Whether the few recorded are a representative sample is also difficult to establish. Procedures have been proposed by Stepp (1972) for testing the stability of a recurrence curve, but the record in this case is so completely saturated by events recorded during the last 17 years, that the procedure does not appear to be applicable.

Statistical theory requires that each seismic event be independent of the other seismic events. It is, therefore, common practice to consider only the major shocks and discard all other preshock and aftershock events. However, the recurrence curve can also be viewed as an indicator of the total energy and of the rate of energy release in the source area, as noted above. Therefore, when aftershocks of significant magnitude occur, dropping such values can reduce the indicated energy release significantly. For example, during 1811-1812 three earthquakes having magnitudes greater than magnitude 7 occurred on the New Madrid fault system in a period of three months, see AA (1976). These earthquakes had local magnitudes that have been estimated to be 7.3, 7.5, and 7.8. Considered collectively, the three earthquakes were comparable to the energy release of a magnitude 8 earthquake. During this period, over 1800 minor aftershocks were also experienced. It would seem logical to assume that purely by coincidence three magnitude 7⁺ earthquakes occurred when for the same strain release, it could have occurred as one magnitude 8 earthquake.

It was found in the development of the recurrence curve for the New Madrid region that consistent results were obtained if this record is treated as three magnitude 7⁺ earthquakes, or as one magnitude 8 earthquake. However, treating it as one magnitude 7⁺ earthquake was not consistent with one

magnitude 8 earthquake. Therefore, in the INEL study, multiple shock events were considered when the magnitudes were comparable to the major shock. However minor aftershocks were omitted by not plotting data for earthquake intensities less than 4.2. In other words, it was considered more important to reflect the total energy release than to rigidly satisfy statistical theory.

This study is concerned with three source areas. The question that immediately arises is whether the average seismicity for the total area is a better indicator of the seismicity of each subarea than would be obtained from the record of each subarea. Since a more adequate statistical sample is available for the total area, it is always advisable to start with the total area to establish the recurrence curve slope and then proceed to the smaller subareas maintaining the slope, but trying to fit the more limited data. Fortunately, a study by Couch for the area indicated in Figure 30 east of longitude 113.5°W includes much of the INEL study area. Since the slope for the recurrence curve developed, Figure 34, has been found to be nearly constant with other western United States areas, this slope was applied first to the total data for Areas A, B, and C for the period 1959 through 1975 with the results shown in Figure 35.* Here, the magnitude intervals 5.4 to 5.9 and 6.0 to 6.5 were used to control the curve location. Since this short period of record had good reporting, data for magnitude intervals 4.2 to 4.7 and 4.8 to 5.3 are also in good agreement. Also shown in the figure, is the Hebgen Lake 1959 earthquake plotted in two positions. One assumes it to have a return period of 100 years, the other assumes a return period of 200 years. Obviously, the period of records is too short to properly utilize this data point.

Couch's recurrence curve for the region east of 113.5° west longitude plots below the recurrence curve developed from the total data for Areas A, B, and C. Since the seismicity for the area considered by Couch, and the seismicity for the total of Areas A, B, and C are comparable, it was concluded

*The slope is greatly affected by the size of the area and the length of the period of record. Slopes may vary from 0.6 to 1.1.

FIGURE 35. COMPARISON OF CUMULATIVE EARTHQUAKE RECURRENCE CURVE FOR A SUMMATION OF AREAS A, B AND C WITH COUCH RELATIONSHIP

that the major difference in the curves results from whether or not aftershock data are considered. This will be demonstrated in the discussion of the recurrence curve for Area A.

Figure 36 provides recurrence curves for Area A. The comparison was first made for the period 1959 through 1975 which had the most complete reporting. The location of the curve was again controlled by the two intermediate magnitude intervals. Including aftershocks of significant earthquakes again gives a curve higher than the curve developed by Couch for a larger area. However, using the same 17 years of record but eliminating aftershocks, drops the curve below the Couch curve which makes it a comparable curve when scaled by relative seismic source areas. Also, since earthquakes were reported in this area as early as 1896, a curve was constructed for the 80-year period with no aftershocks included. The location of this curve would seem to indicate that the earlier period does not have a complete record. However, the increased activity associated with the Hebgen Lake 1959 earthquake may also have increased the level of the 17-year curve abnormally, as the cutoff time for defining aftershocks is purely arbitrary.

The recurrence data for Area B is plotted in Figure 37. The location of the curve in this case was controlled by lower magnitude earthquakes than used for Figures 35 and 36. In this case the magnitude intervals used were 4.2 to 4.7 and 4.8 to 5.3. Since a six-month period separated two magnitude 4.8 to 5.3 events during the 17-year period, no aftershocks were considered to be in the basic data. Therefore, no reduction is indicated in the curve for no aftershocks. This contrast with the curves for Area A is another indication that aftershock activity may have continued for many years in Area A following the 1959 Hebgen Lake earthquake. Both curves are also well below the Couch curve, as they should be. Since earthquakes were recorded in this area as early as 1916, a recurrence curve using only the magnitude intervals 4.8 to 5.3 and 5.4 to 5.9, was constructed but based on an 80-year period in order to be consistent with the extended period used in Figure 36. Again the location of this curve would indicate that earthquakes during the earlier period were probably under reported.

FIGURE 36. COMPARISON OF CUMULATIVE EARTHQUAKE RECURRENCE CURVES FOR AREA A

FIGURE 37. COMPARISON OF CUMULATIVE EARTHQUAKE RECURRENCE CURVES FOR AREA B

The data for Area C has been plotted in Figure 38. For the 17-year period starting with 1959, no magnitude 5.4 to 5.9 earthquakes were reported. The curve was, therefore, controlled using magnitude intervals of 4.8 to 5.3 and 6.0 to 6.5. Relatively wide scatter in data is indicated compared to the curves developed for Areas A and B. However, these curves are based on very little data.

Examination of the records indicates that the earthquake of 28 March 1975 was assigned a magnitude of 6.0 which is the lower limit of the intensity interval 6.0 to 6.5. Also the earthquake of 2 April 1965 has an assigned magnitude of 4.5 which places it near the upper limit of the magnitude interval 4.2 to 4.7. Shifting these two earthquakes one magnitude interval would move the plotted points (as indicated by arrows) in Figure 38 to very close agreement with the curve. When there is deficient data, scatter of the type indicated in Figure 38 can easily result by the magnitude increments selected for plotting. For example using a magnitude interval of 5.5 to 6.0 rather than 5.4 to 5.9 would have moved the one data point listed in the 6.0 to 6.5 increment to the lower increment.*

No aftershocks were included in the magnitude intervals used to control the location of the 17-year curve for Area C. Therefore, the same curve applies for the no aftershock condition. A curve was also prepared for the 80-year period extending back to 1896. Again it would appear that the early records are not complete.

It should also be noted that only slight adjustment had to be made to the 17-year curves (including aftershocks) for Areas A, B, and C to provide equations for these curves that would collectively yield the same answer as the equation for the total area given in Figure 35. The equations are, therefore, consistent and are listed as follows.

*Dr. Robert Smith has also pointed out that earthquakes in this magnitude range have occurred at the bottom boundary of Subarea C. Thus, the use of a slightly larger area would have improved the stability of the data for Area C.

FIGURE 38. COMPARISON OF CUMULATIVE EARTHQUAKE RECURRENCE CURVES FOR AREA C

$$\text{LogN} = 4.46 - 0.86 m_b \text{ (Area A)} \quad (1)$$

$$\text{LogN} = 3.64 - 0.86 m_b \text{ (Area B)} \quad (2)$$

$$\text{LogN} = 3.76 - 0.86 m_b \text{ (Area C)} \quad (3)$$

$$\text{LogN} = 4.59 - 0.86 m_b \text{ (Areas A, B, and C)} \quad (4)$$

It is evident that an average curve could be used for Areas B and C, and that the curve for Area A may be slightly higher than normal and probably reflects higher than normal seismic activity that has followed the Hebgen Lake 1959 earthquake. However, this has been the most active seismic area, and it would seem prudent to assign a higher recurrence relationship to this area. Also, it should be noted that this area is 80 to 150 mi from the INEL site, and some over conservatism for this area will have little impact on the hazard assessment. For these reasons, Equations 1, 2, and 3 were selected to represent the recurrence relationships in Areas A, B, and C, respectively. The manner in which the seismicity indicated by these equations is distributed within each area is discussed in Section 5.5.

5.3 SELECTION OF MAXIMUM EARTHQUAKE MAGNITUDE

In the deterministic approach defined by 10 CFR 100 Appendix A, it is customary to assign maximum earthquakes based on postulated fault lengths. Also, in regions where surface faulting has occurred in Recent time, the design earthquake is associated with a capable fault. Discussions in Chapters 2 and 3 have pointed out the lack of geologic information in the Idaho region (which is also true for most areas of the United States), and the uncertainties associated with correlations between fault lengths and earthquake magnitudes. It has also been noted in Chapter 2, that the epicenters of past earthquakes are not clearly associated with previously existing capable faults. There is therefore reason to question a completely deterministic approach.

Probabilistic prediction procedures can make major contributions to the ground motion prediction study. Important contributions are first, the method permits one to assign maximum earthquakes, as well as lesser magnitude earthquakes, to a source area rather than to a specific fault. There is, for example, no reason to assume that one capable fault has a higher probability of movement than the remaining capable faults unless there is supporting field data, which there seldom is. Certainly there is no reason to assume that the capable fault closest to the INEL site has a 100% probability of movement while the remaining capable faults have zero probability. This essentially is the assumption of the deterministic procedure. Second, the statistical study required to define recurrence curves for the source areas provides valuable information on the recurrence interval of large magnitude earthquakes. This information permits an extrapolation of the recurrence curves to maximum magnitudes that have reasonable recurrence intervals and prevents the assignment of unreasonable magnitudes to the prediction procedure. Finally, the probabilistic approach permits a rational evaluation of the relative importance of the many variables that influence the prediction procedure, should this be desirable.

Selecting the maximum earthquake to be assigned to each source area is an important step, and should not be done solely by a fault length study, such as is done in the deterministic procedure, nor should it be done solely by cutting off the recurrence curve at some predetermined recurrence interval. The selection process should consider all geological information, as well as the seismic history. However, in the final analysis, based on current knowledge, it must be a judgment decision.

The seismic history of Area A indicates that a local magnitude 7.1 earthquake with an epicentral intensity of IX-X has been experienced within this area. Local magnitudes greater than 8 are rare and would probably never be exceeded in this area. Local magnitudes of 7.5 to 8.0 are equivalent to body wave magnitudes, m_b , of 7.2 to 7.5. These values are consistent with

those that have been assigned in previous deterministic studies. A maximum epicentral intensity of X or an m_b of 7.2 to 7.5 was therefore assigned to Source Area A. The recurrence interval for this magnitude based on the recurrence curve for Area A is abnormally high. This would indicate that aftershocks from the 1959 Hebgen Lake earthquakes have probably raised the curve above the average for this area. However, as noted above, because this area is remotely located from the INEL site, this conservative curve has been used although judgment indicates a lower curve is justified.

The recurrence curves for Area B indicate that the largest earthquake that has been experienced in this area occurred in 1944. This earthquake had an epicentral intensity of VII, and an assigned magnitude of about 6 (type of magnitude not known). Earthquakes in this area are associated with the Idaho Batholith province and not with the Basin and Range Structure province where the major range front faults are located. To be conservative a maximum epicentral intensity of IX or an m_b of 6.6-7.1 was assigned to Source Area B. This earthquake has a recurrence interval of 250 years.

Source Area C experienced an earthquake on 28 March 1975 with a magnitude, m_b , of 6. This is the largest earthquake of record in Area C. There are, however, faults in this area that are of significant length. An earthquake of magnitude 6.7 occurred on the Tushar fault zone to the south of Zone C in 1871. Our conclusion is that this area has the same magnitude potential as Area A, but a longer recurrence interval. A maximum epicentral intensity of X or an m_b of 7.2 to 7.5 was therefore assigned to Source Area C. This earthquake has a recurrence interval of 400 years.

5.4 INTENSITY ATTENUATION RELATIONSHIPS

Probability calculations can be provided based on attenuation relationships for either Mercalli Intensity or maximum horizontal ground acceleration. Both attenuation relationships have been discussed in Chapter 3. The attenuation relationships based on Mercalli Intensity have been developed from regional earthquakes, but the acceleration attenuation relationships, as well as the correlation between Mercalli Intensity and peak ground acceleration, are based on California data (also Japanese and Peruvian for the acceleration attenuation relationship). Therefore, the probability calculations for the INEL site risk assessment can be expressed with greater confidence in terms of Mercalli Intensity than in terms of peak ground acceleration. For this reason, the probability calculations in this study have been based on the Mercalli Intensity attenuation relationships given in Figure 25 of Chapter 3. The same attenuation relationship was used for all three source areas.

5.5 CALCULATION PROCEDURE

The probability calculations for this study were performed using the recently published mathematical model by Der-Kiureghian and Ang (1977). This model has the capability of considering three source conditions. The first type is the case where the source is a well defined fault, whose direction and location is known. The second type assumes the source is a faulted region for which the faults have a known dominant direction, but their exact location in the source area is unknown. The third type assumes the source area is known, but the direction and location of the faults are unknown. Since the source areas for the analysis based on only the historical seismic activity are quite distant from the INEL site, an initial comparative analysis indicated that the difference between solutions using the second and third types was insignificant. Since epicenters are not clearly associated with known faults, and all source areas have numerous capable faults, the Type 3 model was used.

A recent report by Smith (1977) indicates that the average focal depth for earthquakes in the three source areas is about 8 km or 5 mi (see C, D, E, and F in Fig. 39). A focal depth of 5 mi was used in the calculations.

For the lower bound estimate which is based solely on the source areas indicated by the historical record, the recurrence relationship for each source area was distributed equally to each 10 mi band shown in Figures 31 and 32, starting at 80 mi from the INEL site and extending radially outward to the 150 mi arc. An alternative procedure would be to weight the seismicity of each 10 mi band based on the historical record of earthquakes. However, in our opinion, this would place too much emphasis on the historical record, since the distribution of earthquakes in each source area is certain to be different in the next 50-100 years than in the past 17 years.

Since there is geologic evidence of Recent faulting in the Basin and Range Structure province but no historical record of seismic activity, a more conservative estimate of the seismic hazard was made by assuming the region indicated in Figure 40 extending from 10 to 80 mi of the INEL site to also be seismically active. For this analysis, the area indicated in Figure 40, as well as the area indicated in Figure 32 extending from 80 to 150 mi radially from the INEL site were assumed to be seismically active. The two areas were assumed to have uniform seismicity, and to be represented by the recurrence curve given in Figure 35, which is a summation of the seismicity of Areas A, B, and C. A maximum earthquake of $m_b = 6.6 - 7.1$ was assumed for the area indicated in Figure 40 and for Area B. A maximum earthquake of $m_b = 7.2 - 7.5$ was assumed for Areas A and C.

5.6 COMPUTED PROBABILITIES

The results of the probability calculations have been plotted in Figures 41 and 42. It will be noted, for example, that the maximum lower bound Mercalli Intensity predicted for the site, regardless of service life is between VII and VIII. The upper bound curves in Figure 42, however, indicate a maximum Mercalli Intensity between VIII and IX at a probability of 0.01%. For equipment that may be shut down in a safe condition for significant periods of the service life, the percent probability may be reduced in proportion to the plant use factor, since the relationship is linear.

FIGURE 39. FOCAL DEPTH OF EARTHQUAKES (Smith, 1977)

FIGURE 40. REGION WITHIN BASIN AND RANGE STRUCTURE PROVINCE ASSUMED TO BE SEISMICALLY ACTIVE

FIGURE 41. LOWER BOUND ESTIMATE OF SEISMIC HAZARD AT INEL SITE IN PERCENT

FIGURE 42. UPPER BOUND ESTIMATE OF SEISMIC HAZARD AT INEL SITE IN PERCENT

5.7 CONVERSION OF MERCALLI INTENSITIES TO PEAK GROUND ACCELERATION

In order to develop response spectra, the predicted Mercalli Intensities given in Figures 41 and 42 must be converted to an equivalent peak horizontal ground acceleration. This requires the use of considerable judgment since all acceleration correlations are based on meager information. The curves given in Figure 28 are recommended for this conversion. The mean plus the 50% of mean curve is recommended when the intensity is an epicentral intensity, or the site is very near the source. The mean curve applies to moderate distances and lower values should be used for large distances. The curve drawn for the Hebgen Lake earthquake in Figure 28 is a good example of the probable decreasing relationship between Mercalli Intensity and acceleration with distance for this region.

The intensity VII-VIII predicted for the INEL site by the lower bound calculation results from an earthquake having an epicentral intensity of X, located approximately 80 mi from the INEL site. A curve for an earthquake having an epicentral intensity of X has been drawn in Figure 28. For an intensity VII-VIII, a peak ground acceleration of about 0.1 g is indicated. This is a reasonable estimate for an epicentral distance of about 80 mi from an earthquake having an epicentral intensity of X and $m_b = 7.2-7.7$. This also agrees with the curve in Figure 15a for ground surface accelerations by Housner.

The upper bound calculation indicates that an intensity VIII-IX could result at the INEL site. Since this will be near source (i.e., within 10 mi of the epicenter), the mean plus 50% of mean curve in Figure 28 should be used to convert the intensity to peak horizontal ground acceleration. This curve indicates a value of 0.4 g.

CHAPTER 6

SEISMIC DESIGN CRITERIA

The scope of this investigation included a review of the procedures used to develop design response spectra for the LOFT reactor and NWCF facilities. This chapter provides the results of this review. It provides first a background discussion of response spectra that are in use, and a review of NRC requirements. This is followed by a comparison of the procedures used at the INEL site with NRC procedure. Since the response spectra are defined for free-field conditions (i.e., with no structure present) seismic analyses of the structure and equipment must be based on response spectra derived from the free-field criteria using soil/structure interaction models. At the INEL, the SHAKE and FLUSH computer codes have been used to provide these analyses. Since the SHAKE and FLUSH codes for some site conditions give abnormal response in a narrow range of frequencies, comparative free-field analyses were made of an INEL site using the SHAKE and a two-dimensional TRISAC model to test the stability of the two models. The results of this comparative study indicates that since the criteria spectra are defined at the bedrock level at the INEL site, the SHAKE and LUSH codes can be used for seismic analyses when the subsurface conditions are comparable to those used in the comparative study. The results of this comparative study are provided in this chapter.

6.1 BACKGROUND DISCUSSION OF SEISMIC RESPONSE SPECTRA

There are several procedures available for developing seismic response spectra. The basis for the different procedures should be understood to avoid misapplication of the procedures. Important procedures that will be briefly reviewed are those by Housner (1959), Newmark and Hall (1969), Newmark, Blume and Kapur (1973), Seed, Ugas and Lysmer (1976), and Agbabian Associates (1977a and b). Only a brief review will be presented. Reference should be made to the references cited for additional details and background.

Housner spectra are generally accepted as being *mean* spectra curves and were the first published in this country. These spectra are based on the two horizontal components of ground motion recorded for four earthquakes at the following stations: El Centro 1934, El Centro 1940, Olympia 1949, and Taft 1952. The magnitudes of these earthquakes varied from 6.3 to 7.7. The site of the El Centro recorder was considered at that time to be a firm soil site, but today it is recognized as being a deep alluvial site, having an alluvial soil depth of at least 600 ft (SW/AA, 1977). The Taft site has shallow overburden (SW/AA, 1977), while the Olympia site is also considered to be a deep soil site. The most important characteristic of the Olympia earthquake, however, is its focal depth, which was about 40 mi. This is much greater than the depths associated with California earthquakes. The epicentral (source) distances for these earthquake records varied from about 6 mi for the El Centro 1940 earthquake record, to 25 mi for the Taft record, and 36 mi for the El Centro 1934 record. Different types of faulting are associated with these earthquakes. Normal faulting was associated with the Olympia earthquake, strike-slip faulting with the El Centro earthquake, and thrust faulting with the Kern County (Taft) earthquake. Thus, site soil conditions, earthquake magnitudes, source distances, types of faulting and regional geological conditions were all uncontrolled variables in the development of the Housner mean spectra.

The exact earthquakes considered in the development of the Newmark-Hall procedures is unpublished. However, these procedures were forerunners of the Newmark-Blume-Kapur spectra presented in 1973, and currently accepted by NRC in Regulatory Guide (RG) 1.60 (USAEC, 1973). The RG 1.60 spectra are the most widely used spectra in nuclear power plant design, and are based on two separate statistical analyses, one by N.M. Newmark Consulting Engineering Services (1973), which utilized 28 horizontal components of earthquake ground motion, and one by J.A. Blume Associates, Engineers (1973), which utilized 33 horizontal components. Twelve horizontal components were common to both analyses. The RG 1.60 spectra are considered to represent mean plus one standard deviation spectra (i.e., spectra not exceeded 84% of the time)

based on a significant sample (49) of records. However, earthquake magnitude, type of faulting, source distance, regional geology, and near surface site conditions (i.e., soil depth and properties) were uncontrolled variables.

It is generally recognized that each of the uncontrolled variables noted above has some influence on the resulting ground motion experienced. However, most of the variables, including the near surface site conditions, are not known with certainty for the sites of many earthquake records. Also, there are not sufficient records available to permit a statistical assessment of the influence of all important variables. Therefore, it is held by many that it is more reliable to use spectra (such as RG 1.60) that are based on a statistical analysis of a *large sample* in which these important variables are all uncontrolled, than to use spectra based on a statistical analysis of a relatively *few records* in which only one, or at the most two, variables have been isolated, but the remainder are uncontrolled. The alternative is to carefully select several records for which the earthquake magnitude, epicentral distance, type of faulting, and geological and near surface soil conditions are all similar to those determined for the proposed site. This approach requires detailed study (see SW/AA, 1975), and for many site conditions, an adequate number of records may not be available. In our opinion, such studies are justified when adequate records can be found. Also, if unique soil conditions are present, for example, soft clays, mathematical model analysis may provide some useful information. However, it is easy to be misled by the results of a mathematical model analysis, since the model is usually oversimplified. For this reason, it is always advisable to compare the results of more than one procedure when developing response spectra.

Mean and mean plus one standard deviation ($\text{Mean} + \sigma$) response spectra are available from statistical analyses that have attempted to isolate the effect of differences in near surface site conditions. Perhaps the most widely used are those developed by Seed et al. (1974, 1976). In this investigation, records were compiled for four different near surface site conditions. These were classified as rock, stiff soil, soft-to-medium clays and sands, and deep cohesionless soil sites. In order to obtain a significant sample for

these four classes, it was necessary to augment the west coast United States earthquake records with records from Japanese earthquakes. Again, it should be noted that other important variables such as source distance, earthquake magnitude, type of faulting, and geology were not controlled in this analysis. For example, for deep cohesionless soil sites, the source distance varied from 10 to 80 mi with the source distance unknown for four (13%) of the records. Earthquake magnitudes varied from 5.6 to 7.6, the depth of focus varied from 3 to 40 mi, and normal faulting, strike-slip faulting, and reverse thrust faulting were all represented by different earthquakes for this particular site soil profile condition. In addition, there is some uncertainty associated with the soil conditions present at some recording stations. The El Centro site for example was classified as a stiff soil site. Today, it is known to be a deep soil site. The Taft site was classified as a rock site when it might more logically be classified as a stiff soil site (SW/AA, 1977).

Records for the Seed study were normalized to peak ground acceleration before statistical processing. Recent studies by Agbabian Associates (AA, 1977a and b) indicate that the manner in which the records are normalized prior to processing has an important bearing on the extent to which local near surface site effects appear to influence the response spectra. Also, in many cases the difference in results between RG 1.60 spectra and the Seed procedure is slight. For example, Figure 43 provides the results of a detailed comparative study for the Ferndale site (a deep cohesionless soil site) in which spectra were developed by using site matched records, RG 1.60, and by the Seed method (SW/AA, 1977). The difference in response above frequencies of 2 Hz is relatively insignificant. Below 2 Hz, the site matched record solution agrees closely with RG 1.60. In this case the site matched records consisted of 12 horizontal components from earthquake records having site characteristics, earthquake magnitudes, and source distances approximately the same as for the Ferndale site. The deviation of the Seed spectra in the low frequencies may have resulted from the scaling procedure used prior to statistical processing. Greater differences are experienced between RG 1.60 spectra and Seed spectra

FIGURE 43. COMPARISON OF RESPONSE SPECTRA FOR FERNDAL SITE EVALUATION (SW/AA 1977)

for soft to medium clay sites. Special studies are required for such sites, but this site condition is not a factor for the INEL site.

Figure 44 provides 5% damped mean and mean + σ horizontal and vertical response spectra that were derived by a correlation of records from 75 stations (150 horizontal; 75 vertical) in a recent study performed for ERDA (AA, 1977a). In this investigation, the stations had all been assigned a Mercalli Intensity $\geq$ VII and $<$ VIII. The correlation, therefore, is a direct correlation between Mercalli Intensity and the spectra. That is, the spectra were not distorted by a prior normalization process (such as being scaled to the peak ground acceleration). It is significant that the mean and mean + σ horizontal spectra are both in reasonable agreement with RG 1.60 spectra which were scaled by the mean and mean + σ peak horizontal ground accelerations computed for the records used. *It will be noted that both spectra converge to their respective peak ground accelerations at about 30 Hz.* The fact that the spectra are slightly below RG 1.60 spectra between about 6 and 30 Hz results from the fact that the sample consisted of records that were fundamentally not "near-source" records. We would anticipate *epicentral* Mercalli Intensity spectra to more closely approximate the RG 1.60 spectra in this frequency band.

A second important factor to note in Figure 44, is that the vertical response spectra both lie well below RG 1.60 spectra. An additional correlation (AA, 1977b) of vertical response spectra using peak ground acceleration correlation procedures has also confirmed that RG 1.60 vertical response spectra are overly conservative. We would recommend, based on these investigations, that the vertical response spectra be taken as two-thirds of the RG 1.60 horizontal response spectra throughout the entire frequency band.

Acceptable procedures for defining the vibratory ground motion are described in the Standard Review Plan (SRP) of the U.S. Nuclear Regulatory Commission (NRC, 1975). Section 2.5.2 requires that the wave transmission characteristics of the site materials be described as a function of the

(a) Horizontal motions

(b) Vertical motions

FIGURE 44. INTENSITY-DEPENDENT VII-VIII SPECTRA VS. RG 1.60 SPECTRA SCALED TO SAME PEAK GROUND ACCELERATION (From AA, 1977a)

significant frequencies, and that the type of seismic waves producing the maximum ground motion be determined. This section indicates that the SHAKE computer program (Schnabel et al., 1972) can be used for this frequency dependent analysis when the maximum ground motion results from vertically propagating shear waves. It is indicated that the shear wave model is also currently accepted by NRC for site conditions where the maximum ground motion may result from compressional and surface waves, although reference is made to the work of Trifunac and Udwadia (1974) and Drake (1972) for these conditions.

Section 3.7.1 of the SRP describes acceptable procedures for defining design response spectra and time histories to be used as input in seismic analyses of nuclear power plant structures. This section indicates that the design response spectra should be defined for the free field or rock conditions (i.e., with no structures present) and that it should ordinarily be considered applicable at the finished grade level (ground surface) of the site. If the proposed structures are to be deeply embedded then the free-field ground motion at the elevation of the base of the structures will be different than defined for the ground surface. The applicant in this case has the option of assuming the criteria ground motion to be applicable at either the foundation level of the proposed structures, or at the ground surface.

Design response spectra are considered to be acceptable by NRC if selected in accordance with Regulatory Guide (RG) 1.60 (USAEC, 1973). Regulatory Guide 1.60 provides amplification factors that can be used directly for most sites to construct design response spectra. However, there are sites for which RG 1.60 indicates that the design response spectra should be based on site dependent analyses. Also, the applicant may elect to use site dependent spectra for any site. Site dependent analysis procedures must consider in-situ material properties, a representative number of earthquake records, and the influence of inclined soil and rock strata. Discussion of site dependent analysis procedures is provided in NUREG 75/072 (SW/AA, 1975).

The requirements for soil/structure interaction analyses are set forth in 10 CFR 100, Appendix A, and in Section 3.7.2 of the SRP. The former requires that the engineering method used to ensure that the required safety functions of the nuclear power plant are maintained during and after the vibratory ground motion associated with the SSE shall involve the use of either a suitable dynamic analysis or a suitable qualification test. Furthermore, the analysis or test must take into account soil/structure interaction effects and the expected duration of the vibratory motion. At the present time, verification of response of large structures is provided only by analysis.

Acceptable soil/structure interaction analysis procedures are set forth in Section 3.7.2 of the SRP. Either discrete mass-spring or finite element methods may be used for most site and embedment conditions, but only the latter is currently accepted for deeply embedded structures in soils. Acceptable procedures for developing input time histories for soil/structure interaction analyses are defined in Section 3.7.1 of the SRP. This section discusses time histories to be input *only* at the *base* of the soil/structure system and identifies deconvolution analyses using the SHAKE and LUSH computer codes as an acceptable method. Even though this section indicates that other equivalent computer codes and analysis techniques are acceptable, the combined application of the SHAKE/LUSH computer codes for computing the base input and the soil/structure response have become an almost standard procedure, even for deeply embedded structures in rock. This, in our opinion, is an unfortunate circumstance that has unintentionally resulted from the emphasis given in the SRP to only these two codes. Our experience with the SHAKE and FLUSH codes indicates that for many site conditions these codes give significantly distorted response in a relatively narrow frequency band that corresponds to the fundamental lateral shear mode frequency of the site. Recently, this problem was reviewed by the Advisory Committee on Reactor Safeguards, and the acceptance of analyses by these codes is now subject to a case by case review. For this reason, we have provided comparative analyses with SHAKE and TRISAC codes. These results are discussed in Section 6.3.

6.2 COMPARISON OF INEL AND NRC SPECTRA

Our review of Technical Report No. TR-536, AM-46 by Gorman and Guenzler (1974) indicates that for the LOFT reactor facility, Housner spectra have been scaled by spectrum intensities to provide smoothed Housner mean spectra at the bedrock level equivalent to a peak horizontal ground acceleration of 0.34 g. Careful examination of the spectra in Figure 44 indicates that the mean and (mean + σ) spectra derived from the Mercalli Intensity correlation study have approximately the same shape and could be scaled by peak acceleration, similar to the procedure used to develop RG 1.60 spectra. The peak bedrock acceleration of 0.34 g developed for the LOFT reactor site by deterministic procedures is actually higher than an 84 percentile value. Therefore, if it is assumed that the shape of the spectrum that corresponds to the higher than 84 percentile peak ground acceleration is approximately the same as the (mean + σ) spectrum, then the RG 1.60 (or the Mercalli Intensity VII to VIII) spectrum can be scaled to 0.34 g to provide an appropriate spectrum. This assumption is normally made when using RG 1.60 spectra.

The peak horizontal ground acceleration associated with the Mercalli Intensity VII to VIII (mean + σ) spectrum given in Figure 44 is 0.19 g. If this curve is scaled by the ratio of 0.34/0.19, or if the RG 1.60 spectrum is scaled to 0.34 g, a response acceleration at 5 Hz of about 0.9 g results. The LOFT criteria, in contrast, indicates a value of about 0.5 g or roughly 60% of the RG 1.60 response. This has resulted because Housner mean spectra have been used. Currently, NRC does not accept mean spectra for criteria spectra.

The vertical response for the LOFT reactor facilities has been taken as two-thirds of the horizontal response. Currently NRC requires the vertical response to be equal to the horizontal response for frequencies above 3.5 Hz. Therefore, the criteria for the LOFT reactor facilities would be only about

40% of the RG 1.60 criteria requirements above 3.5 Hz. However, recent studies (AA, 1977a and b) indicate that two-thirds of the present RG 1.60 requirement would be adequate.

A review of ACC (1975) indicates that essentially the same procedure has been used to develop response spectra for the NWCF site as used for the LOFT reactor site discussed above. In this case, a spectrum that has the shape characteristics of a Newmark-Hall spectra have been used but amplification that is intermediate between Housner and Newmark and Hall was used to scale the spectra. For a 0.34 g peak ground acceleration, a maximum horizontal response acceleration of 0.68 g is indicated in the 5 to 10 Hz frequency range which is about 75% of the response given by a properly scaled RG 1.60 spectrum. Also, the vertical response has been taken as two-thirds of the horizontal response which would be about 50% of the RG 1.60 requirement for frequencies above 3.5 Hz.

One additional factor must be considered. The response spectra used as criteria for the LOFT reactor and NWCF sites are assumed to be applicable at the bedrock level, or about 45-ft below the ground surface. Nearly all earthquake records are for the ground surface, and our predictions have been assumed to be applicable at the ground surface. However, a value of 0.4 g was recommended in our alternate predictions for the LOFT reactor site in Section 3.5 of Chapter 3, in contrast to the 0.34 g bedrock value used in the above comparison. The question of how much attenuation in response occurs with depth can only be resolved by careful analysis. Presently, NRC limits the attenuation at any frequency to 30% (i.e., a value of 70% of the ground surface value), regardless of the depth to rock. This limitation has been imposed by the excessive attenuation that sometimes results with SHAKE code analyses. The attenuation indicated by SHAKE code analyses for shallow soil sites, such as the INEL site, is currently subject to careful scrutiny by NRC, and it is doubtful that more than a 25% reduction (i.e., a peak rock acceleration of 0.3 g) would be accepted for the INEL site. This will be discussed further in the next section.

It is recommended that RG 1.60 response spectra prediction procedures be used to develop criteria response spectra for the INEL site when the design earthquake epicenters are within 10 to 20 mi of the site. For epicentral distances greater than 15 to 20 mi, Mercalli Intensity spectra, such as indicated in Figure 44, or RG 1.60 spectra, can be safely justified. The Mercalli Intensity spectra can also be used to justify a significant reduction in vertical response spectra. If RG 1.60 spectra are used, we recommend that the vertical response be taken as two-thirds of the horizontal response throughout the full range of frequencies.

6.3 COMPARATIVE SHAKE AND TRISAC FREE-FIELD ANALYSES

Our review indicates that the SHAKE and FLUSH computer codes are currently being used to provide free-field and soil/structure interaction analyses of vital facilities at the INEL site. In February 1977, the Seismic Subcommittee of the Advisory Committee on Reactor Safeguards (ACRS) conducted a two-day review of NRC problems that have been associated with the use of these two computer codes. On rock sites with shallow overburden these codes frequently indicate excessive ground motion attenuation with depth in a narrow band of frequencies near the fundamental shear mode frequency of the overlying soil layers. When the criteria spectra are defined at the ground surface, and the bedrock spectra are computed by deconvolution, using either the SHAKE or FLUSH code, an unconservative spectra is obtained at the bedrock level in the affected frequency band. As a result of the ACRS Seismic Subcommittee review, NRC and the geotechnical profession are carefully evaluating the use of these programs for this particular site condition, which is typical of the INEL site.

Because of questions that might arise in the future relative to seismic analyses of INEL facilities based on SHAKE and FLUSH codes, our review has included comparative analyses of a typical INEL site profile using

the one-dimensional (1-D) SHAKE code and the two-dimensional (2-D) TRISAC code. The objective was to determine whether the simpler SHAKE and FLUSH codes can be used to provide reliable analyses for INEL site conditions. During the past three years, Agbabian Associates has made comparative analyses of several site conditions using the SHAKE and TRISAC codes. In some cases, it has been evident that better and more reliable results can be obtained with the 2-D code, but in other cases comparable results have been obtained with both the 1-D and 2-D codes. It would appear that comparable answers can be obtained from the two codes when the physical properties and the geometry of the subsurface profile are such that wave transmission through the soils in the 2-D model is the same as assumed in the 1-D SHAKE code (i.e., essentially a vertically propagating shear wave). However, in no case has it been possible to justify the use of the deconvolution procedure with the SHAKE and FLUSH codes. Our recommendations, therefore, are that the criteria spectra should be defined at the bedrock level when using the SHAKE and FLUSH codes, or if defined at the ground surface, a more sophisticated 2-D or 3-D code should be used to compute the bedrock input for the SHAKE and FLUSH code analyses. A description of the two analyses, and a comparison of the results follows.

6.3.1 DESCRIPTION OF SHAKE MODEL

The SHAKE code assumes that the seismic wave is transmitted vertically upward from an assumed firm base as a one-dimensional shear wave when computing horizontal response. The major advantage of this code is that it iterates to a solution in which the computed effective strain level and the shear modulus are compatible. Material properties are assumed at the start of the analysis, but the code has stored material properties for clays, and cohesionless sands and gravel, that are a function of the effective strain levels reached in the various elements in the model. At the conclusion of the first iteration, the code automatically checks the effective strain levels reached in the first solution and compares them with the assumed values at

the start of the analysis. If there is disagreement, new values for the shear modulus and damping are selected for all elements, and the solution is repeated. The process is then repeated until effective strain level agreement is obtained.

The disadvantages to the code are first it assumes the direction of propagation of the seismic wave and the type of wave. As noted above, a simple vertically propagating shear wave is assumed. With this assumption, the highest strains occur at the base which means that the model will select the highest damping and the lowest modulus (relatively speaking) at this level. This results in high energy loss at the base, but large strains. Therefore, the intensity of the motion decays rapidly until it reaches the surface where a high reflection occurs because of normal incidence. If the wave is not really a vertically propagating shear wave, but, for example, an inclined dilatational wave, the strain levels and the reflected condition at the surface may be grossly in error.

A second disadvantage to the SHAKE model is that horizontal and vertical motions must be decoupled and treated separately. Actually, the program will iterate to different material properties for the vertical motion than used in the solution for horizontal motion unless the analyst locks out the iterative routine. Thus, the type and orientation of the seismic wave and the material properties may be incorrect. Also, surface waves cannot develop with this model.

When it can be demonstrated that the site geometry and material properties are such that a nearly vertically propagating shear wave does develop, the SHAKE and FLUSH codes offer important advantages for soil sites, because of their capability to adjust the modulus and damping to the effective strain level, and their use is recommended. However, it is important to be able to demonstrate their validity by comparative calculations with more sophisticated codes. For additional information on the SHAKE and FLUSH

codes, reference should be made to Schnabel et al. (1972) and to Lysmer (1975).

For the SHAKE code analysis, the soil properties reported in the Dames and Moore (1977) foundation investigation report for the Fluorinel and Fuel Storage facilities at the Chemical Processing Plant were used. This report indicates that the soil overlying the basalt has a depth of about 45 ft. The top 40 ft consists generally of a sandy gravel and the lower 5 ft is a residual sandy clay, clayey sand, or silty clay. Table 5 provides the properties assumed for the different materials as input to the analysis, and the final properties used in the final iteration.

TABLE 5. MATERIAL PROPERTIES USED
IN SHAKE CODE ANALYSIS

		Shear Modulus (lbs/in ²)		Damping, Percent	
Depth	Material	Initial	Final	Initial	Final
0-5	Sand	25,000	20,000	6	4
5-10	Sand	26,200	13,850	6	8
10-15	Sand	27,000	11,100	6	11
15-25	Sand	28,000	9,600	6	14
25-35	Sand	29,000	6,500	6	17
35-45	Sand	40,000	10,700	6	16
45-70	Basalt	405,000	377,500	1	1
70-95	Basalt	405,000	370,000	1	1
95-120	Basalt	405,000	366,000	1	1
120-145	Basalt	405,000	365,000	1	1

The primary analyses with the SHAKE code were made with a model depth of 145 ft (i.e., 45 ft of soil and 100 ft of basalt). However, one case was also run with a model depth of only 45 ft to demonstrate the effect of depth of firm base on the results. Ordinarily, the SHAKE code analysis is made to obtain input for a soil/structure interaction analysis using the FLUSH code. Generally, a depth of soil or rock is taken below the base of the structure equal at least to the width of the base of the structure. This is needed to introduce the effect of soil or rock deformations below the base into the response calculation. For very large structures, a model depth of 800 to 1000 ft may be required. At INEL the structures are founded on the basalt. Therefore, a 145-ft depth model implies that structures having base widths up to 100 ft are to be analyzed.

The N69W component of the Castaic February 9, 1971 earthquake record, scaled to a peak acceleration of 0.54 g, was used as input to the SHAKE analyses. The response spectrum for the scaled input record is compared in Figure 45 with a RG 1.60 spectrum for 0.34 g peak acceleration. It will be noted that the spectra compare well between frequencies of 3 and 15 Hz, and the response is equal to or greater than the RG 1.60 spectrum for frequencies between 0.8 and 33 Hz. The advantage of using the Castaic record is that RG 1.60 response can be approximated through the frequencies most significant to nuclear power plant design with only 3 sec of input. A similar comparison is provided in Figure 46 for the vertical component of the Castaic record. The vertical component was not used in the SHAKE code analyses but was used in the TRISAC analyses and will be referred to in Section 6.3.2.

Our review indicates that the criteria spectra are defined at the bedrock level at the INEL sites. Figure 47 provides the results of the SHAKE code analysis using the material properties given in Table 5 and a 145-ft vertical soil and rock model when the N69W Castaic record, scaled to a peak acceleration of 0.54 g, is used as input at the base of the model. It will be noted that the response at the 45-ft depth has attenuated slightly below the RG 1.60 spectrum in the 3 to 7 Hz range, but overall, reasonable response is obtained with the SHAKE analysis.

FIGURE 45. COMPARISON OF HORIZONTAL INPUT SPECTRUM WITH REGULATORY GUIDE 1.60 SPECTRUM

FIGURE 46. COMPARISON OF VERTICAL INPUT SPECTRUM WITH REGULATORY GUIDE 1.60 SPECTRUM

FIGURE 47. COMPARISON OF RESPONSE SPECTRA COMPUTED BY *SHAKE* CODE USING BASE INPUT WITH 145 FT MODEL

Figure 48 has been provided to show the distortion that results in the response spectra at the 45-ft depth when the criteria spectra are defined at the ground surface and the response at the 45-ft depth is computed using the deconvolution routine. A 45-ft SHAKE model was also used to demonstrate the effect of variation in depth of firm base on the results. It will be noted that the greatest distortion occurs at about 4 Hz which is the fundamental shear mode frequency of the soil layer. If a very large structure is to be analyzed, a model depth of 800 to 1000 ft would be required and the structures might be founded more deeply. For such cases a severe spectral distortion will result. We would recommend that the deconvolution routine not be used for SHAKE and FLUSH code analyses of INEL site conditions.

6.3.2 TRISAC MODEL ANALYSIS

A two-dimensional TRISAC model analysis was used to verify the reliability of the response of the SHAKE analysis. Figure 49 shows the mesh used for the analysis. With this model, the horizontal and vertical components of the earthquake record are input simultaneously at the left boundary. An energy absorbing boundary is provided at the right vertical boundary, and the bottom boundary may be either an energy absorbing or a free boundary. Since we are interested only in the response in the top 100 ft or so of the model, a free base boundary was used.

The advantages of the TRISAC model are first, 2-D waves can be propagated and the type and orientation of the waves will adjust to fit the geometry and physical characteristic of the model. Second, the horizontal and vertical components of motion are coupled. The disadvantages of the TRISAC model are first, it does not iterate to a solution in which the moduli and damping are consistent with the effective strain level. By doing a SHAKE analysis first, some indication of the properties can be obtained. However, the direction of wave propagation (and the types of waves present) may be different than assumed in the SHAKE analysis, so good agreement is not obtained by merely making the properties the same as used in a prior SHAKE code analysis. Therefore, a second analysis may be required to obtain compatible physical properties.

FIGURE 48. COMPARISON OF SURFACE AND BEDROCK RESPONSE SPECTRA COMPUTED BY *SHAKE* DECONVOLUTION PROCEDURE USING 145 FT AND 45 FT MODELS

FIGURE 49. TRISAC FREE-FIELD FINITE ELEMENT MODEL

Second, the TRISAC code uses modal damping. Therefore, it is not possible to vary the damping element by element as is done with the SHAKE code. The third disadvantage is the computer time required for the TRISAC analysis. Approximately 2 hr of UNIVAC 1108 computer time was required for the 3 sec Castaic record using the model given in Figure 44. The reader should consult AA (1976b) for additional information on the TRISAC code.

Judgment has to be exercised in selecting the range in modal damping and in the selection of material properties for the model. Referring to Table 5, material damping for the soil averages about 12%,* but much of the TRISAC model consists of basalt which exhibited only 1% damping in the SHAKE code analysis. Based on judgment, the modal damping for the TRISAC analysis (which is frequency dependent) was selected to vary from about 3 1/2 to 8%, see Figure 50. A uniform shear modulus of 15,100 psi was assumed for the 45-ft depth of soil, and a value of 372,000 psi was selected for the basalt. Young's moduli values were 43,400 psi for the soil and 966,000 psi for the basalt (Poisson ratios of 0.42 and 0.30, respectively).

It has been previously noted that the horizontal and vertical components of the Castaic 1971 record (see Figs. 45 and 46) were used as input at the left boundary. Since the variation with depth is not known, the input was assumed to be constant with depth. Because of the two-dimensional characteristics of the model, input that is not consistent with the model, will be adjusted by the model to conform to its geometry and physical properties within a few hundred feet. Thereafter, it will remain nearly uniform except for slight energy losses due to the assumed damping. However, this requires that the response be monitored at various intervals across the model to determine where it becomes stable. For this example, the response was monitored at 280, 630 and 840 ft from the left vertical

*It should be noted that a direct numerical comparison cannot be made between the SHAKE code element damping and the TRISAC modal damping.

FIGURE 50. FREQUENCY DEPENDENT DAMPING USED IN *TRISAC* ANALYSIS

boundary (i.e., Node Points 180, 380, and 400). If the motion does not become stable for the last two monitor stations, the response monitored at the last station (varying with depth) is then used as a new input at the left boundary, and the analysis is repeated until a stable condition develops. Usually a stable condition develops in the first 300 to 500 ft, and it is not necessary to repeat the analysis.

Figure 51 provides the horizontal response from the TRISAC model at the ground surface at Nodes 180, 380, and 500 (280, 630, and 840 ft from the input boundary). It will be noted that at Nodes 380 and 500, almost the same response occurs which indicates a stable condition has been reached at these two stations. However, the response at Node 180 does not reflect the vertically propagating shear wave that apparently develops in the soil layer by the time Node 380 has been reached.

Figure 52 provides comparative response spectra at a depth of 75 ft for the same three distances from the left boundary. Here it will be noted that all spectra are substantially in agreement; indicating that there was a lack of stability at the first station (i.e., at Node 180), only in the soil layer.

Figure 53 provides a comparison of the variation in response with depth at a distance of 840 ft from the left vertical boundary. Also shown is a comparison with a RG 1.60 spectrum for 0.34 g. The response compares favorably with the RG 1.60 spectrum except it is slightly low between 7 and 20 Hz. This could be adjusted by scaling the input to a slightly higher level, or by adding additional input in this frequency range. However, the surface spectrum indicates that there is a significant shear wave propagating nearly vertically upward through the soil at a frequency of 4 Hz. The effect is even more severe than indicated in the SHAKE analysis. However, without additional analysis, the SHAKE results are believed to be more nearly correct for the surface, as the damping used in the TRISAC model may be lower than occurs in the soil.

FIGURE 51. COMPARISON OF SURFACE HORIZONTAL SPECTRA, FROM *TRISAC* ANALYSIS

FIGURE 52. COMPARISON OF HORIZONTAL SPECTRA AT 75-FT DEPTH FROM
TRISAC ANALYSIS

FIGURE 53. COMPARISON OF HORIZONTAL SPECTRA VARIATIONS WITH DEPTH FROM *TRISAC* ANALYSIS

Figure 54 provides a comparison of vertical response spectra at the 45-ft depth from the TRISAC model analysis at Node Points 177, 377, and 497. Again it will be noted nearly stable response has developed at Node 377 and has probably developed at Node 497. Note that the model has reduced the peak that was in the input at 4 Hz and introduced a peak at about 2.5 Hz. Figure 55 provides a comparison of vertical response spectra variations with depth at 840 ft from the left vertical boundary. In our opinion, a stable condition has been reached at this station.

6.3.3 COMPARISON OF SHAKE AND TRISAC ANALYSIS RESULTS

Figures 56 and 57 provide comparisons between the SHAKE and TRISAC analyses at a depth of 45 ft and at the ground surface, respectively. Figure 56 indicates that both models give good results at a depth of 45 ft when the deconvolution routine is not used in the SHAKE code analysis and the input is made at the bedrock level. There is a general tendency for the SHAKE code to give low response in the frequency range above about 8 Hz and this can be noted in Figure 56. Since this is a rock spectrum, the loss cannot be attributed to the damping characteristics of soil. In Figure 57, the reduced response in the higher frequencies is quite conspicuous. This may be partly due to the damping characteristics of the soil, but some reduced response no doubt results from the over simplified wave form being transmitted in the SHAKE code. The user of the SHAKE and FLUSH codes should be aware of this characteristic, as it may be necessary to artificially increase the computed response in this frequency range for some sites.

The very high peaked response indicated in Figure 57 by both models at 2.5 to 4 Hz is obviously a site characteristic, and is probably exaggerated in both models since both are elastic models. This can only be determined by providing a nonlinear analysis which was beyond the scope of this investigation. However it is our opinion that 25 to 30% attenuation at this site between the ground surface and the bedrock level can be justified from the elastic analysis results. Obviously, the true attenuating characteristics of the

FIGURE 54. COMPARISON OF BEDROCK (45 FT. DEPTH) VERTICAL SPECTRA FROM *TRISAC* ANALYSIS

FIGURE 55. COMPARISON OF VERTICAL RESPONSE SPECTRA VARIATIONS WITH DEPTH FROM *TRISAC* ANALYSIS

FIGURE 56. COMPARISON OF *SHAKE* AND *TRISAC* BEDROCK SPECTRA

FIGURE 57. COMPARISON OF *SHAKE* AND *TRISAC* SURFACE SPECTRA

site can be better verified experimentally. Strong motion recorders at the bedrock level and at the ground surface would provide useful information if strong earthquake ground motions are experienced at the site, or if a well planned field test is conducted with high explosives.

CHAPTER 7

RECOMMENDED STUDIES

The geological and seismological investigations that have been conducted to date in support of the INEL facilities have followed the general requirements of 10 CFR 100, Appendix A. However, the investigations that have been conducted have not been as complete and as far reaching as are frequently provided. For this reason, relatively conservative assumptions on capable fault lengths have been made. Studies have been made to better define fault lengths, but little effort has been expended on trying to understand basic factors that might lead to a better interpretation of the tectonic processes in this region. Chapter 2 has pointed out that much information is lacking on the tectonic origin of the Snake River Plains (SRP) and that there is not a verified explanation of the present aseismic behavior of the SRP and the regions immediately to the northeast and southwest of the eastern part of the SRP. This has probably resulted from preoccupation with fault lengths that result when trying to satisfy only deterministic criteria. Since most historical epicenters have not been clearly associated with existing faults, even in the source areas, and the relationship between fault length and magnitude is crude, emphasis on studies should be on the determination of basic area and regional relationships rather than for specific fault length determinations.

In the absence of answers to basic questions concerning the geologic structure and the tectonic processes, the deterministic procedure may well lead to more conservative assumptions as field investigations continue on and adjacent to the INEL site. For example, the Witkind (1975) open file report of faulting in Idaho, as well as the Greensfelder (1976) report, show northwest trending fissures, or faults, within the SRP that are in general alignment with the Howe fault. The recent works of Kuntz (1977) also indicate that these structures extend beneath the Plains. Normal NRC review procedures would require the applicant to demonstrate that capable faults do not exist

in this region. Also volcanic activity on the SRP has probably been more recent than, or may be associated with, movement on the Howe and Arco faults. Therefore, it may be ruled that it is not logical to subordinate the concern for the volcanic hazard to the hazard associated with local capable faults when no seismic activity has been associated with either in historical time.

The probabilistic study provided in Chapter 5 gives more concern to area and regional problems and less concern to a specific fault. In this sense, we prefer and recommend this approach. The studies that we recommend, therefore, are more consistent with the probabilistic approach. However, it is well to recognize that NRC at this time considers only a deterministic approach. Studies recommended are based on recommendations from our consultants and are as follows:

- a. Map the Crustal Structure of the SRP. Detailed reflection or long-line (>200 km) refraction studies should be made along the NE-SW axis of the Plains and two profiles should be run transverse to this axis. This study is needed to obtain knowledge on the velocity layering, attenuation, density layering, and physical properties of the crust, and to understand the tectonic origin of the SRP.
- b. Establish Semi-Permanent Seismograph Array. A 6 to 8 station telemetered seismograph array should be established around the northwest margin of the SRP. These stations should be mobile to move into active areas where necessary. Data should be RF or telephone telemetered to a central recording site for modern recording and analysis. Also, the existing INEL network should be updated and expanded to provide coverage of earthquakes up to 100 mi from INEL. The data should be recorded and analyzed with modern techniques. The data should then be interpreted by scientists trained to integrate the data with other geophysical and geological data. This information is needed to provide a better interpretation of both small and large magnitude earthquakes that may occur in the future within a 100-mi radius of the INEL site.

- c. Modern Analyses of Seismic Data Taken by Combined Arrays. The data collected since 1972 from INEL, Tetonia-Bureau of Reclamation, U.S. Air Force, Ricks College, and the University of Utah should all be correlated and interpreted together. Much of the data have been analyzed by inaccurate graphical methods using limited velocity models, some have had only cursory examination and a total correlation has not been provided. This information could be used to develop a first estimate of velocity models and provide a better interpretation of the local transmission characteristics.
- d. Trenching and Modern Age Dating of Faults. Additional trenching of faults in the Howe and Arco areas be provided and accompanied with modern age dating of correlatable strata in order to establish recurrence intervals of faulting. However, this should be done with the objective of learning more about the history of faulting in this region than as an objective of providing a recurrence curve for the faults that could be used in ground motion prediction studies, as many faults would have to be treated to provide a meaningful data base for the latter, and the cost would be prohibitive. Other faults northwest and southeast of the SRP in areas having no historical seismic activity should also be investigated to determine if a broad area of capable faults with no historical seismic activity exists.
- e. Analyses of Quaternary Sedimentary Deposition and Landform Development across the Howe and Arco Faults. Field studies of this type are needed to support the trenching studies described above. Particular attention should be paid to the geomorphic relationships at the mapped ends of the Arco and Howe faults where the structures die out within or are buried beneath deposits of the Snake River Plains. Cooperative investigations with the USGS mapping projects of the SRP should be developed.

- f. Field Study of Rangefront Faults North of SRP. Maps by Witkind indicate that rangefront faults are offset by shorter north-south faults. The validity of this relationship and its possible cause and significance to the faulting history of this area should be evaluated.
- g. Low Sun-Angle Photography of the INEL Site. Study should be provided of the northwest-trending fractures or faults within the SRP that are in general alignment with the Howe fault. These features and their projected traces across the INEL should be studied both on the ground and with low sun-angle photography.
- h. Geodetic Leveling, Triangulation, and Trilateration. Repeated measurements along leveling profiles and repeated measurements over triangulation grids in the general region of the INEL and the eastern SRP should be provided to detect temporal changes in elevation and distance. This information is needed to determine if the region is undergoing transverse or longitudinal tension, or whether it is in a mode of thermal contraction, or whether it is behaving nonelastically.
- i. Deep Drilling. Deep drilling along the projected axis of the Lemhi or Lost River ranges would provide much useful information on whether these ranges, or faults project beneath the SRP. However, such projects are very expensive and would be best performed in conjunction with deep well-drilling projects.
- j. Attenuating Characteristics of INEL Site Profile. Analyses using SHAKE and TRISAC codes indicate that the shallow soil layer at the INEL site has significant attenuating characteristics with depth. Strong motion recorders placed at the bedrock level and at the ground surface are needed to verify the

analytical predictions since the attenuating characteristics of shallow soil profiles are presently under close scrutiny by NRC and the geotechnical profession. Field tests with explosives could also provide timely information as many years may elapse before strong earthquake ground motion would be recorded.

- k. Attenuating Characteristics of Interbedded Basalt and Alluvium Layers. The TRISAC model used to make two-dimensional ground motion calculations in this study could be used to determine whether alternating beds of alluvium and basalt, that supposedly exist below the INEL site, provide abnormal attenuation of ground motion. However, the depth, thickness, and lateral extent of such layers should be determined. Future drilling programs at the site should be planned with the need for this information in mind.

REFERENCES

- Agbabian Assoc. (AA). (1973) *Procedures and Criteria for Increasing the Earthquake Resistance Level of Electrical Substations and Special Installations*, R-7211-13-2859. El Segundo, CA: AA, Sep.
- . (1976a) *Problem Areas in the Application of Seismic Risk Analysis Procedures*, SAN/1011-101. El Segundo, CA: AA, Jun.
- . (1976b) *User's Guide for TRI/SAC Code*, 2nd rev. ed. R-7128-4-4103. El Segundo, CA: AA, May.
- . (1977a) *Correlation of Ground Response Spectra with Modified Mercalli Site Intensity*, SAN/1011-113. El Segundo, CA: AA, Jun.
- . (1977b) *A Study of Vertical Ground Response Spectrum Shapes*, SAN/1011-114. El Segundo, CA: AA, Aug.
- Allied Chemical Corp. (ACC). (1975) *Chapter 3.0, Site Characteristics, New Waste Calcining Facility, Preliminary Safety Analysis Report*. Idaho Falls, ID: ACC, Oct.
- Armstrong, R.L.; Leeman, W.P.; and Malde, H.E. (1975) "K-Ar Dating Quaternary and Neogene Volcanic Rocks of the Snake River Plain, Idaho," *Am. Jnl. Science*, Vol. 275, pp 225-251.
- Bollinger, G.A. (1972) "Historical and Recent Seismic Activity in South Carolina," *Bull. Seismol. Soc. Amer.* 62:3, Jun, pp 851-864.
- Bonilla, M.G. (1967) *Historic Surface Faulting in Continental United States and Adjacent Parts of Mexico*. Reston, VA: U.S. Geol. Survey. (TID 4500)
- , and Buchanan, J.M. (1970) *Interim Report on Worldwide Historic Faulting*, Open File Report. Reston, VA: U.S. Geol. Survey.
- Chase, G.H. (1973) "Potassium-Argon Ages From Whole-rock Analyses of Igneous Rocks in the Area of the National Reactor Testing Station, Idaho," Prof. Paper 800-D, in *Geological Survey Research, 1972*. Reston, VA: U.S. Geol. Survey, pp D123-126.
- Cloud, W.K. and Perez, V. (1971) "Unusual Accelerograms Recorded at Lima, Peru," *Bull. Seismol. Soc. Amer.* 61:3, Jun, pp 633-640.
- Couch, R.D. and Deacon, R.J. (1972) *Seismic Regionalization Studies, Bonneville Power Administration Service Area*, 0-652. Portland, OR: Shannon & Wilson, Oct.

- Dahl, A.H. and Johnson, B.D. (1974) *Preliminary Results of a Microseismic Study for the Region around the Snake River Plains, 1973-March 1974*, Idaho Academy of Science. Rexburg, ID: Ricks College, Apr.
- , and Price, E.J. (1977) *Preliminary Results of a Microseismic Study for the Region Around the Snake River Plains, January 1974-December 1976*, Idaho Academy of Science. Pocatello, ID: Idaho State Univ., Apr.
- Dames and Moore (DM). (1977) *Report of Foundation Investigation, Fluorinel and Fuel Storage Facilities, Chemical Processing Plant, Idaho National Engineering Laboratory*. Salt Lake City, UT: DM, May.
- Davis, G.A. (1977) Private Communication to Agbabian Associates, Sep.
- Der-Kiureghian, A. and Ang, A.H.-S. (1977) "A Fault Rupture Model for Seismic Risk Analysis," *Bull. Seismol. Soc. of Amer.* 67:4, Aug.
- Donovan, N.C. (1973) "Earthquake Hazards for Buildings," in *Building Practices for Disaster Mitigation*, NBS Science Series 46. Washington, DC: USGPO.
- Drake, L.A. (1975) "Love and Rayleigh Waves in Nonhorizontally Layered Media," *Bull. Seismol. Soc. Amer.* 62:5, Oct, pp 1241-1258.
- Gorman, V.W. and Guenzlar, R.C. (1974) *LOFT SSE Definition and Seismic Analysis Methods*, TR-536-AM-46. Idaho Falls, ID: Aerojet Nuclear Co., Oct.
- Greensfelder, R.W. (1976) *Maximum Probable Earthquake Acceleration on Bedrock in the State of Idaho*, Research Project No. 79. Boise, ID: Idaho Dept. of Trans. Div. of Highways, Aug.
- Gutenberg, B. and Richter, C.F. (1942) "Earthquake Magnitude, Intensity, Energy and Acceleration," *Bull. Seismol. Soc. Amer.* 32:3, Jul.
- . (1956) "Earthquake Magnitude, Intensity, Energy and Acceleration (Second paper)," *Bull. Seismol. Soc. Amer.* 46:2, Apr.
- Hamilton, W. (1963) "Overlapping of Late Mesozoic Orogeny in Western Idaho," *Bull. Geolog. Soc. Amer.* Vol. 74, pp 779-788.
- Housner, G.W. (1959) "Behavior of Structures during Earthquakes," *Proc. ASCE Eng. Mech. Div.* 85:EM4, Oct.
- . (1965) "Intensity of Earthquake Ground Shaking near the Causative Fault," *Proc. 3rd World Conference on Earthquake Eng. Auckland and Wellington, New Zealand, Jan.*
- Kehrman, R.F. (1975) *Selection of Seismic Design Factors for the Clinch River Breeder Reactor Project, Sec. 2.0, Seismic Risk Analyses*. Annapolis, MD: Westinghouse Oceanic Div.

- King, K.W.; Navarro, R.; and Primas, C. (1977) *Administrative Report, Seismic Attenuation of Ground Response Studies at the Idaho National Engineering Laboratory*. Las Vegas, NV: U.S. Geol. Survey.
- Kirkham, V.R.D. (1931) "Snake River Downwarp," *Jnl. of Geol.* Vol. 39, pp 456-482.
- Kuntz, M.A. (1977) "Rift Zones of the Snake River Plain Idaho, As Extensions of Basin-Range and Older Structures," *Geol. Soc. of Amer. Abstr. with Programs*, 9:7.
- Lysmer, J. (1975) *FLUSH, A Computer Program for Approximate 3-D Analysis of Soil/Structure Interaction Problems*, EERC-75-30. Berkeley, CA: Univ. of Calif. Earthquake Eng. Res. Center, Nov.
- Malde, H.E. (1971) *Geological Investigation of Faulting Near the National Reactor Testing Station, Idaho*, Open File Report. Idaho Falls, ID: U.S. Geol. Survey.
- Navarro, R. (1975) *Seismic Attenuation Studies at the Idaho National Engineering Laboratory*, Open File Report 75-512. Idaho Falls, ID: U.S. Geol. Survey.
- Newmark Consulting Engineering Services. (1973) *A Study of Vertical and Horizontal Earthquake Spectra*. Washington, DC: USGPO, Apr. (WASH-1255)
- Newmark, N.M.; Blume, J.A.; and Kapur, K.K. (1973) "Seismic Design Spectra for Nuclear Power Plants," *Proc. ASCE Power Div.* 99:P02, Nov. pp 287-303.
- and Hall, W.J. (1969) "Seismic Design Criteria for Nuclear Reactor Facilities," *Proc. 4th World Conf. on Earthquake Eng. Santiago, Chile, Feb 1969*.
- Richter, C.F. (1958) *Elementary Seismology*, San Francisco: W.H. Freeman.
- Russell, I.C. (1902) *Geology and Water Resources of the Snake River Plains of Idaho*, Bulletin 199. Idaho Falls, ID: U.S. Geol. Survey.
- Schnabel, P.B. et al. (1972) *SHAKE, A Computer Program for Earthquake Response Analysis of Horizontally Layered Sites*, EERC-72-12. Berkeley, CA: Univ. of Calif. Earthquake Eng. Res. Center, Dec. (PB 220 207)
- Schnabel, P.B. and Seed, H.B. (1973) "Accelerations in Rock for Earthquakes in the Western United States," *Bull. Seismol. Soc. Amer.* 63:2, Apr.
- Seed, H.B. et al. (1974) *Site-dependent Spectra for Earthquake Resistant Design*, EERC-74-12. Berkeley: Univ. of Calif. Earthquake Eng. Res. Center, Nov. (PB 240 953)
- Seed, H.B.; Idriss, I.M.; and Kiefer, F.W. (1969) "Characteristics of Rock Motions During Earthquakes," *Jnl. of Soil Mech. and Found. Div.* 95:5. New York: Amer. Soc. of Civil Eng., Sep.

- Seed, H.B.; Ugas, C.; and Lysmer, J. (1976) "Site Dependent Spectra for Earthquake Resistant Design," *Bull. Seismol. Soc. Amer.* 66:1, Feb.
- Shannon & Wilson (SW) & Agbabian Assoc. (AA). (1975) *Procedures for Evaluation of Vibratory Ground Motions of Soil Deposits at Nuclear Power Plant Sites*, NUREG 75/072. Seattle, WA: SW & El Segundo, CA: AA, Jun.
- (1977) *Site-Dependent Effects at Strong-Motion Accelerograph Stations*, Progress Rpt. Seattle, WA: SW & El Segundo, CA: AA, Apr.
- Smith, R.B. and Sbar, M.L. (1974) "Contemporary Tectonics and Seismicity of the Western United States with Emphasis on the Intermountain Seismic Belt," *Bull. Geolog. Soc. Amer.* Vol. 85, pp 1205-1218.
- Smith, R.B. (1977) "Seismicity, Crustal Structure, and Intraplate Tectonics of the Interior of the Western Cordillera," in *Cenozoic Tectonics and Regional Geophysics of the Western Cordillera*, edited by R.B. Smith and G.P. Eaton, Geol. Soc. Amer. Special Paper, in publication.
- Steinbrugge, K.V. and Cloud, W.K. (1962) "Epicentral Intensities and Damage in the Hebgen Lake, Montana, Earthquake of August 17, 1959," *Bull. Seismol. Soc. of Amer.* 52:2, Apr.
- Stepp, J.C. (1972) "Analysis of Completeness of the Earthquake Sample in the Puget Sound Area and Its Effect on Statistical Estimates of Earthquake Hazard," *Proc. Int. Conf. on Microzonation for Safer Construction Res. and Appl.* Seattle, Nov. 1972, Vol. 2.
- Trifunac, M.D. and Udawadia, F.E. (1974) "Variations of Strong Earthquake Ground Shaking in the Los Angeles Area," *Bull. Seismol. Soc. Amer.* 64:5, Oct, pp 1429-1454.
- Trifunac, M.D. and Brady, A.D. (1975). "On the Correlation of Seismic Intensity with the Peaks of Recorded Strong Ground Motion," *Bull. Seismol. Soc. Amer.* 65:1, Feb.
- Ulrich, F.P. (1936) "Helena Earthquakes," *Bull. Seismol. Soc. Amer.* 26:4, Oct.
- U.S. Atomic Energy Commission (USAEC) (1973) "Design Response Spectra for Seismic Design of Nuclear Plants," in *Regulatory Guide 1.60*. Washington, DC: GPO, Oct.
- U.S. Coast and Geodetic Survey (USCGS). (1964) *Abstracts of Earthquake Reports for the Pacific NW*, MSA-115. Washington, DC: USCGS, Jul, Aug, Sep 1962.
- U.S. Geological Survey (USGS). (1967) *U.S. Earthquakes 1967*. Washington, DC: USGS.

- U.S. Nuc. Regulatory Comm. (USNRC). (1975) *Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants, LWR Edition*, 4 vols. Washington, DC: USNRC, Sep. (NUREG 75/087)
- Witkind, I.J. (1975) *Preliminary Map Showing Known and Suspected Active Faults in Idaho*, Open File Report 75-278. Denver, CO: U.S. Geol. Survey.
- Wong, H.L. and Trifunac, M.D. (1972) "A Note on the Effects of Recording Site Conditions on Amplitude of Strong Earthquake Ground Motion," *Proc. 6th World Conf. on Earthquake Eng. New Delhi, India, Jan 1977*.
- Woodward-Lundgren Assoc. (WCC/WLA). (1971) *Preliminary Seismic Risk Evaluation for the National Reactor Testing Station, Idaho*. Oakland, CA: WCC/WLA; Jun.
- Woodward-Clyde Consult. (WCC). (1975) *A Seismic Hazard Study for the LOFT Reactor Facility at the INEL, Idaho*. Oakland, CA: WCC, Jun.
- . (1977) *Preliminary Evaluation of Faults and Linear Features in the Arco Pass Area, Idaho*. San Francisco, CA: WCC.
- Zohdy, A.A.R. and Stanley, W.D. (1973) *Preliminary Interpretation of Electrical Sounding Curves Obtained across the Snake River Plains from Blackfoot to Arco, Idaho*, Open File Report. Idaho Falls, ID: U.S. Geol. Survey.