**Cover Sheet for a Hanford
Historical Document
Released for Public Availability**

Released 1994

**Prepared for the U.S. Department of Energy
under Contract DE-AC06-76RLO 1830**

**Pacific Northwest Laboratory
Operated for the U.S. Department of Energy
by Battelle Memorial Institute**

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, make any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

DECLASSIFIED

By Authority of D.S. Lewis
CG-NMP-1, 16-20-94
 By J.E. Savely 7-29-94
 Verified By Jessie Maley
8-4-94

JUL 30 1956

**300 AREA
 CLASSIFIED FILES**

RESTRICTED DATA

HDC-2296

RECORD CENTER FILE
 HDC-2296
 Page 1 of 3
DISTRIBUTION

1. VD Nixon
2. JR Wolcott
3. KT Perkins
4. WR Lewis
5. WK Alexander
6. RL Dickeman
7. JF Nesbitt/JB Medlin
8. EL Reed
9. GM Roy
10. Yellow
11. 700-300 Files
12. D&C Files

Richland, Washington
 August 14, 1951

COPY 1 OF 1, SERIES-MA

VERTICAL ROD TEMPERATURES

This document consists of
 5 parts, No. [redacted]

INTRODUCTION

An important factor affecting the decision on the use of a seal around the VSR on "C" is the temperature at which the rod can be expected to reach. Also the temperature of the rod-tip affects the choice of tip moderating material. These temperatures are calculated for a given set of conditions for "C" pile.

SUMMARY

The results of the calculations are best seen by referring to the attached figures. The effects of emissivity and weight of rod can be estimated by comparing the proper curves. The assumed conditions for calculating each curve are important and therefore, the basis for each curve is given separately below.

DISCUSSION

The sharp rise in temperature from time zero to time zero plus two seconds is by virtue of heat generated from neutrons captured in shutting down the pile and is therefore a function of power level. The temperature rise from then on is a function of graphite temperature (i.e., the temperature of the graphite surrounding the rod hole). The decay of graphite temperature with time is dependent upon the conductivity of the graphite and is slower in piles where there has been considerable damage due to neutron irradiation. The curves given below, would not be appreciably altered by using higher powers as the basis since only the first part from zero to zero plus is affected.

The graphite temperatures at the face of the hole would be reduced slightly due to the cooling to the rod. This effect was neglected, and leads to slight conservativeness.

Curve 1 is probably the most realistic case and should be considered the best estimate for "C" pile operating at graphite temperatures of 380° centigrade. Should a new pile atmosphere be used at a later date, with resulting higher graphite temperatures, these curves would obviously no longer hold. The production test being run by the Technical Division at "D" will serve to substantiate the method of calculation.

*Plant
 Records*

MASTE**DECLASSIFIED***He*

BASES

A common basis for all calculations is a power level of the 800 mw. For Curves 2 and 3 the relaxation time is 120 minutes; while for Curves 1 and 4 the relaxation time is 100 minutes. The other assumptions used differ for each curve and are listed below.

Figure 1 Curve 1

The temperature of the graphite in the filler block is that of Curve 1 - Figure 2, while the temperature in the tube block is that of Curve 2 - Figure 2. Curve 1 is based on the results given in Document HW 18609, and Curve 2 was taken from the electrical analogue results, (HDC-1855). Calculations were made on the assumption that alternate filler blocks and tube blocks surround the rod in going from top to bottom. The emissivity of the rod was taken as 0.3.

The next layer below or above this section results in filler blocks completely surrounding the rod.

A-A in Elevation
shows up as alternate
tube & filler blocks

Curve 2

The same assumptions as for Curve 1 were used, except that the filler block temperature was assumed to exist throughout and therefore, no allowance was made for the cooler tube block temperatures. The emissivity of the rod was taken as 0.8. This, then, represents the very most conservative case and is the worst condition that would occur. Also the graphite relaxation time was taken as 120 minutes. This is Curve 3 - figure 2.

Curve 3

Same as Curve 2 except that a rod emissivity of 0.4 was used.

DECLASSIFIED

Curve 4

This curve was computed using the same basis of graphite temperatures as that used to calculate Curve 1. The emissivity was taken as 0.3. The only difference is that the tip contained masconite and therefore, the heat capacity is larger. The density used for masconite was 123 lbs. per cubic foot, with a $C_p = 0.3 \text{ Btu} / \text{lb} - ^\circ\text{F}$

JM Roy

JM Roy:rg

DECLASSIFIED

DECLASSIFIED

DECLASSIFIED