**DOE/PC/90275-T17
(DE92004969)**

**DEVELOPMENT OF AN ADVANCED HIGH EFFICIENCY COAL COMBUSTOR FOR
BOILER RETROFIT**

Summary Report

**By
R. C. LaFlesh
M. J. Rini
J. G. McGowan
J. M. Beer
M. A. Toqan**

April 1990

Work Performed Under Contract No. AC22-86PC90275

**For
U.S. Department of Energy
Pittsburgh Energy Technology Center
Pittsburgh, Pennsylvania**

**By
Combustion Engineering, Inc.
Windsor, Connecticut**

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831; prices available from (615)576-8401, FTS 626-8401.

Available to the public from the National Technical Information Service, U. S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

**DEVELOPMENT OF AN ADVANCED HIGH EFFICIENCY
COAL COMBUSTOR FOR BOILER RETROFIT**

SUMMARY REPORT

DOE/PC/90275--T17

DE92 004969

Prepared by

**COMBUSTION ENGINEERING, INC.
WINDSOR, CONNECTICUT 06095**

APRIL 1990

Project Manager

Michael J. Rini

Principal Investigators

R.C. LaFlesh

M.J. Rini

J.G. McGowan

J. M. Beer

M. A. Toqan

Prepared for

**U. S. DEPARTMENT OF ENERGY
PITTSBURGH ENERGY TECHNOLOGY CENTER**

UNDER CONTRACT NO. DE-AC 22-86PC 90275

EXECUTIVE SUMMARY

Introduction

Since the oil embargo of 1974, there has been a major effort to develop energy systems that are not dependent on petroleum-based fuels. The Pittsburgh Energy Technology Center (PETC) of the U.S. Department of Energy (DOE) has directed a number of programs toward increasing both coal usage in existing markets and introducing new premium quality coal-based fuels to markets currently dependent on oil or natural gas. In the American industrial sector, a significant portion of the total boiler capacity in operation in the year 2000 is expected to be composed largely of pre-1980 units. Any substantial near term increase in the use of coal for raising industrial steam will, therefore, have to be accomplished through conversion of existing boilers currently fired by natural gas or oil.

The application of coal or coal-based fuels to industrial boilers originally designed for gas or oil firing presents several technical challenges to the combustion engineer. Specifically, constraints such as carbon conversion efficiency, emissions control, and coal and ash handling must be addressed and resolved. To enable these conversions, significant efforts have been made in the past decade in the fields of coal beneficiation, coal-based alternate fuels, and advanced combustion.

In 1986, in response to DOE PRDA DE-RA22-86PC90259, Combustion Engineering (CE) teamed with the Energy Laboratory of the Massachusetts Institute of Technology (MIT) and assembled a program which addressed Section 1.3.4 of the PRDA, "Advanced Combustors for Boiler Retrofit and Process Heat Applications". DOE later awarded a contract to the CE/MIT team to develop a High Efficiency Advanced Coal Combustor (HEACC) in a systematic multi-task program.

Objectives

The objective of the program was to develop an advanced coal combustion system for

firing beneficiated coal fuels (BCFs) capable of being retrofitted to industrial boilers originally designed for firing natural gas. The HEACC system is capable of firing microfine coal-water fuel (MCWF), MCWF with alkali sorbent (for SO_2 reduction), and dry microfine coal. Design priorities for the system were that it be simple to operate and offer significant reductions in NO_x , SO_x , and particulate emissions as compared with current coal-fired combustor technology. A schematic of the design concept is shown in Figure S-1.

FIGURE S-1 SCHEMATIC OF HEACC BURNER CONFIGURATION

A systematic development program was conducted at Combustion Engineering and the Massachusetts Institute of Technology to achieve these goals. An outline of the overall program is shown below in Table S-1. Under Task 1.0, innovative burner components were developed and integrated into an advanced design burner system for the Pilot-Scale Testing (Task 2.0) and Demonstration-Scale Testing (Task 3.0). Separate reports have been issued for Tasks 1.0, 2.0, and 3.0. This report summarizes the key findings of the three individual reports. For further detail, the reader is directed to the individual Task reports.

TABLE S-1: PROGRAM OUTLINE

TASK 1.0 COLD FLOW BURNER DEVELOPMENT

- 1.1 Program Planning
- 1.2 Cold Flow Swirler Development
- 1.3 Scale Up Criteria Development
- 1.4 Task 1 Report

TASK 2.0 PILOT SCALE TESTING AT MIT

- 2.1 Test Facility Preparation
- 2.2 Atomization Testing
- 2.3 Combustion Testing at 5×10^6 Btu/hr
- 2.4 Clean Up and Waste Disposal
- 2.5 Task 2 Report

TASK 3.0 DEMONSTRATION TESTING AT C-E

- 3.1 Test Facility Preparation
- 3.2 Combustion Testing at 50×10^6 Btu/hr
- 3.3 Clean Up and Waste Disposal
- 3.4 Task 3 Report

TASK 4.0 PROJECT FINAL REPORT

- 4.1 Data Summarization
- 4.2 Project Summary/ Final Report

TASK 5.0 OVERALL PROJECT MANAGEMENT

- 5.1 Project Management

Discussion

Highlights of the individual tasks are discussed below:

Task 1.0 Cold Flow Burner Development

The HEACC was designed to feature uncomplicated operation to facilitate boiler retrofit applications and to incorporate technologies designed to control gaseous pollutant emissions of NO_x and SO_2 . In addition, the HEACC targeted improved aerodynamic efficiency (in the form of reduced combustion air pressure losses) as compared to conventional burner designs.

By definition, burners introduce and mix the fuel and combustion air in a boiler or process heater to obtain a stable flame. A key function of most burner designs is to manipulate the inflowing combustion air stream in such a way as to promote rapid fuel ignition by providing the correct chemical, thermal, and kinetic environment to support combustion of the incoming fuel. In selecting a specific device for generating swirl, the burner designer must concentrate on achieving a balance between aerodynamic efficiency and the required swirl. As swirl requirements increase, so do swirler mechanical energy losses. These losses are reflected in the pressure drop across the burner register. In general, there is significant motivation to minimize these pressure losses as they represent a significant loss on overall thermal system efficiency, since combustion air fan horsepower requirements increase directly proportional to burner pressure drop.

The focus of Task 1.0 of this work was to systematically identify and optimize advanced swirl generating devices for integration into the HEACC. Key components of this work included cold flow swirler development, a cold flow burner model testing program, and the establishment of burner scale up criteria. The cold flow program included the development of primary air swirler designs, the design of the secondary flow geometry, and a swirler test facility program to quantify primary air swirler performance. The end result of this work was the detailed design of a number of test swirlers to be experimentally tested in a swirler test facility (STF), the best of which would be incorporated into the cold flow burner test program. The combination of the swirler design procedure in concert with the noted pressure drop considerations and geometry restrictions, yielded 8 different designs for testing. The best two swirler designs, as determined by the STF tests, were further characterized in the full scale burner cold flow model. The secondary flow geometry design part of the work made use of the principle of "internal staging" of the burner and the HEACC was designed as an internally staged burner.

Under the cold flow burner model testing program, the design for the prototype HEACC was based on the following design requirements:

- 1) The physical envelope of the HEACC (diameter and length) must be similar to

conventional oil burner envelope to facilitate retrofit.

- 2) Primary air swirler stoichiometry (η_p) targeted for a value between 0.3 and 0.4 to minimize NO_x formation via internal staging.
- 3) Incorporation of a low pressure loss staged air distribution system for secondary air stream(s)
- 4) Utilization of the most efficient swirler designs for the primary air stream.

Eight different swirlers, with four basic geometric designs were tested in the STF. The results from this test program showed that several of the new designs were significantly more efficient at generating swirl than previous commercial designs.

One design, the Forced Vortex (Swirler B) produced the greatest torque at equivalent conditions of any of the configurations tested. It produced 110% more torque than the Baseline Swirler, at an equal pressure drop. Another swirler, Free Vortex (Swirler D) produced 40% more torque than the Baseline Swirler. Two other swirlers (A and C) produced increased swirl over the baseline case, but had excessive projected pressure drops. Two segmented flat blade swirlers generated lower torque values than the Baseline Swirler. Based on these results, Swirlers B and D, shown below in Figure S-2 were chosen as the primary air swirler configurations for further testing in the cold flow burner model test program.

SWIRLER B (FORCED VORTEX)

SWIRLER D (FREE VORTEX)

FIGURE S-2 SELECTED PRIMARY AIR SWIRLER CONFIGURATIONS

Seven different configurations, and one baseline high swirl wall fired burner were subjected to extensive testing (flow visualization and velocity mapping) in the cold flow burner model testing program. In summary, the results of the cold flow testing program showed:

- 1) The flow pattern/s generated appeared sufficient to maintain flame stability and had the potential to minimize NO_x production via internal staging.
- 2) The burner flow field was dominated by the swirler size and centrality.
- 3) Both the Forced Vortex- Swirler "B" and the Free Vortex- Swirler "D" demonstrated similar overall flow patterns. The Forced Vortex swirler did produce a somewhat larger and stronger recirculation pattern.
- 4) The removal of the outermost of three divergent nozzle rings was required to reduce the burner pressure drop to an acceptable level while maintaining the desired burner flow pattern.
- 5) The burner near-field aerodynamics remained generally similar over the range of register adjustability.

Task 2.0 Pilot Scale (5×10^6 Btu/hr) Combustion Tests

The specific aims of this task, carried out at the Massachusetts Institute of Technology (MIT) were to characterize a Pilot scale HEACC over a wide range of combustion conditions, with special emphasis on the topics of carbon conversion efficiency, NO_x and SO_x emissions, and flyash composition and particle size distribution. The purpose of this work was to confirm the validity of the HEACC design concept and to provide refinements to the design prior to large scale testing. The experiments at MIT could be divided into two parts:

- 1) Combustion tests in the Combustion Research Facility (CRF)
- 2) Measurements in a Spray Test Facility (STF) designed to determine spray atomization quality

MIT's role included the following:

- 1) Fabrication of a 5×10^6 Btu/hr pilot scale version of the HEACC burner (shown in Figure S-3), and installation of the burner into the flame tunnel of the CRF.
- 2) "Fine tuning" of the burner with the combustion of No. 2 fuel oil.
- 3) A detailed experimental investigation into the combustion behavior of the HEACC using two types of coal-water fuels (CWF).

FIGURE S-3 PILOT SCALE HEACC

In the combustion experiments, the HEACC burner was attached to the front end of the combustion tunnel of the CRF. The 1.2 x 1.2 x 4.5 m test section was designed to permit the detailed investigation of industrial type turbulent diffusion flames by in-flame measurements and optical probing.

The initial combustion tests of the burner optimization study (burning No. 2 fuel oil) showed that, by varying the burner geometry, it was possible to sensitively influence the position of the flame front, combustion length of the flame, and the NO_x emissions.

The burner geometry changes are effected by adjustment of the axial positions of the atomizing nozzle, the primary swirler, and the secondary air annuli. An unexpected finding from these preliminary tests was the very low NO_x emissions (about 125 ppm) obtainable with the HEACC when burning No. 2 oil.

The CWF experimental tests proved that:

1) The burner was capable of stable operation, with high carbon conversion efficiency ($\eta_c > 99\%$) and moderate NO_x emissions. Without overfire air the measured NO_x was in the range 600-700 ppm; with overfire air, the NO_x emissions were reduced about 350 ppm.

2) As in previous CWF combustion studies, atomization quality was shown to be of critical importance. Fuel pre-heating to improve the spray quality by achieving disruptive atomization proved to be beneficial, both for better flame stability and for more rapid carbon burnout. Specifically:

a) When the "ultrafine" CWF was heated to 241 °F (116 °C) upstream of the atomizer nozzle, a very fine flyash particle size distribution, close to that of the individual mineral inclusions, was obtained. This flyash was virtually carbon-free. The same treatment for the "fine-grind" CWF also led to excellent flame conditions, but the presence of traces of unburned carbon in the flyash contributed to a slightly coarser particle size distribution.

b) A significant potential for the use of water-dispersible sulfur sorbents was observed; the sulfur capture efficiency with calcium acetate addition to the CWF was high (71% sulfur capture at Ca/S = 1.8) and sulfur capture with Ca(OH)₂ addition was satisfactory (50% sulfur capture at Ca/S = 2.1). It appears that having a sorbent in close proximity to the coal particles while these are undergoing pyrolysis in a fuel-rich flame zone enhances the sulfur capture efficiency.

In summary, it was the general conclusion at the end of this phase of the work that the HEACC design has potential for becoming a high efficiency, clean combustion device.

The results of the Pilot-Scale testing at MIT were integrated into the design of the Demonstration Scale (50×10^6 Btu/hr) HEACC.

Task 3.0 Demonstration Scale (50×10^6 Btu/hr) Testing at Combustion Engineering

Under this task, the burner system based on the Task 1.0 and 2.0 results was designed and fabricated at a scale of 50×10^6 Btu/hr and installed in the Industrial-Scale Burner Facility (ISBF) at Combustion Engineering. A schematic of the HEACC burner that was installed in this facility is shown in Figure S-4. This burner incorporates the following design features:

- 1) Measured and controllable primary airflow.
- 2) Coaxial construction with 2 axially adjustable secondary air rings.
- 3) Distributed secondary air via perforated plate.
- 4) Adjustable direction tertiary air swirler.
- 5) Non-refractory burner exit nozzle (quarl).
- 6) Ability to install either a CWF gun or pulverized coal nozzle without burner modification.
- 7) Burner envelope to match a standard oil burner opening.

FIGURE S-4 SCHEMATIC OF DEMONSTRATION-SCALE HEACC

A key component of the combustor was the primary air swirler developed under the work of Task 1.0. Two groups of swirlers were developed each producing a different vortex, either free or forced vortex types. The most efficient examples of each type were determined, and then selected for the Task 3.0 work.

The Demonstration-Scale tests were conducted in two major test series. The first utilized coal-water fuels (CWFs) in three forms: a microfine grind (9 micron MMD), a fine grind (21 micron MMD), and a fine grind with two different alkali sorbents (calcium hydroxide and calcium acetate) added for SO₂ capture. The second series of tests utilized a fine grind, dry pulverized coal of 21 micron MMD. This coal was prepulverized, stored in a coal silo, and pneumatically injected into the HEACC via a dense phase transport system.

The results of the CWF tests showed:

- The furnace opening required for the HEACC matched that of a comparable industrial oil burner- this would facilitate boiler retrofit.
- High carbon conversion efficiencies (> 98.0%) could be achieved at excess air levels of 30-35%.
- NO_x could be reduced from over 700 ppm to below 475 ppm, but at the expense of reduced carbon conversion.
- Sulfur capture rates with the sorbent-containing CWFs were lower by a factor of approximately two than those measured in the Pilot-Scale tests.

The results of the pulverized coal tests showed :

- Carbon conversion efficiencies of greater than 98.5% could be obtained at excess air levels of 15 to 25%.
- NO_x emissions could be controlled to below 390 ppm while maintaining high carbon conversion efficiencies of generally greater than 98.5%.
- The use of stored pulverized coal and dense phase pneumatic transport to the

burner was successfully demonstrated. This could be an important method of implementing Beneficiated Coal Fuel (BCF) use in industrial oil replacement applications.

In summary, this program produced an advanced coal firing system that is capable of combusting both water-based and dry pulverized forms of BCFs in an industrial boiler environment. The HEACC could be adapted to a long term field program in a commercially operating unit. As shown in Figure S-5, the optimum configuration for this would employ the HEACC firing either a dry beneficiated coal product using a dense phase storage and transport system or a beneficiated CWF. This long term operation would clearly be another important step in the Department of Energy's stated goal of energy independence for our nation.

HEACC WITH STORED PULVERIZED COAL FIRING

HEACC WITH CWF FIRING

FIGURE S-5 SCHEMATIC OF AN INDUSTRIAL BOILER INCORPORATING HEACC

TABLE OF CONTENTS

	<u>Page</u>
1.0 Introduction/ Background	21
2.0 Summary of Fuel Characteristics	25
2.1 Coal- Water Fuels	25
2.2 Pulverized Coal Fuels	28
3.0 Summary of Task 1.0, Cold Flow Burner Development	32
3.1 Cold Flow Swirler Development	32
3.2 Cold Flow Burner Model Testing Program	49
3.3 Burner Scale Up Criteria	54
4.0 Summary of Task 2.0, Pilot Scale Combustion Tests	58
4.1 General Overview	58
4.2 Combustion tests in the Combustion Research Facility (CRF)	60
4.3 Measurements in the Spray Test Facility (STF)	87
4.4 Summary/ Conclusions	89
5.0 Summary of Task 3.0, Demonstration Scale Testing at 50×10^6 Btu/ hr	93
5.1 CWF Firing	97
5.2 Pulverized Coal Firing	121
6.0 General Discussion of Results	132
7.0 Conclusions and Recommendations for the Generalization of the Technology	135
7.1 Industrial Applications/ Markets	135
7.2 Coal- Based Fuel Applicability	137
7.3 Systems Applications	143
8.0 References	146

LIST OF TABLES

<u>TABLE</u>	<u>PAGE</u>
1.1 Program Outline-"Development of a High Efficiency Advanced Coal Combustor"	23
2.1 Summary of Fuel Analysis for CWF Fuels	30
2.2 Analysis of Pulverized Test Coal	31
3.1 Swirler Test Configurations	48
3.2 Swirler Test Facility Data (Constant Mass Air Flow)	48
5.1 Test Matrix No. 1	98
5.2 Test Matrix No. 2	100
5.3 Test Matrix No. 3	101
5.4 Overview Summary of CWF Tests	103
5.5 Summary of CWF Test Results	104
5.6 Results of Sorbent Injection Tests	119

LIST OF FIGURES

<u>FIGURE</u>	<u>PAGE</u>
1.1 Schematic of Overall Program	24
2.1 Particle Size Distribution of Fine Grind CWF	26
2.2 Particle Size Distribution of Ultrafine Grind CWF	27
2.3 Schematic of Sorbent Injection System	29
3.1 Schematic of Primary Air Swirler Design Procedure	35
3.2 Schematic of Swirl Vane Geometry	38
3.3 Swirler Flow Types	40
3.4 Geometry of Swirl Vanes	42
3.5 Different Swirlers Tested	45
3.6 Schematic of Swirler Test Facility	47
3.7 Prototype HEACC Cold Flow Model	50
3.8 Velocity Flow Results- Typical Cold Flow Model Tests	53
4.1 Pilot Scale HEACC	59
4.2 Effect of Burner Configuration on NO _x Emissions	64
4.3 Effect of Atomizer Type upon Carbon Burnout	68
4.4 Effect of Atomizing Air/Fuel Ratio on Carbon Burnout	69
4.5 Carbon Burnout Profile Along Furnace Centerline	71
4.6 Effect of Coal Content and Air/Fuel Ratio on Carbon Burnout for the Fine Grind CWF	72
4.7 Carbon Burnout Levels along Flame Axis	75
4.8 Effect of Fuel- Rich Conditions on Fly Ash Particle Size Distribution	77

4.9	Effect of Molar Ca/S Feed Ratio on Fly Ash Particle Size Distribution	79
4.10	Effect of Atomizer Type on NO_x Emissions	80
4.11	Effect of CWF Coal Content (Fine Grind) on NO_x Emissions	80
4.12	Effect of Swirl Degree on NO_x Emissions	82
4.13	Effect of Internal Flame Staging on NO_x Emissions	82
4.14	Effect of Primary Air Equivalence Ratio on NO_x Emissions for Externally Staged Flames	84
4.15	Effect of Sorbent on Sulfur Capture	86
4.16	Effect of Ca/S Ratio on Sulfur Content of Flyash	86
4.17	Effect of Atomizing Air/Fuel Ratio on CWF Atomization Quality	88
4.18	Drop Size Distribution in the Fuel Spray	90
4.19	Effect of Temperature on Atomization Quality	90
5.1	Schematic of HEACC Demonstration- Scale Burner	94
5.2	HEACC Prior to Installation in Test Facility	95
5.3	HEACC Prior to Installation in Test Facility	95
5.4	HEACC Burner Installation with CWF Gun in Place	96
5.5	Carbon Conversion vs. Excess Air, 8 Cell Atomizer (Test Points 9-13), Unstabilized Fine Grind	107
5.6	NO_x Emissions vs. Excess Air, 8 Cell Atomizer (Test Points 9-13), Unstabilized Fine Grind	107
5.7	NO_x Emissions vs. PAF- 8 Cell Atomizer, Forced Vortex Swirler (Test Points 9- 13), Unstabilized Fine Grind	108
5.8	Carbon Conversion vs. PAF (Test Points 15-20) 8 Cell Atomizer, 30% Excess Air, Diluted Baseline Ultrafine	110
5.9	NO_x Emissions vs. PAF (Test Points 15-19), 8 Cell Atomizer, 30% Excess Air, Diluted Baseline Ultrafine	110

5.10 Carbon Conversion vs. Primary Air Fraction, 25° Tip, Forced Vortex Swirler, 25% Excess Air, Slightly Stabilized Fine Grind (Test Points 21-23)	111
5.11 Carbon Conversion vs. Primary Air Fraction, 8 Cell Tip, Forced Vortex Swirler, 35% Excess Air, Slightly Stabilized Fine Grind (Test Points 24-27)	111
5.12 Carbon Conversion vs. Excess Air, Effect of Fuel Type, Forced Vortex Swirler, PAF = 0.35	112
5.13 Carbon Conversion Efficiency vs. Excess Air, Comparison of CWF Fuels, 8 Cell Tip, Forced Vortex	114
5.14 Carbon Conversion vs. Excess Air, Fine Grind (Test Points 39-51)	116
5.15 NO _x Emissions vs. Excess Air, Fine Grind (Test Points 39-51)	116
5.16 Carbon Conversion Efficiency vs. PAF, 8 Cell Tip, Forced Vortex Swirler, 22% Excess Air, Fine Grind (Test Points 52-56)	117
5.17 NO _x Emissions vs. Primary Air Fraction, 8 Cell Tip, Forced Vortex Swirler, 22% Excess Air, Fine Grind (Test Points 52-56)	117
5.18 Sulfur Capture Efficiency vs. Ca/S Ratio, CE Test Points 58-63	120
5.19 Staggered Burner Configuration	123
5.20 Telescoped Burner Configuration	123
5.21 Carbon Conversion vs. Excess Air, PC Firing Tests- No. 101-120, Free Vortex Swirler- 100% Load	125
5.22 Carbon Conversion vs. Excess Air, PC Firing Tests- No. 201-215, Forced Vortex Swirler- 100% Load	125
5.23 NO _x Emissions vs. Excess Air, Primary Air Fraction = 0.3	127
5.24 NO _x Emissions vs. Primary Air Fraction, Excess Air = 20%, Free Vortex Swirler, I-Jet Injector	127
5.25 NO _x Emissions vs. Primary Air Fraction, Excess Air = 15%, Forced Vortex Swirler, I-Jet Injector	128

5.26 NO_x Emissions vs. Primary Air Fraction, Excess Air = 20%, Forced Vortex Swirler, I-Jet Injector	128
5.27 NO_x Emissions vs. Excess Air, Free Vortex Swirler, 30 Deg. Cone Injector, Varying Primary Air Fraction	130
5.28 NO_x Emissions vs. Excess Air, Free Vortex Swirler, 30 Deg. Conical Injector, PAF = 0.30, Effect of Telescoped Geometry	130
5.29 Carbon Conversion vs. Excess Air, 60% Load- Forced Vortex Swirler, I-Jet Injector	131
5.30 NO_x Emissions vs. Excess Air, 60% Load- Forced Vortex Swirler, I-Jet Injector	131
7.1 Typical Industrial Boilers	136
7.2 Carbon Burnout Rates of Alma Seam Microfine CWF	139
7.3 Schematic of Microfine Pulverizing System	142
7.4 Schematic of Industrial Boiler Incorporating HEACC	144
7.5 Process Heat Applications for HEACC	145

1. INTRODUCTION/BACKGROUND

Since the Oil embargo of 1974, there has been a major effort to develop energy systems that are independent of petroleum-based fuels. In the United States, with the world's most abundant coal resources, much of this effort has been focused on the expanded use of coal-based fuels by the industrial and utility sectors. The United States Department of Energy has been the leader in fostering this work. Significant progress has been made during the past decade in the fields of coal beneficiation, coal-based alternate fuels, and advanced coal combustion.

In 1986, in response to DOE PRDA DE-RA22-86PC90259, Combustion Engineering (C-E) teamed with the Energy Laboratory of the Massachusetts Institute of Technology (MIT) and assembled a program which addressed Section 1.3.4 of the PRDA, "Advanced Combustors for Boiler Retrofit and Process Heat Applications". DOE later awarded to C-E and MIT a contract to develop a High Efficiency Advanced Coal Combustor (HEACC) in a systematic multi-task program. This report summarizes the work conducted under the HEACC program.

The objective of this program was to develop an advanced coal-combustion system capable of being retrofitted to industrial boilers originally designed for firing natural gas, distillate, and/or residual oil. Through the use of beneficiated coal fuel and advanced combustion technology, the program was to produce a combustion system which is reliable, simple to operate, and incorporates significant reductions in NO_x , SO_x , and particulate emissions over a base coal case.

A systematic and coordinated program was conducted at Combustion Engineering and the Massachusetts Institute of Technology to achieve this goal. The overall program included Cold Flow Burner Development at C-E, Pilot Scale (5×10^6 Btu/hr) Combustion Tests at the MIT, and Demonstration Scale (50×10^6 Btu/hr) Combustion Tests at C-E. An outline of the overall program is given in Table 1.1 and its flow chart is shown in Figure 1.1. Task 1 was completed in 1987 and developed the components needed for Tasks 2.0 and 3.0. Task 2 was completed in 1988 and provided information needed to finalize the design of the full scale combustor. Task 3 was

completed in 1989 and yielded good results firing both coal water and dry pulverized fuels. Separate reports have been issued for Tasks 1.0, 2.0, and 3.0. (Rini, et al 1989a, Toqan, et al, 1989, and Rini, et al, 1989b) This report is intended to document the entire project and to provide an overall summary, including recommendations for the generalization of the technology, and for future demonstration of the HEACC concept. In addition to the Task Reports, several technical papers (Rini, et al., 1988a-e, 1987a) have been published.

TASK 1.0 COLD FLOW BURNER DEVELOPMENT

- 1.1 Program Planning
- 1.2 Cold Flow Swirler Development
- 1.3 Scale Up Criteria Development
- 1.4 Task 1.0 Report

TASK 2.0 PILOT SCALE TESTING AT MIT

- 2.1 Test Facility Preparation
- 2.2 Atomization Testing
- 2.3 Combustion Testing at 5×10^6 Btu/hr
- 2.4 Clean Up and Waste Disposal
- 2.5 Task 2.0 Report

TASK 3.0 DEMONSTRATION TESTING AT C-E

- 3.1 Test Facility Preparation
- 3.2 Atomization Testing
- 3.3 Combustion Testing at 50×10^6 Btu/hr
- 3.4 Clean Up and Waste Disposal
- 3.5 Task 3.0 Report

TASK 4.0 PROJECT FINAL REPORT

- 4.1 Data Analysis
- 4.2 Final Report

TASK 5.0 OVERALL PROJECT MANAGEMENT

- 5.1 Project Management

Table 1.1 Program Outline- "Development of a High Efficiency Advanced Coal Combustor"

FIGURE 1.1 SCHEMATIC OF OVERALL PROGRAM

2.0 SUMMARY OF FUEL CHARACTERISTICS

For the experiments carried out under this test program, both CWF and pulverized coal fuels were used by MIT and Combustion Engineering. The coal used for both forms of the fuel supply was an Elkhorn Seam (Westmoreland Coal Co.) coal provided by DOE via Energy International, Inc. The coal had an inherently low ash level and, with washing, exhibited 2.5 to 3.0% ash. The same coal was used for producing both the coal- water fuels and the pulverized coals to provide directly comparable data. Summary details of the different fuels follow:

2.1 Coal- Water Fuels

Three types of CWFs were used during the CWF test series. These fuels were supplied by the OXCE Fuel Company via Energy International. They included:

1) Fine grind CWF

The size composition of this fuel is typical of CWF that OXCE has supplied to several DOE programs and several commercial demonstrations. With a MMD of 21 microns, this fuel represents a CWF that could potentially be used in the more generously sized furnaces of industrial and small scale utility boilers. It is a considerably finer grind than standard pulverized coal which has a MMD of 55- 60 microns. Figure 2.1 gives the particle size distribution of this fuel.

2) Ultrafine CWF

With a MMD of 9 microns, this CWF represents a potential fuel for boilers with limited residence time such as tightly designed oil-fired boilers and all natural gas fired units. The key to exploiting the ultrafine CWF lies in achieving very high quality atomization to enable the required rapid and full burnout with a small furnace volume. Figure 2.2 presents the particle size distribution of the ultrafine CWF fuel.

FIGURE 2.1 PARTICLE SIZE DISTRIBUTION OF FINE GRIND CWF

FIGURE 2.2 PARTICLE SIZE DISTRIBUTION OF ULTRAFINE CWF

3) Sorbent CWF

In an effort to reduce SO₂ emissions, two CWFs were used which contained a sulfur sorbent. Two classes of sorbent were used: solid particles of calcium hydroxide [Ca(OH)₂] and water soluble calcium acetate [Ca(C₂H₃O₂)₂]. For the Combustion Engineering tests, these sorbents were first premixed with water and then admixed with the fine grind CWF in the fuel piping just prior to combustion. This system is shown schematically in Figure 2.3. The sorbent mixing was different for the MIT testing, also, as will be discussed in Section 4.0, the nature of the sorbent (soluble vs. insoluble) proved to be of significance in sulfur capture ability.

A summary of the fuel analysis for the CWFs used during the tests is given in Table 2.1.

2.2 Pulverized Coal Fuels

The coal used for the pulverized coal portion of the tests was the same Elkhorn Seam as was used for the CWFs. The coal was pulverized to a MMD of 21 microns in a standard Combustion Engineering bowl mill. This grind is considerably finer than conventional pulverized coal (MMD = 55-60 microns), but was achieved using standard grind milling equipment. This is significant because it demonstrated that "semi-micronized" coal fineness could be obtained without the use of special equipment.

The as-fired analysis of the pulverized coal is shown in Table 2.2.

FIGURE 2.3 SCHEMATIC OF SORBENT INJECTION SYSTEM

TEST NUMBERS	MOISTURE	% BY WEIGHT AS FIRED				NITROGEN	OXYGEN	ASH	HHV (BTU/LB)
		HYDROGEN	CARBON	SULFUR					
1-14	36.20	3.30	52.20	0.50		1.00	5.10	1.70	9135
15-19	39.53	3.10	49.40	0.48		1.03	4.83	1.63	8653
20	40.95	3.10	48.20	0.47		1.00	5.32	0.96	8450
21-27	36.10	3.30	52.20	0.50		1.10	5.10	1.70	9144
28-34	40.40	3.10	48.70	0.50		1.00	4.70	1.60	8529
35-38	41.80	3.00	47.50	0.50		1.00	4.60	1.60	8328
39-57	34.50	3.40	53.50	0.50		1.10	5.20	1.80	9373
58	40.80	3.10	48.50	0.50		1.10	4.30	1.70	8490
59	36.50	3.30	52.00	0.51		1.08	4.81	1.80	9106
60	36.10	3.30	52.30	0.51		1.08	4.92	1.79	9163
61	40.80	3.10	48.50	0.50		1.10	4.30	1.70	8490
62	38.20	3.20	50.60	0.50		1.05	4.73	1.73	8862
63	36.80	3.20	51.80	0.51		1.07	4.75	1.77	9063
64-65	34.50	3.40	53.50	0.50		1.10	5.20	1.80	9373

TABLE 2.1 SUMMARY OF CWF TEST FUEL ANALYSES

COAL: Elkhorn Seam- Westmoreland Coal Company

As- Fired Sample

PROXIMATE ANALYSIS (WT. PERCENT)

MOISTURE (TOTAL)	1.1
VOLATILE MATTER	35.2
FIXED CARBON (DIFF)	60.2
ASH	<u>3.5</u>
TOTAL	100.0

HHV, BTU/ LB	14,315
LB ASH/ MM BTU	2.4

ULTIMATE ANALYSIS (WT. PERCENT)

MOISTURE (TOTAL)	1.1
HYDROGEN	5.1
CARBON	81.8
SULFUR	0.5
NITROGEN	1.4
OXYGEN (DIFF)	6.6
ASH	<u>3.5</u>
TOTAL	100.0

TABLE 2.2 ANALYSIS OF PULVERIZED TEST COAL

3.0 SUMMARY OF TASK 1.0. COLD FLOW BURNER DEVELOPMENT

As detailed in the Task 1.0 Report of this project (Rini, et al., 1989a), the Cold Flow Burner Development phase of this project consisted of three major subtasks:

- 1) Cold Flow Swirler Development
- 2) Cold Flow Burner Model Testing Program
- 3) Burner Scale Up Criteria

The purpose of this work was to develop critical combustor components and verify that the flow patterns produced by the prototype HEACC design were conducive to achieving the project performance goals.

A summary of the work carried out under these subtasks follows.

3.1 Cold Flow Swirler Development

The advantages of burner systems that achieve flame stabilization via swirling flows are well documented (e.g., Beer and Chigier, 1972; Schmid, et al., 1987); thus, swirl burners are used in many industrial applications. The unique feature of swirl burners is the vortex-generated internal recirculation zone where the hot products of combustion are carried back towards the burner throat, establishing the flame root within the burner's divergent nozzle. This leads to very stable ignition and high combustion rates in the burner near-field. However, one potential disadvantage of this type of burner is that the intense mixing and combustion in the near-field can cause significant NO_x formation. Therefore, careful control over the air/ fuel mixing and secondary air mixing rates is required to control NO_x production.

In general, swirling air flows in the burner near-field region are typically established by means of tangential injection of a portion of the combustion air stream into the burner register nozzle. The dimensionless ratio of the combustion air angular momentum flux (the tangential component) to the combustion air axial momentum flux times the burner exit radius, defines the initial swirl number of the burner. This parameter is commonly

used to define the relative effectiveness of swirl generation devices. Swirl generators with operating swirl numbers of 0.6 or greater are known to establish recirculating aerodynamic regimes which greatly enhance burner flame stability, and general burner performance.

A wide variety of swirl generation devices are in common use today by commercial burner manufacturers. Several manufacturers have centered on the use of swirl generation concepts which employ multi-vaned tangential inlet devices. For example, Combustion Engineering has successfully employed optimized versions of vaned tangential swirlers into the coal-water fuel burners that they have developed. These devices are relatively inexpensive to construct and are capable of generating swirl numbers of 0.6 or greater.

A major drawback to most vaned tangential swirler designs is that they tend to operate with relatively high pressure losses. These losses translate directly into an increase in burner fan head requirements. An increase in required fan head negatively impacts on the overall efficiency of the power system and can increase plant capital equipment cost as well. In this light, it was decided to improve swirl generation efficiency by following gas turbine combustor design practice (see Lefebvre, 1983) and build the HEACC burner design around the use of axial flow vane type swirlers, with their characteristically lower pressure drops for equal swirl flow generation. In order to explore aerodynamic performance versus fabrication costs, it was decided that both straight and curved vane swirlers would be designed with both forced or free vortex flow leaving the swirlers. For straight vane axial swirlers, the previous work of Beer and Vermes (1982) and Lew and Toof (1984) provided a basis for the initial design.

Although previous axial flow swirler research has shown that this type of geometry could achieve high levels of swirl efficiently, that is, with reduced pressure drop, additional design information was needed before this concept could be applied to stationary boiler burners. Specifically, burner near-field aerodynamics generated by an axial vane swirler could differ from the flow fields established by the tangential inlet vane swirlers in common use today. Also, the impact of the potential difference on

burner flame stability needed to be established, and it was known that blade design was critical in minimizing axial flow swirler pressure losses. Therefore, in order to establish the analytical design and scaling criteria required to apply axial flow swirlers to commercial scale boilers, a comprehensive primary air swirler design procedure was needed.

3.1.1 Important Swirler Design Steps

Figure 3.1 presents an overall schematic of the individual steps and inputs required for the swirler design. The end result of this work was the detailed design of a number of test swirlers to be experimentally tested in the swirler test facility (STF), the best of which would be incorporated into the cold flow burner test program. In the following sections we will present a summary of the individual components of the design procedure for the primary air swirlers.

1. Establishment of Overall Combustion Requirements

This initial phase of the primary air swirler design involves the use of overall combustion mass and energy flow calculations to establish the swirler air flow requirements of the burner assembly. Important inputs to this phase include: burner size (diameter) and firing rate, maximum pressure drop limitations, fuel specifications, and burner emissions requirements.

2. Establishment of Range of Swirl Numbers Desired for Burner Assembly

The swirl number of the burner assembly is an important parameter for determining the performance of a given design. This fact has been noted by numerous researchers and has been the subject of a long term research program at the International Flame Research Foundation (see, for example, Leuckel (1967)). During the development of coal-water slurry burners at Combustion Engineering, variation of the burner swirl number was a key design variable. The resulting burner assembly, named the High Swirl Wall-Fired Burner (HSWF), has been the basis for a series of commercial-scale

FIGURE 3.1 SCHEMATIC OF PRIMARY AIR SWIRLER DESIGN PROCEDURE

CWF burners ranging in capacity for 25 to 100 x 10⁶ BTU/hr (LaFlesh, et al. (1986) and Rini, et al. (1986)). Thus, the HSWF design, with an initial swirl number of approximately 1.0, was selected as the starting point for the new burner design. Similarly designed Combustion Engineering CWF burners for tangential- firing have ranged from 25 to 135 x 10⁶ BTU/hr.

3. Establishment of Combustion Mass Flow Requirements

For the design of low NO_x emission burners, an important parameter that quantifies the magnitude of air staging in such systems is the primary zone stoichiometric ratio, η_p , defined as:

$$\eta_p = \text{primary zone combustion air flowrate} / \text{stoichiometric air flowrate}$$

Based on previous work on coal-water fuels and burner development, it was concluded that the burner primary airflow should be set at a value equivalent to the amount of air required to burn off all the volatile matter in the coal. Following the work of Nsakala, et al. (1985), it was calculated that 35% of the stoichiometric air was required to burn off the volatiles in the selected fuel, OXCE Elk Creek CWF at 65% solids. Thus, a primary zone stoichiometric ratio of 0.35 was used in the design calculations. It should also be noted that entrainment of secondary air plus recirculated partial combustion products was expected to raise the actual η_p to approximately 0.6, an optimum value for internally staged low NO_x flames (Rini, et al. (1987b)).

4. Establishment of Overall Burner Dimension Envelope

In this part of the design procedure, limits to the overall dimensions of the burner assembly were established. A key goal of this project was to develop a coal/ CWF combustor to fit into an existing burner opening in a oil-designed boiler. This would eliminate the need for pressure part modifications and greatly enhance the economics of the retrofit. The major sources of input for these calculations were Combustion

Engineering Design Standards which reflect typical industrial boiler burner opening size limitations.

5. Establishment of Primary and Secondary Air Velocities

Based on previous Combustion Engineering experience with coal-water fuels (LaFlesh, et al. ,1986, Rini, et al.,1987b, 1986), a primary swirler air velocity in the range of 80- 100 ft/s and a secondary air velocity of 75- 100 ft/s were chosen. Using the previous mass flow calculations and burner geometry specifications, these velocities can be readily calculated and compared to the desired velocities.

6. Swirler Blade Design Procedure

Under this task, the geometry of the primary air axial flow swirler blades were determined for both curved vane (Figure 3.2) and flat blade designs. For a flat bladed design the vane angle, θ , is constant. Note that for curved vane swirlers the inlet blade angle is zero and the outlet angle is θ .

Before proceeding with the description of the design procedure for the curved and straight bladed swirlers it is important to note that previous calculations and burner design input should specify, for a given sized burner: the inner hub diameter, D_{hub} , the swirler outer diameter, D_{sw} , the primary air velocity to the swirler, $V_{primary}$, the maximum depth of the swirlers, and limits to the pressure drop across the swirler assembly. Flow design variables that can be changed include the downstream flow swirl number, S , and the desired type of tangential velocity profile (forced or free vortex). A summary description of the design procedure used for the curved and straight bladed swirlers follows.

A). Curved Bladed Swirlers

The procedure used to specify the geometry of primary air swirlers follows that of

FIGURE 3.2 SCHEMATIC OF SWIRL VANE GEOMETRY

Buckley, et al. (1983) that was developed for the design of practical swirlers for integral rockets/ ramjets. Desired tangential velocity distributions from the outlet of the swirler were either a free vortex or forced vortex flow (as shown schematically in Figure 3.3), and are specified by:

Forced vortex: $w = (\text{Constant}) r = (\tan \theta) u$

Free vortex: $w = (\text{Constant})/r = (\tan \theta) u$

where w = tangential velocity, u = axial velocity

For either of these cases, the constant terms can be evaluated for a given hub radius, R_1 , and swirler radius, R_2 , by using the following equation for the swirl number of the flow exiting the swirler, S :

$$S = \frac{\int_{R_1}^{R_2} u w r^2 dr}{R_2 \int_{R_1}^{R_2} u^2 r dr}$$

By relating the swirl number equation and the tangential velocity distributions above, a procedure was developed to describe the airflow turning angle as a function of radial position for both free and forced vortex swirlers.

Following a procedure similar to that used by Buckley, et al. (1983), the swirl vane geometry was designed based on a simplified method for determining the approximate blade angle required to achieve a given airflow turning angle, θ . This

FREE VORTEX

$$W = \frac{C_1}{r}$$

FORCED VORTEX

$$W = C_2 r$$

RANKINE VORTEX

$$W = \frac{C_3}{r} \left[1 \cdot \exp \left(-\frac{r^2}{r_0^2} \right) \right]$$

WHERE:

**W=TANGENTIAL VELOCITY
COMPONENT**

C₁, C₂, C₃=CONSTANTS

r=RADIAL COORDINATE

r₀=INITIAL r

FIGURE 3.3 SWIRLER FLOW TYPES

method was made possible via the use of Carter's rule which was based on the use of experimental data from two-dimensional cascades (Gostelow (1984), Johnsen and Bullock (1965)). Figure 3.4 presents a view of the curved swirl vanes at a given radial position, r , and defines the following variables:

θ = airflow turning angle

ϕ = blade turning angle

δ = deviation angle = $\phi - \theta$

γ = blade chord angle

R = radius of curvature

c = blade chord length

s = distance between blades

σ = solidity = $c/s = cN/\pi d$

N = number of blades

d = diameter at specified location

With the inner and outer radial positions known, the number of blades, N , and the radius of curvature can be initially specified. The chord length can be determined in an iterative fashion once the chord length, c , is calculated, the curved vane design is completely specified, however, due to pressure drop considerations or geometry restrictions on the total number of blades (such as blade overlap or the radius of curvature), the number of swirler blades, N , may have to be changed. Once this change occurred, the previous iterative calculational procedure for c was repeated until new values of c were obtained.

B) Straight Vane Swirlers

Under the design procedure development program for the straight vane type swirlers, designs for both free and forced vortex flows were to result.

Following Mathur and MacCallum (1967), the swirl number for a straight bladed axial flow swirler is given by

FIGURE 3.4 GEOMETRY OF SWIRL VANES

$$(2) (R_2^3 - R_1^3)$$

$$S = \left[\frac{(2) (R_2^3 - R_1^3)}{(3) (R_2^2 - R_1^2) R_2} \right] \tan \theta$$

In order to get either a forced or free vortex flow from the exit of the swirler, a multi-annular design, similar to the Multiannular Swirl Burner (MASB) design described by Beer and Vermes (1982) and Lew and Toof (1984) was used.

For this geometry, a design based on the use of 4 concentric annuli was chosen, subject to the following geometric constraints:

4.0 inch schedule 40 pipe hub (4.5 in O.D.)

Blade height = 1.1 in

16 gauge steel blades (0.0598 in thick)

In the MASB design of Beer and Vermes (1982), blade angles, θ , were varied from 20 to 70 degrees, thus for the 4 vane sections, we chose blade angles of 20, 40, 60, and 80 degrees. For the Forced vortex design, θ at the outer position should be the highest, and for the Free vortex design, θ at the inner position should be the highest.

7. Pressure Drop Considerations and Geometry Restrictions

In the previous section it was noted that the pressure drop characteristics of the curved blade axial flow swirler could change the design, especially the number of blades or limits on curvature, of such components. As summarized by Lefebvre (1983), it is possible to predict the pressure losses through axial swirlers using empirically based expressions, such as those presented by Kilik (1976) or Knight and Walker (1957). As pointed out by Martin (1987), these expressions, which can generally be written in terms of primary air flow velocity head losses or resistance coefficient, are very sensitive to very small changes in swirler geometry. For example, Kilik (1976) showed that for both flat and curved vane swirlers, a key parameter was the number of vanes (reflected in the value of the solidity or space to chord ratio of the swirler). He noted

that this parameter was especially important for curved vane swirlers due to the lower frictional loss associated with such designs. For this test program, it was decided that the pressure drop coefficients of the swirlers that were designed by the previous methodology would be experimentally determined. Further analytical work in this area would be of great benefit to generalizing the design procedures.

As previously noted, the swirler geometry, as reflected in the number of swirler blades or swirler solidity, can greatly influence the pressure drop characteristics of a particular swirler design. For example, a certain amount of blade overlap is necessary to force the airflow through the swirler blades, while excessive overlap will lead to high pressure drops. Thus, it was known that the blade overlap would be an important variable that should be checked after each potential swirler blade geometry calculation. Specifically, after each swirler blade geometry calculation, a sketch of the resulting swirler, using the assumed number of swirler blades, was checked for blade overlap. If there was insufficient overlap, then a new value of N , $N + 2$, was assumed and the calculations were repeated until a satisfactory blade overlapping geometry resulted. An opposite type of procedure was used if the initial geometry resulted in an excessively overlapping blade geometry situation, i. e., the number of blades was reduced to $N - 2$.

8. Establishment of Final Swirler Designs

The combination of the previously described swirler design procedure in combination with the noted pressure drop considerations and geometry restrictions, yielded 4 different designs for curved vane axial vane swirlers (2 free vortex and 2 forced vortex) and 2 different straight vaned swirlers (1 free vortex and 1 forced vortex) that were to be tested in the swirler test facility (STF). Examples of the three different types of test swirlers and the base case tangential inlet swirler are shown in Figure 3.5. The best two swirler designs, as determined by the STF testing, would be further characterized in the full scale burner cold flow model.

Curved Blade Free Vortex Swirler

Curved Blade Forced Vortex Swirler

Baseline Tangential Inlet Swirler

Multi-Annular Flat Blade Swirler

FIGURE 3.5 DIFFERENT SWIRLERS TESTED

3.1.2 Swirler Test Facility Program

In order to quantify the swirl generation performance and pressure drop characteristics of the various primary air swirler designs, this phase of the program involved the testing of the full-scale swirlers in a specially constructed swirler test facility (STF). This facility is similar to a smaller scale facility used by the International Flame Research Foundation (Leuckel, 1967). A schematic of the STF, which was described in detail in a previous paper (Rini, et al., 1987a) is given in Figure 3.6. The experimental output from this facility includes the swirl reactive torque produced by passing the primary air swirler exit flow through a flow straightener, and the pressure drop across the test swirler at a measured airflow.

As shown in Table 3.1, eight different swirlers, with four basic geometric designs were tested in the STF. The results from this test program, including the measured torque from the swirler, the swirler pressure drop (measured and projected to combustion conditions (500 °F inlet temperature)), and the ratio of the torque to the measured pressure drop are summarized in Table 3.2.

The results from this test program showed (see Table 3.3) that the Free Vortex - Swirler D generated an equivalent torque to the Tangential Entry Baseline Swirler (Configuration OB) with a 30% reduction in pressure drop. Or, at equivalent pressure drops, Free Vortex- Swirler D generated a greater torque than the Tangential Entry Baseline Swirler (Configuration OB). Both the Forced and Free Vortex Swirlers with a Swirl Number of 2.0 (Configurations A and C) had excessive projected pressure drops. Note also that the Forced Vortex- Swirler B generated substantially greater torque at a lower pressure loss than any other configuration. Also note that both the Flat Bladed Swirlers (Free and Forced Vortex) generated lower torque values than any of the other swirler configurations.

Based on these results, Swirlers B and D were chosen as the primary air swirler configurations for further testing in the cold flow burner model test program. This program is discussed next.

FIGURE 3.6 SCHEMATIC OF SWIRLER TEST FACILITY

<u>CONFIG.</u>	<u>BLADE GEOMETRY</u>	<u>VORTEX TYPE</u>	<u>SWIRL NO.</u>
OA	Tangential Entry	Forced	1.0
OB	Tangential Entry	Forced	2.0
A	Curved Blade	Forced	2.0
B	Curved Blade	Forced	1.0
C	Curved Blade	Free	2.0
D	Curved Blade	Free	1.0
E	Flat Blade	Forced	1.0
F	Flat Blade	Free	1.0

TABLE 3.1: SWIRLER TEST CONFIGURATIONS

<u>CONFIG.</u>	<u>$\Delta P_{\text{measured}}$</u> (in WC)	<u>$\Delta P_{\text{projected}}^*$</u> (in WC)	<u>Torque</u> (lb/in)	<u>Normalized</u> <u>$\text{Torque}/\Delta P_{\text{meas.}}$</u>
OA	1.9	3.8	10.2	1.3
OB	2.6	5.2	10.7	1.0
A	3.1	6.2	20.5	1.6
B	2.1	4.2	18.3	2.1
C	5.1	10.2	29.2	1.4
D	1.9	3.8	10.7	1.4
E	2.7	5.4	9.1	0.8
F	2.3	4.6	8.6	0.9

* Projected to an inlet air temperature of 500 °F

TABLE 3.2: SWIRLER TEST FACILITY DATA (CONSTANT MASS AIR FLOW)

3.1.3 Secondary Flow Geometry Design

An important concept used in the development of this burner is that of "internal staging" for NO_x control. This necessitates precise control of the primary/ secondary air flows and their rates of mixing. Another important feature of this design is the replacement of the high-maintenance refractory divergent nozzle or "quarl" of previous designs with alloy steel components. This device serves to aid flame stability by enhancing hot gas recirculation and as a staged air distributor to maintain the desired distribution of stoichiometries within the combustion zones.

The ability to provide both swirled and unswirled secondary air that was designed into the pilot-scale burner was also included in the demonstration-scale burner.

3.2 Cold Flow Burner Model Testing Program

Under this phase of the work, the design for the prototype HEACC cold flow model was based on the following design features:

- 1) The physical envelope of the HEACC (diameter and length) must be similar to a conventional oil burner envelope to facilitate retrofit.
- 2) Primary air fraction (PAF) flowing directly through the swirler was targeted for a value between 0.3 and 0.4 to minimize NO_x formation. With entrainment of other combustor air flow and furnace gases it would develop a primary zone stoichiometry (n_p) of 0.6 to 1.0.
- 3) Incorporation of a low pressure loss staged air distribution system for secondary air stream(s)
- 4) Utilization of the most efficient swirler designs for the primary air stream.

A schematic view of the initial version of the HEACC cold flow model is given in Figure 3.7 which shows the axially adjustable feature of the burner and secondary air assemblies. This feature allowed the burner geometry and resulting aerodynamic flow field to be varied in a systematic manner. A total of seven HEACC configurations were studied, along with a base case using Combustion Engineering's High-Swirl

TELESCOPED POSITION

BASELINE POSITION

FIGURE 3.7 PROTOTYPE HEACC COLD FLCW MODEL

Wall-Fired Burner (HSWF) for comparative purposes.

Anderson, et al. (1986) at Combustion Engineering have reviewed the use of isothermal or cold flow modeling techniques for the testing and development of major components in utility scale furnaces. For example, these cold flow modeling techniques were a major design tool in the development of a high-turndown coal-fired utility scale burner (Marion and Towle, 1985).

Therefore, based on this past work, two physical modeling approaches were used in the cold flow model testing program. The first approach produced qualitative data via flow visualization using yarn streamers and/or neutrally buoyant helium bubbles. This data was recorded using high resolution black and white photography. Such data was used to depict the overall flow pattern including areas of flow recirculation and areas of high turbulence. The second approach produced detailed quantitative aerodynamic flow data using a three dimensional pressure and velocity mapping system. This system uses a five hole pitot tube in conjunction with an automatic probe traversing device and associated data acquisition equipment. In general, the combination of data obtained from the flow visualization and the three dimensional velocity and pressure mapping was used to interpret the near field aerodynamics of the different burner configurations.

Using the basic HEACC configuration shown in Figure 3.7, seven different configurations were tested, along with one baseline HSWF burner. Due to excessive pressure drop in the burner assembly, the outermost secondary annulus (Ring C) was removed from the burner assembly during shakedown testing- all subsequent testing was with Ring C removed.. The tested configurations consisted of the following: (unless noted the Free Vortex Swirler "D" was installed)

Configuration 1- This was the baseline HEACC design. Rings A and B were aligned to form a smooth continuous cone inside the windbox.

Configuration 2 - Ring A and the swirler were withdrawn 4" into the burner windbox to form a deeper cone.

Configuration 3 - Ring A and the swirler were withdrawn 6" into the burner windbox to form a still deeper cone.

Configuration 4 - Ring A and B were aligned to form a smooth cone, with the entire burner assembly projected forward such that the front edge of Ring A was 2" forward of the windbox front plate.

Configuration 5 - The burner was arranged as Configuration 1, with the addition of a 60 psi compressed air jet used to simulate a fuel spray.

Configuration 6 - The 33% open area plate of Ring A was replaced with a 51% open area perforated plate.

Configuration 7 - The burner was arranged as Configuration 1, with the use of the Forced Vortex Swirler "B".

Configuration 8 - An existing model of the HSWF burner was used to obtain comparative flow field data.

Figure 3.8 presents a series of velocity profile information (Configuration 1) obtained from the detailed mapping procedure. Figure 3.8A shows the vertical plane velocity vectors issuing from the burner model. The magnitude and uniformity of direction of the flow in the center of the burner is indicative of strong swirl. As can be seen, some of this secondary air is entrained into the primary air as intended. Figure 3.8B shows the axial flow along the centerline of the burner. This flow is in the negative direction for the initial 22 inches. This indicates recirculating flow which is required for flame stability. The length of the recirculation zone will increase under hot (combustion) conditions. The flow fields were generally similar for all the tested HEACC configurations.

To summarize, the results of the cold flow testing program showed:

- 1) Removal of Ring C reduced the burner pressure drop to an acceptable level while maintaining the desired flow pattern.
- 2) The burner near field aerodynamics remained generally similar over the range of register adjustability.
- 3) The burner flow field was dominated by the swirler size and centrality.

FIGURE 3.8A VERTICAL PLANE (X - Y) VELOCITY VECTORS

FIGURE 3.8A AXIAL FLOW ALONG CENTERLINE OF BURNER

FIGURE 3.8 VELOCITY FLOW RESULTS- TYPICAL COLD FLOW MODEL TESTS

- 4) The Forced Vortex Swirler "B" produced a somewhat larger and stronger recirculation pattern than the Free Vortex Swirler "D". However, both the Forced Vortex Swirler and the Free Vortex Swirler demonstrated similar overall flow patterns.
- 5) The flow patterns generated appear sufficient to maintain flame stability and have the potential to minimize NO_x production via internal staging.

3.3 Burner Scale Up Criteria

3.3.1 General Scale Up Background

The objective of this subtask was to develop swirler/ burner design and scaling criteria based on information derived from the parametric testing of the proceeding work tasks. Under this task, the criteria was used to design a 5×10^6 Btu/ hr HEACC burner for pilot-scale testing, as well as to obtain a general understanding of scale up to a broad range of industrial sizes.

The scaling criteria developed under this subtask was based on the empirical information obtained under the previous cold flow modeling tasks as well as analytical procedures that have been developed by Combustion Engineering for general burner scaling (see Rini, et al., 1987b). Since the burner design was based on the use of swirling flows, additional burner scaling information is based on the work (primarily for heavy fuel oils) carried out by the International Flame Research Foundation (summarized by Lawn, 1987). Some of this work will be summarized in the following discussion.

As pointed out by Lawn (1987), one of the reasons for needing to understand flame processes is to be able to interpret the results of tests on small burners in terms of the likely performance of larger ones. This is generally accomplished via the use of "flame scaling" by which is meant the achievement of similarity in all the combustion processes in the scaled domain. In general, compromises are needed because the physical and chemical processes do not scale in the same way. Specifically, since it is

impossible to scale all the chemical kinetic rates to the same extent, the spatial distribution of the residence times must be similar and this can only be accomplished if all the velocities are scaled down by the linear scale factor. For atomized fuel firing, it is then necessary for the droplet size distribution to be maintained and for the heat transfer to the droplets to be similar. This will not be the case in practice, however, even if the temperature field were similar between the prototype and the scale model.

In general, burner manufacturers do not use this constant residence time approach when designing burners of different sizes. As noted in Lawn (1987), this occurs for a number of reasons. The most important is that the range of air velocities would lead to windbox pressures which would extend beyond the operating range of the conventional equipment. For the smaller burners, the windbox pressures would be lower than can be conventionally measured for control purposes; for the largest burners, the windbox pressures would be beyond the capabilities of conventional fan designs. There would also be a difficulty in adjusting the fuel spray momentum to match the air flow. Therefore, most heavy fuel-oil burners are designed on a constant velocity basis so that windbox pressures and fuel injection velocities are similar at all scales. The consequence is that flames on all sizes of burners tend to have the same length (because evaporation is rate limited), unless lower-throughput flames are deliberately shortened (for example, increasing swirl or decreasing droplet size).

In recent studies (Bortz, 1983), investigators have sought to develop analytical models capable of predicting the size and strength (defined as percent recirculated mass flow ratio) of a swirl burner's aerodynamic internal recirculation zone (IRZ). A large amount of their effort has centered on attempting to establish a solution of the equations of motion (derived from the Navier Stokes equations) for steady, inviscid cylindrical expanding flow in order to predict the diameter and strength of the IRZ. In addition, based on the results of isothermal burner modeling studies, they have identified a number of key swirler/burner parameters for defining IRZ diameter, length, and strength. These parameters include:

- 1) Axial flow Reynolds number
- 2) Swirl number in the burner throat
- 3) Diameter of the burner throat (initial vortex diameter)
- 4) Burner nozzle exit diameter (final vortex diameter)
- 5) Burner nozzle divergence angle

The HEACC scaling efforts were carried out with this type of background and previous C-E experience on the subject. In this respect, it was envisioned that the aspect ratio (length/diameter) and strength of the IRZ generated by the 50×10^6 Btu/hr isothermal model (as quantified in Task 1.3) would be replicated in the 5×10^6 Btu/hr burner design via appropriate scaling procedures.

3.3.2 Design of Pilot Scale Burner

In order to illustrate the scaling procedure, the details of the scaling calculations for the pilot scale burner follow:

Firing rate of combustor- 5×10^6 Btu/ hr

Burner airflow- 4,873 lb/ hr = 1.354 lb/ sec (Assumes 30% excess air, typical of CWF combustion requirements)

Primary air flowrate, m_p , equals 35% of stoichiometric flow rate =

$$(0.35)(1.354/ 1.3) \text{ lb/ sec} = 0.365 \text{ lb/ sec}$$

With a 2.00 in diameter hub and 4.75 in outer swirler diameter, the primary air free flow area, A_p , equals 14.6 in²

Therefore, the primary velocity, V_p , is found from

$$V_p = m_p / ((\rho_{air})(A_p)) = 0.365 (144) / ((0.0415)(14.6)) = 86.7 \text{ ft/ sec}$$

which fits within the design range of 80 to 100 ft/ sec.

For the secondary flow, a velocity, V_s , equal to 75- 100 ft/ sec is desired

The secondary mass flow, m_s , is equal to $1.354 - 0.365 = 0.99$ lb/ sec.

Assuming a screen with a blockage of 60% of the free area, and an outer annulus of 12 in diameter, the secondary area, A_s , is equal to 37.4 in².

V_s can be found from

$$V_s = m_s / ((\rho_{air})(A_s)) = 0.99 (144) / ((0.0415)(37.4)) = 91.8 \text{ ft/ sec}$$

which fits within the desired design velocity range.

The next step in the overall design process involves the design of the primary air swirler. The details of this process were discussed earlier, and include the following steps:

- 1) Establishment of Overall Combustion Requirements
- 2) Establishment of Range of Swirl Numbers Desired for Burner Assembly
- 3) Establishment of Combustion Mass Flow Requirements
- 4) Establishment of Overall Burner Dimension Envelope
- 5) Establishment of Primary and Secondary Air Velocities
- 6) Swirler Blade Design Procedure

For the pilot scale design, a target swirl number of 2 was selected. Based on previous work in earlier CWF studies (see Borio, et al., 1984) and due to the small scale of the system, a highly efficient, Y-jet style single hole CWF fuel nozzle was used. This twin fluid atomizer utilizes compressed air as an atomizing media. In establishing the overall burner physical envelope for the MIT facility, the dimensions of their fixed windbox arrangement had to be considered. Also, the pilot scale HEACC design had to take into account such important design parameters as available windbox air pressure and available CWF fuel pressure at MIT.

The pilot scale burner designed under this subtask was fabricated and extensively tested at MIT under Task 2. Details of this work are discussed in the next section.

4.0 SUMMARY OF TASK 2.0, PILOT SCALE COMBUSTION TESTS

4.1 General Overview

As summarized in the Task 2.0 Report of this project (Toqan, et al, 1989), the specific aims of this subtask, carried out at the Massachusetts Institute of Technology (MIT) were to characterize an experimental (Pilot scale) HEACC burner over a wide range of combustion conditions, with special emphasis on the topics of carbon conversion efficiency, NO_x and SO_x emissions, and flyash composition and particle size distribution.

In general, the research had both experimental and theoretical parts. However, for this project, major emphasis was placed on the experimental work. The experiments at MIT could be divided into two parts:

- 1) Combustion tests in the Combustion Research Facility (CRF)
- 2) Measurements in a Spray Test Facility (STF) designed to determine spray atomization quality

Descriptions of the CRF and STF along with the methodology of the experimental measurements are given in the Task 2.0 Report.

MIT's role as a subcontractor for Task 2.0 included the following:

- 1) Fabrication of a 5×10^6 Btu/hr pilot scale version of the HEACC burner (shown in Figure 4.1), and installation of the burner into the flame tunnel of the CRF.
- 2) "Fine tuning" of the burner with the combustion of No. 2 fuel oil.
- 3) A detailed experimental investigation into the combustion behavior of the HEACC using two types of coal-water fuels (CWF).

In the combustion experiments, the HEACC burner was attached to the front end of the combustion tunnel of the CRF. The 1.2 x 1.2 x 4.5 m test section was designed to permit the detailed investigation of industrial type turbulent diffusion flames by in-flame

FIGURE 4.1 PILOT SCALE HEACC

measurements and optical probing.

The main input variables of the combustion experiments included :

- 1) Fuel type
- 2) Burner parameters
- 3) Atomizer type and mode of operation
- 4) CWF fuel temperature
- 5) Combustion air staging level
- 6) Sulfur sorbent type

Two types of experiments were carried out in the CRF: parametric and detailed in-flame studies, with each involving different levels of measurements. For the parametric studies, properties of gaseous combustion products and the size distribution and chemical composition of the particulates carried by the gas stream were determined at the exit of the combustion chamber. For the detailed flame studies, in-flame measurements were made of velocity and temperature, gas composition, and sampling of solids species along the flame.

In the cold flow atomization study, the drop- size distributions of CWF sprays were determined by laser diffraction measurements for the effects of:

- 1) CWF dilution with water
- 2) Atomizing air to fuel mass flow ratio
- 3) Fuel temperature
- 4) Coal particle size

The important details of the CRF combustion tests and the atomization study are summarized in the following sections.

4.2 Combustion tests in the Combustion Research Facility (CRF)

4.2.1 Overall Worksopce

The worksopce of this task, using the CRF facility at MIT, consisted of two major tasks:

a burner optimization study and coal-water fuel combustion tests. A summary of the scope of these tasks follows:

Task 1. Burner Optimization Study

In these initial tests, combustion experiments with No. 2 fuel oil were carried out to define the optimum burner configuration for a stable oil flame with minimum NO_x emissions. The variables considered in these tests included:

- 1) Position of fuel nozzle relative to primary air swirler
- 2) Primary/ secondary combustion air flowrate ratio
- 3) Position of rings A, B, and C relative to primary air swirler
- 4) Swirl degree of the secondary combustion air

To simulate the combustion conditions that exist in practical CWF flames, the thermal input in these experiments was maintained at 1.5 MW, and the fuel spray was introduced into the combustion chamber using the 20° solid cone internally mixed OR-KVB Nozzle.

Task 2.0 Coal Water Fuel Combustion Tests

Task 2.1 Parametric CWF Combustion Tests

After the completion of the optimization tests using No. 2 fuel oil, it was evident that the optimum combustion conditions for No. 2 fuel oil were different from those expected for coal-water fuels (CWFs). Consequently, an optimization study of the burner relative to CWF combustion was carried out before the detailed CWF flame characterization experiments. For this purpose, two CWF fuels (Upper Elkhorn high volatile bituminous coal) were used: one fuel (fine grind) had a mean particle size (MMD) of about 21 microns while the other (ultra-fine grind) had an MMD of about 9 microns. The burner parameters varied in these tests included:

- 1) Primary/ secondary air ratio
- 2) Primary air swirl degree
- 3) Fuel atomizer position relative to primary air swirler

- 4) Position of rings A, B, and C relative to primary air swirler
- 5) CWF atomizer type.

Task 2.2 CWF Flame Characterization Experiments

After the conclusion of the parametric combustion study, an optimum burner configuration was chosen for the flame characterization experiments. The ultra-fine CWF which proved to have better combustion characteristics than the fine grind CWF was used. The fuel atomizer used was the internally mixed twin fluid spray nozzle supplied by Combustion Engineering, and the thermal input in these experiments was maintained at 5.0×10^6 Btu/hr (1.5 MW). Fuel temperature was varied from 68 to 239 °F (20 to 115 C), and flame characterization studies were carried out to determine if disruptive atomization could influence carbon burnout and NO_x emissions.

Task 2.2 Sulfur Capture

For this series of tests, six batches of the ultra-fine CWF premixed with three known quantities of calcium hydroxide or calcium acetate were burned in the CRF in an investigation of sulfur capture. The generated fuels were introduced via the HEACC burner into the combustion chamber, and gas and solid particle analyses of the combustion products were carried out.

Task 2.4 NO_x reduction

For this series of tests, two different methods of air/ fuel mixing for producing the fuel-rich and lean flame zones were tested: the internally staged flame technique vs. the externally staged system. In the first of these, both the fuel-rich and fuel-lean flame zones were formed aerodynamically by adjusting the secondary air supply. In the second, external staged system, staging of air was achieved by spatially separated combustion zones. The furnace zone near the burner was operated fuel-rich, and secondary (or overfire) air was then injected at some distance downstream in the combustion chamber to create a lean furnace zone for completion of combustion.

4.2.2 Experimental Results

Task 1. Burner Optimization Study

For this series of initial experimental tests, No. 2 fuel oil was burned and the composition of flue gas, in particular NO_x , was monitored as the burner parameters were varied. The purpose of the oil burning experiments was to permit the exploration of mixing in the near-field flame region as affected by the burner adjustments. It was not expected that these experiments would yield significant data that defined the optimum burner configuration when burning CWF, and therefore, the optimization studies were completed with a series of tests burning CWF.

Since the objective of this task was to determine the optimum burner configuration for staging the flame internally, the parameters varied were those that affected the aerodynamic mixing pattern of the fuel and the combustion air near the burner throat. Thus, the burner parameters that were varied included:

- 1) Position of fuel nozzle relative to primary air swirler
- 2) Primary/ secondary combustion air flowrate ratio
- 3) Position of rings A, B, and C relative to primary air swirler
- 4) Swirl degree of the secondary combustion air

It should be noted that by varying the secondary air distribution ring configuration, the mixing rates of the combustion air with the fuel and the aerodynamic mixing patterns change accordingly.

As described in detail in the Task 2.0 report, since the combination of these variables leads to a large number of burner configurations, several burner geometries thought to result in low NO_x emissions were chosen, and the concentration of NO_x in the flue gas was measured as the burner parameters were varied. During the initial experiments it was observed that the swirl degree of the secondary air did not influence NO_x emissions; therefore, in all of the experiments reported no swirl was imparted to the secondary combustion air.

Typical results for this series of tests are shown in Figure 4.2 (In this case showing the effect of burner configuration on NO_x emissions for a low primary/ secondary air ratio). In general, the results of the oil burning experiments showed that by varying the

CASE (1)
P/S AIR RATIO = 0.07

NO_x CONC. = 140 PPM

CASE (2)
P/S AIR RATIO = 0.07

NO_x CONC. = 125 PPM

CASE (3)
P/S AIR RATIO = 0.07

NO_x CONC. = 125 PPM

**FIGURE 4.2 EFFECT OF BURNER CONFIGURATION ON NO_x EMISSIONS
(LOW PRIMARY/ SECONDARY AIR RATIO)**

burner geometry through the adjustment of the positions of the primary air swirler, the atomizing nozzle, and the secondary air annuli in the HEACC burner, it is possible to influence the position of the flame front, the combustion length of the flame, and the emissions level of NO_x .

Task 2.0 Coal Water Fuel Combustion Tests

The combustion experiments with No. 2 fuel oil showed that highly stable flames could be obtained with the HEACC burner; however, it was expected that the configuration which was best for the oil would not necessarily be the optimal one for CWF combustion. Hence, a parametric study was carried out using CWF in which the combustion conditions were varied and, at the combustion tunnel exit, measurements were made of gas composition and flyash particle size distribution, composition, and extent of carbon burnout.

A) Combustion Variables/ Experimental Conditions

The major input parameters, and their variation for the test series, which were found to affect the characteristics of CWF flames included:

1) CWF atomization quality as affected by:

- A) Fuel Nozzle: OR-KVB vs. CE Swirl Jet
- B) Fuel temperature: 68-239 °F (20 - 115 °C)
- C) Coal mean particle size: 9 vs. 21 μm
- D) Atomizing air/fuel ratio: 0.10 to 0.30
- E) Fuel solids content: 55 to 65%

2) Combustion air staging as affected by:

- A) Primary/ secondary combustion air mass flow ratio: 0.22 - 0.43
- B) Secondary air swirl degree
- C) Fuel equivalence ratio of primary stage in a two stage system: rich vs. lean configuration

3) Sorbent injection and Ca/S ratio

- A) Calcium Acetate $[\text{Ca}(\text{C}_2\text{H}_3\text{O}_2)_2]$ vs. Calcium Hydroxide $[\text{Ca}(\text{OH})_2]$
at $0 < \text{Ca/S} < 2.1$

The three fuels used in the combustion experiments included the fine grind, the base

ultrafine grind, and the ultrafine grind CWF mixed with two types of sorbents. The experimental inputs maintained for each of these fuels were presented in the Task 2.0 report. Measurements of gas composition including O₂, CO, CO₂, NO_x, and SO_x were made in the flue gas. Solid samples were collected at the same location and analyzed for elemental composition and particle size distribution.

B) Summary of Experimental Results

1) Ignition and Flame Stability

A parameter which was found to significantly affect ignition and flame stability is the coal particle size. The flames studied using the HEACC system show that when the ultrafine CWF was used a stable flame was obtained even without fuel preheating. In the case of the fine grind CWF, however, a stable flame could not be obtained unless the fuel was preheated to secondary atomization levels (>212 °F (100 °C)). It was observed that even at that temperature the flame became unstable if the atomizing air/fuel mass ratio exceeds about 0.25.

Since the mean droplet size of the fine grind CWF was greater than 21 μm, it was considered that the large droplets pass through the internal recirculation zone in a time less than that required to evaporate the water and to ignite the coal agglomerates close to the fuel nozzle. Specifically, an unstable, lifted flame was observed for this case. As the fuel was heated above 100 °C, the fraction of the small droplets increased, and the flame was stabilized at the burner. On the other hand, the fraction of the small droplets for the ultrafine CWF (mean particle size about 9 μm) was high enough even for a fuel temperature of 72 °F (22 °C), to sustain a stable flame in the vicinity of the burner. The flame became unstable, however, if the atomizer air/fuel ratio was raised beyond a value of 0.25. CWF burners are typically operated at an air/fuel ratio of approximately 0.20.

2) Carbon Burnout

a) Effect of Atomization Quality Upon Carbon Burnout

The parameters which were found to influence atomization quality were:

Atomizer type.

An advantage of both the OR-KVB and the CE swirl atomizer designs is that the fuel spray pattern is a solid cone centered on the jet axis. The fuel is thus injected directly into the primary air swirl produced central recirculation zone reverse flow region where the drag forces acting on the fuel/particle droplets will be the greatest. While no difference was observed between the stability of flames produced by the OR-KVB and CE nozzles, as shown in Figure 4.3, the carbon conversion efficiency was better in the flames produced with the CE swirl jet nozzle. A possible reason for this is that the CE nozzle spray is finer despite the lower pressure drop of this nozzle on the atomizing air side.

Atomizing Air to Fuel Mass Flow Ratio

As will be discussed in the atomization testing section, it was shown that as the air/fuel ratio increased, the atomization quality of the ultrafine and fine grind CWFs improved. However, during the combustion tests it was found that if this ratio was increased beyond an optimum value, the carbon burnout level dropped or remained essentially constant (see Figure 4.4). Visual observations of these latter flames showed that they were unstable and two detached luminous regions could be seen. As the air/fuel ratio was further increased only the small luminous zone close to the atomizer remained, the larger luminous region moved downstream.

It could be inferred from these measurements and the visual observations, that for fully stable flames, the major fraction of the droplets do not have enough momentum to penetrate the reverse flow region and, hence, devolatilize and ignite in the upstream stagnation region of the central recirculation eddy. However, as the atomizing air flow is raised, an increasing fraction of the CWF droplets penetrate the internal recirculation zone and cause the formation of two flame fronts detached from one another, one sustained by the reverse flow region and the other developing downstream of the central recirculation zone. The latter blows out at higher air/fuel ratios.

Fineness of the Coal Particle Size Distribution

Closely related to atomization quality in impact on carbon burnout is the fineness of the coal particle size distribution used in the formulation of the coal water fuel. The lower limit to which particle droplet sizes can be reduced is a function of the coal

FIGURE 4.3 EFFECT OF ATOMIZER TYPE UPON CARBON BURNOUT

FIGURE 4.4 EFFECT OF ATOMIZING AIR/ FUEL RATIO ON CARBON BURNOUT

particle sizes, since these, in turn, set the lower limit for the size of the fuel flow nozzle and the thickness of the liquid sheet issuing from the nozzle exit port. Increasing coal fineness by its effect of raising the CWF viscosity may adversely influence the quality of atomization. Small dilution of the CWF by water may, however, help to reduce the fuel viscosity and permit full advantage to be gained by finer coal sizes. As shown in Figure 4.4, higher carbon burnouts were achieved with the ultrafine CWF.

Fuel Preheating Level

The experiments carried out using the HEACC system demonstrated that the preheating of the CWF improved flame stability and carbon burnout. For example, Figure 4.5 shows the carbon burnout along the axis of two 5×10^6 Btu/hr (1.5 MW) ultrafine grind CWF flames which differed only in the level of fuel preheat and the atomizing air/fuel ratio. It should also be noted that although high burnout levels were achieved in the unpreheated fuel flame, the atomizing air/fuel ratio required for this case was higher than the ratio maintained in the preheated fuel flame. This indicates that fuel preheating permits a relaxation of the pump pressure as well as the air/fuel ratio without a penalty in carbon conversion efficiency. However, the capital and energy cost to preheat the fuel must also be considered.

The effect of fuel preheating was even more dramatic for the fine grind CWF. When the fuel temperature was maintained at 68 °F (20 °C), a stable flame could not be sustained unless natural gas was injected coaxially with the fuel. As the fuel temperature was raised to 230 °F (110 °C), a stable flame was obtained without feeding gas. However, the carbon burnout achieved in this case (about 98%) was lower than that obtained using the ultrafine CWF (about 99.9%). These results clearly demonstrate the utilization of thermal atomization for improving CWF flame stability and combustion efficiency.

Dilution of CWF with Water

Past experiments of researchers at MIT have shown that adding small amounts of water to the base fuel can significantly reduce the viscosity and thus improve carbon burn-out via finer atomization. The experimental results shown in Figure 4.6, however,

FIGURE 4.5 CARBON BURNOUT PROFILE ALONG FURNACE CENTERLINE

FIGURE 4.6 EFFECT OF COAL CONTENT AND AIR/FUEL RATIO ON CARBON BURNOUT FOR THE FINE GRIND CWF

showed that, for this particular fuel, the combustion efficiency did not increase when the fuel was diluted.

Figure 4.6 shows that initially the carbon conversion efficiency improves with increasing atomizing air/fuel ratio. As the latter is raised, the carbon conversion efficiency drops for the three diluted fuels. Visual observations of the flame indicated that as the atomizing air/fuel ratio is raised from 0.10 to 0.15, better atomization quality results in increasing carbon burnout levels. However, as the atomizing air/fuel ratio increases beyond 0.15, the flame becomes unstable, thus allowing the carbon burnout levels to drop. In fact, the critical atomizing air/fuel ratio for an unstable flame is lower for the fuel containing 61% solids followed by that containing 62 and 62.5% respectively. It can be concluded that, for this particular fuel, despite the improved spray quality, the aerodynamic flow field next to the burner was the major factor which determines flame stability and the final carbon burnout level to be achieved.

b) Effect of Combustion Air Mixing on Carbon Burn-out

The effect of the mixing rate of the combustion air and fuel on carbon burnout levels was determined by varying the swirl degree (S) of the secondary combustion air, the burner configuration, and the primary/secondary air ratio (a_p/a_s). Since the primary combustion air is introduced through a fixed vane swirler, raising the a_p/a_s ratio increases the fraction of the combustion air that has a tangential velocity component and hence increases the total pressure drop through the burner.

For a fixed burner geometry, it was found that the carbon conversion efficiency increased slightly as S and a_p/a_s were increased. Maximum improvements in carbon burnout levels were obtained for a value of about 0.22 for a_p/a_s and 0.75 for S . No additional improvements were observed at higher values of S and a_p/a_s . As S and a_p/a_s are raised, the internal recirculation zone becomes more intense, and the time of flight of the fuel droplets through the internal recirculation zone increases thereby promoting early ignition and more complete burnout within the available combustion

space. However, as S and a_p/a_s are raised further, any additional benefit of increased turbulence in the recirculation zone diminishes as the fuel spray size distribution becomes the limiting factor in determining the final carbon conversion efficiency.

c) Effect of Sorbent Injection on Carbon Burn-out

Although the primary objective of introducing calcium hydroxide was to capture sulfur, its effect on carbon burnout was also examined. For this test, a fraction of the base ultrafine CWF was mixed with a known quantity of Ca(OH)_2 forty-eight hours prior to the experimental run. Ca(OH)_2 powder was first suspended in a water solution and then mixed slowly with the CWF. Consequently, the water content in the prepared batch was higher than in the base fuel (45 vs. 40%).

In the combustion tests the CE atomizer was used to spray the CWF prepared with the Ca(OH)_2 into the combustion chamber. As discussed later, the difference in the water content caused finer atomization of the sorbent containing fuel. The carbon conversion efficiency results of this experiment, as compared with and without fuel preheat are shown in Figure 4.7 and show that carbon burnout improved in the presence of the Ca(OH)_2 additive. Since the spray was finer with the increased water from the additive mixture, this could explain the carbon burn-out improvement. However, other research studies have shown that one of the elements that catalyzes char oxidization is calcium. Specifically, the work done by Mcollor, et al. (1988) showed that when calcium was ion exchanged in the char, it enhanced the char burning rates. Thus, the experimental observation indicates that the improved carbon conversion efficiency might be due both to the presence of calcium and the very fine atomization obtained with this fuel.

3) Flyash Particle Size Distribution and Composition

In CWF flames, several parameters, in particular, atomization quality and sorbent types, may influence the flyash size distribution and composition. In order to study how these variables might influence flyash, several samples were collected at the combustor exit and were analyzed for elemental composition and particle size

- (A) $\text{Ca}(\text{OH})_2$ -containing ultrafine CWF, $T_F = 111^\circ\text{C}$
 (B) Ultrafine CWF, $T_F = 111^\circ\text{C}$
 (C) Ultrafine CWF, $T_F = 22^\circ\text{C}$

FIGURE 4.7 CARBON BURNOUT LEVELS ALONG FLAME AXIS

distribution. Since the carbon content of all samples was less than 9%, the particle size distributions determined for these samples represent the true ash particle size.

a) Effect of Atomization Quality on Flyash Particle Size Distribution

In order to examine the effects of atomization quality on flyash particle size distribution (psd) and composition, samples of flyash were compared for flames in which the atomization quality was varied by raising the fuel temperature from 72 to 232 °F (22°C to 111°C). It was shown that preheating the fuel to 232 °F (111°C) caused the flyash psd to become finer in both single stage and two stage flames. The fraction of particles in the 0-2 µm size range increased while the number of 10 µm flyash particles decreased when the fuel temperature was raised from 72 to 232 °F (22°C to 111°C).

b) Effect of Combustion Air Staging upon Flyash Particle Size Distribution

The two major methods which proved to be effective in reducing NO_x and which also affect flyash composition and particle size distribution are internal and external "overfire air" flame staging. Due to the nature of these techniques, the local reducing conditions close to the burner can create conditions favorable for lowering the softening temperature of mineral inclusions, and increasing the likelihood of coalescence. To examine this, flyash samples obtained from two-stage flames were compared with those collected from single-staged ones. Figure 4.8 shows that the particle size distributions on a char free basis are coarser than in single-stage flames. The experimental observation indicates that fuel-rich conditions existing in the first stage are conducive to increasing the probability of mineral coalescence.

c) Effect of Sorbent Injection upon Flyash Particle Size Distribution

Under this work, sorbents were primarily mixed with the ultrafine CWF prior to combustion in order to capture the sulfur present in the coal. It was thought that the sorbents might act as binding agents for the mineral matter inclusions present within the burning char particles. To determine the extent of this problem, a study was conducted in which flyash samples were collected from flames of sorbent-containing CWFs and analyzed for composition and size distribution. The two sorbents used in these experiments were calcium hydroxide particles and calcium acetate, the latter of

FIGURE 4.8 EFFECT OF FUEL-RICH CONDITIONS ON FLY ASH PARTICLE SIZE DISTRIBUTION

which was atomically dispersed within the coal-water fuel droplets. The Ca/S ratio was varied from 0 to 2.10. The results from these experiments are shown in Figure 4.9.

For the atomically dispersed calcium, as the Ca/S is raised the number density of the 2 μm particles decreased in favor of the 7- 10 μm flyash particles. It appears that the calcium present either acts as a binding agent for the mineral matter inclusions or it adds to the individual inclusions, thus increasing their size. As for the calcium hydroxide sorbent, raising the Ca/S ratio causes an increase in both the 2 μm and the 7-10 μm particles. It is thought that since the mean diameter of Ca(OH)_2 particles is around 5 μm , the addition of such particles would increase the fraction of particles that have diameters ranging between 1 and 10 μm even if the calcium hydroxide particles do not coagulate with flyash.

3) NO_x Emissions

a) Effect of Atomization Quality upon NO_x Emissions

In this series of experiments, the effects of atomization quality on NO_x was investigated over a range of air/fuel ratios with varying atomizer and fuel condition properties. Figure 4.10 shows the effect of atomizer type on NO_x emissions (ultrafine grind), and Figure 4.11 shows the effect of water content (fine grind) on NO_x emissions. Also, another series of tests varying the fuel inlet temperature and measuring the NO_x along the flame axis was carried out.

For the ultrafine grind experiments, except for the small difference in NO_x emissions between the two different nozzles, it was observed that the adjustment of either the atomizing air/fuel ratio or fuel temperature did not have a significant effect on NO_x emissions (which were relatively high). In the case of the fine grind CWF (shown in Figure 4.11), however, when a stable flame front could be sustained close to the fuel

FIGURE 4.9 EFFECT OF MOLAR CA/S FEED RATIO ON FLY ASH PARTICLE SIZE DISTRIBUTION

FIGURE 4.10 EFFECT OF ATOMIZER TYPE ON NOX EMISSIONS

FIGURE 4.11 EFFECT OF CWF COAL CONTENT (FINE GRIND)
ON NOX EMISSIONS

nozzle, the NO_x concentration was relatively lower (~ 675 ppm). As the atomizing air/fuel ratio increased, the NO_x levels rose beyond 800 ppm. During these tests it was observed that, as the atomizing air/fuel ratio increased, the flame became highly unstable and as the value of the atomizing air/fuel ratio increased beyond 0.2, the flame front moved further downstream.

Examination of the combustion data indicated that if the aerodynamic conditions generated by the burner are capable of decelerating the fuel droplets in the vicinity of the internal recirculation zone, nitrogen evolution would primarily take place in the fuel-rich core of the flame. However, if the droplets start their flight with an internally high momentum, they would penetrate the fuel-rich internal recirculation zone and reach the fuel-lean zone on the flame where the fuel nitrogen would mainly convert to NO_x . Therefore, to achieve low NO_x , flame stability limits have to be determined first for the burner. It is within these stability limits that any additional reduction of NO_x emissions could be achieved by the adjustment of other variables, such as the staging of the combustion.

b) Effect of Combustion Air Staging on NO_x Emissions

The rate of mixing of the combustion air with the ultrafine grind CWF spray was varied by both internal and external flame staging. In the internal flame staging this was accomplished by the adjustment of both the primary/secondary air ratio and the secondary air swirl degree. In the external flame staging, this was achieved by introducing a fraction of the total air through the burner, and the rest was injected through tertiary air supply nozzles located about 5 ft (1.6 m) downstream of the burner.

The effect of internal flame staging on the NO_x emissions is shown in Figure 4.12. The swirl degree of the secondary air was seen to have a minor effect upon NO_x emissions; NO_x concentration increased by about 25 ppm with increasing swirl degree.

Figure 4.13 shows that as the primary/secondary air ratio was raised from 0.22 to 0.28,

FIGURE 4.12 EFFECT OF SWIRL DEGREE ON NOx EMISSIONS

FIGURE 4.13 EFFECT OF INTERNAL FLAME STAGING ON NOx EMISSIONS

the NO_x concentration increased approximately by 65 ppm. At ratios higher than 0.28, the NO_x emissions did not change significantly. The results of both experiments indicate that at low secondary air swirl degrees and low primary/secondary air ratios, fuel nitrogen, as it evolves from the devolatilizing coal agglomerates, is converted to molecular nitrogen due to the fuel-rich environment surrounding the fuel spray. As the internal staging is decreased, more oxygen becomes available for the fuel nitrogen in that region; and, hence, more NO_x is formed. At still higher ratios, it is thought that the rate of nitrogen evolution is slower than the rate of mixing of the fuel with the combustion air; hence, no changes in NO_x emissions could be observed when the primary/secondary air ratio or the swirl degree of the secondary combustion air are increased beyond a critical value.

For the external air staging, Figure 4.14 shows that, if fuel-rich conditions are maintained across the entire flame cross section by introducing some of the combustion air further downstream, a significant effect on NO_x occurs. As the fuel equivalence ratio, ϕ (inverse of stoichiometric ratio) of the primary stage increases from 0.81 to 1.4, NO_x emissions drop from 640 to 400 ppm. At $\phi = 1.65$, NO_x emission levels decrease to about 350 ppm, indicating that only a marginal benefit could be obtained by raising ϕ from 1.4 to 1.65. Hence, it can be concluded that the optimum equivalence ratio is between a value of 1.2 to 1.4. At these conditions, the fuel nitrogen evolves from the coal particles in an environment rich in hydrocarbon radicals essential to the reduction of HCN and NH_3 to N_2 .

c) Effect of Sorbent Injection upon Flyash Particle Size Distribution

As previously mentioned, the introduction of sorbent into the combustion chamber was done primarily to capture the sulfur present in the fuel. However, the effect the sulfur capturing method might have had on NO_x reduction was evaluated by measuring the NO_x emissions. After evaluating the data from the sorbent injection experiments it was concluded that the sulfur capture techniques do not have any effect on the efficiency of

FIGURE 4.14 EFFECT OF PRIMARY AIR EQUIVALENCE RATIO ON NOX EMISSIONS FOR EXTERNALLY STAGED FLAMES

conversion of fuel nitrogen to N_2 . As will be discussed next, however, the reducing conditions needed for the combustion of fuel nitrogen to N_2 might enhance the sulfur capture process.

4) SO_x Emissions

In pulverized coal or CWF fuel combustion fuel-sulfur is primarily converted to SO_2 . In contrast to NO_x , SO_x emissions cannot be controlled by manipulation of the combustion variables that influence NO_x emission levels. Therefore, sulfur-capture agents such as calcium oxide and calcium carbonate have been used to remove the sulfur from combustion gas mixtures. For this study, two types of agents were introduced with the fuel to capture sulfur from within the flame envelope; a water soluble calcium acetate and insoluble calcium hydroxide. Details of this in-flame sulfur capture mechanism were discussed in the Task 2.0 report.

The results of this series of experiments are shown in Figures 4.15 and 4.16. All of the investigated flames, except one, were generated by introducing all of the combustion air through the burner. In this test, 2/3 of the air was introduced through air nozzles located about 5 ft (1.6 m) downstream of the burner. Thus, the primary stage equivalence ratio in this case was 1.57, while the overall fuel equivalence ratio was maintained at 0.81, similar to the other flames. The results shown in Figure 4.15 indicate that the calcium acetate was more effective than calcium hydroxide in capturing the sulfur. Specifically, at a 1.8:1 Ca/S ratio, a sulfur capture of 72% resulted for the calcium acetate as compared to 48% for the calcium hydroxide. It is thought that the ability to disperse the calcium uniformly among the coal particles resulted in a higher sulfur removal efficiency.

As seen in Figure 4.16, the sulfur removed from the exit gas is captured by the flyash. The mass fraction of sulfur in the flyash samples collected in the calcium acetate case is much higher than that in the calcium hydroxide case. It should be pointed out that as the Ca/S ratio for the calcium hydroxide exceeds 2.0, the capture efficiency approaches a limit of 55-60%, thus reducing the $Ca(OH)_2$ utilization efficiency. On the

FIGURE 4.15 EFFECT OF SORBENT ON SULFUR CAPTURE

FIGURE 4.16 EFFECT OF CA/S RATIO ON SULFUR CONTENT OF FLYASH

other hand, it was observed that when the calcium is atomically dispersed, the asymptote could be at a much higher value of Ca/S ratio. These results show that calcium acetate is superior to calcium hydroxide in removing the sulfur from the combustion products gas mixture. It is thought that the removal efficiency for this sorbent would be much higher for coals that have higher sulfur contents than the 0.8% sulfur coal used in this program.

4.3 Measurements in the Spray Test Facility (STF)

In the atomization study, the drop-size distributions of CWF sprays were determined by laser diffraction measurements for the effects of atomizing air to fuel mass flow ratio and fuel temperature. All spray tests were carried out with a "solid cone" Combustion Engineering swirl jet atomizer.

The experimental results for the effect of air/fuel ratio on the spray droplet size (reflected by the mass mean diameter, MMD) are shown in Figure 4.17. As shown, these results show that as the air/fuel ratio increased, the atomization quality of the ultrafine and fine grind CWFs improved.

In order to measure the effects of fuel heating on atomization quality using the Malvern Particle Sizer (MPS), an effort was needed to find a reliable interpretation for the results (due to multiple scattering effects). In order to obtain a general idea of the shape of the distribution, all measurements were first analyzed with the MPS model independent technique. As the effects of multiple scattering can not be corrected when this technique is used, the distributions were expected to appear finer (smaller mean sizes) and broader (larger spread of sizes) than they actually were (Felton, et al., 1985). Nevertheless, it was believed that the overall shape of the distribution would not be seriously distorted.

Distributions obtained with the model independent technique were found always to be unimodal, and the log-normal distribution function fit the results reasonably well. The Rosin-Rammler distribution function was found to be less useful; the best-fit

FIGURE 4.17 EFFECT OF ATOMIZING AIR/FUEL RATIO ON CWF ATOMIZATION QUALITY

Rosin-Rammler distribution always underestimated the fraction of large droplets in the spray. This observation is somewhat surprising, since the Rosin-Rammler distribution has been widely used in spray studies. However, a similar conclusion was reached by Meyer and Chigier (1985) in their study of CWF sprays. It was speculated that the Rosin-Rammler distribution function is perhaps more appropriate when low viscosity liquids are sprayed and good atomization is easily achieved, than when high viscosity slurries are sprayed and poorer atomization is expected.

As the droplet size distribution seemed to obey the log-normal distribution function, the measurements were reanalyzed with the MPS log-normal model and the equations of Felton, et al. (1985) were used to calculate the corrections for multiple scattering. These results probably give the best quantitative basis for comparisons of spray droplet sizes under different atomization conditions.

Spray droplet size distributions at two different fuel temperatures obtained with the MPS model independent technique are shown in Figure 4.18. The MPS log-normal analysis with multiple scattering corrections resulted in a volume mean diameter of 40.7 microns for fuel temperatures of 72 °F (22 °C) and a volume mean diameter of 36.3 microns for a fuel temperature of 240 °F (116 °C). In both cases, the logarithmic standard deviation of the distribution was found to be 2.0. It was concluded, therefore, that fuel heating clearly improved atomization, and corresponding improvements in flame quality were to be expected.

Another result from this series of tests is given in Figure 4.19. In addition to the temperature effects on particle size, these results show that the spray was finer in the CWF doped with the additive probably because of the increased water content of the mixture.

4.4 Summary/ Conclusions

The initial combustion tests of the burner optimization study (burning No. 2 fuel oil) showed that, by varying the burner geometry, it was possible to sensitively influence

FIGURE 4.18 DROP SIZE DISTRIBUTIONS IN THE FUEL SPRAY

FIGURE 4.19 EFFECT OF TEMPERATURE ON ATOMIZATION QUALITY

the position of the flame front, combustion length of the flame, and the NO_x emissions. The burner geometry changes are effected by adjustment of the axial positions of the atomizing nozzle, the primary swirler, and the secondary air annuli. An unexpected finding from these preliminary tests was the very low NO_x emissions (about 125 ppm) obtainable with the HEACC when burning No. 2 oil.

The CWF experimental tests proved that:

1) The burner is capable of stable operation, with high carbon conversion efficiency ($\eta_c > 99\%$) and moderate NO_x emissions. Without overfire air the measured NO_x was in the range 600-700 ppm; with overfire air, the NO_x emissions were reduced about 350 ppm.

2) As in previous CWF combustion studies, atomization quality was shown to be of critical importance. Fuel pre-heating to improve the spray quality by achieving disruptive atomization proved to be beneficial, both for better flame stability and for more rapid carbon burnout. Specifically:

a) When the "ultrafine" CWF was heated to 241 °F (116 °C) upstream of the atomizer nozzle, a very fine flyash particle size distribution, close to that of the individual mineral inclusions, was obtained. This flyash was virtually carbon-free. The same treatment for the "fine-grind" CWF also led to excellent flame conditions, but the presence of traces of unburned carbon in the flyash contributed to a slightly coarser particle size distribution.

b) A significant potential for the use of water dispersible sulfur sorbents was observed; the sulfur capture efficiency with calcium acetate addition to the CWF was high (71% sulfur capture at $\text{Ca/S} = 1.8$) and sulfur capture with Ca(OH)_2 addition was satisfactory (50% sulfur capture at $\text{Ca/S} = 2.1$). It appears that having a sorbent in close proximity to the coal particles while these are undergoing pyrolysis in a fuel-rich flame zone enhances the sulfur capture efficiency.

In summary, it was the general conclusion at the end of this phase of the work that the

HEACC design has potential for becoming a high efficiency, clean combustion device. The results of the Pilot-Scale testing at MIT were integrated into the design of the Demonstration Scale (50×10^6 Btu/hr) HEACC. The results of the Demonstration Scale tests are described in the next section of this report.

5.0 SUMMARY OF TASK 3.0. DEMONSTRATION SCALE TESTING

Under this part of the program, the burner system based on the Task 1.0 and 2.0 results was designed and fabricated at a scale of 50×10^6 Btu/hr and installed in the Industrial- Scale Burner Facility (ISBF). Details of this facility are given in the Task 3.0 Report (Rini, et al., 1989b)

A schematic of the HEACC burner that was installed in this facility is shown in Figure 5.1. This burner incorporates the following design features:

- 1) Measured and controllable primary airflow.
- 2) Coaxial construction with 2 axially adjustable secondary air rings.
- 3) Distributed secondary air via perforated plate.
- 4) Adjustable direction tertiary air swirler.
- 5) Non-refractory burner exit nozzle (quarl).
- 6) Ability to install either a CWF gun or pulverized coal nozzle without burner modification.
- 7) Burner envelope to match a standard oil burner opening.

The HEACC was constructed under Combustion Engineering's supervision and is shown in Figures 5.2 and 5.3 just prior to installation in the test facility. Figure 5.4 shows the burner installation with a CWF gun in place. The primary air venturi tube is located in the insulated duct on the right side of the photograph.

A key component of the combustor was the primary air swirler developed under the work of Task 1.0. Two groups of swirlers were developed each producing a different vortex, either free or forced vortex types. The free vortex type is characterized by a maximum velocity at the swirler hub and the forced vortex is characterized by a maximum velocity at the outer diameter of the swirler. As reported in the Task 1.0 work, the most efficient examples of each type were determined, and then selected for the Task 3.0 work.

FIGURE 5.1 SCHEMATIC OF HEACC DEMONSTRATION-SCALE BURNER

FIGURE 5.2, FIGURE 5.3 HEACC PRIOR TO INSTALLATION IN TEST FACILITY

FIGURE 5.4 HFACC BURNER INSTALLATION WITH CWF GUN IN PLACE

For the series of combustion experiments carried out under this phase of the work, both CWF and pulverized coal fuels were used. In order to provide directly comparable data, the same coal was used for producing the coal-water fuels and the pulverized coals. Specifically, the coal used for both forms of the fuel supply was an Elkhorn Seam (Westmoreland Coal Co.) provided via Energy International. This coal had an inherently low ash level, and, with washing, exhibited 2 to 3% ash. A summary of the characteristics of these fuels was given in Section 2.0 of this report.

The following three types of coal-water fuels were used:

- 1) Fine grind CWF
- 2) Ultrafine CWF
- 3) CWF containing sorbent

For the pulverized coal portion of the tests, the Elkhorn Seam coal was pulverized to a MMD of 21 microns in a standard Combustion Engineering bowl mill.

Under this phase of the work, two separate series of experiments using CWF and pulverized coal fuels were carried out. A summary of the work performed under these tasks follows.

5.1 CWF Firing

5.1.1 Scope of Experimental Tests

Under the original scope of the experimental test program, three combustion test matrices were planned for the CWF portion of the HEACC Demonstration Scale tests. The objective of this program was to systematically optimize and document the combustion performance of the HEACC (using CWF fuels). As shown in Table 5.1, in Matrix 1, an evaluation of the performance of four different atomizer configurations was planned. This approach was used to determine the best atomizer for further testing.

TEST MATRIX 1- PARAMETRIC TEST MATRIX

OBJECTIVE: DETERMINE THE PERFORMANCE OF THE FOUR ATOMIZER DESIGNS SELECTED FOR TESTING AGAINST TWO DIFFERENT SWIRLER DESIGNS

ATOMIZERS:

- a) 7 - 7 MBtu cells, 25° Spray angle
- b) 7 - 7 MBtu cells, 45° Spray angle
- c) 8 - 7 MBtu cells, 4 on 55° Spray angle
4 on 30° Spray angle
- d) 10 cells: 5 - 3.5 MBtu cells on 50° Spray angle
5 - 7 MBtu cells on 30° Spray angle

SWIRLERS:

- a) Forced Vortex
- b) Free Vortex

COMBUSTION AIR TEMPERATURE- 500 °F

<u>% LOAD</u>	<u>% EXCESS AIR</u>	<u>PRIMARY AIR</u> (% Stoichiometric)	<u>ATOMIZER</u>	<u>SWIRLER</u>
100	25	35	a	Forced
100	25	35	b	Forced
100	25	35	c	Forced
100	25	35	d	Forced
100	25	35	a	Free
100	25	35	b	Free
100	25	35	c	Free
100	25	35	d	Free

TABLE 5.1 TEST MATRIX NO. 1

The four styles of atomizers were variations of Combustion Engineering's commercial CWF multi-cell atomizer. A review of the development work on this type of atomizer design is given in the Task 3.0 Project Report. The four variations of the CWF atomizer that were tested during the course of this program were:

- a) 7 - 7 MBtu cells, 25° Spray angle
- b) 7 - 7 MBtu cells, 45° Spray angle
- c) 8 - 7 MBtu cells: 4 on 55° Spray angle
4 on 30° Spray angle
- d) 10 cells: 5 - 3.5 MBtu cells on 50° Spray angle
5 - 7 MBtu cells on 30° Spray angle

Atomizers a and b feature a constant spray angle designed to match the burner's aerodynamic flow field. Atomizers c and d feature dual spray angles in an attempt to generate a highly fuel-rich primary zone.

Each of the atomizers was fired independently in combination with the two best free and forced vortex swirlers developed in Task 1. Based on the results of these tests (Matrix 1), a best atomizer configuration and swirler type were chosen for a detailed burner performance characterization series (Matrix 2). This matrix, as shown in Table 5.2, included testing over the full load range, total excess air variation, and three levels of primary air flow. While the HEACC was designed as an internally staged burner, this test matrix evaluated the use of physically separated staged air for NO_x control.

In Matrix 3 (given in Table 5.3) the use of an in-fuel sorbent for SO₂ control was addressed. This series of tests was conducted using two sorbents, hydrated lime (calcium hydroxide) and calcium acetate. Also, Matrix 3 was conducted using optimized burner settings as determined in Matrix 2.

TEST MATRIX 2- BURNER PERFORMANCE CHARACTERIZATION

(Combustion Air Temperature - 500 °F)

NO.	%LOAD	<u>EXCESS</u>	<u>PRIMARY</u>	<u>ATOMIZER</u>	<u>SWIRLER</u>	<u>GAS</u>	<u>FOT</u>	<u>HEAT</u>	<u>STAGING</u>
		<u>AIR. %</u>	<u>AIR</u>			<u>ANALYSIS</u>		<u>FLUX</u>	
1	100	30	A	OPT	OPT	YES	YES	YES	NO
2	100	20	A	OPT	OPT	YES	YES	YES	NO
3	100	MIN	A	OPT	OPT	YES	YES	YES	NO
4	100	20	B	OPT	OPT	YES	YES	YES	NO
5	100	20	C	OPT	OPT	YES	YES	YES	NO
6	50	OPT	D	OPT	OPT	YES	YES	YES	NO
7	50	OPT	D	OPT	OPT	YES	YES	YES	NO
8	50	OPT	E	OPT	OPT	YES	YES	YES	NO
9	50	OPT	E	OPT	OPT	YES	YES	YES	NO
10	MIN	OPT	F	OPT	OPT	YES	YES	YES	NO
11	MIN	OPT	F	OPT	OPT	YES	YES	YES	NO
12	100	30	OPT	OPT	OPT	YES	YES	YES	YES-G
13	100	20	OPT	OPT	OPT	YES	YES	YES	YES-G
14	100	MIN	OPT	OPT	OPT	YES	YES	YES	YES-G
15	100	30	OPT	OPT	OPT	YES	YES	YES	YES-H
16	100	20	OPT	OPT	OPT	YES	YES	YES	YES-H
17	100	MIN	OPT	OPT	OPT	YES	YES	YES	YES-H

A = Design Primary Air

B = Design Primary Air + 10%

C = Design Primary Air - 10%

D,E,F = To be Determined

G = Staging Configuration 1

H = Staging Configuration 2

TABLE 5.2 TEST MATRIX NO. 2

TEST MATRIX 3- OPTIMUM BURNER PERFORMANCE WITH SORBENT INJECTION

(Combustion Air Temperature - 500 °F)

<u>NO.</u>	<u>%LOAD</u>	<u>EXCESS</u>	<u>PRIMARY</u>	<u>ATOMIZER</u>	<u>SWIRLER</u>	<u>GAS</u>		<u>SORBENT</u>
		<u>AIR.%</u>	<u>AIR</u>			<u>ANALYSIS</u>	<u>STAGING</u>	<u>(Ca/S)</u>
1	100	OPT	OPT	OPT	OPT	YES	NO	A (1/1)
2	100	OPT	OPT	OPT	OPT	YES	NO	A (2/1)
3	100	OPT	OPT	OPT	OPT	YES	NO	A (3/1)
4	100	OPT	OPT	OPT	OPT	YES	YES	A (1/1)
5	100	OPT	OPT	OPT	OPT	YES	YES	A (2/1)
6	100	OPT	OPT	OPT	OPT	YES	YES	A (3/1)
7	100	OPT	OPT	OPT	OPT	YES	NO	B (1/1)
8	100	OPT	OPT	OPT	OPT	YES	NO	B (1.5/1)
9	100	OPT	OPT	OPT	OPT	YES	NO	B (2/1)
10	100	OPT	OPT	OPT	OPT	YES	YES	B (1/1)
11	100	OPT	OPT	OPT	OPT	YES	YES	B (1.5/1)
12	100	OPT	OPT	OPT	OPT	YES	YES	B (2/1)

A = Calcium Hydroxide

B = Calcium Acetate

TABLE 5.3 TEST MATRIX NO. 3

5.1.2 Detailed Experimental Results

The combustion tests were conducted in two major series: Expanded Matrix 1 tests were used to evaluate four different configurations of the C-E CWF atomizer, and a variety of operating conditions were tested to optimize the HEACC's performance. Next, a series of matrix tests (following Matrix 2 and 3) were conducted to document the burner's performance in a systematic manner.

During the Matrix 1 testing, based on previous experience with other CWF fuels, it became evident that the additive package contained in the CWF was exerting a strong influence over the combustion test results. Specifically, as detailed in the Task 3.0 Report, it was determined that the stabilizer material greatly affected the fuel spray's breakup into the fine droplets required for high combustion efficiency.

An overview of the total test series is given in Table 5.4. Test Numbers 1 to 38 are the Prematrix 1 tests, during which several variations of CWF formulation were combusted. It is important to note that much valuable and useful data was generated during the course of this testing. The Matrix Tests 2 and 3 are numbered Tests 39 to 63. Based on the screening work of Tests 1 to 38, a fine grind (21 micron MMD) CWF of commercially viable stability was prepared and utilized for these tests.

A complete summary of the test input conditions, including atomizer and swirler types, for Test Numbers 1 to 65 was presented in the Task 3.0 Report. A summary of the test results is given in Table 5.5. In addition to the emissions of NO_x , SO_2 , and CO , this table includes the actual excess air used for each test, the carbon conversion efficiency, and the primary air fraction, PAF. PAF is defined as the measured air flow ducted through the primary swirler divided by the measured total air flow. The PAF parameter is similar to the parameter η_p (primary zone stoichiometry) discussed in the Task 1 report and is intended to serve as a measure of the primary zone fuel to air ratio. As will be discussed, this is an important parameter influencing both NO_x and carbon conversion efficiency levels.

TEST NOS.	DATES	DESCRIPTION OF TEST	% SOLIDS
1 - 8A	6/21-22/88	Fine Grind	63.8
9 - 13A	6/24/88	Fine Grid Unstabilized	63.8
14	6/24/88	Baseline Fuel- Cool Fuel Test	63.8
15 - 19	6/27/88	Baseline Ultrafine	60.5
20	6/27/88	Diluted Ultrafine	59.1
21 - 27	6/28/88	Slightly Stabilized Fine Grind	62.4
28 - 34	6/28-29/88	20% Regular Grind/ 80% Ultrafine	59.6
35	6/29/88	New Process- Fine Grind	63.8
36 - 38	6/29/88	Unstabilized Ultrafine	58.2
39 - 41	7/11-13/88	Fine Grind, 8-cell, Forced Vortex, Baseline Conditions	65.2
42 - 44	7/13/88	Fine Grind, 8-cell, Free Vortex	65.2
45 - 48	7/13/88	Fine Grind, 25°, Free Vortex	65.2
49 - 51	7/13/88	Fine Grind, 2" Primary ΔP , 8 cell, Forced Vortex	65.2
52	7/13/88	Fine Grind, 3.6" Primary ΔP , 8 cell, Forced Vortex	65.2
53	7/13/88	Fine Grind, 0.45" Primary ΔP , 8 cell, Forced Vortex	65.2
54 - 55	7/13/88	Fine Grind, External Staging, 0.45" Primary ΔP , 8 cell, Forced Vortex	65.2
56	7/13/88	Fine Grind, External Staging, 4.3" Primary ΔP , 8 cell, Forced Vortex	65.2
57	7/13/88	Fine Grind, 50% Load, 8 cell, Forced Vortex	65.2
58	7/14/88	Fine Grind, Calcium Acetate Inj., 1.2" Primary ΔP , 8 cell, Forced Vortex	59.2
59	7/14/88	Fine Grind, Calcium Acetate Inj., 1.2" Primary ΔP , 8 cell, Forced Vortex	63.5
60	7/14/88	Fine Grind, Calcium Acetate Inj., 1.2" Primary ΔP , 8 cell, Forced Vortex	63.9
61	7/14/88	Fine Grind, Calcium Acetate Inj., 2" Primary ΔP , 8 cell, Forced Vortex	61.8
62 - 63	7/14/88	Fine Grind, Calcium Hyd. Inj., 1.2" Primary ΔP , 8 cell, Forced Vortex	63.2
64 - 65	7/14/88	Fine Grind, 2.0" Primary ΔP , 8 cell, Forced Vortex	63.2

TABLE 5.4 OVERVIEW SUMMARY OF CWF TESTS

TEST	EMISSIONS CORRECTED TO 3% O2, PPM			% EXCESS AIR	% CARBON CONVERSION	PAF
	NOX	SO2	CO			
1	719	*	54	25.7	95.0	0.36
2	734	*	54	25.0	93.2	0.37
3	666	*	62	23.1	94.3	0.34
4	737	*	65	22.4	93.6	0.33
5	781	*	64	22.4	95.2	0.35
6	737	*	77	23.8	86.7	0.35
7	755	*	74	21.7	90.5	0.32
8	699	*	75	22.6	86.8	0.34
8A	693	*	80	22.6	86.9	0.35
9	672	*	61	28.7	99.9	0.37
10	604	*	52	34.0	98.3	0.34
11	525	*	56	33.6	97.2	0.25
12	470	*	62	27.9	96.6	0.18
13	423	*	71	22.9	93.6	0.12
14	714	*	95	35.6	92.2	0.34
15	704	*	79	46.5	99.4	0.33
16	717	*	74	30.7	99.3	0.34
17	754	272	56	29.3	97.7	0.48
18	745	278	73	32.4	98.0	0.50
19	696	254	49	34.0	95.8	0.50
20	695	262	41	33.9	97.0	0.50
21	712	278	44	26.6	93.6	0.36
22	605	342	68	25.8	93.6	0.25
23	627	368	101	25.1	96.0	0.21
24	743	324	121	29.4	94.0	0.36
25	715	323	125	34.0	93.4	0.33
26	715	323	127	34.4	93.7	0.25
27	773	320	88	34.2	92.7	0.44
28	650	317	164	31.3	94.0	0.32
29	725	313	127	33.3	94.7	0.43
30	716	304	83	42.8	95.6	0.43
31	700	296	92	41.2	90.6	0.46
32	722	296	63	36.1	89.3	0.56
33	626	326	125	32.6	95.2	0.42
34	476	333	48	24.1	96.9	0.14
35	658	332	56	33.7	96.9	0.32
36	472	342	62	22.8	95.3	0.07
37	664	322	36	31.5	99.9	0.32
38	689	319	35	33.4	99.9	0.41
39	816	363	51	17.1	92.1	0.48
40	734	370	50	18.9	91.4	0.36
41	743	358	54	27.7	93.7	0.35
42	735	*	52	20.4	96.9	0.44
43	732	*	61	18.0	95.0	0.34
44	740	*	50	27.5	96.6	0.33
45	509	*	58	22.4	94.2	0.40
46	521	*	56	33.4	94.9	0.41
47	496	*	52	33.7	97.4	0.12
48	494	*	53	21.3	97.0	0.15
49	577	268	41	33.8	97.4	0.34
50	552	295	48	24.5	94.9	0.33

TABLE 5.5 SUMMARY OF CWF TEST RESULTS

(* Analyzer not Functioning)

TEST	EMISSIONS CORRECTED TO 3% O ₂ , PPM			% EXCESS AIR	% CARBON CONVERSION	PAF
	NOX	SO ₂	CO			
51	586	295	47	18.6	94.5	0.33
52	749	287	32	22.2	96.0	0.44
53	437	293	48	20.9	94.7	0.15
54	708	285	39	23.8	96.7	0.16
55	736	292	42	22.7	97.2	0.15
56	695	292	48	24.3	97.1	0.48
57	444	236	13	80.1	99.9	0.80
58	767	215	24	18.9	96.7	0.21
59	745	222	28	24.1	99.9	0.22
60	648	278	31	20.1	96.6	0.23
61	729	252	26	26.5	99.9	0.27
62	728	239	2	25.9	99.9	0.23
63	537	258	0	25.7	99.3	0.24
64	600	313	26	26.0	99.9	0.33
65	611	303	20	40.5	99.9	0.34

TABLE 5.5 (CONTINUED) SUMMARY OF CWF TEST RESULTS

A summary of the individual experimental tests using the CWF fuel follows. It should be noted that since low NO_x emissions was a key goal, a decision was made to run at relatively low excess air conditions to minimize NO_x emissions. In many cases, this resulted in lower than otherwise achievable carbon conversion efficiencies. Later in the test series it was demonstrated that the HEACC was fully capable of achieving high combustion efficiencies at excess air levels more typical of CWF combustion.

1) Matrix 1 Tests

The first tests (Test Numbers 1- 8A), using the fine grind CWF, were carried out to evaluate the 4 candidate nozzle types that were previously described . On the basis of these tests, the 25 degree and 8 cell atomizers were selected for further testing.

A concern over the relatively low carbon conversion efficiency observed in Test Numbers 1 to 8 lead to the decision to test a batch of unstabilized fine grind CWF in order to determine if the stabilizer package was responsible for the low carbon conversion efficiency. The results of this series of tests showing the carbon conversion efficiency as a function of excess air for different primary air fraction (PAF) ratios are summarized in Figure 5.5. For this relatively narrow range of excess air levels, the carbon conversion efficiency was acceptably high (97.3 to 99.9%) for values of PAF between 0.25 and 0.35. The carbon conversion efficiency fell off sharply as the PAF and excess air were decreased. As shown in Figures 5.6 and 5.7 where NO_x emissions are given as a function of excess air or PAF, the NO_x emissions were relatively high. As shown in Figure 5.7, the lower PAF ratios between 0.18 and 0.25 lowered the NO_x emissions to 470 to 525 ppm, but also resulted in lower carbon conversion efficiencies of 96.6 to 97.2% (See Figure 5.5). Furthermore, a PAF value of 0.12 lowered NO_x emissions to 423 ppm, however, carbon conversion efficiency was reduced significantly to 93.6%.

These tests did show that at PAFs comparable to those used in Tests 1 to 8 (PAF = 0.32- 0.37) the unstabilized CWF produced improved carbon conversion efficiency

FIGURE 5.5

FIGURE 5.6

**NO_x EMISSIONS VS PAF - 8 CELL ATOMIZER,
FORCED VORTEX SWIRLER (TEST POINTS 9-13)
UNSTABILIZED FINE GRIND**

FIGURE 5.7

(98.3 to 99.9% vs 94.3%) thus demonstrating the adverse effect of the stabilizer. Further tests were carried out to define an acceptable level of stabilizer to meet both storage and atomization requirements.

For the testing sequence consisting of Test Numbers 15 to 19, ultrafine CWF fuel was used with PAF values ranging from 0.33 to 0.50. Figure 5.8 presents the results of these tests showing the carbon conversion efficiency as a function of PAF. These results showed that the carbon conversion efficiency decreases as the PAF ratio was increased beyond the design value of 0.35. These results suggested that too much air was allowed into the primary zone, decreasing flame zone temperature, thus resulting in low carbon conversion. The effect of varying PAF on the NO_x emissions is shown in Figure 5.9. The values of NO_x emissions were still high and, with the exception of the data point at the highest value of PAF, the results follow an expected trend of decreasing NO_x with decreasing PAF.

The next series of tests (Test Numbers 20 to 27) were carried out with fine grind CWF containing a moderate amount of stabilizer. Results of this series of experiments showing carbon conversion efficiency as a function of the primary air fraction, PAF, are given in Figures 5.10 (25 degree atomizer tip) and 5.11 (8 cell atomizer tip). As can be seen, the carbon conversion efficiency was low, and the values of NO_x emissions that were measured were still high. This demonstrated the influence that the CWF additive package was exerting on the combustibility of the fuel.

Figure 5.12 presents a comparison of the carbon conversion efficiency of this series of tests using the moderately stabilized fine grind with the previous results obtained for the unstabilized fine grind CWF fuel (for a PAF value of approximately 0.35). The relatively low values for carbon conversion efficiency again shows the negative impact of the additive package used in the stabilized CWF.

For the next series of tests, Test Numbers 28 to 34, it was theorized that a mixture of a 20% fine grind CWF with an 80% ultrafine CWF fuel would provide larger particles to

FIGURE 5.8

FIGURE 5.9

**CARBON CONVERSION VS PRIMARY AIR FRACTION
25° TIP, FORCED VORTEX SWIRLER, ~ 25% EXCESS AIR
SLIGHTLY STABILIZED FINE GRIND (TEST POINTS 21-23)**

FIGURE 5.10

**CARBON CONVERSION VS PRIMARY AIR FRACTION
8 CELL TIP, FORCED VORTEX SWIRLER, ~ 35% EXCESS AIR
SLIGHTLY STABILIZED FINE GRIND (TEST POINTS 24-27)**

FIGURE 5.11

FIGURE 5.12

aid in the breakup of atomization ligaments, thus providing better atomization and improving combustion. A summary of the carbon conversion efficiency vs excess air for this series of tests in comparison with previous results using the baseline ultrafine CWF fuel (Test Numbers 16 - 19) is given in Figure 5.13. As can be seen, the mixing of the CWF fuels did not provide the means for the improvement of the carbon conversion efficiency performance of the HEACC system. These fuels both contained the baseline amount of stabilizer.

Test 35 evaluated a variation of both additive quantity and the fuel mixing process. It exhibited reasonably good carbon conversion (approximately 97%) when fired at a PAF of 0.32 and an excess air level of 33.7%. This was a valuable point in the refinement of the fuel.

The next series of tests, Test Numbers 36 to 38, were carried out using an unstabilized ultrafine CWF with a solids content of 58.2%. Higher carbon conversion efficiencies at excess air levels between 31.5 and 33.4% excess air were attained- at high values of NO_x emissions. Lower excess air operation, in an attempt to reduce NO_x emissions caused the carbon conversion efficiency to diminish to less than 96%; however, NO_x emissions were reduced to 475 ppm.

As previously stated, the Prematrix testing served to optimize the performance of the HEACC and to formulate a CWF which balanced storage and atomization requirements. A 30,000 gallon batch of this fine grind (21 micron MMD) CWF was prepared by OXCE and utilized for the Matrix Tests. The prematrix operation of the HEACC was optimized with a 63.8 solids CWF. The production batch of CWF was produced at 65.2% solids. Previous experiments have noted the adverse impact of increased solids content upon carbon conversion efficiency. However, excess air level and PAF were found to be the dominant factors in influencing carbon conversion efficiency.

**CARBON CONVERSION EFFICIENCY VS EXCESS AIR
COMPARISON OF CWF FUELS
8 CELL TIP, FORCED VORTEX**

FIGURE 5.13

2) MATRIX 2 AND 3 TESTS

Test Numbers 39 to 51 were carried out varying the atomizer (8 cell vs. 25 degree) and swirler (forced vs free vortex) types. The results of this test series, giving carbon conversion efficiency and NO_x emissions as a function of excess air are shown in Figures 5.14 and 5.15. These test results demonstrate the ability of the both the 8 cell atomizer with the forced vortex swirler and the 25 degree spray nozzle tip with the free vortex swirler to obtain carbon conversion efficiencies of over 97% with excess air levels greater than 30%. Figure 5.15 shows that both these nozzle-swirler combinations could yield NO_x emissions as low as approximately 500 ppm, when the excess air levels were sufficiently low.

Based on these experimental results and the cold flowing modeling results of Task 1.0 (which showed the forced vortex type swirlers to produce a larger and stronger recirculation pattern), the next series of experimental runs (Test Nos. 52 to 57) were all carried out using a forced vortex swirler and 8 cell tip atomizer configuration.

In an attempt to control NO_x emissions, the next series of tests (Test Numbers 52 to 56) were run at lower values of excess air (approximately 22%). In this test series, Test Numbers 54 to 56 were carried out with external staging- accomplished by introducing air externally along the side of the furnace through four 6-inch ports approximately 12 to 14 ft downstream of the burner. The results of these tests showing carbon conversion efficiency and NO_x emissions as a function of the primary air fraction, PAF, are given in Figures 5.16 and 5.17. These show that the use of external staging increased the carbon conversion efficiency, but gave little reduction in NO_x emissions.

The lack of reduction of NO_x emissions with external staging may have been caused by the low velocity (and jet penetration) of the externally staged air jets. This was due to limitations in the available fan head at the test facility.

FIGURE 5.14

FIGURE 5.15

FIGURE 5.16

FIGURE 5.17

Figure 5.17 shows a dramatic drop in NO_x levels when the PAF was reduced from 0.44 to 0.15. This drop in NO_x emissions is due to both the effect of the internal staging and a reduction in carbon conversion efficiency.

Test Number 57 was a 50% load test and yielded a carbon conversion efficiency of 99.9% and NO_x emissions of 444 ppm. The high carbon conversion efficiency was realized due to the increased residence time inside the furnace at the lower load, and the lower NO_x emissions were primarily due to the effectively lower value of volumetric heat release in the combustion chamber at low load.

The last experiments in this test series (Test Numbers 58 to 63) were performed with sorbents added to the CWF fuel. Two types of sorbents were used- either Calcium Hydroxide ($\text{Ca}(\text{OH})_2$) or Calcium Acetate ($\text{Ca}(\text{C}_2\text{H}_3\text{O}_2)_2$). The results for this series of experiments are summarized in Table 5.6. It should be noted that the tests reported all used the 8 cell atomizer tip, with the forced vortex swirler, and a primary air fraction of about 0.23. The sulfur capture efficiency is defined as the percentage reduction in SO_2 emissions from an averaged baseline value (in this case 300 ppm).

A graphical summary of these results showing the sulfur capture efficiency as a function of the Ca/S mole ratio is given in Figure 5.18. For comparison, the results from the MIT testing, summarized in the Task 2.0 report, are also given. It should be noted that the sulfur capture efficiency values for this series of tests are considerably below those reported in the MIT testing. As noted previously, the CE testing added the sorbents directly before combustion. Careful examination of the Demonstration Scale data has not provided a full explanation for the substantial differences between the two test series. MIT (Toqan, et al., 1989) has attributed the successful sorbent performance to the several days that sorbent and CWF mixture spent in storage barrels prior to firing. They concluded that "the ability to disperse the calcium uniformly among the coal particles resulted in a higher sulfur removal efficiency". This explanation, or potentially significant differences in the aerodynamic flow field or temperature field between the Pilot and Demonstration scale HEACC tests merits

TEST NO.	SORBENT	Ca/S DESIRED	Ca/S ACTUAL	SO2 Emissions, ppm	Sulfur Capture Eff, %
58	Calcium Acetate	2/ 1	1.49/ 1	215	28.3
59	Calcium Acetate	1.5/ 1	1.03/ 1	222	26
60	Calcium Acetate	1/ 1	0.73/ 1	278	7.3
62	Calcium Hydroxide	2/ 1	2.03/ 1	239	20.3
63	Calcium Hydrox.de	1/ 1	0.9/ 1	258	14

TABLE 5.6 RESULTS OF SORBENT INJECTION TESTS

SULFUR CAPTURE EFFICIENCY VS. Ca/S RATIO
CE TEST POINTS NO. 58-63

FIGURE 5.18

further investigation since the Pilot scale results show such a significant SO₂ reduction by fuel mixed sorbent injection.

5.2 Pulverized Coal Firing

Under the scope of the pulverized coal portion of the experimental plan, two combustion matrices were planned for the pulverized coal (PC) portion of the HEACC Demonstration Scale testing. The general objective of this test program was to systematically test and document the combustion performance of the HEACC using PC fuels. This series of tests involved evaluating the following design variables:

- 1) Swirler type**
- 2) Fuel Injector type**
- 3) Burner configuration**
- 4) Secondary swirl direction**
- 5) Firing rate**
- 6) Excess air**
- 7) Primary Air Fraction (PAF)**

A discussion of each of these variables follows:

1) Swirler type: PC Matrix 1 (Test Numbers 101- 120) was conducted using the free vortex swirler. PC Matrix 2 (Test Numbers 201- 219) was conducted using the forced vortex swirler. These were the two most efficient swirlers developed under Task 1 and are described in detail in the Task 1 final report. They were also the same ones used in the CWF test matrices.

2) Fuel Injector: Two types of fuel injectors were used in PC Matrix 1. The conical injector features a 30° cone mounted on the end of a dense phase fuel pipe. Its purpose was to provide a hollow cone fuel "spray" with a relatively narrow angular distribution. The Impinging Jet (or I-Jet) injector was derived from a small scale

International Flame Research Foundation (IFRF) design (Smart and Weber, 1989). The Combustion Engineering design featured 8 jets angled in upon each other to impinge approximately 10 inches downstream of the burner face. This impinging design lowers the momentum of the fuel particles and produces a highly fuel-rich zone at the heart of the burner's internal recirculation zone. In general, this proved highly beneficial to NO_x control. Based on the success of the I-Jet design in the Matrix 1 testing, this design was used exclusively for the Matrix 2 test series.

3) Burner Configuration: The HEACC was designed for a high degree of axial adjustment. Two configurations that looked promising during the cold flow model testing were used during the pulverized coal matrix test series. A "staggered" configuration (Figure 5.19) was predominately tested. This allowed a good flame stability while approximating the desired levels of burner stoichiometry distribution. The "telescoped" configuration (Figure 5.20) was also tested because it would minimize the entrainment of secondary air into the burner's internal recirculation zone. This would allow primary zone stoichiometric control (n_p) mainly via the primary airflow (PAF).

4) Secondary Swirl Direction: The direction of rotation of the swirl of the burner's secondary air stream controls the rate of mixing with the primary air stream. This rate of mixing is known to have a strong influence on NO_x emissions and combustion efficiency. A co-rotational secondary air swirl would produce relatively slow mixing while a counter-rotational secondary air swirl would produce much faster mixing with the fuel and primary air streams. Tests were conducted in both pulverized coal matrices using secondary air swirls co-rotational, counter-rotational, and at zero rotation relative to the direction of the primary air stream.

5) Firing Rate (Load): The majority of tests were carried out at the HEACC's design firing rate of 50×10^6 Btu/hr, and this was the area of primary interest. The minimum load tested was 60% because of fuel system limitations. Specifically, an existing Combustion Engineering coal pump used in the fuel supply system was designed for high mass flow rates up to 7 tons/hr. Minimum operating capability was about 1 ton

FIGURE 5.19 STAGGERED BURNER CONFIGURATION

FIGURE 5.20 TELESCOPED BURNER CONFIGURATION

per hour, which represents a fuel energy input of about 60% of 50×10^6 Btu/hr. The HEACC is probably capable of stable operation at a 4 to 1 or 3 to 1 turndown on pulverized coal; however, this could not be attempted during the test program.

6) Excess Air: Excess air levels for the test matrices were varied over the range of 12-30%. This represents the normal operating range for industrial boilers. Efforts were made to optimize the HEACC's performance at 15- 20% excess air- as this is conducive to efficient boiler performance and low NO_x production.

7) Primary Air Fraction (PAF): Control of a burner's primary zone stoichiometry (η_p) represents a key factor in NO_x control. In the HEACC, the primary zone stoichiometry is composed of two main components: 1) the amount of combustion air admitted directly through the primary air swirler- this is called the primary air fraction (PAF) and is measured using a precision venturi tube. 2) Entrained secondary air and furnace gases also contribute to η_p . For the HEACC, an η_p of 0.6- 0.7 was desired and a PAF of 0.35 was used at the design point. With entrainment, an operational η_p of 0.6 to 0.7 was expected. Both pulverized coal matrices varied PAF over a wide range to assess the effect of this important parameter on NO_x emissions and combustion efficiency.

5.2.1 Detailed Experimental Results

The following discussion summarizes the series of experimental tests that were conducted with the PC fuels using both the free and forced vortex swirlers.

An overall summary of the carbon conversion efficiency as a function of the excess air supplied to the burner for the 100% load test points is given in Figures 5.21 and 5.22. Figure 5.21 gives the results for the free vortex swirler (Test Points Numbers 101- 120) and Figure 5.22 shows the results for the forced vortex swirler (Test Points Numbers 201- 219). As shown in these figures, the HEACC produced excellent carbon conversion values (98% to 99.9%) over a wide range of excess air values for both types of swirlers. In comparison to the previous tests of the HEACC system using a

FIGURE 5.21

FIGURE 5.22

CWF, the results of this test series shows the advantage of using coal as a dry product as opposed to a CWF.

As will be emphasized in the following discussion, based on the favorable carbon conversion efficiency of the HEACC system using the micronized dense phase pulverized coal, the focus of the experiments emphasized the reduction NO_x emissions to minimal levels.

Figure 5.23 shows the NO_x emissions as a function of excess air for a number of the HEACC tests with a fixed primary air fraction (PAF) averaging 0.30. During these tests, both the swirler type (free vs. forced vortex) and the fuel injection method (I-Jet vs 30 degree cone) were varied. These results clearly demonstrate the positive effect that low excess air has on the NO_x emissions as well as the superiority of the I-Jet fuel injector design over the 30 degree conical injector. As is shown in this figure, there appears to be no NO_x emissions difference (within data scatter) between the free and forced vortex swirlers when used with the I-Jet injectors. Specifically, NO_x emission levels below 365 ppm were demonstrated at several test points, while high carbon conversion was maintained.

A comparison of the pressure drop through the free and forced vortex swirlers showed the forced vortex swirler exhibits a pressure drop of approximately one half of that of the free vortex swirler at the same airflow. Since both swirlers have a design swirl of 1.0, this represents essentially identical amounts of swirl imparted to the primary air. Since the NO_x levels are also the same, this means that the forced vortex swirler would allow the burner to operate with a lower consumption of fan power, thus contributing to improved operating economics for the boiler.

Figures 5.24 through 5.26 present the NO_x emissions as a function of primary air fraction (PAF) for the I-Jet fuel injector for both the forced and free vortex swirler designs. The first two figures show that the optimum value (lowest NO_x emissions) for the primary air fraction was about 0.30. These trends confirm the validity of the design

**NO_x EMISSIONS VS EXCESS AIR
PRIMARY AIR FRACTION ~ 0.3**

FIGURE 5.23

**NO_x EMISSIONS VS PRIMARY AIR FRACTION
EXCESS AIR ~ 20%
FREE VORTEX SWIRLER, I-JET INJECTOR**

FIGURE 5.24

FIGURE 5.25

FIGURE 5.26

value PAF of 0.35. Figure 5.26 (Forced vortex swirler, 20% excess air) does not show this trend as clearly, but the minimum NO_x emissions do occur in Figure 5.26 near a PAF of 0.30.

As shown in Figure 5.27, the 30 degree conical injector exhibited NO_x emissions trends that differed from the I-jet injector. Based on a more limited series of test points, the lowest NO_x emissions occurred at a primary air fraction of 0.16. The fuel and air mixing patterns produced by the conical injector probably differ significantly from the I-jet. It is most important to note that the minimum NO_x level obtained for the conical injector is significantly higher than with the I-jet injector; thus, further development of the HEACC would focus on the I-jet concept for the coal injector.

Figure 5.28 shows that (for a PAF of 0.30 with the 30 degree conical injector, and a free vortex swirler) the telescoping HEACC configuration did not give a reduction in NO_x emissions. However, it should be pointed out the degree of telescoping was limited with the conical injector because of fuel impingement limitations.

Figures 5.29 and 5.30 summarize the results of the testing for the HEACC system operated at a partial load of 60%, using the forced vortex swirler and the I-Jet fuel injector. As shown in Figure 5.29, the carbon conversion efficiency held at high values over a wide range of excess air. Figure 5.30 shows the NO_x emissions performance at partial load of the HEACC system and, as for the full load tests, shows the advantage of operation at low excess air levels and of the I-jet injector. As discussed earlier in this section, partial load operation was fuel supply limited and it is expected that the HEACC could operate satisfactorily at a turndown ratio of from 3:1 to 4:1.

**NO_x EMISSIONS VS EXCESS AIR
FREE VORTEX SWIRLER, 30 DEG CONE INJECTOR
VARYING PRIMARY AIR FRACTION**

FIGURE 5.27

**NO_x EMISSIONS VS EXCESS AIR
FREE VORTEX SWIRLER, 30 DEG CONICAL INJECTOR
PAF = 0.30, EFFECT OF TELESOPED GEOMETRY**

FIGURE 5.28

FIGURE 5.29

FIGURE 5.30

6.0 GENERAL DISCUSSION OF RESULTS

The overall objective of this program was to develop a relatively simple environmentally sound, firing system for coal-based fuels to enable the replacement of oil and natural gas in boilers and other fuel firing equipment currently using these premium fuels. Through the systematic, multi-task program described in this report, the HEACC firing system was developed which met this objective.

Task 1.0 produced a family of highly efficient combustion air swirlers which were based on gas turbine blade designs and produced effective amounts of swirl at reduced pressure drops. The Task 1.0 report describes in detail the design steps required for the swirlers. This will facilitate the incorporation of these types of swirlers into other combustion devices, thus promoting potentially significant energy savings in the form of reduced fan power consumption. Under Task 1.0, the prototype HEACC cold flow model was tested and verified the design basis for the burner.

Under Task 2.0, the Pilot-Scale (5×10^6 Btu/hr) combustor demonstrated the HEACC's ability to burn CWF's with high combustion efficiency and low NO_x levels. In-fuel sulfur sorbents were able to reduce SO_2 emissions by up to 70%. The Pilot-Scale tests confirmed the validity of the HEACC design under combustion conditions.

Based on the success of the first two tasks, a Demonstration-Scale HEACC was designed and tested. The demonstration scale program evaluated two swirler types, several CWF atomizer configurations, two dry coal injectors, fine grind (21 microns MMD) CWF, ultrafine grind (9 micron MMD) CWF, and dry fine grind (21 microns MMD) pulverized coal. The results clearly showed that the HEACC met the program objective of developing a retrofittable coal-based fuel combustor. Specifically, the HEACC was successfully able to fire several forms of CWFs, as well as dry pulverized coal. Some goals, such as burner physical envelope and carbon conversion were fully met. Others, such as NO_x emissions, were more difficult to achieve, but generally were met. The test results are summarized below.

The results of the CWF tests showed:

- The furnace opening required for the HEACC matched that of a comparable industrial oil burner- this would facilitate boiler retrofit.
- High carbon conversion efficiencies (> 98.0%) could be achieved at excess air levels of 30-35%.
- NO_x emissions could be reduced from over 700 ppm to below 475 ppm, but at the expense of reduced carbon conversion.
- Sulfur capture rates with the sorbent containing CWFs were lower than those measured in the Pilot-Scale tests.

The results of the pulverized coal tests showed :

- High carbon conversion efficiencies of greater than 98.5% could be obtained at excess air levels of 15 to 25%.
- NO_x emissions could be controlled to below 390 ppm while maintaining high carbon conversion efficiencies.
- The I-jet fuel injector showed excellent results. This type of fuel injector merits further development and application.
- The use of stored pulverized coal and dense phase pneumatic transport to the burner was successfully demonstrated. This could be an important method of implementing BCF use in industrial oil replacement applications.

Finally, the overall results of the combustion tests showed:

- The HEACC Primary Air Fraction (PAF) design value of 0.30 to 0.35 produced the minimum NO_x levels. This design value should be maintained in future applications.
- Both the free and forced vortex swirlers produced satisfactory operation; however, the forced vortex swirler required approximately one half of the pressure drop to achieve these results. From a plant efficiency viewpoint, the forced vortex swirler is superior.
- A commercial application of the HEACC should employ the staggered burner configuration. The telescoped configuration showed no significant benefits.

In summary, this program produced an advanced coal firing system that was capable of combusting both water-based and dry pulverized forms of BCFs in an industrial boiler environment. The HEACC could be adapted to a long term field program in a commercially operating unit. The optimum configuration for this would employ the HEACC firing either a dry beneficiated coal product using a dense phase storage and transport system or a beneficiated CWF. This long term usage would clearly be another important step in the Department of Energy's stated goal of energy independence for the United States.

7.0 CONCLUSIONS AND RECOMMENDATIONS FOR THE GENERALIZATION OF THE TECHNOLOGY

7.1 Industrial Applications/ Markets

The overall objective of this project was to develop a firing system (HEACC) for coal-based fuels to enable the replacement of oil and natural gas in boilers and other fuel firing equipment. The primary target for the application of the HEACC is industrial users. In the industrial sector, a significant proportion of total boiler capacity in operation in the year 2000 is expected to be composed of pre- 1980 units (Bergman and Dykes, 1982). Thus, any substantial near term increase in the use of coal for producing industrial steam will therefore have to be accomplished through conversion of boilers currently fired by natural gas or oil. The application of coal or coal- based fuels to industrial boilers originally designed for gas or oil firing presents a number of challenges to the combustion engineer. For example, constraints such as the burner's physical size, carbon conversion efficiency, emissions control, and coal and ash handling must be addressed and resolved.

In order to accommodate installation into a wall-fired industrial boiler, the HEACC has been designed to be compact and fully scalable over a wide size range. It is also capable of use in multi- burner arrays. The usable size range encompasses boilers from small 5500 kg/hr (12,000 lb/hr) package boilers to utility boilers up to about 100 MWe. Figure 7.1 shows typical boilers in this size range.

In addition to industrial boiler and small utility boiler retrofits, the HEACC could be potentially applied to cement kilns, mineral processing equipment, and some chemical process heaters. Application to cement kilns and mineral processing equipment (i.e., rotary aggregate dryers, etc.) is very attractive since most of these applications are very tolerant of coal ash in the fuel. In process heaters, the use of coal-water fuels (CWF), in a HEACC type system could also be technically feasible and economically practical in some cases.

SHOP-ASSEMBLED INDUSTRIAL BOILER

LARGE FIELD-ERECTED INDUSTRIAL BOILER

FIGURE 7.1 TYPICAL INDUSTRIAL BOILERS

7.2 Coal-Based Fuel Applicability

Borio and Hargrove (1982) noted that coal slurry fuels offer an alternative way to use coal as a substitute fuel in industrial and utility retrofit applications. Also, other investigators (Rini, et al., 1987a; Margulies and Zabolotny, 1985) have noted the potential of dry, microfine pulverized coal as an oil replacement fuel. In general, the HEACC system has been designed to be extremely flexible in terms of fuel type and fuel quality (i.e., ash level). Depending on the specific application, the HEACC is designed to fire:

- 1) Inherently low ash (5-6%) coal-water fuel (CWF), microfine coal water fuel (MCWF), or microfine pulverized coal (MFPC) for coal designed or widely-spaced tube oil-design boilers.
- 2) Moderately beneficiated, 2-3% ash, MCWF or MFPC for oil-designed boilers.
- 3) Highly beneficiated, 1% or less ash, MCWF or MFPC for natural gas-designed boilers.

This fuel flexibility will enable the HEACC to be applied to a very wide range of boiler types. In addition, the HEACC could be made capable of firing oil or natural gas should the specific application require dual fuel capability to be incorporated into the design.

Although it is beyond the scope of this section to discuss the details of recent developments in coal-water fuels and the use of micronized coal in boiler systems, a short summary of recent work on these subjects and their specific applicability to an HEACC system is appropriate.

7.2.1 Coal- Water Fuels

The use of coal-water fuels for retrofit applications in practical combustor systems has been discussed and demonstrated by a number of researchers (Beer, 1986; LaFlesh, et al., 1986; Rini, et al., 1987b), and it has been generally concluded that atomization

quality and burner design are two key parameters required for the successful application of this fuel. Furthermore, as reported by Borio, et al. (1986), microfine CWF (MCWF) has been tested in a pilot- scale facility to assess its combustion/ fireside characteristics. The basis for this investigation was the premise that MCWF has the potential to offer improved combustion efficiency in the limited residence time environment of an oil- designed furnace, as well as produce smaller and less erosive fly ash particulate matter, thus allowing the boiler to carry a higher portion of its original design load. These studies have shown that a key to obtaining these benefits is to achieve an atomization level that takes advantage of the fine coal particles within the MCWF. This is difficult to achieve in practice, because as the coal particle size decreases (in a CWF of constant solids content), both the shear and extensional viscosities increase dramatically. These factors have a strong negative influence on CWF atomization quality.

In the CWF combustion program cited above, experimental tests were conducted at conditions simulating those anticipated for commercial CWF firing. The temperature of the fuel was varied and furnace flame temperatures, furnace residence times, convective pass gas temperatures, and gas velocities were representative of oil- designed boilers. Ash slagging characteristics were determined from a series of waterwall panels located in the high temperature zone of the furnace. Ash fouling was determined from a series of convection tubes downstream of the furnace outlet. The test unit also included a high velocity erosion measurement section to assess boiler tube erosion due to the presence of fly ash in the flue gas.

In the area of combustion efficiency, as shown in Figure 7.2, the combustion behavior of MCWF was found to be highly dependent upon solids concentration and fuel temperature. Both of these parameters are believed to impact directly on CWF atomization quality, which directly influences combustion behavior. For example, during the initial MCWF testing with the high solids loading fuel (68 and 66% by weight), carbon conversion rates were relatively low (approximately 97.7%) with average fly ash particle diameter exceeding 35 microns on a mass median diameter (MMD) basis. It should be noted that these comparatively large fly ash particles which

FIGURE 7.2 CARBON BURNOUT RATES OF ALMA SEAM MICROFINE CWF

derive from agglomerated coal particles in a poorly atomized fuel spray would tend to negatively impact boiler tube erosion. However, dilution of the fuel to a lower solids concentration (64% by weight) resulted in dramatic improvements to combustion behavior- this effect was concluded to come as a result of improved atomization quality, since both shear and extensional viscosity decrease with dilution. With fuel dilution, carbon conversion efficiency increased to a maximum of 99.6% and fly ash particle size decreased to about 9 microns MMD. Heating the MCWF to 220 F further improved the combustion performance with carbon conversion efficiency increasing to 99.9% and fly ash particle size decreasing to 4 microns MMD. Experimental data from the erosion testing also indicated a substantial reduction in measured erosion rates as the solids content of the fuel was reduced.

In general, these results indicate that the combustion performance of MCWF's can be comparable to the results obtained from standard and fine grind dry pulverized coal firing. Also, the fuel-related technologies identified in this study are directly applicable to the HEACC development program, if CWF based fuels are to be used.

The results of the HEACC test program, described in detail in Section 5.0 of this report, showed that fine grind CWF could be efficiently combusted in a furnace that modeled an oil fuel designed boiler. The tests also showed that NO_x could be held to moderate levels while still maintaining reasonable combustion efficiency.

7.2.2 Microfine Pulverized Coal

For the practical combustion of a microfine pulverized coal fuel (MFPC), storage and handling problems beyond those normally considered with conventional pulverized coal firing systems have to be addressed. In this area, Combustion Engineering, as part of a burner development program for the Direct Spark Ignition of Pulverized Coal (DIPC), developed procedures for the storage and conveying of dry pulverized coal (Clukey, et al., 1984). The DIPC system, which involves a method of sealing and self-inerting the storage silos, has been in safe and reliable operation at TVA's Bull

Run Plant since 1982, where large quantities of stored pulverized coal are utilized with great frequency. However, MFPC represents another step in storage difficulty since the high surface areas available for fast reaction increase the stringency with which the fuel must be handled. The U.S. DOE has recently initiated a program to develop the technology required to handle MFPC.

For application with an HEACC burner system, the following discussion describes a large industrial/ small utility scale system that could be utilized to avoid on-site storage of the MFPC. A schematic of this system is shown in Figure 7.3, and it should be noted that this system differs from the more typical direct firing system by the addition of a cyclone collector to separate the conveying/ drying medium from the pulverized coal. Raw coal from the customer's coal conveyers would be deposited in coal bunkers capable of 24-hour storage. Each coal bunker would supply an individual mill with raw coal via a volumetric feeder mounted on the pulverizer. An independent primary blower directly feeds the microfine coal to the furnace, and the pulverizing component would utilize flue gas from the boiler for the drying medium and tempered air as the transport medium. This transport gas is then vented into the furnace.

The microfine coal (98% through 325 mesh) would be ground in commercially available roller mills (e.g., C-E Raymond No. 73612 Roller Mills). Integral with each mill is a cyclone, two rotary air locks beneath the cyclone, a primary blower and venturi, fuel piping and distributors designed for 50 psi construction. The system fan would be inerted with flue gas. From the mill the ground coal is carried by inert gas to a cyclone where the microfine coal particles are separated from the flue gas. The cyclone vent flow consisting of flue gas and ultrafine coal particles not collected by the cyclone would be recycled back to the system fan inlet and injected into the roller mill. The separated pulverized coal would be fed out the bottom of the cyclone through two rotary valve locks into the transport venturi. This coal would be conveyed to the burner by the primary blower with tempered air from the air heater. The use of this method allows the firing system to operate at normal gas-to-coal ratios.

FIGURE 7.3 SCHEMATIC OF MICROFINE PULVERIZING SYSTEM

7.3 Systems Applications

The HEACC is intended to be integrated into industrial steam generation systems or some types of process heaters. A total system would include subsystems for fuel delivery, on-site handling and storage, combustion, environmental control, and waste disposal. Figure 7.4 gives schematics of a total system required for application of the technology developed under this project to an industrial boiler. Figure 7.5 shows two types of process heaters to which the HEACC could be adapted. The top picture shows a direct fired cement kiln, and the bottom picture shows a indirect fired rotary dryer. A process tolerance to ash contamination would dictate the use of direct or indirect fired applications. Both CWF and microfine pulverized coal applications are feasible using the HEACC. The use of microfine pulverized coal would substitute solid fuel handling equipment for the CWF equipment. Either fuel form could be utilized with off-site manufactured fuel, thus facilitating conversion of oil- and gas-fired equipment. It should be noted that all the components shown in these systems are commercially available and have been demonstrated to function in full-scale testing or commercial use.

HEACC WITH STORED PULVERIZED COAL FIRING

HEACC WITH CWF FIRING

FIGURE 7.4 SCHEMATIC OF AN INDUSTRIAL BOILER INCORPORATING HEACC

DIRECT-FIRED ROTARY KILN FOR CEMENT PROCESSING

INDIRECT- FIRED ROTARY DRYER

FIGURE 7.5 PROCES HEAT APPLICATIONS FOR HEACC

8.0 REFERENCES

- Anderson, D. A., Bianca, J. D., and McGowan, J. G. (1986) "Recent Developments in Physical Flow Modeling of Utility Scale Furnaces," Proc. 1986 Symposium on Industrial Combustion Technologies.
- Beer, J. M. (1986) "Coal- Water Fuel Combustion; Fundamentals and Application- A North American Overview," ICHEME Symposium Series No. 95.
- Beer, J. M. and Vermes, G. (1982) "Gas Turbine Combustor for Coal Water Mixtures," Proc. of Engineering Foundation Conference: Combustion of Tomorrow's Fuels, Santa Barbara, Nov. 7- 12.
- Beer, J. M. and Chigier, N. A. (1972) Combustion Aerodynamics, Wiley, New York.
- Bergman, M. K. and Dykes, R. M. (1982) "Prospects for Increasing the Direct Use of Coal In Industrial Boilers," EPA Report: EPA-600/S7-82-046, NTIS.
- Borio, R. W., et al. (1984) "C-E's CWF Experience in Laboratory and Commercial Firing Systems," Proc. 3rd. Int. Coal Liquid Workshop, Halifax, Nova Scotia.
- Borio, R. W., et al. (1986) "Performance Characteristics of Micro-Fine Coal-Water Fuel versus Pulverized Coal," Proc. Coal Liquid and Alternative Fuel Technology, Halifax, Nova Scotia.
- Borio, R. W., and Hargrove, M. J. (1982) "The Effects of Coal Slurry Fuels on Steam Generation," ASME Paper No. 82-JPGC-Pwr-42.
- Bortz, S. (1983), "Background and Programme Outline for the IFRF Burner Near Field Aerodynamics Project," IFRF Study Report, Doc. No. G 14/a/2.
- Buckley, P. L., et. al. (1983, 1980), "The Design and Combustion Performance of Practical Swirlers for Integral Rocket/ Ramjets," AIAA Journal, p 733 or AIAA Paper 80-1119.
- Clukey, D. J., et al. (1984) "Operating Experience with Direct Ignition of Pulverized Coal (DIPC) at TVA's Bull Run Station," ASME Paper No. 84-JPGC-Pwr-35.
- Felton, P. G., et al. (1985) "Measurement of droplet size distribution in dense sprays by laser diffraction," 3rd Int. Conf. on Liquid Atomization and Spray Systems, July, London.
- Gostelow, J. P. (1984) Cascade Aerodynamics, Pergamon Press, Oxford.
- Johnsen, I. A. and Bullock, R. O. (1965) Aerodynamic Design of Axial-Flow Compressors, NASA SP-36.

- Knight, H. A. and Walker, R. B. (1957), "The Component Pressure Losses in Combustion Chambers," Aeronautical Research Council R and M 2987, London.
- Kilik, E. (1976), "The Influence of Swirl Design Parameters on the Aerodynamics of the Downstream Recirculation Region," Ph. D. Thesis, Cranfield Institute of Technology.
- LaFlesh, R. C., et. al., 1986, "Combustion Characteristics of Coal- Water Fuels," Proc. 8th Int. Symposium on Coal Slurry Fuels Preparation and Utilization.
- Lawn, C. J. (1987), Principles of Combustion Engineering for Boilers, Academic Press, London.
- Lefebvre, A. H. (1983) Gas Turbine Combustion, Hemisphere Press, New York.
- Leuckel, W. (1967) "Swirl Intensities, Swirl Types and Energy Losses of Different Swirl Generating Devices," International Flame Research Foundation Report: Doc.no. G 02/a/16.
- Lew, H. G. and Toof, J. L. (1984) "Low Emission Combustor Technology Program," Westinghouse Electric Corporation Report, DOE/MC20228-1653, NTIS.
- Margulies, A. E. and Zabolotny, E. R. (1985) "Emerging Coal Fuels for Oil and Gas Fired Boilers," Proc. ASME Energy Sources Technology Conf., Dallas.
- Marion, J. L. and Towle, D. P. (1985) "Development of a High Turndown 'T' - Fired Pulverized Coal Nozzle," ASME Paper No. 85-JPGC-PWR-30.
- Martin, C. A. (1987) "Aspects of the Design of Swirlers as used in Fuel Injectors for Gas Turbine Combustors," ASME Paper No. 87-GT-139.
- Mathur, M. L. and MacCallum, N. R. L. (1967), "Swirling Air Jets Issuing from Vane Swirlers. Part 1: Free Jets," J. Institute of Fuel, May.
- Meyer, P. L and Chigier, N. (1985) "Vaporization and devolatilization of coal water sprays," Carnegie Mellon University, Report No. DOE/RA/50266-FINAL.
- Mcollor, D. P, et al. (1988) "Promotion of Char Oxidization by Inorganic Constituents", The 22 Symposium (International) on Combustion.
- Nsakala, N., et al. (1985) "Combustion Characteristics of Coals for Industrial Applications," Combustion Engineering Report: DOE/PC/40267-5, NTIS.
- Rini, M. J., et al. (1989a) "Development of an Advanced High Efficiency Coal Combustor for Boiler Retrofit- Task 1: Cold Flow Burner Development," U.S. DOE Report- Contract DE-AC 22-86PC90275.
- Rini, M. J., et al. (1989b) "Development of an Advanced High Efficiency Coal Combustor for Boiler Retrofit- Task 3: " Demonstration Scale Testing at 50×10^6 Btu/hr" U.S. DOE Report- Contract DE-AC 22-86PC90275.

- Rini, M. J., et al. (1988a) "Progress in the Development of a High Efficiency Advanced Combustor for Boiler Retrofit," Proc. 13th International Conference on Slurry Technology, Denver.
- Rini, M. J., LaFlesh, R. C., McGowan, J. G., Beer, J. M., Toqan, M. A. (1988b) "Development of a High Efficiency Advanced Coal Combustor for Industrial Boiler and Process Heat Retrofit," Proc. Fifth Int. Pittsburgh Coal Conference, U.S. DOE, Pittsburgh, September.
- Rini, M. J., LaFlesh, R. C., McGowan, J. G., Beer, J. M., Toqan, M. A. (1988c) "Development of an Advanced Coal Combustor for Boiler Retrofit," Proc. ASME Industrial Power Conference, ASME, Houston, October .
- Rini, M. J., LaFlesh, R. C., McGowan, J. G., Beer, J. M., Toqan, M. A. (1988d) "Development of an Advanced Coal Combustor for Industrial Boiler Retrofit," Proc. Fifth U.S./Korean Joint Workshop on Coal Combustion, New Orleans, U.S. Department of Energy, October .
- Rini, M. J., LaFlesh, R. C., McGowan, J. G., Beer, J. M., Toqan, M. A. (1988e) "Development of a High Efficiency Advanced Coal Combustor for Industrial Boiler and Process Heat Retrofit," Proc. POWERGEN 88, Orlando, Dec.
- Rini, M. J., et al. (1987a) "Development of a High Efficiency Advanced Coal Combustor for Boiler Retrofit," Proc. 12th International Conference on Slurry Technology, New Orleans.
- Rini, M. J., et al. (1987b) "Demonstration of the Combustion Engineering 100-MBtu/h Burner for Coal-Water Slurries," EPRI Report: CS-4987.
- Rini, M. J., et al. (1986) "Commercial CWF Burner Development at Combustion Engineering," Proc. 11th International Conference on Slurry Technology, Hilton Head, South Carolina.
- Schmid, C., Weber, R., and Roberts, P. A. (1987) "Interactions Between Primary Air Jets and Swirl Generated Vortices," International Flame Research Foundation Report: Doc. No. K 70/a/2.
- Smart, J. P. and Weber, R. (1989) "NO_x Reduction and Burnout Optimisation using an Aerodynamically Air Staged Burner and an Air Staged Precombustion Burner," Proc. AFRC Spring Meeting.
- Toqan, M. A., et al. (1989) "Development of an Advanced High Efficiency Coal Combustor for Boiler Retrofit- Task 2: Pilot Scale Combustion Tests," U.S. DOE Report-Contract DE-AC 22-86PC90275.

END

**DATE
FILMED**

3 / 23 / 92