DOE/CE/283

DOE/CE/28310--T2

DE92 006629

REPORT TO THE DEPARTMENT OF ENERGY ON

GRANT NUMBER: DE-FG01-89CE28310

ELECTRIC THERMAL STORAGE DEMONSTRATION PROGRAM

I BACKGROUND AND GENERAL INFORMATION

In early 1989, MMWEC, a joint action agency comprised of 30 municipal light departments in Massachusetts and one affiliate in Rhode Island, responded to a Department of Energy request to propose for the Least Cost Utility Planning (LCUP) program. The MMWEC submission was for the development of a program, focused on small rural electric utilities, to promote the use of electric thermal storage heating systems (ETS) in residential applications.

The promotion of ETS centered around the concept of, "making conservation as easy as buying electricity," with one-stop shopping for equipment, zero interest loans, installation, customer training and equipment maintenance. Each light department was to set-up the service and MMWEC was to provide grant and program management including centralized purchasing of equipment and promotion of the program. Eight MMWEC member light departments stated they would be interested in participating in the program.

However, due to MMWEC personnel changes and the time between submission and notice of award, the level of interest in participation declined among the member light departments. Of the original eight systems interested in participating only four remained.

This change in the level of member interest caused MMWEC to revise the program description for a much less ambitious and costly program to the participating member light departments.

mg MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

The modified MMWEC LCUP grant proposal focused on the demonstration, as opposed to the mass marketing of ETS in each of the four remaining light departments. These demonstrations of ETS technology were to be in public buildings selected by the light department. Sites were either new or existing elderly housing units or the light department offices and buildings.

Program Participants Characteristics and Background

The four light departments participating in the ETS demonstration program were: Boylston, Holden, Pascoag and Sterling. Each of these light departments are small, rural and municipally-operated. The following town descriptions provide some background information on each light department, its size and composition and a summary of what was accomplished in their ETS effort.

Boylston Light Department

Located in Central Massachusetts, Boylston Light Department was created in 1912 and is presently comprised of six employees. The number of meters served is 1,665 having an average consumption of 12,708 kilowatt hours usage annually. The customer base is 64% residential. Total 1989 sales were approximately 21 million kilowatt hours. The summer peak is 3.8 megawatts and the winter peak is 4.9 megawatts.

Boylston's participation in the program was the installation of ETS equipment in housing for the elderly. The housing was new construction and originally planned for electric resistance heat. Since Boylston was the only system to install a large (278 kilowatt) thermal storage system as a part of the grant program, a more detailed description of this project is provided in Section III.

Holden Light Department

Located in central Massachusetts, the Holden Light Department was created in 1912. Holden Light Department currently has seventeen employees and serves 6,392 meters having an average consumption of 13,040 kilowatt hours. The customer base is 50% residential. Annual sales in 1989 were approximately 83,000,000 kilowatt hours and revenue from sales was over \$8,000,000. Summer peak is 14 megawatts and winter peak is 17 megawatts.

Holden completed a number of tasks related to ETS demonstration program. Of primary importance to Holden's effort was the survey on customer knowledge and attitudes toward ETS which was conducted to provide the light department information on the customers' understanding of thermal storage, customer interest in having thermal storage installed and the level of incentive required for a customer to participate in such a program. Survey results are included in this report as Appendix One. Holden also completed the development of an off-peak thermal storage rate and installed ETS equipment in the light department offices at their expense. Although a site for the installation of equipment was selected, an installation project was not completed.

Pascoag Light Department

Located in northern Rhode Island and an affiliate member of MMWEC, Pascoag Light Department was created in 1887.

The light department has 10 employees and serves 3,701 meters which have an average

annual consumption of 8,159 kilowatt hours. Total kilowatt hours sales were 30,199,388 kilowatt hours and the customer base is 61% residential. Summer peak is 6.0 megawatts and winter peak is 7.1 megawatts.

Pascoag completed installations in two separate locations, both the light department main office and the operations center/switch yard building were retrofitted with thermal storage equipment. A total of 40 kilowatts of ETS were installed in Pascoag. The impact of the new ETS load upon Pascoag was determined to be too small to show any effect upon the peak or typical day load shapes. A copy of an informational package which was provided to customers is attached as Appendix Two.

Sterling Light Department

Also located in central Massachusetts and created in 1910, Sterling Light Department has 11 employees and serves 2,563 meters which have an average annual consumption of 11,614 kilowatt hours. Total kilowatt hour sales were 29,766,000 in 1989 and the customer base is 63% residential. The summer peak is 5.7 megawatts and the winter peak is 6.2 megawatts.

Sterling was an early thermal storage enthusiast and initiated ETS projects in six residences in mid-1989. The light department developed an off-peak rate, coordinated a zero interest loan program with a local bank, arranged for ETS equipment with a supplier and provided customers with equipment below the retail price. This approach was similar to the program description initially submitted by MMWEC in response to DOE's request for proposal for LCUP funds. Sterling had planned to do a demonstration project as a part of the revised LCUP grant at their local housing for the elderly site but was unable to coordinate it with

the agency in charge of the housing. An unfortunate note to Sterling's effort was that the ETS project unexpectedly received approval to proceed from the agency in charge in late November, after the grant expired. A copy of Sterling Light Department's ETS promotional brochure is contained in Appendix Three.

II. TECHNOLOGY REVIEW OF ELECTRIC THERMAL STORAGE EQUIPMENT

Developmental History

Electric Thermal Storage was originally developed in Europe at the end of the second world war and has seen wide acceptance. The level of acceptance seen in Europe has not occurred in the United States for a number of reasons. Primary among the reasons for low acceptance of ETS is that thermal storage did not appear in the U.S. until the 1970's. The European companies manufacturing the ETS equipment began to promote thermal storage in the U.S. once interest in it began to be seen. Continued lagging market share, especially in new construction is due to the lack of awareness of the technology as a space heating option by electrical contractors, builders, homeowners and the utility industry. A few of the exceptions in the utility industry have been, Pennsylvania Power and Light, New York State Electric and Gas and Central Vermont Public Service, (an early proponent). Many other utilities have conducted pilot programs to assess customer acceptance and load shape impacts on their systems. The New England Power Service Company has completed several site specific evaluations, primarily in multi-family housing and both the South Kentucky RECC and the Eastern Kentucky Power Cooperative have jointly conducted a three year pilot study on equipment and customer acceptance.

American manufacturers also began appearing in the 1970's but they focused upon large centralized

units as opposed to the European focus on smaller room-sized heating units. Most U.S. companies still import their room-size ETS equipment from Europe. New U.S. companies have begun to have more of a presence in the market and new applications such as, crushed rock storage and thermal storage additions to heat pumps have begun to appear.

Technology Description

An Electric Thermal Storage device is, in simple terms, a series of electric resistance coils which heat a storage medium, in most cases ceramic bricks, which are housed in a well insulated container. Controls to vary the amount of charge received by the bricks and to set the room temperature are also a part of the equipment. A diagram of a typical unit is included in Appendix Four - ETS Equipment.

As was previously mentioned, there are, in general, two types of storage units, room unit heaters and centralized furnaces. Manufacturers are identified and their ETS products are described in detail in Appendix Two.

Individual room units are by far the most prevalent type of ETS system and are comprised of two types of units known as static and dynamic. A static unit has only resistance coils and ceramic bricks, there are no moving parts such as fans and they have limited control. Heat is discharged from the unit through vents and by radiant heat from the unit container. Static units are limited in use to those area that have lower heating needs or can do without heat such as a, hallway, entry way or bathroom. Static units need to be sized larger than dynamic units because of their uncontrolled means of discharge. Dynamic units incorporate fans for a more thorough and consistent distribution of heat and better unit controls for fan operation and charging level. In addition, dynamic unit operation is controlled at a central control point. A control panel provides

for a more consistent charging of the individual ETS units, outdoor temperature adjusted charging and they also regulate charging times to the off-peak. In addition, the control panel can offer access for a utility load control device to ensure that the ETS equipment operates only in the off-peak hours.

Equipment Sizing Considerations

To determine the appropriate sizing of either room or central units an hourly heat loss analysis needs to be conducted on either a room-by-room basis for sizing individual room units, or the entire house for a central storage furnace. Heat loss analysis is essential to the proper sizing of the ETS unit. Equipment manufacturers like to provide this service to contractors and architects, or will provide the installer or designer with training on how to size an installation. Inadequately sized equipment will result in poor performance affecting not only the comfort of occupants but the reputation of the utility company, the equipment supplier, electrical contractor and builder.

The second component to determining the size of an ETS system is the off-peak charging period allowed by the utility. This time period depends upon each utility's load shape and the hour or hours of peak demand on the system. ETS charging periods can be any number of hours per day, but the shorter the charging period, the larger the equipment needs to be sized, in order to store an adequate charge in the shorter charging period. The ETS equipment installed in Boylston at the housing for the elderly has an eight-hour charging period from 11 p.m. to 7 a.m. For the ETS equipment used at this site, which are units supplied by American TechnoTherm, an eight hour charging period corresponds to a sizing factor of two. Or if, for example, the site was to be heating by electric resistance heating, the size in kilowatts of that resistance system would be

multiplied by two to obtain the appropriate size for an ETS. The sizing factor accounts not only for the number of off-peak hours allowed for charging the ETS equipment but to also provide active heating to the residence during the charging hours. In the Boylston example cited above, the housing for the elderly had already been designed for 139 kilowatts of electric resistance heat and the number of hours for off-peak charging were set by the utility. The sizing factor or the sizing multiplier for ETS equipment, in the Boylston case, two, is determined by dividing the product of the hourly heat loss, the design day heating degree day and an adjustment factor by the indoor temperature. This quotient is then divided by the number of hours allowed for charging and finally the result is again divided by the hourly heat loss to obtain the sizing factor.

III. REVIEW AND FINDINGS FROM COMPLETED PROJECTS

Boylston and Pascoag light departments completed ETS demonstration projects. Both projects were very different in the ultimate end-user and in the size of the heating load. While Boylston installed ETS equipment in multi-unit housing complex for the elderly with over 18,000 square feet of occupied space and 272 kilowatts of ETS load, Pascoag had two buildings, the main light department office and the operations center with a combined square footage of 5,000 and 35 kilowatts of installed ETS equipment.

The Boylston ETS project site, known as Sunshine Village, is a multi-unit elderly housing site comprised of two separate buildings having a total of 24 apartments and a community building.

Initially designed to be heated by electric resistance units, Sunshine Village would have added 136

kilowatts to the Boylston Light Department's winter peak of nearly 5 megawatts if ETS equipment had not been installed.

Although the architect had already completed plans for electric resistance heat in the housing units, there was very little modification in the plans needed to incorporate the ETS units. The electrical contractor was familiar with ETS installation procedures, having previously installed equipment in another multi-family housing complex. The only additional construction item needed for the installation of ETS equipment was a Romex cable to connect each ETS unit to its respective control panel. The charging level and operation periods of the 24 ETS units were divided among three separate control panels which are located in a secured closet on the first floor of each building. The existing design for the electrical service was adequate for the additional load of ETS equipment. One 4 and one 6 kilowatt dynamic ETS units were installed in each apartment and 2.7 and 3.6 kilowatt static heaters were placed in hallways and entryways.

Equipment installation was completed in the fall of 1990, which enabled a comparison of winter peak day and typical day load shapes for 1990 and 1991.

Standard electric meters were used in this installation since Boylston's ETS rate is a flat charge of 8 cents per kwh with no demand charge for all electricity consumed on-peak or off-peak.

LOAD IMPACT

Assumptions

In order to determine load impacts, two assumptions had to be made. The first assumption is that

the 1991 peak day load includes the ETS installation at Sunshine Village. This is assured since the system was in operation during the 1990-1991 heating season. The second assumption is the impact on the Boylston load of a hypothetical Sunshine Village having 139 kilowatts of resistance heat instead of thermal storage. An estimate of the additional load, shown as "without storage" on Exhibit A, placed upon the Boylston system by the 139 kilowatts of resistance heat was determined from the "Database Inputs"- Temperature Sensitive Use Profile for Electric Heating, used for the NEPOOL Forecast of New England Electric Energy and Peak Load 1991-2006. The NEPOOL electric heat data are hourly and were used to create a load shape for the elderly housing as if it had resistance heat.

Description of Load Impacts

The effect of the installation of 278 kilowatts of ETS on the Boylston peak day load shape can be seen in Exhibit A. The comparison of the resultant system load shapes does show how the ETS equipment would lower the expected winter peak day peak. A look at the 1991 to 1990 actual peak day peaks, which both occur at 8 a.m., shows very little change between the two years. The actual difference in the two peaks (4560 and 4520 kilowatts, 1991 to 1990), was 40 kilowatts or less than a 1% increase. Since winter peaks are temperature driven and the measure of heating need, heating degree days, for the two peak days are 51 and 50 heating degree days, respectively for 1991 and 1990, or a 2% increase between 1990 and 1991. From the heating degree day data, it could be assumed that ETS had no impact on the increase in peak demand between the two years. A marginal peak day impact of 4 kilowatts could be attributed to the additional dynamic ETS units fan motors, however this impact is too small to be measured in the available data. The peak day difference between the two days is more likely to be attributed to existing customers increased demand for electricity for the marginally colder day experienced in 1991.

BOYLSTON

WINTER PEAK DAY

—■— ACT. 91 PEAK DAY —+— 91 NO STORAGE —*— ACT. 90 PEAK DAY

BOYLSTON TYPICAL DAY

Off-Peak Impact

The most evident impact of ETS on the system load shape can be seen between the hours of eleven p.m. and six a.m., which comprise the majority of the off-peak charging hours for the ETS equipment. These hours, when total system load drops considerably, allow for a better look at smaller load impacts and reveal the increase in off-peak consumption due to the charging of the ETS equipment. One of the benefits to utilities that is touted by ETS equipment manufacturers and suppliers is the load leveling effects of ETS. Although some minor load leveling is shown in this graph, a greater number of ETS units could show a more pronounced effect on the load shape. Given this minor leveling of the peak day load, the 1991 daily load factor improved by 2.7 percent to slightly over 80 percent from the previous year peak day load factor of 78 percent.

Exhibit B displays the load shapes for a typical winter day in 1991 with and without ETS. The typical day load shape displays more of a dual peak nature than the peak day. Historically the typical winter day peak in Boylston is set in the evening as opposed to the morning peak seen in the winter peak day. As in Exhibit A, the reduction in the peak and the off-peak increase are evident.

The small positive changes evident in the maintenance of the daily peak between 1990 and 1991, the increased off-peak consumption and the load factor improvement show the impact even a small shift in load caused by ETS can have upon a small electric system. From the load data alone, additional installations of ETS would seem to be of value to Boylston for the reasons of maintenance of the peak day load and an increased load factor from greater off-peak usage. Further evaluation needs to be done to determine the optimum amount of ETS heating for Boylston.

COST SAVINGS TO BOYLSTON

Boylston is a part of the New England Power Pool (NEPOOL) which controls the dispatch of all utility generating units in New England by their operating economies. NEPOOL requires all utilities to maintain adequate capacity. To ensure that each utility has adequate capacity, NEPOOL sets the annual capability responsibility for each utility adding approximately 18 percent above the anticipated demand. Boylston's current capability responsibility is 5,855 kilowatts. Since Boylston's peak in the winter of 1990-91 was 4,560 kilowatts and well within its capability responsibility, no capacity savings were realized. Nor were there any savings from avoiding short term energy purchases since existing resources were adequate to meet Boylston's energy needs. The impact of ETS on the longer term power needs of the Boylston light department is also uncertain. MMWEC's most current projections on power supply needs shows that Boylston has a surplus until 1998.

The further development of ETS in the near term, within five years, may offer Boylston a means to reduce its capability responsibility by reducing its peak demand. Since capability responsibility is determined on an annual basis a reduced annual winter peak, which is when Boylston sets its peak, could result in lower capability responsibility requirements in the future. This could provide Boylston with the opportunity to prevent the addition of a new generation resource for its resource mix, which could quite possibly be a more expensive peaking unit. In addition to capacity needs reduction, the increase in off-peak energy consumption due to ETS could prevent Boylston from dumping any excess, unneeded power, onto the grid at a price which is lower than its purchased power costs.

If the constrained market for electricity which existed when the grant was received in 1989 had been sustained due to continued economic expansion and insufficient generation resources, the savings in avoided power or capacity purchases would be much clearer.

Cost Analysis

To determine if there were any cost savings to Boylston, MMWEC analyzed the 1991 peak day and typical January day through its IOLD program. IOLD is power cost analysis software comprised of data bases for generation mix, fuel costs, hourly loads and generator availability information. A front-end program reads all the data and creates input files to the IOLD program which then models own-load (an individual utility's mix of base, intermediate and peaking generation), power plant dispatches and creates hourly production costs and generation amounts by power plant. Actual data for peak and typical day hourly loads, fuel costs, generation mix and availability were used in this analysis. Typical day (February 27, 1991) hourly load data was modified by removing the ETS load during the off-peak hours. The modified hourly load duration for resistance heat was then added to the typical day load for all hours.

Scenarios

Four scenarios were analyzed for daily costs - peak day thermal storage, peak day resistance, typical day thermal storage and typical day resistance. Each of these scenarios were analyzed for two cases an "all units" generation mix case and a "minus one baseload unit generation mix case. The "minus one baseload unit" was done as a sensitivity analysis to determine if savings cost savings varied based on the generation mix.

Findings

From these analyses, it was shown that there are savings for the 1991 peak day and for the typical winter day ranging from about two to five percent of the total daily cost. Savings occurred in three of the four scenarios but the greatest savings were found in the typical day scenario for the "all units" case and in the peak day scenario "minus one baseload unit" case. Significant savings also occurred in the the peak day "all units" scenario. The savings in these cases result from the change in the generation mix brought about by either the addition of off-peak ETS, which allowed for continued use of low cost baseload units during the off-peak, or from the additional on-peak load due to the resistance that would have been in operation if not for ETS.

For instance, in the typical day, "all units" scenario, which had the greatest daily savings of all scenarios, the savings resulted from the reduction of off-peak baseload and an increase in the on-peak load which would have occurred with resistance heating. The graph in Exhibit C presents the total hourly cost of power for both the ETS and the resistance heat scenarios in the typical day - all units case. This case had the greatest savings, approximately forty-one dollars, primarily due to the lower off-peak costs, when compared to the other cases for peak and typical day.

The other two scenarios which had significant savings in daily energy cost were, Peak Day, Minus One Baseload (Exhibit D) and Peak Day - All Units, (Exhibit E). The Peak Day - Minus One Baseload case for ETS had a savings of \$38.00 over the resistance heat scenario. The Peak Day - All Units case for ETS had a savings of over \$27.00 from the resistance scenario. In general, for all cases, the on-peak costs for the resistance heat scenario always exceeded those of the ETS

TYPICAL DAY

ALL UNITS

PEAK DAY

MINUS ONE BASELOAD CASE

PEAK DAY

ALL UNITS

TYPICAL DAY

MINUS ONE BASELOAD

scenario, due to the need for more expensive generation.

The exception to the above positive savings cases was the typical day "minus one baseload plant" case (Exhibit F) where there was a cost increase due to ETS operation. This loss occurred because with the loss of a major baseload plant, another higher cost power plant was brought on-line to serve the increased off-peak need attributable to ETS. The percentage loss for the day was only three quarters of one percent or about \$7.00.

SUMMARY

Because of Boylston's small size, we were able to measure with a reasonable degree of confidence, that the addition of a small amount of thermal storage provides some benefit to the light department load shape. From the data available and the analyses performed, Boylston should see a savings in its energy costs ranging from just under two percent in the peak day "all units" and "minus one baseload" cases to slightly less than four percent for the typical day "all units" case.

From the above analyses, it appears that Boylston Light Department can benefit from energy cost savings in the present and the reduction in need for future capacity savings from additional ETS installations. Further evaluation of the electric space heating loads available for conversion to ETS and the maximum economically feasible amount of load shifting to be attained before negative impacts occur on Boylston's system are needed prior to initiating a future ETS program.

APPENDIX ONE

HOLDEN MUNICIPAL LIGHT DEPARTMENT

**Survey of Electric Customers and a Report
on their Responses**

The following questionnaire and presentation of its results is the work of David Fleury, Douglas Folsom and Manish Kumar, former students at the Worcester Polytechnic Institute. The following represents only a portion of their final report to the Holden Municipal Light Department.

QUESTIONNAIRE

It would be a great help to our project if you could kindly take some time and answer the following questions.

Name: _____

Address: _____

- 1) Are you concerned with the size of your electric bill during the winter months?

very_____ somewhat_____ not concerned_____

- 2) Have you considered converting to another heating systemsuch as wood, oil, or gas? yes_____ no_____

- 3) Have you invested in energy conservation (such as insulation) in your current residence? yes_____ no_____

- 4) Would you give serious thought to purchasing the kind of thermal storage system described prteviously?

____yes, I would consider such a system ____no

- 5) If no, why not? (check all that apply)

____do not own property

____plan to move

____too expensive

____initial cost too high for the for the savings in future

____not interested in investing in equipment to lower electric bills at this time

_____ other _____

6) How many rooms do you have in your present residence?

_____ Bedrooms _____ Other

7) Which of the following best describes your home?

_____ single family	_____ townhouse
_____ single family attached (twin/duplex)	_____ apartment
	_____ condominium

8) How long have you lived in your present residence?

_____ less than 2 years	_____ between 2 and 10 years
_____ over 10 years	

9) Do you rent or own your place of residence?

(please circle one)

rent own

10) What is the average age of the bill payer(s) in the household?

(please circle one)

18 - 35 yrs	36 - 64 yrs	65 yrs and above
-------------	-------------	------------------

11) Under which of the following does your household income fall?

___ 10,000 - 30,000

___ 31,000 - 60,000

___ 60,000 and above

"YES" TO QUESTION NUMBER FOUR

Hello, I'm _____, a student at WPI. We're doing a project for the Holden Light Department and we trust that you have received the information we sent you regarding ETS. I was wondering if you had any questions pertaining to our project or ETS. (Allow them to ask questions and record)

I would like to find out your level of interest in electric thermal storage systems.

- 12) How would you describe your interest in electric thermal storage?

Very interested?
Somewhat interested?
Not at all interested?

The Light Department may be able to help customers purchase an electric thermal storage system.

- 13) How would you describe your interest if the Light Department offered the option to pay for the system by installments at moderate interest rates?

Very interested?
Somewhat interested?
Not at all interested?

- 14) How would you describe your interest if the Light Department offered a zero or low percent loan?

Even better than above?
Very interested?
Somewhat interested?
Not interested?

Thank you very much for your cooperation.

"NO" TO QUESTION 4, DON'T OWN, MOVING

Hello, I'm _____, a student at WPI. We're doing a project for the Holden Light Department and we trust that you have received the information we sent you regarding ETS. I was wondering if you had any questions pertaining to our project or ETS. (Allow them to ask question and record)

I see from your questionnaire return that you are not interested in ETS because you < don't own / plan to move from > your present residence.

- 12) If you did < own your residence / not plan to move >, how would you describe your interest in electric thermal storage?

Very interested?
Somewhat interested?
Not at all interested?

The Light Department may be able to help customers purchase electric thermal storage devices.

- 13) Again, if you did < own / not plan to move >, how would you describe your interest if the Light Department offered the option to pay for the system by installments at moderate interest rates?

Very interested?
Somewhat interested?
Not at all interested?

- 14) How would you describe your interest if the Light Department offered a zero or low percentage loan?

Even better than before?
Very interested?
Somewhat interested?
Not interested at all?

Thank you very much for your cooperation. It will be of great help to our project.

"NO" TO QUESTION 4, TOO EXPENSIVE, INSUFFICIENT SAVINGS

Hello, I'm _____, a student at WPI. We're doing a project for the Holden Light Department and we trust that you have received the information we sent you regarding ETS. I was wondering if you had any questions pertaining to our project or ETS. (Allow them to ask questions and record)

I see from your questionnaire that you are not interested in electric thermal storage because you feel that < it is too expensive / initial cost too high for savings >.

The Light Department may be able to help customers purchase electric thermal storage devices

- 13) How would you describe your interest in electric thermal storage if the Light Department were to offer you the option of paying for these units in installments at moderate interest rates?

Very interested?
Somewhat interested?
Not interested at all?

- 14) How would you describe your interest if the Light Department were to offer a zero or low percentage loan?

Even more than before?
Very interested?
Somewhat interested?
Not interested at all?

Thank you very much for your cooperation. It will be of great help to our project.

5.3 HOLDEN'S ELECTRIC CUSTOMERS

As was stated in Chapter IV of this report, 203 high consumption electric heat customers formed the sample that was polled. Each member of the sample was sent a brief informational letter and questionnaire on November, 3 1989. Over the next several weeks, 88 of the 203 questionnaires were returned. This amounts to roughly a 44% return. 70 of the 88 were contacted by telephone, roughly 80%. The questionnaire response percentages were compiled for both the sample of 70 and the sample of 88 and no significant differences were observed. Therefore, it can be assumed that the telephone interview percentages are also similar, and those observed for the 70 telephone interviews can also be applied to the sample of 88. This fundamental assumption is important to understand when examining our data.

Each response to our questionnaire was processed using SPSSX, Statistical Program for the Social Sciences, to determine the frequency of each response. These frequencies, and combinations thereof, yielded some very interesting data.

The first question of the questionnaire dealt with the customers concern with their electric bills. 69.3% of the customers who returned their questionnaires indicated that they were very concerned with the size of their electric bills. Also, or 26.1%, indicated that they were somewhat

concerned about the size of their monthly electric bill. Adding the two frequencies yielded that 95.5% of those customers who returned the questionnaire were at least somewhat concerned about the amount that they payed for electricity (See Table 5.4). This was not surprising given the high rate that these customers are charged for electricity in Holden. This high percentage indicates that there is tremendous potential for the acceptance of money saving technology, such as electric thermal storage, in the town of Holden. It should be noted that those who were not interested were less likely to respond to the questionnaire on the topic.

Table 5.4 Frequencies of Question One

(Concern with Electric Bills) CHOICE	FREQUENCY	PERCENT
very concerned	61	69.3
somewhat concerned	23	26.1
not concerned	2	2.3
no response	2	2.3
TOTAL	88	100.0

Question number two inquired if the customer had considered switching from electric heat to another form of home heating. Exactly 50% responded that they had not considered switching from electric heat to some other method (See Table 5.5).

Table 5.5 Frequencies of Question Two

(Considered Switching Systems) CHOICE	FREQUENCY	PERCENT
Yes	42	47.7
No	44	50.0
No Response	2	2.3
TOTAL	88	100.0

The third question on the questionnaire asked if the customer had invested in energy conservation measures in their present residence. 76.1% of the responses indicated that they had taken energy conservation measures in their homes (See Table 5.6). This, in conjunction with the 95.5% of the returns that were at least somewhat concerned with their electric bills, indicated that a large majority of the people who responded are energy concious people. This strengthens the feeling that there is potential for acceptance of a technology that could substantially reduce monthly electric bills in Holden.

Table 5.6 Frequencies of Question Three

(Invested In Conservation) CHOICE	FREQUENCY	PERCENT
Yes	67	76.1
No	18	20.5
No Response	3	3.4
TOTAL	88	100.0

Question four was the most important question on the questionnaire. It dealt with interest in electric thermal storage. Question four asked if the customers would give serious thought to purchasing an electric thermal storage system. 72.7% of the customers who returned their questionnaires answered positively (See Table 5.7). Based on the brief exposure to electric thermal storage, this percentage is good. A high percentage, such as this, is emphasized by the high percentages of concern with electric bills and energy consciousness. All of this together indicates the potential for success with an electric thermal storage program in Holden.

Table 5.7 Frequencies of Question Four

(Consider ETS) CHOICE	FREQUENCY	PERCENT
Yes	64	76.1
No	23	26.1
No Response	1	1.1
TOTAL	88	100.0

Question five provided seven reasons why one would not consider purchasing an electric thermal storage system. It was reserved for those people who responded that they were not interested in electric thermal storage. 23 out of 88 people who returned a questionnaire responded that they would not consider electric thermal storage, thus qualifying them

to respond to question five. However, some of the people who showed an interest to question four also expressed some concerns by checking the appropriate response to question five. From the responses that were received, a very interesting trend developed. 8 out of 23, or 34.78%, indicated that they were not the owners of the residence in which they lived. 5 out of 23, or 21.74%, responded that they planned to move in the near future and would not invest such a large amount of money on their present home. These percentages were expected to be low, given the nature of the people in the town. However, 8 out of 23, or 34.78%, said that electric thermal storage was too expensive for the savings in the future, and 10 out of 23, or 43.48%, indicated that the initial cost of electric thermal storage was too high to be considered. These percentages were lower than expected because the initial cost of the technology is quite high. 13 out of 23, or 56.52%, by far the highest percentage, responded that they did not know enough about electric thermal storage at the present time to consider it. This indicates that a substantial number of people are unsure about what electric thermal storage involves. 4 out of 23, or 17.39%, responded that they were not interested in investing in ways to reduce their electric bills at this time (See Table 5.8). In difficult times like these, in the town of Holden, this low percentage was also expected.

Table 5.8 Frequencies of Question Five

(Why Not Consider ETS) CHOICE	FREQUENCY	PERCENT
Do Not Own Property	8	9.1
Plan To Move	5	5.7
Too Expensive	8	9.1
Initial Cost Too High	10	11.4
Do Not Know Enough About ETS	13	14.8
Not Interested In Investing To Save Money	4	4.5
Other	11	12.5

Finally, 11 out of 43, or 47.83%, said that they had other reasons for not considering electric thermal storage. A large number of people, both in the space provided and over the phone, expressed some re-occurring concerns. One of the main concerns was to be sent more information concerning the technology. Some of these people even indicated that they were interested in learning of the results of this study. The fact that there was such an overwhelming interest in more information indicates that there is the possibility of an even higher percentage of interest than is reported here. Other than information questions, there were also a great deal of questions regarding the aesthetics of electric thermal storage. People seem to be very concerned about the units

disrupting the room that they heat by being unsightly. The last concern that was expressed most frequently was for an exact percentage rate for the financing options available. These questions and major concerns have no statistical basis, but are only impressions that were gotten from our data. There was no statistical analysis done on this data using the methods above.

All of the preceeding numbers and precentages indicate one thing. There is not one predominant reason why the customers surveyed would not consider electric thermal storage as a means of heating their homes. However, the relatively high percentages associated with lack of information and initial cost indicate that there is the need for more exposure to electric thermal and financing assistance of some kind.

The first five question on the questionnaire dealt solely with energy issues. The next six were designed to find out as much about the sample as possible. From this cross-section of the town, the demographics of the entire town were inferred. Relationships between these demographical characteristics and the interest in electric thermal storage were analyzed and noted in the next chapter. From the final six questions some very interesting characteristics presented themselves. The average number of bedrooms per household surveyed was 3.012 and the average number of other rooms such as kitchen, dining room, den or family room, was 4.316. Almost 96% of our sample owned their present residence and

84% of our sample have done so for more than 2 years. In addition, the age groupings were as follows: 25% of the 88 returns were between 18 and 35 years of age; 55.7% of the 88 returns were between 36 and 64 years of age; and only 14.8% of the 88 responses were over 65 years of age. Also, the income groupings were as follows: only 15.9% claimed their yearly income to be between \$10,000 and \$30,000; 37.5% claimed that their annual household income was between \$30,000 and \$60,000; and 36.4% claimed a household income of over \$60,000 a year (See Tables 5.9 - 5.15). All of these points combine to indicate that Holden is a young, well established, single family, residential community. These points also indicate, because the average age is so low, income is so high and there is such a high percentage of residential dwellings, that there is potential for the success of an electric thermal storage system.

Table 5.9 Frequencies of Question Six (Bedrooms)
(Number of Rooms)

NUMBER	FREQUENCY	PERCENT
1	1	1.1
2	22	25.0
3	36	40.9
4	23	26.1
5	1	1.1
No Response	5	5.7

Table 5.10 Frequencies of Question Six (Other Rooms)
(Number of Rooms)

NUMBER	FREQUENCY	PERCENT
2	6	6.8
3	17	19.3
4	21	23.9
5	17	19.3
6	10	11.4
7	4	4.5
8	1	1.1
No Response	12	13.6

Table 5.11 Frequencies of Question Seven

(Type of Home) CHOICE	FREQUENCY	PERCENT
Single Family	64	72.7
Townhouse	7	8.0
Apartment	2	2.3
Condominium	10	11.4
No Response	5	5.7
TOTAL	88	100.0

Table 5.12 Frequencies of Question Eight

(Period Lived in Current Residence) CHOICES	FREQUENCY	PERCENT
Less Than 2 Years	10	11.4
Between 2 and 10 Years	41	46.6
Over 10 Years	33	37.5
No Response	4	4.5
TOTAL	88	100.0

Table 5.13 Frequencies of Question Nine

(Rent or Own) CHOICES	FREQUENCIES	PERCENT
Rent	5	5.7
Own	79	89.8
No Response	4	4.5
TOTAL	88	100.0

Table 5.14 Frequencies of Question Ten

(Average Age of Bill Payer(s))

CHOICE	FREQUENCY	PERCENT
18 to 35	22	25.0
36 to 64	49	55.7
65 and Over	13	14.8
No Response	4	4.5
TOTAL	88	100.0

Table 5.15 Frequencies of Question Eleven

(Household Income)

CHOICE	FREQUENCY	PERCENT
\$10,000 to \$30,000	14	15.9
\$31,000 to \$60,000	33	37.5
\$60,000 and Above	32	36.4
No Response	9	10.2
TOTAL	88	100.0

The telephone interviews produced even more data to be considered. The questions that were asked on the telephone were also analyzed using SPSSX. The frequency of responses is

presented here.

The first question asked over the telephone (Question 12) was designed to determine the customers level of interest in electric thermal storage, based on the information provided by the informational letter. 34.1% of the people who responded to the questionnaire classified themselves as very interested in electric thermal storage. 33.0% classified themselves as somewhat interested in the technology. Only 3.4% responded that they were not interested in ETS at all. By adding the two positive response percentages, a comparison can be made between this question and question four on the questionnaire. The telephone interviews yielded an interest percentage of 67.0%, while the questionnaire yielded an interest percentage of 72.7%. This deviation can be attributed to the 29.5% who were not asked this question (See Table 5.16). If these people were omitted from the calculation of percentages, the telephone interview produced a much higher percentage of interest, 83.8%. This shows that, by allowing the customer to ask questions during the telephone interview, their interest substantially increased with the additional information. All things aside, interest in electric thermal storage is very high in the town of Holden.

Table 5.16 Frequencies of Question Twelve

(Level of Interest Over Telephone) CHOICE	FREQUENCY	PERCENT
Very Interested	30	34.1
Somewhat Interested	29	33.0
Not Interested	3	3.4
No Response	26	29.5
TOTAL	88	100.0

The second and third questions asked on the phone dealt with interest in several financing options. The second question (Question 13) asked if the customer would be interested in electric thermal storage if the town allowed them to pay for the systems in installments at a moderate interest rate. 29.5% of the people interviewed responded that they were very interested if given this option. 35.2% responded that they were somewhat interested in the technology if a moderate interest installment plan was offered. Adding these two percentages yeilds a 64.8% of interest if a moderate rate plan is offered. 14.8% responded that they were not interested if given this option, a substantial increase from the previous question. 20.5% were not asked this question because they could not be reached (See Table 5.17).

Table 5.17 Frequencies of Question Thirteen

(Interest in ETS if Moderate Interest Loan Offered)		
CHOICE	FREQUENCY	PERCENT
Very Interested	26	29.5
Somewhat Interested	31	35.2
Not Interested	13	14.8
No Response	18	20.5
TOTAL	88	100.0

The third question of the telephone interview (Question 14) dealt with the customers interest in electric thermal storage if they were offered the option of an installment plan at a 0% interest rate. 27.3% indicated that they would be more interested in the technology if this option was offered as opposed to the previous alternative. 19.3% considered themselves very interested if this option was offered. 18.2% classified themselves as somewhat interested if a 0% rate was offered. Adding these all together yeilds a percentage of 64.8% who are interested in this type of financing option, 27.3% of which prefer this option to the previous option. This percentage of interest is exactly the same as the percentage of interest if a moderate rate was to be offered. 14.8% were, again, not interested at all if a 0% installment plan was offered. Once again, 20.5% were not asked this question because they could not be

reached (See Table 5.18).

Table 5.18 Frequencies of Question Fourteen

(Interest in ETS if Zero or Low Percentage Loan Offered)

CHOICE	FREQUENCY	PERCENT
Even Better	24	27.3
Very Interested	17	19.3
Somewhat Interested	16	18.2
Not Interested	13	14.8
No Response	18	20.5
TOTAL	88	100.0

These findings were difficult to analyze because they were contrary to what was expected. From this data, it was determined that the type of financing plan had little effect on the interest in electric thermal storage. This was consistent with the concerns expressed in the questionnaire. It appeared from the questionnaire that the initial cost was a fairly significant concern. The financing options did nothing to reduce the initial cost, and, as a result, had very little effect on interest in electric thermal storage.

APPENDIX TWO

PASCOAG FIRE DISTRICT

Report to Customers

PASCOAG FIRE DISTRICT
ELECTRIC THERMAL STORAGE HEATING PROGRAM

TABLE OF CONTENTS

PAGE

1	Project Summary
2	Project Costs to Date
3	PFD Load Shapes
4	DOE News Letter
7	American TecnoTherm Brochure

PASCOAG FIRE DISTRICT ELECTRICAL THERMAL STORAGE (ETS)
PROJECT SUMMARY

June 12, 1991

The Pascoag Fire District recently installed an electrical thermal storage heating system at both the office and power station. The program, partially funded by a DOE grant through MMWEC, will be used to demonstrate and show the benefits of ETS as an alternate to regular electrical resistance heating. The units replace both existing and planned resistance heating installations.

Through this program, Pascoag will keep 40KW off its peak which is usually set during the evening hours in the month of December. 40KW calculates to approximately \$5000.00 savings per year in wholesale power costs. These savings will be passed on to all customers through our capacity charge. The ETS system will also be coordinated with the EMETCON load management system which will allow accurate peak shaving and valley filling thereby increasing our load factor.

The units will be available for inspection by customers who may wish to purchase ETS systems for their homes. We will also provide information to them in the form of a brochure which will explain the time-of-use rate, thermal storage heating, and list the manufactures of the ETS units. Customers who choose to install an ETS system will save money each month by shifting much of their KWH consumption to off peak periods. They may also qualify for a low interest loan through RISE which can be used for the installation.

The PFD has filed with the PUC and is presently testing a time-of-use rate to be used for this purpose. The time-of-use rate is actually two rates on one meter. During peak periods the rate is higher than off peak periods which encourages the customer to shift his usage to the off peak period. PFD'S peak period for the TOU rate is 3pm-9pm during summer months, 11am-1pm and 3pm-9pm during the winter months. The on peak energy charge is \$.0345 per KWH and the off peak charge is \$.0133 per KWH.

Total project costs to date are \$11840.27 of which \$6659.00 was paid for by the DOE grant.

PASCOAG FIRE DISTRICT ETS PROJECT COSTS

ETS EQUIPMENT	\$6,097.64
	\$1,100.00
OTHER ELECTRICAL EQUIPMENT	\$650.00
MISC	\$100.00

TOTAL EQUIPMENT	\$7,947.64
LABOR	\$3,892.63

TOTAL JOB COST	\$11,840.27
DCE GRANT	(\$6,659.00)
PFD ACTUAL COST	\$5,181.27

PASCOAG FIRE DISTRICT PROJECTED YEARLY SAVINGS ETS VS RESISTANCE HEATING

ETS KW POWER PLANT	21
ETS KW OFFICE	19
TOTAL KW	40
KW COST	\$125.00
SAVINGS	\$5,000.00

APPENDIX THREE

STERLING MUNICIPAL LIGHT DEPARTMENT

Electric Thermal Storage (ETS) Program Brochure

Do you....

heat your home
with electricity?

want to lower
your home
heating costs?

want to improve
your home's
energy efficiency?

Energy Efficient Light Distribution
Electric Thermal Storage Program
a component of Energy Management
Programs

If you answered **yes** to these questions, Sterling Municipal Light Department's Electric Thermal Storage (ETS) program is the answer for lower home heating costs, added comfort and improved efficiency.

The ETS program

The program, specially-designed to introduce electric heat customers to improved heating technology, offers heat storage system purchase and installation assistance. Sterling Municipal Light

- determines the size of the heat storage unit to meet your heating requirements
- prepares the quote including materials, installation and payback period
- places the order
- arranges for an electrical contractor to install the unit.

To help you invest in the system, the Clinton Savings Bank offers 0% financing with the support of the Sterling Municipal Light Department.

After you have installed the system, Sterling sends a monthly savings analysis so you can compare heating costs.

What is electric thermal storage heating?

Electric thermal storage heating is a system that literally stores and distributes heat in your home. The system takes advantage of lower electrical rates, because it's timed to go on at night when the rates are lowest. During this time, the electricity generates heat which is stored in thermal mass ceramic bricks in individual heaters. During the day when the electric rates are higher, the stored heat is released as needed into your home.

How does the system know how much heat needs to be stored?

The system automatically measures the outside temperature and adjusts the amount of heat to be stored. On a cold winter night, the heater is fully charged. During a cool spring or autumn night the system automatically adjusts and reduces the charge level.

How is the size of the unit determined?

The number and size of the individual heaters are based on the size of your home. Each heater is compact and designed to blend into the room's decor. In addition, each heater has its own thermostat so you select the desired temperature.

"I've never had a warmer house; the heat is so even and quiet. I'm thrilled with the system. You can't stress the benefit of off-peak electric pricing enough."

Kirk Bodwell, Sterling MA
Sterling Municipal Light
Department ETS customer
since October, 1988

The ETS program can help you save on your heating costs and help the department reduce its overall supply costs. Supply costs are based on our day time or peak demand so when you shift to off-peak use you are lowering daytime use and costs.

APPENDIX FOUR

ETS EQUIPMENT

Removed - copyrighted page -

ENDED

**DATE
FILMED**

3 / 17 / 92