


BNWL-CC--1367

DE92 003703

RADIOLOGICAL CONDITIONS IMMEDIATELY
FOLLOWING THE 9/29/65 PRTR INCIDENT (a)



D. McConnon (b)

Pacific Northwest Laboratory
Battelle Memorial Institute
Richland, Washington

<i>L.A. Rogers</i>	<i>35836</i>	<i>329</i>	October, 1967 MAY 11 1967

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

- (a) This paper is based on work performed under United States Atomic Energy Commission Contract AT(45-1)-1830. Permission to publish is gratefully acknowledged.
- (b) Supervisor, Radiation Monitoring

DISTRIBUTION RESTRICTED TO U.S. ONLY

402
MASTER

RADIOLOGICAL CONDITIONS IMMEDIATELY
FOLLOWING THE 9/29/65 PRTR INCIDENT



D. McConnon

INTRODUCTION

On September 29, 1965, radioactive contamination was released to the containment vessel and several reactor systems of PRTR when approximately 700 grams of fuel material was lost from a ruptured fuel rod. The containment vessel immediately went into ventilation containment and remained in this condition for approximately 19 hours. During this period, one brief personnel entry was made to collect an air sample. A complete radiological survey of operating areas was made about six hours after restoration of ventilation. This report summarizes the radiological conditions observed immediately following the incident until controlled shutdown of the reactor was achieved and the situation was controlled.

SUMMARY

A summary is presented of the radiological conditions observed inside and outside the PRTR containment vessel following the fuel rod and pressure tube ruptures of September 29, 1965. No attempt is made to discuss the data, only to preserve it for future reference and use.



MEASUREMENTS OUTSIDE THE 309 BUILDING (PRTR)

At 0645 on 9/29/65, approximately one and one-half hours after the incident, a series of check points were established on or near the road which encircles the 309 Building. Surveys of exposure rates were performed hourly at these check points. The locations of check points are given in Figure 1. The results of surveys performed at various intervals are given in Table 1. By 0300 on 9/30/65, the exposure rate at each check point was less than 1 mR/hour. (Note: The PRTR came out of containment at 0034 on 9/30/65 and established a flow at 0210.) The exposure rates decreased with an apparent half-life of approximately 4.5 hours. No surface contamination was detected on the ground or vehicles in the vicinity of the PRTR.

MEASUREMENTS INSIDE SERVICE BUILDING AND M & M WINGExposure Rates and Surface Contamination

The Radiation Monitor on duty at the time of the incident measured exposure rates of 30 mR/hour and 200 mR/hour in the control room and maintenance shop, respectively, at approximately 0530. The exposure rates in the Rupture Loop Annex Equipment Room were noted as being normal. The exposure rate at Manhole #2 was 200 mR/hour. Check points were established at the step-off pad and control room at 0815 and measurements were made at about half hour intervals until 0800 on 9/30/65. Other check points were established at 1515 on 9/29/65 in the M & M Wing and Service Building. The locations of the check points and the results of the initial surveys are given in Figure 2 and Table 2, respectively. The measured exposure rates decreased with an apparent half-life of 4.5 hours. No surface contamination was detected in the building outside of established Radiation Zones.

Airborne Contamination

Initial air samples collected in the control room by the Radiation Monitor on duty approximately one hour after the incident indicated an air concentration of $\sim 1 \times 10^{-6}$ $\mu\text{Ci/cc}$ of beta-gamma particulate contamination. Air samples were collected at one-half hour intervals starting at 0730 in the control room. The results of the air samples are presented in Figure 3. The radioactivity on the air samples decayed with an apparent half-life of 20 minutes. The initial air samples from the Rupture Loop Annex and Storage Basin indicated an air concentration of 3.1×10^{-7} $\mu\text{Ci/cc}$ and 2.2×10^{-8} $\mu\text{Ci/cc}$ respectively at 1445 on 9/29/65.

MEASUREMENTS INSIDE THE CONTAINMENT VESSELExposure Rates

The only indications of external exposure rates in the containment vessel, until a personnel entry was made at 1900 on 9/29/65, were RAM chamber recordings. The highest reading was obtained from a RAM chamber located in the Reactor Hall

on the steam drum enclosure. The readings from this chamber are plotted in Figure 4. An entry to the Reactor Hall was made at 1900 on 9/29/65. The exposure rate measured during this entry was 15 rad/hour including 4R/hour. The gamma component of this measurement agrees closely with the RAM chamber indication at 1900 hours. All other RAM chamber indications were below those of the chamber located in the Reactor Hall. Exposure rate measurements were obtained during personnel entries to various areas of the containment vessel to perform necessary functions. The time of the measurements and the results are given in Figure 5-11 and represent the first measurements taken at the indicated locations following the incident.

2. Surface Contamination

The first sample of smearable surface contamination was taken from the Reactor Hall floor at 2140 on 9/30/65. The radiation level measured from the sample was 80 mrad/hour and the radionuclides identified included ^{131}I , ^{133}I , ^{132}Te , ^{99}Mo and ^{140}La . A complete survey of the containment vessel was completed on 10/4/65. The levels of smearable contamination are given in Table 3. The major contaminants identified in the samples included those given above and ^{141}Ce , ^{136}Cs , and possibly ^{95}Zr - ^{95}Nb and ^{103}Ru .

3. Airborne Contamination

Four samples of the airborne iodine contamination in the Reactor Hall were collected while the vessel was in containment. Additional samples were collected after the vessel was taken out of containment. The results of airborne iodine samples are given in Table 4, for the period of time between the event and the morning of 10/1/65.

The apparent discrepancies between the results of the samples collected at 0700 and 1700 on 9/29/65 and the samples collected at 1900 on 9/29/65 may be explained by the fact that the first two samples were collected remotely from the Reactor Hall and the third sample was collected in the Reactor Hall during a personnel entry while the reactor was still in containment.

Filter samples of airborne beta-gamma contamination were collected in the Reactor Hall after the vessel was taken out of containment. The results of these samples are summarized in Table 5.

Samples of possible airborne tritium contamination were collected on 9/30/65 and 10/1/65. The results of these samples indicated a tritium concentration of 2×10^{-6} $\mu\text{Ci/cc}$ and 8×10^{-7} $\mu\text{Ci/cc}$ respectively which represent normal levels at the locations sampled.

TABLE 1
MEASURED EXPOSURE RATES AT
CHECK POINTS ESTABLISHED OUTSIDE THE PRTR

(Refer to Figure 1)

Units of mR/hr

<u>DATE</u>	<u>TIME</u>	<u>#1-SE CORNER OF 300 FENCE</u>	<u>#2-SW CORNER OF OF 308</u>	<u>#3-ROAD BETWEEN 308 & 309</u>	<u>#4 ROAD NEAR DUMP CONDENSER</u>	<u>#5-ROAD S OF 309</u>	<u>#6-ROAD AT 318</u>	<u>#7 RLT-2 HOLD UP TANK</u>
9/29/65	0645	22	26	40	70	40	5	
	0800	18	20	35	45	30	4	
	0910	16	17	37	42	15	2	
	0950	13	13	30	35	12	<1	
	1100	11	11	26	29	10	<1	10
	1200	9	9	22	24	8	<1	7
	1300	8	8	19	21	7	<1	7
	1400	6	6	15	19	6	<1	6
	1500	6	6	14	16	5	<1	4
	1600	5	5	12	15	5	<1	4
	1700	4	4	11	13	4	<1	4
	1800	4	4	11	12	4	<1	3
	1900	4	4	10	11	3	<1	3
	2000	3	3	9	10	3	<1	3
	2100	3	3	8	9	3	<1	2
	2200	3	3	7	8	2	<1	2
	2300	2	2	6	7	2	<1	2
2400	2	2	5	6	2	<1	<1	
9/30/65	0100	2	2	4	4	4	<1	<1
	0200	1	1	1	1	1	<1	<1
	0300	<1	<1	<1	<1	<1	<1	<1
	0400	<1	<1	<1	<1	<1	<1	<1
	0500	<1	<1	<1	<1	<1	<1	<1
	0600	<1	<1	<1	<1	<1	<1	<1
	0700	<1	<1	<1	<1	<1	<1	<1

Note: All measurements after 0910, 9/29/65, made using same CP meter at same location.

MEASURED EXPOSURE RATES AT
CHECK POINTS ESTABLISHED INSIDE THE PRTR

(Refer to Figure 2)

<u>DATE</u>	<u>TIME</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>5</u>	<u>6</u>	<u>7</u>	<u>8</u>	<u>9</u>
9/29/65	0815	20	45							
	0850	18	40							
	0950	14	33							
	1023	14	30							
	1052	12	24							
	1125	11	22							
	1210	9	20							
	1300	9	20							
	1415	6	13							
	1445	5	12							
	1515			1	5	8	1	2	8	
	1600	4	10	1	3	7	1	5	9	
	1630	4	9							
	1700	4	9	1	4	7	2	4	7	
	1730	3	8							210
	1800	2	7	1	2	5	1	3	5	
	1900	1	6							
	2000	1	5	<1	2	5	<1	3	5	
	2100	1	5							
	2200		5							
	2230			<1	1	3	<1	1	3	120
	2300	1	5							
	2400	1	5	<1	<1	<1	<1	<1	<1	100
	9/30/65	0100	<1	3						
0130		<1	3	<1	<1	<1	<1	<1	<1	33
0200		<1	3							
0230										7
0300		<1	2							
0400		<1	<1							
0800		<1	<1	<1	<1	<1	<1	<1	<1	< 1

TABLE 3

SMEARABLE CONTAMINATION LEVELS
IN THE CONTAINMENT VESSEL ON 10/4/65

<u>Location</u>	<u>Radiation Level from Smearable Contamination</u>
Reactor Hall Floor	25 mrad/hour including 2 mR/hour
Reactor Hall Walls	2500 c/m
-11 ft. C-Cell floor	40 mrad/hour including 3 mR/hour
-21 ft. C-Cell floor	130 mrad/hour including 3 mR/hour
Stairwell Walls	5000 c/m
-32 ft. C-Cell floor	500 mrad/hour including 13 mR/hour
-32 ft. B-Cell floor	160 mrad/hour including 4 mR/hour
-32 ft. A-Cell floor	34 rad/hour including 1.2 R/hour

TABLE 4AIRBORNE IODINE CONCENTRATIONS IN THE REACTOR HALL

<u>SAMPLING DATE AND TIME</u>		<u>^{131}I</u>	<u>^{133}I</u>	<u>^{135}I</u>
9/29/65	0700	3×10^{-5}	3×10^{-4}	7×10^{-4}
9/29/65	1430	6×10^{-5}	3×10^{-4}	--
9/29/65	1700	3×10^{-5}	2×10^{-4}	6×10^{-5}
9/29/65	1900	5×10^{-5} *	2×10^{-4} *	1×10^{-4} *
9/30/65	2030	4×10^{-8}	1×10^{-7}	--
10/1/65	0525	9×10^{-9}	1×10^{-8}	--

* Average of two samples.

Note: Results for 9/29/65 were taken while the reactor was still in containment.

TABLE 5AIRBORNE CONCENTRATION OF GROSS
BETA-GAMMA EMITTING RADIONUCLIDES

<u>SAMPLING DATE AND TIME</u>		<u>CONCENTRATION - $\mu\text{Ci/cc}$</u>
9/30/65	0630	2×10^{-5}
10/1/65	0900	9×10^{-7}
10/2/65	0915	7×10^{-7}
10/3/65	1100	2×10^{-7}

FIGURE 1

Location of Check Points Outside the PRTR

Refer to Table 1 for results





FIGURE 2

Location of Check Points Inside the PRTR


Refer to Table 2 for results



BETA, GAMMA PARTICULATE AIR CONCENTRATION - $\mu\text{Ci}/\text{cc}$

FIGURE 3

Beta, Gamma Particulate Air Concentration
Measured in the Control Room



TIME ON 9/29/65

SEMI-LOGARITHMIC 358-63
NEUFEL & ESSELE, CO. PATENTED U.S.A.
2 CYCLES X 110 DIVISIONS

EXPOSURE RATE - R/hr




FIGURE 4

Exposure Rates in the Reactor Hall
Based on the Readings from RHM Chamber #5

9/29/65

9/30/65

FIGURE 5

Initial Exposure Rate Measurements Taken
in the Reactor Hall Following the Incident




FIGURE 6

Initial Exposure Rate Measurements
Taken in the -11 ft. Level of "C" Cell Following the Incident




FIGURE 7

Initial Exposure Rate Measurements
Taken in the -21 ft. Level of "C" Cell Following the Incident




FIGURE 8

Initial Exposure Rate Measurements
Taken in the -32 ft. Level of "C" Cell Following the Incident




FIGURE 9

Initial Exposure Rate Measurements
Taken in the -32 ft. Level of "A" Cell
Following the Incident





FIGURE 11

Initial Exposure Rate Measurements
Taken in "B" Cell Following the Incident



DISTRIBUTION

G. D. Carpenter

J. R. Fishbaugher

W. L. Fisher

G. A. Halseth

D. Hammer

K. R. Heid - 2

R. L. Junkins

G. E. King


D. McConnon

R. H. Purcell

H. G. Ruppert

R. F. Warnick

K. L. Young

Technical Information (3) 

Extra - 4

END

**DATE
FILMED**

01/17/92

I

