BASES FOR PUMP PIT REQUIREMENTS CALCULATIONS (U)

WSRC-RP--92-302

by R. A. Jacobs

DE93 003377

Westinghouse Savannah River Company
Savannah River Site
Aiken, South Carolina 29808

Other Authors:

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Received 0977

NOV 27 1992

This paper was prepared in connection with work done under Contract No. DE-AC09-89SR18035 with the U. S. Department of Energy. By acceptance of this paper, the publisher and/or recipient acknowledges the U. S. Government's right to retain a nonexclusive, royalty-free license in and to any copyright covering this paper, along with the right to reproduce and to authorize others to reproduce all or part of the copyrighted paper.

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

for

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831; prices available from (615) 576-8401, FTS 626-8401.

Available to the public from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

Westinghouse
Savannah River Company

INTER-OFFICE MEMORANDUM

WSRC-RP-92-0302

Keywords: DWPF, pump pits,
benzene, hydrogen,
Process Requirements

Retention period: Permanent

cc: J. M. Gillam, 704-27S
M. R. Norton, 704-27S
N. E. Bibler, 773-A
D. D. Walker, 773-A
L. F. Landon, 704-T
SRL Records (4)*

February 13, 1992

TO: E. W. HOLTZSCHEITER, 773-A

FROM: R. A. JACOBS, 704-T

A handwritten signature in cursive script, likely belonging to R. A. Jacobs.

BASES FOR PUMP PIT PROCESS REQUIREMENTS CALCULATIONS (U)

Summary

A task team is preparing the Process Requirements for the interarea transfer pump pits. The team is developing requirements to prevent flammable mixtures from forming and requires values to use on the generation of various components such as benzene, hydrogen, and N₂O. The purpose of this memorandum is to document values to be used and to provide sample calculations using these values. There are no recommendations contained in this document.

Note: All vapor concentrations are in volume percent.

Hydrogen Generation from the Sludge Pump Pit Tank

Hydrogen is generated from sludge by radiolysis.[1] The rate of H₂ formation is estimated using a G value of 0.45 molecules/100eV (recommended by the NRC[2]) and a specific activity for the sludge of 0.44 watts/gal (five year out-of-reactor sludge).[3,4]

A handwritten signature in cursive script, likely belonging to T. Carter.

T. Carter, 704-1T
Authorized Derivative Classifier

Assuming 6500 gallons sludge and allowing for 50% higher activity than in the curie balance, the hydrogen formation rate in the solution is

$$6500 \text{ gal} \times \frac{1.5 \times 0.44 \text{ watts}}{\text{gal}} \times \frac{2.25 \times 10^{22} \text{ eV}}{\text{watt-hr}} \times \frac{0.45 \text{ molecules}}{100 \text{ eV}} \\ \times \frac{1 \text{ gmol}}{6.023 \times 10^{23} \text{ molecules}} \times \frac{1 \text{ lbmol}}{453.6 \text{ gmol}} \times \frac{359 \text{ scf}}{\text{lbmol}} = 0.57 \text{ scfh}$$

where standard conditions are 0°C and 14.7 psia.

A conservative estimate of the evolution is that it is equal to the rate of formation in the liquid. This does not take into account that nitrate ions will react with H₂ precursors.[1] Also not included are effects of H₂ solubility, diffusion, and mass transfer. Actual generation rates from the liquid surface will be significantly lower, perhaps by a factor of two or three.

Hydrogen Generation from the Precipitate Slurry

Hydrogen is also generated from the precipitate slurry. The G value is 0.46 molecules/100 eV [5] and the specific activity from the curie balance is 0.17 watts/gal [3,4] for 15 year out-of-reactor saltcake (36 Ci/gal Cs-137, 71 Ci/gal total). Allowing for 50% higher activity, the calculation for 6500 gallons precipitate slurry is

$$6500 \text{ gal} \times \frac{1.5 \times 0.17 \text{ watts}}{\text{gal}} \times \frac{2.25 \times 10^{22} \text{ eV}}{\text{watt-hr}} \times \frac{0.46 \text{ molecules}}{100 \text{ eV}} \\ \times \frac{1 \text{ gmol}}{6.023 \times 10^{23} \text{ molecules}} \times \frac{1 \text{ lbmol}}{453.6 \text{ gmol}} \times \frac{359 \text{ scf}}{\text{lbmol}} = 0.23 \text{ scfh}$$

Minimum O₂ for Combustion (MOC) for H₂/Benzene Mixtures

The Precipitate Pump Tank (PPT) will be purged with N₂ and the O₂ concentration measured to ensure that insufficient O₂ is present for combustion; that is, it will be maintained below the MOC of 11.4% O₂ for combustion of benzene in air with N₂ as diluent.[6] Under normal conditions, N₂ purge flows through the PPT should be at least 20 scfm. From the above estimation of 0.23 scfh H₂ generation, the expected H₂ at normal conditions would be < 0.02%. At this concentration, the H₂ will have essentially no affect on the MOC for benzene.

However, loss of the Process Vessel Vent System (PVVS) will result in much reduced flows. If this occurs, DWPF will provide a minimum air flow to prevent buildup of H₂. Since the MOC for H₂ in air (with N₂ as diluent) is only 5%[6], the presence of H₂ will serve to reduce the MOC of the of the mixed fuel. Previous

flammability studies recommended using an MOC of 9.0% O₂ for fuel mixtures containing up to a 90/10 ratio of benzene to H₂. [7] The composite LEL of a mixture can be estimated by

$$LEL_{comp} = \frac{100}{\frac{C_1}{L_1} + \frac{C_2}{L_2}}$$

where C_n = concentration of fuel n as % of total oxidants
 L_n = LEL for fuel n.

For $C_1 = 90\%$, $L_1 = 1.3\%$ [8], $C_2 = 10\%$, and $L_2 = 4.0\%$,

$$LEL_{comp} = \frac{100}{\frac{90}{1.3} + \frac{10}{4.0}} = 1.394\%$$

Therefore an MOC of 9.0% O₂ can be used for a H₂ concentration up to 0.14%. At 0.23 scfh of H₂, a minimum N₂ purge rate of 3 scfm would dilute the H₂ to approximately 0.13%.

N₂O Generation in the PPT

The recently proposed mechanism for nitrite radiolysis in precipitate slurry predicts N₂O formation. N₂O has been detected in the vapor space over irradiated simulant slurries. The question was raised whether the N₂O produced might be enough to affect the MOC for benzene in air. A bounding estimate can be made as follows[9]:

Bases: One mole N₂O forms from two moles nitrite
 Nitrite radiolysis is 0.013 gmols/liter-month

$$\begin{aligned} &6500 \text{ gal} \times \frac{0.013 \text{ gmols nitrite}}{\text{liter slurry-month}} \times \frac{1 \text{ mol N}_2\text{O}}{2 \text{ mols nitrite}} \times \frac{3.785 \text{ l}}{\text{gal}} \\ &\times \frac{1 \text{ month}}{730 \text{ hrs}} \times \frac{1 \text{ lbmol}}{453.6 \text{ gmol}} \times \frac{359 \text{ scf}}{\text{lbmol}} = 0.173 \text{ scfh N}_2\text{O} \end{aligned}$$

At typical purge flows of 20 scfm or greater, the N₂O concentration would be less than 0.015%. If a minimum purge flow of 3 scfm is provided, the N₂O concentration would be < 0.1%. At this concentration the N₂O would have essentially no effect on the MOC for benzene and air.

Thermal Decomposition of Tetraphenylborate (TPB) Slurries

Thermal stability studies of potassium tetraphenylborate slurries have been conducted.[10,11,12] At 90°C, the decomposition of KTPB produces approximately 450 μgms benzene/day-g KTPB.[10] Assuming 10% KTPB with $S_g = 1.03$,

$$\begin{aligned}
 & \frac{0.1 \text{ lbs KTPB}}{\text{lb slurry}} \times 1.03 \times \frac{8.33 \text{ lbs slurry}}{\text{gal slurry}} \times \frac{453.6 \text{ gms}}{\text{lb}} \\
 & = 389 \frac{\text{gms KTPB}}{\text{gal slurry}} \\
 \text{therefore, } \frac{d[\text{benz}]}{dt} & = \frac{450 \text{ } \mu\text{gms benz}}{\text{day-g KTPB}} \times \frac{1 \text{ gm}}{10^6 \text{ } \mu\text{gm}} \times \frac{389 \text{ gms KTPB}}{\text{gal slurry}} \\
 & \times \frac{1 \text{ day}}{24 \text{ hrs}} = \frac{0.0073 \text{ gm benz}}{\text{hr-gal}}
 \end{aligned}$$

By comparison, the production of benzene by radiolysis has been measured to be 0.0015 gm benz/hr-gal.[13] The estimated benzene production rate by thermal decomposition at 90°C is about five times greater than by radiolysis. The total benzene production rate by thermal decomposition at 90°C plus radiolysis would be

$$6500 \text{ gal} \times \left(\frac{0.0073 \text{ gm}}{\text{hr-gal}} + \frac{0.0015 \text{ gm}}{\text{hr-gal}} \right) \times \frac{1 \text{ lb}}{453.6 \text{ gm}} = 0.13 \text{ lbs/hr.}$$

To put this number in perspective, the design benzene rate for the pump pit PVVS is 25 lbs/hr.

Precipitate Temperature Limit in an Air Purged Tank

In reference 13, calculations were presented showing how benzene can be purged from precipitate slurries over time. These calculations included benzene generation by radiolysis but assumed normal operating temperatures; that is, no allowance was made for benzene generation by thermal decomposition. (At expected temperatures, thermal decomposition is negligible.) DWPF has a contingency plan which involves steam jet transfer of the precipitate slurry to the Recycle Pump Tank (RPT) in the event the PPT transfer pump is not operable. Since the RPT is not N₂ purged, the plan first involves stirring and purging the benzene from the precipitate in the PPT prior to transfer. The calculations indicated the precipitate can then be safely transferred to the RPT as long as it is stirred occasionally to prevent benzene buildup. DWPF is aware of the necessity to monitor precipitate temperature under these conditions.

Quality Assurance

All the above discussion is based on a thorough analysis of published, reliable scientific data. The discussion is intended to provide ready reference and sample calculations for the team preparing the DWPF Pump Pit Process Requirements. The calculations in this document were checked by L. F. Landon.

References:

1. N. E. Bibler, RADIOLYTIC H₂ PRODUCTION FROM DWPF SLUDGE FEED SOLUTION, DPST-83-373, March 17, 1983.
2. Nuclear Regulatory Commission Guide 1.7, Revision 2, November 1978.
3. J. R. Fowler, DWPF ISOTOPIC DATA, DPST-84-971, February 21, 1985.
4. DWPF BASIC DATA REPORT, Rev. 91, DPSP-80-1033.
5. D. D. Walker, RADIOLYSIS OF TETRAPHENYLBORATE: UNIVERSITY OF FLORIDA TRIP REPORT, DPST-84-827, October 18, 1984.
6. National Fire Codes, NFPA 69, EXPLOSION PREVENTION SYSTEMS, 1986.
7. R. A. Jacobs, FLAMMABILITY OF VAPOR MIXTURES FROM IN-TANK PRECIPITATION, DPST-88-573, October 28, 1988.
8. National Fire Codes, NFPA 325M, FIRE HAZARD PROPERTIES OF FLAMMABLE LIQUIDS, GASES, AND VOLATILE SOLIDS, 1984.
9. Personal communication with D. D. Walker, February, 1992.
10. Electronic mail message from D. D. Walker, February 6, 1992, copy attached.
11. Analytical Report, D. J. Coffin and S. R. Laas, Polymer Products Dept., Experimental Station, E. I. Dupont de Nemours & Co., to W. V. Wright, Savannah River Laboratory, "QUANTITATION OF VOLATILES IN HEADSPACE OVER SIMULATED WASTE SLURRIES, Job #820-1316, PRAL Nos. 82-7120-7122," April 20, 1983.
12. Analytical Report, D. J. Coffin, Polymer Products Dept., Experimental Station, E. I. Dupont de Nemours & Co., to D. D. Walker, Savannah River Laboratory, "QUANTITATION OF BENZENE IN HEADSPACE OVER SIMULATED WASTE SLURRIES, Job #331-585, PRAL Nos. 83-4045-4047," September 27, 1983.
13. R. A. Jacobs and D. D. Walker, BENZENE EVOLUTION FROM PRECIPITATE SLURRY PUMP PIT TANKS, WSRC-TR-91-0478, August 15, 1991.

END

DATE
FILMED

4 / 7 / 93