Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
**Reactor Engineering
Division**
**Reactor Engineering
Division**
**Reactor Engineering
Division**
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division

ANL/RE-91/2
Volume 1

Received OSTI
JAN 29 1992

A Fast Reactor Transient Analysis Methodology for PCs: Volume 1. The Computational Model

by K. O. Ott

Argonne National Laboratory, Argonne, Illinois 60439
operated by The University of Chicago
for the United States Department of Energy under Contract W-31-109-Eng-38

Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

Argonne National Laboratory, with facilities in the states of Illinois and Idaho, is owned by the United States government, and operated by The University of Chicago under the provisions of a contract with the Department of Energy.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government, nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Reproduced from the best available copy.

Available to DOE and DOE contractors from the
Office of Scientific and Technical Information
P.O. Box 62
Oak Ridge, TN 37831
Prices available from (615) 576-8401, FTS 626-8401

Available to the public from the
National Technical Information Service
U.S. Department of Commerce
5285 Port Royal Road
Springfield, VA 22161

Argonne National Laboratory
9700 South Cass Avenue
Argonne, Illinois 60439

**A Fast Reactor Transient Analysis Methodology
for PCs:
Volume 1. The Computational Model**

by

K. O. Ott
School of Nuclear Engineering
Purdue University
West Lafayette, Indiana 47907

Prepared for
Reactor Engineering Division
Argonne National Laboratory

October 1991

MASTER

SP

Table of Contents

Abstract	1
I. Introduction	2
II. Calculation of the Fission Power	4
II.1 Unified Description of Delayed Neutrons, Decay Heat and Delayed Feedback ...	4
II.2 Source Multiplication Formula for the Fission Power	5
II.3 The Finite Difference Formulation	8
II.4 The Quadratic Reactor Dynamics Equation	12
III. Description of the Feedback Reactivity	15
III.1 Temperature Changes in an Average Core Channel	15
III.2 The Feedback Reactivity	18
III.3 The Feedback Reactivity for the Quadratic Dynamics Equation	22
IV. Temperature in the Coolant Loop and Pools	24
IV.1 The Coolant Loop Model	24
IV.2 Temperatures of the Pool Components	25
IV.3 Temperatures in the Hot Pool (HP) and the Control Rod Drive Line	28
IV.4 Outlet Temperature of the Intermediate Heat-Exchanger	29
IV.5 The Sodium Pool Temperatures During LOF Transients	30
V. Quasistatic Approximations of Transients Phenomena	31
V.1 General Discussion	31
V.2 Quasistatic Approximation in Reactor Dynamics	32
V.3 Quasistatic Features in the LTC Model	33
VI. Numerical Results	34
VI.1 Time Steps and Computation Time	34
VI.2 Accuracy of the Power Trajectory	34
VI.3 Maximum Reactivities	37
Summary	38
Appendix A: Numerical Treatment of Convolution Integrals	39
Appendix B: LTC: LMR Transient Calculation Code	42
Acknowledgements	43
References	43

List of Figures

Fig. 1	Primary coolant loop model	24
Fig. 2	Reactivity as function of time for several TOP cases	37

List of Tables

Table I	Feedback Coefficients	19
Table II	Feedback Convolution Integrals	21
Table III	Accuracy of the Power Calculation	35

**A Fast Reactor Transient Analysis Methodology
for PCs:
Volume 1. The Computational Model**

by

K. O. Ott

Abstract

The simplified ANL model for LMR transient analysis, in which point kinetics as well as lumped descriptions of the heat transfer equations in all components are applied, is converted from a differential into an integral formulation. All differential balance equations are implicitly solved in terms of convolution integrals. The prompt jump approximation is applied as the strong negative feedback effectively keeps the net reactivity well below prompt critical.

After implicit finite differencing of the convolution integrals, the kinetics equation assumes the form of a quadratic equation, the "quadratic dynamics equation." This model forms the basis for GW-BASIC program, LTC, for LMR Transient Calculation program, which can effectively be run on a PC. The GW-BASIC version of the LTC program is described in detail in Volume 2 of this report.

I. Introduction

Traditionally, transient analyses for LMR safety investigations require the application of large code systems, such as the Safety Analysis System, SAS (e.g. Refs. 1-3). These programs are written for main-frame computers involving in earlier versions typically 10,000 and in later more sophisticated versions more like 100,000 lines of coding. The physical phenomena encountered during the classical "unscrammed" transients, such as TOP (Transient Over-Power), LOF (Loss of Flow) and LOHS (Loss of Heat Sink), are modeled in these codes in great detail.

Generic problems with such large codes are the verifiability and the interpretation of the results. An experimental verification is rather indirect and more qualitative in nature, and is therefore applicable only to the investigation of major uncertainties in physical models. The more direct verification is within the computational model development itself. In addition to meticulous testing of isolated portions of the program, the interpretation and the plausibility of the results play a crucial and independent role. Such a detailed code verification generally requires the broad expertise of an actual code developer.

The results of transient analyses affect a large variety of activities, ranging from conceptual to actual design, safety reviews and licensing evaluations, to applications in off-normal operations management. To support these activities it is desirable to have a simpler and more transparent transient analysis model available (*J.F. Marchaterre*⁴, *J.E. Cahalan*⁵). This paper addresses the development and application of such a model for transients in which the reactor does not become prompt or superprompt critical. This comprises most of the range of transients of interest in the safety analysis of a modern LMR (Liquid Metal Cooled Reactor), which are the basis of the IFR (Integral Fast Reactor) program (see Sec II.2).

The two *major approximations* that are consistently applied in the presented model development are:

- the neglect of any temporal variations of *spatial* distributions of neutron flux (point-reactor model), of power, temperature and flow distributions *within* the various components, applying the simplified LMR transient analysis model, formulated by J. E. Cahalan⁶, and
- the prompt jump approximation (PJA) to the neutron flux and power calculation.

In addition to these basic approximations, refined mathematical formulations are employed in the solution of the kinetics and heat transfer equations:

The *differential* kinetics equations are cast into the form of *integral* equations which represent an *implicit solution* for the fission power; the fission power is expressed by an arrangement of convolution integrals over the fission-power "history" yielding the "integral kinetics equations" (see Sec. II.2). This formulation employs a unified description of the delayed neutron source, of decay heat and of the delayed feedback reactivity (see Sec. II.1).

Solving this initial value problem requires advancing the convolution integrals step-by-step, applying previously calculated power values. An implicit scheme is applied for this step-by-step advance (see Sec. II.3 and App. A). The fission power is obtained as a solution of a *quadratic equation* in which the coefficients depend only on the neutron flux (or power) history (see Sec. II.3).

The formulation of the reactor dynamics equations as a *quadratic equation* for the fission power hinges on description of the various *delayed* reactivity feedback components by convolution integrals. Section III is devoted to this feedback reactivity description. The flow loop and the associated temperature calculations are presented in Sec. IV.

Section V addresses the question of a gradual realization of quasistatic approximation of feedback reactivities, of delayed neutron groups and of decay heat contributions. Several levels of "quasistatic" approximations are investigated and criteria are given for their applicability.

The simplifications listed above together with the implicit mathematical formulations and the unified description of delayed neutrons, feedback delays and decay heat yield a concise and lucid form of the transient mathematics. As large time steps (typically one to many seconds) can be employed in this algorithm, the entire computation time is reduced considerably compared to the requirements of a program solving the underlying differential equations by finite differences. Then, these transient analyses can be readily performed on a Personal Computer. A program for an IBM XT, written in GW-BASIC, is briefly outlined in App. B. It comprises about 1200 lines of coding. Details are presented in a Manual, Ref. 7. A version in C has been programmed by M. E. Boerner (Ref. 8).

Some computational results are presented in Sec. VI., "Numerical Investigations." All questions addressed in Sec. VI pertain to the model, its accuracy and its possible limitations resulting from the prompt jump approximation. A summary of the main results concludes the paper.

II. Calculation of the Fission Power

II.1 Unified Description of Delayed Neutrons, Decay Heat and Delayed Feedback

The possibility of a unified description of the production of delayed neutrons, of decay heat and of delayed feedback reactivity in the various reactor components comes from the fact that all these phenomena can be described in a good approximation by the same type of ordinary differential equations. Although the *general* balance equations of the phenomena are partial differential or integro-differential equations in *space* and time, in the relatively compact core of an LMR as well as in its various structural components, the space dependencies of the power and temperature distributions are invariable with time in a good approximation. Therefore, these distributions can all be *lumped* into "point" quantities. This then leads to inhomogeneous, first order differential equations, with constant coefficients and time dependent sources or forcing functions, as outlined in the following:

Delayed neutrons are emitted after β -decay of precursors, which had been for prior fissions across the core. In a relatively small LMR the spatial distributions of the precursor populations during a transient are virtually constant in time. Thus, the "lumped" precursor population can be described by a time-function alone. Let $\zeta_k(t)$ denote the lumped precursors of delay-group k , i.e., their lumped density distribution divided by the lumped nominal fission rate (see Ref. 9 for the detailed derivation and the definition of all terms). In the balance equations the rate of change equals the production minus the decay rates:

$$\dot{\zeta}_k(t) = -\lambda_k \zeta_k(t) + \beta_k p_f(t), \quad (\text{for } k = 1 \cdots 6). \quad (1)$$

In Eq. (1), λ_k is the decay constant and β_k the (effective) precursor fraction for delay-group k ; $p_f(t)$ is the relative fission power. Equation (1) is a direct consequence of the main assumption of the "point" reactor model, the invariability of the flux shape with time.

Decay heat results from the energy of electrons and associated gamma rays that are emitted in β -decays of a fission product nuclei. Again, these fission products, which have been produced in prior fissions across the core, have a nearly invariable space distribution during a transient. They can therefore be lumped in the same way as the delayed neutron precursors. Six effective groups with different time constants, λ_k , appear to be adequate to describe the variation of the decay heat during transients. Let $h_k(t)$ be the relative latent energy in decay-heat group k . The balance equation is fully analogous to Eq. (1):

$$\dot{h}_k(t) = -\lambda_k h_k(t) + \beta_k p_f(t) \quad (\text{for } k = 7 \cdots 12), \quad (2)$$

with β_k ($k = 7 \cdots 12$) being the fraction of fission product energy deposited in decay-heat group k .

Reactivity Feedback is caused essentially by two phenomena, Doppler broadening of nuclear resonances and thermal expansion of coolant and of various structural elements. Other feedback phenomena as they result from boiling or material motion do not appear in the class of transients considered in this analysis. Doppler broadening requires the heat-up of the fuel rods, thermal expansion effects result from the heat-up of the sodium coolant or of structural elements such as load-pads, control-rod drive line, grid-plate or vessel.

Assuming the space dependencies of the temperature fields across the core and within each of the components to be independent of time allows a lumping of the partial differential equations into ordinary (first order) differential equations for the changes of the respective average temperatures:

$$\delta \dot{T}_k(t) = -\lambda_k \delta T_k(t) + \lambda_k D_k(t) \quad (\text{for } k > 12) . \quad (3)$$

In Eq. (3), λ_k is a time constant for heat transfer and $D_k(t)$ is the driving or forcing function of the dimension of a temperature.

II.2 Source Multiplication Formula for the Fission Power

II.2.1 The Integral Equation for the Fission Power

As discussed in the Introduction, the reactivity variations considered in this analysis are below 1\$. Furthermore, the practically possible reactivity variation *rates* are small as they require some mechanical motion. Therefore, the prompt jump approximation (PJA) of the point kinetics equation for the relative fission power, $p_f(t)$, is highly accurate for these transients as the extremely small magnitude of $\Lambda \dot{p}_f(t)$ does practically not affect the solution of the kinetics equation. Here, Λ is the mean neutron generation time, $\dot{p}_f(t)$ the derivative of the relative fission power.

The kinetics equation

$$\Lambda \dot{p}_f(t) = [\rho(t) - \beta] p_f(t) + s_d(t) + s \quad (4a)$$

can then be approximated by their PJA-form:

$$0 = [\rho(t) - \beta] p_f(t) + s_d(t) + s \quad (4b)$$

In Eqs.(4), $\rho(t)$ is the reactivity, β the effective delayed neutron fraction and $s_d(t)$ is the relative delayed neutron source, which results from the radioactive decay of the six groups of precursors, and s is an independent source of the dimension of a relative power.

The precursor balance equations [(Eqs. (1))] can be formally solved, expressing $\zeta_k(t)$ by a convolution integral over the fission power. The decay rate ($\lambda_k \zeta_k$) of all precursor groups gives the delayed neutron source:

$$s_d(t) = \sum_{k=1}^6 \lambda_k \int_{-\infty}^t \beta_k p_f(t') e^{-\lambda_k(t-t')} dt' . \quad (5)$$

The integral describes the precursor population at time t , composed of the earlier production rate, $\beta_k p_f(t')$, times the probability (given by the exponential function) that the precursors produced at time t' are still present at time t .

The kinetics equation for the PJA, Eq. (6), allows us to express $p_f(t)$ in terms of a *time dependent source multiplication formula* (Ref. 9):

$$p_f(t) = \frac{s_d(t) + s}{\beta - \rho(t)} = \frac{1}{\beta - \rho(t)} \left[\int_{-\infty}^t K_{dn}(t-t') p_f(t') dt' \right] . \quad (6)$$

Equation (6) is an implicit solution for $p_f(t)$, as it still contains $p_f(t')$ on the right side under the convolution integral as well as in the feedback reactivity component of $\rho(t)$. This formula is being used for a stepwise advance of $p_f(t)$, employing the earlier calculated $p_f(t')$ values under the convolution integral (and in the reactivity as well). The function $p_f(t')$ has to be extrapolated through the last time interval in the intergrands of the convolution integrals.

In order to obtain the relative *total* power the decay heat rate $p_{dh}(t)$, has to be added to the fission power, $p_f(t)$:

$$p(t) = p_f(t) + p_{dh}(t) . \quad (7)$$

Summing up the implicit solutions of Eqs. (2) gives for the decay heat rate

$$p_{dh}(t) = \sum_{k=7}^{12} \beta_k \lambda_k \int_{-\infty}^t p_f(t') e^{-\lambda_k(t-t')} dt' . \quad (8)$$

Thus, the total power is obtained as

$$p(t) = \frac{1}{\beta - \rho(t)} \left[\sum_{k=1}^6 \beta_k \lambda_k \int_{-\infty}^t p_f(t') e^{-\lambda_k(t-t')} dt' + s \right] + \sum_{k=7}^{12} \beta_k \lambda_k \int_{-\infty}^t p_f(t') e^{-\lambda_k(t-t')} dt' . \quad (9)$$

One generally assumes a stationary state prior to the onset of a transient at $t = 0$. Equation (9) applied to $t = 0$ with $\rho(t) = 0$ for $t \leq 0$ and $p_f(t' \leq 0) = p_{fo}$, being constant yields initially

$$p_0 = (1 + \beta_h) p_{fo} , \quad (10)$$

where β_h is the decay heat fraction that is added to the initial fission power. The miniscule spontaneous fission source (of about 10mW, see below) is neglected in the initial condition, as it does not affect the first eight digits.

II.2.2 Feedback Description

The total power, $p(t)$, is the basis for the calculation of the various temperature fields, and thus for the description of the *reactivity feedback*. The detailed description of the reactivity feedback components is deferred to Sec. III. Here only the general form is presented. As all feedback in this model results from changes in temperature fields, the general formula for the feedback reactivity, $\rho_f(t)$, is

$$\rho_f(t) = \sum_k \beta_k \delta T_k(t) \quad (\text{for } k > 12) , \quad (11a)$$

where the β_k (for $k > 12$) are temperature coefficients and $\delta T_k(t)$ are mean changes in temperature. Inserting the solutions of Eqs. (3) gives $\rho_f(t)$ in a form which is directly analogous to $s_d(t)$ per Eq. (5) and $p_{dh}(t)$ per Eq. (8):

$$\rho_f(t) = \sum_{k>12} \beta_k \lambda_k \int_0^t D_k(t') e^{-\lambda_k(t-t')} dt' . \quad (11b)$$

The forcing functions D_k are described in detail in Sec. III.

II.2.3 The Fission-Power Source Multiplication Formula

Inserting Eq. (11b) in Eq. (6) and adding an "external reactivity" $\rho_x(t)$ gives the complete implicit solution for the fission power in form of a source multiplication formula

$$p_f(t) = \frac{\sum_{k=1}^6 \beta_k \lambda_k \int_{-\infty}^t p_f(t') e^{-\lambda_k(t-t')} dt' + s}{\beta - \rho_x(t) - \sum_{k>12} \beta_k \lambda_k \int_0^t D_k(t') e^{-\lambda_k(t-t')} dt'} \quad (12)$$

The notation $V_k(t)$ is introduced for the convolution integrals:

$$V_k(t) = \lambda_k \int_{-\infty}^t p_f(t') e^{-\lambda_k(t-t')} dt' \quad (k = 1 \cdots 12) \quad (13a)$$

and

$$V_k(t) = \lambda_k \int_0^t D_k(t') e^{-\lambda_k(t-t')} dt' \quad (k > 12) \quad (13b)$$

The delayed neutron source can then be written as

$$s_d(t) = \sum_{k=1}^6 \beta_k V_k(t), \quad (14a)$$

and the feedback reactivity feedback as

$$\rho_f(t) = \sum_{k>12} \beta_k V_k(t). \quad (14b)$$

The source multiplication formula for $p_f(t)$, Eq. (12), can then be expressed in the concise form

$$p_f(t) = \frac{\sum_{k=1}^6 \beta_k V_k(t) + s}{\beta - \rho_x(t) - \sum_{k>12} \beta_k V_k(t)}. \quad (15a)$$

The same notation is applied to the decay-heat rate formula, Eq. (8), giving

$$p_{dh}(t) = \sum_{k=7}^{12} \beta_k V_k(t). \quad (15b)$$

II.3 The Finite Difference Formulation

The advantages of solving the integral rather than the differential form of the physical balance equations becomes most apparent in the step-by-step advancing of the solution of the initial value problem. In a differential equation

$$\dot{f}(t) = -\lambda f(t) + g(t) \quad ,$$

the step size Δt is generally dictated by the rate of change, i.e., by λf . In a straight forward procedure, $\lambda \Delta t$ has to be much smaller than the one: $\lambda \Delta t \ll 1$.

In the corresponding integral equation

$$f(t) = \int_{-\infty}^t g(t') e^{-\lambda(t-t')} dt' \quad ,$$

in which $g(t')$ is approximated within Δt by a polynomial expression, the integrals over the exponential functions are carried out and analytically (see the resulting "moments" in Eqs. (19b-d)). This makes the accuracy of the step-by-step advance largely *independent* of λ . In the transition toward an asymptotic state, when $g(t)$ becomes slowly varying, $\lambda \Delta t$ may exceed 100.

II.3.1 Finite Difference Evaluation of the Delayed Neutron Source

The point kinetics equation in the prompt jump approximation, Eq. (4b), has at first been converted in an implicit solution as a *source multiplication formula*, Eqs. (12) or (14). The convolution integrals depend on the power history, $p_f(t')$, with $t' \leq t$. During the solution procedure p_f is known at all times $t' < t$, the value of $p_f(t)$ itself needs to be found by extrapolation.

The numerical evaluation uses time steps, $\Delta t_n = t_{n+1} - t_n$. Suppose $p_f(t)$ has been calculated up to $t = t_n$. Finding $p_f(t_{n+1})$ requires an extrapolation through the interval t_n to t_{n+1} based on the previously calculated values $p_f(t')$ with $t' \leq t_n$. The largest error of this extrapolation would be at the end of the interval, i.e., at ($t' = t_{n+1}$). Unfortunately, the exponential functions in the integral of the convolution integrals have their largest value (equal to one) also at the end of the interval, leading to a situation where the largest extrapolation error would coincide with the largest weight.

This disadvantage can be circumvented by an *implicit* finite differencing scheme, in which the p_f - value at the end of the interval, i.e. $p_f(t_{n+1})$, is applied in the p_f - approximation in the interval t_{n+1} . For the derivation of the *implicit* time-step advancing scheme, all convolution integrals containing $p_f(t')$ are written as *recursion* formulas

$$V_k(t_{n+1}) = \lambda_k \int_{-\infty}^{t_n} p_f(t') e^{-\lambda_k(t_{n+1}-t')} dt' + \delta V_k(t_{n+1}) \quad , \quad (16a)$$

with

$$\delta V_k(t_{n+1}) = \lambda_k \int_{t_n}^{t_{n+1}} p_f(t') e^{-\lambda_k(t_{n+1}-t')} dt' . \quad (16b)$$

The integral in Eq. (16a) is calculated from the previous convolution integral, giving

$$V_k(t_{n+1}) = V_k(t_n) e^{-\lambda_k \Delta t_n} + \delta V_k(t_{n+1}) , \quad (17)$$

with

$$\Delta t_n = t_{n+1} - t_n .$$

A parabolic approximation of $p_f(t')$, based on $p_f(t')$ for t_{n-1} , t_n and t_{n+1} , is applied in Eq. (16 b):

$$p_f(t') = p_f(t_n) + \dot{p}_f(t_n) (t' - t_n) + a_2 (t' - t_n)^2 . \quad (18a)$$

The value of a_2 is determined from $p_f(t_{n+1})$:

$$p_f(t_{n+1}) = p_f^x(t_{n+1}) + a_2 \Delta t_n^2 \quad (18b)$$

with $p_f^x(t_{n+1})$ being the linear extrapolation at t_{n+1} :

$$p_f^x(t_{n+1}) = p_f(t_n) + \dot{p}_f(t_n) \Delta t_n . \quad (18c)$$

One obtains

$$a_2 = \left[p_f(t_{n+1}) - p_f^x(t_{n+1}) \right] \frac{1}{\Delta t_n^2} . \quad (18d)$$

Insertion of Eqs. (18) in Eq. (16b) gives

$$\delta V_k(t_{n+1}) = p_f(t_n) M_0 + \dot{p}_f(t_n) M_1 - \frac{p_f^x(t_{n+1})}{\Delta t_n^2} M_2 + \frac{p_f(t_{n+1})}{\Delta t_n^2} M_2 , \quad (19a)$$

with the "moments"

$$M_0 = \lambda_k \int_{t_n}^{t_{n+1}} e^{-\lambda_k(t_{n+1}-t')} dt' = 1 - e^{-\lambda_k \Delta t_n} \quad (19b)$$

$$M_1 = \lambda_k \int_{t_n}^{t_{n+1}} (t' - t_n) e^{-\lambda_k(t_{n+1}-t')} dt' = \Delta t_n - M_0 / \lambda_k \quad (19c)$$

$$M_2 = \lambda_k \int_{t_n}^{t_{n+1}} (t' - t_n)^2 e^{-\lambda_k(t_{n+1}-t')} dt' = \Delta t_n^2 - 2M_1 / \lambda_k . \quad (19d)$$

Thus, all convolution integrals of the form of Eq. (16a) can be expressed by a term depending on the fission power history, A^H , and a "present" term, A^P times $p_f(t_{n+1})$:

$$V_k(t_{n+1}) = A_k^H(t_{n+1}) + A_k^P p_f(t_{n+1}) , \quad (20a)$$

with

$$A_k^H(t_{n+1}) = V_k(t_n) e^{-\lambda_k \Delta t_n} + p_f(t_n) M_0 + \dot{p}_f(t_n) M_1 - p_f(t_{n+1}) M_2 / \Delta t_n^2 \quad (20b)$$

$$A_k^P = M_2 / \Delta t_n^2 . \quad (20c)$$

Equations (20) give for the delayed neutron source at t_{n+1} :

$$s_d(t_{n+1}) = \sum_{k=1}^6 \beta_k A_k^H + \left[\sum_{k=1}^6 \beta_k A_k^P \right] p_f(t_{n+1}) , \quad (21a)$$

or more concisely

$$s_d(t_{n+1}) = H_{SD}(t_{n+1}) + P_{SD} p_f(t_{n+1}) , \quad (21b)$$

with

$$H_{SD}(t_{n+1}) = \sum_{k=1}^6 \beta_k A_k^H(t_{n+1}) \quad (22a)$$

$$P_{SD} = \sum_{k=1}^6 \beta_k A_k^P . \quad (22b)$$

As an example of the changes during an interval Δt , the fastest decaying precursor group is considered, with its decay constant of $\lambda_6 \approx 3.6/s$. With time steps starting with $\Delta t = 1s$ and increasing to 32 seconds in the slower phases of a transient, the corresponding exponential function dies completely away within the larger interval; e.g. $\lambda \Delta t \approx 115$ yields at the front-end of the Δt - interval (t_n) as exponential weight, $\exp(-115) = 10^{-50}$ compared to 1.00 at t_{n+1} .

II.3.2 The Finite Difference Form of the Feedback Reactivity

The feedback reactivity is also expressed by a term proportional to the "present" p_f -value and a term based on the available "historical" information in full analogy to Eq. (21b):

$$\rho_f(t_{n+1}) = H_{\rho f}(t_{n+1}) + P_{\rho f} p_f(t_{n+1}) . \quad (23)$$

The derivation of $H_{\rho f}$ and $P_{\rho f}$ is presented in Sec. III.2. Here, the contribution to $H_{\rho f}$ and $P_{\rho f}$ are only discussed qualitatively:

The feedback resulting from a change in *power* has two components, $p_f(t')$ and $p_{dh}(t')$. Only the former contributes to $P_{\rho f}$. The decay-heat power, $p_{dh}(t')$, comes from $p_f(t'')$ - values for $t'' \leq t'$. Thus, its effect on $p_f(t_{n+1})$ has a zero weight, as $p_f(t'')$ appears under a double integral. Therefore, p_{dh} contributes only to $H_{\rho f}$.

From all feedback reactivities only the Doppler effect and the unconstrained axial fuel expansion contribute to $P_{\rho f}$. All other feedback effects involve heat transfer which eliminates the direct $p_f(t_{n+1})$ contribution.

The feedback resulting from a change in *inlet temperature*, δT_i , is only related to prior p_f -values, as it is "retarded" by the coolant flow time, Δt_L , between core outlet and inlet; Δt_L is about 25 seconds. Thus, there is no $p_f(t_{n+1})$ contribution and all δT_i -related feedback is counted in $H_{\rho f}$.

Additional forcing functions appear in the treatment of the coolant flow loop, leading to control-rod drive line and vessel expansion. They are introduced below. All of these feedback reactivities are part of $H_{\rho f}$.

II.4 The Quadratic Reactor Dynamics Equation

Inserting Eqs. (21b) and (23) in Eq. (15a) brings this source multiplication relation in the form

$$p_f(t_{n+1}) = \frac{P_{SD}p_f(t_{n+1}) + H_{SD}(t_{n+1}) + s}{\beta - \rho_x(t_{n+1}) - P_{\rho f}p_f(t_{n+1}) - H_{\rho f}(t_{n+1})} \quad (24)$$

Multiplying with the denominator and rearranging the terms yields the **quadratic reactor dynamics equation**

$$p_f^2(t_{n+1}) - R(t_{n+1})p_f(t_{n+1}) + Q(t_{n+1}) = 0, \quad (25a)$$

with

$$R(t_{n+1}) = \left[\beta - \rho_x(t_{n+1}) - H_{\rho f} - P_{SD} \right] / P_{\rho f} \quad (25b)$$

and

$$Q(t_{n+1}) = \left[H_{SD}(t_{n+1}) + s \right] / P_{\rho f} \quad (25c)$$

The solution of Eq. (25a),

$$p_f(t_{n+1}) = \frac{1}{2} \left[R(t_{n+1}) + \sqrt{R^2(t_{n+1}) - 4Q} \right] , \quad (26)$$

is the fission power at t_{n+1} . The right side of Eq. (26) is completely determined by the power history.

During unscrammed LOF and LOHS transients the reactivity may be significantly negative for many hours; the fission power drops then down to the level upheld by the source multiplication of the spontaneous fission source, s (see Ref. 10). The value of the spontaneous neutron source for a 900 MWth reactor has been estimated for a typical plutonium loading to be (Ref. 10):

$$S_{spf} \approx 9 \cdot 10^8 \text{ neutrons/second} . \quad (27)$$

Converting S_{spf} into a power, P_{spf} , yields

$$P_{spf} = \frac{1}{v} S_{spf} \frac{Ws}{3.1 \cdot 10^{10} \text{ fissions}} \approx 10 \text{ mW} . \quad (28)$$

With $P_{spf} \approx 10 \text{ mW}$ the independent source in Eq. (24), to be taken as the relative value, is

$$s = \frac{10 \text{ mW}}{900 \text{ MW}} = 1.11 \cdot 10^{-11} . \quad (29)$$

The limited accuracy of PCs does not allow a calculation of very small p_f -values from the solution of the quadratic equation, Eq. (26). With R being large and negative, and Q being very small and negative, the first eight digits of R are cancelled by the square root, resulting in a meaningless residue. The failure of the solution formula for the quadratic equation comes from the fact that, Eq. (25a) is then practically a linear equation with the solution

$$p_f^{\text{linear}} = \frac{Q}{R} . \quad (30a)$$

The linear solution can readily improved by iteration:

$$p_f^{(i)} = \frac{Q - p_f^{2(i-1)}}{R} , \quad (30b)$$

with i being the iteration number. A detailed investigation of the transition of p_f to near zero values, employing Taylor expansion of the square root in Eq. (26) and a double-precision square root showed that the first iterate,

$$p_f = \frac{Q - (\frac{Q}{R})^2}{R} \quad (30c)$$

yields seven digit accuracy for $p_f < 10^{-4}$ while the same accuracy can be obtained from the quadratic equation for $p_f > 10^{-4}$. Thus, Eq. (26) is replaced in the LTC code by Eq. (30c) for $p_f < 10^{-4}$.

III. Description of the Feedback Reactivity

III.1 Temperature Changes in an Average Core Channel

An average core channel is described by four media: fuel (f), cladding (c), coolant (liquid sodium, L) and structural steel (s). The original heat balance equations for these four media (Ref. 6) are modified by subtracting an initial stationary state and by dividing by the heat capacities of the left side. This gives equations for the respective temperature differences with material properties essentially described by time constants:

$$\frac{d\delta T_f}{dt} = \lambda_{fc} \Delta T_{fc0} \delta p - \lambda_{fc} (\delta T_f - \delta T_c) \quad (31a)$$

$$\frac{d\delta T_c}{dt} = \lambda_{cf} (\delta T_f - \delta T_c) - \lambda_{cL} (\delta T_c - \delta T_L) \quad (31b)$$

$$\frac{d\delta T_L}{dt} = \lambda_{Lc} (\delta T_c - \delta T_L) - \lambda_{Ls} (\delta T_L - \delta T_s) - \lambda_{Li} [f \cdot (\delta T_L - \delta T_i) + \delta f \Delta T_{L0}] \quad (31c)$$

$$\frac{d\delta T_s}{dt} = \lambda_{sL} (\delta T_L - \delta T_s) \quad (31d)$$

The first index of λ 's refers to the index of the balance equation temperature, the second to the neighboring medium. In Eqs. (31), the δT are the temperature changes in the fuel, cladding, coolant (L) and steel respectively; δp is the change in relative power, δf the change of the relative flow f .

The time constants and coefficients are given by the expressions of Eqs. (32). The numerical values of the various factors are for the SAFR reactor design, provided by J. E. Cahalan (Ref. 11).

$$\begin{aligned} \lambda_{fc} &= \frac{2\pi r_f h_{fc}}{\rho_f c_f A_f} = 4.108/s = \lambda_f \\ \lambda_{cf} &= \frac{2\pi r_f h_{fc}}{\rho_c c_c A_c} = 4.725/s \\ \lambda_{cL} &= \frac{2\pi r_c h_{cL}}{\rho_c c_c A_c} = 18.09/s \\ \lambda_{Lc} &= \frac{2\pi r_c h_{cL}}{\rho_L c_L A_L} = 44.51/s \\ \lambda_{Ls} &= \frac{2\pi r_s h_{Ls}}{\rho_L c_L A_L} = 6.613/s \end{aligned} \quad (32)$$

$$f \cdot \lambda_{Li} = \frac{2\dot{m}_{L0}c_L}{\rho_L c_L A_L \Delta Z} = 13.66f/s$$

(32 cont.)

$$\lambda_{sL} = \frac{2\pi r_s h_{Ls}}{\rho_s c_s A_s} = 3.975/s = \lambda_s$$

The r - and A -values are effective radii and areas; ρ_x and c_x are density* and specific-heat values, the h_{xy} are effective heat transfer coefficients from medium x to medium y ; $\dot{m}_{L0}$ is the initial coolant mass flow, and ΔZ the channel length (core height). The quantity ΔT_{fc0} ($= 89.75K$) is the initial average temperature difference between fuel and cladding and ΔT_{L0} ($= 76.38K$) the initial average between coolant in the core and the inlet.

Equations (31) give first the heat source and then the loss terms. It is rewritten here to conform with the structure of the delayed neutron and decay heat equations, having first a (negative) "decay" term and then a (positive) driving or forcing function:

$$\frac{d\delta T_f}{dt} = -\lambda_f \delta T_f + \lambda_f (\Delta T_{fc0} \delta p + \delta T_c) \quad (33a)$$

$$\frac{d\delta T_c}{dt} = -\lambda_c \delta T_c + \lambda_c (L_{cf} \delta T_f + L_{cL} \delta T_L) \quad (33b)$$

$$\frac{d\delta T_L}{dt} = -\lambda_L \delta T_L + \lambda_L (L_{Lc} \delta T_c + L_{Ls} \delta T_s + L_{Li} f \delta T_i - \tau_{L0} \delta f) \quad (33c)$$

$$\frac{d\delta T_s}{dt} = -\lambda_s \delta T_s + \lambda_s \delta T_L \quad (33d)$$

The new time constants and coefficients are composites of the original ones given in Eqs. (32):

$$\lambda_c = \lambda_{cf} + \lambda_{cL} = 22.82/s$$

$$L_{cf} = \lambda_{cf}/\lambda_c = 0.207$$

$$L_{cL} = \lambda_{cL}/\lambda_c = 0.793$$

$$\lambda_L = \lambda_{Lc} + \lambda_{Ls} + \lambda_{Li} f = 64.78/s \quad (f=1) \quad (34)$$

$$L_{Lc} = \lambda_{Lc}/\lambda_L = 0.687 \quad (f=1)$$

$$L_{Ls} = \lambda_{Ls}/\lambda_L = 0.102 \quad (f=1)$$

$$L_{Li} = \lambda_{Li}/\lambda_L = 0.211 \quad (f=1)$$

$$\tau_{L0} = \Delta T_{L0} \lambda_{Li}/\lambda_L = 16.11K \quad (f=1).$$

* Following standard notation, densities as well as reactivities are denoted by ρ ; thus, ρ_f in Eq. (32) is the fuel density, vs. ρ_f in Eq. (23) denotes the feedback reactivity.

Introducing the notation D for the driving functions in Eqs. (33) brings the heat balance equations in the condensed form

$$\begin{aligned}\frac{d\delta T_f}{dt} &= -\lambda_f \delta T_f + \lambda_f D_f \\ \frac{d\delta T_c}{dt} &= -\lambda_c \delta T_c + \lambda_c D_c \\ \frac{d\delta T_L}{dt} &= -\lambda_L \delta T_L + \lambda_L D_L \\ \frac{d\delta T_s}{dt} &= -\lambda_s \delta T_s + \lambda_s D_s\end{aligned}\quad (35)$$

The definitions of the driving functions are apparent from the comparison of Eqs. (33) and (35).

The solutions of Eqs. (35) are given by the respective convolution integrals:

$$\delta T(t) = \lambda \int_0^t D(t') e^{-\lambda(t-t')} dt' = V(D) \quad (36)$$

Inserting the individual driving functions of Eqs. (33) yields as solutions

$$\begin{aligned}\delta T_f &= \Delta T_{fc0} V_f(\delta p) + V_f(\delta T_c) \\ \delta T_c &= L_{cf} V_c(\delta T_f) + L_{cL} V_c(\delta T_L) \\ \delta T_L &= L_{Lc} V_L(\delta T_c) + L_{Ls} V_L(\delta T_s) + L_{Li} V_L(f\delta T_i) - \tau_{L0} V_L(\delta f) \\ \delta T_s &= V_s(\delta T_L)\end{aligned}\quad (37)$$

In this notation, the index of the time constant λ is attached as index to V , and the argument of V gives the particular driving function.

The values of $\lambda_c (= 22.82/s)$ and of $\lambda_L (\geq 64.78/s)$ are so large that the corresponding convolution integrals (V_c and V_L) can be replaced by their singular perturbation limit, i.e., by the driving function itself, as

$$\lim_{\lambda \rightarrow \infty} \lambda \int_0^t D(t') e^{-\lambda(t-t')} dt' = D(t) \quad (38)$$

Thus, Eqs. (37) can be simplified as

$$\begin{aligned}
 \delta T_f &= \Delta T_{fc0} V_f(\delta p) + V_f(\delta T_c) \\
 \delta T_c &= L_{cf} \delta T_f + L_{cL} \delta T_L \\
 \delta T_L &= L_{Lc} \delta T_c + L_{Ls} \delta T_s + L_{Li} f \delta T_i - \tau_{L0} \delta f \\
 \delta T_s &= V_s(\delta T_L)
 \end{aligned} \tag{39}$$

Equations (39) are programmed in LTC.

Three additional temperature changes are needed for the complete feedback description:

The outlet temperature is approximated by:

$$\delta T_{out} = \delta T_i + 2(\delta T_L - \delta T_i) \quad . \tag{40}$$

The temperature of the load-pad is calculated from δT_{out} . The particular form of the feedback resulting from the load pad expansion requires the use of an effective sodium temperature at the load pad level δT_{lp}^{eff} which is derived in Sec. III.2 [Eq. (47b)].

$$\delta T_{lp}^{eff} = \lambda_{lp} \int_0^t \delta T_{L_{eff}}^{lp}(t') e^{-\lambda_p(t-t')} dt' \quad . \tag{41}$$

The second component of the radial expansion results from the expansion of the grid plate, δT_g , which is calculated from δT_i :

$$\delta T_g = \lambda_g \int_0^t \delta T_i(t') e^{-\lambda_g(t-t')} dt' \quad . \tag{42}$$

III.2 The Feedback Reactivity

For the application in the source multiplication formula, Eqs. (12) or (15a), the feedback reactivity, ρ_f , is directly calculated from the respective temperature changes

$$\begin{aligned}
 \rho_f &= a_D \delta T_f + a_{ax} [(1 - \text{STUCK}) \delta T_f + \text{STUCK} \delta T_c] + a_L \delta T_L \\
 &+ \delta \rho_{lp} + a_g \delta T_g + a_{CR} \delta T_{CR} + a_{VHP} \delta T_{VHP} + a_{VCP} \delta T_{VCP} = \sum_{K>12} \beta_k V_k(t) \quad .
 \end{aligned} \tag{43}$$

The temperature coefficients [the a-values in Eq. (43)] are listed in Tab. I. The numerical values are from Ref. 11. The temperature coefficient a_D is the Doppler coefficient. The axial expansion coefficient is a_{ax} ; the axial expansion may be constrained by the fuel rod being stuck

at the clad (STUCK = 1) or it may be free to expand (STUCK = 0). The respective axial expansion would be proportional to the clad (δT_c) or the fuel (δT_f) temperatures. With a value between 0 and 1 assigned to STUCK, one can describe "mixed" states of the core, for which only a certain fraction of the fuel rods is constrained by the clad. The positive temperature coefficient of the coolant is given by a_L .

TABLE I
Feedback Coefficients

Notations	Physical Basis	Value (Ref. 11)
$a_D = \beta_{13}$	Doppler effect	-.098¢/K
$a_{ax} = \beta_{14}$	axial expansion	-.1432¢/K
$a_L = \beta_{15}$	sodium expansion	+.1715¢/K
$100 \frac{XMC}{XAC} = \beta_{16}$	coefficient for δp_{lp} in Eqs. (47)	78.9
$a_g = \beta_{17}$	grid plate or load-pad expansion	-.1184¢/K
$a_{CR} = \beta_{18}$	control-rod drive line expansion	-.1110¢/K
$a_{VHP} = \beta_{19}$	vessel-HP-expansion	+.062¢/K
$a_{VCP} = \beta_{20}$	vessel-CP-expansion	+.062¢/K

The expansion effects of the load-pad (δp_{lp}) and a grid plate ($a_g \delta T_g$) are both based on the radial expansion coefficient, a_r , which is calculated for a uniform radial expansion as it would result from identical temperature changes at the grid plate *and* the load-pad level. This would be the case if only the inlet temperature changes. Assuming equilibrium temperatures one would then have:

$$a_r \delta T_i = a_{lp} \delta T_i + a_g \delta T_i \quad , \quad (44)$$

from which follows:

$$a_{lp} = \frac{1}{2} a_r \quad (\text{if } \delta T_L = \delta T_i) \quad (45a)$$

$$a_g = \frac{1}{2} a_r \quad (\text{always}) \quad (45b)$$

Additional load-pad expansion comes from $\delta T_L > \delta T_i$. The subassemblies then "flower out" like a wedge. The average additional expansion reactivity is given by

$$\delta\rho_{lp}(add) = a_r \frac{XMC}{XAC} (\delta T_{out} - \delta T_i) \quad (46)$$

again, assuming equilibrium temperatures. In Eq. (46), the ratio of the core mid-plane (XMC) to the above core (XAC) load-pad elevation is applied to give the proper axial $\delta T_{L_{eff}}^{lp}$ average expansion (e.g., Ref. 9).

During transients, the delay in establishing the temperature changes is to be taken into account. This gives for $\delta\rho_{lp}$:

$$\delta\rho_{lp} = \frac{1}{2} a_r V_{lp} (\delta T_i) + a_r \frac{XMC}{XAC} V_{lp} (\delta T_{out} - \delta T_i) \quad (47a)$$

By defining an effective coolant temperature, at the load pad, $\delta T_{L_{eff}}^{lp}$

$$\delta T_{L_{eff}}^{lp} = \delta T_i + 2 \frac{XMC}{XAC} (\delta T_{out} - \delta T_i) = \delta T_i + 4 \frac{XMC}{XAC} (\delta T_L - \delta T_i) \quad (47b)$$

Eq. (47a) can be written as

$$\delta\rho_{lp} = \frac{1}{2} a_r V_{lp} (\delta T_{L_{eff}}^{lp}) \quad (47c)$$

The three remaining reactivity components, the expansion effects of the control rod drive line ($\delta\rho_{CR}$) and of the vessel, adjacent to hot (VHP) and cold (VCP) pools, are calculated in the coolant loop. The expansion effect $\delta\rho_{CR}$ is calculated from the temperature of the hot-pool sodium.

The convolution integrals and the respective time constants are listed in Tab. II. The two convolution integrals, $V_f(p_f)$ and $V_f(p_{dh}-p_o)$, result from a split of $V_f(\delta p)$:

$$V_f(\delta p) = V_f(p_f) + V_f(p_{dh}-p_o) \quad (48)$$

which is needed in the next section.

TABLE II
Feedback Convolution Integrals

Notations		Definitions	λ -values (1/s)
$V_f(\delta T_c)$	V(13)	$\lambda_f \int_0^t \delta T_c(t') e^{-\lambda_f(t-t')} dt'$	$\lambda_f = \lambda_{13} = 4.108$
$V_{lp}(\delta T_{L_{eff}}^{lp})$	V(14)	$\lambda_{lp} \int_0^t \delta T_{L_{eff}}^{lp}(t') e^{-\lambda_{lp}(t-t')} dt'$	$\lambda_{lp} = \lambda_{14} = 2.0$
$V_g(\delta T_i)$	V(15)	$\lambda_g \int_0^t \delta T_i(t') e^{-\lambda_g(t-t')} dt'$	$\lambda_g = \lambda_{15} = .0092$
$V_s(\delta T_L)$	V(16)	$\lambda_s \int_0^t \delta T_L(t') e^{-\lambda_s(t-t')} dt'$	$\lambda_s = \lambda_{16} = 3.975$
$V_f(p_f)$	V(17)	$\lambda_f \int_0^t p_f(t') e^{-\lambda_f(t-t')} dt'$	$\lambda_f = \lambda_{17} = 4.108$
$V_{CR}(\delta T_{LHP})$	V(18)	$\lambda_{CR} \int_0^t \delta T_{LHP}(t') e^{-\lambda_{CR}(t-t')} dt'$	$\lambda_{CR} = \lambda_{18} = .041$
$V(\delta p)$	V(19)	$\lambda_f \int_0^t \delta p(t') e^{-\lambda_f(t-t')} dt'$	$\lambda_f = \lambda_{19} = 4.108$
$V_f(p_{dh} - p_o)$	V(20)	$\lambda_f \int_0^t (p_{dh}(t') - p_o) e^{-\lambda_f(t-t')} dt'$	$\lambda_f = \lambda_{20} = 4.108$
$V_{VHP}(\delta T_{LHP})$	V(21)	$V_{VHP}(t)$ per Sec. III. 3.2	$\lambda_V^{HP} = \lambda_{31} = .00085$
$V_{VCP}(\delta T_{VCP})$	V(22)	$V_{VCP}(t)$ per Sec. III.3.3	$\lambda_V^{CP} = \lambda_{25} = .00085$

III.3 The Feedback Reactivity for the Quadratic Dynamics Equation

The feedback reactivity components for the source multiplication formula, Eq. (12), are all based on the respective temperature changes. As the equation system for these δT is coupled, one has to iterate the calculation of core temperature changes and of the fission power p_f . This iteration is combined with the implicit treatment of $p_f(t_{n+1})$ in ρ_f and s_d which has been outlined in Sec. II.4, leading to the quadratic dynamic equation (QDE) for the calculation of $p_f(t_{n+1})$.

Then, the direct appearance of $p_f(t_{n+1})$ in ρ_f needs to be isolated so $\rho_f(t_{n+1})$ becomes available in the form of Eq. (23). The only contribution to the "present" term in Eq. (23) comes from $V_f(\delta p)$ in δT_f of Eqs. (39). However, as the approximate calculation of δT_c and of δT_L in Eqs. (39) do not apply convolution integrals, δT_f also appears in δT_c and through δT_c in δT_L . This represents an instantaneous influence of δT_f on δT_c and δT_L . [see Eqs. (56) and (57)].

The fuel temperature is split as [see Eqs. (39) and (48)]

$$\delta T_f = \Delta T_{fc0} V_f(p_f) + \left[\Delta T_{fc0} V_f(p_{dh} - p_0) + V_f(\delta T_c) \right] . \quad (49)$$

The $V_f(p_f)$ is decomposed into a historical and a present components per Eq. (20), applied here to the feedback term, $k = 17$ (see Tab. II):

$$V_{17}(t_{n+1}) = A_{17}^H(t_{n+1}) + A_{17}^P \cdot p_f(t_{n+1}) . \quad (50)$$

This gives the δT_f -split as

$$\delta T_f(t_{n+1}) = \delta T_f^H(t_{n+1}) + \delta T_f^P \cdot p_f(t_{n+1}) \quad (51)$$

with

$$\delta T_f^H = \Delta T_{fc0} \left[V_{20}(t_{n+1}) + A_{17}^H(t_{n+1}) \right] + V_{13}(t_{n+1}) \quad (52a)$$

$$\delta T_f^P = \Delta T_{fc0} A_{17}^P . \quad (52b)$$

Analogous is the split of δT_c and δT_L :

$$\delta T_c(t_{n+1}) = \delta T_c^H(t_{n+1}) + \delta T_c^P \cdot p_f(t_{n+1}) \quad (53)$$

$$\delta T_L(t_{n+1}) = \delta T_L^H(t_{n+1}) + \delta T_L^P \cdot p_f(t_{n+1}) \quad (54)$$

Because the equations for δT_c and δT_L are coupled per Eqs. (39), the determination of the components of Eqs. (53) and (54) requires some algebra. The result is:

$$\delta T_c^P = \frac{1}{1 - L_{Lc}L_{cL}} L_{cf} \delta T_f^P \quad (55)$$

$$\delta T_c^H = \frac{1}{1 - L_{Lc}L_{cL}} \left[L_{cf} \delta T_f^H + L_{cL}(L_{Ls} \delta T_s + L_{Li} f \delta T_i - \tau_o \delta f) \right] \quad (56)$$

$$\delta T_L^P = \frac{1}{1 - L_{Lc}L_{cL}} L_{Lc} L_{cf} \delta T_f^P \quad (57)$$

$$\delta T_L^H = \frac{1}{1 - L_{Lc}L_{cL}} \left[L_{Lc} L_{cf} \delta T_f^H + L_{Ls} \delta T_s + L_{Li} f \delta T_i - \tau_o \delta f \right] \quad (58)$$

Inserting Eqs. (52) to (58) in the reactivity formula Eq. (43) yields readily the split of ρ_f of Eq. (23) with

$$\begin{aligned} H_{\rho_f}(t_{n+1}) = & a_D \delta T_f^H + a_{ax} \left[(1 - \text{STUCK}) \delta T_f^H + \text{STUCK} \cdot \delta T_c^H \right] + a_L \delta T_L^H \\ & + \delta \rho_p + a_g \delta T_g + a_{CR} \delta T_{CR} + a_{VHP} \delta T_{VHP} + a_{VCP} \delta T_{VCP} \end{aligned} \quad (59)$$

$$P_{\rho_f} = a_D \delta T_f^P + a_{ax} \left[(1 - \text{STUCK}) \cdot \delta T_f^P + \text{STUCK} \cdot \delta T_c^P \right] + a_L \delta T_L^P \quad (60)$$

Although the load pad reactivity contains δT_L it is considered part of H_{ρ_f} because of its additional heat-up delay.

IV. Temperature in the Coolant Loop and Pools

IV.1 The Coolant Loop Model

For the calculation of the temperatures in the major components of the coolant loop, and the evaluation of the delays of the sodium and steel heatup during transients a simplified description of the primary coolant loop, depicted in Fig. 1, is applied in which instantaneous mixing of sodium is assumed within each pool. The sodium flows from the core (C) through the Upper Internal Structure (UIS) to the hot pool (HP), from there through piping, including the intermediate heat exchanger (IHX), to the cold pool (CP). The UIS is combined with the hot pool. The flow delay in the primary loop, between core outlet and IHX outlet, is all accounted for in the loop-component "piping and intermediate heat exchanger", called HX for simplicity.

Fig 1: Primary coolant loop model

Thus, the power coming out of the HX, P_{out}^{HX} , equals the power coming into HX some t_L seconds (here 24s) earlier, minus the extracted power, $P_x(t)$:

$$P_{out}^{HX}(t) = P^{HP}(t-t_L) - P_x(t). \quad (61)$$

From the HX the coolant enters the cold pool (CP) and from there the core inlet. Decay heat removal is considered out of the hot pool, P_{DHR} , and at the vessel surface, with P_V^{HP} and P_V^{CP} being the HP and CP components respectively. Thus, the total heat rejection rate has four contributions:

$$P_r = P_x + P_{DHR} + P_V^{HP} + P_V^{CP} \quad (62)$$

IV.2 Temperatures of the Pool Components

The temperature calculation is a simplified version of the treatment presented by Cahalan (Ref. 5). It is described here first for a generic pool and then specialized for the two pools of the flow loop model of Fig. 1. The heat transfer equation for the generic pool is

$$C_L \frac{dT_L}{dt} = W_P c_L [T_{in}(t) - T_L(t)] - (hA)_s [T_L(t) - T_s(t)] - (hA)_V^{HP} [T_L(t) - T_V(t)] - P_{DHR} \quad (63)$$

In Eq. (63), the subscripts L and s refer to the (liquid) sodium coolant and the steel; C_L is the sodium heat capacity [Ws/K] and c_L its specific heat [Ws/kgK]; W_P is the primary system flow rate [kg/s] and (hA) the respective steel/coolant convection coefficient [W/K]; T_L is the coolant temperature; T_s and T_V are the pool-internal and vessel steel temperatures respectively; P_{DHR} is the decay heat removal power which applies only to the hot pool.

Dividing Eq. (63) by C_L introduces time constants, λ :

$$\frac{dT_L(t)}{dt} = \lambda_w [T_{in}(t) - T_L(t)] - r_{sL} \lambda_s [T_L(t) - T_s(t)] - r_{VL} \lambda_V [T_L(t) - T_V(t)] - P_{DHR}/C_L \quad (64)$$

with the flow time constant, λ_w ,

$$\lambda_w = \frac{W_P c_L}{C_L} = \frac{W_P}{M_L} \left[\frac{1}{s} \right], \quad (65)$$

where M_L is the sodium mass in the pool. Furthermore,

$$\lambda_s = \frac{(hA)_s}{C_s} \left[\frac{1}{s} \right] \quad (66a)$$

$$\lambda_v = \frac{(hA)_v}{C_v} \left[\frac{1}{s} \right] \quad (66b)$$

are the time constants of the two steel components of the pool (internal and vessel). The ratios r are given by

$$r_{sL} = C_s/C_L \quad (67a)$$

$$r_{vL} = C_v/C_L \quad (67b)$$

Equation (64) is rewritten by introducing a driving or forcing function, $D_T(t)$,

$$\frac{dT_L(t)}{dt} = -\lambda_w T_L(t) + \lambda_w D_T(t), \quad (68)$$

with $D_T(t)$ being the pool inlet temperature reduced by the effects of the steel heat-up and heat rejection:

$$D_T(t) = T_{in}(t) - r_{sL} \frac{\lambda_s}{\lambda_w} [T_L(t) - T_s(t)] - r_{vL} \frac{\lambda_v}{\lambda_w} [T_L(t) - T_v(t)] - \frac{P_{DHR}}{\lambda_w C_L}. \quad (69)$$

Instead of using the temperatures as such, it is more convenient to use increments above the initial stationary state:

$$\delta T_{in}(t) = T_{in}(t) - T_{in0}$$

$$\delta T_L(t) = T_L(t) - T_{L0}$$

$$\delta T_s(t) = T_s(t) - T_{s0}$$

$$\delta T_v(t) = T_v(t) - T_{v0} \quad (70)$$

The initial stationary balance per Eq. (64) is given by

$$0 = \lambda_w [T_{in0} - T_{L0}] - r_{sL} \lambda_s [T_{L0} - T_{s0}] - r_{vL} \lambda_v [T_{L0} - T_{v0}] - \frac{P_{DHR}}{C_L}. \quad (71)$$

Equation (68) assumes then the form

$$\frac{d}{dt} \delta T_L(t) = -\lambda_w \delta T_L(t) + \lambda_w D(t), \quad (72)$$

where $D(t)$ is the driving function for the *incremental* temperature, δT_L :

$$D(t) = \delta T_{in}(t) - r_{sL} \frac{\lambda_s}{\lambda_w} \left[\delta T_L(t) - \delta T_s(t) \right] - r_{VL} \frac{\lambda_V}{\lambda_w} \left[\delta T_L(t) - \delta T_V(t) \right] . \quad (73)$$

The incremental driving function, $D(t)$, does not contain the P_{DHR} -term any more; as it is assumed to be constant it cancels by subtracting the initial condition, Eq. (71).

The solution of Eq. (72) is a convolution integral

$$\delta T_L(t) = V_L(t) = \lambda_w \int_0^t D(t') e^{-\lambda_w(t-t')} dt' . \quad (74)$$

As $D(t')$ depends on δT_L , Eq. (74) is an implicit solution, which is treated iteratively. It should be noted that for LOF transients the flow rate, W_p , and thus λ_w depend on time. Equation (74) needs then to be generalized as presented in App. A.

The first term, in Eq. (73), $\delta T_{in}(t)$, is available after the temperature calculation in the previous loop component. The steel temperatures in the forcing function, Eq. (73), need to be calculated from their respective balance equations before δT_L can be found from Eq. (74):

$$\frac{d}{dt} \delta T_s(t) = -\lambda_s \delta T_s(t) + \lambda_s \delta T_L(t) \quad (75a)$$

$$\frac{d}{dt} \delta T_V(t) = -\lambda_V \delta T_V(t) + \lambda_V \left[\delta T_L(t) - \frac{\delta P_V(t)}{\lambda_V C_V} \right] . \quad (75b)$$

An extrapolated value for δT_L is used in Eqs. (75). The solutions are given by

$$\delta T_s(t) = V_s(t) = \lambda_s \int_0^t \delta T_L(t') e^{-\lambda_s(t-t')} dt' \quad (76a)$$

$$\delta T_V(t) = V_V(t) = \lambda_V \int_0^t \left[\delta T_L(t') - \frac{\delta P_V(t')}{\lambda_V C_V} \right] e^{-\lambda_V(t-t')} dt' , \quad (76b)$$

with

$$\delta P_V(t) = P_V(t) - P_{V_0} . \quad (77)$$

Equations (74) through (77) are solved "iteratively" in the LTC program; a single iterative step appears to yield sufficient accuracy as all temperatures are slowly varying functions within a time-step: δT_s and δT_V are extrapolated linearly through the interval t_n to t_{n+1} , using parabolic approximations up to t_n based on the three recent values. Equations (74) then yield a first iterate of δT_L , which is inserted in Eqs. (76). The calculated values of δT_s and δT_V at t_{n+1} are then applied as base points for determining a forcing function parabola from t_{n-1} through t_{n+1} , from which the second iterate of δT_L is calculated. Equations (76) then yield the "updated" steel temperature changes.

IV.3 Temperatures in the Hot Pool (HP) and the Control Rod Drive Line

An "effective" hot pool (HP) is defined by combining the respective sodium and steel masses of the upper core structure and the upper internal structure. It is this combination that is called "HP" in the following.

The general temperature balance equation, Eq. (63), applied to the sodium in the "HP" is:

$$C_L^{HP} \frac{dT_L^{HP}}{dt} = W_{PC_L} \left[T_{out}^C(t) - T_L^{HP}(t) \right] - (hA)_s^{HP} \left[T_L^{HP}(t) - T_s^{HP}(t) \right] - (hA)_V^{HP} \left[T_L^{HP}(t) - T_V^{HP}(t) \right] - P_{DHR} \quad (78)$$

The inlet temperature is the core-outlet T_{out}^C ; decay heat removal (P_{DHR}) and heat-up of the vessel are included.

The resulting temperature per Eq. (74) is given by

$$\delta T_L^{HP}(t) = V_L^{HP}(t) = \lambda_w^{HP} \int_0^t D^{HP}(t') e^{-\lambda_w(t-t')} dt' \quad , \quad (79)$$

with

$$D^{HP}(t) = \delta T_{out}^C(t) - r_{sL}^{HP} \frac{\lambda_s^{HP}}{\lambda_w^{HP}} \left[\delta T_L^{HP}(t) - \delta T_s^{HP}(t) \right] - r_{VL}^{HP} \frac{\lambda_V^{HP}}{\lambda_w^{HP}} \left[\delta T_L^{HP}(t) - \delta T_V^{HP}(t) \right] \quad , \quad (80)$$

per Eq. (73). The steel and vessel temperatures are pre-calculated per Eqs. (75) applied to HP.

Having the sodium temperature in the HP allows a ready calculation of the control-rod drive line temperature:

$$\delta T_{CR}(t) = V_{CR}(t) = \lambda_{CR} \int_0^t \delta T_L^{HP}(t') e^{-\lambda_{CR}(t-t')} dt' \quad (81)$$

IV.4 Outlet Temperature of the Intermediate Heat-Exchanger

Equation (61) describes the flow of energy in the simplified HX-model applied here. Subtracting the initial condition yields

$$\delta P_{out}^{HX}(t) = \delta P^{HP}(t-t_L) - \delta P_x(t) \quad (82)$$

For TOP transients the HX heat rejection is assumed to be constant. The HP-sodium temperature rise is just passed through as $\delta P_x = 0$:

$$\delta T_{out}^{HX}(t) = \delta T_L^{HP}(t-t_L) \quad \text{for TOP.} \quad (83)$$

For a Loss-of-Heat-Sink accident, $P_x(t)$ decreases. A simple linear approximation is applied for $t \leq \tau^{LOHS}$ (and zero thereafter)

$$P_x(t) = \left[1 - \frac{t}{\tau^{LOHS}} \right] P_{x0} \quad (84)$$

Multiplication by $(W_P c_L)^{-1}$ converts Eq. (82) into

$$T_{out}^{HX}(t) = T^{HP}(t-t_L) - P_x(t)/W_P c_L \quad (85)$$

The HX-outlet temperature is inlet temperature for the cold pool. The balance equation for the cold-pool sodium and the analytical and numerical treatment is completely analogous to the hot-pool:

Instead of Eq. (63) one has the temperature balance equation

$$\begin{aligned} C_L^{CP} \frac{d T_L^{CP}(t)}{dt} = W_P c_L \left[T_{out}^{HX}(t) - T_L^{CP}(t) \right] - (hA)_s^{CP} \left[T_L^{CP}(t) - T_s^{CP}(t) \right] \\ - (hA)_V^{CP} \left[T_L^{CP}(t) - T_V^{CP}(t) \right] \quad (86) \end{aligned}$$

Thus, replacing T_{out}^C by T_{out}^{HX} , deleting $P_{DII R}$, and changing all superscripts from HP into CP converts Eq. (78) into Eq. (86). The subsequent equations, Eqs. (79) and (80) apply with these changes.

IV.5 The Sodium Pool Temperatures During LOF Transients

With the sodium flow rate being time dependent during LOF transients, the associated time constant λ_w in Eq. (72) depends on time. Equation (72) is then replaced by

$$\frac{d}{dt} \delta T(t) = -\lambda_w(t) \delta T(t) + \Delta(t) \quad , \quad (87)$$

with

$$\lambda_w(t) = \frac{W_p(t)}{M_L} \quad , \quad (88)$$

and

$$\Delta(t) = \lambda_w(t) D(t) \quad , \quad (89)$$

applicable to all pools.

The solution of Eq. (87), for $\delta T(0) = 0$, is

$$\delta T(t) = V(t) = \int_0^t \Delta(t') e^{-\int_{t'}^t \lambda_w(t'') dt''} dt' \quad (90)$$

The numerical treatment of this convolution integral is presented in App. A.

V. Quasistatic Approximations of Transients Phenomena

V.1 General Discussion

The presented transient model contains implicit solutions of about 30 differential equations in form of convolution integrals with time delays ranging from about 0.1 seconds to over 300 hours. For slow transients, especially during transitions into an asymptotic stationary state, the shorter time delays become unimportant, as the driving function changes very little during a delay period $\tau = 1/\lambda$; i.e.

$$\frac{\delta D}{D} \ll 1 \text{ during } \tau = \frac{1}{\lambda} . \quad (91)$$

The fractional rate of change is then much smaller than λ :

$$\frac{1}{D} \frac{dD(t)}{dt} \ll \lambda . \quad (92)$$

In these cases, the convolution integral can be replaced by the driving function; this is a "quasistatic approximation" in which a rapid process is assumed to occur instantaneously.

Mathematically, time constants (λ) of a very rapid process are eliminated by the limit $\lambda \rightarrow \infty$, i.e., by the method of "singular perturbations" (see e.g., Ref. 10). It is best demonstrated by considering an implicit solution, of a differential equation

$$\frac{\partial}{\partial t} f(x, t) = -\lambda f(x, t) + \lambda D(x, t) , \quad (93)$$

which has the form of a convolution integral. In the limit $\lambda \rightarrow \infty$,

$$\lim_{\lambda \rightarrow \infty} f(x, t) = \lim_{\lambda \rightarrow \infty} \int_{-\infty}^t \lambda D(x, t') e^{-\lambda(t-t')} dt' , \quad (94)$$

the integral becomes singular but only for an infinitely short time, namely at $t' = t$, blending out $D(x, t')$ at $t' = t$, much like a δ - function does:

$$\lim_{\lambda \rightarrow \infty} f(x, t) = D(x, t) \lim_{\lambda \rightarrow \infty} \int_{-\infty}^t \lambda e^{-\lambda(t-t')} dt' = D(x, t) . \quad (95)$$

This eliminates the time derivative of $f(x, t)$ in Eq. (93), leaving as residual the static equation.

V.2 Quasistatic Approximations in Reactor Dynamics

There are several "levels" of quasistatic approximations in reactor dynamics in general and in the presented LMR transient analysis model in particular. The quantitative requirements are briefly addressed here.

The *first level* of a quasistatic approximation is the elimination of the time derivative of the neutron *flux shape function* in space-energy dependent kinetics (Ref. 11).

The *second level*, applied to the point-reactor model, is the prompt jump approximation (PJA), which consists of the elimination of the time derivative of the *flux amplitude function* (see e.g. Ref. 12), approximated here by the fission power, $p_f(t)$. Solving Eq. (4a) gives [λ_p is the prompt inverse period $(\rho - \beta)/\Lambda$]

$$p_f(t) = \int_{-\infty}^t \frac{s_d(t')}{\Lambda} e^{-\lambda_p(t-t')} dt' . \quad (96)$$

The limit $\lambda_p \rightarrow \infty$ or $\Lambda \rightarrow 0$ yields the PJA:

$$\lim_{\lambda_p \rightarrow \infty} p_f(t) = \frac{s_d(t)}{\beta - \rho(t)} . \quad (97)$$

Thus in the PJA, the time variation of $p_f(t)$ needs to be negligible during a prompt period:

$$\frac{\delta p_f}{p_f} \ll 1 \text{ during } \tau_p = \left[\frac{\beta - \rho}{\Lambda} \right]^{-1} \approx 10^{-4} \text{ s} . \quad (98)$$

This condition is fully satisfied for all typical *TOP*, *LOF* and *LOHS* transients in LMRs.

A quasistatic approximation for *extremely* slow transients has been proposed by Sevy¹³:

$$\rho(t) = 0 , \quad (99)$$

being the simplest kinetics equation. The quasistatic approximation that is the underlying assumption is readily obtained from Eq. (97). It requires that the delayed neutron source is approximated quasistatically:

$$p_f(t) = \lim_{\lambda_k \rightarrow \infty} p_f(t) = \frac{\sum_{k=1}^6 \lim_{\lambda_k \rightarrow \infty} \int_{-\infty}^t \lambda_k \beta_k p_f(t') e^{-\lambda_k(t-t')} dt'}{\beta - \rho(t)} = \frac{\beta p_f(t)}{\beta - \rho(t)} , \quad (100)$$

from which follows Eq. (99). Thus, the applicability of Eq. (99) requires

$$\frac{\delta p_f}{p_f} \ll 1 \text{ during } \frac{1}{\lambda_1} \cdots \frac{1}{\lambda_6} = 0.35s \cdots 80s . \quad (101)$$

Other quasistatic approximations are applied in the feedback description. If all convolution integrals in the feedback reactivity are replaced by the respective forcing functions, treating all of them as singular perturbations, one obtains the *quasistatic feedback reactivity*, ρ_f^{qs} :

$$\rho_f^{qs}(t) = \lim_{\lambda_k \rightarrow \infty} \sum_{k>12} \beta_k V_k(t) = \sum_{k>12} \beta_k D_k(t) . \quad (102)$$

Applicability of this approximation requires

$$\frac{\delta p_f}{p_f} \ll 1 \text{ during } \frac{1}{\lambda_k} \text{ for } k > 12 . \quad (103)$$

As the longest mean heat-up time, the one for the vessel is about 20 min, the quasistatic approximation of *all* feedback effects can be applied in the transition into a steady state asymptotic solution.

After the asymptotic solution has been assumed, the inequalities Eqs. (101) and (103) are automatically satisfied, as δp_f has become zero. The asymptotic solution is independent of the treatment of the transient (except when lasting changes occur during the transient).

V.3 Quasistatic Features in the LTC Model

Quasistatic approximations in the LTC method are made for the neutron flux: the flux *shape* adjustment is disregarded as it is assumed to be constant (Point Reactor Model, PRM), and within the PRM, the prompt jump approximation is made, assuming the flux to follow quasistatically the reactivity and source (s_d) changes. Other quasistatic approximations are made in the core temperature calculation for the shorter delay times ($\tau \leq 50 \text{ ms}$ or $\lambda > 20/s$). The calculated values of the convolution integrals would be extremely close to the respective forcing functions. As the transient variation slows down in its transition into an asymptotic state more and more of the 30 calculated convolution integrals gradually approach their respective forcing function. However, making use of this aspect would complicate the computer program and is therefore not done.

VI. Numerical Results

VI.1 Time Steps and Computation Time

The main goal of the physical model and the computational algorithm described above was to stretch the time steps to a size that makes the transient problem amenable to a PC. Further savings in computation time are achieved by structuring the time steps in blocks of typically 40 to 80 steps of equal length. Then, all exponential functions need to be calculated only once per block; the time step selection algorithm is also executed only once per block, based on the maximum relative power change in the previous block (see App. B). User set are the initial time step, the criterion for the automatic time-step selection algorithm, and the length of the maximum time step.

A typical initial time step is 1.0 second, which is gradually increased to a set maximum value (e.g. 32 seconds) as the transient approaches its asymptotic state. The computation time per time step is about 1.6 seconds on a 386-PC. The complete analysis of a TOP transient which may reach asymptotic state in about 2.5 hours takes about 400 time steps, i.e. about 10 minutes of computing time. Results printed out during the run allow the user to observe the transient, its power and reactivity trajectories and various temperatures. The on-line print as well as additional results are filed for subsequent inspection or application. This computing time can be considerably reduced if the program is compiled and a math-coprocessor be used.

VI.2 Accuracy of the Power Trajectory

The strongest dependency of the accuracy in a TOP transient on the size of the time step is during the insertion of the reactivity. Therefore, the accuracy is investigated for the initial period, the initial rise of the power to its maximum and part of the subsequent decline. The step-size selection algorithm was effectively turned off for this investigation by setting the criteria for doubling the step-size to 10^{-4} rather than the more practical value of 1% of the maximum absolute change during the previous block. It should be noted that this 1% value refers to a *change* and not to an inaccuracy. The inaccuracy corresponding to this change in relative power is probably less than $10^{-2}\%$.

Table III shows in its first column the time in seconds and in its second column the power calculated with 0.5s step size for time values ranging from 4s to 240s. The reactivity insertion rate was 1¢/s up to a maximum value of 20¢. The other three columns list the percentage differences of power trajectories calculated with 1s, 2s and 4s step sizes respectively.

TABLE III
Accuracy of the Power Calculation

$t(s)$	$p_{0.5}(t)$	$p_{1.0}(t) - p_{0.5}(t)[\%]$	$p_{2.0}(t) - p_{0.5}(t)[\%]$	$p_{4.0}(t) - p_{0.5}(t)[\%]$
4.000	1.03662	-0.030	0.195	1.054
8.000	1.07955	0.001	-0.113	0.570
12.000	1.12761	0.006	0.112	-0.585
16.000	1.17935	0.008	-0.012	-0.320
20.000	1.22315	-0.008	-0.061	0.289
24.000	1.24643	-0.010	-0.099	-0.392
28.000	1.25689	0.007	0.026	-0.872
32.000	1.26411	0.010	0.012	0.016
36.000	1.26929	0.013	0.034	0.589
40.000	1.27307	0.014	0.035	0.044
48.000	1.27761	0.017	0.046	0.129
56.000	1.27919	0.018	0.051	0.074
64.000	1.27859	0.018	0.052	0.143
72.000	1.27635	0.017	0.050	0.089
80.000	1.27284	0.017	0.049	0.127
96.000	1.26311	0.013	0.042	0.105
112.000	1.25102	0.011	0.034	0.084
128.000	1.23762	0.009	0.027	0.064
160.000	1.20938	0.005	0.013	0.031
176.000	1.19533	0.003	0.008	0.018
192.000	1.18165	0.001	0.003	0.005
208.000	1.16849	-0.001	-0.003	-0.005
224.000	1.15595	-0.002	-0.007	-0.015
240.000	1.14409	-0.003	-0.010	-0.023

The deviations between 1.0s and 0.5s results ($p_{1.0}$ vs. $p_{0.5}$) are of the order of magnitude of 10^{-4} , fading down to 10^{-5} well beyond the maximum. This suggests that

- a) the 0.5s results, compared to 0.25s results would have a maximum deviation well below 10^{-4} throughout. The 0.5 second results thus represent an adequate reference for this comparison.
- b) The 1.0s results, $p_{1.0}$, are generally accurate enough so that 1.0 second can be used as the normal initial time step.

All results have their largest error at the first few time steps, as the reactivity and thus the power (in the prompt jump approximation) start to increase with a discontinuous slope. Then, the parabolic approximations of the power and other quantities have their poorest accuracy. As projections are applied into the next interval, the initial error is passed on to the next interval. It eventually fades away in a damped oscillation which is quite apparent in the 4.0s ($p_{4.0}$) results. After the maximum, the inaccuracies of even the 4s-step results are smaller than 0.1%.

The comparatively large early inaccuracies of the 2s- and 4s-step results would of course not appear in a practical calculation. Practical calculations would be started with a 1s time step which increases later to 2, 4, up to about 32s as the power variation becomes increasingly smooth and slowly varying.

VI.3 Maximum Reactivities

The fundamental assumption needed to stretch the time steps to one or many seconds is the prompt jump approximation, which requires the net reactivity to remain below 1\$. Figure 2 shows the maximum reactivities for input (external) TOP initiating reactivities, $\rho_x^{\max}$, ranging from 0.2\$ to 1.6\$, rising to these values at 2¢/s rate.

The first two transients, $\rho_x^{\max} = 20\text{¢}$ and 40¢ have maximum net reactivity values $\rho_{\text{net}}^{\max}$ of about 8¢ and 11¢ respectively. For the larger $\rho_x^{\max}$ values the maximum of the net reactivity occurs *during* the ramp insertion and is independent of $\rho_x^{\max}$ itself. The net reactivity for insertions of 80¢ or more, shown in Fig. 2 up to 1.60\$, reaches a maximum value of only 12¢. This justifies the application of the prompt jump approximation, and thus of the LTC program even for TOP initiating *reactivities far in excess* of 1\$.

Fig. 2 Reactivity as function of time for several TOP cases

Summary

The simplified model for LMR transient analysis, formulated by J. E. Cahalan (Ref. 6), was the basis for this development. It employs lumped descriptions for the heat transfer equation in each component, such as fuel cladding, coolant, structure, grid-plate, etc, thus expressing the average heat transfer in ordinary differential equations. The neutronics is treated in the point kinetics approximation.

In addition to these simplifications, the prompt jump approximation is applied, limiting the net reactivity to the subprompt critical domain. This approximation appears to be justified as the strong negative feedback effectively keeps the net reactivity well below prompt critical. An investigation of the maximum net reactivities, ρ_{net}^{max} (see Sec. V.3), showed that for a 2¢/s ramp the maximum reactivity, ρ_{net}^{max} remains below 0.15\$, even for initiating reactivities, ρ_x^{max} , well in excess of 1\$ (here 1.6\$). If ρ_x^{max} is large enough, the net value, ρ_{net}^{max} , is determined by the ramp rate, independent of ρ_x^{max} itself.

The differential model of Ref. 6 has been converted into an integral model. All neutronics, decay heat and heat transfer balance equations are then expressed in terms of convolution integrals in a lucid unified description (Sections II to IV). In the finite differencing of the time scale, an implicit recursion formula for the convolution integrals was developed (Sec. III.3). Its application to neutronics as well as feedback brings the kinetics equation into the form of a quadratic equation, the "quadratic dynamics equation" (Sec. III.4).

This computational model has been programmed in GW-BASIC for PCs. The integral and implicit formulations allow transients to be run with a starting time step of 1 second, increasing gradually to about 32 seconds in the slower later phases of transients. A typical TOP transient of about 2.5 hours of duration is run on a 386 PC in about 10 minutes. Program compilation and application of a math-coprocessor could substantially reduce this running time.

Appendix A

Numerical Treatment of Convolution Integrals

Constant Lambda

For the finite difference evaluation of convolution integrals one has to distinguish three types:

- I. Convolution integrals, $V^I(t)$, over the fission power, $p_f(t)$, which directly affect the quadratic dynamics equation [Eq. (25a)]:

$$V^I(t_{n+1}) = \lambda \int_{-\infty}^{t_{n+1}} p_f(t') e^{-\lambda(t_{n+1}-t')} dt'; \quad (A1)$$

$p_f(t)$ is represented here by a parabola with the base points t_{n-1} , t_n , t_{n+1} ; the resulting formula is to be solved for $p_f(t_{n+1})$ [see Eqs. (16) through (20)].

- II. Convolution integrals over a driving function, $D(t)$, that needs to be extrapolated from t_n to t_{n+1} :

$$V^{II}(t_{n+1}) = \lambda \int_{-\infty}^{t_{n+1}} D(t') e^{-\lambda(t_{n+1}-t')} dt'. \quad (A2)$$

- III. Convolution integrals, $V^{III}(t)$, in which the driving function is being known up to and including t_{n+1} .

For the first type, the implicit finite difference scheme is described in Sec. II.3.1. It yields the "present" p_f - terms in the delayed neutron source [Eqs. (22)] and the feedback reactivity [Eq. (23)], which form the three terms of the quadratic dynamics equation, Eq. (25a).

In the second type, $D(t')$ is extrapolated through the last interval. An implicit scheme is not useful in this case as no component of $D(t_{n+1})$ can be obtained from Eq. (26). These convolution integrals make up those feedback terms that do not directly depend on the fission power.

The linear extrapolation applied in the calculation of V^{II} uses the slope at t_n , $\dot{D}(t_n)$, as obtained from a parabolic interpolation of the recent three values (t_{n-2} , t_{n-1} , t_n). To obtain the recursion formula for Eq. (A2), it is first split as in Eq. (17), with

$$\delta V(t_{n+1}) = \lambda \int_{t_n}^{t_{n+1}} \left[D(t_n) + \dot{D}(t_n)(t' - t_n) \right] e^{-\lambda(t_{n+1} - t')} dt' \quad (A3)$$

$$\delta V(t_{n+1}) = D(t_n)M_0 + \dot{D}(t_n)M_1, \quad (A3)$$

with M_0 and M_1 given in Eqs. (19). This results in

$$V(t_{n+1}) = V(t_n)e^{-\lambda \Delta t_n} + D(t_n)M_0 + \dot{D}(t_n)M_1, \quad (A4)$$

which is entirely calculated from prior values.

For the third type, V^{III} , a parabolic representation can be extended to t_{n+1} , using the base points t_{n-1} , t_n and t_{n+1} :

$$D(t) = d_0 + d_1(t - t_n) + d_2(t - t_n)^2, \quad (A5)$$

with $V(t_{n+1})$ given by

$$V(t_{n+1}) = V(t_n)e^{-\lambda \Delta t_n} + d_0 M_0 + d_1 M_1 + d_2 M_2. \quad (A6)$$

Time Dependent Lambda

The calculation of the hot and cold pool temperatures during an LOF transient requires the numerical evaluation of convolution integrals with a time dependent λ , given in Eq. (88). The finite difference formulation is derived in complete analogy with the one for constant λ , Eqs. (16) and (17), i.e. the convolution integral $V(t_{n+1})$,

$$V(t_{n+1}) = \int_0^{t_{n+1}} \Delta(t') \exp \left[- \int_{t'}^{t_{n+1}} \lambda(t'') dt'' \right] dt' \quad (A7)$$

is written as recursion formula

$$V(t_{n+1}) = X_{n+1} V(t_n) + \delta V(t_{n+1}) \quad (A8)$$

with

$$X_{n+1} = \exp \left[- \int_{t_n}^{t_{n+1}} \lambda(t) dt \right] \quad (A9a)$$

and

$$\delta V(t_{n+1}) = \int_{t_n}^{t_{n+1}} \Delta(t) \exp \left[- \int_t^{t_{n+1}} \lambda(t') dt' \right] dt \quad . \quad (\text{A9b})$$

The integrand $I(t, t_{n+1})$ is represented by a parabola:

$$I(t, t_{n+1}) = \lambda(t) D(t) \exp \left[- \int_t^{t_{n+1}} \lambda(t') dt' \right] = d_0 + d_1(t - t_n) + d_2(t - t_n)^2 \quad . \quad (\text{A10})$$

This gives for $\delta V(t_{n+1})$ simply

$$\delta V(t_{n+1}) = d_0 \Delta t_n + \frac{1}{2} d_1 \Delta t_n^2 + \frac{1}{3} d_2 \Delta t_n^3 \quad , \quad (\text{A11})$$

to be used in Eq. (A8).

Appendix B

LTC: LMR Transient Calculation Code Brief Description

A manual of the LTC code which includes a program-listing is issued separately (Ref. 7). Only a brief description of the LTC program is presented here. Primary emphasis is placed on the aspects that contribute to the reduction in the computation time and limit the storage requirements to the approximately 60K which can be addressed by GW-BASIC.

The program is written in GW-BASIC for an IBM XT (or compatible) with about 1050 lines of coding. A version in C has been programmed by M. E. Boerner (Ref. 8). In the GW-BASIC version about 200 lines are Input, Input echoing and Input editing screens, leaving about 850 lines for the actual program. The LOF transient is not included in the GW-BASIC version because of storage limitations (see below).

Temporal Structure

The program is run in blocks of equal time steps. The duration of each block is longer than the coolant flow delay (t_L) between core-outlet and inlet, so that prior values need to be "looked up" only in the same or the previous block. Then, only two blocks of arrays have to be retained in the memory. This allows to run the program for *any* length of time without storage problems. A further advantage of the use of time-step blocks is that all exponential functions need to be calculated only once per block. The flow delay time t_L for TOP and LOHS is typically about 20 to 30s. For LOF-transient this delay becomes much larger such that the storage requirements for saving the outlet history exceed the amount that can be addressed by GW-BASIC.

A typical initial time step is 1 second. Reduction of the initial time step to 0.50 and 0.25 seconds did not show any change in the power in the first 4 to 5 digits (see Sec. V.1). For each block the maximum percentage power change is calculated and, the time step size is doubled or halved depending on user specified limits. The advantage of the solution of the integral equations is that the time steps can be fairly large (≥ 1 s) compared to a solution of differential equations.

Acknowledgements

This work was supported by the Reactor Engineering Division. I'm grateful to John F. Marchaterre and Jim E. Cahalan for continued discussions. Special thanks are due to Jim Cahalan for running sample problems which have been a guidance through this method and program development.

References

1. J. C. Carter et al., "SAS1A, A Computer Code for the Analysis of Fast-Reactor Power and Flow Transients," ANL-7607, Argonne National Laboratory (1970).
2. F. E. Dunn, G. J. Fischer, T. J. Heames, P. Pizzica, N. A. McNeal, W. R. Bohl, and S. M. Prastein, "The SAS2A Accident Analysis Computer Code", ANL-8138 (Oct. 1974).
3. F. E. Dunn, personal communication, 1975.
4. J. F. Marchaterre, personal communication, September 1988.
5. J. E. Cahalan, personal communication, September 1988.
6. J. E. Cahalan, personal communication, April 1986.
7. K. O. Ott, "A Fast Reactor Transient Analysis Methodology for PCs: Vol. 2, LTC Program Manual," ANL/RE-91/2 Volume 2, Argonne National Laboratory (1991).
8. M. E. Boerner, unpublished report, ANL, November 1990.
9. K. O. Ott and R. J. Neuhold, "Nuclear Reactor Dynamics," American Nuclear Society, La Grange Park, Illinois, USA (1985).
10. K. O. Ott, Nuclear Science and Engineering, **99**, 13-27 (1988).
11. J. E. Cahalan, personal communication, August 1987.
12. Ref. 9, p. 165.
13. K. O. Ott and D. A. Meneley, Nuclear Science and Engineering, **36**, 402 (1969).
14. Ref. 9, p. 158.
15. R. H. Sevy, personal communication, August 1986.

END

**DATE
FILMED**

3 / 18 / 92