10
1-25-94 9501

SANDIA REPORT

SAND93-3900 • UC-212

Unlimited Release

Printed December 1993

Battery Energy Storage: A Preliminary Assessment of National Benefits (The Gateway Benefits Study)

Abbas Akhil, Hank Zaininger, Jonathan Hurwitch, Joseph Badin

Prepared by
Sandia National Laboratories
Albuquerque, New Mexico 87185 and Livermore, California 94550
for the United States Department of Energy
under Contract DE-AC04-94AL85000

Issued by Sandia National Laboratories, operated for the United States Department of Energy by Sandia Corporation.

NOTICE: This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government, any agency thereof or any of their contractors or subcontractors. The views and opinions expressed herein do not necessarily state or reflect those of the United States Government, any agency thereof or any of their contractors.

Printed in the United States of America. This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from
Office of Scientific and Technical Information
PO Box 62
Oak Ridge, TN 37831

Prices available from (615) 576-8401, FTS 626-8401

Available to the public from
National Technical Information Service
US Department of Commerce
5285 Port Royal Rd
Springfield, VA 22161

NTIS price codes
Printed copy: A03
Microfiche copy: A01

Battery Energy Storage: A Preliminary Assessment of National Benefits (The Gateway Benefits Study)

Prepared By

**Utility Battery Storage Systems Program
Sandia National Laboratories**

Abbas Akhil, Sandia National Laboratories
Hank Zaininger, Zaininger Engineering Company
Jonathan Hurwitch and Joseph Badin, Energetics, Inc.

Prepared for
Advanced Utility Concepts Division
Office of Energy Management
U.S. Department of Energy

December 1993

Abstract

Preliminary estimates of national benefits from electric utility applications of battery energy storage through the year 2010 are presented along with a discussion of the particular applications studied. The estimates in this report were based on planning information reported to DOE by electric utilities across the United States. Future studies are planned to refine these estimates as more application-specific information becomes available.

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

Contents

Background	1
Approach/Information Sources	1
Findings.....	2
Appendix I	I-1
Appendix II.....	II-1
Appendix III	III-1

Table

I Estimate of Benefits by Application.....	2
---	----------

Background

Electric utilities in the U.S. are facing new challenges to preserve the complex electrical network that has until now provided reliable, inexpensive electricity to support the nation's economy. In this time of change, recognition is growing that storage could be one option to help utilities build a secure energy future. Along with this recognition, there is a gradual shift away from centralized generation to distributed systems, and energy storage, especially battery energy storage, can play a crucial role because of its inherent modularity and siting flexibility. Battery energy storage has thus expanded from its limited role as a load-leveling resource to serve in many other applications such as generation and transmission and distribution, and to meet requirements on the customer's end of the utility network.

This analysis is a preliminary estimate of the impact of battery energy storage on a national scale based on the current understanding of its key benefits. Currently, there are limited data available on the value of these applications in the utility network. However, SNL, EPRI, and individual utilities are pursuing several studies that will further define and quantify their value in various utility scenarios. Results of these studies will enable future refinement of the estimates presented here, and revised versions of this study will be released as extensions of this preliminary report. Appendix I shows the outline and approach proposed for such a follow-on effort. It relies on a relatively detailed assessment, resulting in a higher degree of confidence and accuracy in the expected benefits.

This analysis and the future work planned to refine these estimates has been designated the "Gateway Benefits Study" to give this effort a unique identity.

Approach/Information Sources

The combined value of the benefits of battery energy storage for several utility applications on a national scale through the year 2010 were estimated in this "Gateway" Analysis. The benefits were obtained by examining utility operating and planning data reported to various regulatory and government agencies and using them to project the expected penetration of battery energy storage in the utility market. Potential savings to utilities through these applications of battery energy storage were compared to the cost of installing the battery systems, and a benefit-to-cost ratio was calculated.

Several information sources were used in preparing the estimated cost/benefit figures. Utility generation

expansion and transmission line addition data were obtained from the sources referenced in Appendix III. However, the distribution substation benefits could not be estimated because the necessary information is not reported by utilities to any agency in a consolidated form. Distribution substation planning information of the kind that is needed is generally available only from utilities on an individual basis. Efforts are being made to identify sources for obtaining this information, and it is expected that it will be available by the time the detailed follow-on assessment is undertaken in FY94. All assumptions, calculations and source data references used to support these estimates are contained in Appendix III.

The analysis is based on two important assumptions: (1) there are no changes in the regulatory climate of the investor-owned utilities and (2) distributed utility and integrated resource planning and evaluation have not had a major impact on utility planning practice, and traditional central station planning practice prevails. Deregulation of utilities, or a shift toward distributed utility or integrated resource planning, is not likely to change the estimate of absolute MW and MWh of battery systems installed, but it could have a significant impact on the *rate* and *manner* in which battery energy storage systems penetrate the utility energy storage market. If there is significant deregulation, then permitting, capital investment, and cost recovery of generation and transmission and distribution (T&D) assets would receive different treatment than under the existing regulated environment. With a direct effect on asset utilization, battery energy storage could emerge as an attractive option in a deregulated climate, a situation that could change the rate at which battery energy storage systems are brought on-line.

The specific utility applications and the related benefits considered in this analysis are listed below. A detailed description of each application and the source of the benefit is given in Appendix II.

Generation Applications

- Spinning reserve
- Capacity deferral
- Generation dispatch

Transmission and Distribution Applications

- Transmission line deferral
- Distribution substation

Customer-side Applications

- Demand-side management

Findings

The results of this analysis are summarized in Table I. These benefits are based on a cumulative market estimate of 11.33 GW of battery storage by the year 2010. The total national benefit is \$17.2 billion by 2010. The corresponding estimate of the capital cost of the battery systems needed to capture this benefit is \$9.06 billion, which yields a benefit/cost ratio of 1.9. An estimate of \$800/kW was used for the battery system cost for the entire study period, and no cost reductions were assumed in the out years resulting from higher production volumes and/or introduction of advanced battery technologies with improved performance and lower cost in the late 1990s and early 2000s.

Wide-scale implementation of resource planning concepts could impact how battery energy storage enters utility storage market. Both the distributed utility and the integrated resource planning concepts rely on small bundles of energy storage systems dispersed throughout the utility network to maximize asset utilization and facilitate the integration of distributed generation sources. Both methodologies favor smaller sizes of battery energy storage systems. Wider acceptance of these planning concepts may result in a large number of smaller sized battery energy systems being deployed by utilities, rather than the larger sizes preferred under central planning methodologies.

Table I. Estimate of Benefits by Application
Through 2010, in billions, 1993 \$
(Captured by installing 11.33 GW of batteries at a cost of \$9.06 billion)

Battery Energy Storage Application	Benefit
Generation	\$10.3
Spinning Reserve	\$3.3
Capacity Deferral	\$5.7
Generation Dispatch	\$1.3
Transmission and Distribution	\$3.9
Transmission Line Deferral	\$3.9
Distribution Substation*	TBD
Customer-Side	\$3.0
Demand-Side Management	\$3.0
Total Battery Energy Storage Benefits	\$17.2
Cost for Installing 11.33 GW of Battery Storage	\$9.1
Benefit/Cost Ratio	1.9

* Distribution substation benefits could not be estimated because of a lack of source data at the time of the analysis. Benefits related to this application will be estimated in the follow-on study.

Appendix I: Outline for a Proposed Follow-on National Benefits/Market Study*

Objectives

This two-phase study estimates the technical and financial benefits of battery energy storage to electric utilities at the national level. Phase I will focus on estimating the benefits of battery energy storage, and Phase II is a separate but related joint DOE-SNL/Industry supported market study that uses the findings of Phase I to estimate the size of the battery energy storage systems market in electric utility applications.

Approach

Phase I will be performed through the Utility Battery Storage Systems program at SNL and benefits of battery energy storage for one major region of the U.S. will be estimated within two to three months after the study starts. These estimates will quantify the economic benefits that could potentially be captured by electric utilities in one region of the U.S. through the widespread use of battery energy storage systems. The findings of the regional assessment will be extrapolated to estimate the impact of battery energy storage in the utility sector at the national level. The remaining section of this appendix details the proposed work plan and its salient features.

Phase II is an adjunct activity that utilizes the results of Phase I to estimate the size of the battery energy storage market for an extended study horizon comprised of several time windows. This information will be valuable for battery manufacturers and system suppliers to perform their business planning to meet the needs of this evolving market. It will also assist DOE in identifying specific program needs such that DOE support can be used effectively to accelerate the maturation of this market. It is proposed that Phase II be performed in partnership with an industry consortium made up of

utilities and battery system suppliers on a cost shared basis.

Description and Discussion of Work Plan for Phase I: Benefits Study

The Western Systems Coordinating Council (WSCC) is made up of 11 western states. The WSCC is one of nine regions recognized by the North American Electric Reliability Council (NERC) that make up the national utility network. The generation capacity installed in this region is approximately 150,000 MW, which represents 20% of the national capability. The WSCC also contains several major utilities such as PGE, SCE, and SMUD that are well informed about battery energy storage benefits and have conducted internal evaluations of this technology. PGE and SMUD are also likely to initiate battery projects in the near future.

Figure I-1 illustrates the major elements for Phase I of the study. The essence of this effort is to make two estimates of benefits for selected battery energy storage applications. One estimate is based on all relevant data reported by utilities to various regulatory and other agencies. These data include information on each utility regarding its current and future operations and are a good indicator of the generation resources available to the utility, both at present and in the future. Utilities also report information of load growth, fuel mix, etc. Examination of this data base will be a means for estimating the benefits that the utilities could derive by the use of battery energy storage systems.

A second estimate of the same benefits will be made through information obtained during on-site interviews with each utility's planning staff. These interviews will not reference the estimates derived earlier through the data screening steps and will be an independent estimation by each utility's planning staff of the

* Draft proposal submitted by SNL to DOE/OEM: June 1993

Figure I-1. SNL Utility Battery Storage Systems Program. Phase I: National Benefits Study Work Plan.

potential benefits that their network could derive through the use of battery energy storage.

These two estimates will be reconciled, as shown in Figure I-1, to provide a best estimate of the potential benefits of battery energy storage that may be available in the WSCC region. The WSCC estimates can be extrapolated to a national estimate through probabilistic analysis. There are several methodologies available for performing the probabilistic analysis segment of this

study, including the use of synthetic utility models that are available from EPRI. These synthetic utility models were created and are maintained by EPRI to represent all the features of a typical utility in each reliability region. The use of these models may be a preferred option to estimate the national benefits after the WSCC benefits estimate is complete. A decision of the preferred methodology has not been made at this time for this probabilistic segment of the study and will be determined at a later date.

Appendix II: Discussion of Battery Energy Storage Applications and Benefits

In the early 1980s, the concept of battery energy storage was based on the traditional role of storage in electric utility networks, that is, to reduce the utility's peak demand by discharging energy generated and stored during off-peak hours. The primary incentive for this mode of operation was to capture the differential in the cost of relatively inexpensive base-load generation and more expensive on-peak generation. Figure II-1 illustrates this with the typical summer and winter daily load profile from a representative utility whose generation resources include a mix of nuclear, coal, and oil-fired units as well as pumped storage. The lower plot shows the load profile for January 2, 1985, where the load peaked about 10:00 AM at 2600 MW and was supplied entirely by the baseload nuclear and coal units. The upper plot shows the load profile for a summer day (August 23, 1985). The load stayed above the 2600-MW mark and required baseload as well as the intermediate oil-fired units. At about 12:00 noon, the utility used up its fossil-fuel generation sources and dispatched the pumped storage to meet the peak demand. This condition lasted until about 7:00 PM, and the pumped storage discharge was terminated and the system load requirements were met with the fossil-fuel generation units. During this peak period, the utility discharged approximately 1000 MWh of stored energy over a seven-hour period to meet its system requirements.

This example is representative of the type of central storage capability needed to meet the load-leveling requirements of an average-sized utility with a peak summer load of about 4500 MW. Depending on load profiles, most utilities require storage capacities of four or more hours to perform any significant degree of load leveling, and pumped storage is the only conventional, commercial storage technology that can satisfy this requirement today. Typically, pumped storage units have power ratings of several hundred megawatts and storage capacities that range from 8 to 14 hours. But utilities have been constrained in utilizing pumped storage because of its severe environmental impact on land and water resources. Utilities recognize the economic

advantages of large-scale storage but cannot utilize it because no existing technology can meet the requirements for such a system. Considering the long discharge time requirement, it was clear by the late 1980s that existing lead-acid battery energy storage systems could not perform this function economically, and utilities showed little interest in utilizing this technology in this mode.

However, if the battery system size is reduced and no more than two to three hours of storage capacity are needed to meet a particular application's requirement, then battery systems could offer benefits that have economic value to the utility. In this size range, battery energy storage systems could also take advantage of their other distinguishing attributes, such as modularity, fast response, and a high degree of siting flexibility, that are not available with other generation or conventional storage technologies. By the late 1980s, utility applications that required smaller storage capacities had been identified, and there was a renewed interest in battery storage systems and in trying to quantify their benefits.

Specific types of battery energy storage applications and benefits that could be captured by relatively small-sized battery systems with one to three hours of storage capability were identified by four system studies conducted by the SNL Utility Battery Storage Systems program during FY 91 and 92. These studies, along with studies conducted by EPRI, identified battery benefits in the generation, transmission, and end-use areas of the utility network as listed below:

- Generation benefits
 - Spinning reserve
 - Capacity deferral
 - Generation dispatch
- Transmission & Distribution benefits
 - Transmission line deferral
 - Distribution substation upgrade deferral
- Customer-side benefits
 - Demand-side management

Figure II-1. Typical Daily Load Profile for Winter and Summer and Generation Mix.

Each of these applications and their qualitative benefits are described in more detail in the remainder of this appendix.

Spinning Reserve

Utilities are required to hold a certain amount of generation capacity in reserve at all times to make up the capacity lost from the unscheduled outage of any generating unit. Typically, this requirement is met by operating fast response combustion turbines or backing down coal units to replace the lost capacity quickly until the system operator can take control measures and bring other generation on-line to make up the shortage. Battery energy storage can effectively displace the fossil-fueled generating units operated in spinning reserve duty, thereby saving the cost of fossil fuel and freeing up the generation capacity otherwise set aside for spinning reserve.

Batteries systems used primarily for spinning reserve do not need high cycle life because events that typically generate the need for spinning reserve occur no more than one or two times a month on the utility network. When such an event occurs, the utility system operator needs less than 30 minutes to bring the system under control. Thus, spinning reserve is required only

until the operator stabilizes the utility network, and battery energy systems for spinning reserve do not need more than 30 to 40 minutes of storage capability. The use of battery systems in this application has been demonstrated successfully by BEWAG, which is the electric utility that serves Berlin, Germany. BEWAG installed such a battery to provide frequency control and spinning reserve to the Berlin area when it was a divided city and electrically isolated from neighboring utility networks. Encouraged by the success of the BEWAG battery, the Puerto Rico Electric Power Authority purchased a 20-MW/14-MWh battery system to perform the same function for their system. This battery will be operational in late 1993/early 1994.

Capacity Deferral

Capacity deferral is a benefit that can be claimed when a battery energy storage system defers the need for adding new generation capacity to meet the load growth in a utility network. Because of economies of scale and generation unit size availability, utilities can add new generation only in large increments of several hundred megawatts. Generation additions in these size increments usually have a low level of initial utilization until the utility system load grows. Battery storage systems

are more modular and can be installed in much smaller incremental sizes that are more closely matched to the utility system load.

Generation Dispatch

At any given time, a utility typically operates sufficient number of generation units to satisfy the system load. However, because of inherent mismatches in aggregate kW capacity of the generation units and system load requirements, one or more of the operating units have to be operated at partial loads. Such a condition might persist for several hours every day until the system load grows and the partially loaded units can be ramped up to more efficient operating set points.

Under these conditions, battery energy storage can be used very effectively to decommit and/or more economically dispatch the otherwise partially loaded units, until the system load requirements more closely match the incremental output of the available generating units.

Transmission Line Deferral

Battery energy storage can be used to defer the construction of new transmission lines to import more power into a service area by meeting load during peak hours. Utilities could potentially perceive battery energy storage as an attractive alternative to new transmission additions because the permitting process for new lines is becoming unacceptably long from delays caused by environmental concerns.

Distribution Substation

If a battery energy storage system is installed at a substation, it can effectively defer planned substation upgrades that would otherwise be necessary to meet new load growth in the substation service area. In this mode, the battery system can defer the transformer upgrade or, in some cases, the need to build a new substation. This application requires battery systems in the 2 to 3 MW range, with storage capability of two or three hours.

This is a relatively new concept for using storage in the utility network because the traditional preconceptions of what a storage system should look like precluded the visualization of storage down at the substation level. Until now, substation planners in utility systems did not consider storage as a viable option in their planning scenarios. Today's lead-acid battery tech-

nology makes it possible to package a self-contained storage system of 1 to 3 MW and locate it within the boundary of an existing substation. Such a package also meshes well with the distributed utility planning and provides the hardware that can demonstrate its benefits in the near term.

Studies on substation feeder loads performed by Pacific Gas & Electric show the economic viability of a storage system based on asset utilization within the utility network. Figure II-2 shows the load duration on approximately 3000 feeders in the PG&E system. This figure shows that most substation feeders are loaded to their peak capacity for less than 10% of the time, or less than 870 hours per year. Since the system peak is the aggregate of individual feeder peaks, a storage device placed on those feeders with peaks that are coincident with the system peak could offer substantial benefits. In this application, the storage system not only defers the need for upgrading local substation facilities but indirectly also reduces the need for new peaking generation capacity at the system level. In this sense, the combined effect of all storage systems dispersed at the substations is to collectively perform a function equivalent to the original load leveling concept that has been the ultimate goal of battery energy storage application in utility networks.

As stated earlier, this is a new concept, and its benefits and the hardware that can perform this function are in the developmental stages. PG&E has received proposals for the design and fabrication of prototype systems to demonstrate feasibility of the concept. It is expected that it will be built and fielded in late 1994 or early 1995.

However, because of a lack of data on substation activity, the benefits associated with this application could not be estimated at this time. These benefits will be estimated in the more detailed assessment planned for the future.

Demand-Side Management

Battery energy storage systems can be installed at the customer site to reduce the kW peak and hence reduce the demand charges that are assessed based on the peak kW load. Industries with heavy machinery, or processes that create a sudden, sharp demand for electricity are suitable candidates for the installation of a battery energy storage system to reduce the peak. Battery systems that are less than 1 MW in size, with a storage capability of one or two hours, can satisfy this application's requirements.

Figure II-2. Feeder Load Duration Estimates (~3000 feeders).

Appendix III: Assumptions, Calculations, and Source Data References

Market Calculation

Generation

The generation capacity outlook for electric utilities is based on resource plans to meet growth in electricity demand. As competitive forces grow, so do the uncertainties and the array of options utilities will pursue. Among the options being considered are increasing output of existing plants; extending the lives of existing plants; increasing investment in demand-side management; purchasing power from nonutility generators; importing power from Canada and Mexico; and building new plants.

In terms of new construction, until the year 2000, utilities will have excess capacity to serve baseload needs and will be adding gas-fired combined-cycle and combustion turbines to serve intermediate and peak needs. After 2000, baseload additions will be needed, while intermediate and peak plants will still account for a large portion of new additions.

As shown below, peak capacity will grow from 54.9 GW in 1995 to almost 80.1 GW by 2010. It is assumed that battery systems will defer 25% of the projected peaking capacity to the year 2000, and 50% of this capacity through 2010. This results in a potential market of 9.18 GW, as shown below.

[Reference: Table A.5 Electricity Generating Capability - DOE/EIA Annual Energy Outlook 1993 - Combustion Turbine/Diesel (GW)]

Year	GW
1995	54.9
2000	68.6
2010	80.1

Peak Capacity Deferral Assumptions:

25% from 1995-2000

50% from 2000-2010

Potential Market (GW):

$$0.25 (68.6 - 54.9) + 0.50 (80.1 - 68.6) \\ = 3.43 + 5.75 = 9.18 \text{ GW}$$

Potential Market:

9.18 GW (approximately 1.2% of total installed capacity)

Demand-Side Management

According to utility reports, the impacts of utility-sponsored demand-side management (DSM) programs have reduced peak demand by 25 GW in 1990 and will reduce it by 56 GW by the year 2000, which accounts for approximately 10% of utility needs. DSM savings are projected in the National Energy Strategy (NES) to be 57 billion kWh/yr in 2000 and 171 billion kWh/yr, by 2010.

It is assumed that current trends in peak capacity reductions will continue through the year 2010, and then DSM reductions will track the rate of growth for electricity demand at an average of 1.5% to 2% per year. The following table presents the capacity trends through 2010:

Year	Peak Capacity (GW)	DSM Savings (GW)	DSM Savings (%)
1990	46.4	25	35.0
2000	68.6	56	44.9
2010	80.1	109*	57.6

* Extrapolated from 1990-2000 trends.

The DSM market for battery storage can be estimated based on the following conservative assumptions: a market penetration of 1% in the year 2000 and 3% by the year 2010, which is based on the energy tripling from 2000 to 2010. An estimated 53-GW peak reduction between 2000 and 2010 could be expected (109 GW - 56 GW).

[Reference: Pg. 50 DOE/EIA Annual Energy Outlook 1993 - DSM Programs and Table A-23 DSM Savings Assumptions - NES Technical Annex, 2, 1991/1992.]

Potential Market (GW)
 $= (56 \text{ GW} \times .01 + 53 \text{ GW} \times .03)$
 $= 0.56 \text{ GW (2000)} + 1.59 \text{ GW (2010)}$
 $= 2.15 \text{ GW}$

ESTIMATED TOTAL BATTERY MARKET
 $= 9.18 + 2.15 = 11.33 \text{ GW by 2010}$

The total potential battery market is comprised of peak capacity deferral on the supply side and demand-side savings on the customer side of the system. The market estimates are additive.

Transmission Market

Typically, an expansion of transmission facilities must accompany an expansion of generation if a system is to be adequate and reliable. Even when generating facilities are not added, transmission systems are modified from time to time to accommodate changes in the load. Strategic siting of battery systems such as at the end of a long line or dispersed in an urban load center can defer transmission expansion.

Generally, projected transmission additions are keeping pace with generation additions. The ratio of miles of transmission line (22 kV and above) per megawatt of installed capacity has reached an asymptote of 0.857. Also, the ratio of extra high voltage (EHV) transmission miles is approximately 11.56% of total transmission circuit miles.

The calculations below establish the basis of transmission line additions.

Ratio: Transmission Circuit Miles (22 kV and above to Installed Capacity (MW)
 $= 0.857$

Ratio: EHV (254 kV and above) to Total Transmission (22 kV and above)
 $= 11.56\%$

Year 2000: $0.857 \times 809,000 \text{ MW}$
 installed
 $= 693,313 \text{ miles (22 kV +)}$
 $= 80,147 \text{ miles EHV}$

Year 2010: $0.857 \times 897,000 \text{ MW}$
 installed
 $= 768,729 \text{ miles (22 kV +)}$
 $= 88,865 \text{ miles EHV}$

Difference 2000-2010 = 75,416 miles,
 22 kV and above and 8,718 miles EHV
 (254 kV and above)

[Reference: 22 kV and above: Chapter 5, Staff Report, Electric Power Supply and Demand for Contiguous US. 1989-1998, March 1990, US Department of Energy.]

Benefits Calculation

Generation

Studies involving production cost models indicate that batteries are often worth considerably more serving as spinning reserve rather than being cycled for supplying peak electricity.

As an alternative to using the battery as a charge/discharge unit, a utility could use a battery only to provide spinning reserve with benefits that include shutting down the least efficient units and allowing generating units to operate at a higher load, thus reducing their average heat rates. The system total operating costs would be substantially lower.

Operating reserve criteria vary from utility to utility and NERC region to NERC region. Operating reserve policy generally consists of on-line MW spinning reserve requirements plus additional off-line quick start generation capable of responding within a specified time period (10 - 30 minutes). Spinning reserve typically includes unused MW capability of generators operating at partial load to cover sudden loss of generation.

Since batteries can be quickly started or changed from charging to discharging in the millisecond time frame, they can be used to supply the spinning reserve requirement. The potential benefit will depend on the type of generation used for spinning reserve.

Potential economic benefits from battery storage systems are expected to include

- More efficient operation of units that would otherwise operate at partial load to provide spinning reserve and
- Cost savings from not running higher cost units that would otherwise have to operate to provide spinning reserve.

It is also expected that batteries used for this application would only have to operate until other generation units could be started or power purchased after sudden loss of a generating unit. Hence, batteries used for spinning reserve would probably not require large MWh storage capability.

Spinning Reserve: The benefit for spinning reserve is approximately 0.4% of total production cost.

[Reference: Zaininger, "Benefits of Battery Storage as Spinning Reserve," EPRI-AP-5327.]

National Production Costs = \$70 B/year in 1990.

[Reference: Financial Statistics for Selected Investor-Owned Electric Utilities, 1990, DOE/EIA-0437.]

Annual Benefit: $0.4\% \times 70 \text{ B} = \$280 \text{ M/year in } 1990 \times (1.04)^5 = \$340 \text{ M/year in } 1995$ (assuming long-term inflation is 4%.)

Present Value: $(6\%, 1995-2010, 15 \text{ years}) = \$340 \text{ M} \times 9.712 = \3.3 B (assuming 6% weighted average cost of capital as utility discount rate)

Spinning Reserve Benefits = \$3.3 billion

Capacity Deferral: Battery systems will displace 9.18 GW of peaking capacity by 2010 (Section 1.1). The capital cost of a peaking unit (combustion turbine) is about \$500/kW. The estimated benefit (cost deferral) is calculated below.

Capital cost of combustion turbine = \$500/kW

Potential market = 11.33 GW (from Generation, p. III-1)

Benefit = $11.33 \text{ GW} \times 500 \text{ $/k}$
= \$5.665 B $\approx$ \$5.7 B

Capacity Deferral Benefit = \$5.7 billion

Generation Dispatch Benefits: In some utilities, there is a significant difference in incremental fuel costs during daily peak load periods and during minimum night loads. In addition, some utility systems, with large base-load units and a relatively low minimum load, experience difficulty in dispatching during morning load pick-up and off-peak hours. Economic dispatch, unit minimum load limits, and minimum down time requirements of base-load units cause this problem.

Batteries may be employed to dispatch the generation system and solve these daily dispatch problems more economically. For example, batteries may be discharged during daily peaks or ramped (from full charge to full discharge) at a higher rate during the morning load pick-up and ramped in the opposite direction during the evening load drop-off period. In addition, charging batteries at night can increase night generation levels and reducing daily cycling constraints.

Batteries may only require one to two hours of storage to relieve unit ramping constraints during morning pick-up and evening drop-off periods. However, several hours of energy storage are required to relieve daily generation unit cycling constraints.

Generation dispatch, including ramping and decommitment, is approximately 40% of spinning reserve benefit.

(References: SNL System Studies for Oglethorpe and San Diego Gas & Electric; Zaininger, "Benefits of Battery Storage as Spinning Reserve," EPRI AP-5327.)

Benefit: $40\% \times \$3.3 \text{ B} = \1.3 B

Generation Dispatch Benefit = \$1.3 billion

Demand-Side Management

From the customer perspective, the key benefits of battery DSM are monthly demand charge reductions and potential power quality improvements. Conservatively, focusing only on the demand charge savings, the estimated benefits are calculated as follows:

Typical Large Customer Demand Charge: \$12/kW per month

[Reference: EPRI - AP/EM-5895.]

Potential Market: 2.15 GW (from Demand-Side Management, p. III-2)

Annual Benefit: $2.15 \text{ GW} \times 12 \text{ $/kW month} \times 12 \text{ months} = \309.6 M/yr.

Present Value: $\$309.6 \text{ M/yr.} \times 9.712 = \$3.007 \text{ B} \approx \3.0 B (9.712 is the present value factor for 6% discount rate, 15 years)

**Demand-Side Management Benefits
= \$3.0 billion**

Transmission Deferral (22 kV and Above)

As discussed in the Transmission Market subsection, transmission line expansion tracks generation expansion in proportion to a fairly constant ratio (.857). Based on generation capacity deferrals shown there, transmission line deferrals are calculated. The expected benefits are based on half the transmission circuit miles, since battery systems would still require one-way transmission expansion (as opposed to a round-trip transmission circuit expansion).

1995 - 2000: $3.43 \text{ GW} \times 0.857 \text{ (ratio)}$
= 2,940 miles
Expected deferral of 50%
= 1,470 miles

2000 - 2010: $5.75 \text{ GW} \times 0.857 \text{ (ratio)}$
= 4,928 miles
Expected deferral of 50%
= 2,464 miles

Total deferral: $1,470 + 2,464 = 3,934 \text{ miles}$ (22 kV and above)

Average cost of 1 mile of transmission is about \$1 M.

[Reference: SNL System Studies for Oglethorpe, San Diego Gas & Electric, EPRI Report GS-6687, Table 2-2.]

Benefit = $3,934 \text{ miles} \times \1 M/mile
= $\$3.934 \text{ B} \approx \3.9 B

Transmission Deferral Benefit = \$3.9 billion

References

- Battelle-Columbus, "Load-Leveling Lead Acid Battery Systems for Customer-side Applications—Market Potential and Commercialization Strategy," EPRI-AP/EM-5895, July 1988, p. S-3.
- Gjerde, A.R., Haas, S.M., Jabbour, S.J., et al., "Potential Benefit Storage to San Diego Gas and Electric—A Screening," prepared for Sandia National Laboratories and San Diego Gas & Electric, Jan. 1992, Table 3.3, pp. 3-4.
- Prabhakara, F.S., Clark, H.K., "An Estimate of Battery Energy Storage Benefits on the Oglethorpe Power System," prepared for Sandia National Laboratories and Oglethorpe Power Corp., PTI No. 147-92, Dec. 1992, p. 55.
- U.S. Department of Energy, "National Energy Strategy, Technical Annex 2," 1991/1992, Table A-22, pg. 93, Table C-15, p. 127.
- U.S. Department of Energy, "Staff Report, Electric Power Supply and Demand for the Contiguous United States, 1989-1998," March 1990, Chapter 5.
- U.S. Department of Energy, "Annual Energy Outlook, 1993," DOE/EIA-0383(93), Jan. 1993, p. 50.
- U.S. Department of Energy, "Financial Statistics of Selected Investor-Owned Electric Utilities, 1990," DOE/EIA-0437(90), Jan. 1992, Table 12, p. 26.
- Zaininger, H.W., "Benefits of Battery Storage as Spinning Reserve: Quantitative Analysis," EPRI-AP-5327, July 1987, Table S-1, p. S-2.
- Zaininger, H.W., Clark, H.K., Brownell, G.C., "Potential Economic Benefits of Battery Storage to Electrical Transmission and Distribution Systems," prepared for EPRI, EPRI GS-6687, Jan. 1990, Table 2-2, p. 2-4.

Distribution

ABB Power T&D Co., Inc. (2)
630 Sentry Parkway
Blue Bell, PA 19422
Attn: P. Danfors
H. Weinrich

AC Battery Corporation
P.O. Box 325
East Troy, WI 53120
Attn: R. Flemming

Alaska Energy Authority
P.O. Box 190869
Anchorage, AK 99519-0869
Attn: D. Denig-Chakroff

American Electric Power Service Corp.
1 Riverside Plaza
Columbus, OH 43215
Attn: C. Shih

Argonne National Laboratories (3)
CTD, Building 205
9700 South Cass Avenue
Argonne, IL 60439
Attn: C. Christianson
W. DeLuca
K. Myles

Arizona Public Service
P.O. Box 5399
Phoenix, AZ 85072
Attn: R. Hobbs

AT&T Energy Systems
3000 Skyline Drive
Mesquite, TX 75149
Attn: M. Bize

Bechtel
P.O. Box 193965
San Francisco, CA 94119-3965
Attn: W. Stolte

Bonneville Power Administration
Routing EO
P.O. Box 3621
Portland, OR 97208
Attn: J. Ray

C&D Charter Power Systems, Inc.
3043 Walton Road
P.O. Box 239
Plymouth Meeting, PA 19462-0239
Attn: S. Misra

California State Air Resources Board
Research Division
P.O. Box 2815
Sacramento, CA 95812
Attn: J. Holmes

Chugach Electric Association, Inc.
P.O. Box 196300
Anchorage, AK 99519-6300
Attn: T. Lovas

Consolidated Edison (2)
4 Irving Place
New York, NY 10003
Attn: M. Lebow
N. Tai

Corn Belt Electric Cooperative
P.O. Box 816
Bloomington, IL 61702
Attn: R. Stack

Decision Focus, Inc.
650 Castro Street, Suite 300
Mountain View, CA 94041
Attn: S. Jabbour

Delco-Remy
7601 East 88th Place
Indianapolis, IN 46256
Attn: R. Rider

Distribution

Doug Danley
18131 Metz Dr.
Germantown, MD 20874

Eagle-Picher Industries
C & Porter Street
Joplin, MO 64802
Attn: J. DeGruson

East Penn Manufacturing Co., Inc.
Deka Road
Lyon Station, PA 19536
Attn: M. Stanton

Electric Power Research Institute (6)
3412 Hillview Avenue
P. O. Box 10412
Palo Alto, CA 94303
Attn: J. Birk
S. Chapel
S. Eckroad
R. Schainker
P. Symons
R. Weaver

Electrotek Concepts, Inc.
P.O. Box 16542
Chattanooga, TN 37416
Attn: H. Barnett

Eltech Research Corporation
625 East Street
Fairport Harbor, OH 44077
Attn: E. Rudd

Energetics, Inc. (5)
7164 Columbia Gateway Drive
Columbia, MD 21046
Attn: J. Badin
D. Baker
J. Hurwitch
C. Matzdorf
P. Taylor

Energy Systems Consulting
41 Springbrook Road
Livingston, NJ 07039
Attn: A. Pivec

Exxon Research Company
P.O. Box 536
1900 East Linden Avenue
Linden, NJ 07036
Attn: P. Grimes

Firing Circuits, Inc.
P.O. Box 2007
Norwalk, CT 06852-2007
Attn: J. Mills

General Electric Company (2)
Building 2, Room 605
1 River Road
Schenectady, NY 12345
Attn: E. Larson
D. Swann

General Electric Drive Systems
1501 Roanoke Blvd.
Salem, VA 24153
Attn: C. Romeo

Giner, Inc.
14 Spring Street
Waltham, MA 02254-9147
Attn: A. LaConti

GNB Industrial Battery Company (3)
Woodlake Corporate Park
829 Parkview Blvd.
Lombard, IL 60148-3249
Attn: S. Deshpande'
G. Hunt
J. Szymborski

Hawaii Electric Light Co.
P.O. Box 1027
Hilo, HI 96720
Attn: C. Nagata

Hughes Aircraft Company
P.O. Box 2999
Torrance, CA 90509-2999
Attn: R. Taenaka

Integrated Power Corp.
7524 Standish Place
Rockville, MD 20855
Attn: J. Adelman

ILZRO
P.O. Box 12036
Research Triangle Park, NC 27709
Attn: R. Nelson

Johnson Controls Battery Group, Inc. (4)
5757 N. Green Bay Avenue
P. O. Box 591
Milwaukee, WI 53201
Attn: P. Eidler
R. Miles
T. Ruhlmann
W. Tiedeman

Johnson Controls Battery Group, Inc.
12500 W. Silver Spring Drive
P. O. Box 591
Milwaukee, WI 53201-0591
Attn: J. Zagrodnik

Lawrence Berkeley Laboratory (3)
University of California
One Cyclotron Road
Berkeley, CA 94720
Attn: E. Cairns
K. Kinoshita
F. McLarnon

Jo Meglen
P.O. Box 3232
Oakton, VA 22124

N.E.T.S.
P.O. Box 32584
Juneau, AK 99803
Attn: T. Neubauer

National Renewable Energy Laboratory (3)
1617 Cole Blvd.
Golden, CO 80401-3393
Attn: R. McConnell
J. Ohi
N. Rau

New York Power Authority
1633 Broadway
New York, NY 10019
Attn: B. Chezar

Northern States Power
414 Nicollet Mall
Minneapolis, MN 55401
Attn: M. Rogers

Oak Ridge National Laboratory
P.O. Box 2008
Oak Ridge, TN 37831
Attn: B. Hawsey, Bldg. 3025, MS-6040
J. Stoval, Bldg. 3147, MS-6070
J. VanCoeveering, Bldg. 3147, MS-6070

Oglethorpe Power Company (2)
2100 E. Exchange Place
P.O. Box 1349
Tucker, GA 30085-1349
Attn: K. Scruggs
C. Ward

Omnion Power Corporation (2)
P.O. Box 879
East Troy, WI 53120
Attn: H. Meyer
F. Ruf

Pacific Gas & Electric (3)
3400 Crow Canyon Road
San Ramon, CA 94583
Attn: G. Ball
B. Norris
R. Winter

Pacific Northwest Laboratory (2)
Battelle Blvd.
Richland, WA 99352
Attn: J. DeSteeze, K5-02
K. Drost

Power Technologies, Inc.
1482 Erie Blvd.
P.O. Box 1058
Schenectady, NY 12301
Attn: P. Prabhakara

Power Technologies, Inc.
775 Sunrise Ave.
Suite 210
Roseville, CA 95661
Attn: H. Clark

Puerto Rico Power Authority
G.P.O. Box 4267
San Juan, Puerto Rico 00936-426
Attn: W. Torres

R&D Associates
2100 Washington Blvd.
Arlington, VA 22204-5706
Attn: J. Thompson

Robicon Corporation
100 Sagamore Hill Road
Pittsburgh, PA 15239
Attn: A. Maruschak

Sacramento Municipal Utility District
6201 S. Street
Sacramento, CA 95817
Attn: L. Wittrup

Salt River Project
MS PAB 357, Box 52025
Phoenix, AZ 85072-2025
Attn: H. Lundstrom

San Diego Gas & Electric Company (2)
P.O. Box 1831
San Diego, CA 92112
Attn: T. Nelson
J. Wight

W. J. Schafer Associates
303 Lindbergh Avenue
Livermore, CA 94550-9551
Attn: S. Schoenung

R. K. Sen & Associates
3808 Veazey Street NW
Washington, DC 20016
Attn: R. Sen

Silent Power, Inc.
163 West 1700 South
Salt Lake City, UT 84115
Attn: J. Rassmussen

Silent Power, Inc.
489 Devon Park Drive
Suite 315
Wayne, PA 19087
Attn: W. Auxer

Silent Power, Ltd.
Davy Road, Astmoor
Runcorn, Cheshire
UNITED KINGDOM WA7 1PZ
Attn: M. McNamee

Southern California Edison (2)
2244 Walnut Grove Avenue
P.O. Box 800
Rosemeade, CA 91770
Attn: A. Rodriguez
R. Scheffler

SRI International
333 Ravenswood Ave.
Menlo Park, CA 94025
Attn: C. Seitz

Stuart Kuritzky
347 Madison Avenue
New York, NY 10017

Superconductivity, Inc.
2114 Eagle Drive
Middleton, WI 53562
Attn: J. Emerick

United Engineers and Contractors
700 South Ash St.
P.O. Box 5888
Denver, CO 80217
Attn: A. Randall

University of Missouri - Rolla
112 Electrical Engineering Building
Rolla, MO 65401-0249
Attn: M. Anderson

University of Wisconsin - Madison
Dept. of Electrical & Computer Eng.
1415 Johnson Drive
Madison, WI 53706
Attn: D. Divan

U.S. Department of Energy
Energy Information Administration
EI-531 FORSTL
Washington, DC 20585
Attn: T. Petersik

U.S. Department of Energy
Office of Energy Management
EE-14 FORSTL
Washington, DC 20585
Attn: M. Gunn

U.S. Department of Energy (21)
Office of Energy Management
EE-142 FORSTL
Washington, DC 20585
Attn: R. Eaton (20)
N. Rossmeissl

U.S. Department of Energy
Office of Propulsion Systems
EE-321 FORSTL
Washington, DC 20585
Attn: A. Landgrebe

U.S. Department of Energy
Albuquerque Operations Office
Energy Technologies Division
Albuquerque, NM 87115
Attn: G. Buckingham

U.S. Windpower, Inc.
6952 Preston Avenue
Livermore, CA 94550
Attn: B. Erdman

Westinghouse STC
1310 Beulah Road
Pittsburgh, PA 15235
Attn: H. Saunders

W. R. Grace & Company
62 Whittemore Avenue
Cambridge, MA 02140
Attn: S. Strzempko

Yuasa-Exide
P.O. Box 14205
Reading, PA 19612-4205
Attn: F. Tarantino

Zaininger Engineering Co., Inc.
1590 Oakland Road, Suite B211
San Jose, CA 95131
Attn: H. Zaininger

2000 H. Schmitt
2200 R. Bair
2206 R. Clark
2206 L. Lachenmeyer
2222 K. Grothaus
2223 D. Doughty
2225 P. Butler (10)
2225 A. Akhil
2225 J. Braithwaite
2225 N. Clark
2225 J. Freese
2225 R. Jungst
2225 S. Klassen
10214 J. Kerr, Attn: D. Wilt
6200 D. Arvizu
6213 T. Bickel
6218 W. Bower
6218 R. Bonn
8111 P. Falcone
8300 W. McLean
8523-2 Central Technical Files
7141 Technical Library (5)
7151 Technical Publications
7613-2 Document Processing for
DOE/OSTI (10)

END

**DATE
FILMED**

2/23/94