PNL-SA--19963

DE92 006515

FLUORESCENCE LIFETIME MEASUREMENTS
OF SM:YAG AND POTENTIAL USE AS AN
OPTICAL THERMOMETER

N. J. Hess
G. J. Exarhos
S. M. Wood

December 1991

Presented at the
American Geophysical Union
Fall Meeting 1991
December 3-9, 1991
San Francisco, California

Work supported by
the U.S. Department of Energy
under Contract DE-AC06-76RL0 1830

Pacific Northwest Laboratory
Richland, Washington 99352

MASTER

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

12/9-13/91

Fluorescence Lifetime Measurements of Sm:YAG and Potential use as an Optical Thermometer

NJ Hess and GJ Exarhos (Pacific Northwest Laboratory, Richland WA 99352)
S Wood (Shock Dynamics Laboratory, Washington State University, Pullman WA 99163)

In situ phase equilibrium studies require a means of accurate pressure and temperature measurement. Earlier work has demonstrated that the frequency shift of the laser-induced fluorescence of samarium-doped yttrium aluminum garnet, Sm:YAG, can be used without temperature correction as a pressure sensor for high temperature diamond anvil cell experiments. Reported here are the results of preliminary studies on the temperature and pressure dependence of the Sm:YAG fluorescence lifetime and its use as a possible optical thermometer.

The lifetime of laser-induced fluorescence of Sm:YAG was measured as a function of Sm dopant concentration, temperature, and pressure using the phase modulation technique. The Sm dopant concentration was varied between 0.1 to 3.0 % mole fraction Y in crystalline powders prepared from a metal nitrate precursor solution. The temperature dependence of the lifetime was measured between 20 and 1200 °C. For all dopant concentrations, a similar temperature dependence is observed; namely, at low temperature the lifetime is insensitive to temperature and at higher temperature the lifetime decreases sharply. In addition, the temperature at which the lifetime becomes strongly temperature dependent varies with dopant concentration. Preliminary high pressure studies indicate the lifetime of Sm:YAG is relatively unchanged to 40 kbar. These results suggest that the Sm:YAG fluorescence lifetime may be a promising optical thermometer for high pressure experiments and that the region of temperature sensitivity can be "tuned" by varying the dopant concentration.

1. 1991 Fall meeting
2. 009269781
3. (a) NJ Hess
Battelle
PO Box 999, K2-44
Richland WA 99325
(b) 509 375-2142
(c) 509 375-2186
4. V
5. (a) Mineral Physics
(b) 3994 Instruments
and techniques
3924 High-pressure
behavior
(c) Mineral Physics
- 6.
7. 0%
8. \$60.00
MC: 5425 1802 0525 5547
exp: 6/93
Nancy J. Hess
9. c
10. yes
11. no

END

**DATE
FILMED**

2 / 26 / 92