DISTRIBUTION SHEET

To J. P. Harris	From J. R. Bellomy	Page 1 of 1
Project Title/Work Order Project W-320 Heel Jet Secondary Catch Mechanism Lateral Load Test - Test Report		Date 2-09-95
		EDT No. 606586
		ECN No. N/A

Name	MSIN	Text With All Attach.	Text Only	Attach./ Appendix Only	EDT/ECN Only
D. E. Ball	G6-46		X		
J. R. Bellomy	S6-12	X			
J. P. Harris	S6-12		X		
J. J. Huston	S6-12		X		
T. C. Mackey	S2-03	X			
Central Files (2)	L8-04	X (2)			
O.S.T.I. (2)	L8-07	X (2)			

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

FEB 10 1995 Sta. #3 58	ENGINEERING DATA TRANSMITTAL	Page 1 of <u>1</u> 1. EDT 606586
---	-------------------------------------	--

2. To: (Receiving Organization) Retrieval Engineering	3. From: (Originating Organization) Retrieval Engineering	4. Related EDT No.: N/A
5. Proj./Prog./Dept./Div.: W-320 / Org. 7F820	6. Cog. Engr.: J. R. Bellomy	7. Purchase Order No.: N/A
8. Originator Remarks: Original Issue of Supporting Document for Approval		9. Equip./Component No.: N/A
11. Receiver Remarks:		10. System/Bldg./Facility: 241-C-106
		12. Major Assm. Dwg. No.: H-2-83746, H-2-83747
		13. Permit/Permit Application No.: N/A
		14. Required Response Date: ASAP

15. DATA TRANSMITTED					(F)	(G)	(H)	(I)
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	Approval Designator	Reason for Transmittal	Originator Disposition	Receiver Disposition
1	WHC-SD-W320-TRP-001		0	Project W320 Heel Jet Secondary Catch Mechanism Lateral Load Test - Test Report	SQ	1	1	

16. KEY					
Approval Designator (F)		Reason for Transmittal (G)		Disposition (H) & (I)	
E, S, Q, D or N/A (see WHC-CM-3-5, Sec.12.7)		1. Approval	4. Review	1. Approved	4. Reviewed no/comment
		2. Release	5. Post-Review	2. Approved w/comment	5. Reviewed w/comment
		3. Information	6. Dist. (Receipt Acknow. Required)	3. Disapproved w/comment	6. Receipt acknowledged

17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)										(G)	(H)
(G)	(H)	(J) Name	(K) Signature	(L) Date	(M) MSIN	(J) Name	(K) Signature	(L) Date	(M) MSIN	Reason	Disp.
1	1	Cog. Eng. J. R. Bellomy		1-16-95	S6-12						
1	1	Cog. Mgr. J. P. Harris		1-16-95	S6-12						
1	1	QA J. J. Huston		1-16-95	S6-12						
1	1	Safety G. E. McPherson		1-16-95	S6-12						
1	1	Struct. Eng. T. C. Mackey		2/9/95	S2-03						

18. J. R. Bellomy Signature of EDT Originator	19. J. P. Harris Authorized Representative for Receiving Organization	20. J. P. Harris Cognizant Manager	21. DOE APPROVAL (if required) Ctrl. No. ☐ Approved ☐ Approved w/comments ☐ Disapproved w/comments
---	---	--	---

RELEASE AUTHORIZATION

Document Number: WHC-SD-W320-TRP-001, REV 0

Document Title: Project W320 Heel Jet Secondary Catch Mechanism
Lateral Load Test - Test Report

Release Date: 2/9/95

**This document was reviewed following the
procedures described in WHC-CM-3-4 and is:**

APPROVED FOR PUBLIC RELEASE

WHC Information Release Administration Specialist:

Kara M. Broz

February 9, 1995

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

This report has been reproduced from the best available copy. Available in paper copy and microfiche. Printed in the United States of America. Available to the U.S. Department of Energy and its contractors from:

U.S. Department of Energy
Office of Scientific and Technical Information (OSTI)
P.O. Box 62
Oak Ridge, TN 37831
Telephone: (615) 576-8401

Available to the public from:

U.S. Department of Commerce
National Technical Information Service (NTIS)
5285 Port Royal Road
Springfield, VA 22161
Telephone: (703) 487-4650

SUPPORTING DOCUMENT

1. Total Pages

18

2. Title

Project W320 Heel Jet Secondary Catch Mechanism
Lateral Load Test - Test Report

3. Number

WHC-SD-W320-TRP-001

4. Rev No.

0

5. Key Words

Project W-320, Heel Jet, Secondary Catch
Mechanism, Test Report

6. Author

Name: J. R. Bellomy

Signature

Organization/Charge Code 7F820/D2M49

7. Abstract

This test report summarizes testing activities and documents the results of the lateral load test performed on the Heel Jet Secondary Catch Mechanism.

8. RELEASE STAMP

OFFICIAL RELEASE 58
BY WHC
DATE FEB 10 1995

Sta. #3

WHC-SD-W320-TRP-001
REVISION 0

PROJECT W-320
HEEL JET SECONDARY CATCH MECHANISM
LATERAL LOAD TEST
TEST REPORT

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED *ww*

MASTER

J. R. Bellomy
December 1994

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

CONTENTS

1.0 INTRODUCTION	1
2.0 DESCRIPTION OF TEST	1
3.0 TEST METHOD AND TEST EQUIPMENT	1
4.0 TEST RESULTS	2
5.0 CONCLUSIONS AND RECOMMENDATIONS	2
6.0 DISPOSITION OF TEST ITEMS	2
7.0 REFERENCES	3

APPENDICES

- A ICF KH Interoffice Memorandum, R. T. Hallum to C. D. Jones, "Heel Jet Lifting Bail," dated January 20, 1994.
- B Completed Test Procedure

1.0 INTRODUCTION

The Heel Jet located in tank 241-C-106, Pit B is planned to be removed as part of equipment removal activities associated with Project W-320, Tank 241-C-106 Waste Retrieval. A lifting fixture has been designed, fabricated, and tested and will be used as the primary means to connect the flexible receiver lifting hook to the heel jet lifting bail during removal.

During design review activities, ICF KH raised a concern regarding the integrity of the welds that attach the lifting bail to the heel jet flange (Appendix A). The welds on the lifting bail are in the direct load path during lifting of the heel jet and are not accessible for testing or evaluation due to the high radiation levels located within the heel pit.

To resolve the weld concern, a safety catch or secondary catch mechanism (SCM) has been designed and fabricated. The SCM consists of two modified purex connector heads (one 2-inch connector and one 3-inch connector) which are designed to be attached to the nozzles on the heel jet flange and rigged to the flexible receiver lifting hook. This will provide for an alternate load path from the heel jet to the lifting hook, should the welds fail on the existing lifting bail during lifting of the heel jet.

As part of fabrication, the SCM's were load tested by applying 125 percent of the design load in the vertical direction (lifting bail and connector head in line with the load path). However, because the SCM lifting bails will be at an angle when rigged to the flexible receiver lifting hook, a supplemental load test applying a lateral load to the SCM was determined necessary to qualify the design.

Project W320 Heel Jet Secondary Catch Mechanism Lateral Load Test (Bellomy 1994) was prepared and issued to provide instructions for the SCM lateral load test. This test report summarizes the results of that test. The overall design analysis for the SCM's is included in WHC-SD-W320-DA-007, *Structural Analysis for the Heel Jet Secondary Catch Mechanism* (Mackey 1995).

2.0 DESCRIPTION OF TEST

The SCM lateral load test was performed on September 9, 1994, at the Cold Test Facility following the procedure included in WHC-SD-W320-TC-002 (Bellomy 1994). ICF KH construction forces performed the test under the direction of Westinghouse Hanford Company (WHC) Projects. The test was observed by both WHC Engineering Analysis and WHC Quality Assurance. There were no deviations from the approved procedure.

3.0 TEST METHOD AND TEST EQUIPMENT

Testing was performed at the east end of the Cold Test Facility, using the pit mockup framework designed for training personnel in the remote installation of jumper assemblies. The framework is a welded steel frame fabricated primarily from W-beams. Nozzles of varying diameters are welded to the W-beams at several locations and in various positions to simulate nozzle positions typical of the actual pump pits.

WHC-SD-W320-TRP-001
REVISION 0

The 2-inch SCM was placed on a horizontal 2-inch nozzle and rotated so that the lifting bail, when in the 90-degree position, was in line with two of the three SCM fingers. The 2-inch SCM was then torqued in position to 215 foot pounds using the calibrated torque wrench. Following torquing, a calibrated dynamometer with a range of 0 - 2,000 pounds was connected by means of an 8½-ton shackle to the lifting bail on the SCM. To complete the rigging, a nylon sling was looped around a W-beam on the frame and connected to the chain hoist and the dynamometer. The slack was then taken up in the rigging using the chain hoist and the lifting bail was verified to be in the 90 degree position as required by the test procedure.

The SCM was loaded by increasing the tension on the rigging with the chain hoist. The ratchet action of the chain hoist did not allow for gradual increase in tension and resulted in applying a considerably higher load on the SCM than the 350 pounds required by the test procedure. The load momentarily reached 600 pounds, however, the load rapidly dropped off due to the elasticity of the nylon sling and eventually stabilized at 500 pounds.

Once the application of minimum load had been verified, the tension on the SCM was released. The rigging was then disassembled, and the SCM removed from the nozzle for inspection.

All equipment used in testing was as specified by the test procedure. Special test instrument identification numbers, ranges, and calibration due dates were verified and recorded in the space provided in the test procedure.

4.0 TEST RESULTS

After the load test, the SCM and the nozzle were examined visually for signs of damage. No signs of damage of any kind were observed or noted on either component.

The completed test procedure is included in this test report as Appendix B.

5.0 CONCLUSIONS AND RECOMMENDATIONS

The SCM lateral load test was successful and validates considerations made in design. The test demonstrates that the SCM's are capable of performing as designed when subjected to lateral loading. No further testing of the SCM is considered necessary or recommended.

6.0 DISPOSITION OF TEST ITEMS

All testing was completed in accordance with the approved test procedure. The 2- and 3-inch SCMs are fully tested and will be stored until needed to support removal of the 241-C-106 heel jet.

7.0 REFERENCES

- Bellomy, J. R., 1994, *Project W320 Heel Jet Secondary Catch Mechanism Lateral Load Test*, WHC-SD-W320-TC-002, Revision 0, Westinghouse Hanford Company, Richland, Washington
- Mackey, T. C., 1995, *Structural Analysis for the Heel Ject Secondary Catch Mechanism*, WHC-SD-W320-DA-007, Revision 0, Westinghouse Hanford Company, Richland, Washington

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

WHC-SD-W320-TRP-001
REVISION 0

APPENDIX A:

ICF KH Interoffice Memorandum,
R. T. Hallum to C. D. Jones,
"Heel Jet Lifting Bail,"
dated January 20, 1994.

TO C. D. Jones

DATE January 20, 1994

FROM R. T. Hallum *RTH*

COPIES TO R. C. Campbell
R. W. Davidson *ES-21*
M. B. LaSota
D. J. MacIsaac
M. W. Manderbach

JOB W-320
NO.

SUBJECT HEEL JET LIFTING BAIL

Reference: Calculation W320-25-014, Heel Jet Lifting Point Strength Analysis, R. C. Campbell, Dated 12-22-93.

Mike LaSota asked me to look at a lifting bail that is being analyzed for load capacity by the above calculation. The concern is over the material used to fabricate the bail (see drawing H-2-41297). The lifting bail was fabricated from ASTM A 108 grade 1115 bar. Grade 1115 is a free machining grade designed for ease of machinability rather than weldability. It is generally not recommended to be welded. Free machining steels are prone to hot cracking and porosity when welded. Additionally the mechanical properties of the base materials will experience a loss in toughness, strength, and ductility.

Information on the materials used to fabricate the lifting bail are limited. ASTM standards on the bar, the flange, and the weld rod were available only in editions from the early 1960s. These welds were probably made in the early 1950s. The welding standard referenced on the drawing required qualified welding procedures and welders. I am not sure if the welding records are available.

I would suggest an alternate method be devised to lift the heel jets out of the tanks until additional information, such as welding procedure qualification records, can be located. These records might provide information on the mechanical tests conducted on the welded A 108 grade 1115 steel bar. There is insufficient information to determine if the weld joints could produce mechanical properties equal to or greater than the base materials properties used in the above calculation or listed in the ASTMs.

JAN 31 1994
KEH B-PLANT PROJ.

WHC-SD-W320-TRP-001
REVISION 0

WHC-SD-W320-TRP-001
REVISION 0

APPENDIX B:

Completed Test Procedure

ORIGINAL

001 4 1994

Sta. #3 58

ENGINEERING DATA TRANSMITTAL

Page 1 of 1

1. EDT 606574

2. To: (Receiving Organization) Retrieval Engineering	3. From: (Originating Organization) Retrieval Engineering	4. Related EDT No.: N/A
5. Proj./Prog./Dept./Div.: W320 / Org. 7F550	6. Cog. Engr.: J. R. Bellomy	7. Purchase Order No.: N/A
8. Originator Remarks: Original Issue Supporting Document for Approval		9. Equip./Component No.: N/A
		10. System/Bldg./Facility: 241-AY-102, 241-C-106
11. Receiver Remarks:.		12. Major Assm. Dwg. No.: N/A
		13. Permit/Permit Application No.: N/A
		14. Required Response Date: ASAP

15. DATA TRANSMITTED					(F)	(G)	(H)	(I)
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	Impact Level	Reason for Trans- mittal	Orgi- nator Dispo- sition	Receiv- er Dispo- sition
1	WHC-SD-W320-TC-002		0	PROJECT W320 HEEL JET SECONDARY CATCH MECHANISM LATERAL LOAD TEST	SQ	1		

16. KEY											
Impact Level (F)		Reason for Transmittal (G)				Disposition (H) & (I)					
1, 2, 3, or 4 (see MRP 5.43)		1. Approval 2. Release 3. Information 4. Review 5. Post-Review 6. Dist. (Receipt Acknow. Required)				1. Approved 2. Approved w/comment 3. Disapproved w/comment 4. Reviewed no/comment 5. Reviewed w/comment 6. Receipt acknowledged					
(G)	(H)	17. SIGNATURE/DISTRIBUTION (See Impact Level for required signatures)						(G)	(H)		
Reason	Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN	(J) Name	(K) Signature	(L) Date	(M) MSIN	Reason	Disp.
1	1	Cog. Eng. J. R. Bellomy	<i>[Signature]</i>	9-29-94	S6-12						
1	1	Cog. Mgr. J. J. Harrison	<i>[Signature]</i>	10-3-94	S6-12						
1	1	QA J. J. Huston	<i>[Signature]</i>	7-21-94							
1	1	Safety G. E. McPherson	<i>[Signature]</i>	T4-10		10-3-94					
1	1	Struct. Eng T. C. Mackey	<i>[Signature]</i>	S2-03		10/3/94					

18. <i>[Signature]</i> J. R. Bellomy Signature of EDT Originator	19. _____ Authorized Representative for Receiving Organization	20. <i>[Signature]</i> J. P. Harris Cognizant/Project Engineer's Manager	21. DOE APPROVAL (if required) Ltr. No. ☐ Approved ☐ Approved w/comments ☐ Disapproved w/comments
--	---	--	--

ORIGINAL

RELEASE AUTHORIZATION

Document Number: WHC-SD-W320-TC-002, REV 0

Document Title: Project W-320 Heel Jet Secondary Catch Mechanism
Lateral Load Test

Release Date: October 4, 1994

* * * * *

This document was reviewed following the
procedures described in WHC-CM-3-4 and is:

APPROVED FOR PUBLIC RELEASE

* * * * *

WHC Information Release Administration Specialist:

Kara Broz

(Signature)

October 4, 1994

(Date)

ORIGINAL

REVISION 0

SUPPORTING DOCUMENT		1. Total Pages 8
2. Title Project W-320 Heel Jet Secondary Catch Mechanism Lateral Load Test	3. Number WHC-SD-W320-TC-002	4. Rev No. 0
5. Key Words Project W-320, Heel Jet, Secondary Catch Mechanism, Lateral Load Test APPROVED FOR PUBLIC RELEASE <i>KMB 10/4/94</i>	6. Author Name: J. R. Bellomy <i>J. R. Bellomy</i> Signature Organization/Charge Code 7F830/D2M49	
7. Abstract This test procedure applies a lateral load to the Heel Jet Secondary Catch Mechanism to very assumptions made in design analysis.		
8. PURPOSE AND USE OF DOCUMENT - This document was prepared for use within the U.S. Department of Energy and its contractors. It is to be used only to perform, direct, or integrate work under U.S. Department of Energy contracts. This document is not approved for public release until reviewed. PATENT STATUS - This document copy since it is transmitted in advance of patent clearance, is made available in confidence solely for use in performance of work under contracts with the U.S. Department of Energy. This document is not to be published nor its contents otherwise disseminated or used for purposes other than specified above before patent approval for such release or use has been secured, upon request, from the Patent Counsel, U.S. Department of Energy Field Office, Richland, WA. DISCLAIMER - This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or any third party's use or the results of such use of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.		10. RELEASE STAMP <div style="border: 1px solid black; padding: 5px; text-align: center;">OFFICIAL RELEASE 58 BY WHC DATE OCT 4 1994 <i>Sta. #3</i></div>
9. Impact Level SQ		

WHD-SD-W320-TRP-001
REVISION 0

ORIGINAL

WHC-SD-W320-TC-002
REVISION 0

PROJECT W-320
HEEL JET SECONDARY CATCH MECHANISM
LATERAL LOAD TEST

J. R. Bellomy
September 1994

B-4

ORIGINAL

WHC-SD-W320-TC-002
REVISION 0

PROJECT W-320
HEEL JET SECONDARY CATCH MECHANISM
LATERAL LOAD TEST

1.0 TEST IDENTIFICATION

This test procedure establishes the requirements for performing a lateral load test of the Heel Jet Secondary Catch Mechanism (SCM). Successful performance of this test will demonstrate that the SCM is capable of performing as designed when subjected to a force applied normal to the longitudinal axis of the mechanism.

This test procedure is prepared following the recommended format and content guidelines for test procedures as prescribed in WHC-IP-1026, *Engineering Practice Guidelines*, Appendix K, *Test Plans, Specifications, Procedures and Reports*.

2.0 GENERAL TEST DESCRIPTION

2.1 Test Objectives

The objective of this test is to verify that the SCM's are capable of performing as designed and will not fail when subjected to angular or lateral loading. Successful performance of the 2-inch SCM test will validate assumptions made in design analysis for both the 2-inch and the 3-inch SCM's.

2.2 Test Method

The load test will be performed by connecting the 2-inch SCM to a fixed 2-inch horizontal nozzle and torquing it in position to 215 foot pounds. The 2-inch SCM will be oriented on a horizontal nozzle such that a minimum force of 325 pounds can be applied to the SCM while the lifting bail is in the approximate 90 degree position (normal to the longitudinal axis of the mechanism). Following application of the load, the 2-inch SCM will be removed. The 2-inch SCM and the fixed nozzle will then be visually inspected to ensure that structural integrity has been maintained.

3.0 TEST CONDITION LIMITS

3.1 Environmental Conditions

There are no environmental conditions (excepting unforeseen site emergencies) which have potential to impact the load test performance.

ORIGINAL

WHC-SD-W320-TC-002
Revision 0

3.2 Operational Conditions and Pre-Test Requirements

The following operational conditions and pre-test requirements shall exist prior to test performance:

- All fabrication inspections and tests shall have been completed on the 2-inch SCM as required by the fabrication details.
- Load testing of the 2-inch SCM as required by the DOE-RL Hanford Site Hoisting and Rigging Manual shall have been successfully completed.

4.0 TEST INSTRUMENTS AND CALIBRATION

A calibrated torque wrench and a dynamometer are required to support test performance. The torque wrench and dynamometer identification number, range, and calibration due date shall be recorded in the space provided below.

Torque Wrench

Identification Number 0751 WB04080
Range 60 - 300 FT/LBS
Calibration Due Date 12/14/94

Dynamometer

Identification Number # 34 B15-28-06-834
Range 0 - 2000 LBS
Calibration Due Date 9/19/95

Verified by:

Quality Assurance DMW Date 11-1-94

ORIGINAL

WHC-SD-W320-TC-002
Revision 0

5.0 FACILITIES, EQUIPMENT, AND MATERIALS

5.1 Test Facility

Testing is planned to be performed at the Cold Test Facility. If the Cold Test Facility is not available, testing may be performed at any location determined suitable by the Test Director.

5.2 Equipment and Materials

The following equipment and materials shall be available to support testing:

- 2-inch Secondary Catch Mechanism (H-2-83746)
- Fixed horizontal 2-inch nozzle
- Calibrated torque wrench
- Digital or analog dynamometer (0 to 5,000 pound range maximum)
- Cable or chain come-a-long (2-ton minimum rating)
- 8 1/2 ton shackle
- Rigging hardware

6.0 SAFETY

The following represents mandatory safety requirements to be followed at all times during testing:

- 6.1 WHC and/or KEH safety practices and standards of conduct shall be adhered to at all times.
- 6.2 Hard hats and safety glasses shall be worn by all personnel during equipment assembly operations and during test performance.
- 6.3 Equipment which is damaged or excessively worn shall not be used.

ORIGINAL

WHC-SD-W320-TC-002
Revision 0

7.0 MAINTENANCE AND FAILURES

7.1 Maintenance

In the event any test equipment is not functioning or performing properly, the test shall be suspended. Testing may be resumed only after the defective component is replaced or required adjustments/maintenance has been performed.

7.2 Failures

Any observable evidence of failure of any component within the load path shall immediately be brought to the attention of the Test Director. The Test Director shall evaluate the condition and determine necessary corrective actions. If an unsafe condition is determined to exist, testing shall be discontinued and the load released in a safe manner as soon as possible. Testing may be resumed only after any required corrective actions have been performed.

8.0 TEST DATA

Test data shall be recorded in the space provided in Section 11, Test Procedure. Copies of all supplemental inspection sheets generated as a result of testing shall be attached to the test procedure.

9.0 PERSONAL REQUIREMENTS

Special training requirements for test personnel shall be as noted in the following. There are no special training requirements for other test support personnel.

- 9.1 Test Director - The Westinghouse Hanford (WHC) W-320 Project Cognizant Engineer or his designee shall act as the Test Director. The Test Director shall have overall authority for test performance and shall be responsible for ensuring that testing is performed in accordance with the requirements of this procedure.
- 9.2 Quality Assurance Representative - The WHC W-320 Project Quality Assurance Engineer or his designee shall be responsible for performing all quality assurance verifications required by this test procedure.

10.0 TEST WITNESSES

The WHC Quality Assurance Representative shall witness the test performance. The designated Quality Assurance representative shall be notified 24 hours prior to test performance.

ORIGINAL

WHC-SD-W320-TC-002
Revision 0

11.0 TEST PERFORMANCE

Load test prerequisites and the procedure for testing the 2-inch SCM are included in this section. Testing shall be performed specifically as sequenced in this section.

11.1 Test Prerequisites

- 11.1.1 Position the SCM on the fixed 2-inch horizontal nozzle. Orient the SCM such that when lifting bail is in the approximate 90 degree position it is in line with the load path and two of the three SCM connector fingers.
- 11.1.2 Torque the SCM to the fixed 2-inch horizontal nozzle to 215 foot pounds.
- 11.1.3 Install the 8 1/2 ton shackle on the SCM lifting bail.
- 11.1.4 Connect the dynamometer and the come-a-long to the 8 1/2 ton shackle on the SCM lifting bail and to a weight exceeding 350 pounds or a point on a fixed structure using the rigging hardware.

11.2 Load Test Performance

- 11.2.1 Verify that all prerequisites have been completed and rigging is properly assembled.

Test Director JRBellon Date 11-1-94
- 11.2.2 Using the come-a-long increase tension on the SCM until the dynamometer measures a minimum of 325 pounds.
- 11.2.3 Record and verify the lateral load applied to the SCM as measured on the dynamometer.

Force Applied: 500 #

Test Director JRBellon Date 11-1-94
Quality Assurance DWickham Date 11-1-94
- 11.2.4 Using the come-a-long, release the tension applied to the SCM.
- 11.2.5 Break down the rigging and remove the SCM from the horizontal nozzle.

ORIGINAL

WHC-SD-W320-TC-002
Revision 0

- 11.2.6 Inspect the SCM and the horizontal nozzle and verify by signing below that structural integrity has been maintained and no visual signs of damage on either component is apparent.

Test Director *JRB* Date 11-1-94
Quality Assurance *OW* Date 11-1-94

12.0 DISPOSITION OF TEST ITEMS

At the conclusion of testing, all test items shall be relocated and/or stored as specified by the Test Director or the KEH Construction Manager.

13.0 DATA SHEETS

The Test Director shall review the test procedure (Section 11.0) and ensure all verifications have been obtained where required. Copies of Surveillance Reports generated as part of test performance shall be obtained and attached to the test procedure.