Engineering Technology Division

TRANSPHASE COOL STORAGE TEST REPORT

Therese K. Stovall

Date Published: December 1993

Prepared for the
Electric Power Research Institute
under Interagency Agreement No. DOE ERD-91-1022

Prepared by the
OAK RIDGE NATIONAL LABORATORY
Oak Ridge, Tennessee 37831-6285
managed by
MARTIN MARIETTA ENERGY SYSTEMS, INC.
for the
U.S. DEPARTMENT OF ENERGY
under contract DE-AC05-84OR21400

MASTER

2P

CONTENTS

	<u>Page</u>
LIST OF FIGURES	v
LIST OF TABLES	vii
ABBREVIATIONS AND SYMBOLS	ix
ACKNOWLEDGMENTS	xi
ABSTRACT	1
1. INTRODUCTION	1
2. SYSTEM DESCRIPTION	4
2.1 TRANSPHASE STORAGE SYSTEM	4
2.2 TEST FACILITY	5
3. SYSTEM TESTS	8
4. ANALYSIS METHODOLOGY	9
4.1 DATA PROCESSING	9
4.2 REFRIGERATION EFFECT	10
4.3 DISCHARGE ENERGY AVAILABLE	11
5. RESULTS.	13
5.1 GENERAL OPERATION	13
5.2 CHARGING PERFORMANCE	19
5.3 DISCHARGE PERFORMANCE	25
5.4 STANDBY HEAT GAINS	34
6. CONCLUSIONS AND RECOMMENDATIONS	37
REFERENCES	38
APPENDIX A: ISTF INSTRUMENTATION	39

LIST OF FIGURES

Figure		Page
1	ISTF schematic for Transphase storage system	5
2	Transphase storage tank heat exchanger pressure drop with all nine circuits open for 25% glycol brine	13
3	Caustic concentration in the Transphase storage tank	15
4	NaOH/H ₂ O phase diagram	17
5	Caustic temperature measured 21 in. below surface during freeze tests	18
6	Two charge tests starting from fully-melted state	22
7	Temperature profiles for tests 0508 and 0530 differ based on storage tank's initial conditions	23
8	Charge test 0606 began with some frozen eutectic in the tank and charged at a rate of ~19 ton	24
9	Charging rate varies only slightly during course of nine freeze tests	25
10	Brine inlet and average temperatures for tests with charging rates from 21 to 23 ton	26
11	Brine temperature at storage tank outlet during melt tests	29
12	NaOH temperature measured ~21 in. below surface during melt tests	30
13	Brine flow rates for two different control strategies during melt tests	31
14	Storage tank outlet temperature for two different control strategies during melt tests	32
15	Variable discharge rate during melt test 0625	33
16	Storage tank outlet temperatures for controlled tank inlet temperature of 60°F with constant discharge rates	34
17	Storage tank outlet temperatures for controlled tank inlet temperature of 60°F with constant discharge rates	35

LIST OF TABLES

Table		Page
1	ISTF monitoring points for the Transphase eutectic system	6
2	Transphase charge test conditions	19
3	Transphase charge test summary	20
4	Transphase discharge test summary	27

ABBREVIATIONS AND SYMBOLS

cap_h	discharge capacity measured at heater
cap_t	discharge capacity measured at storage tank
c_p	specific heat
DX	direct expansion
EPRI	Electric Power Research Institute
FE1	refrigerant mass flow to the expansion valves
FE3	brine flow to storage tank
FE4	brine flow to the heater
FE5	refrigerant volumetric flow to the condenser
FE6	water flow rate
gpm	gallons per minute
HE1	refrigerant enthalpy entering the condenser
HE2	refrigerant enthalpy leaving the condenser
HE10	enthalpy corresponding to the measured suction temperature and pressure of the superheated refrigerant leaving the chiller/evaporator
ISTF	Ice Storage Test Facility
JE1	compressor energy and power
JE3	brine pump energy and power
JE10	heater energy and power
NaOH	sodium hydroxide
OD	outer diameter
ORNL	Oak Ridge National Laboratory
PCM	Phase Change Material
PE1	compressor discharge pressure
PE2	condenser outlet refrigerant pressure
PE4	chiller inlet refrigerant pressure
PE5	chiller inlet refrigerant pressure
PE10	compressor suction pressure
psi	pound per square inch

$\dot{Q}_r$	heat rejected by the refrigerant
Re_b	refrigeration effect as determined by measured brine flow rate and temperature change at cool storage tank
Re_{bch}	refrigeration effect as determined by measured brine flow rate and temperature change at chiller/evaporator
RE_{fch}	refrigeration effect as determined by measured refrigerant flow rates and thermodynamic properties
SG	specific gravity
T	temperature
TE1	compressor discharge temperature
TE2	condenser discharge temperature
TE4	chiller inlet refrigerant temperature
TE5	chiller inlet refrigerant temperature
TE10	compressor suction temperature
TE11	brine temperature entering heater
TE12	brine temperature leaving heater
TE14	storage tank outlet brine temperature
TE15	brine temperature leaving the storage tank
TE16	brine temperature entering the storage tank
TE17	brine temperature leaving the chiller/evaporator
TE18	brine temperature entering the chiller/evaporator
TE19	water temperature entering the condenser
TE20	water temperature exiting the condenser
ton	12,000 Btu/h
T-h	ton-hour
ρ	density
τ	time

ACKNOWLEDGMENTS

This important research has been made possible by the support of the Electric Power Research Institute. I would like to thank the program manager, Ronald Wendland, for his critical support and enthusiasm. Transphase, Inc. provided the cool storage unit for testing. John Tomlinson of Oak Ridge National Laboratory designed the Ice Storage Test Facility, supervised its construction, and has provided valuable guidance during the testing process. Delmar Fraysier is the chief operator of the test facility and made important contributions to the test procedures.

TRANSPHASE COOL STORAGE TEST REPORT*

Therese K. Stovall

ABSTRACT

The Ice Storage Test Facility (ISTF) is designed to test commercial cool storage systems. Transphase, Inc. provided a prototype of a new storage tank design equipped with coils designed for use with a secondary fluid system and filled with a eutectic designed to freeze at 41°F. The Transphase cool storage system was tested over a wide range of operating conditions. Measured system performance during charging showed the ability to freeze the tank with relatively constant brine temperatures over most of the charging cycle. During discharge cycles, the storage tank outlet temperature was governed mainly by the brine flow rate and the tank's remaining charge. The discharge capacity was dependent upon both the selected discharge rate and maximum allowable tank outlet temperature. This prototype unit experienced several operational problems, not unexpected for the first full-size execution of a new design. Such prototype testing was one of EPRI's primary goals in founding the ISTF.

1. INTRODUCTION

Commercial air-conditioning loads are a large component of the afternoon peak loads served by electric utilities. Increased use of cool storage would shift this electrical load from peak to off-peak periods. This shift would permit utilities to defer construction of additional generating capacity and reduce customers' demand charges.

Although the number of cool storage installations in commercial buildings is growing, it represents only a small fraction of the potential market. One major barrier to the use of cool storage equipment has been the uncertainty associated with its performance. Uniform testing by an independent agency has not been available. The performance data available

*Units used throughout this report are common to and exclusive in the industry.

from manufacturers are varied in scope and detail from one type of device to another and across manufacturers as well. Often system performance values are given for only one operating point, making it difficult to predict performance under other operating conditions.

The Electric Power Research Institute (EPRI) therefore sponsored the development of an Ice Storage Test Facility (ISTF) in 1985 to permit uniform testing of commercial-size cool storage equipment of many different types. This testing serves two purposes: (1) to provide uniform performance test results and (2) to promote system improvements based on experimental data. Uniform test results will be useful to utilities in promoting cool storage installation and use and in requesting rate incentives from public utility commissions and to building designers in specifying appropriate equipment for their applications. The experimental data will also be useful to equipment designers because it will describe component behavior as well as overall system performance. The capacity of the ISTF was sized at 250 T-h, large enough to test most commercially available units. Real-time data acquisition and precise computer controls were included.

The ISTF can be used to test dynamic, liquid recirculation, secondary fluid, and direct expansion (DX) ice makers. The simplest ice maker is a DX machine. In a DX ice maker, the refrigerant is sent as a cold liquid into coils submerged in a tank of water. As the refrigerant passes through these coils it absorbs heat from the water and evaporates. As the refrigerant leaves the coils it is completely gaseous and usually slightly superheated. The water in the tank is thereby chilled until it becomes frozen. When the stored cooling is needed, the ice is melted by circulating warm water from the heat load through the ice and returning the chilled water to the heat load. This arrangement is called an exterior melt because the ice is melted from the surface opposite from where it is formed.

In a secondary fluid system, the cold liquid refrigerant is sent to a heat exchanger outside the tank of water. In this heat exchanger, a secondary fluid, typically a glycol mixture, is chilled. This secondary fluid is sent to the tank of water where it absorbs heat from the water, again freezing the water in the tank. The secondary fluid can also be used to transfer the stored cooling to the heat load. This arrangement is called an internal melt.

The stored cooling energy can also be transferred to the heat load by using an external melt as described for the DX system.

A liquid recirculation system is similar to the DX system because the cold refrigerant is sent to coils submerged in the tank of water. However, in the liquid recirculation system, the amount of refrigerant circulated through the coils is typically two to three times greater than in a DX system so that only a portion of the refrigerant is evaporated and the coils remain wetted throughout their length for improved heat transfer. This additional refrigerant circulation is accomplished through the use of gravity feed or a refrigerant pump. The stored cooling energy is transferred to the heat load using an external melt arrangement.

A dynamic ice maker freezes ice using either a DX or a liquid overfeed arrangement. However, in a dynamic system, the ice is harvested on a periodic basis by a defrosting cycle. This harvesting cycle reduces the ice thickness on the heat transfer surface of the chiller. After the ice is harvested, it is stored in a slush or slurry of ice and water. The water is circulated to provide the stored cooling to the heat load.

This report describes the test results for a cool storage tank furnished by Transphase, Inc. The Transphase storage tank holds a eutectic that freezes at a warmer temperature than water and is both charged and discharged using a secondary fluid or brine. The Transphase storage system and the test facility are described in Sect. 2. Section 3 describes the tests that were performed to characterize the storage system, and Sect. 4 describes the analysis methods used to evaluate the performance data. The results and recommendations are summarized in Sects. 5 and 6.

2. SYSTEM DESCRIPTION

2.1 TRANSPHASE STORAGE SYSTEM

Transphase has marketed cool storage systems based on various eutectics, providing a range of storage temperatures. In the past, their systems have circulated brine around stationary containers. The system tested at the ISTF was a significant departure from these previous designs. This system circulated brine through heat exchanger tubing within a large tank containing a eutectic mixture of NaOH and water with a freezing temperature of 41°F. The unit tested was the largest prototype of this new design with a capacity of 250 T-h. As described earlier, testing such new designs was one of EPRI's primary goals in founding the ISTF.

The cool storage tank tested was a horizontal cylinder with an external header arrangement along the length of the top of the tank. The eutectic within the tank is chilled by the flow of brine through 1/2-in.-OD plastic tubing, arranged in nine circular bundles within the tank. These tubes are arranged in concentric coils and almost completely submerged in the eutectic fluid. The brine used for these tests was a mixture of ethylene glycol and water with a freezing point of 10°F ($\pm 2^\circ\text{F}$). The Transphase storage tank is discharged by circulating the brine through the tank and then through the desired heat load, simulated by a heater in the test facility. During an initial leak test, the tank was filled with 4,660 gal. of water. This water was drained and the tank was filled with 4,582 gal. of the eutectic mixture. This filled the tank to a level approximately three in. below the tops of the coils. The volume of brine in the storage system coils was estimated to be 580 gal., based on the amount of brine pumped into the tank and the nearby piping. However, as is discussed later in this report, this amount may be in error due to the difficulty in removing air from the Transphase coils (causing the volume to be under-estimated) and due to brine leakage which would cause an over-estimate of the coil volume.

2.2 TEST FACILITY

The test facility was designed to test a wide variety of storage systems. It includes all refrigeration system components necessary to charge brine systems. Figure 1 shows the test facility configuration used to test the Transphase storage tank equipped with the brine coils. The test facility is well-equipped with monitoring devices to measure temperature, pressure, flow, and energy use. The monitoring points shown in Fig. 1 are listed in Table 1. The test loop instrumentation is described more fully in Appendix A and Ref. 1.

A variable speed pump was used to circulate brine during both the charge and discharge cycles, as is shown in Fig. 1. The evaporator/chiller (see Fig. 1) connects the test facility's refrigeration system to the brine loop that charges the cool storage tank. In the evaporator/chiller, a refrigerant, HCFC-22, is vaporized, absorbing heat from the brine. To accommodate the desired wide range of testing conditions, a chiller with two independent

Fig. 1. ISTF schematic for Transphase storage system.

Table 1. ISTF monitoring points
for the Transphase eutectic system

Point label	Measured quantity
FE1	Chiller inlet flow, refrigerant, mass
FE3	Chiller inlet flow, brine
FE4	Brine pump discharge flow
FE5	Compressor outlet flow, volume
FE6	Condenser inlet water flow
JE1	Compressor energy and power
JE3	Brine pump energy and power
JE10	Heater energy and power
PE1	Compressor discharge pressure
PE2	Condenser outlet refrigerant pressure
PE4	Chiller inlet refrigerant pressure
PE5	Chiller inlet refrigerant pressure
PE10	Compressor suction pressure
TE1	Compressor discharge temperature
TE2	Condenser discharge temperature
TE4	Chiller inlet refrigerant temperature
TE5	Chiller inlet refrigerant temperature
TE10	Compressor suction temperature
TE11	Heater inlet water temperature
TE12	Heater outlet water temperature
TE14	Storage tank outlet brine temperature
TE15	Storage tank outlet brine temperature
TE16	Storage tank inlet brine temperature
TE17	Chiller outlet brine temperature
TE18	Chiller inlet brine temperature
TE19	Condenser inlet water temperature
TE20	Condenser outlet water temperature

and equal-size refrigerant coils was selected. The control system is designed to select one or both chiller coils based on the compressor loading. The thermal expansion valves feeding refrigerant to these coils open and close in response to the measured superheat at the coil exit. Two parallel compressors with part-load capabilities are used to vary the nominal chiller capacity from 15 to 95 tons. The flow of water to the condenser controls the condensing temperature between 80 and 100°F. The brine pump speed was varied to control the brine flow rate at the selected value during the charge cycle. The bypass line

was always closed during the charge tests. During discharge cycles, the brine pump speed, heater power, and bypass valve positions are used to control test conditions.

3. SYSTEM TESTS

All units tested at the ISTF are examined for their operational characteristics. However, because the Transphase unit was a prototype unit, this aspect of the testing received additional attention. Performance tests were also planned, similar to those used for ice storage systems. These test plans are based on Ref. 1, modified as necessary to reflect the elevated melting temperature of the eutectic mixture.

The test plan was structured to test the storage tank's capabilities under a wide range of operating conditions. Transphase expected the tank to work well with brine flow rates between 50 and 200 gpm, with the most efficient flow rate being between 80 and 120 gpm. The charging tests were designed to determine how the storage system would respond to charging periods from 6 to 14 h and brine flow rates from 50 to 200 gpm.

The discharge tests emulated discharge periods ranging from 7 to 12 h with varying temperature and flow requirements at the heater. For most tests, the temperatures at the heater inlet and outlet were maintained for a constant heater power by varying the brine flow to the storage tank. The tank was considered to be fully discharged when it was no longer possible to maintain the desired heater outlet temperature. Some latent storage may remain in the tank at that time but is unavailable to meet the load. A few tests were made at a constant brine flow rate through the heater and storage tank; i.e., the brine temperatures at the heater were not controlled. One test was also made with a constant heater outlet temperature, constant brine flow, and variable heater power.

Storage tank shell heat gains were not measured because this prototype was not insulated by the manufacturer. The main steel storage tank was surrounded with a plastic tank for leak containment purposes. However, this provided no substantial insulation, as was shown by the large amount of condensation on the tank skin whenever the tank was cooler than ambient.

4. ANALYSIS METHODOLOGY

The primary concern of the data analysis is to produce useful information and to present it in a meaningful fashion. Another concern is to distinguish between the performance of the cool storage system and the performance of the refrigeration system. While analysis of the refrigeration system performance can prove enlightening and is certainly useful to system designers, it must be distinguished from that of the manufacturer's storage system.

4.1 DATA PROCESSING

The data available for each operational test permit redundant calculations that increase our understanding and confidence in the test results. For example, the refrigeration effect is measured at the chiller on both the brine and refrigerant sides. The refrigeration effect to the storage tank is measured by the brine flow and temperature change. The energy available for discharge is measured by brine flow and temperatures at the heater and at the storage tank, as well as by the power going to the discharge heater. This duplication of measurements also enables us to fully separate the performance of the cool storage system from that of the refrigeration system.

The data are collected for each monitoring point every 30 s. This collection frequency is dictated by system control requirements rather than by the analysis requirements. The data are immediately summed (for flows or energy uses) or averaged (for temperatures, pressures, power uses, and flow rates) to represent the appropriate values on a 5-min basis.

Thermodynamic properties for HCFC-22 are calculated from a computerized format developed by G. T. Kartsounes and R. A. Erth and adapted for use at Oak Ridge National Laboratory (ORNL) by C. K. Rice and S. K. Fischer.² Brine properties, as a function of concentration and temperature, were provided by Union Carbide Corporation, and information for the temperature range of interest was extracted.³

4.2 REFRIGERATION EFFECT

The stored cooling effect at the storage tank is calculated from the measured brine flow rate and temperature gain as is shown in Eq. (1).

$$RE_b = FE3 \times c_p \times \rho \times (TE15 - TE16) , \quad (1)$$

where

RE_b = refrigeration effect produced by the brine,

$FE3$ = brine flow from the chiller,

c_p = brine specific heat,

ρ = brine density,

$TE15$ = brine temperature leaving the storage tank, and

$TE16$ = brine temperature entering the storage tank.

The brine specific heat and specific gravity are provided in the form of families of curves in Ref. 3. Interpolations from these curves for the temperature range from 20 to 60°F and a brine concentration of 25 wt % produced the following equations for specific gravity (relative to water at 60°F) and specific heat.

$$SG = (-0.000108) \times T + 1.0482 , \quad (2)$$

$$c_p = 0.000275 \times T + 0.922 . \quad (3)$$

where

SG = specific gravity,

T = average brine temperature (°F), and

c_p = specific heat [Btu/(lb-°F)].

The system capacity was also measured at the evaporator/chiller, on both the brine and refrigerant sides. These measurements provide another checkpoint to guard against instrument failure. The capacity measured at the chiller is expected to be slightly higher

than that at the storage tank due to shell heat gains at the tank and in the piping and also by the amount of energy added by the brine pumps. The brine-side measurements are similar to those used for the storage tank and are shown in Eq. (4). The refrigerant-side measurements are used in Eq. (5). Shell losses from the well-insulated chiller are assumed to be negligible.

$$RE_{bch} = FE3 \times c_p \times \rho \times (TE18 - TE17) , \quad (4)$$

where

RE_{bch} = refrigeration effect at the chiller, based on brine flow and temperature measurements,

$FE3$ = brine flow from the chiller,

c_p = brine specific heat,

ρ = brine density,

$TE17$ = brine temperature leaving the chiller, and

$TE18$ = brine temperature entering the chiller.

$$RE_{fch} = FE1 \times (HE10 - HE2) , \quad (5)$$

where

RE_{fch} = refrigeration effect at the chiller, based on refrigerant flow and property measurements,

$FE1$ = refrigerant flow to the chiller,

$HE10$ = enthalpy corresponding to the measured suction temperature and pressure of the superheated refrigerant leaving the chiller, and

$HE2$ = enthalpy corresponding to the saturated liquid refrigerant leaving the condenser.

4.3 DISCHARGE ENERGY AVAILABLE

The cool storage available to meet a cooling load was measured by the brine flow rates and temperature changes at the heater and at the storage tank [see Eqs. (6) and (7)].

$$cap_h = FE4 \times (TE12 - TE11) \times c_p \times \rho , \quad (6)$$

$$\text{cap}_i = \text{FE3} \times (\text{TE15} - \text{TE16}) \times c_p \times \rho , \quad (7)$$

where

cap_h = discharge capacity measured at the heater,

FE4 = brine flow to heater,

TE12 = brine temperature leaving heater,

TE11 = brine temperature entering heater,

c_p = specific heat of brine,

cap_i = discharge capacity measured at the storage tank,

FE3 = brine flow to storage tank,

TE15 = brine temperature leaving storage tank,

TE16 = brine temperature to storage tank, and

ρ = brine density.

The heater power was also measured but is considered to be less accurate than the other available measurements, as is discussed in Appendix A.

5. RESULTS

5.1 GENERAL OPERATION

The brine pressure drop across the Transphase coils was measured at flow rates from 50 to 105 gpm with all nine circuits fully open. The measured pressure drop ranged from 6.5 psi at 50 gpm to 18.5 psi at 105 gpm. These values were taken at a brine temperature of 80°F and a concentration of 25%. As the brine temperature decreased, the pressure drop increased, as is shown in Fig. 2. The constant-temperature relationship between pressure drop and flow rate shown here doesn't correspond to that expected for either laminar or turbulent flow. An examination of the Reynold's number shows that the brine flow through the heat exchanger is in the transition region between laminar and turbulent flow whenever the overall flow rate is between 50 and 190 gpm.

Fig. 2. Transphase storage tank heat exchanger pressure drop with all nine circuits open for 25% glycol brine.

Some operational difficulties were encountered with this prototype unit. The method of joining the heat exchanger tubing to the header apparatus resulted in a large number of leaks. Most of these leaks were very small and difficult to locate, but a few leaks were large enough to produce spurting jets of brine. Because of leaks, one to two circuits (out of nine) were closed off for most tests, effectively reducing the available heat exchanger surface area by ~10 to 20%. Although the circuit shut-off valves isolated the worst leaks and the brine loop was depressurized whenever the unit was shut down, leaks continued. These continuing leaks made it necessary to add brine at the start of every charge cycle. Over the four-month trial period, 66 gal of brine were added to make up for leakage. Some of the leaking brine ran off the tank exterior and some was caught with a series of tubes and beakers. However, most of the leaking brine fell down into the Transphase tank and floated on top of the eutectic mixture, where it was visible as a greenish coating. If this unit had been installed in an underground location, the leaking brine would eventually have caused the caustic material in the tank to overflow, as was observed at the test facility during the final tests. A redesign of the header connections and a rigorous quality control program to eliminate these leaks should be implemented.

The Transphase heat exchanger tubing is arranged in a large number of coils around a horizontal axis. This creates a large number of high points where air bubbles can become trapped and are impossible to vent. It becomes necessary to circulate the brine for extended periods of time to purge the system of air. It is particularly easy to trap air in the heat exchanger tubing in the process of initially filling the Transphase heat exchanger with brine. If a low volume brine transfer pump is used, the coils can become air-locked. A high volume pump is therefore required for this initial fill.

With mixtures there is the potential for phase separation of the components, especially when freezing or melting on surface heat exchangers. As a result, the temperatures throughout the tank will not be uniform at each time step. Because of this, there is the potential for chemical nonuniformities developing in the tank so there may be a gradual loss in storage capacity. This loss in capacity would probably not be noticed in short-term thermal tests but would be noticeable in actual installations as cycling proceeds. Therefore, the mixture was sampled at several points during the testing process to study this

effect. Laboratory analysis of the composition of these samples indicates that there may be a long term concern. Figure 3 shows the measured caustic concentration for a number of samples. The first sample was taken after the initial fill, before the caustic was ever frozen, and tested at 45.86% caustic. The caustic supplier tested the material at 46.66%. The supplier was diluting the caustic from a standard 50% strength in a large tank and the amount of mixing done before their sample was taken is unknown. Samples taken at a single point, 10 in. below the surface of the caustic in the tank, over a one month period (over four freeze and melt cycles) decreased from 45.66% to 45.23%. A stronger indication of a separation effect is found in a sample removed from the bottom of the tank five months after the initial fill. This bottom sample tested at 50.2 wt.% caustic, a significant increase in concentration.

The stratification and changes in concentration could be due to the partial separation of the two solid phases that are in equilibrium when the NaOH-H₂O drops below its eutectic

Fig. 3. Caustic concentration in the Transphase storage tank.

point of 41°F for the nominal 47% concentration. Figure 4, an NaOH/H₂O phase diagram taken from Ref. 4, shows that these solid phases consist of NaOH·3½H₂O and NaOH·2H₂O. If a portion of the denser crystals (NaOH·2H₂O) settle out during each freeze cycle, the NaOH concentration at the bottom of the tank will gradually increase. Such a stratification will eventually affect the freezing point of the mixture. A slight drop (~1°F) in the NaOH freezing temperature was seen in ISTF tests from May 22 to June 26 and is shown in Fig. 5. The temperatures shown in Fig. 5 were taken ~21 in. below the surface of the caustic, approximately 1/3 of the way from one end of the tank. This figure shows the NaOH temperature as it recovers from the initial sub-cooling and reaches a relatively stable plateau. Each of the tests shown in Fig. 5 began from the fully melted state. It is not known whether this change in freezing temperature is due to a change in the caustic concentration or to the small amount of brine spilled into the system.

The effect of the spilled glycol on this caustic stratification is unknown. Under proper operating conditions, there would be no glycol within the caustic mixture. However, a surface sample taken soon after the first leaks were noticed showed a glycol concentration of 1.6 wt.% (±0.5 wt. %) and a reduced caustic concentration of 40.96 wt.%. It's not clear to what extent the glycol permeated the caustic mixture. The glycol specific gravity was much lower than that of the caustic mixture, and the glycol would therefore be expected to float, considering the much higher viscosity of the caustic mixture and the absence of any physical mixing device. Indeed, the series of samples taken 10 in. below the surface showed only very small amounts when tested for glycol, registering from 0.2 wt.% (±0.2) to 0.3 wt.% (±0.3). Another factor to be considered is the presence of a nucleating agent within the tank. Although this agent is supposed to be physically restrained from mixing with the caustic, the initial sample taken near the top of the tank showed trace amounts of 26 ppm. A final sample taken from the bottom of the tank showed a much higher concentration of 100 ppm.

As currently designed, the Transphase system has a drain plug on the bottom of the cylindrical storage tank. Although draining the caustic would not be a part of normal operation, it could become necessary for heat exchanger repairs. This bottom drain was found to be unusable at the end of the ISTF tests and it was necessary to pump the caustic

Fig. 4. NaOH/H₂O phase diagram

Fig. 5. Caustic temperature measured 21 in. below surface during freeze tests.

out from the top of the tank. One caustic reference source indicates that caustic should always be removed from a small distance above the bottom of any storage tank to avoid a sludge made up of slowly accumulating settled solid impurities.⁵ For the bottom drain to be usable, it should be redesigned to include a short length of pipe extending into the storage tank. The drain could also be relocated to the end wall of the tank, again placed a short distance above the bottom of the tank.

The Transphase tank is not equipped with any kind of thermal storage inventory meter. This makes it difficult to assure a full tank of solid phase change material (PCM) is available at the start of the discharge cycle. This problem was most noticeable after a series of partial charge/discharge cycles. The only indication of charge available is the brine temperature during the charge cycle. As will be described later in this report, this temperature shows a marked drop as the tank approaches the fully charged state. However, we found that it is this temperature drop and not any particular brine temperature, that must

be used to judge whether the tank is fully charged. This is especially true under experimental conditions with variable charge rates and variable brine flow rates.

5.2 CHARGING PERFORMANCE

When designing a thermal storage system for a given application, the heat rejection temperature, storage capacity, and time available for charging are usually known.⁶ This establishes the average capacity needed during the charging cycle. The ability of a storage system to meet these requirements is a function of both the storage tank/coil design and of the balance of the refrigeration system, most importantly the compressor. A large number of tests were made to measure the Transphase charging performance. These tests are summarized in Tables 2 and 3.

Table 2. Transphase charge test conditions

Test ID	Initial condition	Compressor loading (hp/%)	Circuits in use	Condensing temperature (°F)	Brine flow rate (gpm)	Brine temperature change in ice tank ^a (°F)
0425	Melted	40/50	9	95	87	3.9
0508	Melted	40/75	9	90	71	8.0
0522	Melted	40/100	7	95	94	6.3
0528	Melted	40/100	9	95	49	10.6
0530	Some solid PCM	40/75	8	94	77	6.6
0606	Some solid PCM	40/100	7	91	91	5.2
0611	Melted	75/100	7	99	91	8.7
0618	Melted	75/100	8	80	99	9.7
0620	Melted	75/100 and 40/75	8	100	98	9.0
0626	Melted	75/75	8	94	100	7.3

^a Measurement accuracy of $\pm 0.2^\circ\text{F}$.

Table 2 shows initial test conditions including whether or not solid PCM was present at the start of the charge test and how many circuits were in use (as discussed in the previous section, some circuits were closed to reduce the amount of brine leakage into the storage tank). By comparing tests made with the same pump settings, the effect of closed circuits on total charging capacity can be estimated. The brine flow rate dropped from 87 to 77 gpm between tests 0425 and 0530 when the number of circuits changed from 9 to 8. This should cause a capacity derating of ~10%. Tests 0522, 0606, 0611, 0618, 0620, and 0626 were also made with comparable pump settings. This group of tests show that reducing the number of circuits further from 8 to 7 drops the brine flow rate, and therefore the capacity, by approximately another 8%. The brine temperature change in the storage tank ranged from a low of 4°F to a high of almost 11°F. With a calibrated RTD accuracy

Table 3. Transphase charge test summary

Test ID	Test duration (h)	Average charging rate ^a (ton)	Average chiller capacity - pump heat ^b (ton)	Total charge ^a (ton-h)	Brine temperature to tank	
					Average (°F)	Minimum (°F)
0425	25.8 ^c	13.6	13.8	355	37.0	32.8
0508	12.7 ^c	22.8	23.1	287	29.9	23.6
0522	10.4	23.5	23.6	246	32.0	28.7
0528	3.1	20.9	21.5	66	31.2	26.1
0530	18.8 ^c	20.7	21.2	392	32.5	24.8
0606	14.3	19.3	19.6	279	30.8	23.4
0611	8.7 ^c	32.0	32.4	280	28.7	19.8
0618	7.2	38.1	38.7	276	27.2	20.6
0620	8.4	35.5	35.9	301	28.1	18.8
0626	10.3 ^c	29.0	29.4	305	31.4	25.7

^a From brine flow rate and temperature change in storage tank.

^b From brine flow rate and temperature change in the chiller/evaporator minus the pump energy.

^c Long tests were interrupted and took place over two or more days.

of $\pm 0.2^{\circ}\text{F}$, the capacity calculations should show a high degree of accuracy. This is shown by comparing the average capacity measured at the storage tank to the average measured at the chiller (minus the pump energy) as was discussed in Sect. 4.2.1. As Table 3 shows, these values match within $\pm 2\%$ for every test except the 3-h long test 0528, which matched within 3%. Over all these charge tests, the agreement averages 99%. A comparison was also made between the refrigerant and brine sides of the chiller/evaporator. All the tests before 0611 showed agreement within $\pm 1\%$. Tests 0611 to 0626 showed differences between 3 to 10%. This is most likely attributable to some drift in a refrigerant monitor, either flow or temperature. These refrigerant values, especially flow rates, are much more difficult to measure than their brine counterparts. Also, if these later errors were due to a brine measurement error, it would have shown up when comparing the redundant temperature and flow measurement points throughout the loop.

The total charge shown on Table 3 is the product of the average charging rate and the test duration, therefore showing the total amount of cooling provided to the storage tank by the chilled brine flow. However, due to significant jacket losses, this does not represent the total amount of cool storage that might have been available for discharge if the tank had been insulated. The difference between the amount of cooling stored and the amount available during discharge is greatest for those tests made at very low charging rates over a period of several days. This is discussed further in Sect. 5.3.

Compressor capacity depends on suction and discharge pressures and temperatures. When charging an ice-on-coil storage tank, the suction temperature gradually drops as the water in the tank becomes colder and solid ice builds up on the coils. The lower suction temperature leads to a reduced refrigeration capacity. (The Transphase eutectic reduces this penalty by raising the freezing temperature of the storage medium.) The temperature profile of the fluid entering the tank throughout the charge cycle is therefore an important characteristic of the storage system. Figure 6 shows this temperature profile for two freeze tests, both of which started from a fully melted state. The brine inlet and internal NaOH temperatures (measured 21 in. below the eutectic surface) are plotted against the tank's cumulative charge based on the brine flow rate and temperature change. The second test shown, 0618, was run at a higher capacity of 38 tons and shows a corresponding lower

Fig. 6. Two charge tests starting from fully-melted state.

brine inlet temperature (the brine flow rate was nearly the same for these two tests). Both tests show the characteristic brine inlet temperature profile for a fully melted tank. The temperature drops nearly linearly until nucleation occurs after a period of subcooling, seen also in the internal tank temperature profile. The inlet temperature then recovers and begins to increase as the heat transfer surface area expands as solid PCM forms on the tubes. After the solid PCM thickness reaches a certain point, however, the additional heat transfer resistance causes the brine inlet temperature to again drop.

The difference between charging from a fully melted tank and a partially frozen tank can be seen most clearly in Fig. 7. This figure shows two tests run at very nearly the same capacity (20 to 23 tons) and brine flow rates (70 to 77 gpm). The first test, with test ID number 0508, began with a fully melted tank. Neglecting the discontinuities due to a test interruption, this profile is similar to in shape to those shown in Fig. 6. Test 0530 began with some solid PCM present in the storage tank, and shows a very different profile. The subcooling is very nearly eliminated for this case and both the brine inlet and internal

Fig. 7. Temperature profiles for tests 0508 and 0530 differ based on storage tank's initial conditions.

NaOH temperatures are very nearly constant throughout the test. The Transphase design includes a nucleating agent to reduce the subcooling. Indeed, another NaOH/H₂O phase diagram shows a subcooling curve for this concentration that drops to ~26°F, much lower than any internal tank temperatures measured during the tests.⁵

Capacity calculations were described in Sect. 4.2 and are based on an energy balance on the storage tank. At any given time, the capacity is the product of the brine mass flow rate and the brine temperature change in the storage tank. Figure 2 showed that the brine flow rate drops somewhat (for a constant pump setting) as the brine temperature drops. Figure 8 shows that the difference between the brine inlet and outlet also decreases slightly as the solid PCM builds up within the storage tank, even though the internal tank temperature remains constant. These factors combine to produce the capacity curves shown in Fig. 9. Overall, the capacity remains relatively steady throughout most of the charge cycle. This is most visible for those tests run at the higher rates, greater than 35 ton. Tests

Fig. 8. Charge test 0606 began with some frozen eutectic in the tank and charged at a rate of ~19 ton.

in the 25 ton range show the more traditional curvature, expected as solid PCM begins to form and grows ever thicker on the tubular heat exchanger surface. Those tests that began from the partially frozen state show less variation in the early stages of the tests compared to those that began in the fully melted state. All tests at rates greater than 20 ton show the expected decrease in capacity near the end of the test, as the tank becomes fully charged. However, one test was run at a very slow rate of about 15 ton. This test never showed any decrease in charging rate, even though the test extended over a 4-day period. Later calculations estimated that the jacket heat gains for the uninsulated tank were very large and that this test probably never reached the fully charged state.

The brine flow rate is also an important parameter in determining the brine inlet temperature. Figure 10 shows the variation in brine inlet temperature for tests with the approximate charging rate of 21-23 tons and brine flows that vary from 50 to 93 gpm. All of these tests began with a fully melted tank. The ISTF evaporator froze at the lowest flow

Fig. 9. Charging rate varies only slightly during course of nine freeze tests.

rate and that test had to be stopped before nucleation began in the storage tank. Figure 10 also shows the mean brine temperature in the storage tank, i.e. the average of the brine inlet and outlet temperatures. The difference between the brine inlet temperatures for the high and low flow tests is greater than the difference between the average brine temperatures. Theoretically, this average brine temperature should be strictly a function of capacity and the heat exchanger design, with the flow rate controlling the difference between the brine inlet and outlet temperatures.

5.3 DISCHARGE PERFORMANCE

The ISTF simulates a building load with a resistance heater. This portion of the test loop was designed to model a constant load while maintaining constant inlet and outlet temperatures to the load. This is accomplished by recirculating a portion of the brine from the heater outlet to the heater inlet, bypassing the storage tank, as is shown in Fig. 1.

Fig. 10. Brine inlet and average temperatures for tests with charging rates from 21 to 23 ton.

During the course of the discharge test, the brine temperature leaving the storage tank gradually rises and this recirculation steadily decreases until the brine exiting the storage tank is at the desired heater inlet temperature. After that time, the desired heater outlet temperature is maintained by increasing the brine flow through the heater/storage tank loop. The test is considered completed when it is no longer possible to increase the brine flow and the heater outlet temperature exceeds the desired value. Also, tests were made with a constant flow through the storage tank to investigate whether this would increase the available cool storage capacity. For these tests, the brine flow rate and heater power were held constant, there was no brine recirculation, and the brine temperatures were uncontrolled. Also, one test was made with a constant brine flow and a variable discharge rate, maintaining the heater outlet (storage tank inlet) temperature below a selected maximum value. All the discharge tests are summarized in Table 4.

Table 4. Transphase discharge test summary

Test ID	Test duration (h)	Number of open circuits	Control strategy ^a	Average discharge rate (ton)	Cumulative discharge energy (T-h)	Cumulative discharge energy ^b ≤ 50°F (T-h)	Average pump power (kW)	Average flow to storage tank (gpm)	Average temperature leaving storage tank (°F)	Average temperature into storage tank (°F)
0506	5.8	8	Constant flow	32.7	194 ^c	86 ^c	3.0	88	53.7	62.8
0523	5.2	7	60°F in	35.1	185	NA	1.8	59	44.8	60.1
0604	6.2	8	Constant flow	35.4	223	218	4.9	107	44.6	52.8
0610	7.0	7	60°F in	27.9	199 ^d	185 ^d	1.5	53	46.0	59.6
0614	6.7	9-8 ^e	Constant flow	34.2	231	228	4.0	100	44.4	52.9
0619	11.6	8	60°F in	21.9	254	219	1.0	44	46.8	60.0
0625	10.8	8	Variable power	27.0	292	229	4.3	102	48.6	55.2
0627	11.1	8	Constant flow	21.9	249	215	4.9	105	45.1	50.3

^a 'Constant flow' tests maintained a constant brine flow rate to the storage tank. '60°F in' tests used the heater bypass to maintain a constant temperature of 60°F entering the ice tank.

^b Discharge energy produced with a storage tank outlet temperature ≤ 50°F.

^c Five days elapsed between end of charge and start of discharge test. Initial storage capacity diminished by substantial tank wall heat gains over this period.

^d Two days elapsed between end of charge and start of discharge test.

^e One circuit was closed during the test.

As mentioned in Sect. 4.3, the discharge capacity was measured at both the heater and the storage tank. The measurement at the heater should be slightly less than the measurement at the storage tank because of heat added to the brine by the circulation pumps. Therefore, the total discharge energy measured at the storage tank was compared to the sum of the total measured at the heater plus the pump energy. These two values matched within 3% for all the tests, good agreement considering that the flow meters and temperature measurements are completely independent. All capacity data presented in this section are based on the temperature difference and brine flow rate at the storage tank.

The heat transfer resistance between the brine flowing through the storage tank and the frozen NaOH consists of three components: the convective heat transfer at the inner wall of the heat exchanger tubing, the conduction through the thickness of the tube wall, and the conduction through the melted NaOH surrounding the tube. The second term is constant and the largest of the three. The convective transfer at the inner wall of the tube varies with the brine flow rate. At the rates tested at the ISTF, from ~50 to 100 gpm, the flow is in the transition region between laminar and turbulent flow. For this reason, the convective heat transfer coefficient is not precisely defined, but will range from 5 to 30% of the constant resistance posed by the tube wall thickness. This convective resistance is a constant value for those discharge tests run at a constant brine flow rate but will gradually decrease for those tests with controlled heater inlet and outlet temperatures as the brine flow rate to the tank increases near the end of the discharge cycle. The maximum decrease in the convective heat resistance would occur when the flow changes from laminar to turbulent and would then account for a maximum decrease of 15% in the temperature difference between the brine and the solid NaOH. The resistance due to the melted NaOH surrounding the tube will increase throughout the discharge cycle, rising to a level almost equal to that of the tube wall thickness near the end of the discharge. This growing resistance can be seen in Figs. 11 and 12, where the frozen NaOH supply maintains a nearly constant temperature but the brine temperature leaving the tank rises at the end of the discharge cycle. The shape of the brine temperature curves is related to the logarithmic growth (due

Fig. 11. Brine temperature at storage tank outlet during melt tests.

to the cylindrical geometry) of this liquid heat transfer resistance, culminating in a 50% increase in the temperature difference between the brine and the frozen NaOH.

Figure 11 shows the discharge temperature profiles vs the cumulative discharge energy for all the discharge tests listed in Table 4. This figure demonstrates that the tank outlet temperature holds a relatively constant value throughout much of the discharge cycle. (The one test showing much higher temperatures is discussed later in this section.) The increase in temperature near the end of each test signals the end of the available latent storage. Figure 12 shows the temperature measured within the NaOH, at a point about 21 in. below the surface and between two sections of heat exchanger tubes. Examination of these two figures shows that total latent storage and total available latent storage are different quantities depending on the maximum useable brine outlet temperature. The NaOH temperature is relatively constant, indicating that a significant portion of the NaOH is still frozen for ~50 T-h after the tank outlet temperature has begun to rise rapidly.

Fig. 12. NaOH temperature measured ~21 in. below surface during melt tests.

The dependence of storage capacity on brine outlet temperature is shown in Table 4, by comparing the cumulative discharge energy throughout each test to the cumulative discharge energy available at outlet temperatures $< 50^{\circ}\text{F}$. For other cool storage units, we have correlated the total available energy with the discharge parameters of acceptable outlet temperature, discharge rate, or inlet temperature. However, for the Transphase unit, the initial conditions for each test were not always comparable because the shell heat gains were very large and because there was no way to measure the latent storage inventory. Therefore, slight differences in charging conditions or in the amount of elapsed time between the charge and discharge cycle had an important effect on the total amount of available storage. The best example of this initial variability is shown by the one test in Fig. 11 that started with initial temperatures greater than 45°F and a sharply rising temperature. This test represents a case where the tank was not fully charged at the beginning of the discharge test. Although these constraints prevent a meaningful prediction of total available capacity, the data can still be used to estimate the sensitivity of the

available capacity to the acceptable outlet temperature and discharge rate. This analysis showed, with high confidence levels, that ~12 additional T-h are available for each increase of 1°F in the acceptable outlet temperature. Also, the capacity is increased by ~10 T-h for each increase of 1 h in the discharge time, i.e. a decrease in the discharge rate increases the total available stored energy.

Figures 13 and 14 show 4 tests made with constant discharge capacities of 21 or 35 tons. Figure 13 displays the difference in control strategies among the tests. Two tests were made with constant brine flow rates to the storage tank with no attempt to control the temperatures anywhere in the loop. The other two tests used the bypass control shown in Fig. 1 to maintain the heater inlet temperature at 45°F and the heater outlet temperature at 60°F. After the brine temperature leaving the tank exceeded 45°F, these two tests were continued until the heater outlet temperature of 60°F could no longer be maintained. Figure 14 shows the temperature profiles of the brine leaving the storage tank for these same four

Fig. 13. Brine flow rates for two different control strategies during melt tests.

Fig. 14. Storage tank outlet temperature for two different control strategies during melt tests.

tests. As expected, the higher brine flow rates produce lower brine temperatures for comparable discharge rates because the product of the brine mass flow and temperature change must be the same (see Eq. 7). Those tests with temperature controls (0523 and 0619), and therefore growing brine flow rates, show a markedly different temperature profile than those for the constant brine flow rate tests (0604 and 0627). As discussed earlier, with a constant brine flow rate, the temperature of the brine leaving the tank will only vary with the logarithmic growth of the fluid resistance surrounding the heat exchanger tubes. Therefore tests 0604 and 0627 show an initially flatter profile with a sharply increasing temperature near the end of the test. However, with variable brine flow, the convective heat transfer within the tube is increasing as the heat transfer through the melted NaOH is decreasing, producing the more linear temperature profile shown for tests 0523 and 0619.

Another test was made to examine the reduction in capacity that would occur for a discharge in which the tank inlet (or heater outlet) temperature was held constant. The

discharge rate was held constant at 35 tons (the maximum available at the ISTF) until the heater outlet temperature exceeded 60°F, after which the heater power was reduced as necessary to maintain this temperature. Figure 15 shows the storage tank outlet temperature, the internal NaOH temperature, and the discharge rate for this test. The drop off in discharge rate after 7 h, or ~250 T-h was quite sharp. However, the internal tank temperature remains almost constant throughout the test, indicating the presence of remaining latent storage. Again, the growing volume of melted NaOH provides quickly growing heat transfer resistance near the end of the discharge cycle, limiting the availability of the stored energy.

Three tests were made under the same control strategy (45°F into the heater and 60°F out of the heater) at three different discharge rates of 35, 28, and 21 tons. The storage tank outlet temperatures for these tests are shown in Figs. 16 and 17. Figure 16 shows that

Fig. 15. Variable discharge rate during melt test 0625.

Fig. 16. Storage tank outlet temperatures for controlled tank inlet temperature of 60°F with constant discharge rates.

the slower discharge rate provides slightly lower outlet temperatures, as expected, for a longer period of time. However, when these same temperature profiles are plotted against the cumulative discharge energy in Fig. 17, they are very nearly identical. It may be possible, therefore, to characterize the tank's inventory as a function of brine outlet temperature for a given tank inlet temperature.

Power requirements during discharge include brine pumping power. The pumping power varies with the brine flow rate and ranged from 1 to 5 kW. This accounted for an approximate heat input to the brine of between 2 to 13 T-h over the course of the discharge cycle, assuming that all the pump power is converted to heat in the brine. Those tests made with a constant brine flow rate used from 2 to 3 times as much pumping power as those made with controlled temperatures at the heater inlet and outlet.

Fig. 17. Storage tank outlet temperatures for controlled tank inlet temperature of 60°F with constant discharge rates.

5.4 STANDBY HEAT GAINS

The Transphase prototype unit was not insulated, although the double wall construction provided a small amount of heat transfer resistance. Anytime the tank contents were cold, there was visible condensation on the outer plastic wall, usually running and dripping down the side of the tank. At one point, so much condensation had accumulated in the dike surrounding the tank that it was necessary to add chlorine to this diked area to inhibit the growth of odoriferous water creatures. The ambient temperature in the test area remained between 65 and 85°F, the humidity was usually high, and there was no direct sunlight upon the tank.

Without an inventory meter, it was not possible to directly measure the jacket heat gains. However, an estimate was made using the well defined parameters of tank surface area, surface temperature, and ambient temperature. The appropriate convective heat

transfer coefficient, for condensation under natural convection conditions, is not as easy to pin down. Various handbooks recommend values ranging from 0.59 to 1.65 Btu/h-ft²-°F, giving heat gain rates from 0.7 to 3 tons.^{7,8} These produce daily heat gain estimates ranging from 18 to 70 T-h/day, for a tank in a cold (~40°F) state. One charge test, 0425, was run at a very slow rate of about 15 ton. This test never showed any decrease in charging rate, even though the test extended over a 4-day period and the refrigeration system removed ~355 T-h of heat from the tank (see Fig. 9). This steady charging rate indicates that the tank was never fully charged. Since most charge tests showed some decrease in charging rate at ~200 T-h, one could estimate that at least 150 T-h of heat had been added to the storage tank through the shell. The shell heat gain rate would then be at least ~40 T-h/day and could be greater. If the shell heat gains occurred at a rate of 70 T-h/day, it would have taken about 6 days to fully charge the system (with a charging cycle of 15 h/day at a rate of 15 ton) before any decrease in the cooling capacity would have been visible.

6. CONCLUSIONS AND RECOMMENDATIONS

The cool storage unit tested was Transphase, Inc.'s first full scale prototype of a new design based on a 41°F eutectic. The design is comprised of a horizontal cylinder filled with eutectic material and containing an internal plastic heat exchanger used to circulate a brine mixture through the storage medium. This prototype was tested to determine both its thermal and operational characteristics. During the ISTF tests, the thermal behavior was measured and met reasonable expectations. The eutectic froze and melted very near the predicted temperature of 41°F, with only a small amount of subcooling when freezing from a fully-melted state. Compared to available subcooling curves for this material, the design effectively reduced this unwanted phenomenon. Although the lack of insulation makes any quantitative determination of total storage capacity imprecise, the unit was able to provide ~250 T-h of cooling under a variety of test conditions.

The prototype unit exhibited several operational problems that should be eliminated from future models. First, the heat exchanger construction should be made leak-free. Second, some means of removing the air from the heat exchanger coils should be implemented, perhaps by reorienting the coils or the tank to permit the necessary venting. Third, future development efforts should include some form of inventory measurement. Fourth, the bottom drain plug should be removed from the tank design to improve the overall safety. Future installations should be insulated.

One of the most important issues in this prototype test was that of eutectic stability. This issue warrants further study. Although the trends toward stratification noted in this work are slight, they were measurable and would impact the long term thermal qualities of the eutectic. Unfortunately, the confounding effect of the brine leakage into the storage tank can't be separated from the stratification effects under observation, leaving this issue open to debate.

REFERENCES

1. T. K. Stovall and J. J. Tomlinson, *Commercial Cool Storage Laboratory Test Procedure*, ORNL/TM-11511, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., May 1990.
2. G. T. Kartsounes and R. A. Erth, "Computer Calculation of the Thermodynamic Properties of Refrigerants 12, 22, and 502," *ASHRAE paper No. 2200*, presented at ASHRAE Annual Meeting, Washington D.C., August 22-25, 1971.
3. *UCARTHERM Heat Transfer Fluid*, Union Carbide Corporation, Industrial Chemicals Division, Danbury, Connecticut, 1986.
4. *Caustic Soda Handbook*, VMC-3395, Rev. 3/89, Vulcan Chemicals, Vulcan Materials Company, Birmingham, Alabama, 1989
5. A. Standen, Executive Editor, *Kirk-Othmer ENCYCLOPEDIA OF CHEMICAL TECHNOLOGY*, 2nd edition, Vol 1, Interscience Publishers, Division of John Wiley & Sons, Inc., New York, 1963, pp. 740-758.
6. Electric Power Research Institute, *Commercial Cool Storage Design Guide*, EM-3981, Palo Alto, California, May 1985.
7. T. Baumeister, Ed., *Marks' Standard Handbook for Mechanical Engineers*, 8th Ed., McGraw-Hill Book Company, New York, New York, 1978
8. E. Stamper, Ed., *Handbook of Air Conditioning, Heating, and Ventilating*, 3rd Ed., Industrial Press, Inc., New York, New York, 1979

Appendix A

ISTF INSTRUMENTATION

A.1 DATA ACQUISITION AND CONTROL

A data acquisition system and computer are used to control the thermal loading rate, the brine and refrigerant circulation pump speeds, recirculation valve positions, and the condensation temperature and to collect the data from system instrumentation. The computer allows short sampling times of the instrumentation to provide data for detailed analysis and feedback during transient system operation. Direct controls, outside of the data acquisition/computer system, are available for compressor loading, booster pump operation, and auxiliary portions of the test facility.

A.2 TEMPERATURE MEASUREMENTS

Refrigerant temperature measurements are made by RTDs bonded to the outside of the copper pipes. These RTDs were calibrated by the manufacturer to 0.3°F. After installation, the recorded refrigerant temperatures were compared to the expected thermodynamic states for the corresponding pressure measurements. Water and brine temperature measurements are made by RTDs inserted into the PVC pipes. These RTDs are calibrated to $\pm 0.2^\circ\text{F}$ and are checked against an ice bath periodically. The RTDs were also checked against each other under conditions where an unloaded heat exchanger, for example, would be expected to show the same inlet and outlet temperature.

A.3 FLOW MEASUREMENTS

Vortex-shedding flowmeters are used to measure the condenser cooling water flow, the water/brine flow to the heater, the water/brine flow to the storage tank, and the gaseous refrigerant flow to the condenser. The vortex-shedding refrigerant flowmeter imposes a pressure drop of ~ 0.5 psia. These flowmeters are accurate to $\pm 0.8\%$ of the reading for liquid flows and $\pm 1.5\%$ of the reading for gaseous flows. The flowmeters used to measure

water and brine volumetric flow were checked after installation by running water through the lines into a 55-gal. drum placed on a scale.

The Coriolis mass flowmeters used to measure liquid refrigerant mass flows to the low-pressure receiver, the storage tank, and the thermal expansion valves were calibrated by the manufacturer to $\pm 0.4\%$ of full scale, which is 1000 lb/min. A sight glass is positioned to provide a visual confirmation of single-phase flow downstream of the meter. These Coriolis flowmeters are very difficult to calibrate after installation because of the closed nature of the refrigerant system. However, the volumetric flow through one of the vortex-shedding flowmeters can be compared to the mass flow through one of these Coriolis meters. Also, energy balances on the condenser, low-pressure receiver, chiller/evaporator, and storage tank can be used to assess the continued accuracy of these devices.

A.4 PRESSURE MEASUREMENTS

Refrigerant pressure measurements are made with pressure transducers to allow the electronic recording of the values. The accuracy of these absolute pressure readings is rated at $+0.11\%$ of full scale. However, the calibration certificates supplied with each transducer show accuracies of $\pm 0.004\%$ or better. Also, the transducer calibration was rechecked after installation and periodically thereafter using laboratory calibration equipment. The pressure transducers located in the high-pressure portion of the loop, that is, between the compressor discharge and the expansion valve, are rated for 0 to 500 psia. All others are rated for 0 to 250 psia. During testing, the pressure measurements are periodically compared to other measurements within the loop and to the expected refrigerant properties.

A differential pressure meter can be used to measure the change in tank water depth during charging. The meter measures from 0 to 10 in. of water with an accuracy of $\pm 0.5\%$ of full range output (i.e., ± 0.05 in. of water). This instrument was not used during the Transphase tests.

A.5 ELECTRICAL MEASUREMENTS

Electrical measurements for the compressor power (rated at 40 and 75 hp), circulating pump(s) power (from 2 to 5 hp), agitation air compressor power (1/2 hp), and heater power (0 to 135 kW) are measured by watt/watt-hour transducers. The watt-hour measurements are accurate to $\pm[0.2\%$ of the reading + 0.01% of the rated output]/(power factor)]. The watt-hour meters for the compressors were checked by measuring the voltage and current on each of three phases. The watt-hour meter for the heater was checked by comparison to the heat absorbed by the water as measured by the flow and temperature change. The accuracy of this heater's watt-hour meter is poor because of the semiconductor-controlled rectifier (SCR), or phase-angle power controller, used to vary the heater power. Heater energy use measurements are therefore based on the fluid flow rate and temperature change, although the power consumption is recorded as an additional check.

Internal Distribution

1.	T. D. Anderson	15.	A. C. Schaffhauser
2.	V. D. Baxter	16.	M. Siman-Tov
3.	S. H. Buechler	17-26.	T. K. Stovall
4.	R. S. Carlsmith	27.	J. J. Tomlinson
5.	W. G. Craddick	28.	C. D. West
6.	P. D. Fairchild	29.	G. L. Yoder
7.	D. J. Fraysier	30.	ORNL Patent Section
8.	W. Fulkerson	31.	Central Research Library
9.	R. B. Honea	32.	Document Reference Section
10.	J. E. Jones Jr.	33-34.	Laboratory Records Department
11.	L. Jung	35.	Laboratory Records (RC)
12.	W. A. Miller		
13.	W. R. Mixon		
14.	M. Olszewski		

External Distribution

- 36. Doug Ames, Transphase, Inc. 15572 Commuter Lane, Huntington Beach, California 92649
- 37. John Stephen Anderpont, Chicago Bridge & Iron Company, 800 Jorie Boulevard, Oak Brook, IL 60522-7001
- 38. John Bruce, Transphase, Inc. 15572 Commuter Lane, Huntington Beach, California 92649
- 39. Debra L. Catanese, P.E., Pennsylvania Electric Company, 311 Industrial Park Rd., Johnstown, PA 15904
- 40. Tom Carter, Baltimore Aircoil Company, P.O. Box 7322, Baltimore, MD 21227
- 41. Russ Eaton, Director, Advanced Utility Concepts Division, U.S. Department of Energy, Forrestal Building, CE-142, 1000 Independence Avenue, Washington, DC 20585
- 42. Freemon Ford, FAFCO, Inc., 2690 Middlefield Road, Redwood City, California 94063-3455
- 43. Imre Gyuk, Office of Energy Storage and Distribution, U.S. Department of Energy, Forrestal Building, CE-32, 1000 Independence Avenue, Washington, DC 20585
- 44. Landis Kannberg, Battelle Pacific Northwest Laboratories, P.O. Box 999, Battelle Boulevard, Richland, WA 99352
- 45. Don Kemp, Turbo Refrigerating Company, 1815 Shady Oaks Drive, P.O. Box 396, Denton, TX 76202
- 46. K. W. Klunder, Director, Office of Energy Management, Department of Energy, CE-14, Forrestal Building, 1000 Independence Avenue, Washington, DC 20585

- 47-96. Dave Knebel, Director of Research, Thermal Storage Applications Research Center, University of Wisconsin-Madison, 150 E. Gilman Street, Suite 1200, Madison, WI 53703-1493
- 97. George Manthey, DOE, Oak Ridge Operations, Oak Ridge, TN 37831
- 98. Robert P. Miller, Baltimore Aircoil Company, P.O. Box 7322, Baltimore, MD 21227
- 99. Tony Min, Mechanical Engineering Department, North Carolina Agricultural and Technical State University, Greensboro, NC 27411
- 100. Victor A. Needham III, Marketing Programs Director, Cincinnati Gas & Electric Company, P. O. Box 960, Cincinnati, Ohio, 45201.
- 101. Dave Pellish, U.S. Department of Energy, Forrestal Building, MS CE-332, Room 5H-79, 1000 Independence Avenue, Washington, DC 20585
- 102. Veronika A. Rabl, Electric Power Research Institute, 3412 Hillview Avenue, P.O. Box 10412, Palo Alto, CA 94303
- 103. Eberhart Reimers, Advanced Utility Concepts Division, U.S. Department of Energy, Forrestal Building, CE-142, 1000 Independence Avenue, Washington, DC 20585
- 104. Richard Rhodes, FAFCO, Inc., 2690 Middlefield Road, Redwood City, California 94063-3455
- 105. Marwan Saliba, Energy Engineering Institute, Dept. of Mechanical Engineering, San Diego State University, San Diego, CA 92182-0191
- 106. Brian Silvetti, Calmac Manufacturing Corporation, Box 710, 150 South Van Brunt Street, Englewood, NJ 07631
- 107. Robert L. San Martin, Deputy Assistant Secretary, Office of Utility Technology, Department of Energy, CE-10, 6C-026/Forrestal Bldg., 1000 Independence Avenue, Washington, DC 20585
- 108. Chang W. Sohn, U.S. Army Corps of Engineers, P.O. Box 4005, Champaign, IL 61824-4005
- 109. Laura Thomas, Marketing Manager, York International Corporation, P.O. Box 1592, York, PA 17405-1592
- 110. Samuel G. Tornabene, Edison Electric Institute, 1111 19th Street, N.W., Washington, DC 20036-3691
- 111-135. R. D. Wendland, Electric Power Research Institute, 3412 Hillview Avenue, Box 10412, Palo Alto, CA 94303
- 136. Maurice W. Wildin, Professor, The University of New Mexico, Department of Mechanical Engineering, Albuquerque, NM 87131
- 137. Office of Assistant Manager for Energy Research and Development, Department of Energy, ORO, Oak Ridge, TN 37831
- 138-147. Given distribution as shown in DOE/OSTI-4500-R75 under Category UC-202 (Thermal Energy Storage)

END

DATE

FILMED

3 / 30 / 94