Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
**Reactor Engineering
Division**
**Reactor Engineering
Division**
**Reactor Engineering
Division**
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division

Received OSTI
JAN 29 1992

ANL/RE-91/2
Volume 2

A Fast Reactor Transient Analysis Methodology for PCs: Volume 2. LTC Program Manual

by K. O. Ott

Argonne National Laboratory, Argonne, Illinois 60439
operated by The University of Chicago
for the United States Department of Energy under Contract W-31-109-Eng-38

Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division
Reactor Engineering
Division

Argonne National Laboratory, with facilities in the states of Illinois and Idaho, is owned by the United States government, and operated by The University of Chicago under the provisions of a contract with the Department of Energy.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Reproduced from the best available copy.

Available to DOE and DOE contractors from the
Office of Scientific and Technical Information

P.O. Box 62

Oak Ridge, TN 37831

Prices available from (615) 576-8401, FTS 626-8401

Available to the public from the
National Technical Information Service

U.S. Department of Commerce

5285 Port Royal Road

Springfield, VA 22161

Argonne National Laboratory
9700 South Cass Avenue
Argonne, Illinois 60439

**A Fast Reactor Transient Analysis Methodology
for PCs:
Volume 2. LTC Program Manual**

by

K. O. Ott
School of Nuclear Engineering
Purdue University
West Lafayette, Indiana 47907

Prepared for
Reactor Engineering Division
Argonne National Laboratory

October 1991

MASTER

THIS DOCUMENT IS UNCLASSIFIED

Table of Contents

Abstract	1
1. Review of the Mathematical Model	2
1.1 Kinetics and Feedback	2
1.2 The Convolution Integrals	4
1.3 Solution of the Dynamics Equation	7
1.4 The Primary Coolant Loop Model	8
2. LTC-Program Structure : Overview	10
3. Detailed Discussion of the LTC Program	14
3.1 INFORMATION AND INPUT (Section I)	14
3.2 INITIAL VALUES AND GENERAL PREPARATIONS (Section II)	19
3.3 CONTROL OF BLOCKWISE POWER CALCULATION (Section III)	22
3.4 POWER CALCULATION FOR GENERAL TIME STEP IN BLOCK BL (Section IV) .	24
Appendix A: Computational Details	32
Appendix A1: The Three Types of Convolution Integrals	32
Appendix A2: Limited Ramp Descriptions	33
Appendix A3: SUBROUTINE PARABOLA AND NEW SLOPES	34
Appendix A4: Base-Time Identification for the Hot Pool Outlet Parabola	36
Appendix A5: Temperatures of the Coolant Pools	36
Appendix B: GW-BASIC Listing of LTC	40
Appendix C: Sample Problem	58
Appendix D: Glossary	62
Acknowledgements	69
References	69

List of Figures

Fig. 1 Primary coolant loop model	9
Fig. 2 LTC flow chart	13
Fig. 3 Input screens Nr. 1 and 2	15
Fig. 4 Input screens Nr. 3 and 4	16

List of Tables

Table I Numbering of Parabolas	27
--------------------------------------	----

**A Fast Reactor Transient Analysis Methodology
for PCs:
Volume 2. LTC Program Manual**

by

K. O. Ott

Abstract

This Manual describes a PC program for LMR Transient Calculations, LTC, written in GW-BASIC. It calculates the power and temperature trajectories for unscrammed TOP and LOHS transients. The LOF transient treatment is not operational in the GW-BASIC program because of storage limitations. The corresponding mathematical model, which allows a rapid treatment of the kinetics and the various feedback effects, is described in Ref. 1. It is briefly reviewed in Sec. 1. The program structure is outlined in Sec. 2, followed by a more detailed description in Sec. 3. Computational details are presented in Appendix A. A complete listing of the GW-BASIC program is given in Appendix B. Appendix C shows input-echo and output for a TOP sample problem, and Appendix D is a Glossary of all quantities used in the LTC program.

The limitations of the GW-BASIC storage (to about 60K) are removed if it is run within Quick-BASIC. This then allows the extension of this program to treat LOF transients. Running LTC in Quick-BASIC permits also larger "Dimensions" for TOP and LOHS transients.

Copies of the LTC program in GW-BASIC and Quick-BASIC are available from the author. Address: School of Nuclear Engineering, Purdue University, West Lafayette, IN 47907.

1. Review of the Mathematical Model

1.1 Kinetics and Feedback

The transient model applies point kinetics simplified by the Prompt Jump Approximation, PJA. This removes the "stiffness" of the problem and thus allows the application of large time steps. The PJA restricts the transients to the subprompt critical reactivity domain, a limitation that appears not to be exceeded during unscrammed TOP, LOHS and LOF transients for current LMR designs.

The relative fission power, $p_f(t)$, can then be expressed by a source multiplication formula, representing an implicit solution of the PJA version of the kinetics equation,

$$p_f(t) = \frac{s_d(t) + s}{\beta - \rho(t)} \quad , \quad (1)$$

with the delayed neutron source, $s_d(t)$, given by

$$s_d(t) = \sum_{k=1}^6 \lambda_k \beta_k \int_{-\infty}^t p_f(t') e^{-\lambda_k(t-t')} dt' \quad . \quad (2)$$

The independent source results from spontaneous fission. It needs to be included as it may limit the flux die-away during LOF and LOHS transients. The effective beta is denoted by β , with the component-fractions given by β_k , and the decay constants by λ_k , where k runs from 1 to 6.

The decay-heat power, $p_{dh}(t)$, is obtained from an analogous formula:

$$p_{dh}(t) = \sum_{k=7}^{12} \lambda_k \beta_k \int_{-\infty}^t p_f(t') e^{-\lambda_k(t-t')} dt' \quad . \quad (3)$$

The fractions, β_k , and the decay constants λ_k , in Eqs. (2) and (3) are distinguished by their index values; i.e. $k = 1$ to 6 refers to delayed neutrons, whereas $k = 7$ to 12 indicates the decay-heat components.

The same convention is followed for the various feedback effects: The feedback reactivity ρ_f is expressed as

$$\rho_f(t) = \sum_{k=13}^{20} a_k \delta T_k(t) \quad , \quad (4)$$

where the a_k for $k > 12$ are the temperature coefficients of the reactivity and the $\delta T_k(t)$ are the changes in the mean temperatures of various core and system components. Equation (4) can be written in the same form as Eqs. (2) and (3) by introducing "driving" or "forcing" functions D_k and time constants:

$$\rho_f(t) = \sum_{k>12} \lambda_k \beta_k \int_{-\infty}^t D_k(t') e^{-\lambda_k(t-t')} dt' \quad . \quad (5)$$

The common element of the formulas for fission power, decay heat and feedback reactivity, Eqs. (2), (3) and (5), are convolution integrals

$$V_k(t) = \lambda_k \int_{-\infty}^t p_f(t') e^{-\lambda_k(t-t')} dt', \quad \text{for } k=1 \cdots 12 \quad (6a)$$

and

$$V_k(t) = \lambda_k \int_0^t D_k(t') e^{-\lambda_k(t-t')} dt', \quad \text{for } k > 12 \quad . \quad (6b)$$

The fission power, $p_f(t)$, and the total power, $p(t)$, can then be completely expressed by convolution integrals

$$p_f(t) = \frac{\sum_{k=1}^6 \beta_k V_k(t) + s}{\beta - \rho_x(t) - \sum_{k>12} \beta_k V_k(t)} \quad (7a)$$

$$p(t) = p_f(t) + \sum_{k=7}^{12} \beta_k V_k(t) \quad . \quad (7b)$$

In the denominator of Eq. (7a), the reactivity of Eq. (1) is split into an "external" reactivity, $\rho_x(t)$ (for TOP-initiation), and the feedback reactivity, $\rho_f(t)$, given by the sum for $k > 12$:

$$\rho_f(t) = \sum_{k=13}^{20} \beta_k V_k(t) \quad . \quad (8)$$

For the V_k that describe temperature changes, δT_k , the β_k are equal to the corresponding a_k of Eq. (4). If not, the β_k includes a conversion factor between V_k and a temperature change (see below).

1.2 The Convolution Integrals

The convolution integrals are defined in Eqs. (6). In solving the initial value problem of the transient, the convolution integrals need to be incremented for the next time step. The corresponding recursion formulas are different for Eq. (6a) and Eq. (6b), as p_f , the unknown to be determined from Eq. (7a), appears explicitly in Eq. (6a), but only implicitly in Eq. (6b), except if D_k contains p_f directly [see Eq. (16b)].

For the derivation of the *implicit* time-step advancing scheme, all convolution integrals containing $p_f(t')$ are rewritten as

$$V_k(t_{n+1}) = \lambda_k \int_{-\infty}^{t_{n+1}} p_f(t') e^{-\lambda_k(t_{n+1}-t')} dt' = \lambda_k \int_{-\infty}^{t_n} p_f(t') e^{-\lambda_k(t_{n+1}-t')} dt' + \delta V_k(t_{n+1}) , \quad (9a)$$

with

$$\delta V_k(t_{n+1}) = \lambda_k \int_{t_n}^{t_{n+1}} p_f(t') e^{-\lambda_k(t_{n+1}-t')} dt' . \quad (9b)$$

The integral on the right side of Eq. (9a) is calculated from the previous convolution integral. This gives the recursion formula

$$V_k(t_{n+1}) = V_k(t_n) e^{-\lambda_k \Delta t_n} + \delta V_k(t_{n+1}) , \quad (10)$$

with

$$\Delta t_n = t_{n+1} - t_n . \quad (11)$$

A parabolic approximation of p_f - values, based on p_f -values for t_{n-1} , t_n and t_{n+1} , is applied in the increment δV_k , Eq. (9b):

$$p_f(t') = p_f(t_n) + \dot{p}_f(t_n) (t' - t_n) + c_2 (t' - t_n)^2 . \quad (12a)$$

In order to obtain an implicit finite differencing scheme, the value of c_2 is related to $p_f(t_{n+1})$; Eq. (12a) gives

$$p_f(t_{n+1}) = p_f^x(t_{n+1}) + c_2 \Delta t_n^2, \quad (12b)$$

with $p_f^x(t_{n+1})$ being the linear extrapolation at t_{n+1} :

$$p_f^x(t_{n+1}) = p_f(t_n) + \dot{p}_f(t_n) \Delta t_n. \quad (12c)$$

One obtains

$$c_2 = \left[p_f(t_{n+1}) - p_f^x(t_{n+1}) \right] \frac{1}{\Delta t_n^2}. \quad (12d)$$

Insertion of Eqs. (12) in Eq. (9b) gives

$$\delta V_k(t_{n+1}) = p_f(t_n) M_0(k) + \dot{p}_f(t_n) M_1(k) - \frac{p_f^x(t_{n+1})}{\Delta t_n^2} M_2(k) + \frac{p_f(t_{n+1})}{\Delta t_n^2} M_2(k), \quad (13a)$$

with the "moments"

$$M_0(k) = \lambda_k \int_{t_n}^{t_{n+1}} e^{-\lambda_k(t_{n+1} - t')} dt' = 1 - e^{-\lambda_k \Delta t_n} \quad (13b)$$

$$M_1(k) = \lambda_k \int_{t_n}^{t_{n+1}} (t' - t_n) e^{-\lambda_k(t_{n+1} - t')} dt' = \Delta t_n - M_0(k)/\lambda_k \quad (13c)$$

$$M_2(k) = \lambda_k \int_{t_n}^{t_{n+1}} (t' - t_n)^2 e^{-\lambda_k(t_{n+1} - t')} dt' = \Delta t_n^2 - 2M_1(k)/\lambda_k. \quad (13d)$$

Thus, the convolution integrals, Eqs. (9) can be expressed by a term depending on the fission power history prior to t_{n+1} , $A^H(t_{n+1})$, and a "present" term, A^P times the "present" p_f , i.e. $p_f(t_{n+1})$:

$$V_k(t_{n+1}) = A_k^H(t_{n+1}) + A_k^P p_f(t_{n+1}), \quad (14a)$$

with

$$A_k^H(t_{n+1}) = V_k(t_n) e^{-\lambda_k \Delta t_n} + p_f(t_n) M_0(k) + \dot{p}_f(t_n) M_1(k) - p_f^x(t_{n+1}) M_2(k) / \Delta t_n^2 \quad (14b)$$

$$A_k^P = M_2(k) / \Delta t_n^2. \quad (14c)$$

Equations (14) give for the delayed neutron source at t_{n+1} :

$$s_d(t_{n+1}) = H_{SD}(t_{n+1}) + P_{SD} p_f(t_{n+1}), \quad (15a)$$

with

$$H_{SD}(t_{n+1}) = \sum_{k=1}^6 \beta_k A_k^H(t_{n+1}) \quad (15b)$$

$$P_{SD} = \sum_{k=1}^6 \beta_k A_k^P. \quad (15c)$$

Inserting Eq. (14b) in Eq. (15b) yields

$$\begin{aligned} H_{SD}(t) = & \sum_{k=1}^6 V_k(t_n) e^{-\lambda_k \Delta t_n} + p_f(t_n) \sum_{k=1}^6 \beta_k M_0(k) + \dot{p}_f(t_n) \sum_{k=1}^6 \beta_k M_1(k) \\ & - p_f(t_{n+1}) \frac{1}{\Delta t_n^2} \sum_{k=1}^6 \beta_k M_2(k). \end{aligned} \quad (15d)$$

Corresponding expressions are obtained for decay heat and the feedback reactivity:

$$p_{dh}(t_{n+1}) = H_{DH}(t_{n+1}) + P_{DH} p_f(t_{n+1}) \quad (16a)$$

$$\rho_f(t_{n+1}) = H_{\rho f}(t_{n+1}) + P_{\rho f} p_f(t_{n+1}) \quad (16b)$$

with

$$H_{DH}(t_{n+1}) = \sum_{k=7}^{12} \beta_k A_k^H(t_{n+1}) \quad (16c)$$

$$P_{DH} = \sum_{k=7}^{12} \beta_k A_k^P \quad (16d)$$

and

$$H_{\rho f}(t_{n+1}) = \sum_{k=13}^{20} \beta_k A_k^H(t_{n+1}) \quad (16e)$$

$$P_{\rho f} = \sum_{k=13}^{20} \beta_k A_k^P. \quad (16f)$$

The equations for H_{DH} and H_{pf} are decomposed into the moment contributions in analogy to Eqs. (15). However, the split of the feedback reactivity in present and "historical" terms requires special considerations:

All feedback effects that rely on heating up one of the sodium pools are driven by the past power trajectory. They are therefore all part of $H_{pf}(t_{n+1})$. Specifically, they include the feedback effects resulting from changes in inlet, vessel, and control rod drive line temperatures.

Directly dependent on power are the Doppler effect, axial and radial expansion. But the corresponding convolution integrals contain the total and not just the fission power. Only the fission power component can contribute to P_{pf} . The convolution integrals over the total power increment are split as

$$V(k) = \int_0^t \left[p(t') - p_0 \right] e^{-\lambda_k(t-t')} dt' = \int_0^t p_f(t') e^{-\lambda_k(t-t')} dt' + \int_0^t \left[p_{dh}(t') - p_0 \right] e^{-\lambda_k(t-t')} dt' \quad (17a)$$

or

$$V(k) = VFP(k) + VDH(k) \quad (17b)$$

The first convolution integral, VFP, is treated as described in Eqs. (9) through (16), i.e. with a parabolic expansion of p_f through the current interval. For the second integral as well as all others that do not depend *directly* on $p_f(t')$ such an implicit finite differencing scheme is not suitable. Therefore, the integrand is just linearly extrapolated from t_n to t_{n+1} . The explicit expressions for H_{pf} and P_{pf} are given in Ref. 1. If Eq. (17a) is iterated, the second integral is calculated first from a linear extrapolation of p_{dh} , but from a parabola in subsequent iterates.

1.3 Solution of the Dynamics Equation

Inserting Eqs. (15) and (16) in Eq. (7a) and solving for $p_f(t_{n+1})$ yields the *quadratic dynamic equation* for the fission power

$$p_f^2(t_{n+1}) - R(t_{n+1})p_f(t_{n+1}) + Q(t_{n+1}) = 0, \quad (18a)$$

with

$$R(t_{n+1}) = \left[\beta - \rho_x(t_{n+1}) - H_{pf} - P_{SD} \right] \frac{1}{P_{pf}} \quad (18b)$$

$$Q(t_{n+1}) = \left[H_{SD}(t_{n+1}) + s \right] \frac{1}{P_{pf}} \quad (18c)$$

The fission power at t_{n+1} is then obtained as solution of the quadratic dynamics equation:

$$p_f(t_{n+1}) = \frac{1}{2} \left[R(t_{n+1}) + \sqrt{R^2(t_{n+1}) - 4Q} \right] \quad (19a)$$

If $p_f(t_{n+1}) \ll 1$ the accuracy of a PC is not sufficient to calculate p_f from Eq. (19a) as Eq. (18a) then becomes nearly linear. Equation (19a) is then replaced by

$$p_f = \frac{Q - (\frac{Q}{R})^2}{R} \quad (19b)$$

The combination of Eqs. (19a) and (19b), i.e. Eq. (19a) for $|\frac{Q}{R}| \geq 10^{-4}$ and Eq. (19b) for $|\frac{Q}{R}| < 10^{-4}$, yields always seven or more valid digits.

1.4 The Primary Coolant Loop Model

For the calculation of the temperatures in the major components of the coolant loop, and the evaluation of the delays of the sodium and steel heatup during transients, a simplified description of the primary coolant loop, depicted in Fig. 1, is applied in which instantaneous mixing of sodium is assumed within each pool. The sodium flows from the core (C) to the hot pool (HP), from there through piping, including the Intermediate Heat Exchanger, to the cold pool (CP). The Upper Internal Structure is combined with the hot pool. The flow delay in the primary loop, between core outlet and Intermediate Heat Exchanger outlet, is all accounted for in the loop-component "piping and intermediate heat exchanger," called HX for simplicity. Thus, the power coming out of the HX, P_{out}^{HX} , equals the power coming into HX some t_L seconds (here 24s) earlier, minus the extracted power, $P_x(t)$:

$$P_{out}^{HX}(t) = P^{HP}(t - t_L) - P_x(t). \quad (20)$$

From the HX the coolant enters the cold pool (CP) and from there the core inlet. Decay heat removal is considered out of the hot pool, P_{DHR} , and at the vessel surface, with P_V^{HP} and P_V^{CP} being the HP and CP components respectively. Thus, the total heat rejection rate has four contributions:

$$P_r = P_x + P_{DHR} + P_V^{HP} + P_V^{CP} \quad (21)$$

The mathematical treatment of a coolant pool is presented in App. A.5. In the program, these equations are specialized for the hot and cold pool respectively.

Fig. 1: Primary coolant loop model

2. LTC-Program Structure : Overview

The ~ 1050 lines of the GW-BASIC program consist of four larger sections (comp. App. B). In the following the respective sub-section titles are listed behind bullets.

Section I: INFORMATION AND INPUT

[300 lines of coding; executed once]

- Information
- Array Declaration
- Input Menu
- Input Data
- Read Input
- Input Edit

Section II: INITIAL VALUES AND GENERAL PREPARATIONS

[130 lines of coding; executed once]

This section comprises all preparations for the transient calculation. They include

- Initial Values (including modification of Input as needed)
- Open Output Files
- Printing of Header and Initial Values
- Preliminary Second and Third Values
- General Preparations
- Transient Selection
- Set-Up of Input Reactivity (for TOP only)

Section III: CONTROL OF BLOCKWISE POWER CALCULATION

[150 lines of coding; executed once per time block]

The (repetitive) time dependent calculations are structured in "blocks", with BL being the block number. The characteristics of a block are: The step-size within a block is constant: $\Delta t = DT$ (BL). The length of a block needs to be longer than the flow delay between core outlet and IHX-outlet (typically 20 to 30 seconds for TOP and LOHS).

The use of these blocks has several advantages:

1. Most coefficients used in the calculation for each step need to be calculated only once for each block; e.g. the moments of Eqs. (13) and all other exponential function quantities.

2. The algorithm for the time-step determination is executed only once per block.
3. The calculation of the inlet temperature requires outlet information only out of the same or the previous block. Thus, data of prior blocks need not be retained.

Section III has the following subsections:

- Initialization
- Start of Block BL Loop
- New Time Step
- Block BL Coefficients.

Section IV: POWER CALCULATION FOR GENERAL TIME STEP IN BLOCK BL

[550 lines of coding; executed for each time step]

Section IV is the main body of the program. It is executed "FOR N = N0 (BL) TO NE (BL)". Section IV is broken into the following subsections:

- Preparations for Time-Step N+1 [40 lines of coding]

These preparations include the calculation of the N -dependent coefficients, and the input reactivity in the case of TOP.

- Cold Pool [130 lines of coding]

The temperature calculation in the coolant loop begins with the Cold Pool to obtain core-inlet temperature ΔT_i , which in the case of LOF and LOHS induces the nuclear transient. Thus, the CP-temperature calculation precedes the first power calculation. For a TOP calculation, ΔT_i is zero for the first t_L seconds (here 24s) due to of the flow delay between core outlet and IHX outlet. Therefore, the power-change is (automatically) calculated first, leading to subsequent temperature changes in HP.

This Cold Pool program calculates the inlet temperature change for interval t_n to t_{n+1} , yielding $\Delta T_i(t_{n+1}) = DTI(N + 1)$, based on a linear extrapolation of the heat exchanger outlet temperature to t_{n+1} : $DTOHX(N + 1)$.

- Projected Convolution Integrals and Temperatures.

The temperature and feedback reactivity changes of the grid-plate are calculated from the ΔT_i -parabola. The core calculation includes an *iteration* for which "interim convolution integrals", $IV(K)$, are calculated here; they $IV(K)$ are first obtained from *extrapolations* of the driving functions.

- Historical Temperature and Feedback Components [Eq. (16e)]
- Application of New Fission Power for the Calculation of
 - Temperature Differences
 - Reactivity
 - Power Related Terms
 - Parabolas and Slopes
 - Convolution Integrals from Parabolas [yielding the iterated values of $IV(K)$]
 - Iteration Control: Returns to "Historical Temperature and Feedback Components" to be calculated with the improved $IV(K)$, or continues as:
- Set $V(K) = IV(K)$ at "End of Iteration", with $V(K)$ being the final convolution integrals at the end of the interval t_n to t_{n+1} .
- Hot Pool Control (using core outlet temperature change)
- Printing of Time Step N+1
- Preparations for Next Time Step
- * NEXT N (Next Time Step)

*****End of Block BL - Calculations*****

After the completion of all time steps in a block, the following operations are performed:

- Reshuffling of Blocked Arrays (the newly calculated data are transferred to the "prior" block arrays.)
- PRINT: Elapsed Time/Block and Fission Power
- PRINT: Max $|\delta p/p|$, and New Time Step

Section V: SUBROUTINES

- Subroutine : Parabola
- Subroutine : Cold Pool
- Subroutine : Hot Pool
- Subroutine : Vessel Heat Rejection
- Subroutine : Steam Generator Heat Flux

The structure outlined in this Overview is depicted in the Flow Chart, Fig. 2. A detailed discussion is presented in the following. The basis for this discussion is the program listing in the Appendix. Line numbers mentioned refer to this listing.

Fig. 2 LTC flow chart

3. Detailed Discussion of the LTC Program

3.1 INFORMATION AND INPUT (Section I) *

The INFORMATION includes the options for transients, i.e, TOP and LOHS, options for reactivity insertion, as ramp or according to a worth curve, and information on the kinetics, i.e, fission power is calculated from the quadratic dynamics equation. (lines 110-156).

The INPUT is presented on four screens, called Part I, Part II, Part III and Part IV, available through the keys F2, F6, F7 and F8 respectively. They are depicted on Fig. 3 and 4. The input can be readily edited on the screen. The INPUT MENU and the Input Data are listed from lines 200 - 396. The sample input of Figs. 3 and 4 has been used to calculate the output table of App. C. Every fifth value is printed out. The starting time step is 1 second, increasing to 32 seconds as the transient slows down.

ARRAY DECLARATION (lines 158-176)

INPUT MENU (lines 200-235)

INPUT DATA PART I (lines 238 - 278; see Fig. 3)

The INPUT DATA PART I include:

Transient Type: TT = 1 (TOP), 2 (LOHS), 3(LOF) (LOF not operational)

Time Structure: DT(1) = time step size in first block (sec)

NM = number of time steps per block

It is assumed that the block length, DT(1) * NM is, larger than the duration of the ramp insertion of the TOP-reactivity, and larger than the flow delay between core outlet and IHX-outlet. If this is not the case the program stops with a BEEP and displays the message "Block Size Too Small" (lines 496 and 1222 respectively).

BE = number of blocks

As the time step changes along the calculation, the total time span of the transient calculation depends on BE and the limits used in the time step algorithm.

LDB = limit for doubling the time step

LHA = limit for halving the time step

The time step algorithm in Sec. III (lines 1748-1772) doubles the time step for the next block if the maximum change in the absolute relative power, $|\delta p/p|$ across a time-step in the previous block is smaller than LDB, the Limit for Doubling; it halves the next time step if $|\delta p/p| > LHA$, the Limit for Halving. Typical values are 0.01 for LDB and 0.02 for LHA.

* Section titles quoted from GW-BASIC are shown in all capital letters.

```

INPUT DATA:: F2: PART I; F6: PART II; F7: PART III
              F8: PART IV;      F9 : EXECUTE PROGRAM
238 '===== INPUT DATA PART I =====
240 REM:  I.  TRANSIENT TYPE :
242        TT = 1      '1=TOP, 2=LOHS, 3=LOF(NOT WORKING)
244 REM:  II. TIME STRUCTURE :
246        DT(1) = 1   'TIME STEP SIZE (SEC) OF FIRST BLOCK
248        NM = 40     '# OF TIME STEPS PER BLOCK
250        BE = 14     '# OF BLOCKS
252        LDB = .01    'RELATIVE-POWER-CHANGE LIMIT FOR DT(BL)-DOUBLING
254        LHA = .02    'RELATIVE-POWER-CHANGE LIMIT FOR DT(BL)-HALVING
256        MAXDT = 32   'MAXIMUM STEP SIZE (SEC)
258 REM:  III. REACTIVITY INSERTION :
260        RG = 1      '1=RAMP, 2=WORTH-CURVE
262        A = .01      'RAMP INSERTION RATE
264        RM = .2      'END-POINT REACTIVITY OF RAMP
266        DR = 1      'DURATION OF PARABOLIC RAMP SMOOTHING
268        'END-POINT OF RAMP +/- DR*DT
270        H = 90      'CORE HEIGHT (CM)
272 REM:  IV. OTHER QUANTITIES :
274        P0 = 1      'INITIAL POWER RELATIVE TO NOMINAL POWER
276        TL = 24     'FLOW-TIME CORE-OUTLET TO IHX-OUTLET (SEC)

```

```

INPUT DATA:: F2: PART I; F6: PART II; F7: PART III
              F8: PART IV;      F9 : EXECUTE PROGRAM
280 '===== INPUT DATA PART II =====
282 REM:  V.  OTHER QUANTITIES : (FP=FULL POWER; FPS=FP SECONDS)
284        DHR = .0036  'DECAY HEAT REMOVAL FROM HOT POOL (FP)
286        BH = .0587   'INITIAL DECAY HEAT FRACTION (FP)
288        SSP = 1.11E-11 'SPONTANEOUS FISSION SOURCE (FP)
290        ARVHP = 110  'HOT POOL VESSEL AREA (M**2)
292        ARVCP = 190  'COLD POOL VESSEL AREA (M**2)
294        CLHP = .4613 'HOT POOL SODIUM HEAT CAPACITY (FPS)
296        CLCP = .5089 'COLD POOL SODIUM HEAT CAPACITY (FPS)
298        CSHP = .2188 'HOT POOL STEEL HEAT CAPACITY (FPS)
300        CSCP = .5422 'COLD POOL STEEL HEAT CAPACITY (FPS)
302        CVHP = .0083 'HOT POOL VESSEL HEAT CAPACITY (FPS)
304        CVCP = .0205 'COLD POOL VESSEL HEAT CAPACITY (FPS)
306        CCOR = .00762 'CORE HEAT CAPACITY (FPS)
308        CFUL = .00271 'FUEL HEAT CAPACITY (FPS)
310        DTCOOL=152.76 'NOMINAL COOLANT TEMPERATURE RISE (K)
312        DTFC0= 89.56 'NOMINAL FUEL/CLAD TEMPERATURE RISE (K)
314        TVCP0= 630.56 'INITIAL COLD POOL SODIUM TEMPERATURE (K)
316        TVHP0= 783.33 'INITIAL HOT POOL SODIUM TEMPERATURE (K)

```

Fig. 3: Input screens Nr. 1 and 2

```

INPUT DATA:: F2: PART I; F6: PART II; F7: PART III
              F8: PART IV;      F9 : EXECUTE PROGRAM
322 '===== INPUT DATA PART III =====
324 REM: BETA , BT(1) TO BT(6), DELAYED NEUTRONS
326 DATA .00826,.07248,.06336,.12134,.05513,.01773
328 REM: BETA , BT(7) TO BT(12), DECAY HEAT
330 DATA 1.6232,2.094,1.163,.5523,.0852,.3521
332 REM: BETA , BT(13) TO BT(21), FEEDBACK (INDEX NOT CORRESPONDIG TO LAMBDA)
334 DATA -.0981,-0.1432,+.1715,-.1184,-.1184,-.1110,+.062 ,+.062,78.9
340 REM: LAMDA, L(1) TO L(6), DELAYED NEUTRONS
342 DATA .01298,.03137,.1354,.3457,1.369,3.7376
344 REM: LAMDA, L(7) TO L(12), DECAY HEAT
346 DATA .1985,.01437,.009360,.0000762,.00000973,.000000888
348 REM: LAMDA, L(13) TO L(20), FEEDBACK (INDEX NOT CORRESPONDING TO BETA)
350 DATA 4.108,2.00 ,.0092 ,3.975 ,4.108 ,0.041, 4.108,4.108
352 REM: LAMDA, L(21) TO L(32), FLOW LOOP
354 DATA .01282,.01282,.001025,.01282,.00085,0.01282,0.01415,0.01415,.01016,0.01
415,.00085,0.01415
356 REM: SPECIAL LAMBDA VALUES
358 DATA 18.09,4.725,6.613,13.66,44.51

```

```

INPUT DATA:: F2: PART I; F6: PART II; F7: PART III
              F8: PART IV;      F9 : EXECUTE PROGRAM
362 '===== INPUT DATA PART IV =====
364 REM: TEMPERATURES FOR RACS HEAT-FLUX CORRELATION
366 DATA 433.,495.7,577.8,681.6,753.6,810.2,857.5,898.4,951.5,1025.,1086.,1139.
368 REM: RACS HEAT FLUXES
370 DATA 5.0E-7,1.0E-6,2.0E-6,4.0E-6,6.0E-6,8.0E-6,1.0E-5,1.2E-5,1.5E-5,2.0E-5,2
.5E-5,3.0E-5
372 REM: TIMES FOR STEAM GENERATOR HEAT-FLUX CORRELATION
374 DATA 0,2,4,6,8,10,12,14,16,18,20,25,30,35,40,45,50,55
376 REM: STEAM GENERATOR HEAT FLUXES
378 DATA 1,.368,.195,.122,.084,.062,.047,.038,.031,.026,.022,.015,.011,.009,.007
,.006,.005,0
380 '.....
382 PR   = 1      ' NOMINAL HEAVY REJECTION (FP)
384 TLOF = 6      ' CHARACTERISTIC TIME FOR FLOW LOSS IN LOF (SEC)
386 TLOHS= 82     ' TIME FOR SG LOOSING HEAT FLUX IN LOHS (SEC)
388 NPNT = 5      ' PRINT EVERY NPNT STEP
390 INED = 1      ' 1=ENABLE INPUT EDIT; 0=NO EDIT; 0.1=ONLY HEADING
392 STUCK = 0     ' STUCK=0 IF FUEL FREE TO EXPAND
394 PI = 3.141592654#
396 '.....

```

Fig. 4: Input screens Nr. 3 and 4

Furthermore, a maximum time step, MAXDT, needs to be specified. A value of MAXDT = 32s appears to be suitable for most transients. For larger values of MAXDT (≥ 64 s) the solution of the set of heat transfer equations in the core may start to diverge. This divergence can be avoided, or postponed, if more iterations are employed (see "Iteration Control").

MAXDT = Maximum time step.

Reactivity Insertion

RG = 1 for (limited) ramp reactivity

RG = 2 for worth curve reactivity (see App. A1)

A = ramp rate

RM = maximum reactivity inserted by ramp

DR = duration of parabolic smoothing of the end of the ramp in units of DT(1)

(Note: a true limited ramp with a discontinuous slope at its end is not available in this program).

The reactivity insertion is programmed as a limited ramp with a continuous (smoothed) end. The smoothing is either done by a parabola over DR time steps before and after the end time of the ramp, TX. Alternatively a worth curve can be employed, assuming a control rod withdrawal from the mid-plane of the core, starting with a velocity that yields the input ramp. The reactivity is calculated from a worth proportional to the square of a cosine over the core height plus 20 cm extrapolation length on both ends. (see below: External Reactivity)

H = core height

Other Quantities

Initial Power Relative to Nominal Power

Flow Delay Between Core and IHX Outlets.

INPUT DATA PART II (lines 280 - 320; see Fig. 3)

The INPUT DATA PART II include:

DHR = decay heat removal rate from hot pool (fraction of full power, FP)

BH = initial decay heat fraction

SSP = spontaneous fission source (or other independent source), expressed as a fraction of the full-power fission neutron source; i.e. in units of FP

ARVHP = hot pool vessel area (m^2)

ARVCP = cold pool vessel area (m^2)

Heat Capacities (FPs/K):

CLHP : hot pool sodium (liquid, hot pool)

CLCP : cold pool sodium (liquid, cold pool)

CSHP : hot pool steel (steel, hot pool)

CSCP : cold pool steel (steel, cold pool)

CVHP : hot pool vessel (vessel, hot pool)
 CVCP : cold pool vessel (vessel, cold pool)
 CCOR : core
 CFUL : fuel

DTCOOL = nominal coolant temperature rise along channel (K)

TVCP0 = initial cold pool sodium temperature (K)

DTFC0 = initial average temperature difference between fuel and cladding (K)

TVHP0 = initial hot pool sodium temperature (K)

INPUT DATA PART III (lines 322 - 360; see Fig. 4)

The INPUT DATA PART III include:

Beta :	BT(1) ... BT(6)	delayed neutrons
	BT(7) ... BT(12)	decay heat
	BT(13) ... BT(20)	feedback (see Tab. I of Ref. 1)
	BT(21) ... BT(32)	flow loop, all equal to zero : no direct reactivity effect
Lambda :	L(1) ... L(6)	delayed neutrons
	L(7) ... L(12)	decay heat
	L(13) ... L(20)	feedback (see Tab. II of Ref. 1)
		: The numbering of $L(k)$ in this group is not
		corresponding to the numbering of BT(13 ... 20)
	L(21) ... L(32)	flow loop (see Tab. II of Ref. 1)

Special lambda values (see Sec. III.1 of Ref. 1) : $SLAMBDA(1) = \lambda_{CL}$, $SLAMBDA(2) = \lambda_{cf}$, $SLAMBDA(3) = \lambda_{LS}$, $SLAMBDA(4) = \lambda_{Li}$, $SLAMBDA(5) = \lambda_{LC}$. All temperature coefficients are input in $^{\circ}C/K$, they will be converted to $^{\circ}F/K$ later.

INPUT DATA PART IV (lines 362-396; see Fig. 4)

Heat flux correlations for the Reactor Air Cooling System, listed by base temperatures and a corresponding set of heat flux values RACS:

Temperatures for RACS heat-flux correlation
 RACS heat fluxes

Heat flux correlation for Steam Generator, SG, listed by base times and corresponding heat fluxes:

Times for Steam Generator Heat-Flux Correlation
 Steam generator heat fluxes

PR = 1: Nominal heat rejection

TLOF = characteristic time for loss of flow in the hyperbola $1/(1 + \text{time}/\text{TLOF})$

TLOHS = time for linear heat flux loss in steam generator in LOHS

NPNT = print every NPNT time step

INED = flag for INPUT EDIT

 INED = 1: complete edit

 INED = .1: only version number, date and time, and column heading above the
 online print-out of results

 INED = 0: no edit

*****End of Input Part IV*****

The key F9 starts to RUN the program, beginning with the ARRAY DECLARATION (lines 158 - 176), followed by reading the explicitly given data values in Parts I, II and IV. The READ INPUT program (lines 420 - 498) reads the DATA of Input Parts III and IV.

Identification of flow-time constants for cold and hot pool respectively:

 LWCP = L (21)

 LWHP = L (27)

Calculation of first block size, $BS = DT(1) * NM$; it beeps and stops if it is too small.

INPUT EDIT

The subsequent INPUT EDIT (lines 500 - 760) can either be skipped entirely or restricted to just the "version, date, time" and the headings the output of the results (flags 0 or 0.1 or 1, set above).

3.2 INITIAL VALUES AND GENERAL PREPARATIONS (Section II)

INITIAL VALUES (lines 1006 - 1164)

The initial values for time, power, flow, delayed neutrons, decay heat, temperature and reactivity changes are set or calculated in lines 1006-1090. If any of these standard initial conditions (e.g. $t_0 = 0$) needs to be changed, it has to be done in the respective lines of the program.

Time

BL = 1 : first block of time steps

N = 1 : first time step

T(1) = 0 : initial time

Power

$P0 = 1$: initial (relative) power (= 1 FP)

$FP0 = P0 * (1 - BH)$: initial relative fission power

FPD : initial derivative of fission power

FPD : $FP0 * A$ (Note, FPD is positive for TOP ($A > 0$), and zero if $A = 0$).

$PTD = FPD$: initial derivative total power

Flow and Power Flow

$FL0 = 1$ initial relative flow

Delayed Neutrons (K=1 to 6)

$BT(K)$ are converted from ϕ to $\$$

$B (= \beta_{eff})$ is calculated

$V(K) = FP0$: convolution integrals for $k=1$ to 6 are initially equal to $FP0$

$SD = B * FP0$: current delayed neutron source; here initial value.

Decay Heat (K=7 to 12)

Renormalization of the input β_K such that

$DH0 = BH$

$V(K) = FP0$: initial values of convolution integrals for $k=7$ to 12

$DHD = 0$: initial decay heat derivative

Temperatures and Heat Rejection

The initial values and derivatives of all temperature changes are equal to zero.

Feedback Reactivity

Renormalization of input coefficients $BT(K)$ from ϕ to $\$$ ($K = 13$ to 21)

Initial values for the three types of convolution integrals of the core feedback description:

$V(K)$, $VDH(K)$ and $VFP(K)$ are set to zero.

OPEN OUTPUT FILES

The on-line output that is printed during the calculation, as well as additional information on temperatures, power and reactivities is *filed* in two output files, "DTEMP" and "POWRO". They can be printed out after the calculation by the standard DOS command `PRINT file name`. This print-out has the same time-format as the on-line print-out; so the three print-out sheets can be layed side by side to obtain the complete information. For later computer application, e.g. drafting, the output files have to be copied on a floppy disk.

PRINT HEADER AND INITIAL VALUES

The HEADER for the on-line has the time in minutes.seconds; e.g. 1.30 is 1 minute and thirty seconds. It is followed by (see sample output in App. C) power, decay heat, changes in the temperatures at the core outlet (DTOUTLET), the hot pool (DTLHP), the heat exchanger outlet (DTHX) and the core inlet (DTINLET) and by the reactivity in ρ with its components, ρ_x (external) and ρ_f (feedback).

Then the headers for the two files are printed:

File DTEMP : TIME (sec), DT-Fuel, DT-Clad, DT-Coolant, DT-Structure, DT-CR-Drive Line,
DT-Outlet, DT-Sodium Hot Pool, DT-IHX-Outlet, DT-Inlet

File POWRO : TIME (sec), POWER (%), DECAY HEAT, Reactivity (ρ) DOPPLER, AX.EXP,
COOLANT, RAD. EXP, CR-ROD.

All reactivities are printed in ρ .

This is followed by the printing of the corresponding initial values.

BASE POINT NOTATION OF INITIAL VALUES

The driving functions that are expressed as parabolas for the finite difference integration of the convolution integrals. In order to save storage space in the limited GWBASIC environment (limited to about 60K), a dimensioning of arrays was avoided whenever possible. But, four base-points for the parabolic approximation needed to be carried through the calculation. The following general notation is used

XO2 for N-2

XO1 for N-1

XO for N

XN for N+1,

where X stand for any quantity.

The base point notation for the initial values is XO. The first calculated value is XN.

TRANSIENT SELECTION

TOP, Set-Up of Input Reactivities

Two types of reactivity insertions are provided, both with the essential characteristics of a "limited ramp", i.e. starting with a given ramp rate (A\$/s) and ending with a given maximum amount of inserted reactivity, RM(\$). But the kink at the end of the ramp has been smoothed as described in detail in App. A1.

Set-Up of Smoothed Ramp (lines 1230-1244)

Set-Up of Worth Curve (lines 1250-1268)

Furthermore, a parameter OPT is for each transient type that specifies the deviation from the nominal heat rejection capability of the heat exchanger.

TOP: OPT = 0

LOHS: OPT = 1 - PRVHP - PRVCP - DHR

LOF: OPT = 0

This concludes the section "INITIAL VALUES AND GENERAL PREPARATIONS."

3.3 CONTROL OF BLOCKWISE POWER CALCULATION (Section III)

INITIALIZATION

NO(1) = 1 : number of first time step in block 1

NE(1) = NM : number of last time step in block 1

PP is a parameter that characterizes the intervals used in the parabolic approximations of driving functions (see App. A.3):

PP = 0 : two equal intervals

PP = 1 : second interval twice the size of the first one

PP = 2 : second interval half the size of the first one.

Within a block of time steps PP is always zero. For parabolas that extend over a last interval out of the previous block and over the first interval out of a subsequent block, the PP-flag is different from zero if the time step has changed.

TELAP = 0 : TSTART = TIMER : Start counting elapsed time

START OF BLOCK-BL LOOP

NEW TIME STEP (lines 1748-1772) (skipped for the first block, BL = 1)

The absolute maximum change in relative power within a block (MAXD) is used as criterion for the step size selection. If MAXD is smaller than a set lower limit (LDB), the step size is doubled; if MAXD exceeds the upper limit LHA, the step size is halved. Based on this decision, the PP-flag is left to be 0, or, if the time step is changed, it is set to be 1 or 2.

The previous block number, the elapsed time and the last value of the fission power are printed. Furthermore, the new block number (BL), MAXD and the new time step, DT(BL) are printed in a second line (see Sample Output).

BLOCK BL COEFFICIENTS

The finite differencing scheme involves a number of coefficients and exponential functions that depend on the index k of the convolution integral and the time step $DT(BL)$. They are calculated once for each block, before entering the time-step loop:

General Coefficients

For all k ($k = 1$ to 32) the three moments, defined in Eqs. (13) are precalculated here. These general coefficients are the same for all time-steps within a block.

The λ -values vary over seven orders of magnitude. They range from about $10/s$ for the heat release out of a metal fuel rod to about $10^{-6}/s$ for the longest living decay heat group. In addition, the time steps may cover a wide range also; e.g. from 0.1 to $32s$. Thus, the exponent $\lambda_k \Delta t$ may vary from 10^{-7} to 300 , i.e. by more than nine orders of magnitude. Therefore, the calculation of the moments M_1 and M_2 , that contain $\exp(-\lambda_k \Delta t)$ requires special consideration to avoid failures for extremely small $\lambda \Delta t$. The limits for small $\lambda \Delta t$ are analytically given by

$$\lim_{\lambda \Delta t \rightarrow 0} M_1(\lambda \Delta t) = \frac{\lambda [\Delta t]^2}{2} = M_{1as} \quad (20a)$$

$$\lim_{\lambda \Delta t \rightarrow 0} M_2(\lambda \Delta t) = \frac{\lambda [\Delta t]^3}{3} = M_{2as} \quad (20b)$$

Both, M_1 and M_2 have to be between zero and M_{1as} or M_{2as} . If a calculated value is outside of this range due to the limited accuracy of the PC it is replaced by the corresponding asymptotic values. It should be noted that high accuracy is not required at this point because the M_1 and M_2 contributions to the convolution integrals disappear with $\lambda \Delta t \rightarrow 0$. But it is necessary to replace meaningless large negative or positive numbers that may be calculated by a PC in the extreme cases in which $\lambda \Delta t \lll 1$.

Delayed Neutron Coefficients

The three moments are combined for $k=1$ to 6 per Eq. (15d), yielding the present component, P_{SD} (Eq. 15c) and the factors D_{SD} and M_{SD} for the later calculation of the historical term:

$$D_{SD} = \sum_{k=1}^6 \beta_k M_0(k) \quad (21a)$$

$$M_{SD} = \sum_{k=1}^6 \beta_k M_1(k) \quad , \quad (21b)$$

Decay Heat Coefficients

The moments are combined for $k=7$ to 12, yielding quantities that are directly analogous to the ones for the delayed neutron source.

Prompt Feedback Component

The prompt component of the feedback reactivity, Eq. (16f), is the same throughout a block. It is precalculated here.

MAXD

MAXD = 0: At the beginning of the power calculations for block BL, the starting value for the absolute maximum relative change in power (MAXD) is set to zero.

3.4 POWER CALCULATION FOR GENERAL TIME STEP IN BLOCK BL (Section IV)

The power calculation is executed

FOR N = N0(BL) TO NE(BL).

3.4.1 PREPARATIONS FOR TIME STEP N+1

The next time value is set:

$$T(N+1) = T(N) + DT(BL).$$

The factor in the historical components of all convolution integral that contains the extrapolated power [see Eqs. (12c) and (14b)] is calculated:

$$AAH = -p_f^x(t_{n+1}) \cdot AAP, \text{ with}$$

$$p_f^x = FPX = D0N(1) + D1N(1) * DT(BL).$$

For the parabola coefficients D0N and D1N see App. A.3.

Historical Component of Delayed Neutron Source

Calculation of HSD per Eq. (14b) ($k=1$ to 6)

Historical Component of Decay Heat

Calculation of HDH per Eq. (14b) ($k=7$ to 12)

External Reactivity: $RX(N+1)$

Calculation of $RX(N+1) = \rho_x(t_{n+1})$ per smoothed ramp or per worth curve, using the previously calculated coefficients.

Flow Calculation

For TOP and LOHS the flow calculation is skipped and FLN, the flow for the next time step, is set equal to one: $FLN = 1$. The flow calculated for LOF is not included in the GWBASIC program.

After these preparations the program is ready for the calculation of power and temperature changes during the next time step.

3.4.2 The Sequence of Calculations

The sequence of calculations begins with the calculation of the change in core inlet (i.e. cold pool) temperature, $\Delta T_i(t_{n+1})$, which is the basis for the reactivity feedback during Δt_n . The Cold Pool routine also provides the coefficient of a parabolic approximation of ΔT_i for the interval Δt_n . This parabola is needed for the calculation of several convolution integrals yielding changes of temperatures and feedback reactivities.

The calculation proceeds with an iterative treatment of the core problem, i.e. the temperature and reactivity changes, and from it - through solution of the kinetics problem in form of the quadratic dynamics equation - the changes in fission power. These calculations involve the evaluation of the three types of convolution integrals described in Appendix A1.

The recursion formula for the convolution integral $V(t_{n+1})$, derived in Eqs. (9) through (13), is based on the previous value $V(t_n)$. During the iteration of the core equations, Eq. (10) needs to be replaced by an "interim convolution integral":

$$IV(t_{n+1}) = V(t_n) e^{-\lambda \Delta t_n} + \delta V(t_{n+1}) \quad (22)$$

The first term in Eq. (22), the contribution of the previous interval remains the same for all iterative steps, only the second term changes during the iteration. At the end of the iteration, the convolution integrals of the new interval are the "converged" values of the IVs:

$$V(t_{n+1}) = \left[IV(t_{n+1}) \right]_{converged} \quad (23)$$

The IV s are first calculated in Sec. IV.3 "Projected Convolution Integrals and Temperatures." They form the basis for the "Historical Temperature and Feedback" [H_{pf} per Eq. (16a)] components. Then, all terms of the coefficients of the quadratic equation, Eqs. (18), are available and Eqs. (19) yields the fission power, $p_f(t_{n+1}) = \text{FPN}$.

Based on the new fission power, all quantities can now be *calculated* for t_{n+1} , yielding parabolas for this interval. Then, new convolution integrals, $IV(K)$, are calculated, using the complete 3-term parabolas. They replace the first set of IV s that was obtained from extrapolated quantities.

One then enters the previous sequence by calculating a new value of H_{pf} and from it a new fission power. The new FPN is the basis of new convolution integrals and temperatures, etc.

Detailed investigations showed that a single iterative step, just an update, replacing the linear extrapolations by 3-term parabolas, is sufficient for time steps $\leq 16s$. Therefore, the number of iterations (ITMX) has been programmed in, rather than using convergence criteria:

$ITMX = 2$ for $DT \leq 16s$

$ITMX = 3$ for $DT > 16s$

$ITMX = 4$ for $DT > 32s$

$ITMX = 5$ for $DT > 64s$

However, extending DT beyond $32s$ may only lead to "semi-convergence", i.e. nearly converged results will start to diverge.

3.4.3 Numbering of the Parabolas

The coefficients of parabolic approximations are derived in the subroutine "PARABOLA AND NEW SLOPES." They are labeled by an integer M that is set as part of the input to this subroutine. The M -values are listed in Tab. I. They are applied with different λ_k values. The parabola calculation as such is described in App. A3.

TABLE I: Numbering of Parabolas

M	Notation	Quantity
1	FP	fission power
2	DH	decay heat
3	DTO	outlet temperature
4	DTLHP	hot pool sodium temperature
5	DTSHP	hot pool steel temperature
6	DTVHP	hot pool vessel temperature
7	DTOHX	IHX outlet temperature
8	DTI	inlet temperature
9	DTSCP	cold pool steel temperature
10	DTLCP	cold pool vessel temperature
11	DTC	clad temperature
12	DTL	coolant temperature (core)
13	DTLPEFF	effective load-pad temperature

3.4.4 COLD POOL

(Calculation of IHX Outlet and Core Inlet Temperature Changes)

The formulas for the calculation of CP temperatures are based on the general pool equations presented in App. A.5: The CP subroutine it begins with the time $T(N+1) \leq TL$, which is within the first block. Specifically:

For TOP ($TT = 1$) all ΔT_i are zero if $T(N+1) \leq TL$.

For LOHS (and LOF) the values at the end of the first interval are determined from initial slopes times the first moment of the convolution integral:

$$value (N = 2) = slope (N = 1) M_1(\lambda). \quad (24)$$

The calculation of the cold pool involves the convolution integrals V(21) to V(26) which correspond to the temperature changes of the CP-components.

Parabola Base-Time Identification

The beginning of the inlet temperature to the cold pool involves the somewhat complicated identification of the "base-time" for the IHX- outlet parabola, t_B . The complication results from the flow delay, TL ; this requires the use of IHX-inlet temperatures from a previous block, that may have had a different time-step than the present block. The details are presented in

Appendix A3. Together with the base time, special integration limits for the IHX-outlet temperature (*TU* for upper and *LL* for lower limit) are required as *Integration Limits* for calculating the heat-up of the cold pool during the interval Δt_n .

Heat Exchanger Outlet Temperature and Parabola

Based on the HP-temperature parabola, the change in HX outlet temperature, DTOHXN, is determined. Using this and three earlier values, DTOHXO2, DTOHXO1 and DTOHXO, the input for the PARABOLA subroutine is set up; it is executed with the label $M=7$ (see Tab. I).

DTI: Flow, Steel Heat-Up and Vessel Heat-Up Terms

The calculation of a pool sodium temperature has three terms, the *Flow Term* the *Steel Heat-Up Term* and the *Vessel Heat-Up Term*. The flow term is evaluated as a convolution integral of the second type as the integrand is known: V(21). For the two heat-up terms, the driving function, DF and its derivative DDF at the beginning of the interval form the basis for a calculation with a convolution integral of the third type: V(22) and V(24).

DTI: First Calculation and Parabola

The combination of these three convolution integrals give the first calculated value of DTIN. It is used as the outer base point of a DTI parabola, labeled $M=8$ (see Tab. I).

DTSCP and DTVCP : Calculation and Parabola

The availability of the DTI-parabola allows a calculation of the steel (DTSCP) and the vessel (DTVCP) heat-up by convolution integrals of the second type. The corresponding two parabolas are labeled $M=9$ and 10 (see Tab. I).

DTI: Second Calculation

The availability of these three parabolas, $M=8$ to 10, allows a calculation of all three terms of DTI to be carried out in form of a convolution integral of the second kind. This represents an iteration of the DTI calculation; it completes the ΔT_i -calculation.

3.4.5 Projection Based Convolution Integrals and Temperatures

This program section begins with the calculation of the change of the grid plate temperature from the ΔT_i -parabola inserted in the convolution integral $V(15)$. All other convolution integrals in this section are based on linear extrapolations of parabolas of the preverious interval. They include

$IV(13)$, a contribution to DT Fuel calculated from the clad temperature projection ($M=11$),

$IV(14)$, the effective temperature change of the load pad ($M = 13$),

$IV(16)$, the SS-structure temperature change calculated from the coolant temperature projection ($M=12$)

$IV(20)$, a contribution to DT Fuel resulting from decay heat minus P_0 .

Historical Components of Temperatures and Feedback Reactivity

Based on these convolution integrals, the historical temperature and feedback components are calculated, yielding HRF for the quadratic dynamics equation.

3.4.6 CALCULATION OF FISSION POWER

After the calculation of the feedback-reactivity historical component, Eq. (16e), the coefficients of the quadratic dynamics equation are formed and the fission power is calculated from Eq. (19a). If $p_f \equiv |Q/R| < 10^{-4}$, FPN is calculated from Eq. (19b), instead of Eq. (19a).

3.4.7 APPLICATION OF NEW FISSION POWER

Power Temperatures and Convolution Integrals

With the new fission power available, all quantities depending directly on it are recalculated. These are:

- Temperature differences
- Reactivity components, reactivity
- Power, decay heat, delayed neutron source
- Power parabolas and slopes
- Temperature parabolas and slopes
- Convolution integrals for $k=1$ to 16, $k=17$ and 20.

3.4.8 ITERATION CONTROL

After the calculation of the new iterim parabolas, a core iteration step is completed and then program enters "Iteration Control."

If the iteration index ITER is smaller than ITMX a further iteration step is initiated, starting with the application of the new IVs for the calculation of the historical components of temperatures and reactivities.

IF ITER = ITMX, the iteration is completed; the last IV(K) are set to be the V(K) for this interval.

3.4.9 HOT POOL

As the treatment of the core and coolant loop started with the cold pool, based on the IHX-outlet flow and temperature, it commences with the treatment of the hot pool, yielding the input to the intermediate heat exchanger. The subprogram HP is called from here and it returns. The HP-program is completely analogous to the CP routine; see App. A.5. After this, the treatment of the flow loop is completed.

3.4.10 PRINTING OF TIME-STEP N+1

The first line checks if N/NPNT is an integer. If not, the print routine is skipped. The format of the print-out can be seen in the sample problem listed in Appendix C2.

Additional data on power, temperatures and reactivities are printed as files for output after the completion of the run.

3.4.11 RESHUFFLING OF UN-BLOCKED ARRAYS

Only four values are needed for most variables, the three base-points for the recent parabola and the new value. All these short arrays are set back by one to make room for the new value.

*****This completes the N-th Loop*****

3.4.12 RESHUFFLING OF BLOCKED ARRAYS

Only time, HP-temperature and the corresponding parabola are retained as an array through the previous and the present block. After the completion of the "present" block, the arrays are reset to become the previous block.

3.4.13 POST-BLOCK PRINT-OUT

This print-out is described in Sec. 2.1

*****This completes the Block BL Calculation*****

The calculation is completed if $BL = BE$, the end value of BL (see Input Data Part I).

APPENDIX A COMPUTATIONAL DETAILS

APPENDIX A1 : The Three Types of Convolution Integrals

General Expression:
$$V(t_{n+1}) = V(t_n)e^{-\lambda\Delta t_n} + \lambda \int_{t_n}^{t_{n+1}} D(t)e^{-\lambda(t-t_{n+1})} dt \quad . \quad (A1.1)$$

Type 1: Fission power as driving function; parabola through $p_f(t_{n-1})$, $p_f(t_n)$ and $p_f(t_{n+1})$, with $p_f(t_{n+1})$ implicitly assumed. The evaluation of this convolution integral is described in Eqs. (10) through (14).

Type 2: Driving function is known at the three base-points, $DF(t_{n-1})$, $DF(t_n)$ and $DF(t_{n+1})$. A parabolic approximation yields the coefficients d_0 , d_1 and d_2 of

$$DF(t) = d_0 + d_1(t - t_n) + d_2(t - t_n)^2 \quad (A1.2)$$

giving

$$V(t_{n+1}) = V(t_n)e^{-\lambda\Delta t_n} + d_0M_0 + d_1M_1 + d_2M_2 \quad . \quad (A1.3)$$

The moments, M_0 , M_1 and M_2 are given in Eqs. (13).

Type 3: Driving function not known at t_{n+1} , and it cannot be implicitly assumed.

Then, a linear expansion is applied at t_n :

$$DF(t) = DF + DDF(t - t_n) \quad , \quad (A1.4)$$

giving

$$V(t_{n+1}) = V(t_n)e^{-\lambda\Delta t_n} + d_0^*M_0 + DDF^*M_1 \quad . \quad (A1.5)$$

APPENDIX A2 : Limited Ramp Descriptions

Parabolically Smoothed Ramp

Let t_x be the end of the linear ramp at the maximum value ρ_m ($\rho_m = at_x$). The standard formula

$$\rho_x(t) = \begin{cases} at & \text{for } 0 \leq t \leq t_x \\ \rho_m & \text{for } t \geq t_x \end{cases} \quad (\text{A2.1})$$

is replaced by:

$$\rho_x(t) = \begin{cases} at & \text{for } 0 \leq t \leq t_x - \delta t \\ a_o + a_1(t - t_x) + a_2(t - t_x)^2 & \text{for } t_x - \delta t \leq t \leq t_x + \delta t \\ \rho_m & \text{for } t \geq t_x + \delta t \end{cases} \quad (\text{A2.2})$$

The coefficients are given by

$$\begin{aligned} a_o &= \rho_m - \frac{a}{4} \delta t \\ a_1 &= \frac{a}{2} \\ a_2 &= -\frac{a}{4\delta t} \end{aligned} \quad (\text{A2.3})$$

The value of δt is set to be a multiple, DR, times the interval of the first block:

$$\delta t = DR * DT(1) \quad (\text{A2.4})$$

Ramp as Worth-Curve Integral

A control rod, inserted up to the core midplane ($z=0$) is withdrawn with a velocity

$$\dot{z} = v_z \quad , \quad (\text{A2.5})$$

until it reaches an extrapolated half-height $H_x/2$,

$$\frac{1}{2}H_x = \frac{1}{2}H + 20 \text{ cm} \quad . \quad (\text{A2.6})$$

The reactivity insertion is the integral over the reactivity worth curve, $w_p(z)$:

$$\rho_x = \int_0^{z(t)} w_p(z) dz \quad , \quad (\text{A2.7})$$

with

$$w_p(z) = \rho'(0) B_z \cos^2 B_z z \quad , \quad (\text{A2.8})$$

where

$$B_z = \frac{\pi}{H_x} \quad , \quad (\text{A2.9})$$

and

$$\rho'(0) = \frac{4}{\pi} \rho_m \quad . \quad (\text{A2.10})$$

Inserting Eq. (A2.8) in the integral yields

$$\rho_x(t) = \frac{2}{\pi} \rho_m \left[\cos B_z z \sin B_z z + B_z z \right] \quad (\text{A2.11})$$

with

$$B_z z = B_z z(t) = B_z v_z t = \frac{\pi a t}{2 \rho_m} \quad \text{for } B_z z \leq \frac{\pi}{2} \quad (\text{A2.12})$$

Equation (A2.11) starts with $\rho_x(t) = at$ and ends with ρ_m for $B_z z = \frac{\pi}{2}$.

APPENDIX A3 : SUBROUTINE PARABOLA AND NEW SLOPES

Three cases are to be distinguished in calculating the coefficients of the parabolic fit over two intervals with three base-points. They are distinguished by a flag PP:

1. Both intervals are equal (PP = 0)
2. The second interval is twice as large as the first one (PP = 2)
3. The second interval is half of the size of the first one (PP = 1)

After the new time step has been determined, the value of PP is set, depending on the change of the time step. The parabolas with PP = 1 or 2 apply to the first interval of the new time block, if DT(BL) has been changed. From the second interval on, PP = 0, as all intervals within a block are equal.

This subroutine is applied to parabolic approximations of several variables, characterized by the index M, that had been detailed above (Tab. IV). The value of PP is reset to zero, after the last of these parabolas has been calculated for a given interval. This is indicated by PFLAG = 1

or 0. As long as more parabolas are to be calculated, PFLAG = 0. After the last one, PFLAG is set equal to one, which then resets PP to zero.

In addition to the three integers, PP, PFLAG and M, four base points are specified: Y0 for T(N-2), Y1 for T(N-1), Y2 for T(N) and Y3 for T(N+1).

The parabola for a function f(t) has the form

$$f(t) = C_0 + C_1(t - t_B) + C_2(t - t_B)^2, \quad (\text{A3.1})$$

with a base-time, t_B , that is different in the three cases. The coefficients are determined by fitting to three base points, at t_B , at $t_B + DT$ and $t_B + 2DT$, which yields

$$C_0 = f(t_B)$$

$$C_1 = \left[1.5f(t_B) - 2f(t_B + DT) + 0.5f(t_B + 2DT) \right] \frac{1}{DT} \quad (\text{A3.2})$$

$$C_2 = \left[f(t_B) - 2f(t_B + DT) + f(t_B + 2DT) \right] \frac{1}{DT^2}$$

The subroutine applies the following notation:

$$\begin{aligned} PAR(M, 1) &= t_B \\ PAR(M, 2) &= C_0 \\ PAR(M, 3) &= C_1 \\ PAR(M, 4) &= C_2 \end{aligned} \quad (\text{A3.3})$$

The specific formulas for the three cases are:

Case 1:

$$t_B = T(N-1)$$

The fit is based on Y1, Y2 and Y3:

$$C_0 = Y1$$

$$C_1 = -(1.5Y1 - 2Y2 + 0.5Y3) \frac{1}{DT} \quad (\text{A3.4})$$

$$C_2 = (Y1 - 2Y2 + Y3) \frac{1}{2DT^2}$$

Case 2:

$$t_B = T(N-2)$$

The fit is based on Y0, Y2 and Y3:

$$C_0 = Y0 \quad (\text{A3.5})$$

$$C_2 = -(1.5Y0 - 2Y2 + 0.5Y3) \frac{1}{DT}$$

$$C_2 = (Y_0 - 2Y_2 + Y_3) \frac{1}{2DT^2} .$$

Case 3:

$$t_B = T(N) - DT$$

The fit is based on Y_2 , Y_3 and an interpolated earlier value, using the earlier parabola:

$$\begin{aligned} C_0 &= PAR(M,2) + PAR(M,3) - 3DT + PAR(M,Y) - 9DT^2 \\ C_1 &= -(1.5C_0 - 2Y_2 + 0.5Y_3)/DT \\ C_2 &= (C_0 - 2Y_2 + 0.5Y_3)/DT \end{aligned} \quad (A3.6)$$

The application of the parabolas in convolution integrals leads to the moments M_0 , M_1 and M_2 . The forcing-function parabolas in the moments are used as

$$D(t) = d_0 + d_1(t-t_n) + d_2(t-t_n)^2 \quad (A3.7)$$

The d-values are given by

$$\begin{aligned} d_0 &= Y_2 \\ d_1 &= PAR(M,3) + 2PAR(M,4)(t_n - PAR(M,1)) \\ d_2 &= PAR(M,4) \end{aligned} \quad (A3.8)$$

APPENDIX A4 : Base-Time Identification for the Hot Pool Outlet Parabola

The base-time values for the parabolas are given in App. A3. However, the base time for the hot pool temperatures require special considerations, as parabolas for time t in the cold pool input are the ones for the hot pool some TL seconds earlier, i.e. at $T(N+1)-TL$.

Let N_1 be the first N -value below $T(N+1)-TL$. There are three different cases of $t_B = T(NB)$:

- a) $NB = 1$ if $N_1 = 1$
- b) $NB = N_1 - 1$ if $1 < N_1 < N$
- c) $NB = N_1 - 2$ if $N_1 = N$.

APPENDIX A5 : Temperatures of the Pool Components

The temperature calculation is a simplified version of the treatment presented by Cahalan (Ref. 2). It is described here first for a generic pool and then specialized for the two pools of the flow loop model of Fig. 1. The heat transfer equation for the generic pool is

$$C_L \frac{dT_L}{dt} = W_P C_L [T_{in}(t) - T_L(t)] - (hA)_s [T_L(t) - T_s(t)] - (hA)_V^{HP} [T_L(t) - T_V(t)] - P_{DHR} \quad (A5.1)$$

In Eq. (A5.1), the subscripts L and s refer to the (liquid) sodium coolant and the steel; C_L is the sodium heat capacity [Ws/K] and c_L its specific heat [Ws/kgK]; W_P is the primary system flow rate [kg/s] and (hA) the respective steel/coolant convection coefficient [W/K]; T_L is the coolant temperature; T_s and T_V are the pool-internal and vessel steel temperatures respectively; P_{DHR} is the decay heat removal power which applies only to the hot pool.

Dividing Eq. (A5.1) by C_L introduces time constants, λ :

$$\frac{dT_L(t)}{dt} = \lambda_w \left[T_{in}(t) - T_L(t) \right] - r_{sL} \lambda_s \left[T_L(t) - T_s(t) \right] - r_{VL} \lambda_V \left[T_L(t) - T_V(t) \right] - P_{DHR}/C_L, \quad (\text{A5.2})$$

with the flow time constant, λ_w ,

$$\lambda_w = \frac{W_P c_L}{C_L} = \frac{W_P}{M_L} \left[\frac{1}{s} \right], \quad (\text{A5.3})$$

where M_L is the sodium mass in the pool. Furthermore,

$$\lambda_s = \frac{(hA)_s}{C_s} \left[\frac{1}{s} \right] \quad (\text{A5.4a})$$

$$\lambda_V = \frac{(hA)_V}{C_V} \left[\frac{1}{s} \right] \quad (\text{A5.4b})$$

are the time constants of the two steel components of the pool (internal and vessel). The ratios r are given by

$$r_{sL} = C_s/C_L \quad (\text{A5.5a})$$

$$r_{VL} = C_V/C_L \quad (\text{A5.5b})$$

Equation (A5.2) is rewritten by introducing a driving or forcing function, $D_T(t)$,

$$\frac{dT_L(t)}{dt} = -\lambda_w T_L(t) + \lambda_w D_T(t), \quad (\text{A5.6})$$

with $D_T(t)$ being the pool inlet temperature reduced by the effects of the steel heat-up and heat rejection:

$$D_T(t) = T_{in}(t) - r_{sL} \frac{\lambda_s}{\lambda_w} \left[T_L(t) - T_s(t) \right] - r_{VL} \frac{\lambda_V}{\lambda_w} \left[T_L(t) - T_V(t) \right] - \frac{P_{DHR}}{\lambda_w C_L}. \quad (\text{A5.7})$$

Instead of using the temperatures as such, it is more convenient to use increments above the initial stationary state:

$$\begin{aligned}
\delta T_{in}(t) &= T_{in}(t) - T_{in0} \\
\delta T_L(t) &= T_L(t) - T_{L0} \\
\delta T_s(t) &= T_s(t) - T_{s0} \\
\delta T_V(t) &= T_V(t) - T_{V0}
\end{aligned} \tag{A5.8}$$

The initial stationary balance per Eq. (A5.2) is given by

$$0 = \lambda_w \left[T_{in0} - T_{L0} \right] - r_{sL} \lambda_s \left[T_{L0} - T_{s0} \right] - r_{VL} \lambda_V \left[T_{L0} - T_{V0} \right] - \frac{P_{DHR}}{C_L} . \tag{A5.9}$$

Equation (A5.6) assumes then the form

$$\frac{d}{dt} \delta T_L(t) = -\lambda_w \delta T_L(t) + \lambda_w D(t) , \tag{A5.10}$$

where $D(t)$ is the driving function for the *incremental* temperature, δT_L :

$$D(t) = \delta T_{in}(t) - r_{sL} \frac{\lambda_s}{\lambda_w} \left[\delta T_L(t) - \delta T_s(t) \right] - r_{VL} \frac{\lambda_V}{\lambda_w} \left[\delta T_L(t) - \delta T_V(t) \right] . \tag{A5.11}$$

The incremental driving function, $D(t)$, does not contain the P_{DHR} -term any more; as it is assumed to be constant it cancels by subtracting the initial condition, Eq. (A5.9).

The solution of Eq. (A5.10) is a convolution integral

$$\delta T_L(t) = V_L(t) = \lambda_w \int_0^t D(t') e^{-\lambda_w(t-t')} dt' . \tag{A5.12}$$

As $D(t')$ depends on δT_L , Eq. (A5.12) is an implicit solution, which is treated iteratively. It should be noted that for LOF transients the flow rate, W_p , and thus λ_w depend on time. Equation (A5.12) needs then to be generalized as presented in App. A.

The first term, in Eq. (A5.11), $\delta T_{in}(t)$, is available after the temperature calculation in the previous loop component. The steel temperatures in the forcing function, Eq. (A5.11), need to be calculated from their respective balance equations before δT_L can be found from Eq. (A5.12):

$$\frac{d}{dt} \delta T_s(t) = -\lambda_s \delta T_s(t) + \lambda_s \delta T_L(t) \tag{A5.13a}$$

$$\frac{d}{dt} \delta T_V(t) = -\lambda_V \delta T_V(t) + \lambda_V \left[\delta T_L(t) - \frac{\delta P_V(t)}{\lambda_V C_V} \right] . \tag{A5.13b}$$

An extrapolated value for δT_L is used in Eqs. (A5.13). The solutions are given by

$$\delta T_s(t) = V_s(t) = \lambda_s \int_0^t \delta T_L(t') e^{-\lambda_s(t-t')} dt' \quad (\text{A5.14a})$$

$$\delta T_V(t) = V_V(t) = \lambda_V \int_0^t \left[\delta T_L(t') - \frac{\delta P_V(t')}{\lambda_V C_V} \right] e^{-\lambda_V(t-t')} dt' \quad , \quad (\text{A.14b})$$

with

$$\delta P_V(t) = P_V(t) - P_{V_0} \quad . \quad (\text{A5.15})$$

Equations (A5.12) through (A5.15) are solved "iteratively" in the LTC program; a single iterative step appears to yield sufficient accuracy as all temperatures are slowly varying functions within a time-step: δT_s and δT_V are extrapolated linearly through the interval t_n to t_{n+1} , using parabolic approximations up to t_n based on the three recent values. Equation (A5.12) then yields a first iterate of δT_L , which is inserted in Eqs. (A5.14). The calculated values of δT_s and δT_V at t_{n+1} are then applied as base points for determining a forcing function parabola from t_{n-1} through t_{n+1} , from which the second iterate of δT_L is calculated. Equations (A5.14) then yield the "updated" steel temperature changes.

APPENDIX B : GW-BASIC Listing of LTC

```

50      *****
52      *****
54      **                                     **
56      **                               LTC                               **
58      **                                     **
60      **   LMR TRANSIENT CALCULATION PROGRAM   **
62      **                                     **
64      *****
66      *****
68      *                                VERSION    3                                *
70      *****
72      *                                SEPTEMBER 1991                                *
76      *****
84
86      ::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::
88
94      *****
96      *****
98      *                                     *
100     *           INFORMATION    AND    INPUT           *
102     *                                     *
104     *****
106     *****
108
110     '----- INFORMATION -----'
112     '-----'
114 REM: TRANSIENT TYPES : TOP=TRANSIENT OVER-POWER
116 REM:                      LOHS=LOSS OF HEAT SINK
118 REM:                      LOF=LOSS OF FLOW(NOT AVAILABLE IN THIS VERSION)
120 '
122 REM: TOP REACTIVITY INSERTION : RAMP INSERTION OR WORTH CURVE
124 '
132 REM: FISSION POWER IS CALCULATED FROM QUADRATIC DYNAMICS EQUATION
134 '
146 ' ::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::
148 '
150 GOTO 200 '>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>'
152 '
158 '----- ARRAY DECLARATION -----'
160 '
162 DIM BT(32),L(32),FBS(32,4),AP(32),AH(32)
164 DIM V(32),IV(32),EX(32),MO(32),BX(32),M1(32),M2(32),LDT(32)
166 DIM DT(20),NO(20),NE(20)
168 DIM PAR(13,4),D0(13),D1(13),D2(13),SLP(13),DON(13),D1N(13),PARLHP(161,4)
170 DIM IDON(13),ID1N(13),DTLHP(161),T(161)
172 DIM TRAC(12),QRAC(12),TLF(18),QLF(18)
174 GOTO 238 '>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>'
176 ' ::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::::
178 '
200 '----- INPUT MENU -----'
202 '
204 KEY 6,"RUN 216"+CHR$(13)
206 KEY 7,"RUN 220"+CHR$(13)
208 KEY 8,"RUN 224"+CHR$(13)
210 KEY 9,"RUN 160"+CHR$(13)
212 GOSUB 228
214 LIST 238-276 'INPUT I
216 GOSUB 228
218 LIST 280-318 'INPUT II
220 GOSUB 228

```

```

222 LIST 322-358 'INPUT III
224 GOSUB 228
226 LIST 362-396 'INPUT IV
228 CLS
230 PRINT"      INPUT DATA:: F2: PART I; F6: PART II; F7: PART III"
232 PRINT"                  F8: PART IV;      F9 : EXECUTE PROGRAM"
234 RETURN
236 '.....
238 '===== INPUT DATA PART I =====
240 REM:  I.  TRANSIENT TYPE :
242      TT = 1      '1=TOP, 2=LOHS, 3=LOF(NOT WORKING)
244 REM:  II. TIME STRUCTURE :
246      DT(1) = 2   'TIME STEP SIZE (SEC) OF FIRST BLOCK
248      NM = 80     '# OF TIME STEPS PER BLOCK
250      BE = 6      '# OF BLOCKS
252      LDB =.01    'RELATIVE-POWER-CHANGE LIMIT FOR DT(BL)-DOUBLING
254      LHA =.02    'RELATIVE-POWER-CHANGE LIMIT FOR DT(BL)-HALVING
256      MAXDT = 16  'MAXIMUM STEP SIZE (SEC)
258 REM:  III. REACTIVITY INSERTION :
260      RG = 1      '1=RAMP, 2=WORTH-CURVE
262      A = .02     'RAMP INSERTION RATE
264      RM =1.2     'END-POINT REACTIVITY OF RAMP
266      DR = 1      'DURATION OF PARABOLIC RAMP SMOOTHING
268      'END-POINT OF RAMP +/- DR*DT
270      H = 90      'CORE HEIGHT (CM)
272 REM:  IV. OTHER QUANTITIES :
274      PO = 1      'INITIAL POWER RELATIVE TO NOMINAL POWER
276      TL = 24     'FLOW-TIME CORE-OUTLET TO IHX-OUTLET (SEC)
278 '.....
280 '===== INPUT DATA PART II =====
282 REM:  V.  OTHER QUANTITIES : (FP=FULL POWER; FPS=FP SECONDS)
284      DHR =.0036   'DECAY HEAT REMOVAL FROM HOT POOL (FP)
286      BH =.0587    'INITIAL DECAY HEAT FRACTION (FP)
288      SSP =1.11E-11'SPONTANEOUS FISSION SOURCE (FP)
290      ARVHP= 110   'HOT POOL VESSEL AREA (M**2)
292      ARVCP= 190   'COLD POOL VESSEL AREA (M**2)
294      CLHP = .4613 'HOT POOL SODIUM HEAT CAPACITY (FPS)
296      CLCP = .5089 'COLD POOL SODIUM HEAT CAPACITY (FPS)
298      CSHP = .2188 'HOT POOL STEEL HEAT CAPACITY (FPS)
300      CSCP = .5422 'COLD POOL STEEL HEAT CAPACITY (FPS)
302      CVHP = .0083 'HOT POOL VESSEL HEAT CAPACITY (FPS)
304      CVCP = .0205 'COLD POOL VESSEL HEAT CAPACITY (FPS)
306      CCOR = .00762 'CORE HEAT CAPACITY (FPS)
308      CFUL = .00271 'FUEL HEAT CAPACITY (FPS)
310      DTCOOL=152.76 'NOMINAL COOLANT TEMPERATURE RISE (K)
312      DTFCO= 89.56 'NOMINAL FUEL/CLAD TEMPERATURE RISE (K)
314      TVCP0= 630.56 'INITIAL COLD POOL SODIUM TEMPERATURE (K)
316      TVHP0= 783.33 'INITIAL HOT POOL SODIUM TEMPERATURE (K)
320 '.....
322 '===== INPUT DATA PART III =====
324 REM: BETA , BT(1) TO BT(6), DELAYED NEUTRONS
326 DATA .00826,.07248,.06336,.12134,.05513,.01773
328 REM: BETA , BT(7) TO BT(12), DECAY HEAT
330 DATA 1.6232,2.094,1.163,.5523,.0852,.3521
332 REM: BETA , BT(13) TO BT(21), FEEDBACK (INDEX NOT CORRESPONDIG TO LAMDA)
334 DATA -.0981,-0.1432,+.1715,-.1184,-.1184,-.1110,+.062 ,+.062,78.9
340 REM: LAMDA, L(1) TO L(6), DELAYED NEUTRONS
342 DATA .01298,.03137,.1354,.3457,1.369,3.7376
344 REM: LAMDA, L(7) TO L(12), DECAY HEAT
346 DATA .1985,.01437,.000360,.0000762,.00000973,.000000888

```

```

348 REM: LAMDA, L(13) TO L(20), FEEDBACK (INDEX NOT CORRESPONDING TO BETA)
350 DATA 4.108,2.00 ,.0092 ,3.975 ,4.108 ,0.041, 4.108,4.108
352 REM: LAMDA, L(21) TO L(32), FLOW LOOP
354 DATA .01282,.01282,.001025,.01282,.00085,0.01282,0.01415,0.01415,.01016,0.01
415,.00085,0.01415
356 REM: SPECIAL LAMBDA VALUES
358 DATA 18.09,4.725,6.613,13.66,44.51
360 '.....
362 '===== INPUT DATA PART IV =====
364 REM: TEMPERATURES FOR RACS HEAT-FLUX CORRELATION
366 DATA 433.,495.7,577.8,681.6,753.6,810.2,857.5,898.4,951.5,1025.,1086.,1139.
368 REM: RACS HEAT FLUXES
370 DATA 5.0E-7,1.0E-6,2.0E-6,4.0E-6,6.0E-6,8.0E-6,1.0E-5,1.2E-5,1.5E-5,2.0E-5,2
.5E-5,3.0E-5
372 REM: TIMES FOR STEAM GENERATOR HEAT-FLUX CORRELATION
374 DATA 0,2,4,6,8,10,12,14,16,18,20,25,30,35,40,45,50,55
376 REM: STEAM GENERATOR HEAT FLUXES
378 DATA 1,.368,.195,.122,.084,.062,.047,.038,.031,.026,.022,.015,.011,.009,.007
,.006,.005,0
380 '.....
382 PR = 1 ' NOMINAL HEAT REJECTION (FP)
384 TLOF = 6 ' CHARACTERISTIC TIME FOR FLOW LOSS IN LOF (SEC)
386 TLOHS = 82 ' TIME FOR SG LOOSING HEAT FLUX IN LOHS (SEC)
388 NPNT = 4 ' PRINT EVERY NPNT STEP
390 INED = .1 ' 1=ENABLE INPUT EDIT; 0=NO EDIT; 0.1=ONLY HEADING
392 STUCK = 0 ' STUCK=0 IF FUEL FREE TO EXPAND
394 PI = 3.141592654#
396 '.....
420 '===== READ INPUT =====
422 FOR K=1 TO 21
424 READ BT(K)
426 NEXT K
428 FOR K=1 TO 32
430 READ L(K)
432 NEXT K
442 FOR K=1 TO 5
444 READ SLAMBDA(K)
446 NEXT K
450 RSLHP=CSHP/CLHP
452 RSLCP=CSCP/CLCP
454 RVLHP=CVHP/CLHP
456 RVLCP=CVCP/CLCP
458 RSLCP=CSCP/CLCP
460 FOR I=1 TO 12
462 READ TRAC(I)
464 NEXT I
466 FOR I=1 TO 12
468 READ QRAC(I)
470 NEXT I
472 FOR I=1 TO 18
474 READ TLF(I)
476 NEXT I
478 FOR I=1 TO 8
480 READ QLF(I)
482 NEXT I
484 IF TT<>1 THEN A=0 : RM=0
492 '.....
494 BS=DT(1)*NM: REM: BLOCK SIZE OF FIRST BLOCK
496 IF BS<TL AND BE>1 THEN BEEP:PRINT"BLOCK SIZE TOO SMALL!":STOP
498 '

```

```

500 '===== INPUT EDIT =====
502 '
504 IF INED=0 GOTO 800 : REM: SCIP INPUT EDIT ENTIRELY
506 '
508 LPRINT"*****-- VERSION LTC-3 --*****"
510 DDS=DATES
511 TMS=TIMES
512 IF TT=1 THEN LPRINT"          "DD$"          TOP          "TMS"
514 IF TT=2 THEN LPRINT"          "DD$"          LOHS          "TMS"
516 IF INED=.1 GOTO 800 : REM: SCIP REMAINING INPUT EDIT
518 '
520 LPRINT"=====EDIT OF INPUT DATA=====
522 LPRINT
524 LPRINT"TT=TRANSIENT TYPE, 1:TOP ; 2:LOHS ; 3:LOF....."TT
526 LPRINT"DT(1)=TIME STEP SIZE OF FIRST BLOCK (SECONDS)....."DT(1)
528 LPRINT"MAXDT=MAXIMUM STEP SIZE (SECONDS)....."MAXDT
530 LPRINT"NM=NUMBER OF TIME STEPS PER BLOCK....."NM
532 LPRINT"BE=NUMBER OF BLOCKS....."BE
534 LPRINT"LOB=REL. POWER-CHANGE LIMIT FOR DT(BL)-DOUBLING....."LDB
536 LPRINT"LHA=REL. POWER-CHANGE LIMIT FOR DT(BL)-HALVING....."LHA
602 LPRINT"RG=OPTION OF EXTERNAL REACTIVITY, 1:RAMP ; 2:WORTH CURVE....."RG
604 LPRINT"A=INPUT RAMP RATE ($/S)....."A
606 LPRINT"RM=MAXIMUM RAMP REACTIVITY ($)....."RM
608 LPRINT"DR=DURATION OF PARABOLIC RAMP SMOOTHING (+/- DR*DT(1))....."DR
610 LPRINT"H=CORE HEIGHT (CM)....."H
614 LPRINT"TL=FLOW DELAY BETWEEN OUTLET AND INLET (SECONDS)....."TL
616 LPRINT"BH=INITIAL DECAY HEAT FRACTION OF TOTAL POWER....."BH
618 LPRINT"PR=HEAT REJECTION RATE (FULL POWER)....."PR
620 LPRINT"ARVHP=HOT POOL VESSEL AREA (M**2)....."ARVHP
622 LPRINT"ARVCP=COLD POOL VESSEL AREA (M**2)....."ARVCP
624 LPRINT"DHR=DECAY HEAD REMOVAL (FULL POWER)....."DHR
626 LPRINT"DTCOOL 'NOMINAL COOLANT' TEMPERATURE RISE ALONG CHANNEL....."DTCOOL
628 LPRINT"NPNT=PRINT EVERY NPNT STEP....."NPNT
630 LPRINT"TLOF=CHARACTERISTIC TIME FOR FLOW LOSS in LOF (SEC)....."TLOF
632 LPRINT"TLHS=TIME FOR SG LOSING HEAT FLUX IN LOHS (SEC)....."TLHS
634 LPRINT"SSP=SPONTANEOUS FISSION SOURCE....."SSP
636 LPRINT
638 LPRINT"          K          BT(K)          L(K)          "
640 FOR K=1 TO 32
642 FBS(K,1)="          "+STR$(K)
644 FBS(K,2)=STR$(BT(K))
646 FBS(K,3)=STR$(L(K))
648 IF K<=6 THEN FBS(K,4)=" DELAYED NEUTRON"
650 IF K>6 AND K<=12 THEN FBS(K,4)=" DECAY HEAT"
652 IF K>12 AND K<=20 THEN FBS(K,4)=" FEEDBACK(NOTE#2)"
654 IF K>20 AND K<=26 THEN FBS(K,4)=" FLOW COLD-POOL"
656 IF K=23 THEN FBS(K,4)=" STEEL COLD-POOL"
658 IF K=25 THEN FBS(K,4)=" VESSEL COLD-POOL"
660 IF K>26 THEN FBS(K,4)=" FLOW HOT-POOL"
662 IF K=29 THEN FBS(K,4)=" STEEL HOT-POOL"
664 IF K=31 THEN FBS(K,4)=" VESSEL HOT-POOL"
666 LPRINT USING"\          \";FBS(K,1),FBS(K,2),FBS(K,3),FBS(K,4)
668 NEXT K
670 LPRINT
672 LPRINT"NOTE#1 : BT(K)=BT(K)/100          FOR DELAYED NEUTRONS"
674 LPRINT"          BT(K)=BT(K)/100/(1-BH)          FOR DECAY HEAT"
676 LPRINT
678 FOR K=13 TO 20
680 FBS(K-12,1)=STR$(BT(K))

```

```

682 FBS(K-12,2)=STR$(L(K))
684 NEXT K
686 LPRINT
688 LPRINT"NOTE#2 : INDIVIDUAL FEEDBACK COEFFICIENTS & TIME CONSTANTS : "
690 LPRINT
692 LPRINT"--DRIVING FORCE---DELAY LOCATION---TIME CONSTANT-----"
694 LPRINT USING"\          \";"CLAD -TEMP "," FUEL ROD ",FB$(1,2)
696 LPRINT USING"\          \";"OUTLET-TEMP"," LOAD PAD ",FB$(2,2)
700 LPRINT USING"\          \";"INLET-TEMP"," GRID PLATE",FB$(3,2)
702 LPRINT USING"\          \";"COOLANT  "," STRUCTURE ",FB$(4,2)
704 LPRINT USING"\          \";"FISSION POWER","FUEL ROD",FB$(5,2)
708 LPRINT USING"\          \";"HP-TEMP  "," CR-DRIVE  ",FB$(6,2)
710 LPRINT
712 LPRINT
714 LPRINT"----- INDIVIDUAL FEEDBACK COEFFICIENTS: BT(K) -----"
716 LPRINT"DOPPLER ..... "BT(13)
718 LPRINT"AXIAL EXPANSION ..... "BT(14)
720 LPRINT"COOLANT EXPANSION ..... "BT(15)
722 LPRINT" 100*XMC/XAC ..... "BT(16)
724 LPRINT"GRID PLATE EXPANSION ..... "BT(17)
726 LPRINT"CR-DRIVE-LINE EXPANSION ..... "BT(18)
728 LPRINT"HOT POOL VESSEL EXPANSION..... "BT(19)
730 LPRINT"COLD POOL VESSEL EXPANSION..... "BT(20)
732 LPRINT
734 LPRINT
736 LPRINT
738 LPRINT
740 LPRINT"----- HEAT CAPACITIES -----"
742 LPRINT"CLHP=HEAT CAPACITY OF HOT-POOL SODIUM (FPS/K)....."CLHP
744 LPRINT"CLCP=HEAT CAPACITY OF COLD-POOL SODIUM (FPS/K)....."CLCP
746 LPRINT"CSHP=HEAT CAPACITY OF HOT-POOL STEEL (FPS/K)....."CSHP
748 LPRINT"CSCP=HEAT CAPACITY OF COLD-POOL STEEL (FPS/K)....."CSCP
750 LPRINT"CVHP=HEAT CAPACITY OF HOT-POOL VESSEL (FPS/K)....."CVHP
752 LPRINT"CVCP=HEAT CAPACITY OF COLD-POOL VESSEL (FPS/K)....."CVCP
754 LPRINT CHR$(6)
756 '::::::::::::::::::::-- END INPUT DATA AND EDIT --::::::::::::::::::::
758 '
760 '
800 '=====-- LAMBDA AND BETA COMBINATIONS =====
802 '
804 LC =SLAMBDA(1) + SLAMBDA(2)
806 LCF=SLAMBDA(2)/LC
808 LCL=SLAMBDA(1)/LC
810 '
812 FLN=1 '----- TOP AND LOHS -----
814 LL =SLAMBDA(5) + SLAMBDA(3) + SLAMBDA(4)*FLN
816 LLC=SLAMBDA(5)/LL
818 LLS=SLAMBDA(3)/LL
820 LLI=SLAMBDA(4)/LL
822 LLL=1/(1-LLC*LCL)
824 TLO=.5*DTCOOL*SLAMBDA(4)/LL '-----TAU-0 -----
826 '
830 '
896 ':::::::::::::::::::: END INFORMATION AND INPUT ::::::::::::::::::
988 '
990 ' *****
992 ' *****
994 ' *
996 ' * INITIAL VALUES AND GENERAL PREPARATIONS *
998 ' *

```



```

1000 ' *****
1002 ' *****
1004 '
1006 '=====-- INITIAL VALUES & SLOPES -----
1008 '
1010 '----- TIME -----
1012 BL=1
1014 N=1
1016 T(1)=0
1018 '----- POWER -----
1020 P0=P0 'INITIAL POWER (INPUT)
1022 FP0=P0*(1-BH) : DON(1)=FP0 'FISSION POWER
1024 FPD=FP0*A : D1N(1)=FPD 'FISSION POWER DERIVATIVE
1026 PTD=FPD 'TOTAL POWER DERIVATIVE
1028 '----- FLOW -----
1030 FLO=1 'INITIAL FLOW
1036 '----- DELAYED NEUTRONS -----
1038 B = 0
1040 FOR K= 1 TO 6
1042 BT(K)=BT(K)/100
1044 B=B+BT(K)
1046 V(K)=FP0 'CONVOLUTION INTEGRALS, K=1 TO 6
1048 NEXT K
1050 SD=B*FP0 'DELAYED NEUTRON SOURCE (NO DERIVATIVE)
1052 '----- DECAY HEAT -----
1054 FOR K= 7 TO 12
1056 BT(K)=BT(K)/100/(1-BH)
1058 V(K)=FP0 'CONVOLUTION INTEGRALS, K=7 TO 12
1060 NEXT K
1062 DH0=P0*BH : DON(2)=DH0 'DECAY HEAT
1064 DHD=0 : D1N(2)=DHD 'DECAY HEAT DERIVATIVE
1070 '----- FEEDBACK REACTIVITY -----
1072 FOR K= 13 TO 21
1074 BT(K)=BT(K)/100
1076 V(K)=0 'CONVOLUTION INTEGRALS
1078 NEXT K
1090 '----- TEMPERATURES -----
1092 DTIO=0 : DON(8)=0 : DDTIO=0 : D1N(8)=0 ' INLET
1094 DTO0=0 : DON(3)=0 : DDTO0=0 : D1N(3)=0 ' OUTLET
1096 DTF0=0 : DDTF0=0 ' FUEL
1098 DTC0=0 : DON(11)=0 : DDTC0=0 : D1N(11)=0 ' CLAD
1100 DTL0=0 : DON(12)=0 : DDTL0=0 : D1N(12)=0 ' COOLANT
1102 DTOHX0=0 : DON(7)=0 : DDTOHX0=0 : D1N(7)=0 ' HX-OUTLET
1104 DTSCP0=0 : DON(9)=0 : DDTSCP0=0 : D1N(9)=0 ' SS COLD POOL
1106 DTLHP0=0 : DON(4)=0 : DDTLHP0=0 : D1N(4)=0 ' SODIUM HOT POOL
1108 DTSHPO=0 : DON(5)=0 : DDTSHPO=0 : D1N(5)=0 ' SS HOT POOL
1110 DTVHP0=0 : DON(6)=0 : DDTVHP0=0 : D1N(6)=0 ' VESSEL HOT POOL
1112 DTVCP0=0 : DON(10)=0 : DDTVCP0=0 : D1N(10)=0 ' VESSEL COLD POOL
1114 TVHP=TVHP0 : TVCP=TVCP0 ' VESSELS
1116 '
1118 '.....
1120 '
1122 FOR M=1 TO 13
1124 D0(M)=DON(M) : IDON(M)=DON(M)
1126 D1(M)=D1N(M) : ID1N(M)=D1N(M)
1128 NEXT M
1130 '.....
1132 '
1136 '----- HEAT REJECTION -----
1138 '

```

[illegible]

```

1302 OPT=1-PRVHP-PRVCP-DHR
1304 GOTO 1700 '>>>>>>>>>>>>>>> CONTROL OF POWER CALCULATION >>>>>>>>>>>>>>>'
1306 '.....'
1400 '*****----- LOF -----*****'
1402 OPT=0
1404 GOTO 1700 '>>>>>>>>>>>>>>> CONTROL OF POWER CALCULATION >>>>>>>>>>>>>>>'
1406 '.....'
1408 '
1410 ':::::::::::: END OF INITIAL VALUES AND GENERAL PREPARATIONS ::::::::::::'
1490 '
1494 '          *****
1496 '          *****
1498 '          *
1700 '          " CONTROL OF BLOCKWISE POWER CALCULATION "
1702 '          *
1704 '          *****
1706 '          *****
1710 '
1720 '=====-- INITIALIZATION --=====
1722 NO(1)=1
1724 NE(1)=NM
1726 PP=0
1728 TSTART = TIMER : TELAP = 0
1730 '.....'
1732 '
1734 FOR BL=1 TO BE '***** START OF BLOCK BL LOOP *****'
1736 '
1738 IF BL=1 GOTO 1800
1748 '=====-- NEW TIME STEP, NO & NE =====
1754 IF MAXD < LDB THEN DT(BL)=2*DT(BL-1)
1756 IF MAXD > LHA THEN DT(BL)=.5*DT(BL-1)
1758 IF DT(BL)*NM < TL OR DT(BL) > MAXDT THEN DT(BL)=DT(BL-1)
1760 LPRINT " BLOCK #"BL;" MAXD OF PREVIOUS BLOCK="MAXD;" THUS NEW DT="DT(BL)
1762 PRINT#1,"BLOCK "BL : PRINT#2,"BLOCK "BL
1764 NO(BL)=NM+1
1766 NE(BL)=2*NM
1768 IF DT(BL)/DT(BL-1)=2 THEN PP=2
1770 IF DT(BL-1)/DT(BL)=2 THEN PP=1
1772 '.....'
1800 '=====-- BLOCK BL COEFFICIENTS -----'
1802 '
1804 '----- GENERAL COEFFICIENTS -----
1806 AAP=1/DT(BL)/DT(BL)
1808 '
1810 FOR K = 1 TO 32
1812 LDT(K)=L(K)*DT(BL)
1814 EX(K)=EXP(-LDT(K))
1816 M0(K)=1-EX(K)
1818 BX(K)=BT(K)*EX(K)
1820 M1(K)=DT(BL)-M0(K)/L(K)
1822 M1AS=LDT(K)*DT(BL)/2
1824 IF M1(K)>M1AS THEN M1(K)=M1AS
1826 IF M1(K)<0 THEN M1(K)=M1AS
1828 M2(K)=DT(BL)*DT(BL)-2*M1(K)/L(K)
1830 M2AS=LDT(K)*DT(BL)*DT(BL)/3
1832 IF M2(K)>M2AS THEN M2(K)=M2AS
1834 IF M2(K)<0 THEN M2(K)=M2AS
1836 AP(K)=M2(K)*AAP
1838 NEXT K
1840 '----- TEMPERATURE COMPONENTS -----

```

```

1842 DTFF=DTFC0*AP(17)
1844 DTCP=DTFF*LCF*LLL
1846 DTLP=DTCP*LLC
1850 '----- DELAYED NEUTRON COEFFICIENTS -----
1852 PSD = 0 : MSD = 0 : DSD = 0
1854 FOR K= 1 TO 6
1856 PSD=PSD+BT(K)*M2(K)
1858 MSD=MSD+BT(K)*M1(K)
1860 DSD=DSD+BT(K)*M0(K)
1862 NEXT K
1864 PSD=PSD*AAP
1866 '----- DECAY HEAT COEFFICIENTS -----
1868 PDH = 0 : MDH = 0 : DDH = 0
1870 FOR K= 7 TO 12
1872 PDH=PDH+BT(K)*M2(K)
1874 MDH=MDH+BT(K)*M1(K)
1876 DDH=DDH+BT(K)*M0(K)
1878 NEXT K
1880 PDH=PDH*AAP
1882 '----- PROMPT FEEDBACK COMPONENT -----
1884 PRF=BT(13)*DTFF+BT(14)*((1-STUCK)*DTFF+STUCK*DTCP)+BT(15)*DTLP
1886 '.....
1894 MAXD=0
1898 '::::::::: END OF CONTROL OF BLOCKWISE POWER CALCULATION :::::::::::
1900 '
1950 ' *****
1952 ' *****
1954 ' *
1956 ' * POWER CALCULATION FOR GENERAL TIME STEP IN BLOCK BL *
1958 ' *
1960 ' *****
1962 ' *****
1964 '
1970 FOR N=N0(BL) TO NE(BL)' *** START OF TIME STEP LOOP ***
1972 '
1974 '===== PREPARATIONS FOR TIME STEP N+1 =====
1978 T(N+1)=T(N)+DT(BL)
1980 FPX=DON(1)+D1N(1)*DT(BL)
1982 AAH=-FPX*AAP
1984 AH(17)=V(17)*EX(17)+DON(1)*M0(17)+D1N(1)*M1(17)+AAH*M2(17)
1990 '.....
1992 '----- HISTORICAL COMPONENT OF DELAYED NEUTRON SOURCE -----
1994 HSD=0
1996 FOR K=1 TO 6
1998 HSD=HSD+V(K)*BX(K)
2000 NEXT K
2002 HSD=HSD+FPO*DSD+FPD*MSD-FPX*PSD
2004 '.....
2010 '----- HISTORICAL COMPONENT OF DECAY HEAT -----
2012 HDH=0
2014 FOR K=7 TO 12
2016 HDH=HDH+V(K)*BX(K)
2018 NEXT K
2020 HDH=HDH+FPO*DDH+FPD*MDH-FPX*PDH
2022 '.....
2028 '----- EXTERNAL REACTIVITY: RX(N+1) -----
2030 IF TT>1 THEN RX=0 : GOTO 2070
2032 IF RG=1 THEN 2036 :REM: RAMP
2034 IF RG=2 THEN 2052 :REM: WORTH CURVE
2036 ' RHO-X SMOOTHED RAMP

```

[illegible]

```

2232 RLP=BT(17)*DTLPEFF
2234 HRF=BT(13)*DTFH+BT(14)*((1-STUCK)*DTFH+STUCK*DTCH)+BT(15)*DTLH+RLP+BT(17)*D
TGP+RCR
2236 '.....
2250 '----- CALCULATION OF FISSION POWER -----
2252 '
2254 '----- QUADRATIC EQUATION -----
2258 Q=(HSD+SSP)/PRF/B
2260 RR=(1-RX-HRF-PSD/B)/PRF
2262 FPN=(RR+SQR(RR*RR-4*Q))/2
2264 IF ABS(Q/RR) < .0001 THEN FPN=(Q+(Q/RR)^2)/RR
2266 '.....
2268 '----- APPLICATION OF NEW FISSION POWER -----
2270 '----- DELTA-TEMPERATURE -----
2272 DTIN=DTIN
2274 DTFN=DTFH+DTFP*FPN
2276 DTS =DTS
2278 DTLN=DTLH+DTLP*FPN
2280 DTCN=DTCH+DTCP*FPN
2282 DTON=DTIN + 2*(DTLN-DTIN)
2284 DTLPEFF=DTLPEFF
2286 DTGP=DTGP
2288 '.....
2300 '----- FEEDBACK REACTIVITIES -----
2304 RDOP=BT(13)*DTFN
2306 RAX =BT(14)*((1-STUCK)*DTFN + STUCK*DTCN)
2308 RCOL=BT(15)*DTLN
2310 RLP =BT(17)*DTLPEFF
2312 RGP =BT(17)*DTGP
2314 RRAD=RLP+RGP
2316 RCR =RCR
2318 'RCR IS CALCULATED IN "HOT POOL (4718)"
2320 'RCR INCLUDES VESSEL EXPANSION
2330 '----- TOTAL RECTIVITY -----
2332 RF=RDOP+RAX+RCOL+RRAD+RCR
2334 RO=RX+RF
2336 '.....
2360 '----- POWER TERMS -----
2362 FPN=FPN
2364 DHN=PDH*FPN+HDH
2366 PN=FPN+DHN
2370 SD=PSD*FPN+HSD
2372 '.....
2380 '----- POWER PARABOLAS AND SLOPES -----
2384 'THE Y0-Y2-VALUES ARE NOT USED FOR N=1
2386 'THE Y2 & Y3-SETTINGS ARE OK FOR N=1, ALTHOUGH ONLY Y3 IS USED
2388 'FOR N=2: Y2 & Y3 ARE TURNED INTO Y1 & Y2, Y3= NEW VALUE
2390 'Y0 IS NOT USED FOR N=2
2392 '
2394 M=1 : PFLAG=0
2396 Y0=FPO2 : Y1=FPO1 : Y2=FPO : Y3=FPN
2398 GOSUB 3100
2400 '
2402 M=2 : PFLAG=0
2404 Y0=DHO2 : Y1=DHO1 : Y2=DHO : Y3=DHN
2406 GOSUB 3100
2408 '.....
2420 '----- TEMPERATURE PARABOLAS AND SLOPES -----
2424 M=3 : PFLAG=0
2426 Y0=DTOO2 : Y1=DTOO1 : Y2=DTOO : Y3=DTON

```

[illegible]

```

2652 '
2654 IF N=NM AND BL=BE THEN 3042 '>>>>!!!!!!!!!!!!!! END !!!!!!!!!!!!!!!!'
2656 '
2700 '----- MAXIMUM RELATIVE POWER CHANGE -----'
2702 DPO=ABS((PN-PO)/PN)
2706 IF DPO>MAXD THEN MAXD=DPO
2708 '.....'
2770 '----- PREPARATION FOR NEXT N -----'
2780 '----- RESHUFFLING OF UN-BLOCKED ARRAYS -----'
2782 FPO2=FPO1 : FPO1=FPO : FPO=FPN
2784 PO2 =PO1 : PO1 =PO : PO= PN
2786 FLO2=FLO1 : FLO1=FLO : FLO=TLN
2790 DHO2=DHO1 : DHO1=DHO : DHO=DHN
2792 DTIO2=DTIO1 : DTIO1=DTIO : DTIO=DTIN
2794 DTOO2=DTOO1 : DTOO1=DTOO : DTOO=DTON
2796 DTFO2=DTFO1 : DTFO1=DTFO : DTFO=DTFN
2798 DTLO2=DTLO1 : DTLO1=DTLO : DTLO=DTLN
2800 DTCO2=DTCO1 : DTCO1=DTCO : DTCO=DTCN
2802 DTOHXO2=DTOHXO1 : DTOHXO1=DTOHXO : DTOHXO=DTOHXN
2804 DTSCPO2=DTSCPO1 : DTSCPO1=DTSCPO : DTSCPO=DTSCPN
2806 DTSHPO2=DTSHPO1 : DTSHPO1=DTSHPO : DTSHPO=DTSHPN
2808 DTVCP O2=DTVCP O1 : DTVCP O1=DTVCP O : DTVCP O=DTVCP N
2810 DTVHP O2=DTVHP O1 : DTVHP O1=DTVHP O : DTVHP O=DTVHP N
2812 NEXT N
2814 ':::::::::::::::::::-- END OF N-TH LOOP --:::::::::::::::::::'
2816 GOTO 2850 '>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>>'
2818 '::::::::::::::::::::'
2820 '----- SURROUTINE: PRINTING OF TIME-STEP N+1 -----'
2822 '
2824 IF N/NPNT-INT(N/NPNT)<>0! THEN 2844:REM:PRINT EVERY NPNT STEPS
2826 REM:-----CONVERSION OF SECONDS INTO MINUTES.SECONDS-----'
2828 MM=INT(T(N+1)/60+.00001)
2830 TS=T(N+1)-60*MM
2832 TM=MM+TS/100+.00001
2834 LPRINT USING "#####.###";TM,100*PN,100*DHN,DTON,DTLHP(N+1),DTOHXN,DTIN,100*RO
,100*R X ,100*R F
2835 PRINT USING "#####.###";TM,100*PN,100*DHN,DTON,DTLHP(N+1),DTOHXN,DTIN,100*RO
,100*R X ,100*R F
2838 PR I NT#1,US I NG "#####.###";T(N+1),DTF N ,D TC N ,D TLN ,D TS ,D TCR ,D TO N ,D TL HP (N +1 ) ,D TO H
X N ,D TI N
2840 PR I NT#2,US I NG "#####.###";T(N+1),100*P N ,100*D HN ,100*R O ,100*R DO P ,100*R AX ,100*R
CO L ,100*R RA D ,100*R CR
2842 '.....'
2844 RETURN
2846 ':::::::::::::::::::-- END PRINTING --:::::::::::::::::::'
2850 ':::::::::::::::::::-- END OF BLOCK BL CALCULATIONS --:::::::::::::::::::'
3002 '
3008 '----- RESHUFFLING OF BLOCKED ARRAYS -----'
3010 '
3012 IF BL=1 GOTO 3042
3014 IF BL=BE GOTO 3042
3016 FOR N=1 TO NM+1
3018 T(N)=T(NO(BL)-1+N)
3020 DTLHP(N)=DTLHP(NO(BL)-1+N)
3022 FOR I=1 TO 4
3024 PARLHP(N,I)=PARLHP(NO(BL)-1+N,I)
3026 NEXT I
3028 NEXT N
3036 '.....'
3040 '----- PRINT "ELAPSED TIME/BLOCK & FISSION POWER" -----'

```


[illegible]

```

3220 PARLHP(N-1,4)=PAR(M,4)
3222 '
3224 RETURN
3300 '----- FIRST INTERVAL PARABOLAS -----
3310 PAR(M,1)=0
3312 PAR(M,2)=IDON(M)
3314 PAR(M,3)=ID1N(M)
3316 PAR(M,4)=(Y3-PAR(M,2)-PAR(M,3)*DT(1))/DT(1)^2
3318 '
3320 D0(M)=PAR(M,2)
3322 D1(M)=PAR(M,3)
3324 D2(M)=PAR(M,4)
3326 '.....
3330 GOTO 3170 '>>>>>>>>>>>>>>>>.
3348 '!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!!
3350 '
4070 '===== SUBROUTINE: COLD POOL =====
4071 '
4072 DTLOHS=OPT*DTCOOL : IF T(N+1)<=TLOHS THEN DTLOHS=OPT*DTCOOL*T(N+1)/TLOHS
4076 IF T(N+1)<=TL GOTO 4080
4078 IF T(N+1)>TL GOTO 4100
4080 IF TT=1 THEN DTOHXN=0 : DTIN=0 : DTSCPN=0 : DTVCPN=0 : GOTO 2106
4082 DTOHXN=DTLOHS
4090 IF N >= 2 GOTO 4146
4092 SLP(7)=(DTOHXN-DTOHXL)/DT(1) : DTIN=SLP(7)*M1(21) : DTSCPN=DTIN/DT(1)*M1(23)
      : DTVCPN=DTIN/DT(1)*M1(25)
4094 TVCP=TVCP0+DTVCPN : SLP(8)=DTIN/DT(1) : SLP(9)=DTSCPN/DT(1) : SLP(10)=DTVCP
      N/DT(1)
4096 V(21)=SLP(7)*M1(21) : V(22)=(SLP(8)-SLP(9))*L(23)*RSLCP/L(22)*M1(22) : V(24)
      =(SLP(8)-SLP(10))*L(25)*RVLCPL/L(24)*M1(24)
4098 V(23)=DTSCPN : V(25)=DTVCPN : V(26)=DTIN : DTON(8)=DTIN : DT1N(8)=SLP(8) :
GOTO 2106 'N=1
4100 '----- PARABOLA BASE-TIME IDENTIFICATION -----
4102 N1=1
4104 FOR I=N-2 TO 2 STEP -1
4106 IF T(I)>=T(N+1)-TL GOTO 4112
4108 IF N1>1 GOTO 4112
4110 N1=I
4112 NEXT I
4114 IF N1=1 THEN NB=N1
4116 IF N1>1 THEN NB=N1-1
4118 IF N1=N-2 THEN NB=N1
4120 '----- INTEGRATION LIMITS -----
4122 TB=PARLHP(NB,1)
4124 TU=T(N+1)-TL-TB
4126 IF TU<0 THEN TU=0
4128 LL=TU-DT(BL)
4130 IF TU=0 THEN LL=0
4132 '----- HEAT EXCHANGER OUTLET TEMPERATURE & PARABOLA -----
4134 IF T(N+1)-TL>2*DT(1) GOTO 4144
4136 IF T(N+1)-TL>0 AND T(N+1)-TL<DT(1) THEN DTOHXN=(DTLHP(2)-DTLHP(1))*(T(N+1)-
      TL)/DT(1)+DTLHP(1)+DTLOHS
4138 IF T(N+1)-TL=DT(1) THEN DTOHXN=DTLHP(2)+DTLOHS
4140 IF T(N+1)-TL>DT(1) THEN DTOHXN=(DTLHP(3)-DTLHP(2))*(T(N+1)-TL-DT(1))/DT(1)+
      DTLHP(2)+DTLOHS
4142 GOTO 4146
4144 DTOHXN=PARLHP(NB,2)+PARLHP(NB,3)*TU+PARLHP(NB,4)*TU*TU+DTLOHS
4146 M=7 : PFLAG=0
4148 Y0=DTOHXL : Y1=DTOHXL : Y2=DTOHXL : Y3=DTOHXN
4150 GOSUB 3100

```

```

4152 '----- FLOW TERM -----
4154 IF TT=1 GOTO 4158
4156 V(21)=V(21)*EX(21)+D0(7)*M0(21)+D1(7)*M1(21)+D2(7)*M2(21) : GOTO 4164
4158 T20=L(21)*TU : L20=L(21)*LL : D20=L(21)*DT(BL)
4160 C0=PARLHP(NB,2) : C1=PARLHP(NB,3) : C2=PARLHP(NB,4)
4162 V(21)=V(21)*EX(21)+C0*(1-EXP(-D20))+C1*(T20-1-(L20-1)*EXP(-D20))/L(21)+C2*(
T20*T20-2*T20+2-(L20*L20-2*L20+2)*EXP(-D20))/L(21)/L(21)
4164 '----- STEEL HEAT-UP TERM -----
4166 DF=(DTIO-DTSCPO)*L(23)*RSLCP/L(22)
4168 DDF=(SLP(8)-SLP(9))*L(23)*RSLCP/L(22)
4170 V(22)=V(22)*EX(22)+DF*M0(22)+DDF*M1(22)
4172 '----- VESSEL HEAT-UP TERM -----
4174 DF=(DTIO-DTVCP0)*L(25)*RVLCPL/L(24)
4176 DDF=(SLP(8)-SLP(10))*L(25)*RVLCPL/L(24)
4178 V(24)=V(24)*EX(24)+DF*M0(24)+DDF*M1(24)
4180 '----- DTI FIRST CALCULATION & PARABOLA -----
4182 DTIN=V(21)-V(22)-V(24)
4184 M=8 : PFLAG=0
4186 Y0=DTIO2 : Y1=DTIO1 : Y2=DTIO : Y3=DTIN
4188 GOSUB 3100
4190 '----- DTSCP CALCULATION & PARABOLA -----
4192 V(23)=V(23)*EX(23)+D0(8)*M0(23)+D1(8)*M1(23)+D2(8)*M2(23)
4194 DTSCPN=V(23)
4196 M=9 : PFLAG=0
4198 Y0=DTSCPO2 : Y1=DTSCPO1 : Y2=DTSCPO : Y3=DTSCPN
4200 GOSUB 3100
4202 '----- DTVCP CALCULATION & PARABOLA -----
4204 V(25)=V(25)*EX(25)+D0(8)*M0(25)+D1(8)*M1(25)+D2(8)*M2(25)
4206 DTVCPN=V(25)
4208 TVCP=TVCP0+DTVCPN
4210 M=10 : PFLAG=0
4212 Y0=DTVCP02 : Y1=DTVCP01 : Y2=DTVCP0 : Y3=DTVCPN
4214 GOSUB 3100
4216 '----- DTI SECOND CALCULATION -----
4218 D00=D0(7)-(D0(8)-D0(9))*RSLCP*L(23)/L(22)-(D0(8)-D0(10))*RVLCPL*L(25)/L(24)
4220 D11=D1(7)-(D1(8)-D1(9))*RSLCP*L(23)/L(22)-(D1(8)-D1(10))*RVLCPL*L(25)/L(24)
4222 D22=D2(7)-(D2(8)-D2(9))*RSLCP*L(23)/L(22)-(D2(8)-D2(10))*RVLCPL*L(25)/L(24)
4224 V(26)=V(26)*EX(26)+D00*M0(26)+D11*M1(26)+D22*M2(26)
4226 DTIN=V(26)
4228 '
4230 '----- DTI NEW PARABOLA -----
4232 M=8 : PFLAG=0
4234 Y0=DTIO2 : Y1=DTIO1 : Y2=DTIO : Y3=DTIN
4236 GOSUB 3100
4290 '::::::::::::::::::::::::::::: END COLD POOL CALCULATION :::::::::::::::::::::::::::::::
4292 GOTO 2106
4294 '
4550 '----- SUBROUTINE: HOT POOL -----
4552 '
4560 '----- HOT POOL SET-UP;BL=1&N=1 -----
4562 DTLHP(1)=0
4564 DTLHP(2)=DTON/DT(1)*M1(27) : DTSHPN=DTLHP(2)/DT(1)*M1(29) : DTVHPN=DTLHP(2)
/DT(1)*M1(31)
4566 TVHP=TVHP0+DTVHPN
4568 SLP(3)=DTON/DT(1)
4570 SLP(4)=DTLHP(2)/DT(1)
4572 SLP(5)=DTSHPN/DT(1) : SLP(6)=DTVHPN/DT(1)
4574 V(27)=SLP(3)*M1(27) : V(28)=(SLP(4)-SLP(5))*L(29)*RSLHP/L(28)*M1(28) : V(30)
)=(SLP(4)-SLP(6))*L(31)*RVLHP/L(30)*M1(30)
4576 V(29)=DTSHPN : V(31)=DTVHPN : V(32)=DTLHP(2)

```

```

4578 GOTO 4714 '>>>>>>>>> VESSEL >>>>>>>>>>>>>>>>>>>>'
4580 '.....'
4600 '----- SUBROUTINE HOT POOL TEMPERATURES -----'
4610 '----- FLOW TERM -----'
4612 V(27)=V(27)*EX(27)+D0(3)*M0(27)+D1(3)*M1(27)+D2(3)*M2(27)
4614 '----- STEEL HEAT-UP TERM -----'
4616 DF=(DTLHP(N)-DTSHPO)*L(29)*RSLHP/L(28)
4618 DDF=(SLP(4)-SLP(5))*L(29)*RSLHP/L(28)
4620 V(28)=V(28)*EX(28)+DF*M0(28)+DDF*M1(28)
4622 '----- VESSEL HEAT-UP TERM -----'
4624 DF=(DTLHP(N)-DTVHPO)*L(31)*RVLHP/L(30)
4626 DDF=(SLP(4)-SLP(6))*L(31)*RVLHP/L(30)
4628 V(30)=V(30)*EX(30)+DF*M0(30)+DDF*M1(30)
4630 '----- DTLHP: FIRST CALCULATION & PARABOLA -----'
4632 DTLHP(N+1)=V(27)-V(28)-V(30)
4634 M=4 : PFLAG=0
4636 Y0=DTLHP(N-1) : Y1=DTLHP(N-1) : Y2=DTLHP(N) : Y3=DTLHP(N+1)
4638 IF N>2 THEN Y0=DTLHP(N-2)
4640 GOSUB 3100
4642 '----- DTSHO: CALCULATION & PARABOLA -----'
4644 V(29)=V(29)*EX(29)+D0(4)*M0(29)+D1(4)*M1(29)+D2(4)*M2(29)
4646 DTSHPN=V(29)
4648 M=5 : PFLAG=0
4650 Y0=DTSHPO2 : Y1=DTSHPO1 : Y2=DTSHPO : Y3=DTSHPN
4652 GOSUB 3100
4654 '----- DTVHO: CALCULATION & PARABOLA -----'
4656 V(31)=V(31)*EX(31)+D0(4)*M0(31)+D1(4)*M1(31)+D2(4)*M2(31)
4658 DTVHPN=V(31)
4660 TVHP=TVHPO+DTVHPN
4662 M=6 : PFLAG=0
4664 Y0=DTVHPO2 : Y1=DTVHPO1 : Y2=DTVHPO : Y3=DTVHPN
4666 GOSUB 3100
4668 '----- DTLHP: SECOND CALCULATION -----'
4670 D00=D0(3)-(D0(4)-D0(5))*RSLHP*L(29)/L(28)-(D0(4)-D0(6))*RVLHP*L(31)/L(30)
4672 D11=D1(3)-(D1(4)-D1(5))*RSLHP*L(29)/L(28)-(D1(4)-D1(6))*RVLHP*L(31)/L(30)
4674 D22=D2(3)-(D2(4)-D2(5))*RSLHP*L(29)/L(28)-(D2(4)-D2(6))*RVLHP*L(31)/L(30)
4676 V(32)=V(32)*EX(32)+D00*M0(32)+D11*M1(32)+D22*M2(32)
4678 DTLHP(N+1)=V(32)
4680 '.....'
4690 '----- DTLHP-PARABOLA: SECOND CALCULATION -----'
4692 M=4 : PFLAG=1 'LAST PARABOLA FOR NEW TIME STEP'
4694 Y0=DTLHP(N-1) : Y1=DTLHP(N-1) : Y2=DTLHP(N) : Y3=DTLHP(N+1)
4696 IF N>2 THEN Y0=DTLHP(N-2)
4698 GOSUB 3100
4700 '----- DTCR-DRIVE-LINE CALCULATION -----'
4702 V(18)=V(18)*EX(18)+D0(4)*M0(18)+D1(4)*M1(18)+D2(4)*M2(18)
4704 '.....'
4706 DTCR=V(18)
4712 '.....'
4714 GOSUB 4800 '>>>>>>>> VESSEL >>>>>>>>>>>>>>>>>>>>'
4716 '.....'
4718 RCR=BT(18)*DTCR + BT(19)*DTVHPN + BT(20)*DTVCPN
4720 '.....'
4786 '.....'
4788 GOTO 2600 '>>>>>>>>>>>>--- END HOT POOL --->>>>>>>>>>>>'
4790 '.....'
4800 '===== SUBROUTINE: VESSEL HEAT REJECTION ====='
4810 '----- PRVHP & PRVCP CALCULATIONS -----'
4812 FOR J=1 TO 11
4814 IF TVHP>TRAC(J) AND TVHP<TRAC(J+1) THEN PRVHP=((ORAC(J+1)-ORAC(J))*(TVHP-T
```


APPENDIX C : Sample Problem *

*****-- VERSION LTC-3 --*****

11-08-1991

TOP

12:24:49

=====EDIT OF INPUT DATA=====

TT=TRANSIENT TYPE, 1:TOP ; 2:LOHS ; 3:LOF..... 1
 DT(1)=TIME STEP SIZE OF FIRST BLOCK (SECONDS)..... 1
 MAXDT=MAXIMUM STEP SIZE (SECONDS)..... 32
 NM=NUMBER OF TIME STEPS PER BLOCK..... 40
 BE=NUMBER OF BLOCKS..... 14
 LDB=REL.POWER-CHANGE LIMIT FOR DT(BL)-DOUBLING..... .01
 LHA=REL.POWER-CHANGE LIMIT FOR DT(BL)-HALVING..... .02
 RG=OPTION OF EXTERNAL REACTIVITY, 1:RAMP ; 2:WORTH CURVE..... 1
 A=INPUT RAMP RATE (\$/S)..... .01
 RM=MAXIMUM RAMP REACTIVITY (\$)..... .2
 DR=DURATION OF PARABOLIC RAMP SMOOTHING (+/- DR*DT(1))..... 1
 H=CORE HEIGHT (CM)..... 90
 TL=FLOW DELAY BETWEEN OUTLET AND INLET (SECONDS)..... 24
 BH=INITIAL DECAY HEAT FRACTION OF TOTAL POWER..... .0587
 PR=HEAT REJECTION RATE (FULL POWER)..... 1
 ARVHP=HOT POOL VESSEL AREA (M**2)..... 110
 ARVCP=COLD POOL VESSEL AREA (M**2)..... 190
 DHR=DECAY HEAD REMOVAL (FULL POWER)..... .0036
 DTCOOL 'NOMINAL COOLANT TEMPERATURE RISE ALONG CHANNEL..... 152.76
 NPNT=PRINT EVERY NPNT STEP..... 5
 TLOF=CHARACTERISTIC TIME FOR FLOW LOSS in LOF (SEC)..... 6
 TLOHS=TIME FOR SG LOSING HEAT FLUX IN LOHS (SEC)..... 82
 SSP=SPONTANEOUS FISSION SOURCE..... 1.11E-11

K	BT(K)	L(K)	
1	.00826	.01298	DELAYED NEUTRON
2	.07248	.03137	DELAYED NEUTRON
3	.06336	.1354	DELAYED NEUTRON
4	.12134	.3457	DELAYED NEUTRON
5	.05513	1.369	DELAYED NEUTRON
6	.01773	3.7376	DELAYED NEUTRON
7	1.6232	.1985	DECAY HEAT
8	2.094	.01437	DECAY HEAT
9	1.163	9.359999E-03	DECAY HEAT
10	.5523	.0000762	DECAY HEAT
11	8.519999E-02	9.73E-06	DECAY HEAT
12	.3521	8.88E-07	DECAY HEAT
13	-.0981	4.108	FEEDBACK(NOTE#2)
14	-.1432	2	FEEDBACK(NOTE#2)
15	.1715	.0092	FEEDBACK(NOTE#2)
16	-.1184	3.975	FEEDBACK(NOTE#2)
17	-.1184	4.108	FEEDBACK(NOTE#2)
18	-.111	.041	FEEDBACK(NOTE#2)
19	.062	4.108	FEEDBACK(NOTE#2)
20	.062	4.108	FEEDBACK(NOTE#2)
21	78.9	.01282	FLOW COLD-POOL
22	0	.01282	FLOW COLD-POOL
23	0	.001025	STEEL COLD-POOL
24	0	.01282	FLOW COLD-POOL
25	0	.00085	VESSEL COLD-POOL
26	0	.01282	FLOW COLD-POOL
27	0	.01415	FLOW HOT-POOL
28	0	.01415	FLOW HOT-POOL
29	0	.01016	STEEL HOT-POOL
30	0	.01415	FLOW HOT-POOL
31	0	.00085	VESSEL HOT-POOL

* Input Data provided by J. E. Cahalan, Ref. 3

```

      32      0      .01415      FLOW HOT-POOL
NOTE#1 : BT(K)=BT(K)/100      FOR DELAYED NEUTRONS
        BT(K)=BT(K)/100/(1-BH)  FOR DECAY HEAT

```

NOTE#2 : INDIVIDUAL FEEDBACK COEFFICIENTS & TIME CONSTANTS :

-DRIVING FORCE--		DELAY LOCATION----	TIME CONSTANT-----
CLAD -TEMP	FUEL ROD		4.108
OUTLET-TEMP	LOAD PAD		2
INLET-TEMP	GRID PLATE		.0092
COOLANT	STRUCTURE		3.975
FISSION POWER	FUEL ROD		4.108
HP-TEMP	CR-DRIVE		.041

```

----- INDIVIDUAL FEEDBACK COEFFICIENTS: BT(K) -----
DOPPLER .....-.0981
AXIAL EXPANSION .....-.1432
COOLANT EXPANSION .....1715
  100*XMC/XAC .....-1184
GRID PLATE EXPANSION .....-1184
CR-DRIVE-LINE EXPANSION .....-111
HOT POOL VESSEL EXPANSION......062
COLD POOL VESSEL EXPANSION......062

```

HEAT CAPACITIES				
CLHP=HEAT	CAPACITY	OF	HOT-POOL SODIUM	(FPS/K)..... .4613
CLCP=HEAT	CAPACITY	OF	COLD-POOL SODIUM	(FPS/K)..... .5089
CSHP=HEAT	CAPACITY	OF	HOT-POOL STEEL	(FPS/K)..... .2188
CSCP=HEAT	CAPACITY	OF	COLD-POOL STEEL	(FPS/K)..... .5422
CVHP=HEAT	CAPACITY	OF	HOT-POOL VESSEL	(FPS/K)..... .0083
CVCP=HEAT	CAPACITY	OF	COLD-POOL VESSEL	(FPS/K)..... .0205

[illegible]

BLOCK # 3 MAXD OF PREVIOUS BLOCK= 5.958568E-04 THUS NEW DT= 2

1.300	126.761	6.884	46.810	26.045	20.288	6.082	0.352	20.000	-19.648
1.400	126.068	6.908	47.570	28.064	22.863	7.880	0.101	20.000	-19.899
1.500	125.299	6.924	48.259	29.904	25.181	9.737	-0.098	20.000	-20.098
2.000	124.475	6.932	48.886	31.588	27.280	11.617	-0.258	20.000	-20.258
2.100	123.615	6.933	49.454	33.134	29.188	13.492	-0.385	20.000	-20.385
2.200	122.733	6.929	49.965	34.559	30.932	15.343	-0.486	20.000	-20.486
2.300	121.842	6.919	50.421	35.874	32.531	17.154	-0.565	20.000	-20.565
2.400	120.950	6.906	50.824	37.089	34.003	18.914	-0.626	20.000	-20.626

BLOCK # 3 ELAPSED TIME IS 173.6797 SECONDS;FISSION POWER= 1.140439

BLOCK # 4 MAXD OF PREVIOUS BLOCK= 1.472602E-03 THUS NEW DT= 4

3.000	119.225	6.869	51.530	39.267	36.614	22.255	-0.697	20.000	-20.697
3.200	117.521	6.822	52.030	41.136	38.858	25.331	-0.741	20.000	-20.741
3.400	115.911	6.769	52.381	42.739	40.785	28.132	-0.750	20.000	-20.750
4.000	114.408	6.713	52.620	44.113	42.438	30.660	-0.738	20.000	-20.738
4.200	113.018	6.655	52.769	45.287	43.855	32.925	-0.711	20.000	-20.711
4.400	111.745	6.597	52.848	46.288	45.067	34.943	-0.675	20.000	-20.675
5.000	110.588	6.540	52.875	47.141	46.101	36.732	-0.632	20.000	-20.632
5.200	109.545	6.486	52.864	47.864	46.981	38.312	-0.586	20.000	-20.586

BLOCK # 4 ELAPSED TIME IS 235.3008 SECONDS;FISSION POWER= 1.030584

BLOCK # 5 MAXD OF PREVIOUS BLOCK= 3.029336E-03 THUS NEW DT= 8

6.000	107.775	6.387	52.776	48.999	48.365	40.920	-0.490	20.000	-20.490
6.400	106.379	6.302	52.650	49.810	49.357	42.917	-0.399	20.000	-20.399
7.200	105.313	6.232	52.538	50.395	50.067	44.434	-0.314	20.000	-20.314
8.000	104.514	6.175	52.471	50.829	50.583	45.588	-0.241	20.000	-20.241
8.400	103.929	6.130	52.461	51.168	50.974	46.470	-0.180	20.000	-20.180
9.200	103.510	6.095	52.508	51.449	51.285	47.159	-0.132	20.000	-20.132
10.000	103.215	6.069	52.611	51.702	51.553	47.712	-0.095	20.000	-20.095
10.400	103.012	6.050	52.763	51.943	51.799	48.174	-0.067	20.000	-20.067

BLOCK # 5 ELAPSED TIME IS 297.0391 SECONDS;FISSION POWER= .9696225

BLOCK # 6 MAXD OF PREVIOUS BLOCK= 3.511698E-03 THUS NEW DT= 16

12.000	102.738	6.024	53.133	52.405	52.260	48.943	-0.037	20.000	-20.037
13.200	102.647	6.012	53.639	52.909	52.753	49.619	-0.012	20.000	-20.012
14.400	102.583	6.005	54.215	53.454	53.288	50.286	-0.010	20.000	-20.010
16.000	102.514	6.000	54.797	54.023	53.851	50.964	-0.011	20.000	-20.011
17.200	102.442	5.996	55.368	54.597	54.425	51.650	-0.010	20.000	-20.010
18.400	102.358	5.992	55.924	55.164	54.995	52.334	-0.012	20.000	-20.012
20.000	102.264	5.988	56.455	55.715	55.552	53.007	-0.013	20.000	-20.013
21.200	102.167	5.983	56.960	56.248	56.090	53.660	-0.013	20.000	-20.013

BLOCK # 6 ELAPSED TIME IS 358.8906 SECONDS;FISSION POWER= .9618376

BLOCK # 7 MAXD OF PREVIOUS BLOCK= 9.194568E-04 THUS NEW DT= 32

24.000	101.928	5.972	57.826	57.200	57.062	54.868	-0.013	20.000	-20.013
26.400	101.805	5.965	58.695	58.097	57.968	55.975	-0.006	20.000	-20.006
29.200	101.623	5.957	59.497	58.940	58.815	56.999	-0.017	20.000	-20.017
32.000	101.490	5.949	60.203	59.707	59.599	57.944	-0.005	20.000	-20.005
34.400	101.362	5.943	60.882	60.411	60.307	58.808	-0.011	20.000	-20.011
37.200	101.228	5.937	61.479	61.059	60.966	59.598	-0.009	20.000	-20.009
40.000	101.134	5.931	62.036	61.648	61.563	60.321	-0.005	20.000	-20.005
42.400	101.024	5.926	62.551	62.192	62.112	60.981	-0.009	20.000	-20.009

BLOCK # 7 ELAPSED TIME IS 420.8399 SECONDS;FISSION POWER= .9509795

BLOCK # 8 MAXD OF PREVIOUS BLOCK= 8.495724E-04 THUS NEW DT= 32

45.200	100.938	5.922	63.010	62.688	62.617	61.585	-0.004	20.000	-20.004
48.000	100.858	5.918	63.445	63.143	63.076	62.138	-0.006	20.000	-20.006
50.400	100.778	5.914	63.833	63.561	63.500	62.644	-0.006	20.000	-20.006
53.200	100.716	5.910	64.193	63.942	63.887	63.107	-0.004	20.000	-20.004
56.000	100.650	5.907	64.524	64.293	64.242	63.531	-0.005	20.000	-20.005
58.400	100.594	5.904	64.823	64.614	64.568	63.919	-0.003	20.000	-20.003
61.200	100.544	5.902	65.102	64.908	64.865	64.273	-0.004	20.000	-20.004
64.000	100.495	5.899	65.354	65.177	65.138	64.598	-0.004	20.000	-20.004

BLOCK # 8 ELAPSED TIME IS 482.8477 SECONDS;FISSION POWER= .9459555

BLOCK # 9 MAXD OF PREVIOUS BLOCK= 2.443231E-04 THUS NEW DT= 32
66.400 100.454 5.897 65.586 65.424 65.388 64.896 -0.002 20.000 -20.002
69.200 100.414 5.895 65.800 65.650 65.617 65.168 -0.003 20.000 -20.003
72.000 100.378 5.893 65.993 65.858 65.828 65.417 -0.002 20.000 -20.002
74.400 100.347 5.891 66.172 66.047 66.020 65.645 -0.002 20.000 -20.002
77.200 100.316 5.890 66.336 66.222 66.196 65.854 -0.002 20.000 -20.002
80.000 100.290 5.888 66.485 66.381 66.358 66.045 -0.002 20.000 -20.002
82.400 100.264 5.887 66.623 66.527 66.506 66.220 -0.002 20.000 -20.002
85.200 100.242 5.886 66.748 66.661 66.641 66.380 -0.001 20.000 -20.001
BLOCK # 9 ELAPSED TIME IS 545.0821 SECONDS;FISSION POWER= .9435582
BLOCK # 10 MAXD OF PREVIOUS BLOCK= 1.053636E-04 THUS NEW DT= 32
88.000 100.222 5.885 66.864 66.783 66.765 66.526 -0.001 20.000 -20.001
90.400 100.202 5.884 66.969 66.895 66.879 66.661 -0.001 20.000 -20.001
93.200 100.185 5.883 67.066 66.998 66.983 66.784 -0.001 20.000 -20.001
96.000 100.169 5.882 67.154 67.092 67.079 66.896 -0.001 20.000 -20.001
98.400 100.155 5.881 67.235 67.179 67.166 66.999 -0.001 20.000 -20.001
101.200 100.142 5.881 67.310 67.258 67.246 67.094 -0.001 20.000 -20.001
104.000 100.130 5.880 67.378 67.330 67.320 67.180 -0.001 20.000 -20.001
106.400 100.119 5.879 67.440 67.397 67.387 67.259 -0.001 20.000 -20.001
BLOCK # 10 ELAPSED TIME IS 607.0899 SECONDS;FISSION POWER= .9423933
BLOCK # 11 MAXD OF PREVIOUS BLOCK= 4.495615E-05 THUS NEW DT= 32
109.200 100.109 5.879 67.497 67.457 67.449 67.332 -0.001 20.000 -20.001
112.000 100.099 5.878 67.550 67.513 67.505 67.398 -0.001 20.000 -20.001
114.400 100.091 5.878 67.597 67.564 67.557 67.459 -0.001 20.000 -20.001
117.200 100.083 5.878 67.641 67.611 67.604 67.514 -0.001 20.000 -20.001
120.000 100.076 5.877 67.682 67.654 67.647 67.565 -0.000 20.000 -20.000
122.400 100.070 5.877 67.718 67.693 67.687 67.612 -0.000 20.000 -20.000
125.200 100.064 5.876 67.752 67.729 67.723 67.655 -0.000 20.000 -20.000
128.000 100.059 5.876 67.783 67.761 67.757 67.694 -0.000 20.000 -20.000
BLOCK # 11 ELAPSED TIME IS 669.1602 SECONDS;FISSION POWER= .9418242
BLOCK # 12 MAXD OF PREVIOUS BLOCK= 2.190941E-05 THUS NEW DT= 32
130.400 100.054 5.876 67.811 67.792 67.787 67.730 -0.000 20.000 -20.000
133.200 100.049 5.876 67.837 67.819 67.815 67.763 -0.000 20.000 -20.000
136.000 100.045 5.875 67.861 67.844 67.841 67.793 -0.000 20.000 -20.000
138.400 100.041 5.875 67.883 67.868 67.864 67.820 -0.000 20.000 -20.000
141.200 100.038 5.875 67.903 67.889 67.886 67.845 -0.000 20.000 -20.000
144.000 100.034 5.875 67.921 67.908 67.905 67.868 -0.000 20.000 -20.000
146.400 100.032 5.874 67.938 67.926 67.923 67.890 -0.000 20.000 -20.000
149.200 100.029 5.874 67.953 67.942 67.940 67.909 -0.000 20.000 -20.000
BLOCK # 12 ELAPSED TIME IS 731.1211 SECONDS;FISSION POWER= .9415456
BLOCK # 13 MAXD OF PREVIOUS BLOCK= 1.04845E-05 THUS NEW DT= 32
152.000 100.026 5.874 67.967 67.957 67.955 67.927 -0.000 20.000 -20.000
154.400 100.024 5.874 67.980 67.971 67.969 67.943 -0.000 20.000 -20.000
157.200 100.022 5.874 67.992 67.983 67.982 67.958 -0.000 20.000 -20.000
160.000 100.020 5.874 68.002 67.995 67.993 67.971 -0.000 20.000 -20.000
162.400 100.019 5.874 68.012 68.005 68.004 67.984 -0.000 20.000 -20.000
165.200 100.017 5.874 68.021 68.015 68.014 67.995 -0.000 20.000 -20.000
168.000 100.016 5.873 68.030 68.024 68.023 68.006 -0.000 20.000 -20.000
170.400 100.014 5.873 68.037 68.032 68.031 68.015 -0.000 20.000 -20.000
BLOCK # 13 ELAPSED TIME IS 793.129 SECONDS;FISSION POWER= .9414096
BLOCK # 14 MAXD OF PREVIOUS BLOCK= 5.243722E-06 THUS NEW DT= 32
173.200 100.013 5.873 68.044 68.039 68.038 68.024 -0.000 20.000 -20.000
176.000 100.012 5.873 68.051 68.046 68.045 68.032 -0.000 20.000 -20.000
178.400 100.011 5.873 68.056 68.052 68.051 68.040 -0.000 20.000 -20.000
181.200 100.010 5.873 68.062 68.058 68.057 68.046 -0.000 20.000 -20.000
184.000 100.009 5.873 68.067 68.063 68.062 68.053 -0.000 20.000 -20.000
186.400 100.008 5.873 68.071 68.068 68.067 68.058 -0.000 20.000 -20.000
189.200 100.008 5.873 68.075 68.072 68.072 68.063 -0.000 20.000 -20.000
192.000 100.007 5.873 68.079 68.076 68.076 68.068 -0.000 20.000 -20.000
BLOCK # 14 ELAPSED TIME IS 854.6406 SECONDS;FISSION POWER= .9413439

APPENDIX D : Glossary *

(Based on LTC Version 3)

Name	Description	Unit
A	reactivity ramp insertion rate	\$/s
AAH	factor in the <i>historical</i> part of convolution integrals	
AAP	factor in the <i>present</i> part of convolution integrals	
AH(K)	factor in the <i>historical</i> component of feedback	
AP(K)	factor in the <i>present</i> component of feedback	
ARVCP	cold pool vessel surface area	m^2
ARVHP	hot pool vessel surface area	m^2
A0,A1,A2	coefficients of the smoothed reactivity ramp	
B	effective delayed neutron fraction	1\$
BE	number of time blocks	
BH	initial decay heat fraction	FP
BL	time block counter	
BS	size of first time block	s
BT(K) for K=1 ... 6	delayed neutron fractions	\$ fractions
BT(K) for K=7 ... 12	decay heat fractions	FP
BT(K) for K > 12	feedback coefficients	\$, or \$/K
BTR	feedback-coefficient components	
BV	reactivity worth curve coefficient	1/s
BZ	square root of axial buckling	m^{-1}
CCOR	core heat capacity	FPs/K
CFUL	fuel heat capacity	FPs/K
CLCP	cold-pool sodium heat capacity	FPs/K
CLHP	hot-pool sodium heat capacity	FPs/K
CSCP	cold-pool steel heat capacity	FPs/K
CSHP	hot-pool steel heat capacity	FPs/K
CVCP	cold-pool vessel heat capacity	FPs/K
CVHP	hot-pool vessel heat capacity	FPs/K
DD\$	date	
DDF	time derivative of driving function	1/s
DDH	zero-th moment component term of convolution integral for decay heat	FP
DDT..0	initial temperature derivatives (all = 0)	

* Not included are terms of a strictly "temporary" application, such as abbreviations used only within a very few lines of coding. The Glossary deviates from strict alphabetic order if it enhances clarity.

DF	driving function, general notation	
DH..	decay heat rate	
DHN	at end of current time interval (N+1)	FP
DHO	at begin of current time interval (N)	FP
DHO1	at begin of previous time interval (N-1)	FP
DHO2	at begin of prior time interval (N-2)	FP
DHR	removal rate	FP
DH0	initial value	
DPN	derivative of power	1/s
DPO	absolute fractional power change	
DR	duration of parabolic ramp smoothing	s
DSD	zero-th moment factor in the convolution integral for delayed neutron source	
DT	time step size	s
DTC..	temperature change of clad	K
DTCH	historical component	K
DTCP	present-component factor [of $p_f(t_{n+1})$]	K
DTCN	at end of current time interval (N+1)	K
DTCO	at begin of current time interval (N)	K
DTCO1	at begin of previous time interval (N-1)	K
DTCO2	at begin of prior time interval (N-2)	K
DTC0	initial value (=0)	K
DTCOOL	nominal coolant temperature rise	K
DTCR	DT of control rod drive line at t_{n+1}	K
DTF..	temperature change of fuel	K
DTFC0	nominal clad-to-fuel	K
DTFH	historical component	K
DTFP	present-component factor [of $p_f(t_{n+1})$]	K
DTFN	at end of current time interval (N+1)	K
DTFO	at begin of current time interval (N)	K
DTFO1	at begin of previous time interval (N-1)	K
DTFO2	at begin of time interval (N-2)	K
DTF0	initial value (=0)	K
DTGP	DT of grid plate at t_{n+1}	K
DTI..	inlet temperature change	
DTIN	at end of current time interval (N+1)	K
DTIO	at begin of current time interval (N)	K
DTIO1	at begin of previous interval (N-1)	K
DTIO2	at begin of prior at time interval (N-2)	K

DTIO	initial value (=0)	K
DTL..	temperature change of coolant (core)	K
DTLH	historical component	K
DTLP	present-component factor [of $p_f(t_{n+1})$]	K
DTLN	at end of current time interval (N+1)	K
DTLO	at begin of current time interval (N)	K
DTLO1	at begin of previous time interval (N-1)	K
DTLO2	at begin of prior time interval (N-2)	K
DTLO	initial value (=0)	K
DTLHP..	temperature change of hot pool sodium	K
DTLHPO	initial value (=0)	K
DTLHP0	initial value (=0)	K
DTLOHS	heat exchanger heat-up due to loss of heat sink	K
DTLPEFF	effective load-pad temperature change	K
DTOHX..	heat exchanger outlet temperature change	K
DTOHXN	at end of current time interval (N+1)	K
DTOHXO	at begin of current time interval (N)	K
DTOHXO1	at begin of previous time interval (N-1)	K
DTOHXO2	at begin of prior at time interval (N-2)	K
DTOHX0	initial value(=0)	K
DTO..	core outlet temperature change	K
DTON	at end of current time interval (N+1)	K
DTOO	at begin of current time interval (N)	K
DTOO1	at begin of previous time interval (N-1)	K
DTOO2	at begin of prior at time interval (N-2)	K
DTO0	initial value (=0)	K
DTS	temperature change of subassembly walls at t_{n+1}	K
DTSCP..	cold pool steel temperature change	K
DTSCPN	at end of current time interval (N+1)	K
DTSCPO	at begin of current time interval (N)	K
DTSCPO1	at begin of previous time interval (N-1)	K
DTSCPO2	at begin of prior at time interval (N-2)	K
DTSCP0	initial value (=0)	K
DTVHP..	hot pool steel temperature change	K
DTSHPN	at end of current time interval (N+1)	K
DTSHPO	at begin of current time interval (N)	K
DTSHPO1	at begin of previous time interval (N-1)	K
DTSHPO2	at begin of prior at time interval (N-2)	K

DTSHPO	initial value	K
DTVCP..	cold pool vessel temperature change	K
DTVCPN	at end of current time interval (N+1)	K
DTVCP0	at begin of current time interval (N)	K
DTVCP01	at begin of previous time interval (N-1)	K
DTVCP02	at begin of prior at time interval (N-2)	K
DTVCP0	initial value (=0)	K
DTVHP..	hot pool vessel temperature change	K
DTVHPN	at end of current time interval (N+1)	K
DTVHPO	at begin of current time interval (N)	K
DTVHPO1	at begin of previous time interval (N-1)	K
DTVHPO2	at begin of prior at time interval (N-2)	K
DTVHP0	initial value (=0)	K
D0,D1,D2	output coefficients of driving function parabolas	
D00,D11,D22	temporary quantities in sodium pool temperature calculation	
D0I,D1I	DTI projection coefficients	
DON,D1N	parabola projection coefficients	
EX(K)	EXP (-L(K)*DT(BL))	
FL..	relative flow	
FLN	at end of current time interval (N+1)	
FLO	at begin of current time interval (N)	
FLO1	at begin of previous time interval (N-1)	
FLO2	at begin of prior at time interval (N-2)	
FL0	initial value	
FP	full power unit	
FPs	full-power second unit	s
FP..	relative fission power	
FPD	derivative at t_n	FP/s
FPN	at end of current time interval (N+1)	FP
FPO	at begin of current time interval (N)	FP
FPO1	at begin of previous time interval (N-1)	FP
FPO2	at begin of prior at time interval (N-2)	FP
FP0	initial value	FP
FPX	extrapolated value	FP
H	core height	m
HDH	historical part of decay heat	FP
HRF	historical part of the total reactivity feedback	\$
HSD	historical part of delayed neutron source	

HX	extrapolated core height	m
ID0N,ID1N	interim parabola projection coefficients	
INED	option for input edit (0; . 1; 1)	
ITER	core iteration index	
ITMX	maximum value of ITER	
L(K)	time constants	1/s
IV(K)	iterim convolution integrals	
LC,LCF,LCL	coefficients in core temperature calculation	
LFL,LL,LLC	coefficients in core temperature calculation	
LLI,LLL,LLS	coefficients in core temperature calculation	
LDB	(relative-power-change) limit for doubling DT	
LDT(K)	$L(K)*DT(BL)$	
LHA	(relative-power-change) limit for halving DT	
MAXD	absolute maximum of relative power change per time-step in a time block	
MAXDT	maximum time step size	s
MDH	first moment term in convolution integrals for decay heat	
MSD	first moment term in convolution integrals for delayed neutron source	
M0(K)	zero-th moment in convolution integral evaluation	
M1(K)	first moment of convolution-integral evaluation	s
M1AS	asymptotic value of M1(K)	s
M2(K)	second moment of convolution-integral evaluation	s^2
M2AS	asymptotic value of M2(K)	s^2
NB	N-value of parabola base-time	
NE(BL)	time step at end of time block BL	
NM(BL)	number of time steps per block	
NPNT	print output every NPNT time step	
N0(BL)	time step at beginning of time block	
OPT	fraction of nominal core temperature rise contributes to loop due to heat exchanger flow loss during LOHS event	
PAR	generic parabola parameters	
PARLHP	hot pool sodium temperature parabola parameters	
PDH	second moment term in convolution integral for decay heat	
PFD	power-to-flow derivative	1/s
PFLAG	flag to reset time step size change indicator (PP) to equal interval	
PI	$\pi = 3.141592654$	

P..	total relative power	
PN	at end of current time interval (N+1)	FP
PO	at begin of current time interval (N)	FP
PO1	at begin of previous time interval (N-1)	FP
PO2	at begin of prior at time interval (N-2)	FP
P0	initial value	
PP	time step change indicator	
PR	nominal heat rejection	FP
PRF	<i>present</i> component of reactivity feedback	
PRVCP	power rejection from cold pool vessel	FP
PRVCP0	initial cold pool vessel heat rejection	FP
PRVHP	power rejection from hot pool vessel	FP
PRVHP0	initial hot pool vessel heat rejection	FP
PSD	second moment term in convolution integral for delayed neutron source	
PTD	total power derivative	FP/s
Q	coefficient in solution of fission power quadratic equation	
QLF	steam generator heat flux in LOF time correlation table	
QRAC	vessel air cooling heat flux	
QRSG	steam generator heat flux during LOF	
RAX	reactivity feedback, axial expansion	\$
RCOL	reactivity feedback, coolant expansion	\$
RCR	reactivity feedback, control-rod drive-line expansion	\$
RDOP	reactivity feedback, Doppler effect	\$
RF	total reactivity feedback	\$
RG	option of either ramp reactivity or worth curve	
RI	reactivity feedback, inlet temperature change	\$
RM	reactivity maximum of limited ramp	\$
RO	total reactivity	\$
RR	coefficient in solution of fission power quadratic equation	
RRAD	reactivity feedback, radial expansion	
RSLCP	cold pool steel-to-sodium heat capacity ratio	
RSLHP	hot pool steel-to-sodium heat capacity ratio	
RVLCP	cold pool vessel-to-sodium heat capacity ratio	
RVLHP	hot pool vessel-to-sodium heat capacity ratio	
RX	external (programmed) reactivity insertion for step N+1	\$
SD	delayed neutron source	
SLAMBDA	special lambda values (in core heat-transfer equations)	$\frac{1}{s}$
SLP	slope of various quantities	

SSP	spontaneous fission source	FP
T	time	s
TB	parabola base-time for IHX outlet	s
TBL	elapsed execution time at end of time block	s
TBV	coefficient of worth curve	
TELAP	elapsed execution time of one time block	s
T1M\$	clock time	
TL	temperature feedback retardation time	s
TLF	time frame in LOF heat flux correlation table	s
TLOF	characteristic time for flow loss in LOF	s
TLOHS	characteristic time for steam generator heat flux loss in LOHS	s
TM	time in the format of "min.sec"	min.s
TR	end of worth curve	
TRAC	temperature in vessel air cooling heat flux correlation table	K
TSTART	elapsed execution time at beginning of time block	s
TT	type of transient (1, 2, 3 for TOP, LOHS, LOF)	
TU	upper limit in parabola integral	s
TVCP	cold pool vessel temperature	K
TVCP0	initial cold pool vessel temperature	K
TVHP	hot pool vessel temperature	K
TVHP0	initial hot pool vessel temperature	K
TX	end of linear ramp	s
T1,T2	coefficients of smooth ramp	sec
V(K)	convolution integral, general notation	
VZ	velocity of control rod extraction	
Y0,Y1,Y2,Y3	base points for parabola-fit subroutine	

Acknowledgements

This work was supported by the Reactor Engineering Division. I'm grateful to John F. Marchaterre and Jim E. Cahalan for continued discussions. Special thanks are due to Jim Cahalan for running sample problems which have been a valuable guidance through this program development. Gratefully acknowledged is also the extensive assistance by Chi-Wen Tsaoi in programming the earlier version of this code which applies quasistatic core temperature calculations.

References

1. K. O. Ott, "A Fast Reactor Transient Analysis Methodology for PCs: Vol. 1, The Computational Model," ANL/RE-91/2 Vol. 1 (1991).
2. J. E. Cahalan, personal communications (1989-1990).
3. J. E. Cahalan, personal communication, August 1987.

END

**DATE
FILMED**

3 / 18 / 92