**U.S. DEPARTMENT
OF ENERGY**

Prepared for
**Office of Energy Efficiency
and Renewable Energy**

**Office of Utility
Technologies**

Prepared by
**Office of Scientific and
Technical Information**

**Generic Serial:
Representative copy**

DOE/GET--95/1
(PB95-914701)
Jan.-Feb. 1995

CURRENT ABSTRACTS

Geothermal Energy

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

OFFICE OF SCIENTIFIC AND TECHNICAL INFORMATION

The Office of Scientific and Technical Information (OSTI) in Oak Ridge, Tennessee, provides direction for the Department of Energy's (DOE) scientific and technical information (STI) program and maintains a centralized base of support to assist Departmental elements in planning, developing, and implementing STI activities. DOE-originated and world-wide literature and software on advances in subjects of interest to DOE researchers are collected, processed, and disseminated using computerized databases, publications, and other media.

This information collection, containing over three million citations, represents a major national resource of scientific and technical information. In addition to information from DOE and its contractors, DOE acquires information through its international partnerships with the International Energy Agency's Energy Technology Data Exchange (ETDE), a consortium of more than 17 countries comprised of members from several continents; IEA Coal Research; the International Atomic Energy Agency's International Nuclear Information System, representing over 100 countries and international organizations; bilateral agreements with foreign governments; exchange agreements with other U.S. government agencies; and contracts with private information organizations and professional societies.

The subject scope of this information extends beyond energy, covering basic scientific studies in such areas as radiology, atomic and nuclear physics, radiation and nuclear chemistry, superconductivity, supercomputers, the environment, health and safety, waste management, nuclear medicine, and arms control.

Major DOE databases are available within the United States through DIALOG Information Services and STN International and outside the United States through formal governmental exchange agreements. DOE and DOE contractor offices can access the databases online through the Integrated Technical Information System (ITIS) maintained by OSTI.

Office of Scientific and Technical
Information
U.S. DEPARTMENT OF ENERGY
P.O. Box 62
Oak Ridge, TN 37831

Geothermal Energy

ABOUT THIS PUBLICATION

Geothermal Energy (GET) announces on a bimonthly basis the current worldwide information available on the technologies required for economic recovery of geothermal energy and its use as direct heat or for electric power production. This publication contains the abstracts of DOE reports, journal articles, conference papers, patents, theses, and monographs added to the Energy Science and Technology Database during the past two months. Also included are U.S. information obtained through acquisition programs or interagency agreements and international information obtained through the International Energy Agency's Energy Technology Data Exchange or government-to-government agreements. The digests in *GET* and other citations to information on geothermal energy dating from 1974 are available for online searching and retrieval on the Energy Science and Technology Database. Current information, added daily to the Energy Science and Technology Database, is available to DOE and its contractors through the DOE Integrated Technical Information System. Customized profiles can be developed to provide current information to meet each user's needs.

PROGRAM ACTIVITIES

The Office of Utility Technologies is sponsoring or jointly sponsoring a series of eight current awareness publications to keep researchers knowledgeable of the latest scientific and technical information in the area of renewable energy sources. The publications are

Biomass Energy Research
Electric Energy Systems
Electric Power Systems
Energy Storage Systems
Geothermal Energy
Photovoltaic Energy
Solar Thermal Energy Technology
Wind Energy Technology

AVAILABILITY

DOE and DOE contractors can obtain copies for \$4.00 per issue by using VISA, MasterCard, or OSTI deposit accounts. Contact the Office of Scientific and Technical Information, P. O. Box 62, Oak Ridge, TN 37831, Attention: Information Services. For further information, call (615) 576-8401.

Public availability is by subscription from the U.S. Department of Commerce, Technology Administration, National Technical Information Service, Springfield, VA 22161. Order PB95-914700.

Managing Editor, Leota S. Kane
Managing Editorial Support, Doris M. Henline
Technical Editor, Barry C. Steele
Technical Editorial Support, Lawrence S. Pichiarella

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DOE/GET--95/1
(PB95-914701)

ISSN: 0896-6257
CODEN: GTENEQ

Jan.-Feb. 1995

Information on the following subjects is included within the scope of this publication, but all subjects may not appear in each issue:

RESOURCE STATUS AND ASSESSMENT

GEOLOGY AND HYDROLOGY OF GEOTHERMAL SYSTEMS

GEOTHERMAL EXPLORATION AND EXPLORATION TECHNOLOGY

LEGISLATION AND REGULATIONS

ECONOMIC, INDUSTRIAL, AND BUSINESS ASPECTS

ENVIRONMENTAL ASPECTS

PRODUCTS AND BY-PRODUCTS

GEOTHERMAL POWER PLANTS

GEOTHERMAL ENGINEERING

DIRECT ENERGY UTILIZATION

GEOTHERMAL DATA AND THEORY

HEALTH AND SAFETY

WASTE MANAGEMENT

MISCELLANEOUS

Worksheet and Order Forms are provided in back of publication.

International Copyright, © U.S. Department of Energy, 1995, under the provisions of the Universal Copyright Convention. United States copyright is not asserted under the United States Copyright Law, Title 17, United States Code.

HOW TO . . .

READ A CITATION

The principal elements of a citation are

Abstract No.	→	37	
Report No.	→	(DOE/FE/60177--2430)	
Title	→	Review of oil shale comminution technology.	
Author(s)	→	McKay, J.F. (Western Research Inst., Laramie, WY (United States)). Southwestern Engineering, Wood City, AZ (United States). Jan 1995. 20p.	← (Affiliation) ← Corporate author(s) ← Date of Publication
Sponsor	→	Sponsored by USDOE, Washington, DC (United States). DOE Contract BC23-123456789. Order	← Contract No.
Order No.	→	Number DE95012345. Source: OSTI; NTIS; GPO.	← Availability

OBTAIN A REPORT

Reports abstracted in this publication can be obtained from one of the agencies listed by acronym in the citation (acronyms and addresses are listed at right). **DOE and DOE contractors may order from OSTI.** OSTI prices are based on total pages unless special pricing applies. The public should order from NTIS or one of the other agencies listed. NTIS price codes may continue to appear in some records. To expedite processing, order forms are provided in the back of this publication.

OBTAIN NONREPORT PRODUCTS

In most cases, sources are given in the citations. First, check local libraries. If the product is not available in a library, request it from the publisher or originator cited. Some possible sources of information follow.

☐ **Journal articles** *Chemical Abstracts Service Source Index (CASSI)* tells which libraries, both U.S. and foreign, contain a journal and the available years. *Ulrich's International Periodicals Directory* contains information on the journal and its publisher. For librarians, another source of information is Online Computer Library Center (OCLC), for interlibrary loans.

☐ **Books, conferences, and monographs** The source for these publications is the publisher or the originating society, organization, or institution. DOE-supported conferences and individual papers reporting DOE-supported research may be available as reports from OSTI.

☐ **Foreign material** The Linda Hall Library is an excellent source of foreign materials. For translations of foreign language material, contact the National Translation Center. For material difficult to locate, check with the British Library Document Supply Centre.

☐ **Software** The Energy Science and Technology Software Center (ESTSC) is DOE's centralized software management facility and is authorized to distribute DOE and NRC software to the government, its contractors, and the public.

OSTI U.S. Department of Energy
Office of Scientific and Technical Information
P.O. Box 62, Oak Ridge, TN 37831
Fax: (615) 576-2865
e-mail: reports@adonis.osti.gov

GPO Superintendent of Documents
Government Printing Office
Washington, DC 20402

GPO Dep. Available for inspection or interlibrary loan
at Government Printing Office regional
depository libraries.

INIS Available only in microfiche.
INIS Clearinghouse
International Atomic Energy Agency
P.O. Box 100, A-1400 Vienna, Austria

NTIS U.S. Department of Commerce
Technology Administration
National Technical Information Service
Springfield, VA 22161

CASI Attention: Document Order
NASA Center for AeroSpace Information
800 Elkridge Landing Road
Linthicum Heights, MD 21090-2934

ESTSC Energy Science and Technology
Software Center
P.O. Box 1020, Oak Ridge, TN 37831-1020
Internet: ESTSC@ADONIS.OSTI.GOV

Online Computer Library Center, Inc.
6565 Frantz Road
Dublin, OH 43107-0702
(614) 764-6000

Linda Hall Library
5109 Cherry Street
Kansas City, MO 64110
(816) 363-4600

National Translation Center
Library of Congress
Washington, DC 20540
(202) 707-0100

**British Library Document
Supply Centre**
Boston Spa, Wetherby
West Yorkshire LS23 7BQ
England
0937-843434

Geothermal Energy

RESOURCE STATUS AND ASSESSMENT

Refer also to citation(s) 14

1

(CONF-9006452—, pp. 58-68)

Latest developments and prospects of the use of geothermal resources in the GDR. Seibt, P. (VEB Geothermie Neubrandenburg (Germany)); Kabus, F.; Bachmann, I. Umweltministerium des Landes Niedersachsen, Hannover (Germany). 1990. 208p. (In German). From Expert discussion with scientists from both parts of Germany: research in the area of renewable energy sources; Oldenburg (Germany); 18-19 Jun 1990. In *Environment Lower-Saxony. Research in the area of renewable energy sources: Expert discussion with scientists from both parts of Germany. Proceedings.* Order Number DE95716361. Source: OSTI; NTIS (US Sales Only).

In this paper the following subjects are dealt with: 1. Methods of geothermal energy production; 2. Geotechnology; 3. Process technology; 4. Operating experience; 5. Economy of geothermal energy use. (HW)

2

Getting the most out of geothermal power. Phair, K.A. (Stone and Webster Engineering Corp., Denver, CO. (United States)). *Mechanical Engineering (United States)*; 116(9): 76-80 (Sep 1994).

This article reviews the current status of geothermal power. Commercial power plants are in service using vapor-dominated and liquid-dominated geothermal power. Meanwhile, research and development continues on hot dry rock resources. The thermal energy in geothermal fluids is absorbed from the surrounding geologic formations over a period of time. When the rate of energy extraction to generate electric power exceeds the natural recharge rate, energy production from the reservoir declines. For reasons ranging from contract issues to traction, the potential variations in the geothermal energy sources were not included in the original design of these power plants. By necessity, existing plants are being modified to respond to changes in resource supply conditions.

3

Geothermal energy research and development. Fridleifsson, I.B. (United Nations Univ. Geothermal Training Programme, Reykjavik (Iceland)); Freeston, D.H. *Geothermics (International Journal of Geothermal Research and its Applications) (United Kingdom)*; 23(2): 175-214 (Apr 1994).

Today, electricity is generated from geothermal energy in 21 countries. The installed capacity is nearly 6300 MW-electric. Four developing countries (El Salvador 18%, Kenya 11%, Nicaragua 18% and Philippines 21%) produce over 10% of their total electricity from geothermal. Electric generation cost is commonly around 4 US cents/kWh. Direct

utilization of geothermal water is known in about 40 countries, thereof 14 countries have each an installed capacity of over 100 MW-thermal. A worldwide survey shows that the total investments in geothermal energy between 1973 and 1992 amounted to approximately 22 billion US\$. During the two decades, 30 countries invested each over 20 million US\$, 12 countries over 200 million US\$, and 5 countries over 1 billion US\$. During the first decade, 1973-1982, public funding amounted to 4.6 billion US\$ and private funding to 3 billion US\$. During the second decade, 1983-1992, public funding amounted to 6.6 billion US\$ and private funding to 7.7 billion US\$. The relative economic viability of geothermal energy will improve significantly if and when a pollution tax is endorsed on power production using fossil fuels. Geothermal exploration and exploitation requires skills from many scientific and engineering disciplines. International geothermal training centers are operated in Iceland, Italy, Japan, Mexico, and New Zealand. The International Geothermal Association was founded in 1988 and has over 2,000 members in all parts of the world.

4

Study mission report on geothermal development in Philippines and New Zealand. Part 2. New Zealand (Geothermal energy resources in New Zealand). Nonoguchi, M. (Japan Geothermal Energy Association, Tokyo (Japan)); Takada, T. *Chinetsu (Journal of the Japan Geothermal Energy Association) (Japan)*; 30(5): 50-54 (28 Feb 1994). (In Japanese).

New Zealand is situated in the plate boundary part of the Pacific Plate and India-Australia Plate. The boundary of the surrounding plates runs from the Kermadec Trench located in northeast of the North Island through east of the North Island, and the subsiding zone shows a westerly inclination there. On the other hand, the subsiding zone is connected to Puysegur Trench southwest of the South Island, but the subsiding zone shows an easterly inclination there. In the middle part of the both subsiding zones, the Alpine Fault of the South Island exists. It is believed that the various volcanic activities and geothermal phenomena occur accompanied with these tectonic structures. The geothermal zones are divided roughly into 4 groups based on their distribution. Out of them 3 groups distribute in the North Island and they are classified into the Northland, Hauraki and Rotorua-Taupo from north. Only the Rotorua-Taupo shows the active surface geothermal signs. On the other hand, as the geothermal regions of the South Island, the hot springs being distributed in the middle parts of this island along the Alpine Fault are pointed out. 3 refs., 3 figs.

GEOLOGY AND HYDROLOGY OF GEOTHERMAL SYSTEMS

Refer also to citation(s) 29

5

Possibility determination for reinjection of used geothermal waters. Anovski, T. (Skopje Univ. (Yugoslavia)); Verbovsek, R.; Andonovski, B.; Minceva, B.; Naunov, J. *Renewable Energy (United Kingdom)*; 5(5-8): 1492-1494 (Aug 1994). (CONF-940904-: World renewable energy congress, Reading (United Kingdom), 11-16 Sep 1994).

Part 2 of 3, edited by A.A.M. Sayigh. (Pt.1: v.5(1-4)).

Due to extensive exploitation of the geothermal waters from Podlog -Banja, Kocani, Macedonia, water level of the local aquifer, is decreasing by up to 10 m/y. With the aim of preserving the natural conditions of the aquifer, a research programme including an experiment on reinjection of the used geothermal water was performed. On the basis of the results obtained so far, a value of $t = 30$ years for a period of safe exploitation without any changing of the temperature, was established. (author)

6

Seismic velocity and attenuation structure of the Geysers geothermal field, California. Zucca, J.J. (Lawrence Livermore National Lab., CA (United States)); Hutchings, L.J.; Kasameyer, P.W. *Geothermics (International Journal of Geothermal Research and its Applications) (United Kingdom)*; 23(2): 111-126 (Apr 1994).

The Geysers geothermal field is located in northern California and is one of the world's largest producers of electricity from geothermal energy. A key resource management issue at this field is the distribution of fluid in the matrix of the reservoir rock. In this paper, the authors interpret seismic compressional-wave velocity and quality quotient (Q) data at The Geysers in terms of the geologic structure and fluid saturation in the reservoir. Their data consist of waveforms from approximately 300 earthquakes. Using compressional-wave arrival times, they invert for earthquake location, origin time, and velocity within a three-dimensional grid. Using the pulse width of the compressional wave, they invert for the pulse width contribution associated with the source and the one-dimensional Q structure. They find that the velocity structure correlates with known mapped geologic units. The dry steam reservoir, which is known from steam well drilling, is mostly correlated with low velocity. The correlation is best for those areas where the steam pressure has been reduced by production. The Q increases with depth to the top of the dry steam reservoir and decreases with depth within the reservoir. This decrease of Q with depth suggests that the liquid saturation of the reservoir rock matrix increases with depth.

7

Numerical simulation study of the Northwest Geysers geothermal field, a case study of the Coldwater Creek steamfield. Antunez, E.U. (Lawrence Berkeley Lab., CA (United States)); Bodvarsson, G.S.; Walters, M.A. *Geothermics (International Journal of Geothermal Research and its Applications) (United Kingdom)*; 23(2): 127-141 (Apr 1994).

Commercial exploitation of the Northwest Geysers began in early 1988. To date, little has been published about the connectivity of this area to the rest of the geothermal field, the interaction between the so-called "typical" reservoir and the underlying high-temperature zone, or the combined potential of both producing horizons. To investigate these issues, a dual-porosity numerical model of The Geysers geothermal system with special emphasis to the NW Geysers was developed. The model was calibrated using

production data from 1957 to early 1991. Simulation results and the measured data suggest that: the typical reservoir in NW Geysers is connected to the rest of the field; significant migration of fluids from this part of the reservoir to the rest of The Geysers has occurred; and there still are some undeveloped areas in the NW Geysers with production potential. The production/injection scenarios analyzed with the model suggest that the existing wells are not sufficient to sustain a 60 MWe operations for 30 years starting in 1991. However, the addition of new wells within the licensed boundaries of the Coldwater Creek steamfield, drilled over a period of years, could sustain the steam production required to generate 60 MWe for 30 years. A 130 MWe development is not feasible within the mid-1993 licensed boundaries.

8

Theoretical analysis of heat transfer in semi-infinite aquifer. Mongelli, F. (Univ. di Bari (Italy). Dipt. di Geologia e Geofisica). *Geothermics (International Journal of Geothermal Research and its Applications) (United Kingdom)*; 23(2): 143-150 (Apr 1994).

A simple model for temperature within an unconfined semi-infinite aquifer is proposed with ground water flowing perpendicular to heat flow. The authors results show that it is possible to correct the observed geothermal gradient in order to obtain the undisturbed gradient, to identify the portion of the aquifer where the perturbation produced by water motion is unimportant, and to recognize the depth and distance from the recharge zone where water temperature is higher and can be exploited for low enthalpy utilization.

9

Numerical simulation of spring water discharge.: Characteristics and application of a nonlinear two-hole tank model. Oyama, M. (Hot Springs Research Inst. of Kanagawa Prefecture, Kanagawa (Japan)); Mizuno, A. *Chikassui Gakkaishi (Journal of Groundwater Hydrology) (Japan)*; 36(1): 1-11 (28 Feb 1994). (In Japanese).

A new simulator is developed which is based on the nonlinear 2-hole a tank model proposed by Sugahara in 1972. The simulator is applied to Ubako hot spring at Hakone volcano to study the responsive relation between precipitation and discharge as well as dynamic properties due to discharge by providing artificial precipitation. Ubako hot spring can be considered as comprising a system which corresponds to the two-hole a tank model which shows short time response between the input (precipitation) and the output (discharge) because it dries up in the dry season and starts discharge when precipitation increases showing sensitive reaction of discharge to precipitation. It is estimated that the amount corresponding to 25% of the built-up groundwater is discharged from Ubako spring, and the 75% remainder penetrates into the abyssal groundwater layer or flows into springs at the foot of mountains. The numerical solution shows good agreement with the measured values proving the validity of the model for which discharge phenomenon is taken into consideration, and the change of the groundwater level which can not be observed visually can be estimated fairly concretely. 11 refs., 11 figs., 1 tab.

10

Groundwater chemistry of the Matsumoto Tunnel and surrounding area. Ii, H. (Shimizu Corp., Tokyo (Japan). Research Inst.); Misawa, S. *Chikassui Gakkaishi (Journal of*

Groundwater Hydrology (Japan); 36(1): 13-29 (28 Feb 1994). (In Japanese).

The spring water and the quality of the groundwater in the vicinity of the Matsumoto Tunnel located on an independent plateau are investigated to study the change in water quality of the precipitation originated groundwater. CO₂ gas pressure of the groundwater is estimated by the relationships between pH and HCO₃⁻ and between pH and Ca²⁺. The result shows that CO₂ gas pressure is low in the tunnel groundwater, and high in the surface water, groundwater in the upper part of the plateau, and in the midslope of the plateau. HCO₃⁻ is low in the groundwater, groundwater in the upper part of the plateau, and groundwater at the breast of the plateau, and is high in the tunnel groundwater. It seems that consumption of the dissolved CO₂ gas and the increase in Ca²⁺ are caused by the weathering of rocks. Carbon isotopic ratio indicates that the HCO₃⁻ in the groundwater in the upper part of the plateau, midslope of the plateau, and in the tunnel are originated from ground organic substances, and deep well water indicates that HCO₃⁻ is supplied from minerals. Sulfur isotopic ratio indicates that SO₄²⁻ of the groundwater in the upper part of the plateau, in the middle part of the plateau, and in the tunnel is of the same origin. 17 refs., 13 figs., 2 tabs.

11

Study mission report on geothermal development in Philippines and New Zealand. Part 1. Philippines (Geology and reservoir). Abe, S. (Japan Geothermal Energy Association, Tokyo (Japan)); Kihara, Y.; Takao, S.; Ota, T. *Chinetsu* (Journal of the Japan Geothermal Energy Association) (Japan); 30(5): 16-25 (28 Feb 1994). (In Japanese).

A distinctive feature of the geothermal development in the Palimpinon is that a geothermal fluid is produced from the plutonic rock bodies and consequently its depth is as deep as some 3000m. This region is situated in a location, the Central-Visayan active fault cut through the Philippines longitudinally cuts across the Negros. Because an existence of the geothermal reservoirs was strongly expected based on the various data, the wells Negros 1 and 2 with a drill length of 600m were drilled in the lower landside of the Okoy-Valley in 1976. The deep drilled wells, Okoy 4 (2130m), Okoy 5 (1975.2m) exhibited a high temperature of 299°C and 310°C, respectively, and furthermore Okoy 5 has shown a production capacity of about 8MW. The Bacon-Manito region is located near the southern end of the Luzon, and in addition in about 80km south of the Tiwi geothermal region. The geology composing this region is the Quaternary volcanic ejecta, and mainly constituted of the pyroxene andesite. A geothermal development on a large scale has been commenced since 1977, and 2 wells with a medium depth were drilled in a region showing a low resistivity. 2 refs., 8 figs., 2 tabs.

12

Heat transfer in a hot dry rock with a complex-shaped fracture network. Akibayashi, S. (Akita Univ., Akita (Japan). Mining College); Sugimoto, F.; Fukuda, M. *Chikasui Gakkaishi* (Journal of Groundwater Hydrology) (Japan); 36(1): 31-44 (28 Feb 1994). (In Japanese).

An analytic method in which finite element and difference methods are combined is proposed to simulate heat transfer in a hot dry rock with a complex-shaped fracture network. The validity of this analytic method and the effects of the shape of fracture network, injection rate, and the number of

fractures on the production temperature and cumulated recovery factor of heat are elucidated, and fundamental data for the design and evaluation of dry high temperature rock artificial reservoir layer are obtained. This analytic method can be applied to the analysis of heat transfer in fracture networks with various kinds of shape, and is found to be adequate for the purpose. Even when the total lengths of the fractures crossing and conducting each other are the same, the temperature of the production fluid is different according to the shape of fracture network. The recovery factor of heat is improved by forming many fractures at equal intervals in the entire area of the high temperature rock which is the object of study. The injection rate must be determined by considering both the available temperature of production fluid and the period of heat recovery. 16 refs., 12 figs.

13

Estimation for aging of well presuming opening ratio of well screen. Ichikawa, T. (Kyushu Tokai Univ., Kumamoto (Japan). Faculty of Engineering); Hoshida, Y.; Hamano, K.; Tokuhira, A. *Chikasui Gakkaishi* (Journal of Groundwater Hydrology) (Japan); 36(1): 45-53 (28 Feb 1994). (In Japanese).

Using a laboratory experimental sand model device, the relational expressions among the pump discharge rate of flow, the resistance of well screen, and the opening ratio of well screen are formulated to grasp the opening ratio of the well screen quantitatively, and a method for the evaluation of clogging (aging of well) is proposed. As an example of the applications, analysis of the laboratory sand model tests using two kinds of methods and evaluation of well screen opening ratio are performed for about one year and a half to estimate the conditions of aging of wells. The opening ratio of the well screen can be estimated by empirical equations if the well loss can be estimated. As a result of long period pumping experiments, it is found that the decrease in the opening ratio of well screen of a pumping well with a short time shutdown can be prevented better than that of well screen of the one which is stopped for a longer period of time. As a result of application to a field pumping test, large decrease in the opening ratio of the well screen is found for one of the two wells, and it is found that the deterioration of the well efficiency can be quantitatively evaluated. 6 refs., 10 figs.

14

Study mission report on geothermal development in Philippines and New Zealand. Part 2. New Zealand (Geology and reservoir). Nonoguchi, M. (Japan Geothermal Energy Association, Tokyo (Japan)); Kawazoe, S.; Ono, J. *Chinetsu* (Journal of the Japan Geothermal Energy Association) (Japan); 30(5): 54-62 (28 Feb 1994). (In Japanese).

The Wairakei geothermal zone is located in west bank of the Waikato river away from about 10km from the Taupo to north. The geology is composed of the volcanic rocks and sedimentary rocks, which have blown out or sedimented in the graben region called the Taupo-Rotorua depression zone and moreover they were chronologically new (0.5-1.0 million years ago). The reservoirs in this region are set up their ranges based on the low resistivity zones, and consequently show an area of about 15km². Because the Tauhara region located about 8km southeast from the Wairakei region is situated in a range of the same low resistivity zone, an area including this region forms a large geothermal zone amounting to about 30km². The Ohaaki geothermal zone is

situated along the Waikato river some 20km away from the Wairakei to northeast. The basement rock is the Mesozoic Graywacke (hard sandstone) as same as the Wairakei region. Although there is an irregular unevenness on an upper surface of the basement rock, it generally inclines from east to west. The main geothermal reservoirs are contained in the Waiora Upper Formation and the Rautawiri Breccia Formation. 6 refs., 9 figs.

15

Study on cation exchange reaction in undisturbed soil columns of farm land. Hiroshiro, Y. (Kyushu Univ., Fukuoka (Japan). College of General Education); Yokoyama, T.; Jinno, K.; Wada, S.; Ichikawa, T.; Sato, S. *Chikasu Gakkaishi (Journal of Groundwater Hydrology) (Japan)*; 36(1): 55-69 (28 Feb 1994). (In Japanese).

In order to learn the behavior of cation in cation exchange reaction which is observed when potassium is applied to a farm land and to evaluate the cation exchange capacity and selectivity coefficients, soil is collected from a farm land in undisturbed condition for a laboratory column experiment to investigate the mechanism of the transport which is required for modeling. The cation exchange capacities (CEC) of the used farm land soil are different for the top layer considered to contain organic material and for the lower layer whose main component is decomposed granite soils, and the CEC of the top layer has a larger value. The presence of Na^+ can be negligible, and ion exchange reaction can be combined into a material transport model comparatively easily if simplification is made so that almost constant value of $K_{\text{Ca/Mg}}$ can be used irrespective of the ion composition of the soil, and $K_{\text{Ca/K}}$ is approximated as the the molar ratio of adsorbed K^+ . 15 refs., 18 figs., 3 tabs.

GEOTHERMAL EXPLORATION AND EXPLORATION TECHNOLOGY

Refer also to citation(s) 32

16

(DOE/AL/73394-T1-Exec.Summ.)

Alpine 1/Federal: Executive summary final report. Witcher, J.C. (New Mexico State Univ., Las Cruces, NM (United States). Southwest Technology Development Inst.). Arizona Energy Office, Phoenix, AZ (United States). Apr 1994. 20p. Sponsored by USDOE, Washington, DC (United States). DOE Contract FG04-91AL73394. Order Number DE94017948. Source: OSTI; NTIS; GPO Dep.

This summary report overviews a State of Arizona and US Department of Energy funded drilling project to determine if near-term hot dry rock (HDR) geothermal potential exists in the eastern portion of the White Mountains region of Arizona. A 4,505 feet deep slim-hole exploratory well, Alpine 1/Federal, was drilled within the Apache-Sitgreaves National Forest at Alpine Divide near the Alpine Divide camp ground about 5 miles north of Alpine, Arizona in Apache County (Figure 1). A comprehensive technical report, in two parts, details the results of the project. Part 1, Alpine 1/Federal, Drilling Report discusses the drilling operations, logging program, permitting and site selection for the hole. Part 2, Temperature Gradients, Geothermal Potential, and Geology,

summarizes the temperature gradients, heat flow, geothermal potential, and subsurface geology.

17

(DOE/AL/73394-T1-Pt.1)

Alpine 1/Federal: Drilling report: Final report, Part 1. Witcher, J.C. (New Mexico State Univ., Las Cruces, NM (United States). Southwest Technology Development Inst.); Pisto, L.; Hahman, W.R.; Swanberg, C.A. Arizona Energy Office, Phoenix, AZ (United States). Jun 1994. 99p. Sponsored by USDOE, Washington, DC (United States). DOE Contract FG04-91AL73394. Order Number DE94017949. Source: OSTI; NTIS; GPO Dep.

Regional geologic and geophysical surveys, shallow temperature-gradient drilling, and published reconnaissance geothermal studies infer possible hot dry rock (HDR) geothermal resources in the Alpine-Springerville area. This report discusses the results of a State of Arizona and US Department of Energy funded drilling project designed to gather the deep temperature and stratigraphic data necessary to determine if near-term HDR geothermal potential actually exists in this portion of the White Mountains region of Arizona. A 4505 feet deep slim-hole exploratory well, Alpine 1/Federal, was drilled within the Apache-Sitgreaves National Forest at Alpine Divide near the Alpine Divide Camp Ground about 5 miles north of Alpine, Arizona in Apache County (Figure 1).

18

(DOE/AL/73394-T1-Pt.2)

Alpine 1/Federal: Temperature gradients, geothermal potential, and geology: Final report, Part 2. Witcher, J.C. (New Mexico State Univ., Las Cruces, NM (United States). Southwest Technology Development Inst.); Hahman, W.R.; Swanberg, C.A. Arizona Energy Office, Phoenix, AZ (United States). Jun 1994. 127p. Sponsored by USDOE, Washington, DC (United States). DOE Contract FG04-91AL73394. Order Number DE94017950. Source: OSTI; NTIS; GPO Dep.

The Alpine 1/Federal drilling project provided valuable new information on the geology of the region. Except for drilling into Precambrian rocks, the objectives of the project were accomplished. sufficient temperature and heat-flow information were obtained to assess the near-term HDR geothermal potential of the eastern White Mountains region. Therefore, the primary mission of the project was successful. The HDR potential for near-term electrical power production is not economic. Potential for HDR direct-use space heating is marginal at best and should realistically be considered uneconomic. The Alpine 1/Federal hole should be deepened to Precambrian basement to provide definitive subsurface geological information for this region. Deeper drilling will determine Precambrian lithology and assess if older Paleozoic rock units are present. The hole may be deepened with a BQ drill string. Depth to Precambrian is likely to be between 800 and 2,000 feet below the current 4,505 feet total depth. The failure to reach Precambrian basement due to a previously unknown and unmapped major structural offset highlights the need for detailed surface geological mapping in this poorly understood region.

19

(ETDE/JP-mf-95714824)

Technological verification of geothermal exploration in 1992.: Development of fractured reservoir exploration

and electromagnetic wave-utilizing exploration (development of array CSMT). New Energy and Industrial Technology Development Organization, Tokyo (Japan). Mar 1993. 138p. (In Japanese). Order Number DE95714824. Source: OSTI; NTIS; Available from New Energy and Industrial Technology Development Organization, Sunshine 60, 30F 1-1, 3-chome, Higashi-Ikebukuro, Toshima-ku, Tokyo, Japan.

An efficient array CSMT (Controlled Source Magnetotellurics) survey system was developed to explore, very accurately on the ground surface, the geothermal reservoir-related fractured zone. Survey stations were set in array on the survey line with an artificial signal transmitter. A 16-channel system was experimentally prepared which could accurately and stably receive even very weak signals. Improvement was made in automatic frequency-switching function and operational performance. Software was also improved in data processing, analysis and display. An application experiment was conducted in Sengan area where the existence of a fractured geothermal reservoir was confirmed. The experimentally obtained resistivity was compared with that from the already known geological structure and logging data. In the survey area, measurement was made at 342 stations set up, with an interval of 50m, on twelve 1.4km-long parallel survey lines. In the above CSMT survey area, a high accuracy MT survey was also conducted at 42 stations. Though the area was comparatively high in noise level, good data could be obtained. In Sengan area, the resistivity structure is divided into three layers, i.e, highly resistive overburden, extremely low resistivity intermediate layer and medium resistivity deep layer. Several detected low resistivity zones which express the geothermal alteration reflect the fractured structure and altered zone. 13 refs., 32 figs., 7 tabs.

20

(SAND-94-0551)

Steamboat Hills exploratory slimhole: Drilling and testing. Finger, J.T.; Jacobson, F.D.; Hickox, C.E.; Eaton, R.R. Sandia National Labs., Livermore, CA (United States). Oct 1994. 102p. Sponsored by USDOE, Washington, DC (United States). DOE Contract AC04-94AL85000. Order Number DE95002956. Source: OSTI; NTIS; GPO Dep.

During July-September, 1993, Sandia National Laboratories, in cooperation with Far West Capital, drilled a 4000 feet exploratory slimhole (3.9 inch diameter) in the Steamboat Hills geothermal field near Reno, Nevada. This well was part of Sandia's program to evaluate slimholes as a geothermal exploration tool. During and after drilling the authors performed four series of production and injection tests while taking downhole (pressure-temperature-spinner) and surface (wellhead pressure and temperature, flow rate) data. In addition to these measurements, the well's data set includes: continuous core (with detailed log); borehole televiwer images of the wellbore's upper 500 feet; daily drilling reports from Sandia and from drilling contractor personnel; daily drilling fluid record; numerous temperature logs; and comparative data from production and injection wells in the same field. This report contains: (1) a narrative account of the drilling and testing, (2) a description of equipment used, (3) a brief geologic description of the formation drilled, (4) a summary and preliminary interpretation of the data, and (5) recommendations for future work.

21

(UCRL-JC-117285)

Microearthquake monitoring and seismic imaging at The Geysers. Zucca, J.J. (Lawrence Livermore National Lab., CA (United States)); Hutchings, L.; Bonner, B.; Kasameyer, P.; Majer, E.L.; Peterson, J.; Romero, A.; Kirkpatrick, A. Lawrence Livermore National Lab., CA (United States). Jun 1994. 7p. Sponsored by USDOE, Washington, DC (United States). DOE Contract W-7405-ENG-48. (CONF-9404102-7: 12. geothermal program review: geothermal's role in global climate change - impacts on the Climate Change Action Plan, San Francisco, CA (United States), 25-28 Apr 1994). Order Number DE95002391. Source: OSTI; NTIS; GPO Dep.

We are monitoring two high-frequency, high-resolution microearthquake networks at The Geysers. The first network consists of 16 stations and is located in the northwest portion of the Geysers. This array is in an area that is representative of a high-temperature, deep, reservoir environment. The second network consists of 13 stations located in the southeast Geysers around the location of the cooperative injection experiment. We are using the data from the networks to compute velocity and attenuation images and earthquake parameters such as precise location and rate and manner of energy release. Our goal is to evaluate the use of this information to manage steam release from geothermal reservoirs. We are supporting this effort with laboratory measurements of velocity and attenuation on Geysers core samples under varying degrees of saturation to help us better interpret our seismic images. To date we find that microearthquake activity follows injection activity, and the dry, low-pressure portions of the reservoir are characterized by low velocity and high attenuation.

22

Geothermal heat from dry rock. Walter, F. (Faculteit der Mijnbouwkunde en Petroleumwinning, TU Delft, Delft (Netherlands)). *Duurzame Energie (Netherlands)*; (6): 32-33 (Oct 1994). (In Dutch).

A brief overview is given of the research on the hot dry rock (HDR) technology in Japan, North-America and Europe. Also attention is paid to the principles and advantages of HDR. 3 ills.

23

Detection of stratified structure of thermal groundwaters by a drilling in the southern part of the Beppu hydrothermal system, Japan. Yusa, Y. (Kyoto Univ., Kyoto (Japan). Faculty of Science); Kitaoka, K.; Kamiyama, K.; Takemura, K. *Onsen Kagaku (Journal of the Balneological Society of Japan) (Japan)*; 44(2): 39-44 (30 Jun 1994). (In Japanese).

A drilling of thermal groundwater experimental well was carried out from November, 1987 to February, 1988 to detect the stratified structure of the thermal groundwater flow system and secure an observation base for long term monitoring. Various obtained data, outline of the flow system, and the method of drilling and water collection were reported together with the result of the drilling. As a result of 300m deep drilling and collection and analysis of water at every 50m depth, the existence of the stratified structure of thermal ground water was confirmed. Characteristic vertical distribution was found in which the temperature reached the maximum (151.3°C) at the depth of 230m and lowered in deeper area. It was unexpected that the water had lower temperature at 300m depth than that above and was of

HCO₃ type, and the fact was a new knowledge obtained by the drilling. It is considered that chloride type geothermal water flows laterally from the southwestern upland, and maintains high temperature conditions in the area centering around 230m depth. 6 refs., 3 figs., 2 tabs.

24

Thermal water flow systems in the Higashine hot spring area, Yamagata Prefecture, Japan. Urakami, K. (Hokkaido Univ., Sapporo (Japan). Faculty of Science). *Onsen Kagaku (Journal of the Balneological Society of Japan) (Japan)*; 44(2): 45-73 (30 Jun 1994). (In Japanese).

Such field tests as electrical exploration, pumping test, analysis of hot spring isotopes, continuous observation of water level were carried out at Higashine hot spring area, Yamagata Prefecture, Japan, and numerical calculation was performed to investigate the thermal water flow system. Considerable difference was observed between the concentration of major anions and the composition ratio. At most of the spring sources in this area, hot water was pumped through multilayered screen, and groundwater of upper layer was mixed during pumping up. By the result of measurement of vertical soil temperature distribution made using disused wells, it became clear that there were the upper thermal aquifer and the lower thermal aquifer, and the structure was such that they would not mix each other directly. From 17.3 to 74.4 cm²/s were obtained for the transmissivities of thermal aquifers. From the result of numerical calculation, it is estimated that the system requires a structure wherein groundwater will not flow directly to aquifers and low permeable layers are distributed to the north of the hot spring area to suppress the extension of hot spring northward. 10 refs., 30 figs., 4 tabs.

25

Polymetallic sulfides on the off-axis volcanoes around the East Pacific rise; 11°30' north latitude. Kuriyama, T. (Deep Ocean Resources Development Co. Ltd., Tokyo (Japan)); Fujioka, H.; Matsumoto, K. *Shigen Chishitsu (Mining Geology (Tokyo, 1992)) (Japan)*; 44(245): 187-199 (20 Jun 1994). (In Japanese).

A report is made on the 2 seamounts in the East Pacific rise which are investigated during the period from 1990 to 1992 and found to have large scale mineralized zones. It is found that hydrothermal mineral deposits are concentrated and distributed between 12°41' N and 12°59' N as well as between 11°20' N to 11°35' N. In the seamount line along 11°30' N, 2 seamounts out of 5 are confirmed to have mineralized zones. The common points of the mineralized zones of the 85D-C, 85D-D, C, and D1 seamounts are about less than 1km distance from the crest to the mineral deposit and less than 100m difference in the elevation between crests. The thermal activity of the mineralized zones of the C and D1 seamounts seems to be inactive judging from little locations having abnormal water temperatures and the distributed conditions of hydrothermal organism. In addition, it is found that sulfide ore, brown precipitates, and siliceous precipitates seem to be distributed on sheet lava cumulatively from the bottom roughly in the respective sequence as thermal water precipitates. 12 refs., 10 figs., 2 tabs.

26

Temperature in a test pit measured by optical fiber and a laser. Sato, Y. (National Inst. for Resources and Environment, Tsukuba (Japan)); Narita, T.; Kuriyagawa, M.; Ishida,

T.; Mizuta, Y.; Sakai, O.; Maru, H. *Nippon Chinetsu Gakkaishi (Journal of the Geothermal Research Society of Japan) (Japan)*; 16(2): 173-183 (25 Apr 1994). (In Japanese).

A method of the use of optical fiber and laser has been developed as a means for continuous measuring of the temperature distribution on a line. The performance of the system is evaluated in a laboratory, and temperature change with time in a test boring pit is measured for half a month to study the possibility of the application of the system. The optical fiber is inserted 145m into the pit along the boring rod. The fiber strand is jacketed by a 1.2mm diameter stainless tube to improve the strength and the easiness of handling. This measuring method is useful for the purpose of long term and stable measurement of the changes in relative temperatures. The temperature at the hot water inflow point is biased from the right one and must be corrected. As regards the distance, slacking and extension of fiber must be corrected, otherwise they must be compensated basing on other measurement results. Proper improvement in the method of jacketing fiber strand by a metal tube will contribute to the solution of handling problem. 3 refs., 8 figs.

27

Simulation of heat extraction test through natural joints zone at Toyoha mine. Tenma, N. (National Inst. for Resources and Environment, Tsukuba (Japan)); Kuriyagawa, M.; Mizuta, Y.; Ishida, T.; Yamashita, M.; Sakai, O.; Zyvoloski, G. *Nippon Chinetsu Gakkaishi (Journal of the Geothermal Research Society of Japan) (Japan)*; 16(2): 185-202 (25 Apr 1994). (In Japanese).

Three heat extraction tests were carried out since 1991 using natural joints zone at Toyoha mine as a reservoir layer. The mineral vein studied for heat extraction and the surrounding rock mass were modeled to simulate heat extraction basing on the results of heat extraction tests and rock mass investigation. In the heat extraction tests, water was injected into a borehole, flowed through natural joints, and was recovered as hot water. The natural water flow through the vein was in both vertical and horizontal direction. The temperature change in 4 days after water injection at the recovery hole, which was observed by the heat extraction tests, was shown also by the model. It was made clear by the simulation that the injection flow rate of 0.67kg/s had little effect on the temperature and the flow rate of water from production boreholes because the natural water flow through the vein was considerably larger. 14 refs., 11 figs., 1 tab.

28

Study mission report on geothermal development in Philippines and New Zealand. Part 1. Philippines (Drilling). Chinju, J. (Japan Geothermal Energy Association, Tokyo (Japan)); Sato, Y. *Chinetsu (Journal of the Japan Geothermal Energy Association) (Japan)*; 30(5): 25-31 (28 Feb 1994). (In Japanese).

According to PNOC and EDC of the Philippines, a geothermal power generation capacity of total nation in the end of 1993 is as large as 1044MW in 5 regions, and furthermore an expansion of 1673MW is planned by 1998. Based on a concrete plan in this plan, 159 wells for the exploration, production and reduction wells are required by 1997, and it is said that 10 more rigs are necessary for the job and on top of them 2 more rigs are needed under a contract with the PNOC-EDC. In such circumstances, in the

existing Palimpinon region, 2 exploration wells are planned in 1993, and 3 production wells are planned by 1995-97. This region is situated in the mountains (altitude 450-600m) and the drilling was initiated in 1976. By the time of 1980, 21 wells were drilled, and based on an analysis of these data, 3 problems on drilling are pointed out. Namely they are the site problems (at the most secluded place among the mountains, rainy season and high cost), the problems on the directional drilling (maximum deviation distance 1500m) and the hard rock problems. 10 figs., 3 tabs.

29

Study mission report on geothermal development in Philippines and New Zealand. Part 2. New Zealand (Exploration and geology). Nagano, H. (Japan Geothermal Energy Association, Tokyo (Japan)); Suzuki, K. *Chinetsu (Journal of the Japan Geothermal Energy Association) (Japan)*; 30(5): 73-83 (28 Feb 1994). (In Japanese).

The Waiotapu geothermal region is located in the northern end of the Reporoa valley, which is 23km south-southwest of the Rotorua City situated in the North Island of New Zealand and, in addition, is about 45km north-northeast of Wairakei. An area of the geothermal region is about 17km², and consequently is the most extended in New Zealand. The geophysical exploration in this region was commenced in the 1950s. 9 hot springs were explored for investigating a heat flow and hydraulics in 1953. The electrical exploration was performed in the 1960s. Beside them, the magnetic exploration and gravity exploration have been executed, and moreover they were compared and investigated with the geological structure. The Orakeikorako region is located in about 19km north-northwest from the Wairakei geothermal zone. Although about 75% of the geothermal signs were now under water in this region because of a construction of the Ohaaki hydropower dam (1960), many geothermal indications such as the gas blowout, hot spring, alteration zone and so forth can be seen even today. The geological exploration in this region has been carried out in 1959 and 1972, and moreover, the airborne magnetic survey by a flight altitude of 350m and 60m above ground has been executed in 1986. 7 refs., 11 figs., 2 tabs.

ECONOMIC, INDUSTRIAL, AND BUSINESS ASPECTS

30

(DOE/EIS-0207)

Newberry Geothermal Pilot Project. USDOE Bonneville Power Administration, Portland, OR (United States). Sep 1994. 50p. Sponsored by USDOE, Washington, DC (United States). Order Number DE95001766. Source: OSTI; NTIS; GPO Dep.

BPA has decided to acquire 20 average megawatts (aMW) of electrical power from a privately-owned geothermal power plant on the west flank of Newberry Volcano in Deschutes County, Oregon. The Newberry Project will generate 30 aMW and will be developed, owned, and operated by CE Newberry, Inc. of Portland, Oregon. In addition, BPA has decided to grant billing credits to EWEB for 10 aMW of electrical power and to provide wheeling services to EWEB for the transmission of this power to their system. BPA expects the Newberry Project to be in commercial operation by

November 1997. BPA has statutory responsibilities to supply electrical power to its utility industrial and other customers in the Pacific Northwest. The Newberry Project will be used to meet the electrical power supply obligations of these customers. The Newberry Project will also demonstrate the availability of geothermal power to meet power supply needs in the Pacific Northwest and is expected to be the first commercial geothermal plant in the region. The Newberry Project was selected under the BPA Geothermal Pilot Project Program. The goal of the Program is to initiate development of the Pacific Northwest's large, but essentially untapped, geothermal resources, and to confirm the availability of this resource to meet the energy needs of the region. The primary underlying objective of this Program is to assure the supply of alternative sources of electrical power to help meet growing regional power demands and needs.

31

Geothermal energy. An old-new energy source. (Energie geothermique). Bronicki, L. pp. 91-98 of Nuclear energy and renewable energies. Societe Francaise d'Energie Nucleaire, Paris (France) (1994). 188p. (In French). (CONF-9211328—: Conference on Nuclear Energy and Renewable Energies, Paris (France), 27 Nov 1992).

Geothermal energy comes from the fusion of earth internal layers and the radioisotope decay. The geothermal zones are bound to tectonic plates and are to be found in volcano recent activity regions or where the earth's crust has become thinner. Geothermal heat sources have been widely used. It's not a renewable energy but a useful one. However geothermics use for electricity production has been only very limited. Present technologies are: direct use, electricity production. The seventies energy crisis promoted geothermal energy use which allows savings. Geothermal energy worldwide resources are extensive but the existing technologies must be improved. When geothermal energy is correctly used, it is renewable and generates no pollution, it is a clean energy because the recent reinjection technologies and the up-to-date geothermal systems exclude the toxic gas leaks towards atmosphere. Geothermal energy represents an important contribution in the developing countries which possess such resources.

32

The options for geothermal heat exploration in the Netherlands. Walter, F. (Faculteit der Mijnbouwkunde en Petroleumwinning, TU Delft, Delft (Netherlands)). *Elektrotechniek (Netherlands)*; 72(10): 604-607 (Oct 1994). (In Dutch).

The application of earth heat in Europe is increasing steadily. This is evident from, among other things, the fact that 29 proposed projects have been entered in connection with the last round of the European Community demonstration programme Thermie. At present, the installed capacity of low enthalpy applications in Europe is approximately 4,000 MW. The Dutch contribution is yet almost nil, which is a reason for taking a closer look at the possibilities that earth heat recovery offers within the framework of a permanent energy supply. Attention is paid to the possibilities for using geothermal heat for different water temperature levels (>90C, 65-90C, <65C, <20C), and the hot-dry-rock technology. 1 fig., 3 ills., 7 refs.

33

Electricity from geothermal energy: analysis of the trend to the year 2000. Dickson, M.H. (International Inst. for Geothermal Research, CNR, Pisa (Italy)); Fanelli, M. *Renewable Energy (United Kingdom)*; 5(5-8): 1483-1491 (Aug 1994). (CONF-940904--: World renewable energy congress, Reading (United Kingdom), 11-16 Sep 1994).

Part 2 of 3, edited by A.A.M. Sayigh. (Pt.1: v.5(1-4)).

At the beginning of the 1980s the installed geothermal electric capacity in the world was 1960 MW, rising to 3698.5 MW in 1985, and 5835.5 MW in 1990. At the beginning of 1993 the installed capacity had reached 5915 MW, an increase of 202% with respect to 1980. The percentage increase in installed capacity worldwide per annum in that same period, however, dropped from 13.5 in the 1980-1984 period to 9.6 in the period 1985-1989 and 0.5 in 1990-1992. Geothermal development has recently assumed a downward trend. There is evidence, however, to show that the situation will improve in the near future. Based on data from reliable sources, approximately 10,200 MW will be installed throughout the world by the year 2000, increasing 72% with respect to 1993 figures. The greatest increase (167%) is expected in Asia. The percentage increase per annum in the world in the period 1993-2000 should rise to 8.1. (author)

34

Study mission report on geothermal development in Philippines and New Zealand. Part 1. Philippines (Situation of affairs). Majima, T. (Japan Geothermal Energy Association, Tokyo (Japan)); Hosaka, T.; Tsuchiya, S.; Iwato, K.; Iizawa, T. *Chinetsu (Journal of the Japan Geothermal Energy Association) (Japan)*; 30(5): 13-16 (28 Feb 1994). (In Japanese).

Total power generation plant capacity of the Philippines in 1990 is approximately 6.87 million kW, and a composition ratio by each power source is constituted of about 55% of the thermal, about 32% of the hydro and 13% of the geothermal. Reflecting a national policy, 'getting rid out of petroleum oil', a thermal ratio is decreased about 14% compared with that in 1980. In addition, total power generation quantity is approximately 26.3 billion kWh, and shows about 1.5% increase compared with that in the previous year, and moreover an average growth rate of about 4% per annum for the past 10 years since 1980. As for the geothermal development in the Philippines, the Philippine National Oil Company (PNOC) is in charge of a steam division and the National Power Corporation (NPC) is in charge of a power generation division respectively. The geothermal power generation plant capacity is 940MW, and it is proud of the second largest scale in the world next to the States. The geothermal plants currently under construction are an expansion of 80MW in the Palimpinon, and a new geothermal plant of 95MW in the Bak-Man. As for a future development plan, according to a remark of a plant manager of PNOC, it is explained that a new geothermal generation plan toward 2005 is 1618MW. 1 fig., 1 tab.

35

Study mission report on geothermal development in Philippines and New Zealand. Part 2. New Zealand (Situation of affairs). Fujimoto, T. (Japan Geothermal Energy Association, Tokyo (Japan)); Yamanogami, Y.; Abe, N.; Yamamoto, A. *Chinetsu (Journal of the Japan Geothermal Energy Association) (Japan)*; 30(5): 44-50 (28 Feb 1994). (In Japanese).

Since a regular development of the natural gas resources such as the Maui gas field discovered offshore southwest of the Taranaki region in the North Island in 1969 and so forth has been advanced, a composition ratio of the energy sources has been substantially changed. A self supply ratio of the total energy at present is above 80%. Also in the beginning of the 21st century, it is forecasted that this self supply ratio can be maintained. As this nation has a country condition mainly composed of the agriculture, total energy demand and supply quantity was in a low level, and accordingly, total primary energy supply quantity in 1991 was 14.3 million tonnes equivalent in oil (TPES). A future supply quantity forecast is predicted to be 16.6 million tonnes TPES in 2005. Even when the largest gas field, the Maui gas field is depleted in the beginning of the 21st century, this prediction is in anticipation of a utilization of the Kupe South gas field offshore of southern Taranaki scheduled in production in 1995 and so forth. The geothermal power generation plant capacity is 296.4MW, and as a future development plan, total 225MW in 6 power plants are programmed. 3 figs., 5 tabs.

ENVIRONMENTAL ASPECTS

36

(NEDO-P-9316)

Survey report on geothermal energy development and the environment (landscape). 2. New Energy and Industrial Technology Development Organization, Tokyo (Japan). Mar 1994. 179p. (In Japanese). Order Number DE95714832. Source: OSTI; NTIS; Available from New Energy and Industrial Technology Development Organization, Sunshine 60, 30F 1-1, 3-chome, Higashi-Ikebukuro, Toshima-ku, Tokyo, Japan.

In the geothermal energy resource survey, a study being viewed from a landscape aspect was made on proper evaluation of the location and drawing-up of a landscape preservation policy. A, B, and C surveys are conducted for the geothermal energy development promotion; the landscape evaluation is made in B and C surveys where the regions for survey are 50-70 km² and 5-10 km², respectively, and the two-stage landscape survey is needed according to the progress of the investigation. In the primary landscape survey to grasp landscape characteristics, the survey is to be made for the region of 10 km² including that of survey B, and the environmental base information is analyzed using the existing literature and the administrative data published, as a rule. In the computer mesh analytical method, a mesh size is to be 250m. In the secondary landscape survey to evaluate landscape characteristics, separate plans for investigating the present situation are worked out to acquire data on the present situation. The appropriate mesh size is 50. By this, a large-bore well drilling area which is a future production well base is determined, and a landscape preservation policy is worked out such as an installation plan for the whole geothermal power generation facilities. 13 refs., 35 figs., 27 tabs.

37

Study mission report on geothermal development in Philippines and New Zealand. Part 1. Philippines (Location management and environment issue). Yuasa, Y.

(Japan Geothermal Energy Association, Tokyo (Japan)); Suetake, S. *Chinetsu (Journal of the Japan Geothermal Energy Association) (Japan)*; 30(5): 43 (28 Feb 1994). (In Japanese).

Because the Philippines is a non-oil producing country as same as Japan, and 94 % of energy depends on an import, it is extremely active for a geothermal development. Since the Geothermal Law was proclaimed in 1967, and at the same time the Uion Oil Company marched in this country, a geothermal development made rapid progress and the geothermal power generation plant capacity is currently 894MW and has the second position in the world next to the United States. When a geothermal development is carried out in the Philippines, an approval relating to an environment is necessary. A main constituent of the gas blowing out from a geothermal well together with a steam and hot water is CO₂. CO₂ is not a pollution substance different from SO_x and NO_x. Accordingly, H₂S is a substance affecting the biggest influence on an environment. However, no large problem has occurred in the site and environmental aspects so far. Out of the chemical constituents contained in the geothermal hot water, the constituents being worried about an influence on the environment are As, B, H₂S and so forth. Nevertheless, generally speaking in Japan, total quantity of the geothermal hot water is returned back underground, and consequently no problem occurs. In the Philippines as well, the steam condensed water is reduced underground. 2 tabs.

38

Study mission report on geothermal development in Philippines and New Zealand. Part 2. New Zealand (Location management and environment issue). Nakamura, N. (Japan Geothermal Energy Association, Tokyo (Japan)); Baba, T. *Chinetsu (Journal of the Japan Geothermal Energy Association) (Japan)*; 30(5): 86-90 (28 Feb 1994). (In Japanese).

New Zealand is situated from 34 degrees to 47 degrees of south latitude and from 167 degrees to 179 degrees of east longitude, and consequently it is very similar to Japan unexpectedly. In the North Island extremely similar to Hokkaido there are many volcanoes, and there is a large geothermal region especially in the middle on the island. In contrast to it, in the long and slender South Island, the ridges of 3000m class stand in a line a little bit close to the west coast, and furthermore the huge glaciers cover near the top of peaks. Due to a plenty of places of scenic beauty, there are many natural parks as well, and their areas occupy about 10% of total land area of entire nation. The promising region for the geothermal resources is outside the natural park. Therefore there is no need to do even the geothermal development, and actually is doing nothing. The Ohaaki geothermal power generation plant is the most modern geothermal power plant with an output of 116.2MW commenced operation in 1989. This development was planned by the planning approval based on the City Planning Act and the Local Planning Act, the water rights based on the Water Quality Management Act and the Soil Management Act, and the Atmospheric Cleaning Act, and then the Environmental Impact Assessment was made in 1977, and subsequently the prudent development is being advanced. 3 refs., 2 figs.

GEOTHERMAL POWER PLANTS

39

Letter from Yamagawa geothermal power plant. *Denryoku Doboku (Electric Power Civil Engineering) (Japan)*; (251): 131-133 (31 May 1994). (In Japanese).

At present, ten geothermal plants with total capacity of about 270 MW are operating in Japan. Kyushu Electric Power Co., Ltd. has three units with total capacity of 122.5 MW, which corresponds to 45 % of total capacity in Japan. In addition these three plants, the company decided to build the fourth geothermal power plant in Yamagawa, Kagoshima Pref. The heat source of geothermal energy is the magma pool which was produced by the friction heat caused by the plate movement. They say that the volcanic activity took place some hundred thousand years ago in Yamagawa area. The rain water penetrates deeply into the ground and is heated up from 300 to 350°C by the magma pool to form the hot water reservoir. A remote operation-monitoring-control system is planned to be applied to the Yamagawa power plant. The operation and control are to be done at Sendai nuclear power plant which is apart from Yamagawa plant by about 80 km. No operator will be stationed to the Yamagawa plant. The construction office was built in April 1993. The temporary work was started in June 1993, and the foundation pillar placement was commenced in September 1993. Since then the construction work is proceeding smoothly. 2 figs., 2 tabs.

40

Study mission report on geothermal development in Philippines and New Zealand. Part 1. Philippines (Construction of Palimpinon II geothermal power station steam production plant and electric power generation plant). Ezaki, Y. (Japan Geothermal Energy Association, Tokyo (Japan)); Narita, M. *Chinetsu (Journal of the Japan Geothermal Energy Association) (Japan)*; 30(5): 31-36 (28 Feb 1994). (In Japanese).

The Palimpinon No.2 power generation plant is dispersed in 3 localities of the Nasuji, Okoy and Sogongon, and consequently each 1-2 sets of 20MW unit are allocated in each locality. Each of production base is located in an adjoining site to a power plant, and therefore it enhances the value of a dispersed allocation. The geothermal fluid is separated into steam and water through a separator installed in a production base, and then the geothermal steam is supplied to a power plant through one steam pipe line. The hot water piping coming out from a separator is branched off, and subsequently the one is delivered to the reduction well and the other is discharged to the pond. Since the new recent geothermal projects in the Philippines are the BOT projects by PNOC for 10 years, they have a system that the developers sell the power generated by the steam supplied by PNOC at no cost to PNOC, and then PNOC sells it to NPC furthermore. The Fuji Electric Co., Ltd. is in all of the plant engineering, equipment supply and installation work, and the NPC is in charge of the civil and construction work. 11 figs., 2 tabs.

41

Study mission report on geothermal development in Philippines and New Zealand. Part 1. Philippines (Construction of Bacon/Manito geothermal power station

steam production plant and electric power generation plant). Kurata, A. (Japan Geothermal Energy Association, Tokyo (Japan)); Saito, S. *Chinetsu (Journal of the Japan Geothermal Energy Association) (Japan)*; 30(5): 36-42 (28 Feb 1994). (In Japanese).

A site, in which the Bacon-Manito (Bac-Man) project is being deployed, is about 50 minutes from Manila by plane and it is forming a boundary between Albay and Sorsogon in the southernmost end of the Luzon. There is the existing Tiwi geothermal power plant in a location of about 50km by an air distance north-northwest from here. The Bac-Man is composed of the first phase (55MW $\times$ 2) and second phase (20MW $\times$ 2), and 2 units of the condensing turbine generator with 55MW delivered by the Ansaldo in the first phase has started operation since the end of 1993. The second phase is in a stage that the installation work is almost completed and the commissioning will be started. Although a construction period for the second phase is only 18 months, due to a higher rock hardness than anticipated originally and so forth, it is forecasted that it will be actually delayed by several months. The Toshiba Electric Equipment Corp. is in charge of a supply of the main electric equipments such as the generators and transformation facilities (GIS), and the Mitsubishi Heavy Industries, Ltd. is confronted with an organization that it has a responsibility to supply the all equipments including the condensers, and moreover to execute through the installation and commissioning of the entire plant. 14 figs., 2 tabs.

42

Study mission report on geothermal development in Philippines and New Zealand. Part 2. New Zealand (Wairakei geothermal power station steam production plant and electric power generation plant). Fujita, T. (Japan Geothermal Energy Association, Tokyo (Japan)); Kido, R. *Chinetsu (Journal of the Japan Geothermal Energy Association) (Japan)*; 30(5): 62-65 (28 Feb 1994). (In Japanese).

In the Wairakei power plant, the 1st unit of A power plant started to generate electricity in 1959, and then, because B power plant was completed, it has generated a power of 192.6MW. This is the second geothermal power generation plant in the world next to the Larderello Plant in Italy commenced operation in 1913, and furthermore it has a significance as the first hydrothermal type geothermal power plant in the world that its wells are blowing out the geothermal fluid with 80% of hot water and 20% of steam. The turbine generators were made in UK, and its manufacturer is the current GEC company. While the back pressure turbines of HP and IP in A power plant are a 3000 rpm machine with a single flow and single axis respectively and the condensing turbine is a 3000 rpm machine with a double flow 10 stages and single axis, the mixed pressure condensing turbine in B power plant is a 1500 rpm machine with a single flow 15 stages and a single axis. In the Wairakei plant, even the hot water with a high temperature separated at the well heads is discharged to the Waikato river as it is. Although it is needless to say that an environmental problems caused by a river pollution should be significant, a fall of the groundwater level is substantial through no reduction of the hot water to underground. 7 figs.

43

Study mission report on geothermal development in Philippines and New Zealand. Part 2. New Zealand

(Ohaaki geothermal power station steam production plant and electric power generation plant). Fujita, T. (Japan Geothermal Energy Association, Tokyo (Japan)); Kido, R. *Chinetsu (Journal of the Japan Geothermal Energy Association) (Japan)*; 30(5): 65-70 (28 Feb 1994). (In Japanese).

The Ohaaki power generation plant is situated in 23km north of the Wairakei power plant. It is a geothermal power generation plant with a big capacity (116.2MW) constructed next to the Wairakei power plant in New Zealand. Since it has commenced operation in June 1989, it has maintained an availability factor of about 95% and consequently has performed a stable power supply. Total number of 25 production wells are producing hot water of approximately 2500t/h, and they are classified into the high pressure wells supplying a high pressure steam with 12.5 bar g and the medium pressure wells supplying a medium pressure steam with 3.5 bar g. The steam generation facilities constituted of 2 units of a high pressure separator and 1 unit of a medium pressure separator are installed in 5 localities, and they are supplying a high pressure steam of 530t/h and a medium pressure steam of 190t/h. 9 reduction wells are set up and the hot water from each separator is reduced underground by using the reduction pump with a variable speed. In the Wairakei power plant, the effluent hot water is discharged to the Waikato river, and therefore a reduction of hot water underground was practically applied at first time in the Ohaaki power plant in New Zealand. 12 figs., 1 tab.

44

Study mission report on geothermal development in Philippines and New Zealand. Part 2. New Zealand (Kawerau geothermal power station (binary cycle system)). Shinohara, K. (Japan Geothermal Energy Association, Tokyo (Japan)); Natori, S.; Shiroo, K. *Chinetsu (Journal of the Japan Geothermal Energy Association) (Japan)*; 30(5): 70-73 (28 Feb 1994). (In Japanese).

In order to make the most of a geothermal energy from the Kawerau geothermal region, under the Tarawera Ormat Installation (TOI) project, 2 units of Ormat binary power generation facility were installed by investing 4 million dollars. The power generation facilities were installed in the bank of the Tarawera river, where the high pressure hot water (172°C) has been diffused in the atmosphere for a long time. This power generation facilities are so designed that they can efficiently take out the energy from the geothermal fluid being diffused in the atmosphere and furthermore they can generate useful power. These power generation facilities are modularized, and the Ormat Turbines Ltd. of Israel has manufactured them. In these facilities, isopentane is vaporized through the heat exchangers by utilizing the high pressure hot water. This gas makes the turbines rotate by its self pressure and as a result generates a power. Furthermore this gas is cooled by the condensers and then returns to the liquid. The generated power is directly connected to a network of the Bay of Plenty Electricity company. 9 figs., 1 tab.

45

Hydrogen sulfide diffusion facilities in a geothermal power generation plant. Kato, K. To Ishikawajima-Harima Heavy Industries Co. Ltd., Tokyo (Japan). Japanese Patent 6-137260. 17 May 1994. Filed date 23 Oct 1992. Int. Cl. F03G4/00; B01F3/02; C01B17/16. 4p. (In Japanese). Source: Available from Japan Patent Information Organization of International Patent Documentation Center.

This invention relates to a geothermal power generation plant to generate electric power by revolving a turbine with steam blown up from the underground and to condense the steam discharged from the turbine with a condenser, and aims to provide a hydrogen sulfide diffusion facility to mix completely hydrogen sulfide contained in the steam and the air, to release and diffuse the hydrogen sulfide after dilution to the concentration below the limitation to prevent bad smell and environmental pollution. This invention presents a hydrogen sulfide diffusion facility in which hydrogen sulfide duct is installed to conduct hydrogen sulfide on a cooling tower to air-cool cooling water used in a condenser and number of nozzles are equipped at the top of the hydrogen sulfide duct with intervals along the peripheral direction of the air exhaust of the cooling tower. With this invention, hydrogen sulfide is released and dispersed from the multiple nozzle little by little and mixed with the whole air flow uniformly to suppress the concentration of hydrogen sulfide to be low. 3 figs.

GEOHERMAL ENGINEERING

Refer also to citation(s) 28

46

The performance and characteristics of the experimental hot dry rock geothermal reservoir at Rosemanowes, Cornwall (1985-1988). Richards, H.G. (Camborne School of Mines, Cornwall (United Kingdom)); Parker, R.H.; Green, A.S.P.; Jones, R.H.; Nicholls, J.D.M.; Nicol, D.A.C.; Randall, M.M.; Richards, S.; Stewart, R.C.; Willis-Richards, J. *Geothermics (International Journal of Geothermal Research and its Applications) (United Kingdom)*; 23(2): 73-109 (Apr 1994).

The experimental Hot Dry Rock (HDR) geothermal reservoir created in 1985 at the Rosemanowes test site in Cornwall is one of a very small number of HDR reservoirs of substantial dimensions whose key performance parameters have been measured. The reservoir linked an injection well (RH12) with a production well (RH15). The initial production temperature (at the casing shoe) was 80 C. The average injection temperature during the early part of the circulation test was about 25 C. Ten per cent thermal drawdown occurred after about 300 days circulation at an average production flow rate of 8.5 kg/s. The mass of fluid produced in this time was 220 million kg. A comprehensive program of reservoir characterization was undertaken to measure as many as possible of the fundamental reservoir parameters was undertaken to measure as many as possible of the fundamental reservoir parameters that are considered to have given rise to the observed thermal and hydraulic performance. This paper reports the main results of this reservoir characterization program. It is concluded that many of the parameters measured are not true estimates of the actual parameters being sought, but apparent parameters, whose values are highly dependent upon the simplifying assumptions used to obtain them. The performance of the RH12/RH15 reservoir is compared with that which would be required of an individual cell of a commercial-scale HDR reservoir consisting of many stimulated cells in parallel. By these criteria, the performance of the RH12/RH15 reservoir falls short in terms of thermal output and water loss, but

meets the required impedance. The performance of the RH12/RH15 reservoir was severely limited by the unfavorable trajectory well (RH12), especially in terms of thermal output.

47

Siliceous deposits formed from geothermal water. Part 1.: Major constituents and the existing states of iron and aluminium. Yokoyama, T. (Kyushu Univ., Fukuoka (Japan). Chemistry Lab.); Sato, Y.; Maeda, Y.; Tarutani, T.; Itoi, R. *Geochemical Journal (Japan)*; 27(6): 375-384 (Jun 1993).

Silica deposition from geothermal water has often presented serious problems for the utilization of geothermal energy. The major problems are caused by siliceous material deposits in surface facilities and in fractures near injection wells at geothermal power stations. To solve these problems, it is essential to elucidate the deposition mechanism of silicic acid from geothermal water. Geothermal water and siliceous deposit samples were now collected from five geothermal fields in Kyushu, Japan, and their chemical analyses were obtained with respect to major constituents. The concentration factors of elements into the siliceous deposits were calculated and the state of aluminium and iron was examined. In this paper, the collected samples and the analytical procedure are explained; the chemical composition of the geothermal waters and siliceous deposits and the concentration factors of elements are discussed. In conclusions, it is stated that aluminium and iron seem to play an important role in the deposition of siliceous deposits from geothermal water. 21 refs., 4 figs., 6 tabs.

48

Geothermal heat extraction facility. Sakamoto, S. (Aomori (Japan)). To Sakamoto, S. (Aomori (Japan)). Japanese Patent 6-137689. 20 May 1994. Filed date 28 Oct 1992. Int. Cl. F24J3/08. 7p. (In Japanese). Source: Available from Japan Patent Information Organization of International Patent Documentation Center.

This invention relates to a geothermal heat utilization facility, which is installed with a geothermal heat intake tank laid underground with its top on the ground or the vicinity and with its lower end in the underground sufficiently deep to take out geothermal heat, a lifting pump to lift the underground water through the geothermal heat intake tank, a heat medium such as granite filled in the tank, an air supply apparatus to supply the air into the geothermal heat intake tank from the lower end of the tank, a heat storage tank laid underground with its top on the ground or the vicinity of the radius larger than that of the geothermal heat intake tank, a connection pipe to connect the lower end of the heat storage tank and the top of the geothermal heat intake tank, an exhaust duct attached to the top of the heat storage tank, a pump for the heat storage tank to lift the underground water through the heat storage tank, and a heat storage medium such as rubble stones. 7 figs.

DIRECT ENERGY UTILIZATION

49

(DOE/ID/13040-T25)

Geothermal direct-heat utilization assistance: Quarterly project progress report, July 1994-September 1994.

Oregon Inst. of Tech., Klamath Falls, OR (United States). Geo-Heat Center. [1994]. 15p. Sponsored by USDOE, Washington, DC (United States). DOE Contract FG07-90ID13040. Order Number DE95001814. Source: OSTI; NTIS; GPO Dep.

This paper is a third quarter 1994 report of activities of the Geo-Heat Center of Oregon Institute of Technology. It describes contacts with parties during this period related to assistance with geothermal direct heat applications. Areas dealt with include geothermal heat pumps, space heating, greenhouses, aquaculture, resources, and equipment. Research is also being conducted on failures of vertical line-shaft turbines in geothermal wells.

50

Geothermal convector design: Solutions, design criteria, and calculation methods. Latrofa, E.M. (Univ. di Pisa (Italy). Dipt. di Energetica); Martorano, L.; Casarosa, C.; Cannaviello, M.; Carotenuto, A. *Energy Sources (United States)*; 16(4): 531-547 (Oct-Dec 1994).

The geothermal convector (GTC) is an unconventional system for heat extraction from a geothermal aquifer without fluid withdrawal. In this system a special two-phase thermosiphon is used. This device works with a downhole evaporator and with a condenser at the ground level. The system shares advantages and disadvantages with other downhole heat exchanger plants; for instance, a second well to return geothermal water to the aquifer is not required. Because of the limitations of the natural heat flow in the hot aquifer, however, the device is most suitable for small-to moderate-size applications. In this article, the fundamental elements required to determine the device performance and the thermal design criteria are reported and a GTC prototype is described. Designed for 70 C temperature of the geothermal water and 3 m length of the evaporator, this prototype was recently installed in a geothermal well on the island of Ischia. In this article the results of the first experimental tests are reported.

51

Study mission report on geothermal development in Philippines and New Zealand. Part 2. New Zealand (Direct utilization of geothermal energy at Tasman Pulp and Paper Co.). Kido, R. (Japan Geothermal Energy Association, Tokyo (Japan)); Fujita, T. *Chinetsu (Journal of the Japan Geothermal Energy Association) (Japan)*; 30(5): 83-86 (28 Feb 1994). (In Japanese).

The Tasman Pulp Co.(TPPC) is a division of the largest undertaking group in New Zealand. The annual production of the Kawerau factory of TPPC is the newsprint paper of 380,000 tonnes and the kraft pulp of 200,000 tonnes, and the sales amount of US \$ 275 million, and the required power is 128MW. The geothermal steam forms about 35% of required quantity for the entire factory, and therefore it contributes substantially to an energy balance. The geothermal steam is utilized also for the drying furnace of the Tasman Lumber company, the binary-cycle power generation of the Bay of Plenty Electricity and the greenhouse for the vegetable growing located in the same plant site. Because the artificial forest afforested for the lumber supply and employment promotion in a business depression time in the former half of the 1920s has grown up to the largest class in the world in the 1930s, this factory was established for a purpose of effective utilization of it in 1952. As the

geothermal utilization facilities, there are 5 units of heat exchanger from the geothermal steam to the clean steam and 2 units of feed water heater to the waste heat recovery boiler and general purpose boiler. 5 figs.

GEOHERMAL DATA AND THEORY

Refer also to citation(s) 15

52

Combined chemical and physical model for plutonic devolatilization: A non-Rayleigh fractionation algorithm. Candela, P.A. (Univ. of Maryland, College Park, MD (United States)). *Geochimica et Cosmochimica Acta (United States)*; 58(10): 2157-2167 (May 1994). DOE Contract FG07-90ID13025. Grant EAR-9018870; Grant EAR-9204671.

Modeling of magmatic-hydrothermal processes requires the estimation of intensive parameters, the experimental determination of partition coefficients and other equilibria, and quantitative models of processes such as magmatic crystallization and devolatilization. In this paper, a new chemical model for magmatic devolatilization, based on a physical model for volatile release during second boiling, is presented. Models are presented for stable isotopes and nonchloride complexed elements. The release of volatiles during isobaric, plutonic crystallization (second boiling) has been modeled as either a batch (closed-system) or Rayleigh-fractional (open-system) process. However, when the chemical mass transfer, attendant to second boiling, is modeled in conjunction with a simple physical model involving critical percolation of the magmatic volatile phase, the mass transfer can be shown to occur as a transitional batch-fractionation process. Early devolatilization during second boiling follows a batch law as discrete bubbles grow. Depending on the depth (pressure) of intrusion, and the initial volatile content of the magma, the discrete volumes of the volatile phase will achieve a spanning cluster of volumes at some stage in devolatilization progress. When connectivity of volatile phase volumes is established, devolatilization will follow a modified fractionation law wherein a finite, rather than infinitesimal volume of the fractionating phase is in equilibrium with the melt. For devolatilization of melts of a given initial volatile concentration, increasing depth leads to later formation of a spanning cluster and increasing batch character. Extreme depletions of magmatic chlorine or deuterium, or enrichments of magmatic molybdenum or fluorine are made more probable by early establishment of spanning clusters of volatile volumes.

53

Fractal analysis for space filling and shape of fractures in rock sections. Tsuchiya, N. (Tohoku Univ., Sendai (Japan). Faculty of Engineering); Matsukawa, Y.; Nakatsuka, K. *Nippon Chinetsu Gakkaishi (Journal of the Geothermal Research Society of Japan) (Japan)*; 16(2): 153-171 (25 Apr 1994). (In Japanese).

To acquire basic knowledge concerning modeling of space filling for the design and evaluation of geothermal fluid reservoir layer, fractal geometry is used to analyze the space filling and shape of fractures on arbitrary sections of the Tamagawa welded tuffs. Space filling of fracture patterns on arbitrary sections of the Tamagawa welded tuffs in the

observation areas ranging from 10m square outcrop to 1.6m square microscopic visual field show statistical self-similarity, and fractal dimensions of fracture filling with a different area can be estimated in this range by measuring fracture patterns of other scales. When fractal dimensions of fracture filling are obtained by box-counting algorithm, fractal dimensions obtained from different scale observation areas can be compared each other by making the ratio nearly identical between the sensitivity of fracture measurement in the observation area having the side of R and the minimum length of the side of the cells which divide the observation area. 23 refs., 11 figs., 2 tabs.

54

Deep circulation of CO₂-rich palaeowaters in a seismically active zone (Kuzuluk/Adapazarı, northwestern Turkey). Greber, E. (ETH Hoenggerberg, Zuerich (Switzerland)). *Geothermics (International Journal of Geothermal Research and its Applications) (United Kingdom)*; 23(2): 151-174 (Apr 1994).

The upflow zone of more than 40 cold and hot mineral springs of Na-(Ca)-(Mg)-HCO₃-Cl type is restricted to an extensional structure within the seismically active. North Anatolian Fault Zone. The chemistry of the waters, which are probably more than 10,000 years old, is influenced effectively in a low-temperature environment by the CO₂ originating from the decomposition of marine carbonates and outgassing of the earth mantle. This gas is thus attributed to the interaction of the minor plates of Turkey and the Black Sea in this area. A strong positive ¹⁸O-shifts is due to water-rock interaction with very long contact times, rather than to isotopic influence of the CO₂-on the ¹⁸O-value of the waters.

WASTE MANAGEMENT

55

(VIMI-G25992)

Analysis of different technologies for deleting and utilization of gas and solid contaminants contained in geothermal waters at geothermal power plants at the Far East region. TsNII Rumb (Russian Federation). Jan 1992. 46p. (In Russian). Source: MF available from the IC-STI (Moscow, RU) under the report number.

Different technologies for removing hydrogen sulfide are discussed. Specific features and drawbacks of these technologies are considered. The technology is offered for gas phase cleaning of geothermal environment from hydrogen sulfide with use of catalysts developed at the Rumb research institute. Ways and methods were developed to protect wells from carbonate sediments and to remove silicates and heavy metals compounds from geothermal water to avoid sediments formation in pipes, wells and turbines. Recommendations are made how to maintain an optimal water regime at geothermal power plants.

56

Biochemical solubilization of toxic salts from residual geothermal brines and waste waters. Premuzic, E.T.; Lin, M.S. To Associated Universities, Inc., Washington, DC (United States). U.S. Patent 5,366,891/A. 22 Nov 1994. Filed date 3 Sep 1993. U.S. Patent Application 8-115,760.

Int. Cl. B09B 3/00; C12N 1/12; C02F 3/00. [10p.] DOE Contract AC02-76CH00016. Source: Patent and Trademark Office, Box 9, Washington, DC 20232 (United States).

A method of solubilizing metal salts such as metal sulfides in a geothermal sludge using mutant *Thiobacilli* selected for their ability to metabolize metal salts at high temperature is disclosed. The method includes the introduction of mutated *Thiobacillus ferrooxidans* and *Thiobacillus thiooxidans* to a geothermal sludge or brine. The microorganisms catalyze the solubilization of metal salts. For instance, in the case of metal sulfides, the microorganisms catalyze the solubilization to form soluble metal sulfates. 54 figs.

MISCELLANEOUS

57

(GSC/ISPG-2773)

1st Springhill geothermal energy conference, Springhill, Nova Scotia, 28-29 October 1992: Summary report. Arkay, K. Geological Survey of Canada, Calgary, AB (Canada). Inst. of Sedimentary and Petroleum Geology. ©Dec 1993. 92p. (CONF-9210481-: 1. Springhill geothermal energy, Springhill (Canada), 28-29 Oct 1992; MICROLOG-94-05200). Source: PC Geological Survey of Canada, Publications Distribution, 601 Booth St., Ottawa, ON, CAN K1A 0E8; MF Micromedia Limited, 240 Catherine St., Ottawa, ON, CAN K2P 2G8; PC \$20.00 CAN; MF PRICES UPON REQUEST.

A conference was held to provide an opportunity to exchange information on a range of issues relevant to development of low-temperature geothermal energy from abandoned mines, and to identify opportunities, problems, needs, and recommended priority actions regarding the assessment, development, protection, and marketing of low-temperature geothermal resources in Nova Scotia. Issues addressed at the conference included the nature of low-temperature geothermal resources, the technology for finding, assessing and recovering the energy, district energy systems, aquifer/data management systems, the economics of geothermal energy use, and legal aspects, including ownership of the resource. The conference presentations, working group sessions, and open discussions at the conference are summarized. Development of geothermal resources from mines is of interest to several Nova Scotia communities in proximity to large abandoned mines, and a number of advantages and benefits related to the use of such energy have already been demonstrated in Springhill, where low-temperature geothermal energy is being used to heat and cool buildings in a cost-effective manner. Specific needs that need to be addressed in order to encourage geothermal energy development include a sound technical and information base, codes of practice regarding recovery and use of the resource, appropriate legislation and regulations to clarify ownership, a licensing and fee policy for use of the resource, and a focal/coordination point to assist in identifying needs, available information, and the work required.

58

Renewable energy application progress in Mexico. Matsumoto, Y. (Instituto Politecnico Nacional, Mexico City

(Mexico). Centro de Investigacion y de Estudios Avanzados; Urbano, A.; Asomoza, R.; Martinez, A.M. *Renewable Energy (United Kingdom)*; 5(1-4): 330-332 (Aug 1994). (CONF-940904-: World renewable energy congress, Reading (United Kingdom), 11-16 Sep 1994).

Part 1 of 3, edited by A.A.M. Sayigh.

This paper gives a general view of the renewable energy systems installed in Mexico, since the early 70s up to the present date. Mention is made of the location, within Mexico, of these systems, their power and the institutions that have participated in this program which are academic, federal government agencies, local government agencies as well as private companies. The installed systems are mainly: wind generators, flat and concentrator collectors, geothermal plants, biomass, solar ponds, photovoltaic systems and small hydrologic plants. (Author)

59

Renewable energy sources in Hungary. Present situation, future possibilities. Hanzely, G. (Ministry of Agriculture, Budapest (Hungary)). *Renewable Energy (United Kingdom)*; 5(5-8): 1387-1389 (Aug 1994). (CONF-940904-: World renewable energy congress, Reading (United Kingdom), 11-16 Sep 1994).

Part 2 of 3, edited by A.A.M. Sayigh. (Pt.1: v.5(1-4)).

Since the early 1980s, Hungary has pursued a policy of adopting renewable energy sources and technologies in order to reduce fuel imports and to lessen the country's vulnerability to disruptions in energy supplies. As other fuel costs have dropped, this policy has needed to be reassessed. Now the emphasis is an environmental protection

as an argument in favour of using renewable sources. Investigations are reported into the use of refuse, straw, wood wastes and other indigenous resources as biofuels for power generation. Hungary still aims to increase the proportion of its gross energy consumption that is generated from renewable energy sources. The potential use of geothermal energy, solar power and wind power are also assessed, briefly. (UK)

60

Ice age for geothermal energy. Dermuehl, P. *Blick durch Wirtschaft und Umwelt (Germany)*; (6): 52-56 (Jun 1994). (In German).

The huge potential danger of nuclear energy, the risk of dependency on the oil and gas producing countries, latent environmental pollution through the policy of coal power, persistent disturbances of the water system through the use of hydro power and the unknown climatic and meteorological implications of certain renewable energy sources: None of the politically feasible energy sources which are used on a large scale carry any guarantee on the ecological and economic risks involved. Particularly when set against the background of the necessary deregulation as the reduction of protectionism in the energy industry, as well as obligations such as European plans for a CO₂ tax, there is scarcely a resource left for future long-term use. In the light of this scenario, the future belongs to one energy source: Geothermal energy presents itself locally and regionally in available inexhaustible supplies. (orig./UA)

NONREPORT PRODUCT WORKSHEET

TO: Librarian

FROM:

NAME _____

ORGANIZATION

ACCOUNT NUMBER

PLEASE PROVIDE THE FOLLOWING:

COMPLETE TITLE

AUTHOR/PUBLISHER

DATE _____

MEDIA/VOLUME/PAGES

This worksheet is provided for your convenience in obtaining nonreport products.

DOE and DOE Contractors ORDER FORM

I. SHIPPING AND PAYMENT INFORMATION

Ordering Address

Name _____ Telephone () _____

Address _____

City _____ State _____ ZIP _____

Shipping Address (If different from above)

Name _____

Address _____

City _____ State _____ ZIP _____

SIGNATURE (Required to validate ALL orders) _____

☐ Charge OSTI deposit account no. _____

☐ Charge my ☐ VISA ☐ MasterCard

Account No. _____ Exp. _____

☐ Enclosed is my ☐ Check ☐ Money Order for \$ _____

For information, call Information Services: (615) 576-8401.

OSTI PRICES FOR R&D REPORTS (effective 4/4/94)

PAPER COPY

Page range	OSTI price
1-10	\$13.00
11-50	18.00
51-100	20.00
101-200	28.00
201-300	36.00
301-400	44.00
401-500	53.00
501-600	61.00
601 & up	Add \$7.00 for each additional 100 pages or portions thereof.

MICROFICHE

Per title \$12.00

Mail order form to

U.S. Department of Energy
Office of Scientific and Technical
Information
P.O. Box 62
Oak Ridge, TN 37831 or

Fax order form to (615) 576-2865

II. SELECTIONS

Abstract No.	No. of Pages	PC	MF	Order Number
1	208	—	—	* DE95716361
16	20	—	—	DE94017948
17	99	—	—	DE94017949
18	127	—	—	DE94017950
19	138	—	—	DE95714824
20	102	—	—	DE95002956
21	7	—	—	DE95002391
30	50	—	—	DE95001766
36	179	—	—	DE95714832
49	15	—	—	DE95001814

* Although the abstract describes a partial document, it is
priced and available only as a full report.

General Public NTIS ORDER FORM

(Please PRINT or TYPE)

I. ADDRESS INFORMATION

Date: _____

Last Name First Initial

Title

Company/Organization

Address

City/State/ZIP

Attention

II. METHOD OF PAYMENT

- ☐ Charge my NTIS Deposit Account _ _ _ _ _
- ☐ Check/Money order enclosed for \$ _____
(Payable in U.S. dollars)
- ☐ Bill me. Add \$7.50 per order (Purchase Order Fee) since full payment does not accompany order.*

Purchase Order No. _____

Charge my ☐ Amer. Express ☐ VISA ☐ MasterCard

Account No. _____ Exp. _____

Telephone number: _____

Fax number: _____

Signature: _____

Required to validate order →

- **RUSH SERVICE:** For Rush Service, call 1-800-553-NTIS. *Do not mail rush orders.* Rush orders are usually shipped next day by overnight courier in the U.S. or by airmail outside the U.S. Add \$15 per report for the U.S., Canada, and Mexico or \$25 for other countries.
- **AIRMAIL:** For airmail service to Canada and Mexico, add \$4.00 per printed report; \$1.00 per microfiche copy. For airmail service to all other international addresses, add \$8.00 per printed report; \$1.25 per microfiche copy.
- **SUBSCRIPTIONS:** To order, call (703) 487-4630.
- **TDD:** To place orders, call (703) 487-4639.
- **REGULAR SERVICE:** Call (703) 487-4650 or fax this form (703) 321-8547.

III. ORDER SECTION

Enter NTIS order number(s) (Ordering by title alone will delay your order)	Customer [†] Routing (up to 8 digits)	Quantity			Specify density for tape order			Unit Price	Int'l Airmail	TOTAL PRICE
		Paper Copy	Micro- fiche	Other	1600 bpi	6250 bpi	3480 Cartridge			
1.										
2.										
3.										
4.										
5.										

Value of Order Handling Fee

\$10.00 or less	\$2.00
\$10.01 - \$50.00	\$4.00
\$50.01 - \$100.00	\$6.00
Over \$100.00	\$8.00

Add \$2.00 to above for orders sent outside of the U.S., Canada, Mexico. No handling fees for subscription or standing order service.

Purchase Order Fee if required (\$7.50)

GRAND TOTAL

* Purchase Order Service is restricted to Government agencies, educational institutions, or corporations in the U.S., Canada, and Mexico.

[†] NTIS will label each item with up to eight characters of your organization's routing code.

Mail orders to: U.S. Department of Commerce
Technology Administration
National Technical Information Service
Springfield, VA 22161

All Sales Final

NTIS does not permit returns for credit or refund. NTIS will replace items if an error is made in filling your order, if the item is defective, or if it was received in damaged condition. Call (703) 487-4660.

United States Department of Energy
Office of Scientific and Technical Information
Post Office Box 62
Oak Ridge, Tennessee 37831

OSTI 48198 FS- 1
ATTN DORIS SAYLOR

Printed on recycled paper
Product is recyclable