DOE/IR/05106--5
DE93 005626

March, 1992

CENTRAL STATION DHC PHASE I FEASIBILITY

Energy Task Force
of the Urban Consortium
for Technology Initiatives

City of Chicago
Richard M. Daley, Mayor

Conducted by:
Department of Environment
Henry L. Henderson, Commissioner

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

EB

PREFACE

YEAR 11 ETF PUBLICATION

The Urban Consortium for Technologies (UC) is composed of over forty of the largest cities and urban counties by population in the United States. The Consortium provides a unique forum to define urban problems common to its member governments and to develop, apply transfer and commercialize technologies and innovative management techniques to address those problems.

The Urban Consortium conducts its work program under the guidance of Task Forces structured according to the functions and concerns of local governments. The Urban Consortium Energy Task Force (UCETF), with a core membership of 20 large cities and counties, was formed in 1979 to help improve urban energy management decision-making through applied research and technology transfer. The UCETF focuses on developing and sharing new approaches and innovative solutions to energy management problems with interested local governments. Projects with similar subjects are organized into Units with each unit managed by a selected Task Force member.

A description of the Units and projects included in the 1990 program are as follows:

ALTERNATIVE VEHICLE FUELS

Alternative vehicle fuels offer a very strong potential to aid in the reduction of US dependence on foreign oil supplies, with the concomitant benefits of decreased air pollution in urban areas. Local governments can play an instrumental role in realizing this potential through practical applied research and highly visible demonstrations for alternative fuel and technology options. Projects in this topic area place a strong emphasis on the examination of all

potential alternate fuels with support from teaming and partnership activities among cities and counties, utilities and other relevant private sector organizations that have matching interests. The 1990 Alternative Vehicle Fuels unit consists of:

Albuquerque, NM -- *Alternative Fuel Vehicles in Municipal Duty Cycles*

Broward County, FL -- *Dual Fuel Conversion Demonstration*

Detroit, MI -- *Assessment of AFV Availability to Meet Emergency Contingency Planning and Long Term Public Fleet Integration*

Denver, CO -- *Alternative Fuels and Transportation Management Associations*

Houston, TX -- *CNG Fueled Vehicle Comparison*

New York, NY -- *Alternative Transportation Fuels: Infrastructure Issues*

Pittsburgh, PA -- *Compressed Natural Gas as an Alternative Vehicle Fuel*

San Diego, CA -- *Siting Alternative Fuel Filling and Maintenance Stations*

ELECTRICITY MANAGEMENT

Energy costs can place a severe burden on residents and limit economic growth for both energy-intensive industries and the vital small business sector that provides the majority of today's employment opportunities. Urban governments, therefore, need to have the ability to manage both the use and demand for electricity supplies. The emphases on the 1990 electricity management projects include attention to broad issues of electricity cost as an economic factor in commercial development decisions, procedures for the design of major new public facilities, and the feasibility of emerging decentralized and/or alternative sources of electrical energy. This 1990 unit consists of:

Chicago, IL -- *Central Station DHC Phase I Feasibility Analysis*
Columbus, OH -- *Electricity Demand Impacts of New Indoor Air Quality Standards*
Dade County, FL -- *Global, Automated Urban Government Energy System (GAUGES)*
Detroit, MI -- *Hydraulic Waste Energy Recovery City of Detroit Water Distribution System*
Kansas City, MO -- *Use of Cogeneration System to Control Electrical Demand*
Montgomery County, MD -- *Integrated Energy Planning for a New Detention Center*
New York, NY -- *Strategies to Reduce Electricity Cost in New Commercial Construction*

ENERGY, ENVIRONMENT AND ECONOMIC DEVELOPMENT

Today's urban centers face critical and continuing problems that constrain their ability to provide affordable housing, to reduce congested highways, and to improve air quality, waste management, and economic development. The efficient use of energy and the development of alternate, clean energy resources can help address these broad community problems and contribute significantly to achieve truly sustainable, environmentally responsible, and economically viable communities. This unit, therefore, deals with community problems, from affordable housing to alternate clean energy resources. Urban strategies to improve energy-sustainability will require attention to both broad based institutional changes, as well as specific projects designed to encourage the application of appropriate technology and community development practices. This 1990 unit consists of:

Phoenix, AZ -- *Impact of Heat Islands on Cooling and Environment*
Los Angeles, CA -- *Heat Island Mitigation*
Pima County, AZ -- *Tucson Solar Village*
Portland, OR -- *The Sustainable City: Phase II*

San Jose, CA -- *The Sustainable City: Phase II*
San Francisco, CA -- *The Sustainable City: Phase II*
St. Louis, MO -- *Pilot Program for Energy Efficient Mortgages*
Washington, DC -- *Energy Efficiency in Public Housing*

WASTE MANAGEMENT

Effective and environmentally sound waste management is a concern of local government that only promises to grow in its significance through the decade. Urban strategies for waste management are evolving into coherent approaches that integrate traditional collection and disposal practices with new emphases on waste source reduction, separation and isolation of hazardous wastes, and practical recycling procedures. This year's unit consists of:

Hennepin County, MN -- *Household Hazardous Waste Processing - Phase II*
Houston, TX -- *Solid Waste Integrated Cost Analysis Model: An Applied Decision Making Tool for Municipalities*
Memphis, TN -- *Sludge Storage Lagoon Biogas Recovery*
New Orleans, LA -- *Pyrolysis Disposal of Scrap Tires*
San Diego, CA -- *Mixed Plastics Recycling*
Seattle, WA -- *Evaluation of Hazardous Waste Management Programs*

Reports from each of these projects are specifically designed to aid the transfer of proven experience to other local governments. Readers interested in obtaining any of these reports or further information about the Energy Task Force and the Urban Consortium should contact:

Energy Program
Public Technology, Inc.
 1301 Pennsylvania Avenue, NW
 Washington, DC 20004

ACKNOWLEDGEMENTS

Dr. Charles H. Williams, Electricity Unit Manager and Director of the Department of Planning's Energy Management Division provided overall direction for the implementation of this project. W. Dwight Bailey, Sr., Project Manager and principal author, was responsible for the day-to-day activities of the project.

This project was made possible through the cooperation of many individuals within several organizations. We would first like to express our sincere gratitude to Fogelson Properties, Inc. for their prudence in contacting the Department of Planning's Energy Management Division to explore the vagaries of district energy. In particular, we extend our thanks to Mr. Gerald Fogelson, Chief Executive Officer, Dennis Harder, Senior Vice-President and Stephen L. Kozerowitz, Vice President of Construction and Development for their willingness to provide all germane information, and host inter-organizational meetings concerning the proposed Central Station development and its potential for district heating and cooling.

Our strong expression of gratitude is also extended to Messrs Thomas O'Sullivan, Director of Gas Sales; Charlie Janek, Manager of Major Accounts; Greg Hansen, Gas Utilization Engineer and the Board of Directors of Peoples Gas Light and Coke Company for their abundant support for this project. In particular, Peoples provided financial resources, technical support and the lead in visiting some of the downtown boiler and chiller plants. Mr. Greg Hansen was especially helpful in those endeavors.

Messrs Tom Casten, President, Goren Mornhead, Mike Weiser and Jean Malahieude, engineers of Trigen Energy Corporation were invaluable in their assistance on defining district heating and cooling technology and how it could adapt to the Central Station development. Mr. Casten was stellar in expressing to the representatives from both the City and Fogelson Properties Inc. how centralized district cooling could be a hedge against further depleting the ozone layer. Mr. Mornhead, Corporate Engineer, provided day-to-day technical expertise to the City.

Midwesco, Inc., represented by Henry Mautner, Chairman of the Board, and David Unger, President, were extremely valuable in assisting the technical analysis of the DHC study. Mr. Mautner was also helpful in arranging technical meetings both with the study group and other organizations that could have an interest in DHC at the Central Station site.

We would like to thank the Technical Assistance Team, sponsored by the U.S. Conference of Mayors and the U.S. Department of Housing and Urban Development (HUD), which qualitatively outlined the issues germane to successful development of a privatized district energy system contiguous to Chicago's Loop. In particular, we would like to thank: Mr. Ronald W. Musselwhite and Mr. David Gatton of the U.S. Conference of Mayors; Mr. Wyhndam Clark of HUD; Mr. John Nimmons, Nimmons & Associates; Mr. John F. Deakin, Director, Public Utilities Commission of the City and County of San Francisco; Mr. Carl E. Avers, Chairman, Catalyst Thermal Energy Corporation and Mr. William E. Eyring, Eyring & Associates for their diligent work in assessing the potential for DHC.

We would like to thank our co-workers in the Department of Planning who provided assistance in this project. Mr. David Mosena, Chief of Staff, Mayor's Office provided impetus as Commissioner of Planning in inaugurating the technical analysis; Mr. Marcel Acosta, Assistant Commissioner in the Department of Planning was very supportive in the integration of energy considerations into the Planned Development process; Mr. Fred Deters, Senior Planner, briefed the Technical Assistance Team on the physical, transportation-related and institutional characteristics of the site and Mr. Steve Harris, intern with the Energy Management Division, provided data-gathering assistance.

We also want to thank Jack Werner, Director of Environment and Energy Programs and Denice DePercin, Research Associate both of Public Technology, Inc. for their thoughtful assistance throughout the project.

CONTENTS

Page

CHAPTER 1--OVERVIEW

Abstract.....	1
Project Purpose.....	3
Report Organization.....	5

CHAPTER 2--BACKGROUND AND CONCEPT

Introduction.....	7
Infusion of DHC into the Central Station	
Planned Development Process.....	8

CHAPTER 3--CENTRAL STATION DISTRICT ENERGY ASSESSMENT

Thermal Market Evaluation	16
Thermal Loads Outside Central Station.....	19
Cost of Non-Centralized Heating and Cooling.....	23
Field Museum.....	24
R.R. Donnelley & Sons.....	24
McCormick Place I.....	25
Mercy Hospital.....	25
Michael Reese Hospital.....	26
The DHC Distribution System.....	26
Heating Concepts.....	26
Hot Water Distribution System.....	27
Steam Distribution System.....	27
Cooling Concepts.....	28
Description of the Distribution System.....	29
Estimates of Heating and Cooling Production.....	33
The Central Heating and Cooling Plant.....	33
Heating Energy Production Design.....	33
Cooling Plant Concepts.....	34
Chiller Drive Options.....	34
Condenser Cooling.....	34
Cogeneration Alternatives.....	35
Central Plant Description.....	36

CHAPTER 4--CENTRAL STATION PRACTICAL AND OPERATIONAL ISSUES

Legal and Regulatory Issues.....	39
Illinois "Public Utility" Definition.....	40
City Options Under "Franchise" and Public Use "Tests".....	42
City Franchise Authority, Potential Benefits.....	43
City Authority to Enter Into a DHC Franchise.....	43
Potential Benefits Derived From a DHC Franchise.....	43
Environmental Regulation of a DHC System.....	45
Chloroflourocarbons.....	47
Ammonia Refrigeration.....	49
Economic Analysis.....	50
Heating and Cooling Revenue.....	51
Operating and Maintenance Cost.....	54
Financial Analysis.....	55
Economic Attractiveness.....	56
Sensitivity Analysis.....	56

CHAPTER 5--SUMMARY AND CONCLUSIONS.....58

Prospects for Implementation.....	59
Technical Considerations.....	60
Economic Conditions.....	61
Legal/Regulatory Conditions.....	62
DHC as a Catalyst for Regional Development.....	64
Lessons Learned.....	65
Future Steps.....	68

APPENDICES

1	Construction Forecast.....	72
2	Annual Heating and Cooling Cost Comparison.....	73
3	Total Plant Load Projections.....	74
4	Chiller Options.....	76
5	First Draft of Illinois DHC Regulatory Exemption.....	77
6	Economic Forecast of the Full System Capital Cost.....	81

FIGURES

1.	Central Plant Location.....	31
2.	Tunnel System Layout.....	32
3.	Plant Design Schematic.....	38

TABLES

3.1	Central Station Heating and Cooling Loads Evaluation.....	18
3.2	Thermal Demands of Central Station Co-Located Large Users.....	19
3.3	Thermal Demands of Large Users Outside of the Immediate Central Station Area.....	21
4.1	Central Station DHC System Capital Cost.....	53

CHAPTER 1 - OVERVIEW AND PROJECT SUMMARY

ABSTRACT

Chicago electricity customers continue to experience high rates. Large commercial customers with all-electric buildings are particularly susceptible to these high rates, especially during the summer when peak demands and associated demand charges rise markedly. Much of the new commercial construction during the 1980s in Chicago's downtown was all-electric. Modern district heating and cooling (DHC) technology - the supply of either steam or hot water and chilled water to two or more separate buildings - is one potential solution to this problem. Modern systems now operating in St. Paul, Minnesota; Hartford, Connecticut; Jamestown, New York; Trenton, New Jersey; Jamestown, New York; Baltimore Maryland; Boise, Idaho; Tulsa, Oklahoma and San Bernadino, California, to cite a few, give credence to the notion of DHC as an means of conserving energy resources and revitalizing downtowns.

This project assisted a private real estate developer in technically assessing the feasibility of integrating a central DHC system into a proposed 72 acre area mixed-use Planned Development (Central Station) just south of the Chicago Central Business District (Loop). The technical assessment concluded that a district heating and cooling system for Central Station will be feasible, provided that a major anchor load can be connected to the system. The system conceived for the site employs a modular approach that adjusts production capacity to actual load growth. The design concept includes gas-fired boilers for heating, gas turbine driven chillers for base loading, electric motor driven chillers for peaking, steam turbines for peak power and back pressure operation, and chilled water storage. Energy will be supplied to the users in the form of steam or low temperature hot water for heating, and low temperature chilled water for cooling.

The feasibility analysis reported here reconfirms the cost-effectiveness of such alternatives, and has already served to justify further implementation work. The system configuration and cost figures reported here will change as subsequent design efforts concentrate on specific and users.

But the basic conclusion is unchanged: district heating and cooling is a very attractive option for Chicago's energy future.

Chicago's diverse economy is dependent on retention and expansion of the business sector in order to maintain its vitality and stability, and the Chicago Department of Planning has for several years sought both supply and end-use alternatives to reduce Chicago's reliance on high-priced sources of energy.

PROJECT PURPOSE

The objective of this project was to demonstrate that an alternative to high electric prices for a future multi-use real estate development could technically be achieved through the development of a district energy system. High energy costs have served to deter economic well-being in many parts of the U.S., encouraging governments at the local state and national levels to devise methods to increase energy efficiency and reduce costs. The distribution of thermal energy from a central source to two or more users -- district heating and/or cooling (DHC) -- is a technology that will play an increasing role in coping with rising energy costs. Three principal benefits DHC offer are:

- 1) economy of scale - large centralized facilities usually operate more efficiently and economically than smaller individual units;
- 2) fuel flexibility - the ability to use a multiplicity of fuels for energy generation and
- 3) better air quality - due to reduced emissions of nitrous oxide, sulfur dioxide, dust particulates, greenhouse gases and chloroflouorocarbons. Emissions can be reduced because of the centralization of point sources resulting in a more efficient use of fuel.

The Department of Planning has inaugurated and/or participated in analyses on the feasibility of DHC for: 1) Community Development Block Grant - eligible neighborhoods for multi-family residential, 2) industrial areas for process applications, 3) commercial customers, that is, high density central business district areas, single high-rise buildings, office buildings, shopping centers and so on, and 4) the institutional sector such as schools, hospitals, colleges, etc. Several non-utility factors have also made the assessment of DHC attractive in Chicago. First, many of the boilers in the City's older building stock have been retrofitted to a multi-fuel capacity (natural gas and oil) and therefore are more easily converted to connection with a district system. Second, extensive networks of existing underground steam lines and freight

tunnels lend themselves to implementation of district energy systems. Third, the City has provided leadership in the analyses of cogeneration (sequential production of thermal energy and electricity) technology and development of waste-to-energy facilities.

The City of Chicago believes that private sector development of a district heating and cooling (DHC) system can introduce cost effective competition into the energy market in downtown Chicago, provide opportunities to reduce summer peak demand for cooling and enhance development of the currently unused Central Station site and the South Loop. In addition, a private DHC system can provide capital and energy savings to the institutions and businesses in the area without significant commitment of scarce public financial resources. Further, the potential exists for using cogeneration as a prime source of thermal energy for the system, thus providing greater efficiency and lower costs for both heating and cooling as well as other non-thermal loads.

Societal benefits can also be realized, since the need for individual commercial heating and cooling systems can be substantially reduced by providing those services from a central source, which will materially diminish the emissions of sulfur dioxide, nitrous oxide, dust particulates and greenhouse gases. District heating and cooling can serve to mitigate the effects of the chloroflourocarbons now used in electric chillers which deplete the so-called stratospheric ozone layer. This is possible because a larger chilling system is much more easily adopted to less environmentally harmful refrigerants such as ammonia or HCFCs.

REPORT ORGANIZATION

This report describes the development of the Central Station district heating and cooling and cogeneration feasibility study and assesses the potential for implementing the system given the current institutional and market conditions.

Chapter 1	Provides a brief summary of the project; its background, objectives and results.
Chapter 2	Describes the partnership developed among Fogelson Properties, Inc., Peoples Gas Light and Coke Company and the Department of Planning, to investigate the potential for DHC and cogeneration at the Central Station site. It also describes how Trigen Energy Corporation was eventually selected as the technical consultant. The integration of DHC considerations into the design of the Central Station process is chronicled as well.
Chapter 3	Describes the conduct of the DHC technical feasibility study. It further describes: 1) the potential for natural gas fired cogeneration as a fuel source for the proposed DHC system, 2) the mechanical components of the proposed system, 3) system phasing requirements based on anticipated real estate build-out, 4) the potential for off-site thermal sales, 5) thermal storage potential and 6) economic parameters.
Chapter 4	Describes the existing legal and regulatory stipulations for developing a district heating and cooling system in Illinois. It provides an approach for alleviating the potential limitations placed upon DHC operators by the Illinois Public Utilities Act.

Chapter 5

Evaluates the prospect of the proposed system being developed, given the conditions most influencing development. It assesses the likelihood of the proposed energy system spurring further redevelopment in the Chicago area. It also presents experiences learned from entering into a partnership with a utility company and a private real estate firm.

CHAPTER 2 - BACKGROUND AND CONCEPT

INTRODUCTION

In 1989, the City of Chicago's Planning Department began working with Fogelson Properties, Inc., a real estate development firm, which was interested in developing the unused land and air rights of the Central Station site. The site is a remnant of the Illinois Central Railroad's development and landfill activities between 1860 and 1930. It is approximately 35 acres of land surface and 34 acres of air rights property running parallel to the southbound lanes of Lake Shore Drive, from 11th Place on the north to Cullerton Street on the south. The property was recently purchased by the developer from the Illinois Central Railroad Company. This project has received particular attention from Chicago city planners due to the magnitude of the site, the transportation and site access issues to be resolved and its proximity to the Lakeshore.

Fogelson Properties, Inc. is a thirty year-old real estate development firm that has successfully developed and rehabilitated residential and commercial properties throughout the Chicago area. The firm enlisted Forest City Enterprises, Inc. as a joint-venture development partner for the Central Station project. This well-capitalized, Cleveland-based firm is a leading developer of shopping centers and downtown mixed-use projects, the most notable being the MetroTech complex in Brooklyn, N.Y. and the Tower City Center in downtown Cleveland, each with a \$1 billion price tag.

Fogelson and his partners worked with City staff on preparing guidelines for development of the Central Station property through Chicago's Planned Development process. A Planned Development (PD), is an amendment to the Chicago Zoning Ordinance which provides for variances to existing zoning which may be required by a specific project, particularly those as large and complex as Central Station. The PD process is divided into two sections: Part I which requires a set of public hearings by the Plan Commission and the City Council before the Zoning

Ordinance is amended by a PD, and Part II, which requires a review of actual project plans prior to construction to ensure that the development conforms to the approved Part I amendment.

The Central Station design is distinguished in several respects. First, the developer envisions a "superblock" concept, configured with irregularly defined blocks, not grids. By implication, transportation and access will be limited, since the developer aims to create a neighborhood ambiance that enhances the pedestrian environment. According to the developer, super blocks would position the site as a destination center that also provides adequate security to residents.

The developer is gearing the site towards occupants seeking proximity to the central business district at moderate prices. "Back office", (clerical) operations of large downtown corporations should be able to take advantage of the reasonably priced rents that will be offered at the site. These operations have increasingly been moved to the suburbs because of ever increasing downtown rents. The hotels envisioned for the site are also anticipated to meet the needs of families seeking moderately priced accommodations.

Infusion of DHC into The Central Station Planned Development Process

Fogelson Properties, Inc. contacted the City Energy Management Division in the spring of 1989 for guidance in examining the possibility of including cogeneration and district energy in the Central Station PD, in order to enhance its economic and environmental attractiveness. Staff met with a company representative to elucidate the concepts of district energy and cogeneration and their attendant benefits, at which time we extended a commitment of resources and staff time toward a technical feasibility analysis.

The DHC inquiry was initiated through a bona fide expression of interest on the part of the real estate developer. As a result, the Energy Management Division in mid-summer, 1989, requested and obtained the assistance of a DHC Technical Assistance Team, sponsored by the

U.S. Department of Housing and Urban Development and administered by the U.S. Conference of Mayors, to qualitatively assess the potential for DHC at the Central Station site. The Technical Assistance Team consisted of representatives from: HUD, the U.S. Conference of Mayors, City of San Francisco staff who had worked on the Mission Bay Energy Plan; John Nimmons, an expert legal consultant in DHC affairs; Trigen Energy Corporation, and Catalyst Thermal Energy Corporation, both owners and operators of DHC systems.

After visiting the site and meeting with the real estate developer and City officials, the Team reached the following conclusions:

- 1) Tremendous potential for DHC development exists because of the size of the Fogelson development and its proposed density; the density of existing development in the area, including, R.R. Donnelley Printing Company, McCormick Place, Michael Reese and Mercy hospitals; the potential expansion of McCormick Place, and the Central Station's proximity to the Loop,
- 2) An existing system of now abandoned freight tunnels under every major street in the Loop represents an opportunity for dramatic savings in transmission cost for expansion of the DHC system to include areas beyond the immediate surroundings of the Fogelson property,
- 3) Private sector development of a DHC system can introduce cost - effective competition in the Chicago energy market, provide opportunities to reduce summer peak demand for cooling, enhance economic and community development, and provide capital and energy savings to institutions and businesses in and around the site as well as the South Loop,
- 4) The Field Museum boiler plant could represent potential thermal capacity for start up phases of a DHC system, and could serve initial development phases of the Central Station site. The linkage between the Field Museum and the Central Station site is made

possible by the existing intact freight tunnel connecting the two sites. The Field Museum could also significantly enhance operating revenues through the sale of excess steam in the early stages of DHC project implementation,

5) A necessary intermediate goal was for the real estate developer to attract a competent DHC developer to the project,

6) The Team saw the early identification of a site of perhaps two acres for a central plant as an important condition to attract a competent DHC developer and,

7) The Team believed the City would have limited financial involvement in the DHC system. It is unlikely that City funds will be expended for energy generation and distribution facilities. However, the City may desire considering the disbursement of public works or CDBG funds in the initial phases of development until sufficient load capacity can be acquired by the developer.

Shortly after release of the Technical Assistance Team report, Energy Management Division staff worked with Team members to put together a list of potential DHC development (as opposed to consulting) experts (item #5 above) from which Fogelson Properties, Inc. could cull DHC engineering design assistance. As previously mentioned, Fogelson Properties, Inc. was strongly interested in utilizing a local engineering firm for that purpose.

The Year 11 UCETF grant provided an opportunity for staff to also commit nominal funding support for this effort. In addition, Fogelson Properties, Inc. and Energy Division staff contacted Peoples Gas to discern its level of interest in supporting the cogeneration feature of the proposed examination. The Fogelson firm identified a local engineering firm, Midwesco, Inc., to lead their efforts in defining the technical issues involved in DHC development.

As it turned out, Midwesco, Inc., a local engineering firm affiliated with Fogelson, and Trigen Energy Corporation are owned by the same parent companies, Cofreth S.A., which is

primarily owned by Lyonnaise des Eaux, both based in Paris, France. Trigen Energy Corporation owns and operates six district heating and cooling companies servicing Tulsa and Oklahoma City, OK; Kansas City, MO; Trenton, NJ; Nassau County, NY and London, Ont. Canada. Trigen employs over 190 people, and 1991 revenues are expected to exceed \$70 million. Fogelson subsequently decided to contract with Trigen for technical engineering feasibility analysis.

It was also necessary to formally link the DHC planning efforts with the overall efforts of the Central Station Planned Development (PD) process. First, staff outlined the anticipated work program for technical feasibility analysis, which was approved under the aegis of Chicago's UCETF Year 11 project and subsequently acknowledged (by Trigen Energy Corporation) as a feasible methodology. Second, staff submitted energy-related language to the Department of Planning's Central Area Division for inclusion into the Central Station Development Guidelines (Part I), adopted by the Chicago Plan Commission in March, 1990¹. This marked the first time energy efficiency and alternative energy systems were included as criteria within a PD application process, and set the stage for Energy Management Division staff to be systemically involved in the PD process.

The Peoples Gas Light and Coke Company was formally integrated into the study process through direct contact with the real estate developer. The real estate developer's principal purpose in contacting the gas company was to gauge its interest in financially supporting the feasibility study of a gas-fired integrated energy system. Peoples Gas administers an Illinois Commerce Commission approved program (General Order 214 of Ill. Admin. Code §430.30) that provides financial assistance to qualifying customers for the technical assessment of cogeneration feasibility. In order to qualify for this assistance, an existing customer or potential customer must initially advise Peoples Gas' Marketing Program of interest in purchasing and installing a gas-fired cogeneration facility. At a maximum, the gas company can provide \$1,000 per KW up to 75 KW of planned or installed electrical generating capacity for a detailed cogeneration economic feasibility assessment.

The company usually makes an initial determination whether the applicant is serious in its investigation of cogeneration, so as not to waste resources. In this instance, Peoples Gas determined that the Central Station inquiry was indeed worthy of its involvement, and agreed to provide financial support for the assessment. In addition to providing the maximum cogeneration allowance (\$75,000), it also provided an additional \$50,000 for study purposes.

Staff also communicated to the gas company our position on the direction of the study. The fact that energy staff has worked for years with Peoples Gas in promoting the development of cogeneration and other energy saving technologies undoubtedly contributed to their timely decision to join Fogelson Properties, Inc. and the City in pursuing this project. Peoples Gas' objective of increasing the use of gas in the commercial building sector, particularly in the air conditioning market, was congruent with the City's objectives of reducing overall costs by introducing competition into the energy services industry, promoting environmentally friendly technologies, and supporting economic development efforts through private sector alternative energy initiatives.

Through a series of meetings, Fogelson Properties, Inc., Department of Planning Energy staff, Peoples Gas and the Midwesco/Trigen tandem agreed upon the scope of work, timetables, and assigned duties. Trigen Energy Corporation and Midwesco, Inc. were charged with developing the overall conceptual design of a DHC system for the Central Station site. The City's role was to evaluate advantages and disadvantages of municipal funding for DHC systems, investigate various city, state and federal permitting requirements as well as procedures for gaining access to the freight tunnel system, and assess the need for and possible means to achieve flexibility in application of State regulation to a DHC system. The City also agreed to assist the technical engineers in gathering data such as maps and boiler and chiller loads in the Chicago downtown area.

Peoples Gas, in addition to the provision of principal financial resources, agreed to provide technical assistance to the engineers through the identification of commercial chilling plants

throughout the Loop area. Fogelson Properties, Inc. agreed to provide information on any significant developments regarding the Central Station project on an as-needed basis.

The technical assessment set out to answer a series of complex, interrelated questions:

- Will the development of the Central Station site and the possible inclusion of existing adjacent customers support a newly developed DHC system?
- Can the Field Museum, the R.R. Donnelley facility or other nearby boiler plants provide interim thermal energy to the anticipated initial development?
- If so, to what extent can the Field Museum and Donnelley benefit economically?
- What other users might easily be accessed, especially through the existing tunnel system, to enhance system economics?
- What are the capital investments needed to provide the type and size of equipment needed for district heating and cooling operations?
- What benefits are derived from having a private district energy firm develop the system, as a partner with Fogelson Properties, Inc.?
- Can a DHC system with cogeneration provide additional savings and a vehicle for the reduction of electrical costs?

The study's authors identified key conditions that will need to be in place to assure project feasibility. First, the load from the planned McCormick Place expansion, or a similar large user, will be needed to provide the base load required for a "viable and cost effective system" ... since the Central Station demand will grow at a deliberate rate. Second, it would likely be beneficial if a DHC operator could be assured of not being regulated as a public utility.

Staff was successful in guiding the technical study along the course it designed as part of the original work plan submitted for this project. Essentially, three issues the City could further investigate to support DHC development were identified:

1. Clarify and codify the City's policy for use of the underground freight tunnel system.

2. Support state legislation that would exempt DHC operators from public utility status.
3. Identify public facilities that could possibly serve as off -site customers for a Central Station DHC system.

At the time of this writing, each of these issues is being actively pursued by Energy Division staff with other agencies of Chicago city government.

The system design requires the use of as much as 1,450,000 mcf of natural gas at a high efficiency through mechanical and electrical cogeneration. The equipment is designed to incorporate modern emission control technology to minimize emissions from the gas turbine drives. The chillers will utilize environmentally friendly ammonia or HCFC refrigerants. The cost of the system was projected at \$74 million in 1990 dollars with a return on assets of 26%, compared to alternative decentralized energy sources.

ENDNOTES - CHAPTER 2

1. Central Station Development Guidelines, March 1, 1990 Section IV. part F. ENERGY states, "Master Plans should address energy efficiency standards for all significant buildings within the property. The standards should reflect those enacted by the U.S. Department of Energy at the time of construction. Because of its size and variety of land-uses, opportunities to implement a centralized district heating and cooling system and energy efficient building design and configuration might exist. The City and developer should explore the use of alternative energy sources and appraise the potential for district heating and cooling. Any agreement between the City and the developer which involves the use of public funds should consider requiring the developer to provide a site for a central energy plant."

CHAPTER 3 CENTRAL STATION DISTRICT ENERGY ASSESSMENT

The objective of this assessment was, in general, to evaluate the technical, economic, regulatory and environmental feasibility of developing a district heating and cooling system for Central Station and other adjacent energy users. Following is an outline of the assessment with emphasis on:

- 1) Thermal Market Evaluation
- 2) Alternative Cost of Non-Centralized Heating and Cooling
- 3) External Energy Sources
- 4) The DHC Distribution System
- 5) The Central Heating & Cooling Plant
- 6) Legal/Regulatory Issues
- 7) Environmental Issues
- 8) Economic Analysis

THERMAL MARKET EVALUATION

Trigen Energy Corporation and Midwesco, Inc. ("the engineers") evaluated the market for heating and cooling utilizing a preliminary construction forecast provided by Fogelson Properties Inc. (see Appendix 1). Based on this schedule, the load was assumed to grow progressively to a maximum of 20,000,000 square feet over a 20 year period. The development guidelines allow for over 12,000,000 sq.ft. of residential and hotel uses, and for approximately 8,000,000 sq.ft. of office, commercial and retail space.

Maximum load was estimated on data from similar projects, and was then re-calculated to adjust for Chicago conditions. The space heating requirements were estimated to be a peak demand of 321 MMBTU/hr. and 602,940 MMBTU annually. These calculations were based on the specific heating requirements of 18 Btu/sq. ft./yr. for residential space and 12 Btu/sq. ft./yr. for commercial space.

Peak demand was estimated based on 2000 and 1600 full load hours for residential and commercial space, respectively (see Table 3.1).

Chilling requirements were estimated at 52,000 tonhours annually based on 500 sq. ft./ton for residential space and 59,510,000 tonhours/annually based on 300 sq. ft./ton for commercial space. The utilization times were estimated to 1300 and 1000 full load hours for residential and commercial space, respectively (see Table 3.1).

As a result of analysis, a heating and cooling energy supply scheme using a low temperature hot water district heating system to meet the space heating and domestic hot water requirements of the proposed buildings was proposed. This type of system will use energy at maximum efficiency with lowest overall capital costs. Hot water with a maximum temperature of approximately 250 degree F will be supplied to the different buildings, employing heat exchangers to produce the low temperature hot water required for space heating and domestic hot water.

TABLE 3.1

HEATING

TYPE OF SPACE	FLOOR AREA (square ft.)	HEATING REQ (Btu/sqft/hr)	USE (hours)	HEAT LOAD (MMBtu/yr)	ANNUAL CONSUMP. (MMBtu)
Residential	10,450,000	18	2,000	188	376,200
Hotel	1,925,000	18	2,000	35	69,300
Commercial	7,200,000	12	1,600	86	138,240
Retail	1,000,000	12	1,600	12	19,200
TOTAL	20,575,000			321	602,940

COOLING

TYPE OF SPACE	FLOOR AREA (square ft.)	COOLING REQ (Btu/sqft/hr)	USE (hours)	COOLING LOAD (ton/hrs)	ANNUAL CONSUMP (MMBtu)
Residential	10,450,000	500	1,300	20,900	27,170,000
Hotel	1,925,000	500	1,300	3,850	5,005,000
Commercial	7,200,000	300	1,000	24,000	24,000,000
TOTAL	20,575,000			52,083	30,033,170

Source: "Central Station District Energy Assessment", September 1990, Chicago, Ill

Chilled water for year - round cooling would be supplied in a separate distribution network. The supply of 34 degrees F chilled water throughout the year would result in significantly reduced capital costs for piping and air handling equipment in the new buildings. The engineers estimated that savings in the order of \$.60 to \$1.00 per square foot of new construction, or as much as \$20 million in 1990 dollars, can be achieved over the build-out schedule.

THERMAL LOADS OUTSIDE CENTRAL STATION

One of the proposed tasks in the Year 11 workplan was to quantify existing adjacent thermal loads for purposes of determining current and future loads. To that end, the engineers, in order to establish technical opportunities for thermal energy sales, visited large users. Most of the identified large users have electrically driven centrifugal chilled water plants with a mixture of fossil fuel and electric boilers for space heating and domestic hot water. The large users and their respective thermal demands are presented below in Table 3.2.

TABLE 3.2

User	Heating Demand (MMBtu/hr)	Cooling Demand* (tons)
Field Museum	25	900
McCormick Place I	120	6000
R.R. Donnelley & Sons	80	0
Michael Reese Hospital	70	0
Mercy Hospital	55	1,800
Hilton Hotel	30	1,600
	—	—
TOTAL	380	10,300

*Loads served by central chiller systems only.

Source: Central Station District Energy Assessment, September 1990, Chicago, Ill

It was determined that a central heating and cooling plant could supply steam and chilled water to a number of these users. Since some of the loads are large, they would have a significant impact on the size and design of a central plant. However, many of these users have existing steam plants with excess capacity. There may be an incentive for these large users to connect to a Central Station district energy system. Many boilers are old models (well over 30 years) and may be operating at low seasonal efficiencies. As a result, escalating operation and

maintenance costs at these aging plants may encourage owners to consider being supplied from an external source.

The base case analysis conducted by the engineers assumed that no external customers would be connected to the central plant. However, it is likely that some external users will hook up to the central system as the connections become economically justifiable. The technical concept of the central plant was therefore developed assuming that supplies of 150 to 200 psig steam would be required in the future.

McCormick Place II & III, planned expansions of the exhibition halls, a domed stadium and a connected galleria shopping center are major developments being considered near the Central Station area. Trigen Energy Corporation developed proposals to supply hot and chilled water to these facilities, and submitted them to each of the competing development teams for consideration. These proposals offered to supply the approximately 120 MMBtu/hr of hot water and 20,000 tons of chilled water that would be required by the new development.

While the certitude of the domed stadium development cannot be determined at this point in time, the financing for McCormick Place II & III expansions and the galleria has received legislative authorization. The heating and cooling demands for McCormick Place II & III are assumed to be 80,000 MMBtu/yr and 6MM/tonhr/yr, respectively. A central heating and cooling system for both McCormick Place II & III and Central Station would provide economies of scale through the provision of a significant thermal load early in the development of Central Station.

Through consultation with Peoples Gas, a number of major energy users were identified outside of the immediate area. All of them are close enough to be considered users/suppliers in a major downtown scheme. Table 3.3 below presents the estimated thermal demands of some of the identified users now served by individual plants.

TABLE 3.3

User	Heating Demand (MMBtu/hr)	Cooling Demand (tons)
Illinois Institute Of Technology	100	0
Union Station Central Plant	100	0
Post Office (previously supplied) from Union Station	100	?
City Hall	135	6,500
Palmer House	75	2,500
Univ. of Illinois - Chicago	170	8,000
Univ. of Illinois Med. Center	450	1,800
Memorial Hospital	210	
Sears Tower	10	9,000
CHA-Public Housing		
-Dearborn	20	0
-Taylor 1-4	210	0
-Stateway	60	0
-Wentworth	100	0
TOTAL	1,755	27,800

Source: Central Station District Energy Assessment September 1990, Chicago, Ill

Most of the users above operate central steam and chilled water plants. It would thus be technically feasible to connect them to a new central system. However, most of the loads are very large compared to Central Station, and are located outside the immediate area. Because of the significant size of the loads, the uncertainty of connection and the substantial impact the loads would have on a limited district heating and cooling scheme at Central Station these users were not included in the base case analysis.

Many downtown large commercial buildings, especially newer buildings, use electricity for heating and cooling. A significant portion of these buildings took advantage of the low capital cost of electric resistance heating and the generous incentives offered by Commonwealth Edison, such as free 12kva risers for all-electric buildings. Since the heating loads of these buildings would be difficult to convert and connect to a central system, they were not given further consideration by the engineers. However, a number of older buildings in the downtown area which use gas fired steam boilers and a steam distribution system for space heating and domestic hot water are suitable candidates for connection to a district heating system using steam as the thermal medium.

The greatest opportunity for connection to a district energy system by downtown buildings lies with chilling loads. Most of the buildings have substantial cooling loads supplied from in-house, electrically driven chillers that use chlorofluorocarbons (CFCs), which have been determined to cause ozone depletion. Due to new federal legislation, these chiller systems will require modification or replacement over the next 4 to 10 years.

Energy staff supplied the engineers with air conditioning machinery and refrigeration permits obtained from the Chicago Department of Buildings. The engineers were able to provide estimates on the potential chilled water load in the Loop. Considering only those units in excess of 400 tons, the permitted capacity exceeds 450,000 tons. Peoples Gas representatives arranged site visits for the engineers to selected buildings. Observations made during the visits indicated that installed capacity often accounts for only 50% to 70% of permitted capacity. Thus, the total potential demand for a future district cooling system was conservatively estimated at approximately 200,000 tons.

With the inevitable phasing out of commonly used CFC refrigerants and the associated cost of chiller replacements, it is conceivable that a large-scale district heating and cooling system will be a feasible alternative for supplying major thermal loads in the Loop area. Should the existing underground freight tunnel system be available as a distribution conduit, minimizing the need for costly excavation, then a downtown DHC system is even more appealing. The engineers did not include the Loop area loads in the base case feasibility analysis because of their significant size of the loads and the uncertainty of connection, but the prospect of such a large potential market is certainly an inducement to further development of a DHC system in or near the Loop.

COST OF NON CENTRALIZED HEATING AND COOLING

The engineers estimated the cost of conventional heating and cooling in order to provide a basis for establishing a competitive rate structure and for estimating the proposed system's revenue from energy sales. The two most common alternatives evaluated for the heating and cooling of new and existing buildings were: 1) electric resistance heating and electrically driven chillers, and 2) gas fired steam/hot water boilers and electrically driven chillers.

The all-electric alternative is most commonly used for large modern buildings in Chicago because of the previously mentioned incentives offered by Commonwealth Edison, through Rate 6L and Rider 25. Surveys revealed that heating by steam boilers with steam or hot water distribution is predominantly used in older buildings.

A central system with gas fired boilers and electric chillers would supply both hot water and chilled water from a single plant, thus eliminating the need for boilers or chillers to be located in the buildings served. Hot and chilled water would be supplied to each air handling system from the central connection point in each building.

Appendix 2 shows the comparison between the total annual heating and cooling costs for a typical 1,200 sq. ft. condominium and a 1,200 sq. ft. office building. The typical condominium unit was estimated to have annual heating requirements of 36,000 Btu/sq.ft. and annual cooling requirements of 2.6 ton hours/sq.ft. The typical office unit was estimated to have annual heating and cooling requirements of 20,000 Btu/sq.ft. and 3.3 ton hours, respectively.

As can be seen, electric heating and cooling has the highest total lifecycle cost, although they are less expensive to install than gas fired boilers and central chillers. Alternatively, district energy offers the lowest total cost. In addition, DHC offers benefits such as less required space, fewer maintenance requirements, lower noise, improved building appearance and environmental attractiveness.

Consistent with elements of the approved Year 11 Workplan, the engineers evaluated a number of existing boiler plants located adjacent to the Central Station site to determine the potential for incorporating them as either primary or backup energy plants to a DHC system. These plants included the Field Museum, Donnelley printing, McCormick Place I, Mercy Hospital and Michael Reese Hospital. Energy staff provided the engineers with background information on the plants culled from previous Department of Planning surveys. Following is a synopsis of the current conditions of each boiler plant with respect to age, capacity and potential for connection to a district heating system.

Field Museum

The Field Museum, located east of the Central Station site, can be connected rather inexpensively to a district heating system. The plant consists of one summer boiler and three winter boilers which were installed between 1949 and 1959, with a total capacity of 63,000 lbs/hr. Of this amount, 8,000 lbs/hr is low pressure steam. The system's current peak demand is approximately 30,000 lbs/hr, resulting in 25,000 lbs/hr of excess high pressure capacity during peak conditions.

A single 950 ton machine operating with a supply temperature of 43 degrees F serves the existing cooling load. The boiler room is interconnected with both the Shedd Aquarium and Soldiers Field (where the Chicago Bears play) via tunnels through which steam was supplied until a few years ago. The boiler room is also connected to the Chicago Freight Tunnel System, although the section between the Field Museum and Wabash Avenue is flooded with about 3 feet of water.

R.R. Donnelley & Sons

Donnelley's central boiler plant, consists of four boilers between 2 and 22 years old with an installed capacity of 200,000 lbs/hr, that supply 120 psig steam to meet a peak demand of up

to 100,000lbs/hr. No chillers are installed in the boiler plant which is located near the southern end of Central Station and McCormick Place II. Donnelley has reduced its operations at this plant over the years and it is unclear as to whether the plant will even remain open, particularly in light of reports of possible conflicts with the planned expansion of the exhibition center. If operations continue at the present site, the R.R. Donnelley central boiler plant has significant excess capacity that might be captured to supply either Central Station or McCormick Place, on an interruptible basis.

McCormick Place I

McCormick Place I, located near the southern end of the Central Station site, has a plant with an installed capacity of 160,000 lbs/hr of 100 psig steam in four boilers. An adjacent room houses 8,500 tons of capacity using five chillers. All of the equipment, with the exception of three older chillers, was installed in 1969 when the center was built.

The boilers and chillers appear to be well maintained, and are well suited to supply energy to Central Station. However, the engineers did not determine to what extent capacity is available during peak conditions. Based on an assumed 30% back-up capacity, up to 50,000 lbs/hr and 2,500 tons could be available on an interruptible basis.

Mercy Hospital

This facility is also located south of the Central Station site and the exhibition center. The installed capacity of the boiler plant, located in the sub-basement of the main building, includes four steam boilers with a capacity of 105,000 lbs/hr; an incinerator with a capacity of 14,000 lbs/hr; and three 1,000 ton chillers. The primary equipment was installed in 1967 and 1974. The peak demand was estimated at 55,000 lbs/hr leaving 50,000 lbs/hr of available capacity to supply a district heating system on an interruptible basis.

Michael Reese Hospital

This facility, located close to Mercy Hospital, has a separate boiler plant with an installed capacity of 170,000 lbs/hr, from four boilers installed in 1953. The hospital's peak demand is 70,000 lbs/hr, of 150 psig steam. The plant's age and lack of proximity renders this facility doubtful as a potential interim supplier for the Central Station site.

As can be seen, there are a number of central boiler plants able to supply steam and/or hot water to a district heating system in Central Station. The potential for supplying chilling capacity is more limited because of a lack of existing excess capacity. The age, ownership and location factors combine to create a degree of uncertainty as to whether any of them can in fact be connected to the system as suppliers. Thus, the engineers elected to not consider the aforementioned excess capacity supplies for base case feasibility analysis. However, the potential for tapping into one or more of these resources is recognized, and would be further explored if the Central Station DHC project is developed.

THE DHC DISTRIBUTION SYSTEM

The engineers designed a distribution system that would supply heating and cooling to McCormick Place II and III, and to other users in the Central Station contiguous area. Two-pipe distribution systems for heating and cooling were selected for design purposes, since both heating and cooling would be provided the entire year. They recommended that a central supply of domestic hot water be further investigated during the actual system development, which would necessitate two additional pipes. This arrangement would have the combined effect of capturing more waste heat and increasing system efficiency.

Heating Concepts

Thermal energy is normally supplied as steam or hot water. Water is an inexpensive medium with high specific heat content, and as such, is suitable for the large-scale distribution of energy.

The end-user requirements determine the choice between steam and hot water. For process applications such as food production or for hospitals, steam would be the medium of choice. On the other hand, space heating requirements can be suitably met, most by employing high temperature hot water.

Steam is more expensive to produce, requires a more expensive distribution system and operates at lower efficiency. On the other hand, steam does offer significant flexibility in that it can serve hydronic (hot water) and steam buildings as well as process loads through the introduction of heat exchangers.

Hot Water Distribution System

This type of system is optimum for a central plant at the proposed Central Station site because it can serve all the thermal needs of the planned buildout and because the McCormick Place expansion is projected to use hot water distribution rather than steam. The engineers developed a design that maximizes the carrying capacity of the network, minimizes heat losses in the ground; and is conceptually close to conventional HVAC equipment.

State-of-the-art equipment such as heat exchangers connected between the district heating system and each building would be used. Also, buildings should be designed to use variable flow and temperature set back of the supply water. Thus, the heat exchanger controls could ensure that the temperature of the supplied hot water during the coldest days is maximized but not so during less severe weather. The engineers recommended a standard piping system commonly used for hot water distribution.

Steam Distribution System

The engineers also designed an expandable steam distribution system that would be necessary to supply the large number of steam users adjacent to the Central Station site; utilizing the

underground freight tunnels as a conduit for distribution. The system would consist of standard steam pipes with an electronic leak detection system installed.

Cooling Concepts

The engineers employed proven industrial chilling concepts and innovative technology currently utilized for Trigen's existing 55,000 tons of central chilling to design a district cooling system for the Central Station project. This approach would allow the power required for pumping and pipe size to be minimized while increasing the chiller load factor.

The installation of temperature control valves to each building, which sense and maintain a minimum return temperature to the central system, is another innovative technology to be employed in the proposed system. If the in-building system is returning water that is cooler than optimal, some of this water will be returned to the supply side, raising the temperature that is entering the building. Consequently, building designs should incorporate several features, including:

- Coils designed to return 58 degrees F at design loads;
- Variable volume in building chilled water distribution; and
- Two-way valve control systems with no bypass of coils allowed.

To further reduce pipe sizes, the engineers considered the use of a thermal storage tank. Thermal storage can accomplish the following:

- Reduce required peak capacity at the central plant.
- Allow the chilled water plant to operate all night, when chilling loads are low, maximizing utilization of capital intensive chilling equipment.
- Take advantage of low off-peak electric rates.

Appendix 3 shows total plant load projections for heating and cooling, on an annual basis for a twenty year term. The projections are based on the previous thermal market evaluation which showed hot and chilled water loads in the Central Station development of 320 MMBtu/hr and 52,000 tons respectively, for final forecast construction. Based on an 80% diversification factor (the buildings do not peak at the same time) the resulting loads were estimated at 250 MMBtu/hr and 44,000 tons/hr. The resulting annual volumes were estimated to be 603,000 MMBtu and 59,510,000 tonhrs. In addition, the system is designed to supply McCormick Place with 12,000 tons and 6,000,000 tonhrs of cooling and with 80 MMBtu/hr and 80,000 MMBtu of hot water annually. The resulting plant peak demands were estimated to 330 MMBtu/hr and 56,000 tons.

Description of Distribution System

The engineers were not able to develop a distribution system layout for Central Station since no street plan was available at the time. Instead, they estimated the extension and pipe sizes for the final system based on general project information and property size. They estimated the system cost based on recent experience from similar installations, adjusted for Chicago conditions. They assumed the system could be installed on the currently vacant land and that few existing streets would be excavated and reinstated. Rather, the piping would be installed under the new public access roadways. Figure 1 shows the plant location which would dictate the distribution system.

The Chicago freight tunnel system would provide an excellent means of routing piping to potential customers throughout the Loop area. Figure 2 illustrates the tunnel system layout. The tunnel system, installed in the late nineteenth century, is located approximately 40 feet below the ground.

A survey of the tunnel system by the engineers indicated that the tunnels are generally in good shape, even though some sections are partly flooded and would have to be pumped out. Parts of the tunnel system are heavily used by Commonwealth Edison, which maintains those portions and keeps security gates locked. Even these sections are part of Chicago's public rights-

of-way, and therefore potentially accessible for a DHC system. Other parts of the system, currently used by cable television and fiber optics companies, have sufficient space for district heating and cooling piping.

FIGURE 1
CENTRAL PLANT LOCATION

FIGURE 2

ESTIMATES OF HEATING AND COOLING PRODUCTION

The aforementioned thermal market evaluation resulted in estimated hot and chilled water loads for Central Station of 320 MMBtu/hr and 52,000 tons for the final forecast construction. An 80% diversification factor (since buildings do not all peak simultaneously) resulted in estimated loads of 250 MMBtu/hr and 44,000 tons of hot and chilled water production. The associated annual volumes were estimated to be 603,000 MMBtu and 59,510,000 tonhrs, respectively. The supply of McCormick Place would require 80 MMBtu/hr and 80,000 MMBtu of hot water annually and 12,000 tons and 6,000,000 tonhrs of annual cooling.

THE CENTRAL HEATING AND COOLING PLANT

The engineers developed the DHC plant's design concept to maximize thermal efficiency while minimizing the total life cycle cost. Specifically, this refers to the first costs in the new buildings that are served by the system and the provision of the required capacity at the highest level of reliability. The plant was developed using a modular approach, to minimize the economic penalty of a more than likely slowly growing load (over a 20 year period).

Heating Energy Production Design

The engineers selected a design using packaged boilers producing 200 psig steam that would provide maximum flexibility in producing inexpensive hot water for McCormick Place and Central Station users and steam to other potential users. Natural gas and/or light fuel oil are the optimal fuel alternatives for a plant in Chicago. Although steam energy is unnecessary for the Central Station project, it provides an opportunity for cogeneration to supply on-site loads at the central plant. Economizers which pre-heat DH water will be connected to the boilers, resulting in the flue gases being cooled to less than 250 degrees F, significantly increasing the efficiency of the plant in comparison to conventional boilers.

Cooling Plant Concepts

The engineers selected industrial ammonia screw compressors and variations of centrifugal HCFC machines as viable options for chilling technology. The technicians evaluated single stage and 2-stage absorption chillers and determined that these machines were economically infeasible since they require high steam consumption, high costs, and high temperature supply, as a result of the utilization of natural gas.

For their base case analysis, the engineers selected 2,000 ton ammonia chillers and as an alternative, large centrifugal HCFC chillers in the 2,000 - 6000 ton range that could be used as they become commercially available. Although there are currently no large centrifugal chillers that use "environmentally benign" refrigerants, i.e., R-134a or R-123, manufacturers expect that such machines can be delivered within the next few years. Appendix 4 shows the comparison among the different chiller options.

Chiller Drive Options

The engineers selected gas turbine drives for the base load chillers and electric drives for the peaking units. These selections were made from a host of options including: electric motors, steam turbines, gas reciprocating engines and gas turbines. The selected configuration offers the optimum efficiency and least cost over the life of the project given current prices for electricity, gas and capital.

Condenser Cooling

It is necessary to reject low grade heat from a central cooling plant. In a decentralized cooling plant, heat rejection takes place through cooling towers. If the Central Station district cooling plant does not have the benefit of thermal storage then as much as 800 MMBtu/hr of low grade heat will need to be rejected. This heat can be rejected either to Lake Michigan, the Chicago River or (through cooling towers) the air.

Staff acquired information from the Illinois Environmental Protection Agency and the Army Corps of Engineers which suggests that it is possible to obtain a permit for rejecting low temperature water into the river. An important issue, however is the transportation of large quantities of water from the river to the cooling plant and back. According to the engineers, as much as 180,000 gallons per minute of water will be need to be transported during peak conditions, assuming no benefit of thermal storage technology. The Chicago freight tunnels could possibly be used for installation of condenser pipes, but this alternative seems remote because of the space they would take up. As a result, the engineers assumed that evaporative chillers would be utilized.

COGENERATION ALTERNATIVES

One of the goals of this technical analysis was to determine the feasibility of incorporating gas fired cogeneration into the design of the district energy system. The engineers evaluated various options to consider how the in-plant and parasitic loads could be handled. The in-plant electricity use can be handled by gas fired cogenerated power and steam-based condensing power. The engineers developed a concept with eight 1 MW gas turbines providing the driving power for the base load chillers. The exhaust gas would be routed through a heat recovery steam generator, producing up to 40,000 lbs/hr of steam during the summer season. This steam can be used in a steam generator set to either heat hot water for the DH system or be condensed at vacuum.

The available gas turbines are incapable of carrying the full load of the chillers during the summer season, because they lose efficiency at high ambient temperatures when compressor horsepower increases. Therefore, the engineers suggested that the remainder of mechanical power be provided by an induction motor/generator installed between each gas turbine and compressor. Inexpensive electricity (for in-plant use during the winter, spring and fall seasons) could be generated by the turbines if the motors are sized to the full output of the turbines. This configuration is commonly referred to as a "combined cycle mode".

During the summer peak, all chillers and electric motors will generate a large net electricity demand, estimated at approximately 15 MW. The average electricity cost (energy + demand) would be quite high, as would the cost of electric service to the facility. The engineers propose the use of steam turbines (200 psig) to handle this load. These steam turbines can be installed at a relatively low cost, offsetting the inefficient use of high pressure steam for power generation. The installation of three 5 MW steam turbines would produce summer peak electricity at a marginal cost of about 6 cents/KWhr, resulting in annual energy cost savings of approximately \$800,000 in 1990 dollars.

Central Plant Description

As previously noted, due to the uncertainty of build-out, it was necessary for the engineers to design a central plant with modular units. The completed plant will include 8 gas turbine driven ammonia chillers and 8 electrically driven ammonia chillers. The chillers will supply up to 29,000 tons of 34 degree F chilled water to three 5 million gallon thermal storage tanks, to meet a cooling demand of up to 56,000 tons of diversified demand. Steam in the amount of 40,000lbs/hr of 200 psig steam will be recovered from the gas turbines and supplied to the hot water district heating system, or used to produce electricity in a steam turbine. The hot water for the DH system will be produced by high pressure steam (200 psig), passed through an extraction turbine and a steam-to-hot water heat exchanger.

Figure 3 shows a schematic of the plant design. In total, the plant will include:

- 5 X 80,000 lbs/hr packaged water tube steam boilers with a rating of 200 psig.
- Eight gas turbine driven and eight electrically driven ammonia chillers, each with a capacity of 1800 tons at 34 degree F. The gas turbine driven chillers will be equipped with additional induction motors/generators.
- Evaporative condensers for 29,000 tons capacity.
- Three 5 million gallon chilled water storages.

- A 40,000 lbs/hr heat recovery steam generator, producing 200 psig steam from the gas turbine exhausts.
- District heating economizers cooling the flue gases to below 250 degree F.
- Two 7.5 MW steam turbine generators for 200 psig saturated steam, with extraction at 15 psig. The turbines will produce approximately 7 MW in the full extraction mode.
- A cooling tower for the steam turbines with a capacity of 200 MMBtu/hr.
- Gas turbine emission control through water ejection, reducing the nitrous oxide emissions to environmentally acceptable levels.
- A staffing mode @ 24 hours per day.

FIGURE 3
PLANT DESIGN SCHEMATIC

CHAPTER 4 - CENTRAL STATION PRACTICAL AND OPERATIONAL ISSUES

Energy staff realized early on that the determination of DHC feasibility in Chicago would involve more than just an economic assessment. Since this project considered the use of Chicago's freight tunnel system and clarification on Illinois' regulatory treatment of thermal energy systems, it was necessary to formally assess the associated issues. During planning discussions for this study, technicians, staff and developers concurred that legal, regulatory and environmental issues were priority items and consequently incorporated into the feasibility study design. The Planning Department's Energy staff took the lead in analyzing these legal, regulatory and municipal permitting issues, both because many of them are municipal responsibilities and because of their experience examining issues of municipal and state authority regarding public utilities and alternative energy systems.

LEGAL AND REGULATORY ISSUES

Staff commissioned John Nimmons & Associates, who served on the HUD/U.S. Conference of Mayors sponsored Technical Advisory Team, to carry out a series of tasks that analyzed state and local law with respect to public utility treatment, franchise issues affecting private district heating and cooling development, and permitting issues. It is important to note that the work performed by the consulting firm was not intended as legal advice to the City but was rather viewed as a guide for City officials to expeditiously support the private development of district energy.

The following is a synopsis of the relevant findings of Nimmons & Associates with respect to the analysis of statutes and court decisions and the identification of options available as alternatives to fully regulated public utility status. In addition, the following outlines the research on the City's authority to enter into a franchise agreement with a private district energy developer, delineating the potential benefits from such an arrangement.

ILLINOIS "PUBLIC UTILITY" DEFINITION

A district heating and cooling system, particularly in its initial stages of development, typically does not meet the conditions traditionally ascribed to a "public utility". Application of such a regulatory status may well impose burdens on the DHC system and pricing restrictions so onerous as to deter successful development of a DHC system.

An entity defined as a public utility "holds itself out for public use", and thereby incurs an "obligation to serve". With some exceptions, it is obligated to provide service to any potential customer which requests it. A public utility typically enjoys monopoly or near-monopoly status in a prescribed service territory. It is therefore subjected to comprehensive regulation of its capitalization, construction, service, rate-setting and other business decisions, for the primary purposes of ensuring that it does not abuse its market power through discriminatory service and pricing decisions.

A DHC system in its initial stages, by contrast, will typically be designed to serve only a limited number of customers, must be competitive with existing suppliers, and will negotiate pricing arrangements with individual customers which reflect not only competitive costs for energy, but also the capital savings to the customer from connecting to a central energy system from displacing in-building equipment.

For these reasons, the comprehensive economic regulations typically applied to an investor-owned public utility may not be necessary for a new DHC system, and the relative inflexibility and heavy compliance costs such regulation often entails may preclude such a system from ever becoming an effective competitor in the energy market. It may therefore be desirable to seek alternative regulatory mechanisms which protect the public interest from unreliable or discriminatory service, but which do not impose undue burdens on the introduction of a potentially lower-cost and more environmentally benign supplier into an energy service market.

Public Utilities Code Section 3-105 is the Illinois statute defining a "public utility". Its relevant language is as follows: "Public Utility means and includes, except where otherwise expressly

provided in this Section, every corporation [or other entity] that owns, controls operates, or manages...directly or indirectly, for public use, any plant, equipment or property used or to be used for or in connection with, **or owns or controls any franchise, license, permit or right to engage in:**

a. the production, storage, transmission, sale, delivery, or furnishing of heat, cold ... power, electricity or water; ..." (emphasis added by consultant)

Thus, two separate and independent tests for public utility status exist to trigger regulation. The first is the conventional test requiring ownership or control for public use of equipment or property for engaging in the specified utility activities. This test measures the scope of service and arrangements with customers to determine whether a public use is achieved. The second test is simply the ownership or control of a franchise, license, permit or right to engage in utility - type activities. It does not include language requiring a "public use": the only determination it appears to require is whether the supplier owns or controls any of the rights or privileges mentioned. According to Nimmons & Associates, this test may be unique to Illinois.

The "franchise, license, permit or right to engage in" language of the Illinois statute appears on its face to constitute independent grounds for Illinois Commerce Commission (the state regulatory body) jurisdiction. However, only a few court cases address this question and they yield no consistent interpretation to guide the City or a prospective Central Station DHC developer (Nimmons & Associates, 1990).

The consultant reviewed three court cases, which all suggested that a public use test was required as a condition of public utility status, with or without a franchise. With one exception, none of these opinions addresses the fact that the "public use" requirement is absent from the statute's "franchise, license or right to engage in" provision.

From the perspective of potential DHC developers, the most favorable interpretation would be that ownership or control of a municipal franchise, license or permit does **not** result in public utility status unless the service is supplied for a public use. The difficulty is that none of the cases say

exactly that, and the ones which suggest it fail to resolve or explain away the statute's contradictory language.

In practical terms, a prospective DHC developer who prefers a non-regulated status may not want to rely on the most optimistic interpretation of a few old cases, which appear to contradict the statute's clear language, as a basis for investing significant capital in a new system and thereby incur the risk that another court will treat it as a public utility the first time a competitor or a disgruntled customer complains.

CITY OPTIONS UNDER "FRANCHISE" AND "PUBLIC USE" TESTS

Conventional wisdom suggests the City (as a promoter of DHC technology) should consider its options under both interpretations of the statute. In other words, we should consider actions available to us to encourage DHC if 1) the statute means what it says and a municipal franchise or other right to engage in DHC activities by itself will make the DHC supplier a public utility, or 2) the statute does not mean what it says and a "public use" is required to trigger regulation whether or not the supplier holds a franchise or similar right from the City.

Determining the appropriate City course of action is also complicated by the lack of precedent as to what type of City "permit" might trigger the cited clause in the Public Utilities Act. It is therefore not clear whether it would be necessary or desirable to issue a franchise for a system with a limited geographic scope.

Nonetheless, there are certain types of business activities which will require City permitting. For example, City policy requires express City permission to use the public way for any private enterprise. Permits are required for several enumerated activities; in all likelihood, a DHC developer will need to conduct some of them¹.

There is no precedent to guide whether permits to use public rights-of-way would trigger the Public Utility Act's definition of regulated public utility status. Our research does indicate that

similar ambiguities have existed in other states, and that the State of Washington and others, desiring to support the development of private DHC development, have resolved these ambiguities by exempting DHC from public utility status.

City Energy Management Division staff directed Nimmons and Associates to draft such a legislative exemption. This draft exemption proposes to amend the Illinois Public Utilities Act to expressly exempt thermal suppliers from "regulation" by the Illinois Commerce Commission. This legislative proposal, modeled after legislation passed in the State of Washington, would require the Illinois Commerce Commission to issue a "nonexclusive operating permit" to a thermal supplier, upon determination by the Commission of the adequacy of the applicants' financial status and business plan. Public utilities, as defined in Section 3-105 of the Illinois Public Utilities Act, would not be prohibited from developing, owning and/or operating district heating and cooling systems. However, the Illinois Commerce Commission would be prohibited from setting a thermal energy provider's rates charged to individual customers (see Appendix 5).

CITY FRANCHISE AUTHORITY, POTENTIAL BENEFITS

City Authority to Enter Into DHC Franchise

Illinois court decisions firmly establish the authority of cities to enter into franchise arrangements with private parties, under their home rule powers, in the absence of a state constitutional provision or general enabling legislation setting forth such authority. Chicago's UCETF Year 9 project, entitled "The Electric Utility Franchise Expiration and Renewal Process", (1988) documents Illinois case law which establishes that the franchise authority extends to areas beneath, in and above streets and other public rights of way, and is not limited to particular types of utility services.

Potential Municipal Benefits Derived From a DHC Franchise

Assuming that some form of franchise or permission to use the public way would be necessary for a private DHC system to become operable, the City requested Nimmons & Associates to outline benefits the City could realize from entering into such an arrangement.

The potential benefits the City could realize (without regard to particular order of importance) include:

1. The right to collect a franchise fee and a municipal utility tax to compensate for the DHC supplier's use of the public way;
2. Legal control over the DHC developer's activities affecting public streets and rights of way, including termination rights in case of serious defaults by the developer;
3. Coordination with other activities affecting City streets and rights of way;
4. Definition of the rights and obligations of the DHC developer and the City concerning excavation, construction, operation, maintenance and repairs;
5. Definition of the DHC development schedule, particularly as it affects other City interests;
6. The right to inspect the supplier's books and records to ensure proper calculation of any fee based on sales revenues;
7. The right to inspect the supplier's operations to ensure proper compliance with safety requirements;
8. Protection through bonding or other means against liability for any damage or injury resulting from the supplier's activities;
9. Reservation of municipal rights to construct or relocate streets and public places notwithstanding the presence of DHC lines;

10. Definition of any terms and conditions under which the City might acquire the DHC system at some future time; and
11. Restrictions protecting City and customer interests in case of any change in DHC system ownership.

In sum, the merits of a DHC franchise for the City and the DHC developer reside in all the benefits listed above. However, the principal merit of a franchise relationship to the developer is increased certainty and predictability. That is, a developer would know beforehand that he has a legal right to use the public right of way, and precisely under what conditions; certainty regarding those rights may be critical to securing system financing.

ENVIRONMENTAL REGULATION OF A DHC SYSTEM

A central DHC facility must comply with the requirements set up by federal, state and local governments that serve to minimize adverse environmental impacts. In this instance, atmospheric emissions from the combustion of natural gas is the most significant impact the proposed system will have on the environment. Through use of more efficient equipment and advanced control systems and cogeneration technology, a facility with very high efficiency and minimal impact on air quality can be designed. Modern emission control technology in combination with the same parameters can help to reduce the environmental impact to a low level unmatched by other energy supply options.

Under the original Clean Air Act (1970), the U.S. Environmental Protection Agency developed national air quality standards and established technology requirements for new sources of air pollution. The National Ambient Air Quality Standards (NAAQS) were formulated for six pollutants, including total suspended particulates (TSP), sulfur dioxide (SO₂), nitrogen oxide (NO_x), carbon monoxide (CO), photochemical oxidants and lead. Pursuant to the act, the Illinois EPA was assigned the responsibility of developing and administering programs to meet the NAAQS.

The use of natural gas as a fuel supply will result in lower general emissions than most other fuels. However, gas turbine emissions are a general concern because combustion takes place at such a high temperature, resulting in the formation of NOx, the most critical of the criteria pollutants associated with burning fossil fuels. Extreme levels of NOx can contribute to unsafe levels of ozone concentrations that can result in acid rain. The engineers identified several methods to significantly reduce NOx emissions from gas turbine combustion, including water or steam injection, low-NOx burners; and catalytic converters.

The Federal and State Environmental Protection Agencies regulate emissions from gas turbines more strictly for certain kinds of new equipment through criteria known as New Source Performance Standards (NSPS). Any new boiler or turbine is subject to NSPS, like maximum emission levels for NOx based on the fuel bound nitrogen and the heat rate of the unit.

The Prevention of Significant Deterioration (PSD) regulations emanating from the federal Clean Air Act govern emissions from a gas turbine fired DHC system as well. The system would be subject to these regulations if it has a "potential to emit" more NOx than 40 tons per year. Limiting the use of fuel is one way to not surpass that restriction.

Based on the estimated loads fully developed plant in the year 2012, the eight gas turbine units could operate for an average of 4,000 hours per year without exceeding the 40 ton limit. If additional gas is used for district heating this would increase the production of NOx above the limit and the plant would be licensed as a "major source" when fully developed. The allowed limits would not be surpassed during the first ten years of operation and the plant will be classified as a minor source during that time frame.

A major source is defined as any stationary source or group of stationary sources located within a contiguous area that emits or has the potential to emit a hazardous air pollutant. "Major source" designation results in disallowance of additional emissions of other sources in the defined area.

Permits to operate would have to be obtained from the Illinois Environmental Protection Agency (EPA) for air pollution controls. Chapter 11 of the City Code empowers the Chicago Department

of Consumer Services to enforce limitations promulgated by the Illinois Pollution Control Board in the areas of air and water quality. Thus, for purposes of applying air quality regulations to a cogeneration (gas-fired) facility the Illinois EPA would:

- Examine the proposed facility to determine whether it will comply with applicable emission standards,
- Examine the NAAQS attainment status of the site for all the regulated pollutants that would be emitted from the proposed facility,
- Based on the attainment status and expected emission rates of the cogeneration facility, determine whether it would be considered a major source of pollution, and whether it would be subject to either the PSD rules or non-attainment rules and,
- Examine compliance with PSD or the non-attainment rules, as applicable.

The City also regulates the use of refrigerants through the Municipal Code as specified in Chapter 13, Article VIII. Specific requirements exist for the use of ammonia (classified as a Group 2 - Irritant) as well as other refrigerants².

Chlorofluorocarbons (CFCs)

Staff as well as the technical consultants were sensitive to the impact of the Montreal Protocol, an agreement signed by 24 nations banning the use of CFCs 11, 12, 113, 114, and 115. The U.S. Environmental Protection Agency has proposed regulations that will be used to enforce cuts in production of these compounds, first scaling back to 1986 levels in 1989 and then reducing the weighted composite production by 20 percent in 1993 and by an additional 30 percent by 1998.

A brief overview of the impact that CFCs have on the atmosphere is in order. The "ozone layer" actually consists of ozone present in very low concentrations in the stratosphere between 7 and

28 miles in altitude. Ozone, or O_3 , is formed by the interaction of ultraviolet radiation from the sun with molecular oxygen (O_2). Ozone is unstable and eventually reverts back to oxygen. Chlorine, emanating from CFCs, in the upper atmosphere will stimulate the destruction of ozone and thus upset the balance between its continuous creation and destruction. Ozone depletion results in excess exposure to the harmful ultraviolet rays from the sun for all life at the surface level of the planet earth.

"Harmful" CFCs in this instance are hydrocarbon based compounds to which chlorine or fluorine are attached. The threat these compounds pose results from them remaining intact in the lower atmosphere over a long period of time. Compounds that are broken down very quickly in the lower atmosphere are washed away by rain. Hence, the ozone-depletion potential of a refrigerant is related not only to its chlorine content but also to its atmospheric lifetime, which has been shown to be a function of its hydrogen content, that is, the more hydrogen present, the likelier to decompose in the lower atmosphere (American Society of Heating and Refrigeration and Air Conditioning Engineers, 1989).

Current technologies for commercial buildings use CFCs 11 and 12 in centrifugal chillers. The ideal substitutes for the CFCs in these applications would be chemical compounds that very nearly duplicate the desired properties of CFC 11 or 12, yet do not pose an environmental threat. Several hydrogen-based CFCS (HCFCS) have been identified that may serve as substitutes for the more conventional refrigerants. These chemicals either contain carbon-hydrogen bonds, which help them break down in the lower atmosphere; or do not contain any chlorine at all; and consequently do not pose a threat to stratospheric ozone.

Some of these substitutes, which require minimal product performance design, production or cost changes do pose other problems. Very few of the CFC compounds under consideration as substitutes to the fully halogenated compounds are simultaneously nonflammable, of low toxicity; and environmentally benign, due to their molecular structure.

One substitute for CFC R-11, HCFC-123, was introduced to the market earlier this year by manufacturers such as Carrier and Du Pont, among others. However, six months after introducing

some of these much-heralded substitutes, manufacturers are informing customers that the new refrigerants may be toxic. In tests with male rats, the substitutes caused nonmalignant tumors. Carrier, at the time of this report, had suspended the sale of industrial chillers that use the new substitutes. Additionally, the company had ceased retrofitting currently operating equipment for use with the new substitute (Wall Street Journal, 1991). Thus, the cooling industry is far from closure on finding suitable substitutes for the ozone-depleting refrigerants.

Ammonia Refrigeration

The proposal by Trigen Energy Corporation to provide centralized chilling through ammonia screw compressor technology has significant merit in light of the fact that CFC R-11 and other traditional refrigerants currently used in Chicago downtown office buildings for air conditioning systems will be phased out of production in the near future. Ammonia was first used as a refrigerant in the 1870's, and continues to be used in some industrial applications such as food processing, the preservation industry and the chemical and process industries. There are currently nearly 160 industrial permits in the city of Chicago for ammonia refrigeration. According to the International Institute of Ammonia Refrigeration, one suburban Chicago office building's ice thermal storage system, which provides chilled water for air conditioning, is served by an ammonia system.

As a basis for assessing the advantages and disadvantages of ammonia, it is prudent to compare its physical properties and performance characteristics with that of its strongest existing competitor - CFC R-22. This refrigerant is not fully halogenated and therefore has one-twentieth the ozone depletion potential of CFC R-12. This refrigerant is found in most packaged air conditioners, such as window units, central residential units and smaller commercial building air conditioning applications. It also directly competes with ammonia in the industrial refrigeration industry.

The principal advantages for using ammonia over CFC R-22 are: (1) lower cost, (2) better cycle efficiency in most temperature ranges, (3) higher critical temperature, (4) higher heat-transfer coefficients, (5) greater detectability in the event of leaks (due to its strong odor), (6) lower liquid pumping costs for liquid recirculating systems, (7) more tolerance of water contamination, (8) more

favorable behavior with oil, (9) no direct effect on the ozone layer and (10) the necessary refrigerant can be transported with smaller pipes.

Toxicity is the major concern of the use of ammonia as a refrigerant, depending on the maximum concentration levels of the liquid. ANSI/ASHRAE Standard 34-78, Number Designation and Safety Classification of Refrigerants and ANSI/ASHRAE Standard 15-78, Safety Code for Mechanical Refrigeration are the two standards that regulate ammonia. Under the Standard 34, ammonia is treated as a Group 2-refrigerant (those which have a higher degree of toxicity than those in Group 1 and may or may not be flammable) and this designation carries over to Standard 15 as well as to certain building codes. Practically speaking, this means that the City of Chicago Building Code currently provides reasonable protection for the application of ammonia refrigeration in the 160 facilities currently permitted in the city.

As can be seen, the advantages of using ammonia as a refrigerant in a central cooling plant application far outweigh the disadvantages. Ammonia compressed by either reciprocating or screw compressors can directly replace typical centrifugal chillers with CFC R-11, as long as materials such as aluminum and steel are used for transport, as opposed to copper and copper-bearing alloys. The Chicago City Code further provides that a separate room with a one hour fire wall be employed to house ammonia chillers, for safety reasons. The proposed design by Trigen of a centralized cooling plant does separate the chillers from public areas and therefore minimizes exposure to the refrigerant in the unlikely event of a leak.

ECONOMIC ANALYSIS

A decision to develop a capital-intensive energy system such as proposed for the Central Station site is largely an economic determination. Hence, the core of the engineer's study of the proposed district heating and cooling energy system was an economic analysis, based on a build-out schedule for 20 years of the Central Station site only. To establish economic viability, the revenue from heating and cooling was calculated; based on a rate (for heating and cooling) developed specifically for the project.

Heating and Cooling Revenue

The following criteria formed the basis for development of the heating and cooling rates:

- rates should be cost competitive;
- rates should consist of a capacity charge and an energy charge that adequately reflect the suppliers' costs for the same components;
- rates should be administered to all customers fairly; and
- rates should cover the project's costs.

Rate for Heating Energy

Capacity Charge: An annual charge of \$800/MMBtu/hr. of peak heating demand. The charge reflects the capital cost of the system, in addition to other fixed costs such as labor and maintenance. Fifty percent of the capacity charge will be at a fixed amount during the contract term and the other fifty percent will be escalated with the Consumer Price Index.

Energy Charge: \$5.50/MMBtu. This charge reflects the variable costs of supplying the energy. The energy charge will be escalated in parallel with the fuel escalator to reflect competitive pricing.

Rate for Cooling Energy

Capacity Charge: \$150/ton of peak cooling demand, annually. This charge reflects the capital cost of the system in addition to other non-capital fixed costs.

Energy Charge: \$0.14/tonhr. This charge will be escalated with the electricity cost escalator to reflect the competitive pricing.

The central energy system will use natural gas for chilled water, hot water, steam and in-plant electricity. The estimated average performance of the plant, the fully developed system for Central Station and the McCormick Place expansion, will demand an estimated 1,450,000 thousand cubic feet (mcf) of natural gas on an annual basis.

The estimates for the district heating and cooling system were based on suppliers' quotations, when available. All capital cost estimates include applicable taxes, freight and installation costs. The total system capital cost was estimated at \$76,000,000 in 1990 dollars. A breakdown of the capital cost is shown in Table 4.1.

TABLE 4.1 Central Station District Energy System Capital Cost

Cooling	(\$000)
Chillers	12,000
Gas Turbine Drives	7,200
Electric Drives	1,200
Evaporative Condensers	2,400
Chilled Water Piping, Pumps	1,100
Gas Compr, Tanks, Misc. Piping	1,000
Electrical	750
Controls, Metering	500
Subtotal	26,150
Chilled Water Storage	
Tank	6,000
Pumps, Piping	1,500
Electrical	500
Land	1,500
Controls, Metering	100
Subtotal	9,600
Heat Recovery - Cogeneration	
Heat Recovery Boiler	600
Hot Water Economizer	200
Piping	100
Electrical	30
Controls, Metering	50
Subtotal	980
Heating	
5 boilers	3000
Hot Water Economizer	600
Feed Water, Tank, Pump	800
Steam Piping	1000
Steam/Hot Water Heat Exchangers	500
Hot Water Piping Connections	500
Water Treatment	400
Electrical	200
Controls/Metering	200
Subtotal	7,200

TABLE 4.1 Central Station District Energy System Capital Cost Cont'd

Power Generation	
2 Steam Turbines & Generators	4,000
Condenser, Pumps	700
Cooling Tower	1,500
Condenser Piping, Pumps, etc.	500
Steam Piping	500
Electrical	500
Controls, Metering	200
Subtotal	7,900
Buildings	
Boiler Building	1,000
Chiller Building	2,000
Stack	500
Landscaping, etc.	200
Land	1,000
Subtotal	4,700
Chilled Water Distribution System	4,000
Hot Water Distribution	3,300
Miscellaneous	
10% Engineering, Project Management	6,423
8% Interest During Construction	5,138
Subtotal	11,561
Total Cost	75,791

Operating and Maintenance Cost

The plant as designed, will be staffed by twelve operators, or two operators per shift. The engineers estimated maintenance costs at \$.02/tonhr/MMBTu produced. Water and chemicals were estimated at 5% of the cost of fuel.

Financial Analysis

For illustrative purposes, the engineers conducted a financial analysis as if they were the third party project sponsors. Thus, they provided financial projections based on the following assumptions:

- All initial values represent real 1990 dollars;
- Interest on 100% bank loans was calculated based on a nominal interest rate of 12%, with debt being amortized over a 20 year period;
- Unit prices for heating and cooling energy were indexed such that: 50% of the capacity charges were escalated with the Consumer Price Index, the energy charge for heating was escalated with the forecast fuel price indexed at 6% annually, the energy charge for cooling was escalated with the forecast electricity price indexed at 8%, annually;
- The price of natural gas is expected to start at an average level of \$3.20/MMBtu in 1990, and to remain steady over the period in real terms (that is, to increase at the rate of inflation);
- Operating costs are expected to remain constant in real terms;
- A 20 year economic life was assumed for the equipment. The actual life of the installation could be significantly longer, however. Therefore equipment was not assumed to be replaced when fully depreciated after twenty years;
- The price of gas was escalated at an annual rate of 6% and the price of electricity was escalated 8% annually. All other costs were indexed to the Consumer Price Index, escalating 5% on an annual basis;
- Financing of working capital and start-up losses was treated as a line of credit, not as a capital item.

Economic Attractiveness

The engineers utilized two commonly accepted measures in the engineering design and system development spheres to evaluate the economic attractiveness, i.e., the time value of money, of the project.

- Return on Assets (ROA): is the rate of return provided by the operating income less the investment cost of the 40 year economic life of the project.
- Net Present Value (NPV): is the present value of the cash flows (before financing costs), assuming a discount rate equal to the investors' minimal acceptable rate of return, for the 40 year economic life of the project. Present value analysis collapses a time stream of cash flows into one value at some particular point. Thus, the project's NPV is the difference between the initial investment and the present value of net income for all 40 years in the study period. In this instance, a discount rate of 12% was assumed. If the NPV is greater than 0 then the project is economically attractive.

The project's ROA was determined to be 26%, before taxes. The NPV was calculated to be \$145,000,000, excluding taxes. Appendix 6 presents an economic forecast for the base case (Central Station and McCormick Place) project. As can be seen, the project will be economically attractive despite the 20 year build-out schedule. Due to unproportionally high initial investment costs, net income was forecast to be negative the initial four years but significantly increasing after year seven. net cash flow was forecast negative the first year.

Sensitivity Analysis

To the extent practicable, it is necessary to understand the investment risks of a proposed project. Certain project variables, such as the staging of system construction or establishing a minimum acceptable rate of return are matters of choice. Others, such as cost and revenue estimates, are open to considerable uncertainty. The engineers acknowledged that construction of a district energy system for the full Central Station development would, to some extent, result

in an oversized plant and appurtenances during the initial years. Consequently, they elected to quantify the impact a delay in the demand growth would have on system economics.

Appendix 6 shows that the capital cost of the full system, in that scenario, was expected to be limited to \$35,000,000 in 1990 dollars. The financial analysis indicated a ROA of 20% and NPV of \$31,000,000. Net Income After Tax was determined to be negative for the initial 6 years while net cash flow would be negative for the first year only.

Because fuel and electricity costs are practically impossible to forecast for 40 years, the impact that "stable" fuel and electricity prices would have on system economics was evaluated. Both fuel and electricity were escalated with the Consumer Price Index, reducing the ROA to 23% and the NPV to \$81,000,000.

A third sensitivity analysis evaluated the impact a 20% increase in capital costs would have on project economics. Appendix 6 also shows that the ROA and NPV would be reduced to 23% and \$133,000,000, respectively.

Chapter 5 summarizes the findings of the technical feasibility analysis for DHC at Central station and suggest issues that need to be further investigated. It outlines the current opportunities and obstacles to project implementation. It also discusses the economic development potential of DHC on the South Loop area.

ENDNOTES - CHAPTER FOUR

1. Chicago's Municipal Code requires City permits and/or authorizing ordinances for the following activities:

- a) opening public ways such as streets, sidewalks, etc., (see Chapter 33 - 1 of the Chicago Municipal Code, 1990);
- b) placing pipes or other conducting devices under public ways by driving, boring or tunneling (Chapter 33 - 6);
- c) the exercise of eminent domain by the supplier;
- d) a franchise or similar right, especially if it includes a requirement to serve all who apply; and
- e) a service which "concerns" the general public, distinct from individuals.

2. Chicago Municipal Code, Section 13-192-560 states "Pressure relief devices protecting a compressor output pressure vessel, in a refrigeration system employing ammonia refrigerant, for over pressure relief purposes, shall have a relieving discharge capacity equivalent to one-third pound of air per minute per ton of refrigeration".

CHAPTER 5 - SUMMARY AND CONCLUSIONS

PROSPECTS FOR IMPLEMENTATION

The purpose of this project was to assess the potential for developing a district heating and cooling system at the Central Station site. By implication, it was necessary to evaluate conditions contributing to or discouraging system development. These conditions were generally categorized as technical, economic, legal/regulatory and environmental.

These conditions could not be considered independent of one another. For example, air quality issues strongly affected system design. Similarly, high local electricity costs provided the opportunity to design a system which takes advantage of cogenerated electricity for in-plant use. The use of water-injected turbines (to reduce NOx emissions) is another example of the interconnectedness of environmental concerns and technical feasibility. This report concludes that such a system is technically and economically feasible with certain caveats.

Establishing a major anchor load is a critical variable in developing a central district heating and cooling cogeneration system at Central Station, due to the slowly growing demand from the projected build-out at the site. This projected slow development is exacerbated by a recent bottoming-out of the local commercial real estate market due to the recent recession. The Commercial real estate market was one of the hardest hit industries in Chicago, as in other parts of the country, resulting in high downtown vacancy rates.

Even with the connection of an "anchor load", the system would be "staged", modularly developed to match production capacity with actual load growth. The proposed Exhibition Hall expansion was identified by the engineers as a potential anchor load that could catalyze system development. Originally, the expansion proposal was coupled with the proposal for a new domed

stadium, which engendered much resistance in the Illinois General Assembly. As a result, the domed stadium proposal was separated from the McCormick Place expansion consideration.

Gaining access to the Chicago Freight Tunnel System is another important element of successful development of this proposed private energy system. There is no legal or regulatory prohibition against a private entity using the freight tunnel system so long as they follow City of Chicago procedures as provided in Chapter 33 of the Municipal Code¹. The tunnel system is part of the public way. Discussions with City personnel in the Departments of buildings and, Public Works convinced energy staff that it will be necessary for the system developers to provide some physical indication (sketch of the proposed distribution system showing linear footage, affected area and pipe size) in order to gain access to the tunnels. A more fully articulated distribution system design of this nature would obviously entail further work in identification and marketing of potential customers.

Technical Considerations

The technical assessment for the district energy system identified specific state-of-the-art technologies that could achieve maximum operating efficiencies in consideration of environmental, fuel cost and regulatory factors. Although the technical assessment focused on a base case assumption (no cooling and heating external customers) the system was conceptually designed to accommodate future connection with exogenous energy users.

The proposed design, utilizing "environmentally benign" refrigerants such as ammonia which manifest reasonably good thermodynamic properties, was of particular interest. The use of ammonia in district cooling applications is not without precedent. Trigen Engineers recently installed ammonia screw compressors in their Tulsa, Oklahoma system. Ammonia is also still widely used in industrial applications throughout the city of Chicago. Discussion with personnel in the Department of Buildings' Mechanical Equipment Division revealed that a plan including the necessary fire wall between the chiller room (where the ammonia compressors would be located) and other operations would be favorably received.

In essence, no technical consideration addressed in the feasibility analysis would appear to hinder development of a central district energy system at Central Station.

Economic Conditions

The melding of economic/financial issues with other factors is a constant theme in this analysis. The decision to go forward with any privately-sponsored project is governed by principles of sound business judgements. Since the early 1970's, energy management government officials in the U.S. have touted the virtues of district heating and cooling systems as a means to ameliorate the increasing costs of heating and cooling buildings. Their message has not gone unheeded, as new district energy systems have begun to emerge in many downtown areas of cities around the country. Yet the movement towards centralized energy systems has been slower than might have been expected, given the benefits of district energy when sufficient density, high load factor and diversified loads are present.

In a purely market driven environment, new product development results from entrepreneurs who identify market opportunities. This project attempted to identify economic opportunities both for the private and public sectors. The economic factors identified on the private side were straightforward: with a given minimum acceptable rate of return if the ROA and the NPV are more than marginal (provided the cost assumptions are correct), then the project is economically desirable.

The economic benefits accruing to the City were suggested rather than quantified. Since it is necessary to gain access to the freight tunnels to minimize distribution system costs, which can be as much as 30% of total system costs, there has to be some economic trade-off. Compensation for use of the public way is the principal direct financial benefit attainable by the City. Current City policy suggests that a district energy provider will have to remit approximately 8% of gross revenue in some combination of utility taxes and franchise fees, which are allowable under the City's Home Rule Authority, for the privilege of using the public right-of-way.

Precedent for this policy is clear. Commonwealth Edison Company compensates the City with a 4 % of gross revenue Municipalities Utilities Tax and approximately 4 % of gross revenues for a franchise fee for the right to use the public rights-of-way including the freight tunnel system. Fiber optics is a growing industry that now utilizes some of the freight tunnel system for conduit distribution. Although there is no city legislation governing the handling of fiber optics companies, and although they are a competitive industry rather than regulated utilities, they are required to compensate the City at the rate of 8 % of their revenues, in a similar fashion to Commonwealth Edison. Other users of the freight tunnel system, such as cable companies and telecommunication companies, are subject to the same compensation policy.

In short, additional research and analysis is necessary to determine the potential financial benefits accruable to the City. Moreover, the City needs to determine if there is potentially a space conflict between the DHC operator and other future users of the freight tunnel system.

Other benefits will have to be economically quantified in order to fully assess the merits of a privatized district energy system. For example, the incremental reduction in Edison's peak demand due to connection to a district cooling system might be quantified to illustrate savings to all Edison customers. Alternatively, the benefit of replacing individual chiller plants using CFCs with an environmentally benign district cooling system should be quantified, considering the costs (to end-users) of the retrofitting or replacement of existing chillers which will be required by the Montreal Protocol and associated environmental regulations.

Legal/Regulatory Conditions

Gaining access to the freight tunnel system was discussed from an economic advantage point of view to both the DHC operator and the City under "Economic Conditions" above. For the reasons discussed earlier, a DHC operator may not want to be regulated by the Illinois Commerce Commission. In fact, Trigen Energy Corporation, assuming they are the developers/operators of the district energy system, has indicated a preference for not being regulated. As a result, staff reviewed legislation in other states where DHC systems are not

regulated or are partially regulated (e.g., Washington). We subsequently requested John Nimmons & Associates to draft amendatory legislation applicable to the Illinois Public utilities Act (see Appendix 5).

The intent of the draft legislation is to provide the proper context for allowing DHC operators to be exempt from the more onerous burdensome requirements of PUC regulation designed for comprehensive control of monopoly utilities rather than for competitive service providers. It allows existing regulated public utilities to be eligible for exemption as owners or operators of DHC systems. The principal regulatory exemption provided in this draft legislation is that it does not allow the Illinois Commerce Commission to set rates for DHC operations. The underlying premises for such regulation are to acknowledge that rates which a DHC operator will charge will already be constrained by existing regulated and unregulated suppliers, and to alleviate the costly and cumbersome burden of regulatory rate-setting procedures in a fledgling industry which is both economically and environmentally beneficial to the host city. It does, however, provide some critical protection to consumers by granting authority to the ICC to issue operating permits (non-exclusive) which shall determine that the applicant is financially capable of providing the services indicated.

This proposed legislation defines the conditions under which the ICC would approve a permit to operate and gives the Commission continuing jurisdiction to oversee the qualifications of the "thermal suppliers". In short, this proposed legislation essentially provides a quasi-exemption from PUC regulation in that the Commission may not set rates, but does have authority to oversee the fiscal and operational soundness of the business.

The potential for this legislation being introduced is currently unknown. Because the Illinois General Assembly is faced with compelling issues, the potential for this legislation is currently unknown. The Assembly will be negotiating the reapportionment of congressional districts and will also be faced with reordering budget priorities, as the state is in dire financial straits. The possibility that the draft DHC exemption legislation will not be considered in the next session does not, however, prohibit further development of a central energy system.

DHC As a Catalyst For Regional Development

Viewed in a regional context, the Central Station site lies on Chicago's south lakefront, immediately south of the Loop business district and Grant Park. It is just west of the major cultural center complex of the Field Museum, Shedd Aquarium and Adler Planetarium. It is immediately north of the McCormick Place exposition halls. The needs of this region are many and interrelated, but can be classified into the areas of: transportation/access, economic development, housing, and imagery.

Street and highway access must be improved in order for successful redevelopment. Direct access and improved signage from the museum campus onto Lake Shore Drive is needed. Lake Shore Drive at present does not provide adequate access from the near south side to the Lakefront, which further impedes much needed revitalization. Improved street access to the central business district is also needed. In short, the region is characterized by poor transportation linkages, both east-west and north-south, due to the past dominance of railroad facilities.

The area's economic development needs are enormous. Commercial support facilities such as community level shopping are needed; since many existing sites are in poor condition. Housing, improved educational facilities; and improved transportational facilities are other parallel needs. Currently, there is some new residential development occurring contiguous to the site, (the Dearborn Park multifamily residential complex). Yet the area is characterized by numerous blocks of commercial and residential blight.

The proposed McCormick Place expansion may be the most significant project to stimulate economic development improvement in the area. A DHC system can improve the economics of the new development by reducing its capital costs through elimination of on-site heating and cooling plants. The construction of this 1,000,000 square foot complex is projected to create 6,000 temporary jobs and 14,000 permanent ones. Other economic benefits to result from the

McCormick Place expansion include increased consumer spending -- well into the hundreds of millions of dollars --- and increased tax revenues of about \$20,000,000 per year.

The Central Station DHC system would support this development by simplifying the design of the new exhibition hall. Preliminary indications are that the McCormick Place in-building heating and cooling plant (48,000 square feet) will be located over the Metra tracks and is projected to cost \$20,000,000. The DHC system would eliminate the need for that space, in addition to shaving off the \$20,000,000 from total capital costs of \$675,000,000. The engineers have indicated that a new DHC system can provide for all of the McCormick Place space heating and cooling needs at lower cost than would otherwise be required, since operating and maintenance costs would be subsumed in an economic large, central plant.

The Department of Planning is considering in aggregate the Central Station development, the McCormick Place expansion, the proposed Lake Shore Drive realignment, and other proposals due to the symbiotic relationship of the infrastructure requirements for huge projects. These developments taken together require and will result in tremendous improvement of the regional transportation network. From a capital-requirement perspective, the proposed Central Station district energy system is a small but significant component of the redevelopment of Chicago's near South Side.

Lessons Learned

Deciding how to approach the Central Station DHC assessment was an exercise in partitioned matrix management. At the very least, there were four agendas that needed to converge.

- 1) The real estate developer (Fogelson Properties, Inc.), was interested in the economic value (savings/square foot) a central energy system would bring to his development, either through marketing value or as a revenue source assuming he took an equity position.

- 2) Peoples Gas' involvement in the project was spurred by a desire to develop new markets for gas-fired cooling and cogeneration.
- 3) The engineers (Trigen/Midwesco) agreed to conduct the technical analysis because they recognized a potential for constructing a modern district system near downtown Chicago.
- 4) The City's interest revolved around supporting the introduction of environmentally conscious and lower - cost competition into the local energy market.

Staff successfully coordinated this public/private enterprise by following a sound conceptual workplan. This was accomplished by persuading each interest to consider the issues from an wholistic perspective. That is, the real estate developer was persuaded of the attractiveness of supporting sound environmental policy and introduction of competition into the energy marketplace. The engineers were apprised of the need to consider the City's positions on use of the public way and environmental issues. The gas company was persuaded that the study would seriously analyze the feasibility of cogeneration. Staff and the gas company also agreed that pursuit of a large central district energy system was an effective technique for competing in the new cooling market.

Although staff had begun assisting Fogelson Properties, Inc. with assessing energy efficiency opportunities before the start of the UCETF Year 11 program, many resources were required to complete the significant amount of unfinished work. These resources included financial support as provided by the UCETF grant, significant funding provided by People's Gas, Light and Coke Company and professional staff time as provided by Fogelson Properties, Inc., Peoples Gas, Trigen/Midwesco and the Department of Planning.

As expressed in the introductory section of this report, Fogelson Properties Inc., initiated the deliberation for DHC feasibility at Central Station. There were, nonetheless, more immediate critical issues for the developer to pursue. Several members of the H.U.D. Technical Assistance Team had forewarned energy staff that there would be lulls in the DHC study process as the

developer dealt with these immediate issues. It was therefore a critically important step in the study process to implement the collaborative arrangement among Trigen, Peoples Gas, Midwesco, and the City to complete the feasibility study. The real estate developer's decision to move forward with the analysis was prompted by a letter from the Commissioner of Planning outlining the specific roles each party could play in the analysis.

The nature of the Central Station PD process affected the approach of the energy study. As a matter of policy, the City will finance street improvements and other infrastructural projects, without which the Central Station development wouldn't occur. The City has created a Tax Increment Financing District (TIF), a method of funding infrastructural projects in a given area by recapturing, for a specific period of time, all or a portion of the increased tax revenues that will result if the redevelopment stimulates private investment. Thus, the Central Station development can be considered a joint venture between the public and private sectors. The City's "investments" are based on sound policy grounds. These provisions, the extension of certain roadways and other infrastructural improvements, will benefit the public even if Central Station is not developed.

As further incentive for the public infrastructure investments in Central Station, and to buttress ongoing City support, energy staff has articulated and emphasized the benefits to be derived from a Central Station DHC system. Early on, staff identified the proposition of an "environmentally benign" system being a community benefit that could convince decisionmakers, on all sides, of the merits of district energy. The engineers also envisioned district energy, employing modern technology, as a hedge against the further pollution of Chicago's air, proactively addressing the ozone depletion problem. The incremental reduction of Edison's peak demand resulting from full development of a district energy (cooling) system is another community benefit that has been cursorily discussed and conveyed to decisionmakers.

The fact that energy staff succeeded in defining the scope of the technical study through cooperative planning with private sector consultants who were not principally compensated by the City, partly illustrated the success of this public and private venture. By design, the City was

the coordinating vehicle for this venture, since it was conducted within the confines of the Planned Development process.

Based on the results of this project, it is likely that energy efficiency will be integrated into the planning process of future major developments where the Department of Planning has a role. Legislation that can facilitate the development of non-regulated privatized district energy was drafted. The City was also successful in forging the argument that energy efficiency - both demand-side and supply-side -- needs to be contemplated simultaneously.

Future Steps

At present, it appears that the decision to go forward with development of a system hinges on whether the district system will be selected as the source of supply for the McCormick Place expansion. The engineers also feel that guaranteed use of the freight tunnel system is essential for economically developing the DHC system. It is apparent that the gas company (which is considering a joint venture as developer of the system) and the engineers should devise a strategy that:

- 1) Identifies a site for the generation plant as soon as possible;
- 2) Re-Approaches the McCormick Place Exhibition Hall Authority's design team again with a sound proposal that guarantees lower bills and reliability for heating and cooling services;
- 3) Identifies other customers (through intense marketing efforts) to be connected via the freight tunnel system and develop a plan for presentation to the City for gaining permission to use the tunnels and other rights-of-way;
- 4) Involves the gas company as a lead party in the venture, and takes advantage of their existing franchise rights and business relationships; and

- 5) Enlists the support of the Energy Management staff to identify other resources that could support the above activities while satisfying the City's goals.

Energy staff will continue to monitor the progress of the draft legislation for exempting DHC from state regulation. Staff will also work with the Departments of Buildings, General Services and Public Works to determine if there are any municipal buildings that are eligible candidates by virtue of location, energy profile and load factor for connecting to a DHC system.

ENDNOTES - CHAPTER FIVE

1. The standard procedure requires an entity to make application for permission to use a public way from the City by providing:

- signature of the alderman in the affected ward(s);
- sketch of the proposed project;
- worksheet (applicant name, address, type of use and amount of public way anticipated to be used;
- an Economic Disclosure Statement and
- an Interdepartmental Authorization form.

APPENDICES

APPENDIX 1

Central Station - Forecast Construction Starts

Year	Rental units	Condo units *	Condo units **	Townhouse units	Office sq.ft.	Retail sq.ft	Motel units
1991	250	0	100	50	0	0	0
1992	250	150	100	40	500,000	0	300
1993	0	0	100	0	0	100,000	200
1994	350	150	100	0	700,000	100,000	300
1995	0	200	150	0	600,000	200,000	200
1996	350	0	175	0	500,000	100,000	400
1997	0	200	0	0	700,00	100,000	0
1998	350	0	0	0	0	0	200
1999	0	175	0	0	600,000	100,000	200
2000	200	0	0	0	0	0	0
<hr/>							
TOTAL	1,750	875	675	90	3,600,000	700,000	1,800

* Midrise

**Lowrise

APPENDIX 2
ANNUAL HEATING AND COOLING COST COMPARISON

	\$/Year/Suite					
	On-Site Electric/Chillers		On-Site Boilers/Chillers		District Energy	
	Condo	Office	Condo	Office	Condo	Office
Capital Cost in Building	6,000	6,700	6,500	7,200	4,000	4,000
Less Saving from Low Temp Water	-	-	-	-	(800)	(800)
Cost of Capital, 13%	780	871	845	936	416	416
DHC Capacity Charge						
Heating - \$8000/MMBtu/hr					172	120
Cooling - \$150/ton					360	600
Maintenance, Service	150	150	200	200	50	50
Labor	100	100	150	150	-	-
Subtotal - "Fixed Costs"	1,030	1,121	1,195	1,286	998	1,186
Heating Energy						
4.4 e/kWh x 36,000/3,413 x 1,200	557					
4.4 e/kWh x 20,000/3,413 x 1,200		309				
\$4.0/mcf/70% x 36 x 1.2			247			
\$4.0/mcf/70% x 20 x 1.2				137		
\$5.50/MMBtu x 36 x 1.2					238	
\$5.50/MMBtu x 20 x 1.2						132
Cooling Energy						
12e/kWh x 1.2 kW/ton x 3,120 ton/hr	449		449			
12e/kWh x 1.2 kW/ton x 3,960 ton/hr		570		570		
\$0.14/ton/hr x 3,120 ton/hr					436	
\$0.14/ton/hr x 3,960 ton/hr						554
Subtotal - Energy Costs	1,006	879	696	707	674	686
TOTAL	2,036	2,000	1,891	1,993	1,672	1,872

APPENDIX 3
CENTRAL STATION LOAD PROJECTIONS

YEAR	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001
HEATING										
Peak Demand,	0	15	20	25	30	45	60	75	90	105
Peak Demand, McCormick	0	60	80	80	80	80	80	80	80	80
Consumption	0	98180	128240	140300	152360	1888540	224720	260800	297080	333260
COOLING										
Peak Demand,	0	3000	4000	5000	6000	9000	12000	14000	17000	2000
Peak Demand, McCormick	0	8000	12000	12000	12000	12000	12000	12000	12000	12000
Consumption	0	8057500	1141000	12762500	14115000	18172500	22230000	24935000	28992500	33050000

Source: Central Station District Energy Assessment, 1990

CENTRAL STATION LOAD PROJECTIONS

YEAR	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012
HEATING											
Peak Demand, CS	120	135	150	165	180	195	210	225	250	250	250
Peak Demand, McC	80	80	80	80	80	80	80	80	80	80	80
Consumption	369440	405920	441800	477980	514180	550340	586520	622700	663000	663000	663000
Cooling											
Peak Demand, CS	22000	25000	27000	30000	32000	35000	38000	40000	42000	44000	44000
Peak Demand, McC	12000	12000	12000	12000	12000	12000	12000	12000	12000	12000	12000
Consumption,	35755000	39812500	42517500	46575000	49290000	53337500	57395000	60100000	62805000	65510000	65510000

Source: Central Station District Energy Assessment, 1990

APPENDIX 4 **CHILLER OPTIONS**

	ABSORPTION Single Stage	ABSORPTION Two Stage	CENTRIFUGAL HCFC	AMMONIA Screw Comp
Supply Temp, °F	44	44	36-46	34-46
Refrigerant	Water	Water	CFC/HCFC	Ammonia
Drive	Steam	Steam	Mechanical	Mechanical
Typical Efficiency Btu/tonhr	18,000	10,000	2,600	2,000
Installed Cost*, \$/ton	700	1,000	700	700
Typical Condenser	Tower	Tower	Tower	Evap Tower
Aux. Power Req.	High	High	Medium	Low
Part Load Perf.	Good	Good	Medium	Good
Space Requirement	High	High	Low	Medium

*including towers, auxiliaries, and complete installation for a 1,500 - 2,500 ton unit.

APPENDIX 5

FIRST DRAFT -

ILLINOIS DHC REGULATORY EXEMPTION

Prepared by John Nimmons, March 4, 1991

NEW SECTION. Sec. __. Legislative Findings & Intent. As established by Section 8-402 of this [the Illinois Public Utilities] Act, it is the policy of the State of Illinois to ensure the provision of adequate, efficient, reliable and environmentally safe energy services at the lowest possible cost to Illinois energy consumers and users, utilizing to the fullest extent practicable all economical conservation, renewable resource technologies, cogeneration, and energy efficiency improvements as the initial sources of new supply. District heating and cooling systems can improve the efficiency of thermal services provided to Illinois consumers and users, provide attractive opportunities for cogeneration and renewable resource development, and minimize the environmental impacts of new energy supplies, at prices competitive with conventional heating and cooling options. Although some regulation of such systems is necessary to protect the public interest in securing and maintaining adequate heating services, the legislature finds that traditional public utility regulation presents unnecessary barriers to the development of district systems, without corresponding benefits to the public. Therefore, it is the intent of the legislature and the purpose of this article to eliminate such regulatory barriers and to establish a streamlined permitting system which will encourage district heating and cooling development while continuing to provide reasonable protections to system customers.

NEW SECTION. Sec. __. Definitions. Unless the context clearly requires otherwise, the definitions in this section apply throughout this article:

__. "Cooling" means chilled water, ice slurry, or other medium supplied to buildings or structures to reduce air or water temperatures for space or water conditioning or process applications.

__. "Commission" means the Illinois Commerce Commission.

__. "District heating and cooling system" means one or more central plants for the production of steam, hot water and/or chilled water, together with associated transmission and distribution pipelines, controls and customer connections, designed to supply heating or cooling services to customers in at least two buildings or structures other than those in which the central plant is located.

__. "Heat" or "heating" means steam, hot water or other medium supplied to buildings or structures to increase air or water temperatures for space or water conditioning or process applications.

__. "Thermal services" means heating or cooling services.

__. "Thermal supplier" means any private person, firm, partnership, association, or corporation which furnishes or proposes to furnish district heating or cooling services to customers for compensation.

NEW SECTION. Sec. __. Thermal Suppliers Subject to Limited ICC Jurisdiction. Notwithstanding any other provision of law, thermal suppliers are not subject to the general jurisdiction of the Commission as to their district heating and cooling activities, but only to the limited jurisdiction conferred by this article .

NEW SECTION. Sec. __. Public Utilities Eligible Under This Article. Nothing in this article prohibits public utilities, as defined in Section 3-105 of this Act, from developing, owning and/or operating district heating and cooling systems or providing thermal services to customers under the operating permit system established herein. As to such activities, public utilities shall be deemed thermal suppliers subject only to the limited Commission jurisdiction conferred by this article.

NEW SECTION. Sec. __. Operating Permit; Issuance. Upon written application by a thermal supplier, the Commission shall issue a nonexclusive operating permit to supply thermal services within a geographic service territory proposed by the applicant if the Commission reasonably determines that:

1. The applicant is qualified and financially responsible to provide the services for which the permit is sought;
2. The applicant's proposed system design and business plan are adequate to provide the services for which the permit is sought; and
3. The contractual arrangements which the applicant proposes to offer its customers for the services for which the permit is sought substantially comply with the requirements set forth in section ____ of this article.

NEW SECTION. Sec. __. Customer Contract Terms; ICC Approval (1) Each thermal supplier shall enter into a written contract with each customer proposed to be served pursuant to any operating permit issued under this article.

(2) Each contract to be offered to each customer or class of customers, and any renewal or modification thereof, shall include but need not be limited to terms specifying:

- a) The type and quantity of thermal services to be provided, including any minimum or maximum delivery or purchase obligation of the supplier and the customer;
- b) The period of time during which thermal services will be provided;
- c) The rates or formula for determining rates to be charged during the contract term;
- d) The allocation of responsibility for installation and retrofit costs and equipment maintenance on customer premises;
- e) Any provision to be made by the supplier or the customer for backup thermal service in case of scheduled or unscheduled shutdowns of the district system;
- f) The method for resolving any disputes under the contract; and
- g) The conditions under which service may be terminated by each party and the notice required for any such termination.

(3) All terms included in contracts between thermal suppliers and their customers shall be fair and reasonable to the customer.

NEW SECTION. Sec. __. Basis for ICC Rate Approval. In accordance with the intent of this article to eliminate regulatory barriers and encourage district heating and cooling development, Commission approval of the rates or rate formula specified in the thermal supplier's customer contract shall not be based on the supplier's cost of providing service or its rate of return on investment. Commission rate approval shall be based solely on the reasonableness of the proposed rates relative to the current and projected rates and prices charged for other heating and cooling alternatives generally available in the proposed service territory.

NEW SECTION. Sec. __. Continuing ICC Jurisdiction. The Commission shall have continuing jurisdiction to oversee the qualifications of thermal suppliers, the adequacy of their systems, and the terms of their customer contracts as provided in this article to ensure compliance with the terms of any operating permit issued pursuant to it.

NEW SECTION. Sec. __. Liberal Construction. The provisions of this article shall be liberally construed to effect the legislative intent set forth in section __.

NEW SECTION. Sec. __. Severability. If any provision of this article or its application to any person or circumstance is held invalid, the remainder of the chapter or the application of the provision to other persons or circumstances shall not be affected.

ECONOMIC FORECAST

	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006
Cooling Demand Annual Consumption	11,000	16,000	17,000	18,000	21,000	24,000	26,000	28,000	32,000	34,000	37,000	38,000	42,000	44,000
Heating Demand Annual Consumption	8,058	11,410	12,763	14,116	16,173	22,220	24,825	26,963	33,050	35,765	39,813	42,518	46,575	49,280
Water Demand Annual Consumption	75	100	105	110	126	140	165	172	186	200	216	220	248	280
Revenue	3,410	5,128	5,959	6,803	8,678	10,999	12,728	15,408	18,363	20,944	24,552	27,718	32,003	35,988
Chilled Water Sales	1,358	1,866	2,115	2,363	2,961	3,611	4,318	5,087	6,022	6,830	7,816	8,884	10,044	11,303
Hot Water Sales														
Operating Expenses	674	975	1,140	1,322	1,781	2,248	2,729	3,322	3,978	4,628	5,415	6,202	7,148	8,098
Fuel	34	48	67	86	108	132	158	186	221	258	310	357	406	456
Water & Chemicals	800	725	761	799	836	1,221	1,367	1,468	1,629	1,808	1,988	2,170	2,352	2,530
Operating Personnel	207	307	359	416	561	719	846	1,004	1,208	1,408	1,644	1,948	2,212	2,500
Maintenance														
Operating Income	3,163	4,959	5,667	6,444	8,390	10,100	11,943	14,517	17,365	19,303	23,352	26,474	30,653	34,488
Interest	3,871	4,170	4,483	4,861	5,530	6,087	6,811	7,086	7,823	8,571	9,885	9,212	8,910	8,794
Book Depreciation	1,530	1,758	1,903	2,108	2,425	2,703	2,838	3,245	3,632	4,038	4,324	4,548	4,862	5,108
Net Income before Tax	-2,037	-970	-689	-523	433	1,310	2,405	4,186	5,909	7,293	10,042	12,713	16,180	19,584
Taxes	1,538	1,758	1,903	2,108	2,425	2,703	2,838	3,245	3,632	4,038	4,324	4,548	4,862	5,108
• Bonds	1,538	1,758	1,903	2,108	2,425	2,703	2,838	3,245	3,632	4,038	4,324	4,548	4,862	5,108
• Tax Depreciation	-2,037	-970	-689	-523	433	1,310	2,405	4,186	5,909	7,293	10,042	12,713	16,180	19,584
Yardage Income	-2,037	-970	-689	-523	433	1,310	2,405	4,186	5,909	7,293	10,042	12,713	16,180	19,584
Loss Carry Forward	-2,037	-970	-689	-523	433	1,310	2,405	4,186	5,909	7,293	10,042	12,713	16,180	19,584
Yardage Income	-2,037	-970	-689	-523	433	1,310	2,405	4,186	5,909	7,293	10,042	12,713	16,180	19,584
Taxable Income	-2,037	-970	-689	-523	433	1,310	2,405	4,186	5,909	7,293	10,042	12,713	16,180	19,584
Tax	-2,037	-970	-689	-523	433	1,310	2,405	4,186	5,909	7,293	10,042	12,713	16,180	19,584
Net Income after Tax	-2,037	-970	-689	-523	433	1,310	2,405	4,186	5,909	7,293	10,042	12,713	16,180	19,584
• Book Depreciation	-2,037	-970	-689	-523	433	1,310	2,405	4,186	5,909	7,293	10,042	12,713	16,180	19,584
• Principal	-2,037	-970	-689	-523	433	1,310	2,405	4,186	5,909	7,293	10,042	12,713	16,180	19,584
Net Cash Flow	-2,037	-970	-689	-523	433	1,310	2,405	4,186	5,909	7,293	10,042	12,713	16,180	19,584
Debt	30,580	34,754	37,106	40,508	44,105	60,723	64,257	69,051	74,428	78,771	80,083	81,518	82,083	81,518
Chicago CFI Escalator	1,15	1,21	1,27	1,33	1,40	1,47	1,54	1,62	1,70	1,78	1,87	1,97	2,07	2,17
Fuel Cost Escalator	1,18	1,26	1,34	1,42	1,50	1,58	1,66	1,75	1,83	1,90	2,01	2,13	2,26	2,34
Electricity Escalator	1,26	1,36	1,47	1,56	1,66	1,76	1,86	1,96	2,06	2,16	2,26	2,36	2,46	2,54
NPV \$(000)	145,578	145,578	145,578	145,578	145,578	145,578	145,578	145,578	145,578	145,578	145,578	145,578	145,578	145,578
ROI	28.78%	28.78%	28.78%	28.78%	28.78%	28.78%	28.78%	28.78%	28.78%	28.78%	28.78%	28.78%	28.78%	28.78%
Principal & Interest	4,085	4,710	5,097	5,638	6,482	7,229	7,868	8,689	9,601	10,616	11,578	12,176	13,019	13,881
Total Plant Cost	87,400	91,770	96,359	101,178	106,235	111,547	117,124	122,961	129,061	135,538	142,385	149,484	156,958	164,808
% Completed	0.35	0.4	0.43	0.47	0.53	0.58	0.62	0.67	0.73	0.79	0.83	0.86	0.9	0.93
Operating Income & Investments	-27,427	370	2,776	2,397	2,018	4,823	7,259	9,368	11,768	14,617	17,857	21,088	24,374	28,544
Net Cash Flow, Incl. Investments	-31,822	-4,339	-2,320	-3,242	-4,478	-2,716	-615	-2,175	-2,727	-2,727	-2,727	-2,727	-2,727	-2,727

	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)
Cooling														
Demand	47,000	60,000	62,000	64,000	64,000	64,000	64,000	64,000	64,000	64,000	64,000	64,000	64,000	64,000
Annual Consumption	53,338	57,585	60,100	62,805	66,510	66,510	66,510	66,510	66,510	66,510	66,510	66,510	66,510	66,510
Heating														
Demand	276	280	305	330	330	330	330	330	330	330	330	330	330	330
Annual Consumption	550,340	598,620	622,700	663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000	663,000
Revenue														
Chilled Water Sales	41,303	47,176	52,534	58,428	64,913	68,288	73,854	78,992	84,412	90,243	96,515	103,284	110,527	118,342
Hot Water Sales	12,667	14,148	15,748	18,102	18,036	20,023	21,087	22,172	23,340	24,578	25,884	27,287	28,730	30,278
Operating Expenses														
Fuel	9,227	10,485	11,711	13,358	14,397	15,281	16,178	17,147	18,178	19,268	20,422	21,648	22,947	24,323
Water & Chemicals	481	523	568	618	720	763	808	857	908	963	1,021	1,082	1,147	1,216
Operating Personnel	2,048	2,182	2,258	2,372	2,491	2,616	2,748	2,883	3,026	3,178	3,338	3,505	3,680	3,864
Maintenance	2,680	3,028	3,330	3,671	4,004	4,204	4,415	4,635	4,867	5,110	5,368	5,634	5,918	6,212
Operating Income	39,553	45,157	50,398	56,463	62,337	68,449	70,875	75,641	80,773	86,300	92,252	98,662	105,567	113,005
Interest														
Book Depreciation	9,743	9,888	9,289	8,598	8,348	7,487	6,544	5,988	5,397	4,804	4,205	3,638	3,089	2,551
Net Income before Tax	24,527	29,733	35,572	42,312	48,224	53,186	58,568	63,907	69,611	75,730	82,281	89,261	96,713	104,688
Taxes														
+ Book Depreciation	6,282	6,555	6,555	6,553	6,785	6,785	6,785	6,785	6,785	6,785	6,785	6,785	6,785	6,785
- Tax Depreciation	6,282	6,555	6,555	6,555	6,785	6,785	6,785	6,785	6,785	6,785	6,785	6,785	6,785	6,785
Taxable Income	24,527	29,733	35,572	42,312	48,224	53,186	58,568	63,907	69,611	75,730	82,281	89,261	96,713	104,688
Less Carry Forward	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Taxable Income	24,527	29,733	35,572	42,312	48,224	53,186	58,568	63,907	69,611	75,730	82,281	89,261	96,713	104,688
Tax	10,885	13,172	15,758	18,744	21,363	23,582	25,945	28,311	30,837	33,548	36,451	39,542	42,844	46,377
Net Income after Tax	13,641	16,561	19,814	23,568	26,861	29,604	32,623	35,596	38,773	42,182	45,831	49,718	53,869	58,311
+ Book Depreciation														
- Principal	6,282	6,555	6,555	6,555	6,785	6,785	6,785	6,785	6,785	6,785	6,785	6,785	6,785	6,785
Net Cash Flow	14,543	17,112	19,764	22,845	25,537	27,450	33,599	36,603	38,598	42,953	48,856	50,921	55,152	59,880
Debt														
Chicago CPI Escalator	81,184	82,244	77,239	71,635	69,584	62,475	54,535	49,737	44,978	40,038	35,041	30,301	25,739	21,257
Fuel Cost Escalator	2,28	2,38	2,51	2,64	2,77	2,91	3,05	3,20	3,36	3,53	3,71	3,89	4,09	4,29
Electricity Escalator	2,88	2,86	3,02	3,20	3,40	3,60	3,82	4,05	4,29	4,55	4,82	5,11	5,41	5,74
NPV \$(000)	3,70	4,00	4,32	4,68	5,03	5,44	5,87	6,34	6,85	7,40	7,99	8,63	9,32	10,08
ROA														
Principal & Interest														
Total Plant Cost	14,144	14,874	14,874	14,874	15,437	15,437	11,342	10,727	10,340	9,798	8,945	8,198	7,571	6,748
% Completed	76,000	181,698	190,783	200,322	210,339	220,855	231,898	243,493	255,668	268,451	281,874	295,967	310,768	326,304
Operating Income + Investments														
Net Cash Flow, Inc Investments	36,082	39,708	50,398	56,463	62,337	68,449	70,875	75,641	80,773	86,300	92,252	98,662	105,567	113,005
	11,384	11,384	11,384	11,384	11,384	11,384	11,384	11,384	11,384	11,384	11,384	11,384	11,384	11,384

		1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006
		\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)
Coaling Demand	Tons	11,000	16,000	17,000	17,000	17,000	17,000	17,000	17,000	17,000	17,000	17,000	17,000	17,000	17,000
Annual Consumption	Tonnes (000)	8,058	11,410	12,763	12,763	12,763	12,763	12,763	12,763	12,763	12,763	12,763	12,763	12,763	12,763
Heating Demand	MMBtu/hr	76	100	105	105	105	105	105	105	105	105	105	105	105	105
Annual Consumption	MMBtu	98,180	128,240	140,300	140,300	140,300	140,300	140,300	140,300	140,300	140,300	140,300	140,300	140,300	140,300
Revenue	\$(000)	3,410	5,128	5,868	6,164	6,480	6,818	7,182	7,571	7,988	8,435	8,915	9,430	9,981	10,573
Chilled Water Sales	\$(000)	1,358	1,886	2,115	2,208	2,301	2,402	2,508	2,621	2,741	2,868	2,999	3,140	3,289	3,448
Hot Water Sales															
Operating Expenses	\$(000)	674	975	1,140	1,209	1,281	1,358	1,439	1,528	1,617	1,714	1,817	1,928	2,042	2,164
Fuel	\$(000)	34	49	67	80	94	108	122	138	151	168	181	198	212	228
Water & Chemicals	\$(000)	660	725	781	799	838	1,321	1,387	1,458	1,529	1,608	1,686	1,770	1,859	1,952
Operating Personnel	\$(000)	207	307	356	377	398	416	437	458	481	505	531	557	585	614
Maintenance	\$(000)														
Operating Income	\$(000)	3,163	4,859	5,667	5,925	6,201	6,058	6,356	6,678	7,020	7,381	7,790	8,220	8,683	9,181
Interest	\$(000)	3,871	4,170	4,453	4,618	4,828	4,928	5,064	5,188	5,305	5,417	5,529	5,642	5,755	5,868
Book Depreciation	\$(000)	1,830	1,759	1,803	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005
Net Income before Tax	\$(000)	-2,037	-970	-688	-688	-332	-374	36	482	968	1,488	2,074	2,703	3,388	4,136
Taxes	\$(000)	1,530	1,759	1,903	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005
+ Book Depreciation	\$(000)	1,530	1,759	1,903	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005
- Tax Depreciation	\$(000)														
Taxable Income	\$(000)	-2,037	-970	-688	-688	-332	-374	36	482	968	1,488	2,074	2,703	3,388	4,136
Loss Carry Forward	\$(000)	-2,037	-3,008	-3,697	-4,395	-4,728	-5,100	-5,064	-4,582	-3,813	-2,115	-41	0	0	0
Taxable Income	\$(000)	0	0	0	0	0	0	0	0	0	0	0	2,682	3,388	4,136
Tax	\$(000)	0	0	0	0	0	0	0	0	0	0	0	1,178	1,501	1,832
Net Income after Tax	\$(000)	-2,037	-970	-688	-688	-332	-374	36	482	968	1,488	2,074	1,524	1,887	2,304
+ Book Depreciation	\$(000)	1,530	1,759	1,903	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005
- Principal	\$(000)	425	539	644	749	838	940	1,053	1,178	1,321	1,479	1,657	1,855	2,078	2,327
Net Cash Flow	\$(000)	-832	249	570	557	834	681	988	1,308	1,652	2,023	2,422	1,873	1,814	1,981
Debt	\$(000)	30,680	34,754	37,108	38,485	37,736	36,898	35,958	34,904	33,724	32,404	30,925	29,268	27,413	25,335
Chicago CPI Escalator		1.15	1.21	1.27	1.33	1.40	1.47	1.54	1.62	1.70	1.78	1.87	1.97	2.07	2.17
Fuel Cost Escalator		1.18	1.26	1.34	1.42	1.50	1.58	1.66	1.76	1.86	1.96	2.01	2.26	2.36	2.54
Electricity Escalator		1.28	1.36	1.47	1.58	1.71	1.85	2.00	2.16	2.33	2.52	2.72	2.94	3.17	3.43
NPV \$(000)		31,434													
ROA		20.04%													
Principal & Interest		4,096	4,710	5,097	5,368	5,368	5,368	5,368	5,368	5,368	5,368	5,368	5,368	5,368	5,368
Total Plant Cost		87,400	91,770	98,359	101,178	108,235	111,647	117,124	122,981	129,130	135,588	142,365	149,484	156,958	164,808
% Completed		0.35	0.4	0.43	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45
Operating Income + Investments		-27,437	370	2,776	3,901	6,201	6,058	6,356	6,678	7,020	7,381	7,790	8,220	8,683	9,181
Net Cash Flow Incl Investments		-31,822	-4,338	-2,320	-1,468	834	681	988	1,308	1,652	2,023	2,422	1,873	1,814	1,981

		2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
		\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)
Cooling Demand	Tons	64,000	64,000	64,000	64,000	64,000	64,000	64,000	64,000	64,000	64,000	64,000
Annual Consumption	Tonhrs (000)	65,510	65,510	65,510	65,510	65,510	65,510	65,510	65,510	65,510	65,510	65,510
Heating Demand	MMBtu/hr	300	300	300	300	300	300	300	300	300	300	300
Annual Consumption	MMBtu	683,000	683,000	683,000	683,000	683,000	683,000	683,000	683,000	683,000	683,000	683,000
Revenue	\$(000)	126,754	135,807	145,553	156,044	167,339	178,500	192,594	208,895	221,881	238,236	255,851
Chilled Water Sales	\$(000)	31,915	33,847	35,480	37,418	39,468	41,639	43,835	46,363	48,933	51,852	54,828
Hot Water Sales												
Operating Expenses	\$(000)	25,783	27,330	28,970	30,708	32,550	34,503	36,573	38,768	41,094	43,560	46,173
Fuel	\$(000)	1,269	1,366	1,448	1,535	1,628	1,728	1,829	1,936	2,056	2,178	2,309
Water & Chemicals	\$(000)	4,067	4,260	4,473	4,697	4,932	5,178	5,437	5,706	5,985	6,284	6,609
Operating Personnel	\$(000)	6,522	6,849	7,191	7,550	7,928	8,324	8,741	9,178	9,637	10,118	10,624
Maintenance	\$(000)											
Operating Income	\$(000)	121,017	129,650	138,950	148,972	159,771	171,408	183,949	197,466	212,034	227,737	244,664
Interest	\$(000)	2,047	1,808	1,246	932	653	441	283	182	114	60	0
Book Depreciation	\$(000)	6,765	6,765	6,765	6,765	6,765	6,765	6,765	6,765	6,765	6,765	6,765
Net Income before Tax	\$(000)	113,205	122,277	131,939	142,274	153,352	165,201	177,900	191,538	206,154	221,912	238,899
Taxes	\$(000)	6,765	6,765	6,765	6,765	6,765	6,765	6,765	6,765	6,765	6,765	6,765
+ Book Depreciation	\$(000)	6,765	6,765	6,765	6,765	6,765	6,765	6,765	6,765	6,765	6,765	6,765
- Tax Depreciation	\$(000)											
Taxable Income	\$(000)	113,205	122,277	131,939	142,274	153,352	165,201	177,900	191,538	206,154	221,912	238,899
Less Carry Forward	\$(000)	0	0	0	0	0	0	0	0	0	0	0
Taxable Income Tax	\$(000)	113,205	122,277	131,939	142,274	153,352	165,201	177,900	191,538	206,154	221,912	238,899
Net Income after Tax	\$(000)	63,055	68,108	73,490	79,247	85,417	92,017	99,090	106,687	114,828	123,605	133,087
+ Book Depreciation	\$(000)	6,765	6,765	6,765	6,765	6,765	6,765	6,765	6,765	6,765	6,765	6,765
- Principal	\$(000)	3,663	3,014	2,613	2,328	1,785	1,315	1,009	401	449	503	0
Net Cash Flow	\$(000)	65,157	70,859	76,642	82,685	89,417	96,467	103,846	112,051	120,144	128,867	138,832
Debt	\$(000)	17,060	13,396	10,382	7,769	5,442	3,677	2,362	1,353	952	503	0
Chicago CPI Escalator												
Fuel Cost Escalator		4.51	4.73	4.97	5.22	5.48	5.75	6.04	6.34	6.66	6.99	7.34
Electricity Escalator		6.08	6.45	6.83	7.24	7.68	8.15	8.63	9.15	9.70	10.28	10.89
NPV \$(000)		10.87	11.74	12.68	13.69	14.79	15.97	17.25	18.63	20.12	21.73	23.47
RDA												
Principal & Interest		6,711	4,622	3,859	3,259	2,418	1,756	1,293	953	663	463	0
Total Plant Cost	76,000	342,619	359,750	377,736	396,625	416,456	437,278	459,143	482,100	506,205	531,515	558,091
% Completed		1	1	1	1	1	1	1	1	1	1	1
Operating Income + Investments		121,017	129,650	138,950	148,972	159,771	171,408	183,949	197,466	212,034	227,737	244,664
Net Cash Flow, Incl Investments		65,157	70,859	76,642	82,685	89,417	96,467	103,846	112,051	120,144	128,867	138,832

	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)
Costing Demand Annual Consumption	17,000 12,763	17,000 12,763	17,000 12,763	17,000 12,763	17,000 12,763	17,000 12,763	17,000 12,763	17,000 12,763	17,000 12,763	17,000 12,763	17,000 12,763
Units Tons	105 140,300	105 140,300	105 140,300	105 140,300	105 140,300	105 140,300	105 140,300	105 140,300	105 140,300	105 140,300	105 140,300
Heating Demand Annual Consumption	105 140,300	105 140,300	105 140,300	105 140,300	105 140,300	105 140,300	105 140,300	105 140,300	105 140,300	105 140,300	105 140,300
Revenue	27,011	28,887	30,862	33,008	35,315	37,797	40,468	43,336	46,426	49,747	53,322
Called Water Sales	7,230	7,813	8,017	8,445	8,897	9,376	9,862	10,416	10,962	11,580	12,213
Hot Water Sales											
Operating Expenses											
Fuel	5,187	5,498	5,828	6,178	6,548	6,941	7,358	7,799	8,267	8,763	9,289
Water & Chemicals	289	276	291	308	327	347	368	390	415	438	464
Operating Personnel	4,057	4,280	4,473	4,687	4,932	5,178	5,437	5,708	5,995	6,294	6,609
Maintenance	1,277	1,341	1,408	1,479	1,552	1,630	1,712	1,797	1,887	1,981	2,080
Operating Income	23,460	25,105	26,879	28,791	30,853	33,076	35,473	38,058	40,845	43,851	47,092
Interest	0	0	0	0	0	0	0	0	0	0	0
Book Depreciation	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005
Net Income before Tax	21,455	23,101	24,874	26,787	28,848	31,071	33,468	36,053	38,840	41,846	45,088
Taxes	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005
+ Book Depreciation	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005
- Tax Depreciation											
Taxable Income	21,455	23,101	24,874	26,787	28,848	31,071	33,468	36,053	38,840	41,846	45,088
Loss Carry Forward	0	0	0	0	0	0	0	0	0	0	0
Taxable Income	21,455	23,101	24,874	26,787	28,848	31,071	33,468	36,053	38,840	41,846	45,088
Tax	9,605	10,234	11,019	11,866	12,760	13,785	14,926	16,171	17,520	18,974	20,538
Net Income after Tax	11,850	12,867	13,855	14,920	16,088	17,307	18,642	20,081	21,634	23,308	25,114
+ Book Depreciation	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005
- Principal	0	0	0	0	0	0	0	0	0	0	0
Net Cash Flow	13,855	14,872	15,860	16,925	18,073	19,311	20,646	22,086	23,639	25,313	27,118
Debt	0	0	0	0	0	0	0	0	0	0	0
Chicago CPI Escalator	4.51	4.73	4.97	5.22	5.48	5.75	6.04	6.34	6.68	6.99	7.34
Fuel Cost Escalator	6.06	6.45	6.83	7.24	7.66	8.14	8.63	9.15	9.70	10.28	10.89
Electricity Escalator	10.87	11.74	12.68	13.69	14.79	15.97	17.25	18.63	20.12	21.73	23.47
NPV \$(000)											
ROA											
Principal & Interest	0	0	0	0	0	0	0	0	0	0	0
Total Plant Cost	76,000	342,619	359,750	377,738	396,625	416,458	437,279	459,143	482,100	506,205	538,091
% Completed	1	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45
Operating Income + Investments	23,460	25,105	26,879	28,791	30,853	33,076	35,473	38,058	40,845	43,851	47,092
Net Cash Flow, Incl Investments	13,855	14,872	15,860	16,925	18,073	19,311	20,646	22,086	23,639	25,313	27,118

	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
	\$ (000)	\$ (000)	\$ (000)	\$ (000)	\$ (000)	\$ (000)	\$ (000)	\$ (000)	\$ (000)	\$ (000)	\$ (000)	\$ (000)	\$ (000)	\$ (000)
Costing														
Demand	17,000	17,000	17,000	17,000	17,000	17,000	17,000	17,000	17,000	17,000	17,000	17,000	17,000	17,000
Annual Consumption	12,763	12,763	12,763	12,763	12,763	12,763	12,763	12,763	12,763	12,763	12,763	12,763	12,763	12,763
Heating														
Demand	105	105	105	105	105	105	105	105	105	105	105	105	105	105
Annual Consumption	140,300	140,300	140,300	140,300	140,300	140,300	140,300	140,300	140,300	140,300	140,300	140,300	140,300	140,300
Revenue														
Chilled Water Sales	11,200	11,890	12,622	13,407	14,260	15,166	16,128	17,172	18,293	19,468	20,793	22,183	23,678	25,284
Hot Water Sales	3,912	3,798	3,973	4,169	4,377	4,595	4,828	5,073	5,332	5,608	5,898	6,202	6,528	6,868
Operating Expenses														
Fuel	2,294	2,432	2,578	2,722	2,898	3,070	3,254	3,450	3,657	3,878	4,108	4,355	4,616	4,893
Water & Chemicals	116	122	129	137	145	154	163	172	183	194	206	218	231	245
Operating Personnel	2,048	2,152	2,259	2,372	2,481	2,515	2,748	2,863	3,028	3,179	3,338	3,505	3,680	3,864
Maintenance	645	677	711	747	784	823	864	908	953	1,001	1,051	1,103	1,158	1,216
Operating Income	9,718	10,298	10,918	11,589	12,311	13,090	13,928	14,832	15,806	16,855	17,986	19,204	20,518	21,934
Interest														
Bank Depreciation	2,781	2,448	2,098	1,705	1,266	774	222	98	29	0	0	0	0	0
Net Income before Tax	4,932	8,843	8,818	7,879	8,041	10,311	11,701	12,731	13,772	14,850	15,981	17,200	18,513	19,929
Taxes														
Bank Depreciation	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005
- Tax Depreciation	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005
Taxable Income	4,932	5,843	6,818	7,879	8,041	10,311	11,701	12,731	13,772	14,850	15,981	17,200	18,513	19,929
Less Carry Forward	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Taxable Income	4,932	5,843	6,818	7,879	8,041	10,311	11,701	12,731	13,772	14,850	15,981	17,200	18,513	19,929
Tax	2,194	2,563	3,018	3,480	4,005	4,568	5,184	5,840	6,101	6,979	7,080	7,819	8,201	8,829
Net Income after Tax	2,738	3,280	3,798	4,399	5,036	5,743	6,518	7,091	7,671	8,272	8,901	9,580	10,312	11,101
Bank Depreciation														
- Principal	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005	2,005
Net Cash Flow	2,158	2,340	2,531	2,731	2,908	3,164	3,472	3,834	4,434	5,278	6,906	11,585	12,317	13,105
Debt														
Chicago CFI Escalator	23,007	20,400	17,481	14,211	10,549	6,447	1,853	803	242	0	0	0	0	0
Fuel Cost Escalator	2,28	2,39	2,51	2,64	2,77	2,91	3,05	3,20	3,36	3,53	3,71	3,89	4,09	4,29
Electricity Escalator	2,89	2,86	3,02	3,20	3,40	3,60	3,82	4,06	4,33	4,65	4,82	5,11	5,41	5,74
NPV \$ (000)	3,70	4,00	4,32	4,66	5,03	5,44	5,87	6,34	6,85	7,40	7,99	8,63	9,32	10,06
PCA														
Principal & Interest	5,368	5,368	5,368	5,368	5,368	5,368	5,368	5,368	5,368	5,368	5,368	5,368	5,368	5,368
Total Plant Cost	173,048	181,898	190,793	200,322	210,338	220,856	231,898	243,483	255,668	268,451	281,874	295,987	310,798	326,304
% Completed	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45
Operating Income + Investments	8,718	10,298	10,918	11,589	12,311	13,090	13,928	14,832	15,806	16,855	17,986	19,204	20,518	21,934
Net Cash Flow, Incl. Investments	2,158	2,340	2,531	2,731	2,908	3,164	3,472	3,834	4,434	5,278	6,906	11,585	12,317	13,105

		1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006
		\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)
Costing Demand	Tons	11,000	16,000	17,000	18,000	21,000	24,000	26,000	28,000	32,000	34,000	37,000	39,000	42,000	44,000
Annual Consumption	Tonnes (000)	8,058	11,410	12,783	14,115	16,173	22,220	24,905	28,893	33,050	35,755	39,813	42,518	46,575	49,280
Heating Demand	MMBtu/hr	75	100	105	110	125	140	155	170	185	200	215	230	245	260
Annual Consumption	MMBtu	94,180	128,240	140,300	152,360	168,540	224,720	260,900	297,080	333,260	369,440	405,620	441,800	477,980	514,160
Revenue	\$(000)	3,268	4,883	5,508	6,177	7,873	9,888	11,126	13,212	15,454	17,268	19,801	21,909	24,871	27,317
Chilled Water Sales	\$(000)	1,337	1,848	2,082	2,291	2,853	3,457	4,108	4,807	5,680	6,389	7,239	8,174	9,179	10,257
Hot Water Sales	\$(000)														
Operating Expenses	\$(000)	652	933	1,081	1,242	1,639	2,073	2,492	3,004	3,562	4,105	4,759	5,400	6,165	6,917
Fuel	\$(000)	33	47	54	62	82	104	125	150	178	205	238	270	308	346
Water & Chemicals	\$(000)	680	725	781	798	839	1,321	1,387	1,458	1,529	1,608	1,686	1,770	1,859	1,952
Operating Personnel	\$(000)	207	307	359	416	581	718	849	1,004	1,238	1,408	1,644	1,846	2,121	2,360
Maintenance	\$(000)														
Operating Income	\$(000)	3,042	4,720	5,315	5,950	7,605	8,937	10,382	12,374	14,508	16,312	18,743	20,828	23,597	26,000
Interest	\$(000)	3,671	4,170	4,453	4,861	5,533	6,087	6,511	7,098	7,823	8,571	9,885	9,212	9,810	9,794
Book Depreciation	\$(000)	1,530	1,759	1,903	2,108	2,425	2,703	2,938	3,245	3,632	4,039	4,324	4,548	4,862	5,109
Net Income before Tax	\$(000)	-2,159	-1,210	-1,041	-1,017	-352	147	933	2,043	3,052	3,702	5,434	7,068	9,124	11,098
Taxes	\$(000)	1,530	1,759	1,903	2,108	2,425	2,703	2,938	3,245	3,632	4,039	4,324	4,548	4,862	5,109
+ Book Depreciation	\$(000)	1,530	1,759	1,903	2,108	2,425	2,703	2,938	3,245	3,632	4,039	4,324	4,548	4,862	5,109
- Tax Depreciation	\$(000)														
Taxable Income	\$(000)	-2,159	-1,210	-1,041	-1,017	-352	147	933	2,043	3,052	3,702	5,434	7,068	9,124	11,098
Less Carry Forward	\$(000)	-2,159	-3,368	-4,409	-5,426	-5,778	-5,831	-4,688	-2,655	0	0	0	0	0	0
Taxable Income	\$(000)	0	0	0	0	0	0	0	0	397	3,702	5,434	7,068	9,124	11,098
Tax	\$(000)	0	0	0	0	0	0	0	0	176	1,840	2,407	3,130	4,042	4,916
Net Income after Tax	\$(000)	-2,159	-1,210	-1,041	-1,017	-352	147	933	2,043	2,876	2,082	3,027	3,938	5,082	6,181
+ Book Depreciation	\$(000)	1,530	1,759	1,903	2,108	2,425	2,703	2,938	3,245	3,632	4,039	4,324	4,548	4,862	5,109
- Principal	\$(000)	425	539	644	777	859	1,182	1,355	1,603	1,903	2,244	2,662	2,968	3,409	3,868
Net Cash Flow	\$(000)	-1,054	10	218	312	1,113	1,669	2,516	3,685	4,805	3,857	4,758	5,518	6,538	7,404
Debt	\$(000)	30,580	34,754	37,106	40,508	46,105	50,723	54,257	59,051	65,198	71,428	74,879	78,771	80,083	81,819
Chicago CPI Escalator		1.15	1.21	1.27	1.33	1.40	1.47	1.54	1.62	1.70	1.78	1.87	1.97	2.07	2.17
Fuel Cost Escalator		1.15	1.21	1.27	1.33	1.40	1.47	1.54	1.62	1.70	1.78	1.87	1.97	2.07	2.17
Electricity Escalator		1.15	1.21	1.27	1.33	1.40	1.47	1.54	1.62	1.70	1.78	1.87	1.97	2.07	2.17
NPV \$(000)		81,071													
ROA		23.06%													
Principal & Interest		4,095	4,710	5,097	5,638	6,492	7,239	7,866	8,689	9,728	10,815	11,578	12,178	13,019	13,681
Total Plant Cost		87,400	91,770	98,359	101,176	108,225	111,547	117,124	122,981	129,130	135,586	142,365	149,484	156,958	164,908
% Completed		0.35	0.4	0.43	0.47	0.53	0.58	0.62	0.67	0.73	0.79	0.83	0.86	0.9	0.93
Operating Income + Investments		-27,848	131	2,424	1,903	1,201	3,360	5,897	8,225	8,761	8,177	13,048	18,342	17,318	21,058
Net Cash Flow, Inc Investments		-31,844	-4,576	-2,672	-3,736	-5,261	-3,879	-2,189	-2,464	-3,142	-4,278	-608	1,004	257	2,459

		2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
		\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)
Cooling Demand	Tons	47,000	50,000	52,000	54,000	56,000	58,000	58,000	58,000	58,000	58,000	58,000	58,000	58,000	58,000
Annual Consumption	Tonnes (000)	53,308	57,395	60,100	62,805	65,510	65,510	65,510	65,510	65,510	65,510	65,510	65,510	65,510	65,510
Heating Demand	MMBtu/hr	276	280	305	330	330	330	330	330	330	330	330	330	330	330
Annual Consumption	MMBtu	650,340	698,620	822,700	883,000	883,000	883,000	883,000	883,000	883,000	883,000	883,000	883,000	883,000	883,000
Revenue	\$(000)	30,670	34,268	37,335	40,613	44,118	46,049	48,077	50,208	52,441	54,788	57,252	59,840	62,557	65,410
Chilled Water Sales	\$(000)	11,415	12,658	13,992	15,967	15,873	17,414	18,193	19,010	19,868	20,770	21,717	22,710	23,754	24,848
Hot Water Sales	\$(000)														
Operating Expenses	\$(000)	7,809	8,773	9,725	10,987	11,731	12,317	12,833	13,580	14,259	14,972	15,720	16,508	17,332	18,198
Fuel	\$(000)	300	439	486	549	587	616	647	679	713	748	786	825	867	910
Water & Chemicals	\$(000)	2,046	2,182	2,259	2,372	2,491	2,615	2,746	2,883	3,028	3,178	3,338	3,505	3,680	3,864
Operating Personnel	\$(000)	2,680	3,025	3,330	3,671	4,004	4,204	4,415	4,635	4,867	5,110	5,368	5,634	5,916	6,212
Maintenance	\$(000)														
Operating Income	\$(000)	29,157	32,540	35,528	39,000	41,979	43,711	45,529	47,438	49,443	51,548	53,759	56,079	58,516	61,075
Interest	\$(000)	9,743	9,869	9,269	8,598	8,348	7,487	6,544	5,868	5,397	4,804	4,205	3,638	3,089	2,551
Book Depreciation	\$(000)	5,262	5,555	5,555	5,555	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765
Net Income before Tax	\$(000)	14,131	17,116	20,703	24,849	27,868	30,448	33,220	35,705	38,280	40,979	43,788	46,878	49,662	52,759
Taxes	\$(000)	5,282	5,555	5,555	5,555	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765
+ Book Depreciation	\$(000)	5,282	5,555	5,555	5,555	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765
- Tax Depreciation	\$(000)														
Taxable Income	\$(000)	14,131	17,116	20,703	24,849	27,868	30,448	33,220	35,705	38,280	40,979	43,788	46,878	49,662	52,759
Loss Carry Forward	\$(000)	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Taxable Income	\$(000)	14,131	17,116	20,703	24,849	27,868	30,448	33,220	35,705	38,280	40,979	43,788	46,878	49,662	52,759
Tax	\$(000)	6,280	7,582	9,171	11,008	12,345	13,489	14,716	15,817	16,958	18,154	19,398	20,678	22,000	23,372
Net Income after Tax	\$(000)	7,851	9,534	11,531	13,841	15,521	16,960	18,503	19,887	21,322	22,825	24,390	26,000	27,662	29,387
+ Book Depreciation	\$(000)	5,282	5,555	5,555	5,555	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765
- Principal	\$(000)	4,401	5,004	5,605	6,278	7,089	7,940	8,797	9,759	10,843	11,984	13,203	14,515	15,916	17,412
Net Cash Flow	\$(000)	8,732	10,084	11,481	13,118	14,197	14,785	15,471	16,384	17,445	18,601	19,972	21,341	22,845	24,385
Debt	\$(000)	81,194	82,244	77,239	71,835	69,564	62,475	54,535	49,737	44,978	40,038	35,041	30,301	25,739	21,257
Chicago CPI Escalator															
Fuel Cost Escalator															
Electricity Escalator															
NPV \$(000)															
RDA															
Principal & Interest		14,144	14,874	14,874	14,874	15,437	15,437	11,342	10,727	10,340	9,798	8,945	8,198	7,571	6,748
Total Plant Cost	76,000	173,046	181,998	190,783	200,322	210,339	220,855	231,898	243,493	255,668	268,451	281,774	295,967	310,768	326,304
% Completed	1	0.95	0.96	0.96	0.96	1	1	1	1	1	1	1	1	1	1
Operating Income + Investments		25,898	27,989	35,526	39,000	37,772	43,711	45,529	47,438	49,443	51,548	53,759	56,079	58,516	61,075
Net Cash Flow, Incl Investments		5,282	4,533	11,481	13,118	14,197	14,785	15,471	16,384	17,445	18,601	19,972	21,341	22,845	24,385

	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)
Cooling Demand	54,000	54,000	54,000	54,000	54,000	54,000	54,000	54,000	54,000	54,000	54,000
Annual Consumption	85,510	85,510	85,510	85,510	85,510	85,510	85,510	85,510	85,510	85,510	85,510
Heating Demand	330	330	330	330	330	330	330	330	330	330	330
Annual Consumption	683,000	683,000	683,000	683,000	683,000	683,000	683,000	683,000	683,000	683,000	683,000
Revenue											
Chilled Water Sales	68,405	71,651	74,853	78,321	81,882	85,785	89,789	94,014	98,440	103,087	107,966
Hot Water Sales	26,000	27,207	28,476	29,807	31,208	32,674	34,215	35,834	37,533	39,318	41,192
Operating Expenses											
Fuel	19,108	20,064	21,067	22,120	23,228	24,387	25,607	26,887	28,231	29,643	31,125
Water & Chemicals	955	1,003	1,053	1,108	1,161	1,219	1,280	1,344	1,412	1,482	1,558
Operating Personnel	4,057	4,280	4,473	4,697	4,932	5,178	5,437	5,709	5,995	6,294	6,609
Maintenance	6,522	6,840	7,191	7,550	7,928	8,324	8,741	9,178	9,637	10,118	10,624
Operating Income	63,762	68,583	69,545	72,655	75,920	79,349	82,950	86,730	90,699	94,867	99,243
Interest	2,047	1,808	1,248	922	653	441	283	162	114	80	0
Book Depreciation	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765
Net Income before Tax	55,948	59,210	62,533	65,957	69,502	73,143	76,901	80,802	84,820	88,042	93,478
Taxes	8,765	8,765	8,765	8,765	8,765	8,765	8,765	8,765	8,765	8,765	8,765
Book Depreciation	8,765	8,765	8,765	8,765	8,765	8,765	8,765	8,765	8,765	8,765	8,765
Tax Depreciation	8,765	8,765	8,765	8,765	8,765	8,765	8,765	8,765	8,765	8,765	8,765
Taxable Income	55,948	59,210	62,533	65,957	69,502	73,143	76,901	80,802	84,820	88,042	93,478
Less Carry Forward	0	0	0	0	0	0	0	0	0	0	0
Taxable Income	55,948	59,210	62,533	65,957	69,502	73,143	76,901	80,802	84,820	88,042	93,478
Tax	24,785	28,230	27,702	29,219	30,788	32,402	34,087	35,795	37,576	39,445	41,411
Net Income after Tax	31,164	32,980	34,831	36,738	38,713	40,740	42,834	45,007	47,245	49,598	52,067
Book Depreciation	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765	5,765
Principal	3,663	3,014	2,613	2,328	1,785	1,316	1,009	401	449	503	0
Net Cash Flow	33,265	35,731	37,983	40,177	42,713	45,181	47,590	50,371	52,561	54,859	57,833
Debt	17,060	13,398	10,382	7,769	5,442	3,877	2,362	1,353	852	503	0
Chicago CPI Escalator	4.51	4.73	4.97	5.22	5.48	5.75	6.04	6.34	6.66	6.99	7.34
Fuel Cost Escalator	4.51	4.73	4.97	5.22	5.48	5.75	6.04	6.34	6.66	6.99	7.34
Electricity Escalator	4.51	4.73	4.97	5.22	5.48	5.75	6.04	6.34	6.66	6.99	7.34
NPV \$(000)											
ROA	5,711	4,822	3,859	3,259	2,418	1,756	1,293	863	563	363	0
Principal & Interest											
Principal	342,619	359,750	377,738	396,825	416,456	437,278	459,143	482,100	506,205	531,515	558,091
Total Plant Cost	78,000	1	1	1	1	1	1	1	1	1	1
% Completed											
Operating Income + Investments	63,762	68,583	69,545	72,655	75,920	79,349	82,950	86,730	90,699	94,867	99,243
	33,265	35,731	37,983	40,177	42,713	45,181	47,590	50,371	52,561	54,859	57,833

		1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006
		\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)
Cooling Demand	Tons	11,000	16,000	17,000	18,000	21,000	24,000	26,000	28,000	32,000	34,000	37,000	39,000	42,000	44,000
Annual Consumption	Tonnes (000)	8,058	11,410	12,763	14,115	16,173	22,230	24,835	28,963	32,050	35,755	39,813	42,518	46,575	49,290
Heating Demand	MMBtu/hr	75	100	105	110	125	140	155	170	185	200	215	230	245	260
Annual Consumption	MMBtu	98,160	128,240	140,300	152,360	188,540	224,720	260,900	297,080	333,280	369,440	405,620	441,800	477,980	514,160
Revenue	\$(000)	3,410	5,128	5,869	6,683	8,078	10,889	12,728	15,408	18,363	20,944	24,552	27,718	32,083	36,998
Chilled Water Sales	\$(000)	1,358	1,888	2,115	2,363	2,981	3,611	4,318	5,087	5,922	6,830	7,815	8,894	10,044	11,303
Hot Water Sales															
Operating Expenses	\$(000)	674	975	1,140	1,322	1,781	2,248	2,728	3,322	3,978	4,628	5,415	6,202	7,148	8,098
Fuel	\$(000)	34	48	57	66	88	112	138	166	199	231	271	310	357	405
Water & Chemicals	\$(000)	680	725	781	798	838	1,321	1,387	1,458	1,528	1,606	1,686	1,770	1,859	1,952
Operating Personnel	\$(000)	207	307	358	418	581	718	848	1,004	1,236	1,408	1,644	1,848	2,121	2,360
Maintenance	\$(000)														
Operating Income	\$(000)	3,163	4,959	5,667	6,444	8,390	10,100	11,943	14,517	17,365	19,903	23,352	26,474	30,653	34,488
Interest	\$(000)	4,444	6,048	6,390	6,864	8,887	7,388	7,881	8,578	9,471	10,378	10,877	11,152	11,833	11,858
Book Depreciation	\$(000)	1,852	2,129	2,304	2,549	2,835	3,273	3,558	3,928	4,387	4,890	5,234	5,506	5,888	6,185
Net Income before Tax	\$(000)	-3,132	-2,219	-2,027	-1,990	-1,242	-541	505	2,011	3,487	4,638	7,240	9,816	13,134	16,447
Taxes	\$(000)	1,852	2,129	2,304	2,549	2,835	3,273	3,558	3,928	4,387	4,890	5,234	5,506	5,888	6,185
+ Book Depreciation	\$(000)	1,852	2,129	2,304	2,549	2,835	3,273	3,558	3,928	4,387	4,890	5,234	5,506	5,888	6,185
- Tax Depreciation	\$(000)														
Taxable Income	\$(000)	-3,132	-2,219	-2,027	-1,990	-1,242	-541	505	2,011	3,487	4,638	7,240	9,816	13,134	16,447
Loss Carry Forward	\$(000)	-3,132	-5,351	-7,378	-9,368	-10,810	-11,151	-10,845	-8,635	-5,137	-500	0	0	0	0
Taxable Income	\$(000)	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Tax	\$(000)	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Net Income after Tax	\$(000)	-3,132	-2,219	-2,027	-1,990	-1,242	-541	505	2,011	3,487	4,638	7,240	9,816	13,134	16,447
+ Book Depreciation	\$(000)	1,852	2,129	2,304	2,549	2,835	3,273	3,558	3,928	4,387	4,890	5,234	5,506	5,888	6,185
- Principal	\$(000)	514	653	780	941	1,181	1,294	1,640	1,940	2,303	2,716	3,138	3,580	4,128	4,704
Net Cash Flow	\$(000)	-1,794	-742	-503	-382	531	1,338	2,421	3,989	5,561	6,811	9,350	7,363	9,075	10,641
Debt	\$(000)	37,000	42,071	44,917	49,037	55,812	61,402	65,679	71,482	78,921	86,465	90,843	92,933	98,943	98,802
Chicago CPI Escalator															
Fuel Cost Escalator															
Electricity Escalator															
NPV \$(000)															
FOA															
Principal & Interest															
Total Plant Cost															
% Completed															
Operating Income + Investments															
Net Cash Flow, Incl Investments															

	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)
Coasting Demand	47,000	50,000	52,000	54,000	56,000	58,000	59,000	60,000	61,000	62,000	63,000	64,000	65,000	66,000
Annual Consumption	53,338	57,395	60,100	62,806	65,510	68,216	70,922	73,628	76,334	79,040	81,746	84,452	87,158	89,864
Heating Demand	275	290	305	320	335	350	365	380	395	410	425	440	455	470
Annual Consumption	550,340	568,520	586,700	604,880	623,060	641,240	659,420	677,600	695,780	713,960	732,140	750,320	768,500	786,680
Revenue	41,303	47,176	52,534	58,428	64,913	71,898	79,383	87,368	95,353	103,338	111,323	119,308	127,293	135,278
Chilled Water Sales	12,667	14,146	15,748	17,428	19,029	20,630	22,231	23,832	25,433	27,034	28,635	30,236	31,837	33,438
Hot Water Sales														
Operating Expenses	9,227	10,485	11,711	13,258	14,397	15,281	16,176	17,147	18,178	19,268	20,422	21,648	22,947	24,323
Fuel	481	523	568	618	670	725	783	844	908	975	1,045	1,118	1,194	1,272
Water & Chemicals	2,048	2,152	2,258	2,372	2,491	2,615	2,746	2,883	3,028	3,179	3,336	3,498	3,664	3,834
Operating Personnel	2,680	3,025	3,330	3,671	4,004	4,320	4,615	4,895	5,160	5,410	5,645	5,865	6,070	6,260
Maintenance	39,553	45,157	50,396	56,463	62,337	68,449	74,875	81,641	88,773	96,300	104,252	112,662	121,567	130,905
Operating Income	11,794	11,947	11,220	10,408	10,105	9,076	7,922	7,226	6,334	5,816	5,090	4,402	3,739	3,068
Interest	6,394	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724
Book Depreciation	21,364	26,486	32,451	39,332	45,253	50,394	55,974	61,437	67,261	73,505	80,182	87,281	94,849	102,938
Net Income before Tax	21,364	26,486	32,451	39,332	45,253	50,394	55,974	61,437	67,261	73,505	80,182	87,281	94,849	102,938
Taxes	6,394	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724
Book Depreciation	6,394	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724
Tax Depreciation	21,364	26,486	32,451	39,332	45,253	50,394	55,974	61,437	67,261	73,505	80,182	87,281	94,849	102,938
Taxable Income	21,364	26,486	32,451	39,332	45,253	50,394	55,974	61,437	67,261	73,505	80,182	87,281	94,849	102,938
Less Carry Forward	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Taxable Income	21,364	26,486	32,451	39,332	45,253	50,394	55,974	61,437	67,261	73,505	80,182	87,281	94,849	102,938
Tax	9,464	11,733	14,376	17,428	20,047	22,326	24,797	27,217	29,708	32,563	35,521	38,666	42,018	45,601
Net Income after Tax	11,900	14,752	18,075	21,908	25,206	28,070	31,178	34,221	37,484	40,942	44,662	48,616	52,831	57,336
Book Depreciation	6,394	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724	6,724
Principal	5,327	6,058	6,785	7,506	8,582	9,812	11,207	12,761	14,483	16,384	18,475	20,757	23,230	25,894
Net Cash Flow	12,987	15,419	18,015	21,033	23,803	26,437	32,349	35,439	38,460	41,878	45,903	50,072	54,384	58,235
Debt	98,287	99,558	99,558	99,558	99,558	99,558	99,558	99,558	99,558	99,558	99,558	99,558	99,558	99,558
Chicago CPI Escalator	2,28	2,30	2,31	2,34	2,77	2,91	3,05	3,20	3,38	3,53	3,71	3,89	4,09	4,29
Fuel Cost Escalator	2,86	2,86	3,02	3,20	3,40	3,60	3,82	4,06	4,29	4,56	4,82	5,11	5,41	5,74
Electricity Escalator	3,70	4,00	4,32	4,66	5,03	5,44	5,87	6,34	6,85	7,40	7,99	8,63	9,32	10,06
NPV \$(000)														
FDA														
Principal & Interest	17,122	18,005	18,005	18,005	18,687	18,687	13,728	12,988	12,517	11,861	10,828	9,924	9,165	8,169
Total Plant Cost	92,000	209,477	219,951	230,948	242,496	254,620	267,351	280,719	294,755	309,493	324,967	341,216	358,276	395,000
% Completed	1	0.95	0.98	0.98	1	1	1	1	1	1	1	1	1	1
Operating Income + Investments	35,353	38,558	50,398	56,463	57,245	66,449	70,975	75,641	80,773	86,300	92,252	98,682	105,567	113,005
Net Cash Flow, Incl Investments	8,777	8,820	18,015	21,033	18,511	25,437	32,349	35,439	38,460	41,878	45,903	50,072	54,384	58,235

		2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
		\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)	\$(000)
Cooling Demand	Tons	58,000	58,000	58,000	58,000	58,000	58,000	58,000	58,000	58,000	58,000	58,000
Annual Consumption	Tonnes (000)	65,510	65,510	65,510	65,510	65,510	65,510	65,510	65,510	65,510	65,510	65,510
Heating Demand	MMBtu/hr	300	300	300	300	300	300	300	300	300	300	300
Annual Consumption	MMBtu	683,000	683,000	683,000	683,000	683,000	683,000	683,000	683,000	683,000	683,000	683,000
Revenue	\$(000)	126,754	135,307	145,553	156,044	167,338	178,500	189,594	200,686	211,881	223,235	235,851
Chilled Water Sales	\$(000)	31,915	33,647	35,480	37,418	39,468	41,639	43,935	46,363	48,933	51,652	54,528
Hot Water Sales	\$(000)											
Operating Expenses	\$(000)	25,783	27,330	28,970	30,708	32,550	34,503	36,573	38,768	41,094	43,560	46,173
Fuel	\$(000)	1,288	1,366	1,448	1,535	1,628	1,728	1,829	1,938	2,055	2,178	2,309
Water & Chemicals	\$(000)	4,067	4,280	4,473	4,697	4,932	5,178	5,437	5,708	5,995	6,294	6,609
Operating Personnel	\$(000)	6,922	7,191	7,473	7,759	8,050	8,354	8,671	9,000	9,341	9,694	10,060
Maintenance	\$(000)											
Operating Income	\$(000)	121,017	129,650	138,950	148,972	159,771	171,408	183,949	197,468	212,034	227,737	244,664
Interest	\$(000)	2,477	1,948	1,508	1,129	781	534	343	198	138	73	0
Book Depreciation	\$(000)	6,978	6,978	6,978	6,978	6,978	6,978	6,978	6,978	6,978	6,978	6,978
Net Income before Tax	\$(000)	111,560	120,725	130,463	140,864	152,001	163,895	176,627	190,290	204,917	220,685	237,685
Taxes	\$(000)	6,978	6,978	6,978	6,978	6,978	6,978	6,978	6,978	6,978	6,978	6,978
+ Book Depreciation	\$(000)	6,978	6,978	6,978	6,978	6,978	6,978	6,978	6,978	6,978	6,978	6,978
- Tax Depreciation	\$(000)											
Taxable Income	\$(000)	111,560	120,725	130,463	140,864	152,001	163,895	176,627	190,290	204,917	220,685	237,685
Loss Carry Forward	\$(000)	0	0	0	0	0	0	0	0	0	0	0
Taxable Income	\$(000)	111,560	120,725	130,463	140,864	152,001	163,895	176,627	190,290	204,917	220,685	237,685
Tax	\$(000)	49,421	53,481	57,795	62,403	67,338	72,605	78,246	84,298	90,778	97,763	105,295
Net Income after Tax	\$(000)	62,139	67,244	72,668	78,461	84,665	91,289	98,381	105,992	114,139	122,922	132,391
+ Book Depreciation	\$(000)	6,978	6,978	6,978	6,978	6,978	6,978	6,978	6,978	6,978	6,978	6,978
- Principal	\$(000)	4,435	3,649	3,163	2,818	2,137	1,592	1,222	485	543	608	0
Net Cash Flow	\$(000)	64,683	70,574	76,483	82,624	89,507	96,676	104,138	112,485	120,574	129,282	139,370
Debt	\$(000)	20,651	18,216	12,568	9,404	6,588	4,451	2,860	1,637	1,152	609	0
Chicago CPI Escalator		4.51	4.73	4.97	5.22	5.48	5.75	6.04	6.34	6.68	6.99	7.34
Fuel Cost Escalator		6.08	6.45	6.83	7.24	7.68	8.14	8.63	9.16	9.70	10.28	10.89
Electricity Escalator		10.87	11.74	12.68	13.68	14.79	15.97	17.25	18.63	20.12	21.73	23.47
NPV \$(000)												
ROA												
Principal & Interest		6,913	5,594	4,672	3,945	2,927	2,126	1,565	682	682	682	0
Total Plant Cost	92,000	414,750	435,487	457,262	480,125	504,131	529,337	555,804	583,594	612,774	643,413	675,583
% Completed	1	1	1	1	1	1	1	1	1	1	1	1
Operating Income + Investments		121,017	129,650	138,950	148,972	159,771	171,408	183,949	197,468	212,034	227,737	244,664
Net Cash Flow, Incl Investments		64,683	70,574	76,483	82,624	89,507	96,676	104,138	112,485	120,574	129,282	139,370

REFERENCES

1. Central Station Development Guidelines, March 1990, Department of Planning.
2. "Central Station District Energy Assessment", September 1990, Trigen Energy Corporation and Midwesco Inc.
3. CFCs: Time of Transition, American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc., 1989.
4. "Electric Utility Franchise Expiration and Renewal Process", City of Chicago Department of Planning, 1988.
5. Final Report to the City of Chicago, Department of Planning "Technical Assistance District Heating", September 1989, The United States Conference of Mayors and the United States Department of Housing and Urban Development Cooperative Agreement No. HA - 13040.
6. Memorandum from John Nimmons and Associates to W. Dwight Bailey on Analysis of Task I and II Research Results - "Public Utility Treatment and Franchise Issues Affecting Private Central Station DHC Development", April 25, 1990 .
7. Municipal Code of Chicago, Chapters 13 and 15, 1990.
8. Wall Street Journal Article on CFCs, 1991 title and date unknown.

REPORT AND INFORMATION SOURCES

Additional copies of the report, "Central Station DHC Phase I Feasibility" are available from:

Publications and Distribution
Public Technology, Incorporated
1301 Pennsylvania Avenue, N.W.
Washington, D.C. 20004

For additional information concerning this project,
please contact:

Charles H. Williams
Director of Energy Management
City of Chicago
Department of Environment
320 North Clark Street - Room 600A
Chicago, Illinois 60610
312/744-8901

DG/90-304
10/92-150

Publications Price List--UCETF Reports

ITEM #	TITLE	PRICE
90-331	Hydraulic Waste Energy Recovery: A Technical Report	15.00
90-318	A Regulatory Framework for Alternative Fuels and Transportation Management Services	15.00
90-316	Alternative Vehicle Fuels: A Demonstration Project	15.00
90-314	Energy Efficiency in Public Housing	15.00
89-330	Analysis of Programmatic Fleet Conversion to Ethanol Blends	15.00
89-325	An Alternative Fuels Evaluation System for Fleet Vehicles	15.00
89-323	Dual Fuel Conversion Demonstration and Technology Transfer Project	10.00
89-321	Summary of Low and Moderate Income Residential Energy Conservation Programs	15.00
89-315	A Case Study in the Pursuit of Urban Energy Efficiency	15.00
89-314	Communicating with the Public About Environmental Health Risks: A Case Study	13.00
89-313	Evaluation and Comparison of Selected Household Hazardous Waste Collection Facilities	15.00
89-311	Yard Waste Recycling Study: A Pilot Study	15.00
89-310	Sludge Storage Lagoon Biogas Recovery and Use, Volume 1	15.00
89-307	Proceeding: 1989 Electric Utility Franchise Conference	20.00
89-306	Reducing Electricity Demand Through Energy-Related Efficient Construction	15.00
89-304	Modernization of Lighting in Municipal Auditoriums	15.00
89-303	Wastewater Treatment Process Energy Optimization	13.00
89-301	Implementation of Alternative Technologies through the Assessment of Energy Markets	14.00
88-322	Marketing Energy Efficiency Programs to Commercial and Industrial Firms: Lighting Incentives and	15.00
88-321	Urban Energy Management Today: Ten Year Compendium of UCETF Programs	10.00
88-319	Integrating Energy Efficiency Into Municipal Purchasing Decisions: Computerizing Procurement	15.00
88-318	Household Hazardous Waste: Implementation of a Permanent Collection Facility	20.00
88-317	Hazardous Waste as an Energy Manager's Issue	15.00
88-316	Household Hazardous Waste Management Planning	15.00
88-312	Summary of Small Business Energy Conservation Programs	15.00
88-310	The Earth-Coupled Heat Pump: Utilizing Innovative Technology in Single Family Rehabilitation	15.00
88-309	Energy Planning for Economic Development	18.00
88-308	Conversion of Resource Recovery Steam to Hot and Chilled Water Systems	10.00
88-306	HVAC Equipment Replacement for Best Size and Efficiency, Transfer Report	15.00
88-305	Cogeneration and Cooling in Small Scale Applications	15.00
88-304	Energy Master Planning: Innovative Design and Energy Analysis Services for New Commercial	22.00
88-303	Energy Efficient Building Design: Guidelines for Local Government	15.00
88-302	Direct Digital Control of Air Washer Cooling System	15.00
88-301	Feasibility Study of Transportation Management Strategies in the Poplar Corridor, Memphis, Tennessee	18.00
87-327	Energy Efficient Urban Cooling Technologies: 1st National Conf.	20.00
87-324	Memphis Area Rideshare	15.00
87-317	Joint City Government/Utility Partnerships to Reduce Business Costs	15.00
87-314	The Impact of Budgetary Incentives on Energy Management	15.00

Publications Price List--UCETF Reports

ITEM #	TITLE	PRICE
87-313	Computer Assisted Control for Municipal Water Systems, Phase II	20.00
87-312	Economic Development Through Energy Technology Transfer	15.00
87-311	Electric Utility Franchise Guide	20.00
87-310	Hidden Link: The Energy and Economic Development, Phase II	15.00
87-307	Municipal Underground Storage Tanks: An Energy Manager's Guide	18.00
87-306	Integrating Energy Efficiency into Mun. Purchasing Decisions	20.00
87-305	Energy Enhancement in New Residential Construction	40.00
87-302	Thermal Energy Storage: Application Guide for Local Governments	20.00
87-301	HVAC Equipment Replacement for Best Size & Efficiency	20.00
86-315	Balancing Single Pipe Steam Heating Systems	20.00
86-314	Inhibition of Respiration in Activated Sludge by High Carbon Dioxide Concentration	7.50
86-313	Water Supply System Energy Conservation Through Computer Control	18.00
86-312	Energy Cost Reduction Through Wastewater Flow Equalization	20.00
86-311	High Efficiency Gas Furnace Modification in Low Income Housing	15.00
86-310	Hidden Link: Energy and Economic Development, Phase I	15.00
86-307	Disposal Techniques with Energy Recovery for Scrapped Vehicle Tires	20.00
86-306	District Heating Marketing: Analysis of a Twelve City Survey	20.00
86-305	Technology Transfer for Residential Energy Programs in New Construction and Existing Housing	15.00
86-304	Technology Transfer for Residential Energy Efficiency	15.00
86-302	Neighborhood Energy Efficiency & Reinvestment	15.00
86-301	On-Site Municipal Fuel Cell Power Plan: Feasibility and Application Guide	15.00
85-326	Resource Recovery for Urban Yard Waste	18.00
85-323	Energy Monitoring and Controlling in Municipal Facilities	10.00
85-320	Transportation Management for Business Relocation	15.00
85-319	District Heating in Denmark	10.00
85-318	Computer-Assisted Control for Municipal Water Systems, Phase I	18.00
85-317	Financing Energy Efficient Housing as a Community Economic Development Tool	15.00
85-316	Modular District Heating Planning as a Development Tool	15.00
85-314	Alternative Techniques for Dev. of Energy Efficient Residences	15.00
85-312	Shared Savings and Low Income Homeowners	18.00
85-311	Measures and Investment Options for Community Energy Conservation	18.00
85-310	Planning for Energy Efficiency in New Commercial Buildings	15.00
85-308	Residential Space Heating with Wood	15.00
85-307	Thermal Storage Strategies for Energy Cost Reduction	18.00
84-325	Shared Savings in the Residential Market	
84-324	Methanol Use in Vehicle Fleet Operations: Barriers	20.00
84-322	Energy Management and Technology for Urban Governments	15.00
84-321	Hydrate Process for Waste Water Treatment Plant Sludge Dewatering	15.00

Publications Price List--UCETF Reports

ITEM #	TITLE	PRICE
84-320	Development of Computerized Inventory and Maintenance System for Municipal Street Lights	15.00
84-315	Facilities Energy Monitoring System	15.00
84-314	Application of Mini-Van Technology to Vanpool Services	18.00
84-312	Implementation Methods for an Integrated Energy System	10.00
84-311	Feasibility of Water-Based District Heating and Cooling	15.00
84-310	Budgetary Incentives for Municipal Energy Management	22.00
84-309	Central Energy Systems Applications to Economic Development	20.00
84-308	On-Site Cogeneration for Office Buildings	15.00
84-306	Analysis of Municipal Bus Operations for the Advancement of Fuel Cell Technology	15.00
84-305	Computer Based Maintenance	15.00
84-304	Innovative Finance Plans for Privately Owned Waste/Vol. 2	15.00
84-303	Innovative Finance Plans for Privately Owned Waste/ Vol. 1	15.00
84-301	Coordinating Preventive Maintenance with Energy Management	15.00
83-319	The Rehabilitation and Retrofit of Older Houses to Superinsulated Standards	15.00
83-318	Developing Sources and Techniques for Alternative Financing of Energy Conservation	20.00
83-316	Hydrate Process for Dewatering Sewage Sludge	10.00
83-315	Financial Planning for District Heating: Brooklyn Navy Yard	15.00
83-314	Memphis Area Rideshare On-Line Information System	18.00
83-313	Renovation Opportunities for Steam District Heating Systems	18.00
83-312	Initial Assessment of District Heating and Cooling	20.00
83-311	Energy Conservation Through Computerized Automation	18.00
83-309	Development of an Energy Park: Issues and Implementation Options	15.00
83-308	Alternative Uses for Digester Methane Gas	25.00
83-307	Innovative Financing and Incentive Package to Reduce Energy	15.00
83-305	Multi-Jurisdictional Planning for District Heating and Cooling	10.00
83-303	Improving Energy Management and Accountability in Municipal Operations	15.00
82-320	Utilization of Felled City Trees as Supplemental Boiler Fuel	7.50
82-319	Methanol Use in Vehicle Fleet Operations: Comparisons	15.00
82-317	Microcomputer Tools for Trans. and Residential Energy Conservation	20.00
82-316	Reduction of Impediments to Alternative Energy Use	20.00
82-315	Reducing Regulatory and Financial Impediments to Energy Conservation	20.00
82-314	Integrating Energy Management with Economic Development	20.00
82-313	Energy Conservation and Economic Development	10.00
82-310	Municipal Technologies	20.00
82-307	Strategies to Improve Community Energy Use Practices	10.00
82-306	Energy Conservation In Water Treatment	
82-305	Development of an Energy Action Plan: Participating Approach	15.00
82-303	Energy Economic Development	20.00

Publications Price List--UCETF Reports

ITEM #	TITLE	PRICE
82-302	Public Housing Energy Efficiency Through Private Financing	10.00
82-300	Developing an Energy Management Tracking System	
81-328	Matching End Use Energy Needs to Source Possibilities	20.00
81-327	Development of a Hydrogen-Fueled Mass Transit Vehicle s	15.00
81-326	Operational and Maintenance Guidelines for Reducing Energy Consumption	
81-324	Energy Management for Small Business	10.00
81-320	Energy Data Gathering, Analysis, and Review System	20.00
81-318	Fuel Management and Planning System for Local Government	25.00
81-316	Production of Ethanol from Cellulosic Fraction	
81-313	Metro-Dade County Comprehensive Energy Emergency Plan	
81-311	Developing Energy Emergency Preparedness	15.00
81-310	Simplified Methodology for Community Energy Management	20.00
81-309	Energy Management: The Public Sector	15.00
81-307	Municipal Technical Assistance-Energy Monitoring	6.00
81-306	New Technology Demonstration	10.00
81-305	Technology Transfer: Unit Report from the Energy Task Force	15.00
81-304	Development of Local Energy Management Preparedness	10.00
81-303	Municipal Energy Management	10.00
80-314	Methodology for Energy Impact Analysis of Urban Development Projects	15.00
80-313	Evaluation of Landfill Gas as an Energy Source	15.00
80-309	Decision Process for the Retrofit of Municipal Buildings	20.00
80-308	Primary Urban Energy Management Planning Methodology	7.50
80-306	Local Government Use of Thermography for Energy	15.00
79-300	Planning for and Purchasing Computer Technology	6.50

END

**DATE
FILMED**

2 / 17 / 93