PNL--8365

DE93 006604

ENVIRONMENTAL RISK ASSESSMENT FOR
AQUIFER THERMAL ENERGY STORAGE

S. H. Hall

January 1993

Prepared for
the U.S. Department of Energy
under Contract DE-AC06-76RLO 1830

Pacific Northwest Laboratory
Richland, Washington 99352

MASTER

zp

U.S. DEPARTMENT OF ENERGY

SUMMARY

This report has been prepared by Pacific Northwest Laboratory at the request of the International Energy Agency (IEA). The U.S. Department of Energy represents the United States in the IEA for Annex IV, the IEA task for research and development in aquifer thermal energy storage (ATES).

Installation and operation of an ATES system is necessarily intrusive to ground-water resources. Therefore, governmental authorities usually require an environmental risk assessment to be performed before permission to construct an ATES system is granted. Writing an accurate statement of risk presupposes a knowledge of aquifer and ground-water characteristics and that an engineering feasibility study has taken place.

Effective and logical presentation of the results of the risk assessment can expedite the grant of approval. Introductory remarks should address questions regarding why the ATES project has been proposed, what it is expected to accomplish, and what the expected benefits are. Next, the system configuration, including the aquifer, ATES plant, and well field, should be described in terms of size and location, design components, and thermal and hydraulic capacity. The final element of system design, the predicted annual operating cycle, needs to be described in sufficient detail to allow the reviewer to appreciate the net hydraulic, thermal, and hydrochemical effects imposed on the aquifer.

Risks may be environmental or legal. Only after a reviewer has been introduced to the proposed system's design, operation, and scale can risk issues can be identified and weighed against the benefits of the proposed ATES system.

CONTENTS

SUMMARY	iii
INTRODUCTION	1
STATEMENT OF RISK - INTRODUCTION	3
PROPOSED DESIGN	5
AQUIFER DESCRIPTION	5
SYSTEM CONFIGURATION	6
SUPPLEMENTARY SYSTEMS	6
OPERATING CYCLE	7
SYSTEM OPERATING CYCLES	7
GROUND-WATER WITHDRAWAL	7
WATER TABLE PERTURBATION	7
EXISTING GROUND-WATER QUALITY	7
PROPOSED SYSTEM ENERGY BUDGET	8
RISK ISSUES	9
INTERFERENCE WITH (OR BY) OTHER USERS	9
PHYSICAL AND CHEMICAL EFFECTS OF INJECTION AND WITHDRAWAL	10
CONCLUSIONS	11
SUPPORTING INFORMATION	13

INTRODUCTION

The installation and operation of aquifer thermal energy storage (ATES) systems are necessarily intrusive to the hydrogeologic regime. Because of this and the need to protect and conserve ground-water resources, the environmental risks associated with any such proposed project must be carefully weighed against anticipated benefits. In most cases, the benefits will be expressed as conservation of electrical power and will be measured in terms of economy and decreased reliance on nonrenewable fuel resources. However, because ATES technology has not yet fully matured, the benefits associated with the results of research and additional operating experience must also be recognized.

This report presents the technical and regulatory issues that must be addressed to facilitate risk assessment for ATES projects. The report 1) provides a checklist of items to consider in evaluating the environmental risk associated with an ATES system, and 2) presents this checklist in a logical and useful example format for organizing the statement of risk that will be presented to regulatory authorities for review and approval.

Ideally, ATES systems are nonpolluting, the environmental effects are strictly localized and temporary, and net consumption of water is negligible. However, technical and legal problems can arise. Local perturbation of the hydraulic or thermal behavior of the aquifer, however temporary, may adversely affect the availability or suitability of the water resource for nearby users. Similarly, heating the water, or any water treatment (e.g., to prevent scaling in the water circulation system) inevitably causes a change in the chemistry of re-injected water relative to that of native ground water.

The checklist and format suggested in this report are designed to facilitate both the anticipation and evaluation of such problems. However, application of the checklist for preparing the formal statement of risk presupposes knowledge of aquifer and ground-water characteristics, and that an engineering feasibility study has been made. The scope and level of detail of these presuppositions will be apparent from the checklist itself. It must be emphasized that the checklist represents those items that are commonly required for

ATES design. It is not intended to be all-inclusive, nor is it intended that each item is necessarily mandatory for the statement of risk.

Each of the following sections represents a major section of the statement of risk as it might be presented to regulatory authorities, and the sections are presented in logical sequence.

STATEMENT OF RISK - INTRODUCTION

The introductory remarks provide a valuable frame of reference for the reviewer and should answer some basic questions:

- Why has the project been proposed?
- What is it expected to accomplish?
- What is the expected benefit?

An example introduction may state that the project may have been proposed as a pilot-scale facility to develop operating experience for future full-scale air-conditioning of nearby commercial buildings, using winter ambient air as a heat sink to supply "chill." Similarly, expectations based on the feasibility study might be that a high percentage; e.g., 90%, of the seasonal cooling requirements of a test building will be supplied by recovering chilled ground water stored during winter months, which is the benefit.

PROPOSED DESIGN

This section defines the configuration of the proposed ATEs system in terms of its major design components, size and location, design capacity, and the use of supplemental heating or cooling systems.

AQUIFER DESCRIPTION

The aquifer is the single most critical design component of an ATEs system. Therefore, it is appropriate to include its description in this section, the first element of which describes the location of the proposed system, a general description of the local geohydrologic regime, a suitably detailed description of the target aquifer and, if appropriate, its hydrologic relationship to overlying or underlying aquifers. Target aquifer description should consider the following:

- type of aquifer (confined, unconfined, confined and leaky, etc.)
- rock or sediment type (consolidated, unconsolidated, composition, grain size distribution, stratigraphy, etc.)
- aquifer thickness and depth to water
- hydraulic conductivity, including anisotropy if appropriate
- rate and direction of ground-water flow
- effective porosity
- well specific capacity in both the injection and withdrawal modes
- ambient ground-water temperature.

Most commonly, these aquifer characteristics will be estimated through a combined program of field testing and literature research. Such a program will yield a great deal of information. However, only that information that directly affects well field design and operation should be included in this section. Ancillary information, testing methods, methods of interpretation, and so forth should be reserved for the section on supporting information.

SYSTEM CONFIGURATION

The second element of this section is a description of the ATES system configuration, and should include the following:

- Well field layout, including plan dimensions, well locations, property boundaries, and production and monitoring well diameters and depths. Also to be included are the locations and depths of nearby wells, surface water bodies, storm sewers, and so forth, that are not necessarily associated with the ATES system, but that may be affected by the system.
- A description of the source, variability, and availability of heat or chill used to "charge" the ATES system
- A description of the plant superstructure, including pipelines, heat exchangers, pumps, buildings, filters, water treatment equipment, and throughput capacities. The use of flow diagrams and perspective drawings is encouraged.

SUPPLEMENTARY SYSTEMS

The final element of this section is a description of supplementary (co-generation) systems that may be used in conjunction with the ATES system to satisfy peak demands for heating or cooling.

OPERATING CYCLE

Up to this point, the reviewer has been told what will be built, why it will be built, and what it is expected to do. In this section, the reviewer is told how it is to be done.

SYSTEM OPERATING CYCLES

The first element of this section is a description of the seasonal operating cycles of the system. For both the storage and recovery cycles, this element should include flow rates, flow duration, net volumes stored or recovered, expected periods of operation, and the sequence of well usage.

GROUND-WATER WITHDRAWAL

If the planned operating cycles include a net withdrawal of ground water, that withdrawal needs to be presented in terms of net flow as a percentage of plant throughput, and in terms of seasonal flow variations. Further, the disposal of the withdrawn water must be discussed (e.g., irrigation, storm sewer).

WATER TABLE PERTURBATION

The maximum seasonal and net annual perturbation of the water table or piezometric surface must be presented and discussed from two viewpoints:

- What will be the peak seasonal and net annual hydraulic effects on nearby wells (probably belonging to other users of the aquifer)?
- What will be the peak seasonal and net annual tendencies to either enhance or retard the migration of thermally or chemically altered water towards nearby wells?

EXISTING GROUND-WATER QUALITY

The existing ground-water quality should be presented here along with a description of the kind and extent of any water treatment that may be necessary. A prediction of the most likely effects of re-injecting treated water into the aquifer should be included.

PROPOSED SYSTEM ENERGY BUDGET

The final element of this section is a description of the energy budget of the proposed system, and should include the following:

- Aquifer storage versus recovery of available energy, including energy losses in the plant itself; i.e., the efficiency of major design components. The result of this discussion will be a figure for net available energy.
- Energy requirements to run the plant (e.g., power to run the pumps and fans, etc.).
- The difference between the above, which reflects the net energy benefit of the ATES system. This difference should be translated into the percentage of heating or cooling requirements that can be supplied by the ATES system to the target building or process. Ultimately, this net result is weighed against the economic costs and environmental risk (or benefit) associated with constructing and operating the ATES system.

RISK ISSUES

This section presents those risk issues that may be attendant to the ATES system described in the preceding sections. Each category of risk must be subjected to certain questions:

- Does it reasonably exist?
- If it exists, is it acceptable?
- If it is not acceptable, can it be mitigated?
- If so, how, and at what cost?
- How can an environmental effect associated with the particular risk issue be detected or monitored?
- Is the environmental effect short-term, long-term, reversible, or permanent?

Risks associated with an ATES proposal can have legal as well as environmental implications. Therefore, for each category of risk presented here, it is expected that appropriate regulations will be cited and discussed.

INTERFERENCE WITH (OR BY) OTHER USERS

The following questions should be asked:

- Will variations in the water table or piezometric surface adversely affect the availability of ground water to nearby users?
- Will offsite migration of ground water affected chemically or thermally by the ATES system adversely affect the quality of ground water available to other users?
- Will the expected net withdrawal of ground water from the aquifer adversely affect the availability of the resource to other users?
- Are there legal barriers to the net withdrawal, re-injection, or other means of disposal of ground water? If so, can a waiver be obtained?

PHYSICAL AND CHEMICAL EFFECTS OF INJECTION OR WITHDRAWAL

- At the required rates of injection and withdrawal of water from the aquifer, is there a likelihood of adversely affecting the aquifer overburden through either overpressure or subsidence?
- Will re-injection of ground water, treated or untreated, legally constitute violation of ground-water quality standards or otherwise promote the spread of ground-water contamination? If so, can a waiver be obtained?
- Will operation of the ATEs system cause any permanent deleterious change in the quality of ground water with respect to its potential future uses in the vicinity of or downgradient from the ATEs installation?

CONCLUSIONS

By its nature, ATEs is an environmentally innocuous method for energy conservation. Therefore, a presumption of minimal environmental risk is justified, given a suitable aquifer, a reliable source of heat or chill, and a plant design of suitable scale. However, this presumption is rebuttable by regulatory authorities, and rebuttal will be based on the legal and environmental risk issues presented in the previous section.

It is likely that some real risks will have been identified. The intent of this section is to summarize those risks and to show that they are acceptable. (If unacceptable risks had been discovered during either aquifer characterization or the conduct of the feasibility study, there would be no point in asking for regulatory approval for the project.) For example, hydrologic modeling may have shown that the unusually shallow well of a nearby user will be effectively dewatered by drawdown when the ATEs plant is in its recovery cycle. This risk can be mitigated by deepening the well and is therefore acceptable. Similarly, if the risk of local ground-water quality degradation is real, a monitoring program may be appropriate.

Finally, risks should be weighed against benefits. This is not particularly difficult because both risks and benefits can be expressed in economic terms, as well as in terms of probability. Thus, it is the duty of the author of the statement of risk to show that the likelihood of economic success is high. The techniques used to quantify risk in economic terms are common to basic business investment analysis.

SUPPORTING INFORMATION

It is expected that the technical knowledge required to design the well field and plant, and to predict their united performance, will come from a combination of literature sources and field testing, and in some cases from experience gained from pilot operations or from similarly designed ATES systems at other locations. Therefore, this section should contain references and appendices whose purpose is to support aquifer characteristics, design presumptions, and the resolution of risk issues. The use of references should be restricted to the open technical literature, governmental regulations, and other readily available sources.

The appendixes will reflect the results of aquifer testing, the examination of ground water quality, well construction and design, engineering or water treatment calculations, and similar studies applied to the proposed ATES system. Analogous and appropriate studies originally prepared for other test sites may also be included.

DISTRIBUTION

No. of
Copies

No. of
Copies

OFFSITE

U.S. Department of Energy
ATTN: R. Eaton
Office of Energy Management
Forrestal Bldg, CE-142 5F-064
Washington, DC 20585

U.S. Department of Energy
ATTN: K. Klunder
Office of Energy Management
Forrestal Bldg, CE-142 5F-064
Washington, DC 20585

U.S. Department of Energy
ATTN: E. Reimers
Office of Energy Management
Forrestal Bldg, CE-142 5F-064
Washington, DC 20585

12 DOE/Office of Scientific and
Technical Information

New York State Energy
Research & Development
Agency
ATTN: G. Walmet
2 Rockefeller Plaza
Albany, NY 12223

McDonnell Douglas
ATTN: G. M. Morris
16055 Space Center Blvd
(MDCAIEF)
Houston, TX 77062

Oak Ridge National Laboratory
ATTN: J. Tomlinson
Building 9204-1, MS 8045
Y-12 Plant, Box 2009
Oak Ridge, TN 37831-8045

University of Alabama
ATTN: E. Brett
School of Mines and Energy
Development
Box 870164
Tuscaloosa, AL 35487-0164

University of Alabama
ATTN: C. Midkiff
Department of Mechanical Eng.
290 Hardaway Hall, Box 870276
Tuscaloosa, AL 35487-0276

University of Massachusetts
ATTN: J. E. Sunderland
Dept. of Mechanical Eng.
Eng. Laboratory Bldg.
Amherst, MA 01003

University of Minnesota
ATTN: R. Sterling/M. Hoyer
Underground Space Center
Dept. of Civil and Mineral Eng.
790 Civil and Mineral Eng. Bldg.
Minneapolis, MN 55455

U.S. Army CERL
ATTN: G. Cler
PO Box 9005
Champaign, IL 61826-9005

U.S. Department of Interior
ATTN: Natural Resources Library
Serials Branch (G/E)
Washington, DC 20240

D. A. Wilke
Architect/Engineer
38 Roosevelt Avenue
Glen Head, NY 11545

No. of
Copies

No. of
Copies

FOREIGN

BDg-Consult AB
ATTN: B. Dahlberg
Gunnvagen 4
S-18264 Djursholm
SWEDEN

F. Cruickshanks
3A Tulip St.
Dartmouth, Nova Scotia
CANADA B3A 2S3

2 Heidemij Adviesbureau
PO Box 264
6800 AG Arnhem
THE NETHERLANDS
ATTN: L.J.M. van Loon
K. van der Heide

Hickling Corporation
ATTN: V. Chant
350 Sparks Street
6th Floor
Ottawa, Ontario
CANADA K1R 7S8

3 I C C Ingenieurs Chimistes
Conseils S.A.
Av. Leopold-Robert 80
case postale 484
La Chaux-de-Fonds
SWITZERLAND CH 2301
ATTN: L. Jollien
F. Miserez
S. Remonnay

IF Technology
ATTN: A. Willemsen
Frombergstraat 1
6814 EA Arnhem
THE NETHERLANDS

LEVEL Energy Technology
ATTN: B. Veltkamp
Parterlaar 20
5 Gb, GD Sen
THE NETHERLANDS

NOVEM BV
ATTN: G. J. van Mourik
PO Box 8242
3503 RE Utrecht
THE NETHERLANDS

Public Works Canada
ATTN: E. Morofsky
Sir Charles Tupper Building
Ottawa, Ontario
CANADA K1A 0M2

Ryerson Polytechnical Institute
ATTN: M. A. Rosen
Dept. of Mechanical Engineering
350 Victoria Street
Toronto, Ontario
CANADA M5B 2K3

2 Strata Engineering Corporation
Suite 410, 170 The Donway west
Don Mills, Ontario
CANADA M3C 2G3
ATTN: C. Mirza
R. Cataford

Swedish Council for Building
Research
ATTN: B. Sellberg
Sankt Goransgatan 66
S-112 33 Stockholm
SWEDEN

2 Technical University of Denmark
Laboratory for Energetics
Building 403
DK-2800 Lyngby
DENMARK
ATTN: S. N. Sorenson
J. Reffstrup

University of Lund
ATTN: J. Claesson/G. Hellstrom
Department of Building Physics
Box 118
Lund, SWEDEN S-221 00

No. of
Copies

- 2 Universität Stuttgart
 Institut für Thermodynamik
 und Wärmetechnik
 PO Box 80 11 40
 Stuttgart 80
 Germany D-7000
 ATTN: E. Hahne
 M. Hornberger
- 3 Universität Stuttgart
 Institut für Siedlungswasserbau,
 Wassergute- und
 Abfallwirtschaft
 Abteilung Chemie
 Bandtale 2
 Stuttgart 80 (Busnau)
 GERMANY 7000
 ATTN: M. Koch
 W. Ruck
 M. Adinolfi
- University of Toronto
ATTN: F. C. Hooper
Dept. of Mechanical Engineering
Toronto, Ontario
CANADA M5S 1A4
- VBB VIAK AB
ATTN: O. Andersson
Geijersgatan 8
S-21618 Malmö
SWEDEN

No. of
Copies

ONSITE

- DOE Richland Field Office
- D. R. Segna, A5-90
- 69 Pacific Northwest Laboratory
- M. K. Drost, K5-19
L. E. Eary, K6-81
J. M. Gephart, K6-86
S. H. Hall, K6-96 (10)
E. A. Jenne, K6-81 (30)
L. D. Kannberg, K5-20 (15)
T. J. Marseille, K7-15
B. L. Mohler, K5-02
S. Somasundaram, K5-19
L. W. Vail, K6-77
Publishing Coordination
Technical Report Files (5)

Routing

- M. J. Graham, K6-78
R. M. Ecker, MSL/Sequim
P. M. Irving, K6-98
R. L. Skaggs, K6-77
C. S. Sloane, K6-04
P. C. Hays (last), K6-86

END

DATE
FILMED
3/9/93