

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

**Cover Sheet for a Hanford
Historical Document
Released for Public Availability**

Released 1994

**Prepared for the U.S. Department of Energy
under Contract DE-AC06-76RLO 1830**

**Pacific Northwest Laboratory
Operated for the U.S. Department of Energy
by Battelle Memorial Institute**



MASTER

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

- 1. EW Seckendorff
- 2. WI Patnode
- 3. OH Greager
- 4. WK MacCready
- 5. RH Beaton
- 6. SD Smiley
- 7. RC Grant
- 8. RB Richards
- 9. RE Smith
- 10. HH Hubble
- 11. JM Frame - LB
- 12. ~~JM Frame~~ *yellow*
- 13. D&C File
- 14. 700 File
- 15. JL Weeks

February 17, 1950

RECORD CENTER FILE

MEMORANDUM

TO: J. M. Frame

FROM: J. L. Weeks *JLW*

SUBJECT: RADIATION INTENSITY AT CENTER 42" RISER ON WASTE STORAGE TANK (MJ-4)

The following figures were obtained in the study of this problem:

Measurements in Chamber Well (7-5537)	Calculated Values No Shield 12" Concrete			
	1 1/2 yr	2 yr	1 1/2 yr	2 yr
25,600 mr/hr	12,000	6,000	50	25

This document consists of 2 Pages No. [redacted]

It is recommended that the actual intensity existing to-day above the liquid be measured before recommendations are made on cutting through the concrete seal.

A detailed statement of work on this problem follows. The calculations have been filed.


RECEIVED

In the study of the feasibility of cutting through the concrete seal on the center riser of the waste storage tank the radiation intensity that would be encountered is critical because direct operator contact would be required.

JUL 30 1956
300 AREA
CLASSIFIED FILES

The question of the radiation intensity to be expected was approached from two standpoints: (a) A study of previous measurements of sludge level and activities in the storage tanks (7-5537, HEW-7402, HW-7776, HW-10,154, HW-11,235), and (b) Direct calculation.

(a) Measurements reported in the above documents were obtained by lowering a special ionization chamber into a 4" chamber well on the storage tank. In a test on December 5, 1946 in the 241-T area on Tank 101-T an ionization chamber reading of 25,600 mr/hr was obtained when the chamber was just below the top of the tank and 7.25 ft. above the surface of the liquid. This reading is probably quite a bit lower than the actual intensity existing at this point due to the construction of the chamber.



CAUTION [redacted] -1-
[redacted] transmission of
[redacted] in any manner.

DECLASSIFIED MASTER

Classification Cancelled and Changed To

DECLASSIFIED

By Authority of RM & Gen
CG-NMP-1 6-21-94
By J.E. Sauchy 6-29-94
Verified By J. J. Malley 7-27-94

The chamber was constructed in the form of a cylinder whose overall dimensions were approximately 4" diameter by 6" length. The ends of the cylinder were shielded with approximately 1" of lead. The electrodes were metal discs about 1" diameter and separated by about 1/4". They were supported in the center of the cylinder. Thus the chamber was most sensitive to radiation entering at right angles to the axis of the cylinder.

(b) The calculations were based on the following assumptions:

1. Metal was irradiated to 200 MWD/ton.
2. Total metal in tank was 315 tons.
3. Average age was 2 years.
4. Ten percent of activity was contained in supernate.
5. Gamma radiation was due to Cs¹³⁷, Pr¹⁴⁴;Rh¹⁰⁶ only.
6. Distance from liquid level to receptor was taken as 16 feet.
7. Concrete seal on riser was assumed to be 12" thick.

On the basis of these assumptions the calculated value of the radiation intensity, with no shielding was 6000 mr/hr, and, with 12" of concrete shielding; 25 mr/hr:

The difference between the calculated value of the radiation intensity and the measurements obtained with the ionization chamber indicates that it would be hazardous to make recommendations on the basis of calculations based on the simplifying assumptions used. Rigorous analysis of the problem would be time-consuming; if not impossible. Several pertinent questions can not be answered at present. For example, what is the exact distribution in the tank of certain fission products?

It is recommended that a request be made for measurements of the radiation intensity in the air space above the liquid with a chamber that will measure the total radiation.

o

DECLASSIFIED