**ADDENDUM TO: A PROBABILISTIC METHOD FOR
DETERMINING EFFLUENT TEMPERATURE LIMITS FOR
FLOW INSTABILITY FOR SRS REACTORS**

by B. J. Hardy

Westinghouse Savannah River Company
Savannah River Site
Aiken, South Carolina 29808

WSRC-TM--90-005-Add. 1

DE93 004554

Other Authors:

This paper was prepared in connection with work done under Contract No. DE-AC09-89SR18035 with the U. S. Department of Energy. By acceptance of this paper, the publisher and/or recipient acknowledges the U. S. Government's right to retain a nonexclusive, royalty-free license in and to any copyright covering this paper, along with the right to reproduce and to authorize others to reproduce all or part of the copyrighted paper.

MASTER

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831; prices available from (615) 576-8401, FTS 626-8401.

Available to the public from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Rd., Springfield, VA 22161.

DOES NOT CONTAIN
UNCLASSIFIED CONTROLLED
NUCLEAR INFORMATION

Reviewing
Official:

Joseph A. Langston
(Name and Title) *Engineer*

Date:

09/13/91

WSRC-TM-90-5
(DPSTM-160)
ADDENDUM 1

NRTSC

NUCLEAR REACTOR TECHNOLOGY
AND SCIENTIFIC COMPUTATIONS

KEYWORDS: LOCA LIMITS
FLOWTRAN
FLOW INSTABILITY
K-14.1 LIMITS

RETENTION: PERMANENT

ADDENDUM TO
A PROBABILISTIC METHOD FOR DETERMINING EFFLUENT TEMPERATURE
LIMITS FOR FLOW INSTABILITY FOR SRS REACTORS (U)

by

B. J. HARDY

WITH CONTRIBUTIONS BY:

J. E. LAURINAT

ISSUED: FEBRUARY, 1991

J. P. Faraci
J. P. Faraci, Authorized Derivative Classifier

2/21/91
Date

SRL

SAVANNAH RIVER LABORATORY, AIKEN, SC 29808
Westinghouse Savannah River Company
Prepared for the U. S. Department of Energy under
Contract DE-AC09-88SR18035

DISTRIBUTION STATEMENT IS UNLIMITED

WSRC-TM-90-5
(DPSTM-160)
ADDENDUM 1

ADDENDUM TO:
A PROBABILISTIC METHOD FOR DETERMINING EFFLUENT
TEMPERATURE LIMITS FOR FLOW INSTABILITY IN SRS
REACTORS (U)

FEBRUARY, 1991

Westinghouse Savannah River Company
Savannah River Laboratory
Aiken, SC 29829

Prepared for the U.S. Department of Energy
Under Contract DE-AC09-87SR18035

PROJECT:

DOCUMENT: WSRC-TM-90-5 (DPSTM-160) ADDENDUM 1

TITLE: ADDENDUM TO: A PROBABILISTIC METHOD FOR
DETERMINING EFFLUENT TEMPERATURE LIMITS FOR FLOW
INSTABILITY IN SRS REACTORS (U)

QA TASK NUMBER: 88-024-1

REVISION NUMBER: 2

APPROVALS

N. M. ASKEW, TECHNICAL REVIEWER

2-21-91

DATE

J. D. MENNA, RESEARCH SUPERVISOR

2-21-91

DATE

A. J. GARRETT, RESEARCH MANAGER

2/22/91

DATE

Table of Contents

1 INTRODUCTION.....	1
2 SUMMARY.....	1
3 BACKGROUND.....	3
4 CODE REVISIONS.....	5
4.1 Modifications to POWCOMB.....	5
4.1.2 Input to POWCOMB3.....	7
4.2 Modifications to CINT.....	8
4.3 Modifications to INTERP.....	9
4.4 Modifications to UNCERT.....	9
5 UNCERTAINTY PARAMETERS.....	10
5.1 Plenum Pressure Variation Over Time.....	10
5.2 Standard Deviations and Means/Biases of Uncertainty Parameters.....	15
5.2.1 Steady State Plenum Pressure Gradient.....	15
5.2.2 Inner Fuel Tube Power Fraction.....	15
5.2.3 Assembly Inlet Temperature.....	16
5.2.4 Steady State Centerline Plenum Pressure.....	16
5.2.5 Effluent Temperature Measurement.....	17
5.2.6 Asymmetric Effects Multiplier.....	17
5.2.7 Other Parameters Described by Distributions.....	18
5.2.8 Summary of Standard Deviations and Means/Biases.....	18
5.3 Uncertainty Parameters Not Treated With Distributions.....	18
5.3.1 The Heated Wall and Void Effects Multiplier $\beta_{hw}\beta_{void}$	18
5.3.2 Axial Power Shape.....	19
5.3.3 Fission Power Transient.....	19
5.3.4 OSV Limits Criterion.....	20
6 UNCERTAINTY CALCULATIONS.....	20
6.1 Sensitivity Coefficients.....	20
6.2 The Value of $\sigma_{T_{cr\ eff}}$	21
6.3 Calculating the Values of N_i	22
6.4 Flowzone Effluent Temperature Limits.....	25
REFERENCES.....	29
APPENDICES.....	33
A.1 Derivation of the Equations for the Sensitivity Coefficients.....	33
A.2 Specific form of the Equation for $\sigma_{T_{cr}}$	38
A.3 Use of $(\Delta T_{ideal\ k_i})_{nominal}$ in CINT2.....	40
A.4 The Expression for $\langle T_{cr\ min\ i} \rangle$	43

List of Tables

Table 2.1	Approximate Impact of Significant Changes Made to LOCA-FI Uncertainty Calculations.....	3
Table 5.1	Standard Deviations and Means/Biases for Significant Parameter Uncertainties.....	19
Table 6.1	Sensitivity Coefficients Which Give $\sigma_{T_{\text{cr eff}}}$ for the K14.1 Charge	21
Table 6.2	Values of $\sigma_{T_{\text{cr eff}}}$ for the K14.1 Charge	22
Table 6.3	Values of N_i	24
Table 6.4	Values of $(T_{\text{ideal min } i})_{\text{nominal}}$ (in °C) for the K14.1 Charge	26
Table 6.5	Flowzone Effluent Temperature Limits, $T_{\text{lim } i}$ (in °C) for the K14.1 Charge	27
Table 6.6	Fit of $T_{\text{lim } i}$ to $T_{\text{in } 0}$	27
Table 6.7	Estimated Core Powers Based on the Assembly Effluent Temperature Limits.....	28

List of Figures

Figure 5.1	Centerline plenum pressure vs exposure	12
Figure 5.2	Schematic representation of the shift in supply and demand curve intersection with increasing assembly losses.....	13
Figure 5.3	TRAC center ring average pressure as a function of change of the base case loss coefficient δk	14

1 INTRODUCTION

Previous values used for the uncertainties in the K14.1 limits calculations were based on the best available data at that time. Some of the data was in preliminary form and many assumptions were made. In addition, not all of the calculations made with the previous data were well documented. Because of an increase in both the volume and quality of data, and to verify calculations, revisions to the values for the uncertainties were appropriate. The revised uncertainty values include updated information which is more accurate and has a high level of quality assurance. The previously developed methodology for the uncertainty analysis¹ was used in the current calculations.

This document provides a complete description of the changes to the uncertainty analysis calculations made since closure. A number of the uncertainties for the K14.1 charge were re-calculated to improve accuracy, to reflect updates in the values of significant uncertainty parameters¹, and to provide complete documentation of bases for these parameters. In this addendum, the uncertainty calculations are described in greater detail than in Reference 1.

2 SUMMARY

The changes made to the uncertainty analysis calculations are as follows:

1. An increase in the plenum pressure was observed for the K13 cycle. The change in plenum pressure was attributed to oxide formation in the assembly flow channels. In order to account for the observed increase in plenum pressure, the assembly entrance loss coefficients were uniformly increased. The codes POWCOMB, INTERP and CINT were modified to improve their modelling accuracy and to accommodate new parameter ranges¹.
2. Modifications were made to the versions of UNCERT to enhance the ability of the codes to calculate values used in the uncertainty calculations².
3. A revision to the reactivity coefficients necessitated the re-calculation of the LOCA fission power transient.

4. A bias on the assembly effluent temperature was used to account for a gradient observed across the isothermal box. Other effluent temperature measurement data was used to re-calculate the variance in the effluent temperature measurement.
5. The fuel distribution model for the K14.1 charge fuel tube power split was checked against as-manufactured data to confirm the validity of assumptions made in the model.
6. The new limits were calculated for a range of inlet temperatures from 10 to 40°C, rather than the previous range from 20 to 40°C.
7. Finally, the standard deviations of other significant uncertainty parameters, as well as other values used in the uncertainty analysis, were re-calculated with current information.

The updated values of the uncertainties will be used in the actual limits calculations for reactor restart. The methodology used to apply these uncertainties to the calculation of effluent temperature limits remains unchanged from that described in detail in Reference 1. The linear statistical model for the critical effluent temperature, shown to be valid in Reference 1, was used to calculate the mean and standard deviation of the critical effluent temperature. The flowzone based effluent temperature limits calculated for restart are reduced by about 3% from the estimate of 53% of historical power given in Reference 1. A list of changes having the most significant effect on the value of the limits, together with rough estimates of their respective impacts, is given in Table 2.1.

The FI-LOCA limits presented in this document are not final restart limits. Studies are currently underway to address the possible impacts of separate effects such as loss of negative pulse and alternative break locations. In addition, imbedded conservatisms are being identified to refine margins and to improve accuracy.

Table 2.1

**Approximate Impact of Significant Changes
Made to FI-LOCA Uncertainty Calculations**

<u>Item</u>	<u>Effect on Limit*</u>
Historical Plenum Pressure Increase	-1.5%
New Reactivity Coefficients	-0.7%
Assembly Effluent Temperature Bias	-1.3%
New Inlet Temperature Bias	-0.5%
Refinements to Uncertainty Analysis	<u>+1.0%</u>
Net Change	-3%

* Percent of historical power

3 BACKGROUND

The effluent temperature limit, given by the uncertainty analysis, was of the form¹:

$$T_{\text{lim } i} = \langle T_{\text{in}} + \beta \Delta T_{\text{ideal min } i} \rangle - N_i \sigma_{T_{\text{cr eff}}} \quad i = 1, \dots, 4 \quad 3.1$$

where: $\langle \rangle$ denotes a mean.

$T_{\text{lim } i}$ = The maximum assembly effluent temperature for flowzone i, also referred to as the flowzone i effluent temperature limit.

T_{in} = Assembly inlet temperature.

$\beta = \beta_{3D} \beta_{\text{hw}} \beta_{\text{void}}$ = The non-ideal effects multiplier.

β_{3D} = The asymmetric effects multiplier.

β_{hw} = The heated wall effects multiplier.

β_{void} = The void effects multiplier.

$\Delta T_{\text{ideal min } i}$ = The minimum limiting temperature rise across an idealized (no asymmetric, void or heated wall effects) assembly in flowzone i.

N_i = The required number of effective, single assembly standard deviations that the limiting mean assembly effluent temperature for flowzone i must be reduced to give an effluent temperature limit which satisfies the assumed flowzone fraction of the corewide no-failure probability.

$\sigma_{T_{\text{cr eff}}}$ = The maximum standard deviation of the critical effluent temperature limit for any assembly in the core, at mean inlet temperature of $\langle T_{\text{in}} \rangle$. This standard deviation was applied to every assembly in the core and was therefore the effective standard deviation for the assemblies.

In this document, the critical effluent temperature limit, T_{cr} , is an assembly effluent temperature limit for a given set of assembly boundary conditions. The term "assembly boundary condition" was used generally and means not only pressure, temperature, etc. boundary conditions on an assembly, but also manufacturing tolerances, geometrical distortions, system effects, etc.

The details of the physical interpretation of the parameters used in Equation 3.1 is given later in this document and in Reference 1.

The assembly inlet temperature undergoes seasonal variation with river water temperature. Therefore, $T_{\text{lim } i}$ was calculated at various assembly inlet temperatures and a curve fit was made for $T_{\text{lim } i}$ vs inlet temperature.

The value of $\sigma_{T_{\text{cr eff}}}$ was given by¹:

$$\sigma_{T_{\text{cr eff}}} = \sqrt{\sum_i (a_i \sigma_i)^2 + \sum_{i \neq j} a_i a_j \sigma_i \sigma_j r_{ij}} \quad 3.2$$

where: a_i = The sensitivity coefficient for the i^{th} uncertainty parameter.

$$= \frac{\partial T_{\text{lim } i}}{\partial x_i}$$

x_i = The i^{th} uncertainty parameter.

σ_i = The standard deviation of the i^{th} uncertainty parameter.

r_{ij} = The correlation coefficient between the i^{th} and j^{th} uncertainty parameter

The goal of the uncertainty analysis was to calculate $T_{\text{lim } i}$. In order to accomplish this, the values of a_i , σ_i , N_i , β and $\Delta T_{\text{ideal min } i}$ had to be calculated. Additionally, bounding values had to be determined for parameters which were difficult to characterize statistically

4 CODE REVISIONS

Revisions were made to the codes POWCOMB, CINT, INTERP and UNCERT which were used in the uncertainty analysis. A discussion of these revisions is presented in Section 4.

4.1 Modifications to POWCOMB

Modifications were made to the POWCOMB¹ code which was used to calculate the asymmetric effects multiplier, β_{3D} . The POWCOMB code and the β_{3D} calculations are briefly described in Section 4.1. A more detailed description of POWCOMB is given in Reference 1. The new version of POWCOMB is called POWCOMB version 3 or POWCOMB3. The changes made to POWCOMB include changes to the fit of the azimuthal fuel distribution and the flux tilt influence factors. Further, the structure of the POWCOMB was changed to improve computational efficiency.

Webb³ obtained fuel and lithium distribution influence factors as discrete values over 30° sectors. In POWCOMB, Webb's values of the fuel distribution influence factors were fit to a sine function so that they could be interpolated for 1° sectors¹. The fit of the influence

factors to Webb's values was improved in POWCOMB3 by using a Fourier cosine series, Reference 4.

The influence factors for the angular orientation of the maximum thickness of the fuel and lithium in the inner and outer tubes to the flux tilt in POWCOMB were of the form:

$$P_b^a(\theta) = 1 + A_b^a \sin(\theta) , \quad 4.1$$

where: $P_b^a(\theta)$ = The influence factor for azimuthal variation in fuel/lithium thickness in fuel/target tube b on the sector to sector average power ratio in tube a over a 1° sector about the angle θ in tube a.

$$A_b^a = \text{A fitting factor for } P_b^a(\theta)$$

In POWCOMB3 a Fourier cosine fit was used for the azimuthal fuel distribution influence factor. The first twelve terms of the Fourier cosine expansion for the azimuthal fuel distribution influence factors were given by ⁴:

$$P_b^a(\theta) = a_0 + \sum_{n=1}^{12} a_n \cos(n\theta) \quad 4.2$$

The terms a_n are the Fourier cosine coefficients, which were found⁴ to be:

$$a_0 = 1.0 \quad 4.3$$

$$a_n = \frac{1}{\pi} \sum_{i=1}^{12} P_b^a(\theta_i) \int_{\theta_i - \pi/12}^{\theta_i + \pi/12} \cos(n\theta) d\theta \quad 4.4$$

where: $\theta_i = 30i - 15$ $i = 1, \dots, 12$

The Fourier cosine expansion of Equation 4.2 was found to be sufficiently converged after six terms that only the first six terms were used in POWCOMB3.

The flux tilt influence factors of Webb³, which were originally treated as discrete values over 30° sectors in POWCOMB, were fit to a cubic spline in POWCOMB3⁴. The spline fit was used to obtain values for the flux tilt influence factors over 1° sectors.

Finally, in POWCOMB3 the structure of POWCOMB was modified to circumvent the unnecessary recalculation of parameters used to simulate the distribution of β_{3D} ⁴.

4.1.2 Input to POWCOMB3

The three dimensional effects multiplier, β_{3D} was defined as:

$$\beta_{3D} \equiv \frac{\Delta T_{\text{asymmetric}}}{\Delta T_{\text{axisymmetric}}} \quad 4.5$$

where: $\Delta T_{\text{asymmetric}}$ = The limiting temperature rise across an assembly which contains asymmetries.

$\Delta T_{\text{axisymmetric}}$ = The limiting temperature rise across an idealized axisymmetric assembly.

Equation 4.5 was used to calculate values for β_{3D} by using the values of $\Delta T_{\text{asymmetric}}$ and $\Delta T_{\text{axisymmetric}}$ output by UNCERT v16-5. Specifically, the polynomial fit for β_{3D} was calculated by using twelve random azimuthal power distributions and an axisymmetric power distribution in UNCERT v16-5 to obtain twelve values for β_{3D} . A least squares technique was used to obtain a quadratic polynomial fit for these values of β_{3D} to the corresponding values of the maximum to average sector power ratio in the outer fuel tube. The quadratic fit for β_{3D} was made to the maximum to average sector power ratio in the outer fuel tube because, under nominal conditions, the OSV limit is reached on the outer surface of the outer fuel tube. The calculated values of β_{3D} were scattered about the curve obtained from the quadratic fit. It was assumed that the differences between the actual values of β_{3D} and the quadratic fit had a normal distribution. The scatter of β_{3D} about the quadratic fit was accounted for by adding error terms, which were randomly selected from the distribution of differences, to the value of β_{3D} obtained from the quadratic fit. The

standard deviation of the distribution of the values of β_{3D} about the polynomial fit was input to POWCOMB3. The details of these calculations are given in Reference 5.

The polynomial fit for β_{3D} was⁵:

$$\beta_{3D} = 3.1101 - 3.6305*pf + 1.3929*pf^2 \quad 4.6$$

The polynomial coefficients in Equation 4.6 were input to POWCOMB3 as the data values a1coef, a2coef, a3coef.

The standard deviation of the distribution of values of β_{3D} about the polynomial given in Equation 4.6 was 0.01215⁵. This value is used for the variable "par" in subroutine CONFIG of POWCOMB3.

The value of the multiplier used to represent heat flux peaking due to the rib effect is 0.2124¹ and is used for the variable "par2" in subroutine CONFIG of POWCOMB3.

4.2 Modifications to CINT

The CINT⁶ code was used to calculate the value N_i in Equation 3.1. CINT produced tables for N_i in which values of $\sigma_{T_{cr\ eff}}$ ranged from 2.5 to 4.0 by intervals of 0.25. It was found that the new values for the uncertainty parameters yielded values of $\sigma_{T_{cr\ eff}}$ which were greater than 4.0. Modifications were made to CINT to accommodate this range of standard deviations. The modified version of CINT was called CINT2⁷.

The modifications made to CINT, to create CINT2, were as follows:

1. The range of $\sigma_{T_{cr\ eff}}$ was expanded from an interval from 2.5 to 4.0 by steps of 0.25 to an interval from 1.5 to 4.5 by steps of 0.5.
2. The range of β was expanded from an interval from 0.75 to 0.85 by steps of 0.01 to an interval from 0.71 to 0.95 by steps of 0.01.

3. The range of N_i was changed from an interval from 2.0 to 4.0 by steps of 0.1 to an interval from 1.5 to 3.5 by steps of 0.1.

4.3 Modifications to INTERP

INTERP⁸ was written to interpolate on the tables for N_i output by CINT. INTERP2 was a modification of INTERP which interpolated on the tables for N_i output by CINT2⁷.

The modifications made to INTERP, to create INTERP2, were as follows:

1. The step size used to interpolate with respect to β was changed from 0.25 to 0.5.
2. The form of the interpolating equations were changed.
3. Constraints were applied to prevent attempts at extrapolation to values off of the CINT2 tables.

4.4 Modifications to UNCERT

The UNCERT code versions used in the current limits calculations were:

1. UNCERT v16-2A for the calculation of the sensitivity coefficients.
2. UNCERT v16-2B for the calculation of the value of the heated wall and void effects multiplier.
3. UNCERT v16-5 for the calculation of the asymmetric effects multiplier.

These codes were modifications of UNCERT Versions 16-1 and 16-1B and FLOWTRAN Version 16-2¹. A description of the modifications to these codes was given in Reference 2 and its references.

5 UNCERTAINTY PARAMETERS

5.1 Plenum Pressure Variation Over Time

From FDAP data for the K13 charge⁹, a range of plenum centerline pressures from 63.8 to 66.0 psig was observed for reactor powers between 1100 and 1300 Mw. This range of reactor powers was selected because it contained the anticipated operating power limit. The pressure data was tabulated for exposures greater than 12465 MwD for all power levels and for exposures greater than 74964 MwD in the 1100 to 1300 Mw power range. Therefore, it was assumed that the base case centerline pressure of 62.66 psig given by TRAC calculations with base case loss factors¹⁰, was representative of 0 MwD exposure.

From the data plotted in Figure 5.1 it can be seen that the centerline plenum pressure tends to increase with exposure. The increase in the plenum pressure with exposure has been primarily attributed to oxide formation^{10,11,12,13}. Oxide formation results in increased surface roughness, and thus, increased frictional losses in the assemblies. As the assembly losses increase, the demand curve for the core is translated upwards, as shown schematically in Figure 5.2. At higher core frictional losses the point of intersection of the supply and demand curves occurs at an increased plenum pressure and reduced core flow. In order to quantify the effect of increased assembly losses on plenum pressure and assembly flow, the entrance loss coefficients for all assemblies in the core were uniformly increased in the TRAC code¹⁰. The TRAC center ring average plenum pressure, which was used to approximate the plenum centerline pressure, was expressed as a function of the change in the assembly entrance loss coefficient, see Figure 5.3.

From the TRAC output it was found that the relation between the center ring average pressure and the change in the assembly entrance loss coefficient was very nearly linear. The relation was approximated by:

$$P = 77.363 + 0.42666\delta k \quad 5.1$$

where: P = TRAC center ring average pressure in psia.

δk = The change in the base case assembly entrance loss coefficient.

The relation between P and δk is shown graphically in Figure 5.3.

From the RDAP data, the high and low plenum pressures were found to be 63.8 psig and 66.0 psig, respectively. Converting these pressures to psia gave:

$$63.8 + 14.7 = 78.5 \text{ psia} \Rightarrow 78.0 \text{ psia}$$

$$66.0 + 14.7 = 80.7 \text{ psia} \Rightarrow 81.0 \text{ psia}$$

Solving Equation 5.1 for δk gave:

$$\delta k = 2.3438P - 181.3224 \quad 5.2$$

Therefore, the values of δk corresponding to 78.0 psia and 81.0 psia are 1.4940 and 8.5254 respectively.

The assembly entrance loss coefficients in TRAC were adjusted by 1.4940 and 8.5254 to obtain transient plenum and tank bottom pressure transients corresponding to the range of observed steady state plenum pressures. These pressure transients were input to FLOWTRAN v16-2 with corresponding assembly entrance loss coefficients and steady state plenum pressures¹⁴. The results showed that the higher value of δk resulted in lower effluent temperature limits. For additional conservatism a value of $\delta k = 11.1$ was used. From Equation 5.2, the steady state plenum pressure for $\delta k = 11.1$ is about 82 psia. When $\delta k = 11.1$ was used in the TRAC code, a center ring average steady state plenum pressure of 82.1744 psia was obtained. The loss coefficients and the steady state and transient plenum pressures corresponding to $\delta k = 11.1$ were used in the sensitivity coefficient calculations made with UNCERT v16-2A, the β_{3D} calculations made with UNCERT v16-5 and the limiting flowzone effluent temperature limit calculations made with FLOWTRAN v16-2. In addition, the value $\delta k = 11.1$ was used in the calculations of the effluent temperature limits which were input to the CINT2⁷ code for corewide interpolation of assembly effluent temperatures.

RDAP Data for Plenum Centerline Pressure vs Exposure
(Rx Power Between 1100 & 1300 Mw)

Figure 5.1
Centerline plenum pressure vs exposure.

Figure 5.2
Schematic representation of the shift in supply and demand curve intersection with increasing assembly losses.

TRAC Center Ring Average Plenum Pressure (in psia) vs δk

Figure 5.3
TRAC center ring average pressure as a function of change of the base case
loss coefficient δk .

5.2 Standard Deviations and Means/Biases of Uncertainty Parameters

In the uncertainty analysis, the random variation of some uncertainty parameters was described with distributions, while the random variation in other uncertainty parameters was so complex that they were treated by using a conservative bound. In Section 5.2 a brief discussion is presented on the current values of the standard deviations and the means/biases for significant uncertainty parameters whose uncertainties were represented by distributions.

5.2.1 Steady State Plenum Pressure Gradient

The original calculations of the uncertainties in the steady state plenum pressure gradient were not well documented. Therefore, to meet quality assurance standards, the calculation of the gradient uncertainties was repeated. The derivation of the plenum pressure gradient uncertainties was described in detail in References 15 and 16. The new values of the plenum pressure gradient uncertainties were obtained from data in Reference 17. The uncertainties include errors in the TRAC correction from a Mark 16-31 to a Mark 22 assembly, errors in pressure measurement, and errors in correcting for different core flowrates between L reactor tests I and C. The values of the steady state plenum pressure gradient obtained from these calculations were:

	Flowzone 1	Flowzone 2	Flowzone 3	Flowzone 4
σ	0.99 psi	1.60 psi	2.38 psi	3.45 psi

The distribution for the steady state plenum pressure gradient was assumed to be normal.

5.2.2 Inner Fuel Tube Power Fraction

The standard deviation of the inner fuel tube power fraction was calculated by a Monte-Carlo technique which utilized a regression fit between the tube power fractions and the U^{235} content of the fuel tubes and the Li^6 content of the target tubes. The details of this calculation are described in Reference 18. The standard deviation of the inner fuel tube power fraction was found to be 0.016, the value used for the mean of the inner fuel tube power fraction was 0.37824. Because of the way the sensitivity coefficient for the inner fuel tube power fraction was derived, a value of 1.6%, rather than 0.016 was used for the standard deviation of the inner fuel tube power fraction. The distribution for the inner fuel tube power fraction was assumed to be normal.

5.2.3 Assembly Inlet Temperature

At present a detailed model for plenum mixing does not exist. However, available temperature data¹⁹ indicates that plenum mixing is incomplete and is better approximated by the assumption of no mixing than by the assumption of complete mixing. The control computer uses the minimum plenum inlet line D₂O temperature as a measure of the assembly inlet temperature. The minimum plenum inlet line temperature, read by the control computer, is an average obtained from two RTDs' located at each of the heat exchanger exits²⁰ for the inlet line. It was therefore necessary to statistically relate the average minimum inlet line temperature, read by the RTDs', to the actual average plenum temperature. This was accomplished by treating the relation between the minimum measured inlet temperature and the actual inlet temperature as a bias for a given assembly as a bias²¹. The mean actual assembly inlet temperature is obtained by adding the mean of the bias to the minimum average measured inlet line temperature. The uncertainty in the assembly inlet temperature arises from the corewide variation of assembly inlet temperatures about the mean assembly inlet temperature²¹. The mean of the bias on the assembly inlet temperature was 0.648°C and the standard deviation of the assembly inlet temperature was 0.96°C.

5.2.4 Steady State Centerline Plenum Pressure

The uncertainty in the steady state centerline plenum pressure was estimated from the range of pressures observed for the K13 charge and from the plenum pressure measurement errors. The range of steady state plenum pressures lies between the base case TRAC plenum pressure ($\delta k = 0.0$)¹⁰ and the maximum plenum pressure observed for the K13 cycle within the anticipated 1100 to 1300 Mw power range²². The steady state centerline plenum pressure for the base case ($\delta k = 0.0$) was 62.66 psig, while the maximum steady state centerline plenum pressure from the RDAP data was 66.0 psig. Because definitive estimates for plenum pressure measurement uncertainty were unavailable when Reference 22 was issued, the range of plenum pressures from 62.66 to 66.0 psig was interpreted as two standard deviations of the measured plenum pressure. From this interpretation, the value for the standard deviation of the steady state centerline plenum pressure was found to be $\frac{3.34 \text{ psi}}{2}$ or 1.67 psi.

More recently a value of 1.0 psi was proposed for the standard deviation of the plenum pressure measurement²³. Knowing the uncertainty for the plenum pressure measurement would allow a reduction in the conservatism used in the interpretation of the standard deviation of the actual steady state centerline plenum pressure range. The 3.34 psi range of observed plenum pressure would then be interpreted to represent three standard deviations. Therefore, the standard deviation of the measured steady state centerline plenum pressure would be 1.11 psi. Combining the standard deviations for the measured range of steady state plenum pressure and the measurement error as root-sum-squares would give the standard deviation of the steady state centerline plenum pressure, σ_{pp} . That is:

$$\sigma_{pp} = \sqrt{1.11^2 + 1.0^2} = 1.50 \text{ psi.}$$

At the time the calculations were performed the uncertainty in the plenum pressure measurement had not been calculated. Therefore, the value of 1.67 psi, rather than 1.50 psi, was used as the standard deviation of the steady state centerline plenum pressure. The distribution of the uncertainty in the plenum pressure was assumed to be normal.

5.2.5 Effluent Temperature Measurement

The uncertainty in the effluent temperature measurement was obtained from an analysis of the uncertainties in the instrument channel from the monitor pin thermocouples to the control computer. A detailed description of the derivation of the effluent temperature measurement uncertainties was given in Reference 24. The bias on the effluent temperature measurement was found to be 0.8°C and was obtained from a conservative treatment of the isothermal box gradient. The standard deviation of the effluent temperature measurement was found to be approximately 0.88°C.

5.2.6 Asymmetric Effects Multiplier

The Monte-Carlo Calculations made with POWCOMB3, described in section 4.1, gave the mean and standard deviation of the asymmetric (or 3D) effects multiplier, β_{3D} . The mean value of β_{3D} was found to be 0.77571, while its standard deviation was found to be 0.024637⁵.

5.2.7 Other Parameters Described by Distributions

The standard deviations of other significant parameters, with uncertainties represented by distributions, remained the same as in Reference 1. Specifically, the parameters with unchanged standard deviations are: the transient plenum pressure, the transient tank bottom pressure, the heated length of the assemblies, the forced convective heat transfer coefficient and the subcooled boiling heat transfer coefficient.

5.2.8 Summary of Standard Deviations and Means/Biases

Table 5.1 summarizes standard deviations and means/biases for the uncertainties in the parameters discussed in section 5.2.

5.3 Uncertainty Parameters Not Treated With Distributions

In Section 5.3 a brief discussion is presented on the current values used for uncertainty parameters which were not described by distributions.

5.3.1 The Heated Wall and Void Effects Multiplier $\beta_{hw}\beta_{void}$

A single multiplier which accounts for the heated wall and void effect was calculated²⁴. This multiplier, written as $\beta_{hw}\beta_{void}$, was defined as:

$$\beta_{hw}\beta_{void} \equiv \frac{\Delta T_{hw\&void}}{\Delta T_{nom}} \quad 5.3$$

where: $\Delta T_{hw\&void}$ = The limiting temperature rise across an assembly, including the heated wall and void effects.

ΔT_{nom} = The limiting temperature rise across an assembly, not including the heated wall and void effects.

Values for $\Delta T_{hw\&void}$ were calculated with UNCERT v16-2B, while the value for ΔT_{nom} was calculated using UNCERT v16-2A²⁵. The value obtained for $\beta_{hw}\beta_{void}$ ²⁶ was found to be 0.98317.

Table 5.1

Standard Deviations and Means/Biases for
Significant Parameter Uncertainties

Parameter	Standard Deviation	Mean/Bias
Transient Plenum Pressure	2.5 psi	0.0 psi
3D Effects Multiplier	0.024637	0.77571
Transient Tank Bottom Pressure	1.00 psi	0.0 psi
Steady State Plenum Pressure Gradient FZ 1	0.99 psi	0.0 psi
FZ 2	1.60 psi	0.0 psi
FZ 3	2.38 psi	0.0 psi
FZ 4	3.45 psi	0.0 psi
Inner Fuel Tube Power Fraction	1.6%	0.37824
Assembly Inlet Temperature	0.96°C	0.648°C
Steady State CL Plenum Pressure	1.67 psi	0.0 psi
Effluent Temperature Measurement	0.83°C	- 0.8°C
Heated Fuel Length	3.00 in	150.0 in
Forced Convective Heat Transfer Coeff	15.0%	0.0%
Subcooled Boiling Heat Transfer Coeff	44.0%	-20.0%

5.3.2 Axial Power Shape

The axial power shape, input to UNCERT and FLOWTRAN in the current uncertainty analysis calculations, was the same as that which was used in previous calculations.

5.3.3 Fission Power Transient

Updated parameter values were used in the current AA3 and LLAP calculations for the fission power transient. A list of these parameters is given in Reference 27. The fission power transient was input to UNCERT and FLOWTRAN.

5.3.4 OSV Limits Criterion

The limiting criterion used for the Onset of Significant Voiding (OSV) was 70% of the minimum Saha-Zuber Stanton number. This criterion was also used in the previous limits calculations¹. The OSV limits criterion was used in the UNCERT and FLOWTRAN calculations.

6 UNCERTAINTY CALCULATIONS

6.1 Sensitivity Coefficients

The sensitivity coefficient for a given uncertainty parameter was the derivative of the critical effluent temperature with respect to that parameter, evaluated at nominal values for the parameters. The full derivation of the formulas used to calculate the sensitivity coefficients is given in Appendix A.1.

The sensitivity coefficients were used in Equation 3.2 to calculate the maximum standard deviation of the critical effluent temperature for any assembly in the core, $\sigma_{T_{cr eff}}$. The sensitivity coefficients vary with the mean assembly inlet coolant temperature, $\langle T_{in} \rangle$.

Because limits must be obtained for a range of inlet temperatures from 10 to 40°C, a set of sensitivity coefficients was calculated for values of T_{in0} at 10, 20, 30 and 40°C.

The sensitivity coefficients were calculated by using formulas A.1.2 - A.1.11 with a value of β_0 given by:

$$\beta_0 = \langle \beta \rangle = \langle \beta_{3D} \rangle \times \beta_{hw} \beta_{void} = 0.76266 \quad 5.4$$

The values of $\langle \beta_{3D} \rangle$ and $\beta_{hw} \beta_{void}$ were obtained from sections 5.2.6 and 5.3.1, respectively.

The sensitivity coefficients also vary with assembly location. A scoping study was performed to identify the location which gave the most conservative sensitivity coefficients²⁸. Sensitivity coefficients are more conservative if, when substituted into Equation 3.2 together with their corresponding uncertainty parameter standard deviations,

they give a greater value for the standard deviation for the critical effluent temperature, $\sigma_{T_{cr}}$. It was found that the greatest standard deviation for $\sigma_{T_{cr}}$, namely $\sigma_{T_{cr eff}}$, was obtained for an assembly in flowzone 4 (28 shell holes) in TRAC cell 18 which had a steady state plenum pressure of 84.2797 psia²⁸. Therefore, the effluent temperature limits used in the derivation of the sensitivity coefficients were calculated with UNCERT v16-2A for these assembly parameters²⁹. The actual sensitivity coefficients were calculated with an Excel spreadsheet which was programmed with formulas A.1.1 - A.1.11 for the sensitivity coefficients³⁰. The values for the sensitivity coefficients are given in Table 6.1.

Table 6.1

Sensitivity Coefficients Which Give $\sigma_{T_{cr eff}}$ for the K14.1 Charge

Parameter	$T_{in0} = 10^{\circ}\text{C}$	$T_{in0} = 20^{\circ}\text{C}$	$T_{in0} = 30^{\circ}\text{C}$	$T_{in0} = 40^{\circ}\text{C}$
Trans Plen Press	0.8785°C/psi	0.8233°C/psi	0.7730°C/psi	0.7154°C/psi
Trans Tank Bottom Press	-0.4175°C/psi	-0.3652°C/psi	-0.3067°C/psi	-0.25922°C/psi
Steady State Plen Press	-0.4679°C/psi	-0.4304°C/psi	-0.3917°C/psi	-0.3538°C/psi
Plen Press Gradient	-0.4679°C/psi	-0.4304°C/psi	-0.3917°C/psi	-0.3538°C/psi
Inlet Temperature	0.4744°C/°C	0.4882°C/°C	0.4900°C/°C	0.4873°C/°C
Inner Fuel Tube Power Fract	0.8797°C/%	0.8124°C/%	0.7221°C/%	0.6458°C/%
Heated Length	0.1202°C/in	0.0993°C/in	0.0947°C/in	0.0895°C/in
Forced Conv HT Coeff	0.0171°C/%	0.0171°C/%	0.0153°C/%	0.0141°C/%
Subcooled Boiling HT Coeff	-0.0036°C/%	-0.0031°C/%	-0.0030°C/%	-0.0028°C/%
β_{3D}	80.0136	73.4103	66.8076	60.2092
Effluent Temp Meas Error	1.00°C/°C	1.00°C/°C	1.00°C/°C	1.00°C/°C

6.2 The Value of $\sigma_{T_{cr eff}}$

The value of $\sigma_{T_{cr eff}}$ was calculated with the standard deviations in Table 5.1 and the sensitivity coefficients in Table 6.1. The specific form of Equation 3.1 used to calculate $\sigma_{T_{cr eff}}$ is given by Equation A.2.1 in Appendix A.2. Because the maximum value of $\sigma_{T_{cr}}$ was obtained for a flowzone 4 assembly, the standard deviation of the flowzone 4 plenum pressure gradient was used in the calculation of $\sigma_{T_{cr eff}}$.

The sensitivity coefficients, and thus $\sigma_{T_{cr\ eff}}$, vary with the value of $\langle T_{in} \rangle$. Therefore, $\sigma_{T_{cr\ eff}}$ was calculated for values of T_{in0} at 10, 20, 30 and 40°C. The actual calculations of $\sigma_{T_{cr\ eff}}$ were made with the Excel spreadsheet³⁰ described in the previous section. The values of $\sigma_{T_{cr\ eff}}$ are given in Table 6.2.

Table 6.2

Values of $\sigma_{T_{cr\ eff}}$ for the K14.1 Charge

	$T_{in0} = 10^\circ\text{C}$	$T_{in0} = 20^\circ\text{C}$	$T_{in0} = 30^\circ\text{C}$	$T_{in0} = 40^\circ\text{C}$
$\sigma_{T_{cr\ eff}}$	4.1375°C	3.8370°C	3.5297°C	3.2290°C

6.3 Calculating the Values of N_i

In the uncertainty analysis, the flowzone effluent temperature limits were obtained from Equation 3.1. The value N_i in Equation 3.1 is the number of effective standard deviations, $\sigma_{T_{cr\ eff}}$, that the effluent temperature limit for flowzone i lies below the minimum mean assembly effluent temperature limit for flowzone i .

The probability distribution functions for all assemblies the core were assumed to be normal with mean equal to the mean assembly critical effluent temperature and to have a standard deviation, $\sigma_{T_{cr\ eff}}$, which is a function of $\langle T_{in} \rangle$. The mean assembly critical effluent temperature limits for all assemblies could be obtained by interpolation from the mean assembly critical effluent temperature limits calculated at the TRAC cell centers. Interpolation on nominal idealized assembly effluent temperatures was done by CINT2^{1,6,7}. As part of its input, CINT2 required nominal idealized assembly effluent temperature limits at the centers of the 24 TRAC cells in rings 1 - 4, for T_{in0} at 10, 20, 30 and 40°C. It will be shown later that the use of nominal values for the assembly effluent temperatures yields the same values for N_i as would the use of mean values.

The acceptable corewide probability of not exceeding the OSV criterion was partitioned into flowzone probabilities of not exceeding the OSV criterion. The probability of not exceeding the OSV criterion is called the no-failure probability. For flowzone i , the

effluent temperature limit could be determined directly by finding the the value $T_{lim i}$ which is such that ¹:

$$\Pr(T_{lim i} < T_{cr k_i}) = \prod_{k=1}^{n_i} \left(1 - \int_{-\infty}^{T_{lim i}} P_{k_i}(T_{cr}) dT_{cr} \right) \quad 6.1$$

with the constraint:

$$\prod_{i=1}^4 \Pr(T_{lim i} < T_{cr k_i}) = 0.84 \quad 6.2$$

where: $\Pr(T_{lim i} < T_{cr k_i})$ = The no-failure probability for flowzone i.

$T_{cr k_i}$ = The critical effluent temperature for the i^{th} assembly in flowzone k.

n_i = The number of assemblies in flowzone i.

P_{k_i} = The probability distribution for the kth assembly in flowzone i. Note that P_{k_i} is

$$N(<T_{cr k_i}>, \sigma_{T_{cr eff}}(<T_{in}>)).$$

In Equation 6.2 it was assumed that the corewide no-failure probability is 84%. A value for N_i could be calculated for the values of $<T_{in}>$ at 10, 20, 30 and 40°C, from the value of $T_{lim i}$ obtained from Equation 6.1, the value of $\sigma_{T_{cr eff}}$ and the minimum value of $\beta\Delta T_{ideal}$ for flowzone i. Because normal distributions with a standard deviation of $\sigma_{T_{cr eff}}$ were used for each assembly, the integral on the right hand side of Equation 6.1 depends on $\sigma_{T_{cr eff}}$ and the differences between the mean values of assembly critical effluent temperatures. Therefore, N_i is a function of $\Pr(T_{lim i} < T_{cr k_i})$, $<T_{in}>$ and the differences between the values of $<T_{in} + \beta\Delta T_{ideal k_i}>$, where $\Delta T_{ideal k_i}$ is the limiting temperature rise across the k^{th} assembly in flowzone i. In Reference 5 it was demonstrated

that β is very nearly independent of axisymmetric random variables. Therefore:

$$\langle T_{in} + \beta \Delta T_{ideal k_i} \rangle = \langle T_{in} \rangle + \langle \beta \rangle \langle \Delta T_{ideal k_i} \rangle \quad 6.3$$

For interpolated values of $\langle \Delta T_{ideal k_i} \rangle$ and a given value of $\langle T_{in} \rangle$, the difference between the values of $\langle T_{in} + \beta \Delta T_{ideal k_i} \rangle$ depends upon the value of $\langle \beta \rangle$. Where, from the definition of β in section 3:

$$\langle \beta \rangle = \langle \beta_{3D} \rangle \beta_{hw} \beta_{void} \quad 6.4$$

For flexibility in the limits calculations, CINT2 outputs tables of N_i as functions of $\langle T_{in} \rangle$, flowzone number, $\langle \beta \rangle$, $\Pr(T_{lim i} < T_{cr k_i})$ and $\sigma_{T_{cr eff}}$.

In Appendix A.3 it is demonstrated that the difference between the values of $\langle T_{in} \rangle + \langle \beta \rangle \langle \Delta T_{ideal k_i} \rangle$ is the same as the difference between the values of $T_{in0} + \langle \beta \rangle (\Delta T_{ideal k_i})_{nominal}$. Therefore, nominal effluent temperature limits may be used in place of mean effluent temperature limits at the centers of the 24 TRAC cell centers for input to CINT2.

The code INTERP2^{6,7} was used to interpolate values of N_i from the tables output by CINT2. The values of N_i , corresponding to a given set of flowzone no-failure probabilities, are given in Table 6.3

Table 6.3

Values of N_i

Flowzone	No-Failure Probability	$T_{in0} = 10^\circ\text{C}$	$T_{in0} = 20^\circ\text{C}$	$T_{in0} = 30^\circ\text{C}$	$T_{in0} = 40^\circ\text{C}$
1	0.9770	3.00773	3.00826	3.00766	3.00557
2	0.9270	2.34965	2.34881	2.34715	2.34612
3	0.9481	2.12440	2.12506	2.12382	2.12550
4	0.9783	2.23484	2.23396	2.23281	2.23159

6.4 Flowzone Effluent Temperature Limits

If the interpolated assembly effluent temperature limits calculated by CINT2 were exact means, there would be no need to calculate N_i . In this case $T_{lim\ i}$ could be calculated directly. However, as discussed in section 6.3, CINT2 used interpolated values of the nominal assembly effluent temperature limits to calculate values for N_i . The differences between the mean assembly effluent temperature limits, required to calculate N_i , were approximated by using the interpolated nominal effluent temperature limits for each assembly in the i^{th} flowzone. Although it was demonstrated that the value of N_i will be unaffected by using nominal idealized assembly effluent temperatures, the value of $T_{lim\ i}$ will be affected because the nominal assembly effluent temperatures are translated from the mean values. Therefore, CINT2 is a means of calculating the value N_i , which is the number of standard deviations that the flowzone i assembly effluent temperature limit lies below the minimum mean assembly effluent temperature limit for flowzone i . Mathematically, N_i is such that, for a given value of $\langle T_{in} \rangle$:

$$T_{lim\ i} = \langle T_{cr\ min\ i} \rangle - N_i \sigma_{T_{cr\ eff}} \quad 6.5$$

where: $\langle T_{cr\ min\ i} \rangle$ = The minimum mean assembly effluent temperature for flowzone i .

Only $\langle \beta \rangle$ and those uncertainties in Table 5.1 which have biases contribute to the difference between the mean assembly effluent temperature limits and the nominal idealized assembly effluent temperature limits. The value of $\langle T_{cr\ min\ i} \rangle$ was calculated from the minimum nominal idealized assembly effluent temperature limit for the i^{th} flowzone (see Appendix A.4). From Equation A.4.8:

$$\begin{aligned} \langle T_{cr\ min\ i} \rangle &\equiv \langle T_{in} + \beta \Delta T_{ideal\ min\ i} \rangle = \\ &T_{in0} + 0.76266 \Delta (T_{ideal\ min\ i})_{nominal} - 0.8 + 0.648 a_{T_{in\ i}} - 20.0 a_{hsc\ i} \end{aligned} \quad 6.6$$

For each nominal assembly inlet coolant temperature, the effluent temperature limit for the i^{th} flowzone was obtained by substituting Equation 6.6 into Equation 3.1. The effluent

temperature limits for the i^{th} flowzone, at nominal assembly inlet coolant temperatures, T_{in0} , of 10, 20, 30 and 40°C, were given by:

$$T_{lim\ i} = T_{in0} + 0.76266\Delta(T_{ideal\ min\ i})^{nominal} - 0.8 + 0.648a_{T_{in\ i}} - 20.0a_{hsc\ i} - N_i\sigma_{T_{cr\ eff}} \quad 6.7$$

The values for the nominal idealized assembly effluent temperature limits for each flowzone, $(T_{ideal\ min\ i})^{nominal}$, were calculated with FLOWTRAN v16-2³¹, at values of 10, 20, 30 and 40°C for T_{in0} . It was found that the minimum nominal idealized effluent temperature limit in a flowzone occurred for the assembly which had the greatest steady state plenum pressure and the most severe transient plenum pressure for that flowzone. This combination of pressure characteristics resulted in the lowest effluent temperature for the FI LOCA because the assembly power limit was set by the pressure transient, while the effluent temperature limit was set by the steady state pressure drop. A more severe plenum pressure transient resulted in lower assembly power limits, while greater steady state assembly pressure drops resulted in greater assembly flowrates. Thus, for a given assembly power, greater steady state assembly pressure drops resulted in lower effluent temperature limits. The minimum nominal assembly effluent temperature limit for flowzone i was conservatively calculated by using a combination of the most severe plenum pressure transient and the greatest steady state plenum pressure found in that flowzone. The values of $(T_{ideal\ min\ i})^{nominal}$ are given in Table 6.4.

Table 6.4

Values of $(T_{ideal\ min\ i})^{nominal}$ (in °C) for the K14.1 Charge				
Flowzone	$T_{in0} = 10^\circ\text{C}$	$T_{in0} = 20^\circ\text{C}$	$T_{in0} = 30^\circ\text{C}$	$T_{in0} = 40^\circ\text{C}$
1	73.99523	78.36313	82.76257	87.13408
2	70.36025	75.01861	79.66985	84.33021
3	68.30368	73.14059	77.98483	82.81217
4	70.17604	74.90282	79.61458	84.33313

Equation 6.7 was incorporated into the Excel spreadsheet which was used to calculate the effluent temperature limits³⁰. Tables 6.1, 6.2, 6.3 and 6.4 were used with Equation 6.7 to calculate the flowzone effluent temperature limits as a function of the nominal assembly

inlet coolant temperature, T_{in_0} . The values for the effluent temperature limits are given in Table 6.5.

Table 6.5

Flowzone Effluent Temperature Limits, $T_{lim\ i}$ (in °C) for the K14.1 Charge

Flowzone	$T_{in_0} = 10^\circ\text{C}$	$T_{in_0} = 20^\circ\text{C}$	$T_{in_0} = 30^\circ\text{C}$	$T_{in_0} = 40^\circ\text{C}$
1	45.9425	52.5477	59.2015	65.8148
2	45.8930	52.5273	59.1742	65.8058
3	45.2565	51.9535	58.6774	65.3604
4	46.2276	52.8797	59.5356	66.1778

The effluent temperature limits for flowzones 5 and 6 were extrapolated from the flowzone 4 effluent temperature limits³².

From Table 6.5 it can be shown that the fit of $T_{lim\ i}$ with respect to T_{in_0} is nearly linear.

The linear fits in Table 6.6 were made with a least squares fitting routine in the Excel spreadsheet³⁰. If the effluent temperature limits from the uncertainty analysis were to be used as K14.1 operating limits, the slope and intercept of the linear fits of $T_{lim\ i}$ to T_{in_0} given in Table 6.6 would be input to the K reactor control computer.

The value of T_{in_0} used by the control computer is the minimum average inlet line temperature, obtained from the averages of the two RTD's on each inlet line, see Section 5.2.3. The bias on the assembly inlet coolant temperature relates the minimum average inlet line coolant temperature to the actual assembly inlet coolant temperature.

Table 6.6

Fit of $T_{lim\ i}$ to T_{in_0}

Flowzone	Linear Fit
1	$T_{lim\ i} = 39.30889 + 0.66271T_{in_0}$
2	$T_{lim\ i} = 39.25379 + 0.66385T_{in_0}$
3	$T_{lim\ i} = 38.55311 + 0.67035T_{in_0}$
4	$T_{lim\ i} = 39.57849 + 0.66507T_{in_0}$

The core power was approximated from the flowzone effluent temperature limits with a correlation^{30,33,34,35}. It was assumed that the core power was limited by the lowest core

power obtained from the flowzone effluent temperature limits. The relationship between the flowzone effluent temperature limit and the core power was used to adjust the values of $\text{Pr}(T_{\text{lim } i} < T_{\text{cr } k_i})$ for each flowzone so that a higher total core power could be obtained. The adjustment was made by iterating on $\text{Pr}(T_{\text{lim } i} < T_{\text{cr } k_i})$, with the constraint applied by Equation 6.2. INTERP2 was then used to calculate values of N_i corresponding to each value of $\text{Pr}(T_{\text{lim } i} < T_{\text{cr } k_i})$, from the tables output by CINT2. Iteration on $\text{Pr}(T_{\text{lim } i} < T_{\text{cr } k_i})$ was continued until the core power limits corresponding to each flowzone effluent temperature limit were within 10 Mw of each other. The lowest estimate of the core power for all flowzones was used as the estimate of the core power limit. Because flowzone 4 has few assemblies, it was undesirable to allow it to have the limiting core power. Therefore, the no-failure probability for flowzone 4 was adjusted so that the flowzone 4 effluent temperature limit yielded a higher core power than that obtained for flowzones 1 - 3. The estimated core powers, based on the flowzone effluent temperature limits are given in table 6.7.

Table 6.7
Estimated Core Powers
Based on the Assembly Effluent Temperature Limits

Flowzone	Core Power (Mw)
1	1203.06
2	1202.21
3	1205.37
4	1211.79

Because the lowest of the estimated core powers was used to estimate the operating core power, the core power from the uncertainty analysis was 1202.56 Mw. It must be re-emphasized that this core power is not a final value. Additional changes, as discussed in Section 2, may be necessary to account for factors not considered in the uncertainty analysis.

REFERENCES

1. B. J. Hardy, A. M. White. *A Probabilistic Method for Determining Effluent Temperature Limits for Flow Instability in SRS Reactors*. Westinghouse Savannah River Company Report WSRC-TM-90-5, DPSTM-160 (1990).
2. J. E. Laurinat. *Documentation of UNCERT, Versions 16-2B, 16-4B, 16-5, and 16-5A*. Westinghouse Savannah River Company Memorandum NES-ART-900188, FIU-90-96 (1990).
3. R. L. Webb. *Radial and Azimuthal Power Profiles in Mark 22 Assemblies*. Westinghouse Savannah River Company Report WSRC-RP-89-724 (1989).
4. J. D. Metzger. *Documentation for the Computer Code POWCOMBV3*. Westinghouse Savannah River Company Memorandum NES-ART-900094, Rev. 2, FIU-90-65 (1990).
5. B. J. Hardy. *Three Dimensional Effects Multiplier*. Westinghouse Savannah River Company Memorandum NES-ART-900221, Rev. 2, FIU-90-104 (1990).
6. J. D. Metzger. *Documentation of the Computer Code CINT*. Westinghouse Savannah River Company Memorandum NES-ART-900021, FIU-90-44 (1990).
7. B. J. Hardy. *Modifications to INTERP and CINT*. Westinghouse Savannah River Company Memorandum NES-ART-900224, FIU-90-107 (1990).
8. J. D. Metzger. *Documentation of the computer code INTERP*. Westinghouse Savannah River Company Memorandum NES-ART-900002, Rev. 1, FIU-90-37 (1990).
9. S. M. Mertz. *Plenum Pressure History*. Westinghouse Savannah River Company Report OPS-RTS-900103 (1990).
10. M. L. Liebmann. *TRAC K14.1 LOCA Fuel Assembly dp Study*. Westinghouse Savannah River Company Report NES-ART-900169 (1990).

11. B. J. Hardy. *Laboratory Notebook*. Westinghouse Savannah River Company WSRC-NB-89-215, ppg 94-96,101 (1989).
12. R. S. Ondrejcin. *Evaluation of Mark 22 Cladding*. E. I. du Pont de Nemours & Company, Inc.Savannah River Laboratory Report DPST-83-324 (1983).
13. B. J. Hardy. *Steady State Centerline Plenum Pressure Uncertainties*. Westinghouse Savannah River Company Memorandum NES-ART-9000123, FIU-90-73 (1990).
14. W. M. Massey. *Laboratory Notebook* . Westinghouse Savannah River Company WSRC-NB-90-115, pg 64 (1990).
15. B. J. Hardy. *Re-calculation of Uncertainties in the Plenum Pressure Gradient*. Westinghouse Savannah River Company Memorandum NES-ART-900080 Rev.2, FIU-90-58 (1990).
16. B. J. Hardy. *Laboratory Notebook*. Westinghouse Savannah River Company WSRC-NB-89-215, ppg 194-213 and ppg 260-268 (1989).
17. D. A. Crowley, L. L. Hamm. *Improved Plenum Pressure Gradient Facemaps fo PKL Reactors*. E. I. du Pont de Nemours & Company, Inc.Savannah River Laboratory Report DPST-88-527 (1988).
18. B. J. Hardy. *Standard Deviation of the Inner Fuel Tube Power Fraction*. Westinghouse Savannah River Company Memorandum NES-ART-900257, FIU-90-155 (1990).
19. S. D. Harris. *Nozzle Stall in Savannah River Reactors*. E. I. Du Pont De Nemours and Company Document DP-1258, Reactor Technology TID-4500, UC-80 (1971).
20. G. L. Gill. *Assembly Effluent and Plenum Inlet Temperature Measurement Uncertainties*. Westinghouse Savannah River Company Memorandum OPS-RTS-900081 (1990).

21. B. J. Hardy. *Inlet Temperature Bias and Uncertainty for No Plenum Mixing*. Westinghouse Savannah River Company Memorandum NES-ART-910038, FIU-91-01 (1991).
22. B. J. Hardy. *Steady State Plenum Pressure Uncertainties*. Westinghouse Savannah River Company Memorandum NES-ART-900123, FIU-90-73 (1990).
23. S. M. Mertz. *Plenum Pressure Measurement Uncertainties*. Westinghouse Savannah River Company Technical Report WSRC-TR-90-42-121 (1991).
24. B. J. Hardy. *Effluent Temperature Measurement Uncertainties*. Westinghouse Savannah River Company Memorandum NES-ART-900118, FIU-90-72 (1990).
25. J. E. Laurinat. *Sensitivities of OSV Limits to Heated Wall and Void Effects Addition 1*. Westinghouse Savannah River Company Memorandum NES-ART-900191, FIU-90-97 (1990).
26. B. J. Hardy. *Heated Wall and Void Effects Multiplier*. Westinghouse Savannah River Company Memorandum NES-ART-900201, FIU-90-100 (1990).
27. M. D. DeHart. *Input Changes for Final K-14.1 LOCA-FI Relative Power Calculations*. Westinghouse Savannah River Company Memorandum NES-ART-900269 (1990).
28. B. J. Hardy. *Laboratory Notebook*. Westinghouse Savannah River Company WSRC-NB-90-273, ppg 226-241 (1990).
29. J. E. Laurinat. *Additional Sensitivities of OSV Limits for Assemblies with 28 Shell Holes at Inlet Temperatures of 10°C, 20°C, 30°C, and 40°C*. Westinghouse Savannah River Company Memorandum NES-ART-900148, FIU-90-83 (1990).
30. N. M. Askew. *Technical Review of the EXCEL Spreadsheet Calculations Under Task No. 88-024-1, Rev. 2, A Probabilistic Method for Determining the Savannah River Site Reactor Assembly Flow Instability Effluent Temperature Limits*. Westinghouse Savannah River Company Memorandum NES-ART-900234 (1990).

31. W. M. Massey. *Laboratory Notebook*. Westinghouse Savannah River Company WSRC-NB-90-115, ppg 83,84 (1990).
32. W. M. Massey. *Laboratory Notebook*. Westinghouse Savannah River Company WSRC-NB-90-155, pg 109 (1990).
33. W. M. Massey. *Revised Equations for Estimating Reactor Power*. Westinghouse Savannah River Company Memorandum RTR-2174 (1984).
34. W. M. Massey. *Laboratory Notebook*. Westinghouse Savannah River Company WSRC-NB-90-155, pg 105 (1990).
35. B. J. Hardy. *Laboratory Notebook*. Westinghouse Savannah River Company WSRC-NB-90-273, pg 49 (1989).

APPENDICES

A.1 Derivation of the Equations for the Sensitivity Coefficients

The sensitivity coefficient of a parameter was defined as the derivative of the critical effluent temperature with respect to that parameter.

The statistical model for the critical effluent temperature was given by¹:

$$T_{cr}(x) = T_{in} + \beta \Delta T_{ideal}(y) + \varepsilon \quad A.1.1$$

where: $T_{cr}(x)$ = The assembly critical effluent temperature at the value x of the parameters.

x = All parameters which affect the critical effluent temperature of an assembly.

T_{in} = The assembly inlet temperature.

$$\beta = \beta_{hw} \beta_{void} \beta_{3D}$$

β_{hw} = The heated wall effect multiplier, a constant.

β_{void} = The void effect multiplier, a constant.

β_{3D} = The asymmetric effects multiplier.

$\Delta T_{ideal}(y)$ = The limiting coolant temperature rise across an idealized (axisymmetric, no cavitation, no heated wall and no void effects) assembly as a function of axisymmetric parameters y .

y = The parameters describing axisymmetric effects, including T_{in} , not including any asymmetric parameters, heated wall or void effects.

Equation A.1.1 was used to calculate the sensitivity coefficients for uncertainties which have distributions. The sensitivity coefficient for a given uncertainty parameter, at a particular set of nominal parameter values, was found by evaluating the derivative of T_{cr} with respect to that parameter at the nominal parameter values.

Transient Plenum Pressure

$$\begin{aligned}
 a_{\text{tp}} &= \frac{\partial T_{cr}(x_0)}{\partial P_t} = 0 + \beta_0 \frac{\partial \Delta T_{\text{ideal}}(y_0)}{\partial P_t} + 0 \\
 &= \beta_0 \left[\frac{\Delta T_{\text{ideal } 1} - \Delta T_{\text{ideal } 0}}{P_{t1} - P_{t0}} \right]
 \end{aligned}
 \tag{A.1.2}$$

where:

The subscript 0 denotes nominal values.

a_{tp} = The sensitivity coefficient for the transient plenum pressure.

P_t = Transient plenum pressure.

$\Delta T_{\text{ideal } 1}$ = The idealized limiting temperature rise across an assembly at P_{t1} and nominal values of the other parameters.

$$P_{t1} = P_{t0} + \delta P_t$$

Asymmetric Effects Multiplier β_{3D}

$$\begin{aligned}
 a_{\beta_{3D}} &= \frac{\partial T_{cr}(x_0)}{\partial \beta_{3D}} = 0 + \beta_{\text{hw}} \beta_{\text{void}} \frac{\partial \beta_{3D} \Delta T_{\text{ideal}}(y_0)}{\partial \beta_{3D}} + 0 \\
 &= \beta_{\text{hw}} \beta_{\text{void}} \Delta T_{\text{ideal}}(y_0)
 \end{aligned}
 \tag{A.1.3}$$

where: $a_{\beta_{3D}}$ = The sensitivity coefficient for the asymmetric effects multiplier, β_{3D}

Transient Tank Bottom Pressure

$$a_{ttbp} = \frac{\partial T_{cr}(x_0)}{\partial P_{ttbp}} = 0 + \beta_0 \frac{\partial \Delta T_{ideal}(y_0)}{\partial P_{ttbp}} + 0$$

$$\approx \beta_0 \left[\frac{\Delta T_{ideal 1} - \Delta T_{ideal 0}}{P_{ttbp 1} - P_{ttbp 0}} \right] \quad A.1.4$$

where: a_{ttbp} = The sensitivity coefficient for the transient tank bottom pressure.

P_{ttbp} = The transient tank bottom pressure.

Steady State Plenum Pressure Gradient for Flowzone i and the Steady State Plenum Center Pressure

$$a_{sspp} = a_{ppg}^i = \frac{\partial T_{cr}(x_0)}{\partial P} = 0 + \beta_0 \frac{\partial \Delta T_{ideal}(y_0)}{\partial P} + 0$$

$$\approx \beta_0 \left[\frac{\Delta T_{ideal 1} - \Delta T_{ideal 0}}{P_1 - P_0} \right] \quad A.1.5$$

where: a_{ppg}^i = The sensitivity coefficient for the steady state plenum pressure gradient for the i^{th} flowzone.

a_{sspp} = The sensitivity coefficient for the steady state plenum centerline pressure.

P = The steady state plenum pressure gradient for the i^{th} flowzone or the steady state plenum centerline pressure.

Inner Fuel Tube Power Fraction

$$\begin{aligned} a_{pf} &= \frac{\partial T_{cr}(x_0)}{\partial I_{pf}} = 0 + \beta_0 \frac{\partial \Delta T_{ideal}(y_0)}{\partial I_{pf}} + 0 \\ &= \beta_0 \left[\frac{\Delta T_{ideal 1} - \Delta T_{ideal 0}}{I_{pf 1} - I_{pf 0}} \right] \end{aligned} \quad A.1.6$$

where: a_{pf} = The sensitivity coefficient for the inner fuel tube power fraction.

I_{pf} = The inner fuel tube power fraction.

Assembly Inlet Temperature

$$\begin{aligned} a_{T_{in}} &= \frac{\partial T_{cr}(x_0)}{\partial T_{in}} = 1 + \beta_0 \frac{\partial \Delta T_{ideal}(y_0)}{\partial T_{in}} + 0 \\ &= 1 + \beta_0 \left[\frac{\Delta T_{ideal 1} - \Delta T_{ideal 0}}{T_{in 1} - T_{in 0}} \right] \end{aligned} \quad A.1.7$$

where: $a_{T_{in}}$ = The sensitivity coefficient for the assembly inlet coolant temperature.

T_{in} = The assembly inlet coolant temperature.

Effluent Temperature Measurement

$$\begin{aligned} a_{\epsilon} &= \frac{\partial T_{cr}(x_0)}{\partial \epsilon} = 0 + 0 + \frac{\partial \epsilon}{\partial \epsilon} \\ &= 1 \end{aligned} \quad A.1.8$$

where: a_{ϵ} = The sensitivity coefficient for the effluent temperature measurement error.

ϵ = The effluent temperature measurement error.

Heated Fuel Length

$$a_H = \frac{\partial T_{gr}(x_0)}{\partial H} = 0 + \beta_0 \frac{\partial \Delta T_{ideal}(y_0)}{\partial H} + 0$$

$$= \beta_0 \left[\frac{\Delta T_{ideal 1} - \Delta T_{ideal 0}}{H_1 - H_0} \right] \quad A.1.9$$

where: a_H = The sensitivity coefficient for the heated fuel length.

H = The heated fuel length.

Turbulent Heat Transfer Coefficient

$$a_{ht} = \frac{\partial T_{gr}(x_0)}{\partial h_t} = 0 + \beta_0 \frac{\partial \Delta T_{ideal}(y_0)}{\partial h_t} + 0$$

$$= \beta_0 \left[\frac{\Delta T_{ideal 1} - \Delta T_{ideal 0}}{h_{t1} - h_{t0}} \right] \quad A.1.10$$

where: a_{ht} = The sensitivity coefficient for the turbulent (forced convective) heat transfer coefficient.

h_t = The turbulent heat transfer coefficient.

Subcooled Boiling Heat Transfer Coefficient

$$\begin{aligned}
 a_{hsc} &= \frac{\partial T_{cr}(x_0)}{\partial h_{sc}} = 0 + \beta_0 \frac{\partial \Delta T_{ideal}(y_0)}{\partial h_{sc}} + 0 \\
 &= \beta_0 \left[\frac{\Delta T_{ideal 1} - \Delta T_{ideal 0}}{h_{sc 1} - h_{sc 0}} \right]
 \end{aligned} \tag{A.1.11}$$

where: a_{hsc} = The sensitivity coefficient for the subcooled boiling heat transfer coefficient.

h_{sc} = The subcooled boiling heat transfer coefficient.

A.2 Specific form of the Equation for $\sigma_{T_{cr}}^2$

The equation for $\sigma_{T_{cr}}^2$ was obtained from Equation 3.2. The only correlated uncertainties are the transient plenum pressure and the transient tank bottom pressure¹. The exact nature of the correlation was unknown, therefore the most conservative correlation coefficient was assumed. Upon expansion, Equation 3.2 becomes:

$$\begin{aligned}
 \sigma_{T_{cr}}^2 &= \sigma_{tp}^2 a_{tp}^2 + \sigma_{ubp}^2 a_{ubp}^2 + (\sigma_{sspp}^2 + \sigma_{ppg}^2) a_{sspp}^2 + \sigma_{T_{in}}^2 a_{T_{in}}^2 + \\
 &\sigma_{pf}^2 a_{pf}^2 + \sigma_H^2 a_H^2 + \sigma_{ht}^2 a_{ht}^2 + \sigma_{hsc}^2 a_{hsc}^2 + \sigma_{\beta_{3D}}^2 a_{\beta_{3D}}^2 + \\
 &\sigma_{\epsilon}^2 a_{\epsilon}^2 - 2.0 a_{tp} a_{ubp} \sigma_{tp} \sigma_{ubp}
 \end{aligned} \tag{A.2.1}$$

where: σ_{tp} = The standard deviation of the transient plenum pressure.

a_{tp} = The sensitivity coefficient for the transient plenum pressure.

σ_{ubp} = The standard deviation of the transient tank bottom pressure.

a_{ltbp} = The sensitivity coefficient for the transient tank bottom pressure.

σ_{sspp} = The standard deviation of the steady state centerline plenum pressure.

a_{sspp} = The sensitivity coefficient for the steady state centerline plenum pressure.

σ_{ppg} = The standard deviation of the steady state plenum pressure gradient.

$\sigma_{T_{in}}$ = The standard deviation of the assembly inlet coolant temperature.

$a_{T_{in}}$ = The sensitivity coefficient for the assembly inlet coolant temperature

σ_{pf} = The standard deviation of the inner fuel tube power fraction.

a_{pf} = The sensitivity coefficient for the inner fuel tube power fraction.

σ_H = The standard deviation of the heated length of an assembly.

a_H = The sensitivity coefficient for the heated length of an assembly.

σ_{ht} = The standard deviation of the turbulent (forced convective) heat transfer coefficient.

a_{ht} = The sensitivity coefficient for the turbulent heat transfer coefficient.

σ_{hsc} = The standard deviation of the subcooled boiling heat transfer coefficient.

a_{hsc} = The sensitivity coefficient for the subcooled boiling heat transfer coefficient.

$\sigma_{\beta_{3D}}$ = The standard deviation of the asymmetric effects multiplier.

$a_{\beta_{3D}}$ = The sensitivity coefficient for the asymmetric effects multiplier.

σ_{ϵ} = The standard deviation of the effluent temperature measurement error.

a_{ϵ} = The sensitivity coefficient for the effluent temperature measurement error.

In Equation A.2.1, the sensitivity coefficient for the steady state centerline plenum pressure is the same as the sensitivity coefficient for the steady state plenum pressure gradient.

A.3 Use of $(\Delta T_{\text{ideal } k_i})_{\text{nominal}}$ in CINT2

The statistical model for the critical effluent temperature given in Equation A.1.1 may be approximated by the linear expression¹:

$$T_{\text{cr } k_i}(\gamma) = T_{\text{cr}_0 k_i} + \sum_j a_{j k_i} (\gamma_{j k_i} - \gamma_{j_0 k_i}) \quad \text{A.3.1}$$

where: $T_{\text{cr } k_i}$ = The critical effluent temperature limit for the k^{th} assembly in flowzone i.

$T_{\text{cr}_0 k_i}$ = The nominal value of the critical effluent temperature of the k^{th} assembly in flowzone i.

γ = The vector of $\gamma_{j k_i}$ values.

$a_{j k_i}$ = The sensitivity coefficient for the j^{th} significant uncertainty parameter for the k^{th} assembly in flowzone i.

$\gamma_{j k_i}$ = The value of the j^{th} significant uncertainty parameter for the k^{th} assembly in flowzone i.

$\gamma_{j0 k_i}$ = The nominal value of the j^{th} uncertainty parameter for the k^{th} assembly in flowzone i.

The mean value of the critical effluent temperature is given by:

$$\langle T_{cr k_i} \rangle \approx T_{cr0 k_i} + \sum_j a_{j k_i} (\gamma_{j k_i} - \gamma_{j0 k_i}) \quad A.3.2$$

where: $\langle \rangle$ denotes a mean.

But:

$$\langle T_{cr k_i} \rangle = \langle T_{in} + \beta \Delta T_{ideal k_i} \rangle = T_{cr0 k_i} + \sum_j a_{j k_i} (\langle \gamma_{j k_i} \rangle - \gamma_{j0 k_i}) \quad A.3.3$$

and because $\beta_0 = \langle \beta \rangle$:

$$T_{cr0 k_i} = T_{in0} + \beta_0 \Delta T_{ideal0 k_i} = T_{in0} + \langle \beta \rangle \Delta T_{ideal0 k_i} \quad A.3.4$$

where: The subscript 0 denotes a nominal value.

Therefore, Equations A.3.3 and A.3.4 give:

$$\langle T_{in} + \beta \Delta T_{ideal k_i} \rangle = T_{in0} + \langle \beta \rangle \Delta T_{ideal0 k_i} + \sum_j a_{j k_i} (\langle \gamma_{j k_i} \rangle - \gamma_{j0 k_i}) \quad A.3.5$$

$\langle \rangle$ denotes a mean.

a_{ϵ_i} = The sensitivity coefficient for the effluent temperature measurement error for flowzone i.

$a_{T_{in\ i}}$ = The sensitivity coefficient for the assembly inlet coolant temperature.

$a_{hsc\ i}$ = The sensitivity coefficient for the subcooled nucleate boiling heat transfer coefficient.

γ_{ϵ_i} = The error in the effluent temperature measurement for flowzone i.

$\gamma_{T_{in\ i}}$ = The assembly inlet coolant temperature for flowzone i.

$\gamma_{hsc\ i}$ = The subcooled nucleate boiling heat transfer coefficient for flowzone i.

Note, for the FI LOCA, the mean and nominal values for γ_{ϵ_i} , $\gamma_{T_{in\ i}}$ and $\gamma_{hsc\ i}$ are independent of the flowzone. The sensitivity coefficients, $\Delta(T_{ideal\ min\ i})^{nominal}$ and T_{in0} are dependent on the nominal assembly inlet coolant temperature. Therefore, by Equation A.4.2, $\langle T_{cr\ min\ i} \rangle$ is dependent on the nominal, and thus the mean, assembly inlet coolant temperature.

By Table 5.1, for $i = 1, \dots, 4$:

$$|(\langle \gamma_{\epsilon_i} \rangle - \gamma_{\epsilon0\ i})| = 0.8^\circ\text{C} \quad \text{A.4.3}$$

$$\langle \gamma_{T_{in\ i}} \rangle - \gamma_{T_{in0\ i}} = 0.648^\circ\text{C} \quad \text{A.4.4}$$

$$\langle \gamma_{hsc\ i} \rangle - \gamma_{hsc0\ i} = -20.0\% \quad \text{A.4.5}$$

By Equation 6.4:

$$\langle \beta \rangle = \langle \beta_{3D} \rangle \times \beta_{hw} \beta_{void} = 0.76266 \quad A.4.6$$

From Table 6.1:

$$a_{\epsilon_i} = 1.0^{\circ}C/^{\circ}C \quad \text{for } i=1, \dots, 4 \quad A.4.7$$

Substituting Equations A.4.3 - A.4.7 into Equation A.4.2 gives:

$$\langle T_{cr \min i} \rangle = T_{in0} + 0.76266 \Delta(T_{ideal \min i})_{nominal} - 0.8 + 0.648 a_{T_{in i}} \cdot 20.0 a_{hsc i} \quad A.4.8$$

END

DATE
FILMED

3 / 24 / 93