**Urban
Consortium
for Technology
Initiatives**

**THE ENERGY TASK FORCE OF THE
URBAN CONSORTIUM FOR
TECHNOLOGY INITIATIVES**

The Urban Consortium for Technology Initiatives (UC) is composed of over forty of the largest cities and urban counties by population in the United States. The Consortium provides a unique forum to define urban problems common to its member governments and to develop, apply, transfer and commercialize technologies and innovative management techniques to address those problems.

With staff, management and business services provided by Public Technology, Inc., the Urban Consortium carries out its work through special projects and Task Forces that focus on specific functional areas of local government management. The UC Energy Task Force is the nation's most extensive cooperative local government program to improve energy management and technology applications in cities and urban counties. Its membership is composed of local government officials from twenty of America's largest urban centers.

The members of the UC Energy Task Force define annual work programs to meet three specific objectives:

- o definition of critical urban energy problems;
- o development of technologies and management practices to resolve these problems; and
- o transfer of resulting solutions to Urban Consortium and other local governments.

Proposals to meet the specific objectives of these annual work programs are solicited from the full UC membership. Projects based on these proposals are then selected by the Energy Task Force for direct conduct and management by staff of city and county governments. Projects selected for each year's program are organized in thematic units to assure effective management and ongoing peer-to-peer experience exchange, with results documented at the end of each program year.

This approach for the definition of priorities and the selection, conduct and documentation of applied research projects by staff from participating local governments is a unique strength of the UC Energy Task Force -- a "user-driven" focus to assure that projects conducted by city and county staff will produce results that effectively meet energy management needs critical to local governments.

PUBLIC TECHNOLOGY, INC. (PTI)

Public Technology, Inc. (PTI), is the research development and commercialization arm of the National League of Cities and ICMA, and a non-profit association of local governments dedicated to improving services and increasing efficiency through the use of technology and management systems.

PTI works with and supports its members in solving widespread and urgent problems facing local governments. This support is handled through a four-tier, interconnected series of service centers, which provide state-of-the-art information, electronic and personal networking with local governments and technical specialists, direct consultation and training with PTI staff experts, and practical research.

To ensure that its programs and research have the widest possible benefit, PTI is guided by a strategic plan that emphasizes partnerships with private industry, expertise in multi-disciplinary technologies, training in the art of change management, and participation in the international arena of local government to further the search for technological and management solutions.

Member cities and counties provide PTI's core financial support. Grants and contracts from foundations, Federal agencies, and corporations also support PTI activities.

PTI's activities are carried out from offices located in Washington, D.C. and Long Beach, California. International coordination is handled through an affiliate in London, England. PTI was founded in 1971 by the major associations of state and local governments.

Costis Toregas, President

The research and studies described in this report were made possible by grants from the Community Energy Program of the Office of Buildings and Community Systems of the United States Department of Energy through the Energy Task Force of the Urban Consortium for Technology Initiatives.

The statements and conclusions contained herein are those of the grantees and do not necessarily represent the official position or policy of the U.S. Government in general or USDOE in particular.

DOE/CHE/27524...710

April 1993

IMPACT OF URBAN HEAT ISLAND ON COOLING AND ENVIRONMENT A DEMONSTRATION PROJECT

Energy Task Force
of the Urban Consortium
for Technology Initiatives

City of Phoenix

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Conducted by:

Energy Conservation Section
Public Works Department
Phoenix, Arizona

MASTER
DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

PREFACE

1991 URBAN CONSORTIUM ENERGY TASK FORCE RESEARCH

THE URBAN CONSORTIUM (UC) is a special network of the Nation's largest cities and urban counties brought together by PTI to find new solutions to their common concerns. The UC provides a creative forum where elected and appointed officials can identify, test, and validate practical ways to improve the provision of public services while generating new revenue opportunities. With staff, management, and business services provided by PTI, the UC addresses the critical needs of large local governments through its three task forces: Energy, Environment, and Telecommunications and Information.

The Urban Consortium Energy Task (UCETF) has 20 members and was established to improve urban energy management and decision-making through applied research and technology transfer. The UCETF focuses on developing and sharing new approaches and innovative solutions to energy management problems with local governments. Projects are organized in thematic units and co-managed by a member of the Task Force.

A description of the 1991 program Units and projects are:

ALTERNATIVE VEHICLE FUELS AND TECHNOLOGIES (AVF)

Alternative vehicle fuels offer a very strong potential to aid in the reduction of U.S. dependence on foreign oil supplies, with the resulting benefits of decreased air pollution in urban areas. Local governments can play an instrumental role in realizing this potential through practical applied research and highly visible demonstrations of alternative fuels and technologies. Issues addressed this year include identifying (a) intensive and credible market development efforts based on an applied research and demonstration program that combines reliable technology with experience-tested applications, (b) environmental and energy diversity benefits, and (c) institutional and infrastructure barriers. The 1991 AVF unit consists of:

Broward County, FL -- *Dual-Fuel Conversion Demonstration and Technology Transfer Project*

New York City, NY -- *Alternative Fuel Vehicle: Financing Issues*

Denver, CO -- *Technical and Market Comparison Between H₂/CNG (Hythane), Electric Hybrid, and CNG Fueled Vehicles*

Denver, CO -- *An Alternative Fuels Fleet Evaluation System -- A Transfer Project*

Detroit, MI -- *Analysis of Institutional and International Limitations for Alternative Fuel Vehicles*

Washington, DC -- *Comparison of Energy Consumption, Energy Savings, and Environmental Effects of EV/PV vs. Conventional Gasoline Vehicle*

ELECTRICITY MANAGEMENT

Urban interests for electricity management focus on means to maintain stable, secure and reasonably priced supplies of electric energy. Approaches include procedures for better demand management, application of "least cost" planning concepts, appropriate use of decentralized and/or small power production facilities, improved end-use efficiency, and developing sound structures for cooperative action among municipalities and energy utilities. Urban strategies include support for decentralized "small" power production, along with better demand management and improved end-use energy efficiency. The successful development and implementation of such strategies will require close cooperation with the utility industry and will address topics in areas of institutional relations, source flexibility, and demand-side management. The 1991 Electricity Management Unit consists of:

Albuquerque, NM -- *Alternatives to Traditional Rate Setting*

Chicago, IL -- *Integrating Innovative Supply and Efficiency Techniques*

Chicago, IL -- *The Chicago Energy Management Cooperative*

Dade County, FL -- *Energy Cost Reduction Through Resource Recovery*

Detroit, MI -- Hydraulic Waste Energy Recovery (Phase II) City of Detroit Water Distribution System

San Jose, CA -- Utility/Local Government Partnership to Increase Energy Conservation in New Construction

ENERGY EFFICIENT FACILITIES

Activities involving energy efficient facilities are at present, part of a national effort to achieve maximum cost-effective energy productivity in the building sector. There exists a need for collaboration between local government officials responsible for energy and environmental programs and other local government officials responsible for facilities, as well as the Federal officials and private sector groups, e.g. utilities. New technologies and management/administration practices to advance energy efficiency in facilities require major partnership efforts and transfer programs. Multi-family housing that has a large concentration of low-income families presents a unique challenge to lowering energy costs and maintaining energy efficient facilities. Projects in this unit are:

Boston, MA -- Neighborhood Energy Efficiency Outreach Partnership

Columbus, OH -- Energy Efficiency and Indoor Air Quality: Solutions for Fire Stations

Louisville, KY -- Partnership Approach to Energy Efficiency in Non-Profit Facilities

Montgomery County, MD -- Technology Transfer of Building Energy Design Guidelines

New Orleans, LA -- Residential Utility Costs Comparative Study

Phoenix, AZ -- Variable Frequency Drive Applications Guide

Portland, OR -- Energy Savings Through Operation and Maintenance Training in the Low-Income Multi-Family Sector

Washington, DC -- Comparison of Two Techniques for Identifying Energy Conservation Measures in Low Income Homes

ENERGY, ENVIRONMENT and ECONOMIC DEVELOPMENT

This an area that has both visionary and immediate practical emphases on the definition and evaluation of realistic strategies and actions to support energy-sustainable and

environmentally responsible communities. Emphases include uses for renewable energy, practical domestic supply and conservation alternatives, and the synthesis of energy concerns with wider local government interests in economic development, environmental quality, and internal cost control. Urban strategies to improve energy-sustainability require attention to both broad based institutional changes, as well as specific projects designed to encourage the application of appropriate technology and community development practices. The "Sustainable Communities" project has involved three municipalities with State agency, Lawrence Berkeley National Laboratory, and a formal advisory committee with broad national representation. Projects under this unit are:

Austin, TX -- Energy Star Sustainable Rating Program

Phoenix, AZ -- Impact of Heat Island on Cooling and Environment: A Demonstration Project

Pima County, AZ -- Tucson Solar Village - Project Management

Portland, OR -- Sustainable City Transfer Project

San Francisco, CA -- Neighborhood Energy/Economic Development at South Bayside

San Francisco, CA -- Sustainable City Transfer Project

San Jose, CA -- Sustainable City Transfer Project

Seattle, WA -- Coordination of Energy and Air Quality (CEAM)

Seattle, WA -- Bicycle Program -- Urban Trails System

Tucson, AZ -- Local Government Involvement in Long Term Resource Planning for Community Energy Services

Reports from each of these research projects, including this report, are specifically designed to aid the transfer of proven experience to other local governments. Readers interested in obtaining any additional reports or further information about the Urban Consortium Energy Task Force and the Urban Consortium should contact:

*Energy R&D Program
Public Technology, Inc.
1301 Pennsylvania Avenue, NW
Washington, DC 20004
1-800-852-4934*

ACKNOWLEDGEMENTS

The City of Phoenix would like to thank the principal investigators, Dr. James R. Simpson, Dr. E. Gregory McPherson and Paul L. Sacamano, U. S. Forest Service, for conducting this study and preparing the final report. The authors would like to acknowledge the City of Phoenix, the Urban Consortium Energy Task Force, the Department of Energy, the Arizona Public Service Company, the Salt River Project and the Arizona Agricultural Experiment Station, University of Arizona for the financial and operational support which made this project possible. We would also like to recognize the support of the Arizona Landscape Contractors Association and the Arizona Nursery Association, in particular for the plant materials, irrigation equipment and other landscape supplies provided by Arid Zone Trees, Bowen's Inc, Mesa Sprinkler Supply, Mountain States Wholesale Nursery, Springtime Growers, V and P Nursery and Western Sod, and for landscape services provided by AAA Landscape, The Groundskeeper, and Western Innovations. We would like to thank the homeowners involved for their cooperation and understanding during the course of the study. Allan Matthias, Luis Alves, Paul Sacamano, Zigang Fang and Rabindranath Patnaik assisted in data acquisition and analysis. Finally, we would like to acknowledge the aid and advice of the project advisory committee: City of Phoenix Energy Conservation Office; Deborah Flowers, Arizona Nursery Association; Kent Newland, City of Phoenix Water Conservation and Resource Office; Brian O'Donnell, Southwest Gas Company, Cindy Pentecost, Salt River Project; Ken Quartermain, Home Builders Association of Central Arizona; Robin Stinnett, Arizona Municipal Water Users Association; and Jim Westberg, Arizona Energy Office.

CONTENTS

CHAPTER 1 - OVERVIEW

ABSTRACT	1
PROJECT PURPOSE	2
PROJECT ORGANIZATION	3

CHAPTER 2 - EFFECTS OF CONTRASTING MICROCLIMATES ON ENERGY USE OF RESIDENTIAL BUILDINGS IN PHOENIX, ARIZONA

INTRODUCTION	5
METHODS	7
<u>Site Characteristics</u>	8
<u>Measurements</u>	11
<u>Data Analysis</u>	14
RESULTS	17
<u>Comparative Weather Conditions</u>	17
<u>Cooling Load Differences</u>	24
<u>Microclimatic Differences</u>	26
SUMMARY	27

CHAPTER 3 - ENERGY SAVINGS FROM RESIDENTIAL LANDSCAPES IN PHOENIX, ARIZONA

BUILDING ENERGY AND LANDSCAPE WATER USE	
MODEL VALIDATION	31
<u>Building Validation Approach</u>	32
<u>Landscape Validation Approach</u>	34
<u>Validation Results</u>	37
<u>Summary</u>	42
LANDSCAPE SIMULATIONS FOR TYPICAL RESIDENTIAL CONSTRUCTION	
<u>Landscape Simulation Approach</u>	44
<u>Landscape Simulation Results</u>	63
<u>Single Tree Shade Results</u>	69

LANDSCAPING DESIGN GUIDELINES FOR ENERGY AND WATER CONSERVATION	71
<u>Applicability of Potential Savings</u>	71
<u>Trees and Practical Turf Areas</u>	71
<u>West Shade</u>	72
<u>East Shade</u>	73
<u>South Shade</u>	73
<u>North Shade</u>	73
<u>Wind Control</u>	74

CHAPTER 4 - CONCLUSIONS AND RECOMMENDATIONS

CONCLUSIONS	75
RECOMMENDATIONS	76
FUTURE RESEARCH	77
LESSONS LEARNED	78

APPENDIX A

References	79
----------------------	----

APPENDIX B

Landscape Simulation Reports	83
--	----

APPENDIX C

Single Tree Shade Simulation Reports	93
--	----

FIGURES

Figure 1. Daily total solar radiation and precipitation for (a) 1990 and (b) 1991 measurement periods.	19
Figure 2. Daily average, maximum and minimum AZMET air temperature for (a) 1990 and (b) 1991 measurement periods.	20
Figure 3. Daily average, maximum and minimum AZMET relative humidities for (a) 1990 and (b) 1991 measurement periods.	21
Figure 4. Daily average and maximum wind speeds and daily vector wind direction at Greenway AZMET station for (a) 1990 and (b) 1991 measurement periods.	22

	outside air temperature (T_{AZMET}) for (a) 1990 and (b) 1991 measurement periods.	23
Figure 6.	Typical differences in hourly outside air temperatures (T_{out}) for all treatments with respect to the rock control in 1990 prior to treatment installation.	28
Figure 7.	Typical differences in hourly outside air temperatures (T_{out}) for all treatments with respect to the rock control in 1991 after treatment installation.	28
Figure 8.	Differences in daily mean outside air temperatures (T_{out}) for all treatments with respect to the rock control in 1990 before treatment installation.	29
Figure 9.	Differences in daily mean outside air temperatures (T_{out}) for all treatments with respect to the rock control in 1991 after treatment installation.	29
Figure 10.	Turf effect on summertime air temperatures.	35
Figure 11.	Hourly modeled and measured energy use.	38
Figure 12.	Projected hourly summertime heatflows.	39
Figure 13.	Projected seasonal cooling elect. energy use.	40
Figure 14.	Projected daily total summertime heatflows.	41
Figure 15.	Mesiscape for 1960 one story residence.	47
Figure 16.	Mesiscape for 1985 residence facing south	48
Figure 17.	Mesiscape for 1985 residence facing east.	49
Figure 18.	Mesiscape for 1992 two story residence.	50
Figure 19.	Xeriscape for 1960 one story residence.	51
Figure 20.	Xeriscape for 1985 residence facing south.	52
Figure 21.	Xeriscape for 1985 residence facing east.	53
Figure 22.	Xeriscape for 1992 two story residence.	54
Figure 23.	Granitescape for 1960 one story residence.	55
Figure 24.	Granitescape for 1985 south facing residence.	56
Figure 25.	Granitescape for 1985 east facing residence.	57
Figure 26.	Granitescape for 1992 two story residence.	58

Figure 26. Granitescape for 1992 two story residence. .	58
Figure 27. Section and plan view of 1992 two story residence with 25 ft Mesquite tree.	60
Figure 28. Annual energy savings for 1960 one story residence.	66
Figure 29. Annual energy savings for 1985 south facing residence	66
Figure 30. Annual energy savings for 1985 east facing residence.	67
Figure 31. Annual energy savings for 1992 two story residence.	67

TABLES

Table 1 - Treatment Summary	8
Table 2 - Treatment Home Surface Areas and Water Heater Data	9
Table 3 - Air Conditioner Characteristics	10
Table 4 - Data Logger Connections For Long Term Measurements	12
Table 5 - Pre-treatment and Post-treatment Climate Summaries	24
Table 6 - Average Daily Cooling Load Ratios ± 1 Std Deviation With Respect To The Turf Control For Pre-treatment And Post-treatment Periods	25
Table 7 - Relationships Between Spatial Averaged (T_{mean} , Dependent Variable) and Point (T_{out} , Independent Variable) Measurements of Outside Air Temperature Near Treatment Houses	26
Table 8 - Characteristics of the Monitored Building .	33
Table 9 - Landscape Water Use Model Validation	41
Table 10 - Base Case Building Characteristics	45
Table 11 - Energy and Water Use Savings	64
Table 12 - Projected Air Conditioning Savings from the Base Case	69

CHAPTER 1 - OVERVIEW

ABSTRACT

Landscaping has been shown in simulation and field studies to reduce building cooling loads by affecting microclimatic factors such as solar radiation, wind speed and air temperature. A demonstration project was undertaken to determine the magnitude of landscape induced changes in microclimate on building cooling loads and water use on four typical residences in Phoenix, Arizona.

The energy use and microclimate of three unlandscaped (bare soil, rock mulch) and one landscaped (turf) home were monitored during summer 1990. In the fall, turf was placed around one of the unlandscaped houses, and shade trees planted on the west and south sides of another. Measurements continued during the summer of 1991. Total house air conditioning and selected appliance electrical data were collected, as well as inside and outside air temperatures. Detailed microclimate measurements were obtained for one to two week periods during both summers.

Maximum reductions of hourly outside air temperatures of 1 to 1.5°C, and of daily average air temperatures of up to 1°C, resulted from the addition of turf landscaping. Addition of small trees to the south and west sides of another treatment did not have a noticeable effect on air temperature.

Cooling load reductions of 10% to 17% were observed between years when well-watered turf landscaping was added to a house previously surrounded by bare soil. Addition of small trees to another bare landscape did not produce a detectable change in cooling load.

The results of the study are used as input to a standard building energy use simulation model to predict landscape effects on cooling load and water usage for three typical houses, and to develop guidelines for use of energy efficient residential landscapes in Phoenix, Arizona.

PROJECT PURPOSE

The purpose of this project is to develop procedures and methods for designing energy efficient landscapes in residential applications through computer simulation.

Because of the importance of site location, the conclusions and recommendations of this demonstration project may or may not coincide with the results of other research projects studying the effect of landscaping on energy usage and water consumption. This report presents the results of field testing a residential microclimate in Phoenix, Arizona. Other research on the influence of the urban heat island effect on energy consumption is also currently being done. Please refer to the references in Appendix A for more general information on the effects of landscaping on energy use and related subjects.

PROJECT ORGANIZATION

In addition to the overview, this report is divided into three additional chapters:

CHAPTER 2 - Provides basic information on how the demonstration project was conducted, data collected, and results obtained.

CHAPTER 3 - Explains the development of the landscape evaluation and design system, demonstrates computer model validation after landscape installation, estimates the energy savings from landscapes around three types of residential structures, and gives landscaping guidelines based on the results of this project.

CHAPTER 4 - Contains recommendations for future research and lessons learned in this project.

CHAPTER 2 - THE EFFECTS OF CONTRASTING MICROCLIMATES ON ENERGY USE OF RESIDENTIAL BUILDINGS IN PHOENIX, ARIZONA

INTRODUCTION

Rapid urbanization of cities in the United States during the past 50 years has been associated with a steady increase in downtown temperatures of about 0.25 to 2°F per decade. The rate of urban warming in Phoenix is about twice the average for large U.S. cities. Average summertime temperatures today in Phoenix are nearly 10°F warmer than 40 years ago (Balling and Brazel, 1987a).

Because electric demand of cities in the United States increases 1.5 to 2% per °F increase in temperature, approximately 3 to 8% of current electric demand for cooling is used to compensate for this urban heat island effect (Akbari et al., 1992). Warmer temperatures in cities compared to surrounding rural areas has other implications, such as increases in carbon dioxide emissions from power plants, municipal water demand, unhealthy ozone levels, and human discomfort and disease. These problems could be accentuated by global climate change, which may double the rate of urban warming. The accelerating world trend towards urbanization, especially in tropical regions, hastens the need for cost-effective urban heat island mitigation. Strategic landscaping that conserves both energy and water may be more economical than other alternatives such as light colored surfaces and urban geometry (McPherson, 1991).

Buildings, paving, and vegetation act as thermal interfaces between the atmosphere and the urban land surface. Urban vegetation measurably affects the thermal behavior of different sites within a city. Maximum temperatures within the greenspace of individual building sites may be 5°F cooler than outside the greenspace (Saito et al., 1990/91). At the larger scale of urban climate (6 miles square), temperature differences of more than 10°F have been observed between city centers and more vegetated suburban areas (Mizuno et al., 1990/91).

Urban greenspace ameliorates climate through (a) shading, which reduces the amount of radiant energy absorbed, stored and radiated by built surfaces, (b) evapotranspiration (ET), which converts radiant energy into latent energy, thereby reducing sensible heat that warms the air, and (c) air flow modification, which effects transport and diffusion of energy, water vapor and pollutants. The relative importance of these effects depends on the area, surface roughness, and configuration of vegetation and other landscape elements (Wilmers, 1990/91). Generally, the climatic effects of larger greenspaces are noticed at further distances (100 to 400 yard distance) than those associated with smaller areas (Honjo and Takakura, 1990/91). Tall trees influence surface roughness and deciduous trees contribute to seasonal differences in turbulence (Oke, 1989). Tree spacing, crown spread, and vertical distribution of leaf area with height will influence the transport of cool air and pollutants along streets by advection, and out of urban canyons by turbulent mixing from above (Oke, 1989; Barlag and Kuttler, 1990/91). Extensive tree cover in residential areas has been associated with inversions that trap cool air and pollutants below the canopy (Grant, 1991).

Several of Phoenix's most important environmental issues are climate related. A comparison of urban and rural temperatures from 1980 to 1985 found that during summertime,

average maximum temperature differences of 5°F (105 to 100°F) or more occurred between central Phoenix and surrounding rural areas (Balling and Brazel, 1987a). Minimum summertime temperature differences were twice as large (79 to 68°F). Urban warming results in higher plant evapotranspiration rates and greater need for landscape irrigation, thus increasing use of limited water resources (Balling and Brazel, 1987b). The increased duration of periods of reduced visibility due to air pollution have been linked to Phoenix's growing urban heat island (Brazel, Brazel, and Balling, 1988). Increased temperatures are also known to contribute to ozone pollution episodes, an emerging problem in metropolitan Phoenix. More intense nighttime storms during summer and associated flooding problems may be influenced by urban heat island processes (Balling and Brazel, 1987c).

City planners, energy and water resource managers, professional designers, landscape managers, and policy makers seek information to guide decisions regarding size, distribution and design of greenspace along streets, in parks, and on private properties. Answers that address the potential of greenspace to have both desirable (e.g., energy and water conservation) and undesirable (e.g., reduced solar access and air pollution dispersion) impacts on urban hydroclimate have been offered for high latitude cities (Oke, 1988; Westerberg and Glaumann, 1990/91), but little information exists for desert cities such as Phoenix.

METHODS

A pre-treatment and post-treatment design using four owner-occupied houses, with two serving as controls, was utilized. Landscapes of two houses were modified after the first summer to determine the effects of the resulting microclimate changes on air conditioning energy use in the second year. Landscapes

of the two controls were not changed. Electrical use, and inside and outside air temperature of all houses were monitored continuously from August, 1990 through October, 1991. Intensive microclimatic measurements were made both summers. This design was selected to minimize effects on cooling load that might arise from differences in building characteristics, air conditioner performance and/or occupant behavior. Effects due to different weather conditions between pre- and post-treatment comparison periods were accounted for based on comparisons with unchanged control treatments.

Site Characteristics

Two houses were surrounded by bare soil until November, 1990, at which time turf was installed around one, and shade trees, shrubs and ground cover on the west and south sides of the other (Table 1). The remaining two houses served as controls for the duration of the study, one surrounded by turf and the other surrounded by decomposed granite ground cover (Table 1). Treatments will be referred to henceforth as turf treatment, tree treatment, turf control and rock control, respectively.

Table 1 - Treatment Summary

House	Year 1	Year 2	Purpose	Occupants
1. Turf treatment	Bare soil	Turf	ET cooling	2 adults, 1 child
2. Tree treatment	Bare soil	Trees/shrubs	Shade effects	2 adults
3. Rock control	Rock mulch	Rock mulch	Control	2 adults, 1 child ^a
4. Turf control	Turf	Turf	Control	2 adults, 1 child

^a Two children after August 1991

All treatments had timer-controlled irrigation, with underground sprinklers for turf areas, and drip systems for trees, shrubs and ground covers. Irrigation schedules were adjusted to ensure plantings would have adequate water. Vegetation at the rock control was limited to small foundation plantings on the south wall providing less than 15% shade, a few small shrubs adjacent to the entry sidewalk, and two citrus trees located at the northeast corner of the lot so as to preclude shading of the house.

Houses were located within a circular area of radius 145 m in a contiguous neighborhood approximately 25 km north of downtown and 2.5 km south of the north city limits of Phoenix, Arizona. Floor plans, living areas, insulation levels, glazing, orientation and other building characteristics were similar (Table 2).

Table 2 - Treatment Home Surface Areas and Water Heater Data

House	Ceiling area (ft ²)	Window area (ft ²)				Hot water heat. cap. (gal)	Hot water heater therms	Wall area ft ²
		N	S	E	W			
Turf treatment	1616	109	54	24	24	80	medium	1359
Tree treatment	1311	88	36	59	34	40	medium	1455
Rock control	1369	85	40	38	38	80	medium	1023
Turf control	1602	108	56	24	24	52	low	1699

The all-electric houses were built in 1985 using slab on grade construction with concrete block walls (R-10) and living areas of 1311 to 1616 ft². Pitched roofs were covered with composition shingles, and ceilings with blown-in attic insulation (R-30). All houses had an east-west orientation, with front entrances facing the street to the south, and were

flanked to east and west by other houses at distances of approximately 5.5 m (18 ft). The tree treatment was an exception, having a corner lot bordering on the west. All homes had roof-mounted central air conditioning units with coefficients of performance (COP's) ranging from 2.65 to 3.06 (Table 3). Lots had approximately 21.3m (70 ft) of east-west street frontage, and were ~30.5 m (100 ft) deep.

Table 3 - Air Conditioner Characteristics

Home	Brand	Model	Size Tons	SEER	COP
1. Turf treatment	Lennox	CHP-10-411- 4P	3	9.0	2.75
2. Tree treatment	Rheem	RPNA 038J000	3	8.35	2.80
3. Rock control	Lennox	CHP-10-311- 1P	3	8.05	2.65
4. Turf control	Lennox	CHP-15-411- 1P	3	10.3	3.06

During the late summer periods for which comparisons were made, houses were occupied by two adults and from zero to two children. Homeowners agreed to maintain thermostat set points between 75 and 78°F (24 and 25.5°C). Shade screens installed on some homes were removed, and the evaporative cooler installed on the rock control was not operated for the duration of the study. In return, study participants were rebated the expected increase in cooling costs; in addition, the landscaping used to create the turf and tree treatment after the first summer, as well as landscaping done at project termination to the two controls was donated by the local landscape industry as additional incentive for homeowner cooperation.

Measurements

Long-term measurements of electrical use, landscape water flow and air temperature data were obtained for each residence using 8-channel pulse input data loggers¹ provided and operated by Arizona Public Service Company (Table 4). Data were sampled continuously, stored as 15 minute totals (kWh and a/c on time) or averages (temperature), then sent to a central computer once per week via internal modems in each data logger connected to the telephone line.

Besides monitoring various electrical loads (Table 4), actual time of air conditioner operation (i.e. on time) for each data interval was determined with a constant frequency (1 Hz) relay activated pulser². By connecting the pulsers to the input power of each air conditioner, pulses were only generated when a unit was in operation.

Since data loggers had provision for pulse input only, analog transducer to pulse interfaces³ with pulse outputs were obtained for measurement of inside and outside air temperature. Temperature measurement accuracy was within the resolution of the mercury in-glass reference thermometer (± 0.5 °C or ± 1 °F) over a temperature range of 0.5 to 50°C (33 to 122 °F), which was established in a laboratory calibration using a stirred water bath. Water meters with pulse outputs⁴ were used to monitor landscape water use. Water meter accuracy was $\pm 1.5\%$ of measured flow over the range of 0.25 to

¹Sentry 100 solid state recorder, P/N 125291030, Process Systems, Inc., Charlotte, NC.

²Pulser board, P/N 112492020, Process Systems, Inc., Charlotte, NC.

³TFI-202 temperature interface, Devices & Services Co., Dallas, TX.

⁴Model MM3 5/8" x 3/4" Magnetic Multi-jet water meter, with contact head electrical output assembly, 1 gallon per pulse, Master Meter, Inc., Longview, TX.

20 gpm, based on manufacturer's specifications. Sensors for inside air temperature were located in centrally located hallways approximately 2 cm below ceiling level near ceiling ducts for cold air return. Sensors were located within 1 m and approximately 1 m above the thermostats. Outside air temperature sensors were located in Gill type radiation shields⁵ mounted to the exterior wall of each house approximately 1.5 m above ground level.

Table 4 - Data Logger Connections For Long Term Measurements

Ch	Variable	Comments			
1	Total house kWh				
2	A/C kWh				
3	Hot water heater kWh				
4	A/c time of operation	relay activated pulser input			
	Sampling period	Turf	Trees	Rock con.	Turf con.
5	1990 (8/90 - ~4/91)	Range	Range	Spa equip	Pool equip
	1991 (~4/91 - 12/91)	Dryer	Dryer	Dryer	Pool equip
6	1990 (8/90 - ~4/91)	Dryer	Dryer	Irri-gation	Irri-gation
	1991 (~4/91 - 12/91)	Irri-gation	Irri-gation	Irri-gation	Irri-gation
7	Inside air temperature	Ceiling mount, near cold air return			
8	Exterior air temperature	North wall mount, ~1.5 m height			

⁵R.M. Young Company model 41301.

Intensive Measurements of microclimate around the test houses were taken in September, 1990, and June and July, 1991. Air temperature variation around the houses was measured using fine wire thermocouples installed at 50, 100, 200, and 300 cm heights on 9 masts. In 1990, two masts were placed on each side of a house to determine air temperature variation with aspect and height, and compute an average temperature for the air volume immediately surrounding the house. In 1991, one mast was situated per side of each house so that measurements could be made simultaneously at paired treatments. Wind speed was measured at a height of 200 cm on each side of a single house in 1990, and at two houses simultaneously in 1991. At the same time, measurements of air temperature, relative humidity, wind speed, wind direction, net radiation, total solar radiation, and reflected solar radiation were obtained on the south sides (front yards) of each treatment at a height of 200 cm.

Shading of building walls for the shade treatment was determined by measuring the overall extent of shaded area and the density of shade within that area. Shaded area was found by establishing a grid system on the sunlit walls, and estimating the percentage shade in each element. Shade density was estimated by measuring solar transmittance in the visible portion of the solar spectrum by sampling photosynthetically active radiation (PAR, 0.4 to 0.7 μm wave band) using a portable integrating radiometer⁶.

This device uses a linear array of radiation sensors to sample radiation along its length. Transmittance on a horizontal surface is calculated as the quotient of average radiation from many samples under the canopy divided by the total incident radiation above the canopy. For a vertical wall, the instrument is oriented vertically and parallel to the building wall, with readings for radiation outside the

⁶Sunfleck Ceptometer, Decagon Devices, Pullman, WA, USA.

canopy taken with the same sensor orientation, except located just outside the horizontal extent of the shading vegetation.

Since the PAR sensors used in this device are not sensitive to the near infrared (IR) portion of the solar spectrum (0.7 - 3 μm), and leaf transmission is about 20% in this region compared to the visible (PAR) portion of the spectrum, it is expected that these results may underestimate to some degree the full extent of near IR radiation transmitted through the leaves. Assuming equal amounts of solar energy in the PAR and near IR wave bands (Monteith and Unsworth, 1990), 10% greater transmission in the near IR would result in about 5% greater transmission through the leaves for the entire 0.3 to 3 μm wave band. Since transmission through the leaves is a relatively small part of the total transmitted radiation compared with radiation transmitted through gaps in the canopy, use of PAR to estimate transmission of solar radiation should result in little error.

Data Analysis

Cooling energy savings were determined from changes in measured air conditioning use between pre-treatment and post-treatment periods selected for similarity in weather conditions. Data became available from all treatments August 14, 1990. Approximately week long periods in August and September of 1990 and 1991 were chosen for analysis to minimize the effect of day to day variability on the results; longer periods with comparable climatic conditions did not occur. Cloudy or rainy periods were avoided due to the lack of microclimatic contrast expected to be generated by the landscapes under such conditions, and because of extreme climatic variability resulting from thunderstorm activity characteristic of these periods. Factors used for identifying similar periods climatically in both years were air temperature, relative humidity, total solar radiation, wind

speed and direction obtained from an Arizona Meteorological Network (AZMET) weather station (Brown 1987). This station was located approximately 4 km to the SSW, which was in the general direction of the prevailing winds during afternoon peak cooling periods. To account for differences in air conditioner set points between treatments and outside air temperature between years, data selection was based on the difference between AZMET outside air temperature and inside temperature for each house, rather than on outside air temperature alone.

To minimize effects of differences in building characteristics or occupant behavior, cooling loads were normalized by forming ratios of turf and tree cooling loads with those from turf and rock controls. Assuming that all factors affecting cooling load except landscape installation remained constant during the experiment, a decrease in these ratios with respect to the controls after landscape installation treatments would indicate a reduction in cooling load due to microclimate modification.

To further refine the focus on cooling load differences due to microclimate only, and to remove biases resulting from differing occupant behavior, further analysis was done in which internal heat gain was removed from calculated cooling load before cooling load ratios were formed. Total cooling load (CL) for each house (1) was calculated by multiplying air conditioning kWh by the appropriate COP (Table 3).

$$\underline{CL} = \underline{kW_{Ac}} \underline{COP} \quad (1)$$

Cooling load (2) is the result of opaque conduction (O) through walls and roof, glazed conduction (G) through windows, infiltration (I), and internal heat gain (INT).

$$\underline{CL} = \underline{O} + \underline{G} + \underline{I} + \underline{INT} \quad (2)$$

Internal heat gain was determined by assuming that all electrical loads with the exception of those external to the conditioned space were converted into internal heat gain (3).

$$INT = kW_{TOT} - (kW_{AC} + kW_{POOL} + kW_{HW} + 0.8kW_{Dryer} + kW_{EXT}) \quad (3)$$

External loads included air conditioners (kW_{AC}), pool equipment (kW_{POOL}), hot water heaters (kW_{HW}), clothes dryers (kW_{Dryer}) and miscellaneous electrical appliances (kW_{EXT}). Hence, the cooling load due only to environmental influences, i.e. with internal gains removed, was determined as (4)

$$CL - INT = kW_{AC}(COP+1) - kW_{TOT} + (kW_{POOL} + kW_{HW} + 0.8kW_{Dryer} + kW_{EXT}) \quad (4)$$

Hot water heaters were located in unconditioned garages; since clothes dryers are vented externally, it was assumed that 80% of the resultant heat was dissipated externally, with the exception of turf treatment, where 100% external dissipation was assumed since the laundry room was not air conditioned in this case. Further, a constant external load of 20 kWh was assumed (ASHRAE, 1985) to account for the refrigerator located in the turf treatment garage. It was not possible to monitor dryer electrical use for the treatments with the swimming pool or spa (1990 only). In these cases, dryer electrical use was estimated from residual electrical use, confirmed with actual dryer measurements at times and locations when these data were available. Residual electrical use is the remainder after all measured loads (air conditioner, hot water heater, and pool/dryer) were subtracted from total house electrical use. Clothes dryers were left as the primary large electrical load in this residual. Their

operation was observed to be almost always associated with step increases in the calculated residual. Using a step threshold in the residual data of between 0.5 and 0.8 kWh for hourly data, it was possible to convert the sudden surges associated with dryer operation into dryer electrical use. Comparisons between this residual and actual dryer electrical use in treatments with actual dryer data revealed good agreement between measured and estimated dryer electrical use.

Previously reported results (Alves et al. 1991) indicated that air temperature varies relatively little with height and aspect for homogeneous landscapes around these houses. Potential bias in outside air temperature introduced by point measurement, and placement of temperature sensors near the north wall of each residence (T_{out}), was investigated by comparison of T_{out} with air temperature measurements made in four locations at heights of 0.5, 1, 2 and 3 m above the ground. Data were obtained simultaneously at two residences at a time from June 24 to July 2, 1991 for all four building aspects, (a total of 16 to 20 individual measurements). All temperatures were averaged for each yard, creating a mean temperature representative of each building's surroundings (T_{mean}). Regression analysis was used to compare T_{out} and T_{mean} .

RESULTS

Comparative Weather Conditions

Weather conditions for both measurement periods were characterized by clear skies and warm temperatures, with peak total solar radiation ranging from 20 to 30 MJ m⁻² except for brief cloudy periods when occasional precipitation occurred in the form of thunderstorms (Figure 1). Average temperatures ranged from 21 to 33°C in 1990, and 26 to 34°C in 1991 (Figure 2). Average relative humidities had a wide range (Figure 3), increasing from low values characteristic of the

desert during outbreaks of humid air associated with summer thunderstorms. Winds averaged less than 2 m s^{-1} during clear weather, with higher winds generally associated with monsoon activity. Wind directions tended to be from southeast to southwest on average, with a tendency for a more easterly component during stormy periods (Figure 4).

Inside/outside temperature differentials ($T_{in} - T_{AZMET}$) were used to test for similarity between years (Figure 5), instead of just outside air temperature. This is because cooling energy use is dependent on temperature differences, which were also a function of thermostat set points. Time periods for which cooling load comparisons between years could be made were somewhat limited due to the lack of periods during which both weather conditions and inside/outside air temperature differentials were similar.

In general, August and September 1991 were warmer than in 1990 (Figure 2). In addition, thermostat set points often differed, despite the best efforts and intentions of study participants. In 1990, despite apparent good agreement between daily average inside/outside temperature differentials (Figure 5), the turf treatment thermostat was often set higher during midday, and several weeks were required to correct this problem. The result was much reduced midday air conditioning use for 1 to 6 hour periods for this treatment, followed by a surge later in the afternoon when the thermostat was reset. Consequently, the 1990 baseline comparison period selected was August 26, 1990 and September 3, 6, 9, 10, 1990, when air conditioners operated continuously and inside/outside air temperature differentials and weather conditions were comparable.

Data were unavailable for the rock control from September 7 to October 2, 1990 due to data logger failure. In 1991 inside/outside air temperature differential was consistently larger for the rock control, and occasionally for the turf control (Figure 5). Hence, the turf control was used as the basis of comparison for energy use differences between years.

Figure 1 - Daily total solar radiation and precipitation for (a) 1990 and (b) 1991 measurement periods.

Figure 2 - Daily average, maximum and minimum AZMET air temperature for (a) 1990 and (b) 1991 measurement periods.

—■— rh.max —+— rh.min —*— rh.mean

Figure 3 - Daily average, maximum and minimum AZMET relative humidities for (a) 1990 and (b) 1991 measurement periods.

Figure 4 - Daily average and maximum wind speeds and daily vector wind direction at Greenway AZMET station for (a) 1990 and (b) 1991 measurement periods.

Figure 5 Differences in daily average inside air temperatures (T_{in}) for each treatment and outside air temperature (T_{AZMET}) for (a) 1990 and (b) 1991 measurement periods.

Table 5 summarizes climate parameters and air temperature differentials for periods in August and September 1991 most similar to the 1990 baseline period.

Table 5 - Pre-treatment and Post-treatment Climate Summaries

Dates	Solar radiation (MJ m ⁻²)	T _{AZMET} (°C)	T _{AZMET} - T _{in} (°C)	r.h. (%)	Wind (m s ⁻¹)
1990:					
8/26, 9/3, 9/6, 9-10	23.6 ±2.7	31.0 ±1.9	-5.8 ±2.0	49.6 ±16.3	1.5 ±0.4
1991:					
8/13 - 19	26.0 ±1.3	32.9 ±0.2	-8.3 ±0.5	32.9 ±7.5	1.8 ±0.2
8/20 - 26	21.9 ±4.3	33.0 ±0.6	-8.1 ±0.6	36.9 ±14.2	2.1 ±0.5
8/28-30, 9/1-9/4	23.3 ±2.6	30.9 ±1.3	-6.4 ±1.0	48.4 ±7.7	2.0 ±0.4

Note: Values given are averages of daily values ±1 standard deviation. Values listed for (T_{AZMET} - T_{in}) are for all treatments combined.

Cooling Load Differences

Cooling load ratios for the turf treatment, when corrected for internal gains (CL-INT), were consistently lower by 18 to 21% after turf was installed (Table 6). Reductions were somewhat smaller (10 to 17%) when no corrections were made to CL. Removing only the external gain due to the swimming pool equipment at the turf control increased the reductions to 18 to 19%, which suggests that only relatively large external gains not common to all buildings in a test need to be separately accounted for. Inside/outside air temperature differentials (recall that AZMET outside air temperatures were used in calculating differentials) were up to 2.5°C larger

Table 6 - Average Daily Cooling Load Ratios ± 1 Standard Deviation With Respect To The Turf Control For Pre-treatment And Post-treatment Periods

Dates	$CL_{\text{Turf or Tree}}/CL_{\text{Turf control}}$		$(CL-INT)_{\text{Turf or Tree}}/(CL-INT)_{\text{Turf control}}$	
	Turf Treatment	Tree Treatment	Turf Treatment	Tree Treatment
1990:				
8/26, 9/3, 6, 9-10	1.15 ± 0.13	1.04 ± 0.12	1.11 ± 0.17	1.10 ± 0.17
1991:				
8/13 - 19	1.01 ± 0.17	0.98 ± 0.11	0.90 ± 0.12	1.03 ± 0.07
8/20 - 26	0.98 ± 0.05	1.06 ± 0.04	0.91 ± 0.06	1.12 ± 0.09
8/28-30, 9/1-9/4	1.05 ± 0.10	1.07 ± 0.08	0.93 ± 0.09	1.11 ± 0.11

during 1991, which would be expected to increase relative energy use. However, even when the differential was only 0.6°C larger during the last period in 1991 (8/28-30, 9/1-9/4/91), the reduction in cooling load ratio was only slightly less (18%). Cooling load ratios for the tree treatment showed essentially no change between years, regardless of internal gain corrections.

Homeowner interviews revealed that no lifestyle changes occurred during the experiment that could be expected to alter basic energy use patterns, except in the case of tree treatment, where a change of occupants occurred in 1991. In evaluating the situation, the homeowner reported increased use of hot water and clothes dryer during the second year of the project as well as an overall impression of increased energy use. While this suggests the possibility that potential cooling load reductions may have been offset by the reported lifestyle changes, no change in energy use patterns are evident when internal heat gains were accounted for (see Table 6). A more likely explanation is that the shade potential of the relatively small trees available to provide

shade for this treatment was not large enough to provide noticeable cooling load reduction.

Microclimatic Differences

Average outside air temperatures (T_{mean}) were closely correlated with the point measurements of air temperature on the north wall of each house (T_{out} , Table 7). T_{out} tended to overestimate T_{mean} somewhat more for the two treatments without vegetative cover (tree treatment had rock mulch ground cover on its north side) than for the turf control ($\sim 0.6^{\circ}\text{C}$ compared with $\sim 0.2^{\circ}\text{C}$ at 30°C). Consequently, comparisons of outside air temperatures between treatments based on T_{out} which follow may overstate those differences by $\sim 0.5^{\circ}\text{C}$ when turf treatment and turf control are compared with rock control or tree treatments.

Table 7 - Relationships Between Spatial Averaged (T_{mean} , Dependent Variable) and Point (T_{out} , Independent Variable) of Outside Air Temperature Near Treatment Houses

Treatment	Averaging Period	Slope	Intercept	r^2
Tree	6/24-28/91	.9227	1.69	0.97
Rock control	6/29-7/2/91	.9530	0.78	0.99
Turf control	6/24-7/2/91	.9848	0.21	0.99

Hourly outside air temperatures differences between turf and tree treatments and rock control before landscape installation were typically less than 1°C , while peak differences between turf control and rock control approached 2°C (Figure 6). After treatment installation, maximum differences were about 2.5°C for both turf treatments compared

to rock (Figure 7), for a net measured reduction in maximum temperature of between 1 and 1.5°C due to installation of turf. Similar cooling was observed both for the turf treatment as well as the turf control.

Daily mean air temperatures (T_{out}) for all treatments typically agreed to within 0.5°C with the rock control for the entire comparison period in 1990 before treatment installation (Figure 8). Differences increased after treatment installation in 1991 up to 1.3°C in early August (Figure 9), gradually decreasing later in the year, for a net observed reduction of up to about 1°C (2°F) due to turf installation.

SUMMARY

Cooling load reductions of 10 to 17% were observed between years when well-watered turf landscaping was added to a house previously surrounded by bare soil. Addition of small trees to another bare landscape did not produce a detectable change in cooling load. Maximum reductions of hourly outside air temperatures of 2 to 3°C, and of daily average air temperatures of up to 1°C, accompanied the addition of turf landscaping. Addition of small trees to the south and west sides of another location did not appear to have a noticeable effect on air temperature.

Differences in cooling loads that may have resulted from dissimilar weather conditions, changes in occupant behavior or other causes between years were minimized by expressing results relative to controls that remained unchanged during the experiment, and by considering multiple comparison periods of several days in length. Analysis in the following chapter will be used to confirm that microclimatic changes of the order of those observed could indeed account for the magnitude of cooling load reductions calculated. Subsequent analysis will also investigate more fully the extent of shading at the tree treatment and its potential for cooling load reduction.

Figure 6 — Typical differences in hourly outside air temperatures (T_{ou}) for all treatments with respect to the rock control in 1990 prior to treatment installation.

Figure 7 — Typical differences in hourly outside air temperatures (T_{ou}) for all treatments with respect to the rock control in 1991 after treatment installation. See Fig. 6 for legend.

Figure 9 — Differences in daily mean outside air temperatures (T_{out}) for all treatments with respect to the rock control in 1991 after treatment installation.

Figure 8 — Differences in daily mean outside air temperatures (T_{out}) for all treatments with respect to the rock control in 1990 before treatment installation.

CHAPTER 3 - ENERGY SAVINGS FROM RESIDENTIAL LANDSCAPES IN PHOENIX, ARIZONA

BUILDING ENERGY AND LANDSCAPE WATER USE MODEL VALIDATION

Before using computer models to estimate potential energy and water impacts of different landscapes, the models were calibrated and validated to insure that results represent what actually occurs in the real world. Calibration refers to adjusting model assumptions and inputs, while validation refers to comparing measured and modeled results. The objectives of model validation were three-fold:

1. Calibrate the building energy analysis program MICROPAS 4.0 so that there is less than a 15% difference between modeled and measured air conditioning energy use for a typical summer day prior to landscape installation. Discrepancies of less than 15% between measured and modeled results are considered good for building energy analysis modeling of this type.
2. Calibrate weather data to account for ET cooling from turf so that air conditioning energy savings modeled with MICROPAS fall within the 10 to 17% savings that were measured.
3. Calibrate the landscape water use model so that there is less than a 15% difference between modeled and measured water use.

In the previous section it was noted that trees had little measurable effect on cooling energy use, however well-watered turf reduced cooling by 10 to 17%. Because there was

little measurable impact of the tree treatment on cooling energy use, only the turf treatment can be validated. Methods used to validate building, landscape, and water models for the turf treatment are outlined below.

Building Validation Approach

MICROPAS 4.0 was used to model building energy use. MICROPAS is a microcomputer-based program that provides hour-by-hour estimation of building energy use based on the building's thermal characteristics, occupant behavior, and specific weather data.

A typical summer day was used as the basis for energy use model validation. The typical summer day was determined using average hourly data for a fourteen day period extending from August 17 through August 30, 1990 (pre-treatment). The typical day is more representative than a single day because it includes a variety of weather conditions and occupant behaviors (e.g., weekday vs. weekend). Also, it permits comparisons of important hourly differences that can influence peak demand.

Building, Occupant, and Climate Data. Information on the building envelope, heating and air conditioning systems, and other characteristics were obtained from an energy audit conducted by Arizona Public Service Company (Table 8). Hourly internal gains were calculated as residuals using measured data for total electricity and various appliances, as explained in Chapter 2. Hourly internal temperatures were measured and used to create an hourly schedule for thermostat settings. Average hourly temperature data were calculated from measurements recorded from the sensor on the north wall, while solar radiation and wind data were obtained from the Greenway AZMET site (4 km to SSW).

Table 8 - Characteristics of the Monitored Building

Item	TURF Building
Floor Area (sf)	1,616
Volume (cu ft)	12,928
Number Stories	1
Front Orientation	South
Window Panes	1 (u = 1.28)
Window Area (sf)	South = 54 East = 24 North = 109 Total = 187
Window Shading Coefficient	
Glass Only	0.77
Drapes or Blinds	0.48
Wall Insulation	R - 10
Attic Insulation	R - 30
Slab Mass (sf)	
Exposed	176
Covered	1,440
Infiltration Class	Tight
Internal Gain (kWh/day)	18.7
Gas Furnace Eff. (HSPF)	6.6
Air Conditioner (SEER)	Heat Pump = 9
Thermostat Settings	variable: night = 76°F midafternoon = 82°F

Calibration. Adjustments were made to variables that were not documented during the energy audit and are difficult to exactly quantify because they depend on occupant behavior. Variables used to calibrate MICROPAS include infiltration rates (ASHRAE values for medium and tight construction assuming variable infiltration rates), shading coefficients of windows and drapes, and solar absorptivity of walls and roof surfaces. The type of drapes or blinds and extent to which they are closed during daylight hours influences solar gains. Similarly, wall/roof surface color and shading by attached unconditioned space (e.g., garage), as well as adjacent fences, buildings, and vegetation can impact cooling loads.

Landscape Validation Approach

The objective of landscape calibration and validation was to obtain modeled air conditioning energy savings within the 10 to 17% range of measured savings associated with ET cooling from the turf treatment (Figure 10). To accurately model and test the effects of ET cooling on air temperature and air conditioning energy use, three steps were followed. First, hourly outside air temperature reductions were calculated for a typical summer day using measured data for the pre-treatment and post-treatment turf. Second, these temperature reductions were converted into hourly percentage reductions from the pre-treatment air temperatures to normalize for daily and seasonal temperature changes. Finally, the normalized temperature reductions were incorporated into a MICROPAS weather file and building cooling energy use reductions were compared using the base case (pre-treatment) and modified (turf treatment) weather files for Phoenix.

Landscape water use is a complex phenomenon that varies with climate, vegetation structure, irrigation technology, and the occupant's water management behavior (McPherson, 1991b).

Figure 10 - Turf effect on summertime air temperatures.

To model landscape water use for this study, a water budget is used. This approach simplifies many of the variables that influence actual irrigation use. More municipalities are using the water budget model for water-efficient landscape guidelines. The objective is to achieve no greater than a 15% difference between modeled and measured landscape water use.

Water Budget Model. The simple water budget formula approximates monthly, site-specific landscape water requirements:

$$\text{Monthly budget} = (\text{Monthly } ET_0)(\text{Adjustment Factor})(\text{Vegetation Area sq ft})$$

where ET_0 is reference evapotranspiration (ET), the ET of a broad expanse of well-watered, 4 to 6 inch tall cool-season grass. ET_0 serves as a bench mark for determining plant water requirements and is not in itself an accurate measure of plant water requirements for a given species. Monthly ET_0 data is

available for several Phoenix locations where AZMET weather stations make continuous measurements of temperature, humidity, wind, and solar radiation. The ET_0 adjustment factor refines the water budget by incorporating specific information on irrigation and plant species:

$$\text{Adjustment Factor} = \text{Plant Factor} / \text{Irrigation Efficiency (IE)}$$

where the Plant Factor quantifies the water requirement of an individual species (also termed crop coefficient) as a percentage of ET_0 . Plant factors have been established for turfgrass and a few ornamental plants. Generally, plants requiring 80% of ET_0 are considered high water use, while plants requiring 50% and 30% are considered moderate and low water users, respectively.

Irrigation Efficiency accounts for the fact that irrigation inefficiencies contribute to landscape water consumption. Two factors contribute to IE:

$$IE = (\text{Hardware Efficiency}) (\text{Management Efficiency})$$

Hardware efficiency is calculated as a measure of the uniformity of application. System efficiencies for properly designed and installed spray and drip systems are generally 65 to 75% and 80 to 95% respectively. Management efficiency is a function of system maintenance and scheduling. Little data are available to quantify management efficiency, but a factor of 80 to 90% is considered normal.

Calibration and Validation. The water budget was validated using measured data for the turf control from April through September, 1991. The turf treatment was not used for validation because data was not available after May 24, 1991 due to an instrument malfunction. To validate the model, monthly measured water use totals were compared to modeled totals. For spray irrigated turf and trees, irrigation efficiencies were assumed to be 75% for hardware and 85% for

management. For drip irrigated trees, hardware and software efficiencies were set at 90% and 85%, respectively.

Plant factors were adjusted within reasonable bounds for model calibration. Turfgrass research indicates that optimum irrigation for warm season grasses is 60% of ET_0 (Gibeault, 1991). Because turf at the turf control residence appeared green and healthy throughout the summer, it was not likely to receive less than 50% of ET_0 . The turf may have been over-irrigated, but this was not observed. Thus, we set turf plant factor adjustment bounds at 50% and 70%.

Validation Results

Building Validation. Initial comparisons between measured and modeled air conditioning energy use indicated model overestimation of total daily use. Further analysis of hourly cooling loads revealed that daytime loads were overestimated and nighttime loads were underestimated. This finding suggested that modeled solar loads were too high. Two factors were determined to largely account for these model overestimates:

1. Shade from adjacent buildings and fences to the east and west of the turf home cast significant amounts of shade in late August before 9:00 a.m. and after 3:00 p.m.
2. Irradiance on the south-facing garage had relatively little impact on cooling load because this space is not cooled.

To better account for shading and irradiance on the unconditioned garage, the solar absorptivity of walls was adjusted from the normal value of 0.5 to 0.3 for east and west walls and to 0.2 for north and south walls. The ground reflectivity was lowered from 0.20 to 0.16 to account for less reflection from adjacent shaded surfaces onto the building.

Infiltration was adjusted using ASHRAE values for a tight well-constructed structure, which reduced cooling loads.

These adjustments significantly improved model performance by making the model building more representative of the actual building. Although the model still over-estimated daytime cooling energy use, the daily totals were well within the 15% target (Figure 11).

Figure 11 - Hourly modeled and measured energy use.

Air conditioning energy use for the typical summer day was modeled as 35.54 kWh, or 9.7% greater than the measured total of 32.08 kWh. A peak demand of about 3 Kw occurs at 7:00 p.m. for both the measured and modeled cases. Modeled heat flows for the typical summer day illustrate the relative magnitude of different heat gain pathways for the monitored structure (Figure 12). Internal gains peak at 6:00 a.m. and then again at 9:00 p.m., about 2 hours after the occupants return from work. Solar gains through opaque and window

Figure 12 - Projected hourly summertime heatflows.

(glazing) surfaces peak at 5:00 p.m. when solar angles are nearly perpendicular to the walls. Conductive heat gains gradually increase as temperatures rise, peak at 7:00 p.m., and then decrease. Infiltration heat gain follows a pattern similar to that of conductive gains, but the magnitude of gain is substantially less.

Daily total heat flows for the monitored structure on the typical summer day summarize the relative magnitudes of each heat gain pathway and can be used to infer the potential impacts of different landscape strategies (Figure 13). Air temperature reductions associated with ET cooling will reduce conductive heat gains, while tree shade will reduce solar gains.

Landscape Validation. Landscape validation results reveal a reduction in total annual cooling energy use of 11.4% for the turf simulation (4,526 kWh), with modified weather data, compared to the base case (5,111 kWh), using unchanged weather data. This reduction falls within the targeted validation objective of 10 to 17%, the reduction measured after turf installation.

Figure 13 - Projected seasonal cooling electric energy use.

Air conditioning energy used during the summer season was 8.7% lower for the simulated turf landscape compared to the base case. Seasonal differences in annual cooling energy use between buildings with and without turf reflect increased ET cooling effects during summer months when ET rates and ambient temperatures are highest (Figure 14). Reduced air temperatures associated with turf lowered peak demand by 4% (from 4.78 kW to 4.59 kW) and peak day consumption by 5.5% (from 66.8 kWh to 63.2 kWh). These results provide a conservative estimate of turf treatment effects and demonstrate good agreement with measured data.

Landscape Water Use Model Validation. Total modeled landscape water use (69,368 gal) underestimated measured use (73,164 gal) by 5%, with the plant factor for turf set at 0.55. Monthly percentage differences ranged from -35 to +46%, indicating that actual use was extremely variable relative to modeled use. Weekly variation in consumption as expressed by the standard deviations of measured use, ranged from 30 to 50% (Table 9).

Figure 14 - Projected daily total summertime heatflows.

Table 9 - Landscape Water Use Model Validation

Month	1991 ET _o	Measured Water Use (gal)	Modeled Water Use (gal)	Difference (gal) Modeled - Meas.	Difference %
April	7.85	14,640	10,082	-4,558	-31
May	10.16	14,787	13,049	-1,738	-12
June	9.65	8,490	12,394	3,904	46
July	10.35	9,176	13,293	4,117	45
August	8.91	12,121	11,444	-677	-6
September	7.09	13,950	9,106	-4,844	-35
Total	54.01	73,164	69,368	-3,796	-5

Changes in occupant-related management that influenced irrigation scheduling are responsible for this variability. Examples of activities that change irrigation regimes include impacts associated with vacations, rainfall events, yard work,

and seasonal changes in irrigation schedules. The landscape water use model assumes constant management efficiency, thus missing variability occurring on a daily and weekly basis. Nevertheless, by providing a close approximation of total water use, the model is acceptable for modeling annual and seasonal landscape water use.

Summary

Validation studies of three models have been presented. MICROPAS was calibrated and validated with the turf treatment building. After calibration to better represent shade from surroundings on solar heat gains, modeled air-conditioning use was 9.7% greater than measured use for the typical summer day. This value fell within the targeted objective of 15%.

The ability to accurately model effects of well-watered turf on ambient temperature and air-conditioning energy use was tested using MICROPAS and unchanged versus modified weather files. An 11.4% reduction in annual cooling energy use for the turf simulation fell within the measured range of 10 to 17%.

The landscape water use model was validated using 6 months of recorded data from the turf control. Total modeled water use was 5% less than measured use and met the objective of less than 15% difference between measured and modeled consumption.

LANDSCAPE SIMULATIONS FOR TYPICAL RESIDENTIAL CONSTRUCTION

Landscaping can mitigate urban heat islands, conserve precious energy and water resources, and increase quality of life in our desert cities. The cost-effectiveness of trees was examined by the Arizona Corporation Commission. Their

analysis assumed that a single tree on the west side of a Phoenix residence could reduce annual air conditioning use by 250 kWh and peak demand by 0.33 kW five years after planting. They found that cooling energy savings from trees could meet the need for electric energy services at a lower cost than the generation of electricity. Greater potential savings were predicted from computer simulations done at Lawrence Berkeley Laboratory: 873 kWh and 0.80 kW from a mature tree shading the west wall.

Xeriscape guidelines recommend using drought tolerant plants and practical turf areas to conserve water. Computer simulations for typical Tucson landscapes found that for low-water-use trees, water costs were equivalent to about 20% of energy savings from shade (McPherson and Dougherty, 1987). However, water costs could more than double energy savings for high-water-use tree species. The objective of practical turf areas is to limit turf to areas where physical use and visual impact is greatest. Although this results in reduced water use, the impact of reduced turf on air conditioning use is unclear. Design guidelines regarding optimal extent of lawn for both energy and water efficiency have not been addressed through research until now. Water conservation ordinances and incentives that result in removal of most lawn and trees may actually increase net energy-water costs due to greater air conditioning loads in Phoenix (McPherson, 1990).

Because landscapes influence both residential energy and water use, guidelines that address issues such as optimal amounts and configuration of turf around the home and optimal tree locations for shading are needed. The following section evaluates the energy and water savings associated with different landscapes, tree locations, and residential buildings in Phoenix.

Landscape Simulation Approach

Methods used to run two sets of simulations are described. The first set of simulations model shading effects from three mature trees (Grantescape) and ET cooling from extensive turf (Mesiscapes) and reduced turf (Xeriscape) on space conditioning energy use of four base case buildings. Water costs are incorporated to calculate net energy-water savings from the unshaded base cases. These landscape simulations provide a basis for comparing savings from tree shade versus ET cooling from turf, as well as savings potential across building types. A second set of simulations were run to determine the effects of shading only, from a single mature tree opposite west, east, and south walls of the four base case buildings.

Base Case Buildings. Four single family detached wood-frame homes were selected and named based on approximate date of construction. The 1960 building is a 1-story, 1,500 sq ft residence (Table 10). Relatively low insulation values (R-7 wall, R-19 attic) and single pane windows are characteristic of this type of older house. However, efficiencies of the natural gas furnace and air conditioner are assumed to be comparable with current HVAC equipment.

Two 1-story, 1,616 sq ft 1985 buildings are actually the same structure with different orientations (Table 10). Monitored energy use data were used to validate cooling energy use by the 1985-South residence (i.e., turf treatment). The 1985-East building faces east rather than south. In contrast to the other buildings, glazing is not equally distributed across the four walls. Thus, differences in orientation can significantly influence solar gains. Reduced wall solar absorptivities and window shading coefficients are assumed based on the previous calibration. The 1985 buildings have single pane windows and moderate insulation (R-10 wall, R-30 attic). Unlike the other buildings, this structure uses a heat pump for heating and cooling.

Table 10 - Base Case Building Characteristics

Item	1960	1992	1985
Floor Area (sf)	1,500	1,761	1,616
Volume (cu ft)	12,750	15,588	12,928
Number Stories	1	2	1
Front Orientation	East	East	South (East)
Window Panes	1 (u = 1.35)	2 (u = 0.87)	1 (u = 1.28)
Window Area (sf)	75 per wall Total = 300	88 per wall Total = 352	South = 54 East = 24 North = 109 Total = 187
Window Shading Coef.. Glass Only Drapes or Blinds	0.77 0.78	0.88 0.78	0.77 0.48
Wall Insulation	R - 7	R - 13	R - 10
Attic Insulation	R - 19	R - 30	R - 30
Slab Mass (sf) Exposed Covered	375 1,125	167 758	176 1,440
Infiltration Class	Medium	Medium	Tight
Internal Gain (Btu/day)	42,500	46,415	44,240
Gas Furnace Eff.	0.78	0.78	HSPF = 6.6
Air Conditioner (SEER)	10	10	Heat Pump = 9
Thermostat Settings Summer Cooling Winter Heating	78 68 day, 60 night	78 68 day, 60 night	78 68 day, 60 night

The 1992 building is a 1,761 sq ft, 2-story home typical of current energy-efficient building construction (Table 10). This buildings has four bedrooms and a garage attached to the front of the building. Double pane windows and high insulation values (R-13 wall, R-30 attic) characterize this example of new residential construction.

Landscapes Simulations. MICROPAS simulations were run for three landscapes to quantify effects of shading and ET cooling on energy costs. Landscape water costs associated with each treatment were also simulated.

Each of the four buildings described above were sited on 7,280 sq ft lots (70 ft x 104 ft). Lot size was assumed constant to provide a stable basis for comparison of energy and water costs across landscapes. Also, each landscape contained three mesquite trees and 34 low-water-use shrubs. The trees were located for desired building shade as available planting space allowed on each lot. Procedures for modeling tree shading and tree, shrub, and turf water use are described later in this section.

Mesiscap. The Mesiscap design was based on the actual landscape of the turf treatment. Turf covers 4,160 sq ft in the 1985 building lots, and 4,800 sq ft in the 1960 and 1992 lots (Figures 15-18)

Xeriscap. Lawn area was reduced by 67% in the Xeriscap designs compared to the Mesiscapes (Figures 19-22). Turf was limited to the backyard, where it is likely to receive the most use. The 1985 Xeriscapes contained 1,390 sq ft of turf and the 1960 and 1995 Xeriscapes contained 1,584 sq ft of lawn.

Granitescap. The Granitescap included the same three mesquite trees and low-water-use shrubs as the other landscapes, but no lawn (Figures 23-26).

Figure 15 - Mesiscape for 1960 one story residence.

0 20 40 60
 Scale Feet

Figure 16 - Mesicape for 1985 residence facing south

Figure 17 - Mesiscape for 1985 residence facing east.

Figure 18 - Mesiscape for 1992 two story residence.

Figure 19 - Xeriscape for 1960 one story residence.

Figure 20 - Xeriscape for 1985 residence facing south.

Figure 21 - Xeriscape for 1985 residence facing east.

Figure 22 - Xeriscape for 1992 two story residence.

Figure 23 - Granitescape for 1960 one story residence.

Figure 24 - Granitescape for 1985 south facing residence.

Figure 25 - Granitescape for 1985 east facing residence.

Figure 26 - Granitescape for 1992 two story residence.

Simulating Tree Shading. The velvet mesquite tree (*Prosopis velutina*) was chosen as the representative species for energy simulation. This species meets many criteria for a desirable yard tree. It grows at a rapid rate to 20 to 40 ft, and has an umbrella-shaped crown. It is a deciduous tree: bare branches permit more solar heat gain during winter than an evergreen. It is a low water user, grows throughout central and southern Arizona, and is widely available. It is valued for its handsome foliage, attractive yellow flowers, resistance to insect/pest damage, and moderately dense shade.

Planting of a 6 ft tall mesquite (15 gallon container) was assumed for this simulation. Using a growth curve with a 3 to 4 foot per year size increase, a tree height and spread of 19 ft at five years after planting and near-mature height and spread of 25 ft at 10 years after planting was modelled (Figure 27). Also assumed was that during leaf-on period the mesquite tree would block 85% of incoming solar radiation, and during leaf-off block 25%. The leaf-on period was assumed to extend from April through November, and leaf-off extended from December through March. These characteristics make the simulated mesquite tree relatively favorable in terms of solar control and solar access.

Tree Locations. The three mesquite trees used in the landscape simulations were located for west, east, and south shade as space permitted and in that order of preference. These locations were based on other studies that suggest that tree shade on west and east facing building surfaces is most desirable in southern latitudes, where cooling loads are important and high summer solar angles enhance south wall shade from overhangs. Although a limited number of simulations have proven that trees in these locations provide the greatest reduction in annual cooling energy use, trees in different locations may give maximum effects on building and system peak load reductions (Buffington, 1979; McPherson and Dougherty, 1988; Sand, 1991). Little research has explored the impact of different tree locations on-peak or annual

Figure 27 - Section and plan view of 1992 two story residence with 25 ft Mesquite tree.

heating and cooling energy use.

The second set of simulations were conducted to assess relations between tree location and energy conservation using the following three scenarios:

1. One tree opposite west wall
2. One tree opposite east wall
3. One tree opposite south wall

In these single tree, shade-only scenarios (no ET cooling effects are considered), trees were placed opposite the middle of their respective walls to maximize the area shaded. Trees were placed 12.5 ft from the walls so that at Year 10 the edge of each crown reached the adjacent wall (except for east tree in the 1985 -South landscape, which was placed on the property line and 8 ft from the east wall).

SPS Simulations. MICROPAS 4.0 was modified by ENERCOMP INC. to accept Shadow Pattern Simulator (SPS) output. SPS files contain hourly shading coefficients for each season that account for tree shade (both crown density and area shaded) on each of eight possible building surfaces (four wall and four roof orientations). Shading coefficients derived for one day of each month are assumed to apply to all days of each respective month. MICROPAS multiplies the hourly shading coefficients times direct and diffuse radiation values, thereby reducing solar heat gains on opaque and glazing surfaces. SPS simulations were run at two time periods (e.g., Years 5 and 10) for each tree location scenario except the single tree on the west, east, and south, which were run for Year 10 only. Tree height and crown diameter were assumed to increase at the same rate and the height from ground to the bottom of the crown remained at 6 ft after an initial start at 4 ft in Year 5. Shading from shrubs was assumed to be negligible.

MICROPAS Simulations. Energy analysis simulations were run for the two time periods associated with each landscape and tree shade simulation scenario. ET cooling for the Mesiscapes was simulated using the modified weather file

developed and previously validated for the turf treatment. To account for 66% less turf in the Xeriscapes than Mesiscapes, and thus slightly warmer air temperatures, only 33% of the hourly percentage temperature reductions calculated for the Mesiscapes was used.

Standardized reports were generated to include the following information:

1. Heating, cooling, and total annual energy use (kBtu/sf)
2. Total annual kWh energy use for air conditioning
3. Total annual kBtu energy use for heating
4. Summer peak day kW energy use

Because simulation results have been known to overestimate actual cooling loads, we present percentage differences from the unshaded base case, as well as simulated energy use and costs. Typical 1992 residential prices for electricity (\$0.10 per kWh) and natural gas (\$0.60 per therm) were assumed.

Landscape Water Use Simulations. The calibrated and validated landscape water use model was used to simulate monthly and annual consumption for each of the different landscapes. Monthly ET_0 values were based on historic data for Phoenix (Bennett and Hazinsky, 1992) and the plant factor for turf was assumed to be 0.55. The plant factor for low-water-use shrubs and the mesquite trees was assumed to be 0.15 because they normally perform well with limited irrigation after establishment. Consumptive use by the trees was modeled at Year 5 and Year 10 based on tree crown areas, while turf area remained constant for each landscape simulation. Shrubs were assumed to reach their ultimate size by Year 5, so their water use did not change during Year 10. Trees in turf (e.g., Mesiscapes and Xeriscapes) were assumed to receive their full ration of irrigation and no interactions between the two were modeled due to limited research on the subject. Theoretically, tree shade on the lawn and diminished air flow could reduce turf ET rates and overall landscape water use. Because these

types of interactions are not modeled, simulation results could slightly overestimate landscape water use. Water prices were based on 1992 City of Phoenix seasonal rates of \$1.24 per CCF (hundred cubic ft) during summer (June through September), \$0.95 per CCF during spring to fall, and \$0.79 per CCF during winter (December through May).

Landscape Simulation Results

Simulation results for each landscape are contained in standard reports (Appendix B). This section summarizes and discusses effects of trees and turf on energy savings and water costs compared to the unlandscaped base case buildings.

1960 Residence. Annual energy costs for the 1960 base case residence were projected to be \$886, higher than the other structures due to less energy-efficient construction (Table 11). Shade increased heating costs by \$3 but reduced cooling costs at Years 5 and 10 by \$54 and \$87, respectively. ET cooling for the Xeriscape and Mesiscapes did not increase heating costs, and reduced cooling costs by \$21 and \$71, respectively.

Water costs at Year 10 ranged from \$16 for trees and shrubs in the Granitescape, to \$200 for all plants in the Mesiscape. Trees in the Granitescape provided the greatest net annual savings (\$68) compared to the base case (Figure 28).

1985 - South Residence. Annual energy costs (\$642) were least for this base case due to its favorable orientation and relatively small floor area (Table 11). Tree shade reduced cooling costs by only \$15 and \$24 at years 5 and 10, respectively. ET cooling reductions were \$16 and \$56 for the Xeriscape and Mesiscape. These energy savings were more than offset by turf irrigation costs of \$53 and \$160 for the

Table 11 - Energy and Water Use Savings

1960 Residence	Base Case		Grantscape			Xeriscape			Mesiscape		
	Use	\$ Cost	Diff	%	\$ Saved	Diff	%	\$ Saved	Diff	%	\$ Saved
Heat(MBtu)	15.5	93	-0.5	3	-3	-0.5	-3	-3	-0.5	-3	-3
Cool (kWh)	7928	793	873	11	87	1079	14	108	1587	20	159
Water(CCF)	0	0	14.2		-16	68.13		-77	177.62		-200
Peak Cool(kW)	8.12		1.94	24		2.06	25		2.30	28	
Energy - Water		886			68			28			-44
1985 - South Residence											
Heat(kWh)	1698	170	-59	-3	-6	-59	-3	-6	-60	-4	-6
Cool (kWh)	4722	472	240	5	24	402	9	40	797	17	80
Water(CCF)	0	0	14.2		-16	61.51'		-69	155.83		-176
Peak Cool(kW)	4.89		0.42	9		0.52	11		0.72	15	-
Energy - Water		642			2			-35			-102
1985 - East Residence											
Heat(kWh)	1656	166	-43	-3	-4	-43	-3	-4	-44	-3	-4
Cool (kWh)	5029	503	336	7	34	501	10	50	897	18	90
Water(CCF)	0	0	14.2		-16	61.51		-69	155.83		-176
Peak Cool(kW)	4.48		1.41	23		1.51	25		1.7	28	
Energy - Water		669			14			-23			-90
1992 Residence											
Heat(MBtu)	11.8	71	-0.3	-3	-2	-0.3	-3	-2	-0.3	-3	-2
Cool (kWh)	7482	748	931	12	93	1109	15	111	1556	21	156
Water(CCF)	0	0	14.2		-16	68.13		-77	177.62		-200
Peak Cool(kW)	6.75		2.12	27		2.21	28		2.41	30	
Energy - Water		819			75			32			-46

Xeriscape and Mesiscape. Only the Granitescape provided a net annual energy-water savings (\$2) (Figure 29).

1985 - East Residence. Annual energy costs (\$669) were greater than those of the south-facing base case, largely due to increased solar heat gains through west-facing windows. Not surprisingly, the two trees shading the west wall and one on the east provided greater cooling savings (\$23 in Year 5 and \$34 in Year 10) than trees in the 1985 - South landscape. ET cooling from turf provided similar savings (\$17 for Xeriscape and \$56 for Mesiscape) as projected for 1985 - South. Although water costs for both 1985 base cases were identical, greater energy savings from shade for the East Residence resulted in larger net annual savings than projected for 1985 South (Table 11 and Figure 30).

1992 Residence. Although this base case building has the most energy-efficient construction, it has the greatest floor area, and highest ratio of heat absorbing wall surface area to interior volume. Annual energy use was projected to be \$819 (Table 11). Tree shade provided savings (\$50 at Year 5 and \$93 at Year 10) comparable to those simulated for the 1960 Residence. Savings from the lawn's ET cooling (\$18 for Xeriscape and \$62 for Mesiscape) were 10 to 20% less than for the 1960 base case due to lower rates of conductive heat transfer. Landscape water costs were the same for both the 1960 and 1992 landscapes, increasing from \$16 (Granitescape) to \$77 (Xeriscape), and then to \$200 for the Mesiscape, respectively (Table 11). Net energy-water savings from the base case were greatest for this base case building, with the Granitescape (\$75) and Xeriscape (\$32) designs achieving net savings (Figure 31). Water costs for the Mesiscape exceeded energy savings by \$46.

Figure 28 Annual energy savings for 1960 one story residence.

Figure 29 Annual energy savings for 1985 south facing residence.

Figure 30 — Annual energy savings for 1985 east facing residence.

Figure 31 — Annual energy savings for 1992 two story residence.

Discussion. Granitecapes provided greater net annual energy-water savings than Xeriscapes or Mesiscapes across all base case buildings, with savings from the base case buildings ranging from \$2 to \$75. Xeriscapes were projected to provide positive net benefits for all buildings except 1985 - South, and savings were significantly greater than projected for Mesiscapes. These findings indicate that the trees simulated in this study provide greater energy savings per unit water consumed than does turf. This advantage is likely to grow because water prices are expected to increase at nearly twice the rate of energy prices during the next decade. However, lawns can provide substantial cooling savings as soon as they are installed, whereas trees take years to fully shade building surfaces. Both lawns and trees provide recreational, aesthetic, and other environmental value that have not been accounted for in this analysis. Although difficult to quantify in dollar terms, these values probably exceed their energy saving value and may in themselves justify expenses associated with maintaining a healthy landscape.

Air conditioning energy savings attributable to ET cooling from turf in the Xeriscapes was equivalent to about 25% of the savings from tree shade for the 1960 and 1992 buildings, and 67% of the shade savings for 1985 - South. Considerably lower ratios for the Mesiscapes suggest that from a strictly energy-water resource economics perspective, "practical turf area" means lawns areas limited to locations near buildings where their cooling effects will most impact air conditioning loads.

Tree shade was most cost-effective for the two story 1992 building, where more shade fell on the west and east walls as opposed to on the roof of the shorter one story buildings. Attic insulation largely decouples the attic from the living area below, thereby minimizing the impact of roof shade on air conditioning energy load. Tree shade was least effective on the already shaded 1985 buildings, pointing out that the marginal savings from new tree shade diminishes as the amount

of pre-existing shade increases. For three of the four base case buildings, tree shade at Year 10 provided greater peak cooling savings than ET cooling from turf in the Mesiscape designs.

Single Tree Shade Results

This section reviews results of single tree shade simulations with a 25 ft tree opposite west, east, and south walls of each building. Standard reports are included in Appendix C.

Savings Across Tree Locations. Total annual energy savings from the west tree shading east-facing residences (e.g., 1960, 1985 East, and 1992) ranged from \$16 to \$45 (146 to 454 kWh) per tree and were about double those provided by a single tree opposite east walls. For these base case buildings, a tree on the west clearly outperformed trees in other locations when total heating and cooling costs are considered. The second best location for a tree is opposite the east wall, where total annual savings ranged from \$8 to \$23 (76 to 241 kWh) per tree. Trees opposite the south wall provided the least cooling savings and the highest heating costs, although dollar impacts on heating were small (up to \$3.52 per year) due to the short heating season in Phoenix (Table 12).

Table 12 - Projected Air Conditioning Savings from the Base Case due to Shade from a 25 ft Mesquite Tree

Base Case Buildings	West Shade			East Shade			South Shade		
	Peak kW	Annual kWh	Annual \$	Peak kW	Annual kWh	Annual \$	Peak kW	Annual kWh	Annual \$
1960	1.06	372	37	0	241	24	0	200	20
1985 - South	0.42	161	16	0	54	5	0	74	7
1985 - East	0.71	146	14	0	76	8	0	36	4
1992	1.25	454	45	0	215	22	0	143	14

The interaction of building orientation and tree location on energy savings can be observed by comparing results for the 1985 - South and East residences. West shade provided the greatest savings in both cases. However, the absence of windows on the east wall and large amount of glazing on the south wall of the 1985 - South residence resulted in south shade outperforming east shade.

Peak cooling savings were greatest from trees opposite west walls regardless of building orientation. East and south shade had minor effects on kW savings during the summer peak day compared to west shade because they provided no shade at 5:00 p.m. when peak demand occurred. Savings from west tree shade ranged from 0.42 kW (1985 - South) to 1.25 kW (1992), and were substantially greater than the 0.33 kW per tree estimated by the Arizona Corporation Commission.

Savings Across Base Case Buildings. Similar cooling savings were found for the 1992 two story residence compared to the 1960 one story residence. This is a surprising result because savings from shading generally increase as building insulation decreases. One explanation for the finding is that the greater wall area of the two story building results in proportionally longer periods of wall shading compared to the one story building. Roof shade on the one story residence provides less potential savings than wall shade due to increased insulation and no windows in the roof and attic space.

As noted above, total energy savings for the 1985 buildings were about half the amount projected for the 1960 and 1992 buildings. This finding is not surprising given the adjustments made to wall absorptivity values during calibration and validation of the model. Cooling savings from tree shade will be relatively small for buildings that have (a) extensive shade from buildings, fences, and vegetation, (b) shutters and blinds closed during the day, (c) relatively little east and west facing wall or window surface, and (d) relatively large internal gains.

LANDSCAPING GUIDELINES FOR ENERGY AND WATER CONSERVATION

In this section, findings from this study and previous research are summarized and presented as initial guidelines for energy and water-efficient residential landscape design in Phoenix, Arizona.

Applicability of Potential Savings

These findings indicate that strategic landscaping can provide substantial energy savings for new energy-efficient construction as well as older homes that are less efficient. Trees are likely to be especially cost-effective conservation measures for new energy-efficient homes, where the marginal costs of additional in-home conservation measures are high relative to tree costs. Landscape ordinances, building standards, and energy conservation programs for new construction should incorporate strategic landscaping as a conservation measure. Similarly, strategic landscaping as an energy conservation retrofit measure for the existing housing stock could be cost-effective and merits consideration by the City of Phoenix and local utilities.

Trees and Practical Turf Areas

When only considering energy savings per unit of water consumed, the low-water-use mesquites provided greater savings at a lower cost than did the lawn. However, lawn can provide cooling savings upon installation, whereas it will take 5 to 10 years for savings to be realized from trees. For optimal use of turf from the energy and water efficiency perspective, lawn areas located upwind and relatively close to the residence are most desirable. The combination of trees with

practical turf areas near buildings is recommended for several reasons. Trees and other tall objects reduce wind speeds and turbulence, thereby "trapping" cool air above the lawn. Also, shade from these objects can reduce ET rates and landscape water demand.

Further research is needed to identify optimal locations and extent of lawn areas. Theoretically, cool air from turf areas that are too small or too far from the building will be mixed with the much larger volume of hot dry air passing through the landscape and thus have little effect on cooling load. Conversely, as turf areas become larger and more distant, a point of diminishing returns is reached because water costs exceed energy savings.

West Shade

The best place to locate the first (and perhaps second) tree for energy savings is opposite west facing windows/walls (McPherson and Sacamano, 1989). Our findings suggest that a tree on the west provides greater annual and peak cooling energy savings, and less increase in heating, than one located to the south or east. Select low branching deciduous trees with broad crowns for extensive shading during summer and less impact on winter solar access than evergreens. If evergreens are a must, this is the place to use them, because winter solar access is more important for south and east walls than it is for west walls. Locate trees fairly close to the building to increase the amount of shade. Deciduous vines and shrubs are also good plants for solar control on west and east walls (Hudson and Cox, 1985; Parker, 1987).

East Shade

The next best place for a tree in most cases is opposite the east wall, where shade reduces mid-peak demand and does not obstruct winter solar gain as much as does a tree to the south. The advantage of east shade over south shade becomes less clear for buildings with south orientations and extensive south-facing windows. Select deciduous trees with broad spreading crowns and relatively short foliation periods (i.e., April-Nov. rather than March-Dec.) for east shade.

South Shade

South shade can be particularly beneficial for south-facing buildings, where it can reduce summer kWh and peak day kW demand more than east shade, especially for taller residential and commercial buildings. Because the heating season is so short in Phoenix, benefits from south shade outweigh the increased heating costs due to reduced winter solar access. However, select large deciduous trees that will eventually branch above the windows to provide winter solar access and summer shade (McPherson and Sacamano, 1989). South trees should be located fairly close (8 to 20 ft) to the building for optimum energy savings. Species with dense foliage and open branching are most desirable.

North Shade

Trees planted northwest and northeast of the residence can reduce late afternoon and early morning cooling demands. Evergreens can provide good summer shade in these locations.

Wind Control

Cool breezes can improve comfort and reduce cooling energy use if natural ventilation is used and outside temperatures are below 90°F (Givoni, 1981). In Phoenix, summer breezes are advantageous during the swing seasons when temperatures drop below 90°F and windows are opened for natural ventilation. Landscapes with an open understory will enhance air flow around the building. Avoid random shrub plantings that can block cool breezes near the ground.

CHAPTER 4 - CONCLUSIONS AND RECOMMENDATIONS

CONCLUSIONS

The following conclusions may be stated based on the results of this demonstration project:

1. Measured air conditioning savings from turf was between 10% and 17%, and negligible from trees one year after installation.
2. When water costs and energy savings were modeled for different landscapes, shade from mature low water use trees in the absence of turf was most cost effective.
3. Turf can lower air temperatures as much as 2 to 3°F and provide considerable air conditioning savings upon installation, but increasing water costs for irrigation can offset energy savings. Lawn areas located upwind and relatively close to the building will maximize net savings.
4. Building orientation and shade from nearby buildings and trees can significantly effect air conditioning energy savings from tree shade. For example, south shade from a 25 foot mesquite was projected to provide twice the cooling energy savings for the south-facing residence compared to the east-facing residence.
5. Generally, trees facing west walls provided the largest savings, both peak and annual (0.42 to 1.25 kW, 146 to 454 kWh, \$14 to \$45) compared to an unshaded building.

6. Once calibrated, models can be useful tools for evaluating building energy and landscape water use associated with different landscape designs and management regimes.
7. Energy and water efficient landscapes are likely to be cost effective conservation measures for both existing and new energy-efficient construction. Strategic landscaping can be implemented without requiring significant changes to overall building and development goals and objectives.
8. Simulated impacts on heating were generally small for shading, being largest on the south facing walls due to the short and relatively mild winters in Phoenix.
9. Other potential benefits from strategic landscaping include improved neighborhood climates and occupant comfort, reduced storm water runoff and flooding, and improved air quality.

RECOMMENDATIONS

The following recommendations can be made based on the results of this demonstration project:

1. Analyze the means to implement energy and water efficient landscape design and management via education, incentives and ordinances.
2. Develop a series of workshops to teach principles of energy and water efficient landscaping to targeted audiences including landscape design professionals, landscape contractors, planners, utility representatives and residents.
3. Develop informational materials (videos, brochures) to document potential energy and water savings techniques and illustrate design/management principles and practices.

4. Develop a Phoenix Urban Forestry Master Plan to guide community reforestation efforts.
5. Explore the cost effectiveness of reforestation partnerships that split tree planting costs in thirds (homeowners/developers, utility companies, the city).
6. Monitor and evaluate neighborhood strategic landscape plantings in old and newly developed areas to demonstrate energy and water efficient landscape design and management.

FUTURE RESEARCH

The following areas are recommended for future research:

1. Consider a study to monitor neighborhood-scale benefits and costs associated with demonstration plantings, including a wider range of benefits and costs.
2. Consider a longer term study with bigger trees and a larger sampling of monitored buildings to better assess the benefits of direct shade on building energy use.
3. Conduct a more detailed examination of effects of strategic design on peak loads.
4. Study effects of turf in more detail to develop design guidelines that balance cooling benefits with water costs for different landscapes.

LESSONS LEARNED

Pulse type data logging equipment commonly used by electrical utilities to monitor electrical use can easily be used to monitor water meters. In addition, it is possible to equip this equipment with digital to analog conversion devices which allow monitoring of the environment. In the current study, this feature was used to monitor inside and outside air temperature.

Despite the best intentions and efforts of volunteer homeowners, thermostat set points often differed by as much as 2°C (4°F). Thermostat setbacks also occurred, which made comparisons difficult on many days. Clearer communication of project requirements is necessary to study participants, and closer oversight necessary by investigators, to ensure comparable conditions for all treatments.

The consistency of the cooling load reductions observed for different time periods in 1991 suggests that the approximately one week sample periods are sufficient to obtain reliable estimates of energy use, provided weather conditions and thermostat set points are similar. It also suggests that the relatively limited number of days available for comparison in 1990 (five total) were sufficient for reliable baseline cooling load determination. Nevertheless, additional study with larger sample sizes and longer time periods are recommended.

Results further suggest that forming ratios with control structures may remove variability associated with differences in internal heat gains due to differing occupant behavior, so that detailed accounting for such differences may not be necessary in future studies of this type.

APPENDIX A - REFERENCES

Akbari, H., Davis, S., Dorsano, S., Huang, J. and Winnett, S. (Editors), 1992. Cooling Our Communities: A Guidebook On Tree Planting and Light-Colored Surfacing . U.S. Environmental Protection Agency, Washington, D.C.

Alves, L. M., J. R. Simpson, E. G. McPherson, and A. D. Matthias. 1991. Microclimatic effects of different landscape treatments on exterior air temperature around similar buildings.

ASHRAE Handbook, Fundamentals Volume. 1985. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Atlanta, GA.

Balling, R.C. and Brazel, S.W., 1987a. "Time and space characteristics of the Phoenix urban heat island." J. Arizona-Nevada Acad. Sci., 21: 75-81.

Balling, R.C. and Brazel, S.W., 1987b. "The impact of rapid urbanization on PAN evaporation in Phoenix, Arizona." J. Climatology, 7: 593-597.

Balling, R.C. and Brazel, S.W., 1987c. "Recent changes in Phoenix, Arizona summertime diurnal precipitation patterns." Theor. Appl. Climatol., 38:50-54.

Barlag, A. and Kuttler, W., 1990/91. "The significance of country breezes for urban planning." Energy and Buildings, 15-16: 291-297.

Bennett, R.E. and Hazinski, M.S., 1992. "Water-Efficient Landscape Guidelines." American Water Works Assoc., unpublished.

Brazel, A.J., Brazel, S.W. and Balling, R.C., 1988. "Recent changes in smoke/haze events in Phoenix, Arizona." Theor. Appl. Climatol., 39:108-113.

Brown, P.W. 1987. "Using a computer bulletin board as an agricultural weather information system." In: Preprints, 18th Conference on Agricultural and Forest Meteorology, Sep 14-18, 1987, W. Lafayette, Indiana, American Meteorological Society, Boston, Mass., pp. 67-69.

Buffington, D.E., 1979. "Economics of landscaping features for conserving energy in residences." Proceedings of the Florida State Horticultural Society, 92: 216-220.

Givoni, B. 1981. Man, Climate and Architecture, 2nd Edition. Van Nostrand Reinhold, New York.

Gibeault, V.A., et al., 1991. Managing turfgrasses during drought. University of California Cooperative Extension Leaflet 21491, March 1991.

Grant, R., 1991. "Evidence for vegetation effects on the daytime internal boundary layer over suburban areas." In: American Meteorological Society (Editor), Tenth Conference On Biometeorology and Aerobiology. American Meteorological Society, Boston, MA. pp. 75-78.

Honjo, T. and Takakura, T., 1990/91. "Simulation of thermal effects of urban green areas on their surrounding areas." Energy and Buildings, 15-16: 433-446.

Hudson, G.M. and Cox, E.J., 1985. The Vine in the Built Environment. Masters of Landscape Architecture, University of Oregon, Eugene.

McPherson, E.G., 1990. "Modeling residential landscape water and energy use to evaluate water conservation policies." Landscape Journal, 9(2): 122-134.

McPherson, E.G. 1991a. "Cooling urban heat islands with sustainable landscapes." Drachman Institute for Land and Regional Development Studies, Tucson, AZ.

McPherson, E.G., Minor, C.T. and Guertin, D.P., 1991. "A prototype model of residential irrigation water use." The Tenth Conference on Biometeorology and Aerobiology and the Special Session on Hydrometeorology. Sept. 10-13, 1991. Salt Lake City, Utah. The American Meteorological Society, Boston, Mass.

McPherson, E.G. and Dougherty, E., 1989. "Selecting trees for shade in the southwest." J. Arbor., 15: 35-43.

McPherson, E.G. and Sacamano, C. 1989. Southwestern Landscaping That Saves Energy and Water. Cooperative Extension, College of Agriculture, The University of Arizona, Tucson, AZ.

McPherson, E. G., J. R. Simpson and M. Livingston. 1989. Effects of three landscape treatments on residential energy and water use in Tucson, Arizona. Energy and Buildings 13:127-138.

Mizuno, M., Nakamura, M., Murakami, H. and Yamamoto, S., 1990/91. "Effects of land use on urban horizontal atmospheric temperature Distributions." Energy and Buildings, 15-16: 165-176.

Monteith, J. L. and M. H. Unsworth. 1990. Principles of Environmental Physics, 2nd ed. Edward Arnold, London.

Oke, T.R., 1988. "Street design and urban canopy layer climate." Energy and Buildings, 11: 103-113.

Oke, T.R., 1989. "The micrometeorology of the urban forest." Phil. Trans. R. Soc. Lond., 324: 335-349.

Parker, J.H., 1987. "The use of shrubs in energy conservation plantings." Landscape Journal, 6: 132-139.

Saito, I., Ishihara, O. and Katayama, T., 1990/91. "Study of the effect of green areas on the thermal environment in an urban area." Energy and Buildings, 15-16: 493-498.

Sand, P.A., 1991. Planting for Energy Conservation in the North. Masters of Landscape Architecture, University of Minnesota, 111.

Swimmer, M.L., 1987. The Energy Interface, Landscaping for Energy Conservation and Environmental Control at the Building/Site Interface. Masters in Architecture and Urban Planning, University of California Los Angeles, 56.

Westerberg, U. and Glaumann, M., 1990/91. "Design criteria for solar access and wind shelter in the outdoor environment." Energy and Buildings, 15-16: 425-431.

Wilmers, F., 1990/91. "Effects of vegetation on urban climate and buildings." Energy and Buildings, 15-16: 507-514.

APPENDIX B - LANDSCAPE SIMULATION REPORTS

Phoenix, 1 story, 1,500 sf, 1960 Residence

1992 Prices

Nat. Gas	(\$/therm):	0.60
Electricity	(\$/kWh):	0.10

Source Energy Use

	Heating Use kBtu/ sf	Cooling Use kBtu/ sf	Total Energy Use	Peak Cool kW
Base Case	10.71	54.12	64.83	8.12
Year 5	10.97	50.42	61.38	6.74
Year 10	11.06	48.16	59.21	6.18
Low ET	10.71	52.71	63.42	8.00
Moderate ET	10.72	49.24	59.96	7.76

	% Saved from Base Case		Energy Use	Peak Cool
	Heating Use	Cooling Use		
Year 5	-2.39	6.84	5.31	17.00
Year 10	-3.21	11.01	8.66	23.89
Low ET	0.00	2.60	2.17	1.48
Moderate ET	-0.06	9.01	7.51	4.43

Annual Energy Use

	Heating kBtu	Cooling kWh
Base Case	15453.92	7927.95
Year 5	15823.14	7385.75
Year 10	15950.20	7054.81
Low ET	15453.92	7721.63
Moderate ET	15463.73	7213.63

	Diff. from Base Case		Percent Diff. from Base Case	
	Heating	Cooling	Heating	Cooling
Year 5	-369.22	542.2	-2.39	6.84
Year 10	-496.28	873.15	-3.21	11.01
Low ET	0	206.33	0.00	2.60
Moderate ET	-9.81	714.33	-0.06	9.01

	1992 \$ Saved from Base Case		
	Heating	Cooling	Total
Base Case			
Year 5	-2.22	54.22	52
Year 10	-2.98	87.31	84.33
Low ET	0	20.63	20.63
Moderate ET	-0.06	71.43	71.37

Year 5		% Change from Base Case					
	Heat kBtu	Cool kWh	Cool kW	Water gal	Heat kBtu	Cool kWh	Cool kW
Base Case	15453.92	7927.954	8.12	0			
Granite	15823.14	7385.753	6.74	7034	-2.39	6.84	17
Xeric	15823.27	7179.56	6.62	47520	-2.39	9.44	18.47
Mesic	15832.54	6671.37	6.38	129717	-2.45	15.85	21.43

Year 10		% Change from Base Case					
	Heat kBtu	Cool kWh	Cool kW	Water gal	Heat kBtu	Cool kWh	Cool kW
Base Case	15453.92	7927.954	8.12	0			
Granite	15950.2	7054.806	6.18	10639	-3.21	11.01	23.89
Xeric	15949.99	6848.96	6.06	51125	-3.21	13.61	25.37
Mesic	15959.26	6340.78	5.82	133322	-3.27	20.02	28.33

Annual Dollar Savings From Base Case

in 1992 Prices and Dollars

Cooling Energy Use

Percent Energy Savings from Base Case

Peak Cooling Savings from Base Case

Phoenix, 1 story, 1,500 sf, 1960 Residence

Phoenix, 1 story, 1,616 sf, East Facing 1985 Residence

1992 Prices		
Nat. Gas	(\$/therm):	0.60
Electricity	(\$/kWh):	0.10

Source Energy Use

	Heating Use kBtu/ sf	Cooling Use kBtu/ sf	Total Energy Use	Peak Cool kW
Base Case	10.49	31.86	42.36	6.08
Year 5	10.71	30.44	41.14	5.24
Year 10	10.77	29.74	40.51	4.67
Low ET	10.49	30.82	41.31	5.98
Moderate ET	10.50	28.31	38.81	5.79

	% Saved from Base Case			
	Heating Use	Cooling Use	Energy Use	Peak Cool
Year 5	-2.06	4.48	2.86	13.82
Year 10	-2.63	6.67	4.37	23.19
Low ET	0.00	3.29	2.48	1.64
Moderate ET	-0.06	11.16	8.38	4.77

Annual Energy Use

	Heating kWh	Cooling kWh
Base Case	1656.09	5029.09
Year 5	1690.27	4803.55
Year 10	1699.58	4693.46
Low ET	1656.09	4863.52
Moderate ET	1657.11	4467.65

	Diff. from Base Case		Percent Diff. from Base Case	
	Heating	Cooling	Heating	Cooling
Year 5	-34.18	225.54	-2.06	4.48
Year 10	-43.49	335.62	-2.63	6.67
Low ET	0	165.56	0.00	3.29
Moderate ET	-1.02	561.44	-0.06	11.16

	1992 \$ Saved from Base Case		
	Heating	Cooling	Total
Base Case			
Year 5	-3.42	22.55	19.13
Year 10	-4.35	33.56	29.21
Low ET	0	16.56	16.56
Moderate ET	-0.1	56.14	56.04

Year 5		% Change from Base Case						
	Heat kWh	Cool kWh	Cool kW	Water gal	Heat kBtu	Cool kWh	Cool kW	
Base Case	1656.092	5029.088	6.08	0				
Granite	1690.267	4803.548	5.24	7034	-2.06	4.48	13.82	
Xeric	1690.21	4638.33	5.14	42561	-2.06	7.77	15.46	
Mesic	1691.2	4242.54	4.95	113360	-2.12	15.64	18.59	

Year 10		% Change from Base Case						
	Heat kWh	Cool kWh	Cool kW	Water gal	Heat kBtu	Cool kWh	Cool kW	
Base Case	1656.092	5029.088	6.08	0				
Granite	1699.584	4693.464	4.67	10639	-2.63	6.67	23.19	
Xeric	1699.65	4528.19	4.57	46166	-2.63	9.96	24.84	
Mesic	1700.64	4132.4	4.38	116965	-2.69	17.83	27.96	

Annual Dollar Savings From Base Case

In 1992 Prices and Dollars

Cooling Energy Use

Percent Energy Savings from Base Case

Peak Cooling Savings from Base Case

Phoenix, 1 story, 1,616 sf
East Facing 1985 Residence

Phoenix, 1 story, 1,616 sf, South Facing 1985 Residence

1992 Prices		
Nat. Gas	(\$/therm):	0.60
Electricity	(\$/kWh):	0.10

Source Energy Use

	Heating Use kBtu/ sf	Cooling Use kBtu/ sf	Total Energy Use	Peak Cool kW
Base Case	10.76	29.92	40.68	4.89
Year 5	11.03	29.00	40.02	4.59
Year 10	11.14	28.40	39.54	4.47
Low ET	10.76	28.89	39.65	4.79
Moderate ET	10.77	26.39	37.16	4.59

% Saved from Base Case				
	Heating Use	Cooling Use	Energy Use	Peak Cool
Year 5	-2.46	3.09	1.62	6.13
Year 10	-3.49	5.08	2.81	8.59
Low ET	0.00	3.44	2.53	2.04
Moderate ET	-0.06	11.80	8.66	6.13

Annual Energy Use

	Heating kWh	Cooling kWh
Base Case	1698.50	4722.34
Year 5	1740.26	4576.42
Year 10	1757.76	4482.45
Low ET	1698.50	4560.10
Moderate ET	1699.55	4165.32

Diff. from Base Case		Percent Diff. from Base Case	
	Heating	Cooling	
Year 5	-41.77	145.92	-2.46 3.09
Year 10	-59.26	239.9	-3.49 5.08
Low ET	0	162.25	0.00 3.44
Moderate ET	-1.05	557.02	-0.06 11.80

1992 \$ Saved from Base Case			
	Heating	Cooling	Total
Base Case			
Year 5	-4.18	14.59	10.41
Year 10	-5.93	23.99	18.06
Low ET	0	16.22	16.22
Moderate ET	-0.11	55.7	55.59

Year 5							
	Heat kWh	Cool kWh	Cool kW	Water gal	% Change from Base Case		
Base Case	1698.499	4722.342	4.89	0			
Granite	1740.264	4576.422	4.59	7034	-2.46	3.09	6.13
Xeric	1740.28	4413.97	4.49	42561	-2.46	6.53	8.18
Mesic	1741.3	4019.19	4.29	113360	-2.52	14.89	12.27

Year 10							
	Heat kWh	Cool kWh	Cool kW	Water gal	% Change from Base Case		
Base Case	1698.499	4722.342	4.89	0			
Granite	1757.755	4482.445	4.47	10639	-3.49	5.08	8.59
Xeric	1757.78	4320	4.37	46166	-3.49	8.52	10.63
Mesic	1758.8	3925.21	4.17	116965	-3.55	16.88	14.72

Annual Dollar Savings From Base Case

in 1992 Prices and Dollars

Cooling Energy Use

Percent Energy Savings from Base Case

Peak Cooling Savings from Base Case

Phoenix, 1 story, 1,616 sf
South Facing 1985 Residence

Phoenix, 2 story, 1,761 sf, 1992 Residence

1992 Prices

Nat. Gas	(\$/therm):	0.60
Electricity	(\$/kWh):	0.10

Source Energy Use

	Heating Use kBtu/ sf	Cooling Use kBtu/ sf	Total Energy Use	Peak Cool kW
Base Case	6.98	43.50	50.48	7.98
Year 5	7.10	40.57	47.66	6.80
Year 10	7.16	38.09	45.25	5.86
Low ET	6.98	42.47	49.45	7.89
Moderate ET	6.98	39.88	46.86	7.69

	% Saved from Base Case			
	Heating Use	Cooling Use	Energy Use	Peak Cool
Year 5	-1.67	6.75	5.58	14.79
Year 10	-2.57	12.45	10.37	26.57
Low ET	0.00	2.37	2.04	1.13
Moderate ET	-0.05	8.34	7.18	3.63

Annual Energy Use

	Heating kBtu	Cooling kWh
Base Case	11819.10	7482.32
Year 5	12017.00	6977.38
Year 10	12122.28	6551.04
Low ET	11819.10	7304.91
Moderate ET	11824.51	6858.26

	Diff. from Base Case		Percent Diff. from Base Case	
	Heating	Cooling	Heating	Cooling
Year 5	-197.9	504.93	-1.67	6.75
Year 10	-303.18	931.27	-2.57	12.45
Low ET	0	177.41	0.00	2.37
Moderate ET	-5.41	624.06	-0.05	8.34

	1992 \$ Saved from Base Case		
	Heating	Cooling	Total
Base Case			
Year 5	-1.19	50.49	49.3
Year 10	-1.82	93.13	91.31
Low ET	0	17.74	17.74
Moderate ET	-0.03	62.41	62.38

					% Change from Base Case		
	Heat kBtu	Cool kWh	Cool kW	Water gal	Heat kBtu	Cool kWh	Cool kW
Base Case	11819.1	7482.316	7.98	0			
Granite	12017	6977.384	6.8	7034	-1.67	6.75	14.79
Xeric	12016.48	6799.93	6.71	47520	-1.67	9.12	15.91
Mesic	12022.39	6353.23	6.51	129717	-1.72	15.09	18.42

					% Change from Base Case		
	Heat kBtu	Cool kWh	Cool kW	Water gal	Heat kBtu	Cool kWh	Cool kW
Base Case	11819.1	7482.316	7.98	0			
Granite	12122.28	6551.042	5.86	10639	-2.57	12.45	26.57
Xeric	12122.85	6373.44	5.77	51125	-2.57	14.82	27.69
Mesic	12128.76	5926.74	5.57	133322	-2.62	20.79	30.2

Annual Dollar Savings From Base Case

in 1992 Prices and Dollars

Cooling Energy Use

Percent Energy Savings from Base Case

Peak Cooling Savings from Base Case

Phoenix, 2 story, 1,761 sf, 1992 Residence

APPENDIX C - SINGLE SHADE TREE
SIMULATION REPORTS

Single Tree's Shade, Phoenix, 1 story, 1,500 sf, 1960 Residence

1992 Prices

Nat. Gas	(\$/therm):	0.60
Electricity	(\$/kWh):	0.10

Source Energy Use

	Heating Use kBtu/ sf	Cooling Use kBtu/ sf	Total Energy Use	Peak Cool kW
Base Case	10.71	54.12	64.83	8.12
East Shade	10.85	52.47	63.32	8.12
South Shade	11.12	52.75	63.87	8.12
West Shade	10.85	51.57	62.43	7.06

% Saved from Base Case

	Heating Use	Cooling Use	Energy Use	Peak Cool
East Shade	-1.25	3.04	2.33	0.00
South Shade	-3.79	2.53	1.48	0.00
West Shade	-1.31	4.70	3.70	13.05

Annual Energy Use

	Heating kBtu	Cooling kWh
Base Case	15453.92	7927.95
East Shade	15647.76	7687.19
South Shade	16039.84	7727.63
West Shade	15655.77	7555.62

Diff. from Base Case

Percent Diff. from Base Case

	Heating	Cooling	Heating	Cooling
East Shade	-193.84	240.77	-1.25	3.04
South Shade	-585.92	200.32	-3.79	2.53
West Shade	-201.85	372.33	-1.31	4.70

1992 \$ Saved from Base Case

	Heating	Cooling	Total
Base Case			
East Shade	-1.16	24.08	22.92
South Shade	-3.52	20.03	16.51
West Shade	-1.21	37.23	36.02

Annual Dollar Savings From Base Case

in 1992 Prices and Dollars, Single Tree's Shade

Cooling Energy Use

Single Tree's Shade

Percent Energy Savings from Base Case

Single Tree's Shade

Percent Peak Cooling Savings from Base Case

Single Tree's Shade

Phoenix, 1 story, 1,500 sf, 1960 Residence

Single Tree's Shade, Phoenix, 1 story, 1,616 sf, South Facing 1985 Residence

1992 Prices

Nat. Gas	(\$/therm):	0.60
Electricity	(\$/kWh):	0.10

Source Energy Use

	Heating Use kBtu/ sf	Cooling Use kBtu/ sf	Total Energy Use	Peak Cool kW
Base Case	10.76	29.92	40.68	4.89
East Shade	10.80	29.58	40.38	4.89
South Shade	11.05	29.45	40.50	4.89
West Shade	10.85	28.90	39.75	4.47

% Saved from Base Case

	Heating Use	Cooling Use	Energy Use	Peak Cool
East Shade	-0.36	1.14	0.74	0.00
South Shade	-2.67	1.57	0.45	0.00
West Shade	-0.82	3.41	2.29	8.59

Annual Energy Use

	Heating kWh	Cooling kWh
Base Case	1698.50	4722.34
East Shade	1704.61	4668.41
South Shade	1743.79	4647.99
West Shade	1712.37	4561.23

	Diff. from Base Case		Percent Diff. from Base Case	
	Heating	Cooling	Heating	Cooling
East Shade	-6.11	53.94	-0.36	1.14
South Shade	-45.29	74.35	-2.67	1.57
West Shade	-13.87	161.12	-0.82	3.41

1992 \$ Saved from Base Case

	Heating	Cooling	Total
Base Case			
East Shade	-0.04	5.39	5.35
South Shade	-0.27	7.43	7.16
West Shade	-0.08	16.11	16.03

Annual Dollar Savings From Base Case

in 1992 Prices and Dollars, Single Tree's Shade

Cooling Energy Use

Single Tree's Shade

Percent Energy Savings from Base Case

Single Tree's Shade

Percent Peak Cooling Savings from Base Case

Single Tree's Shade

Phoenix, 1 story, 1,616 sf
South Facing 1985 Residence

Single Tree's Shade, Phoenix, 1 story, 1,616 sf, East Facing 1985 Residence

1992 Prices

Nat. Gas	(\$/therm):	0.60
Electricity	(\$/kWh):	0.10

Source Energy Use

	Heating Use kBtu/ sf	Cooling Use kBtu/ sf	Total Energy Use	Peak Cool kW
Base Case	10.49	31.86	42.36	6.08
East Shade	10.56	31.38	41.95	6.08
South Shade	10.68	31.64	42.31	6.08
West Shade	10.63	30.94	41.57	5.37

% Saved from Base Case

	Heating Use	Cooling Use	Energy Use	Peak Cool
East Shade	-0.68	1.51	0.97	0.00
South Shade	-1.75	0.71	0.10	0.00
West Shade	-1.35	2.91	1.85	11.68

Annual Energy Use

	Heating kWh	Cooling kWh
Base Case	1656.09	5029.09
East Shade	1667.35	4953.29
South Shade	1685.00	4993.44
West Shade	1678.42	4882.94

Diff. from Base Case

	Heating	Cooling	Percent Diff. from Base Case Heating	Cooling
East Shade	-11.25	75.8	-0.68	1.51
South Shade	-28.91	35.65	-1.75	0.71
West Shade	-22.32	146.15	-1.35	2.91

1992 \$ Saved from Base Case

	Heating	Cooling	Total
Base Case			
East Shade	-0.07	7.58	7.51
South Shade	-0.17	3.57	3.4
West Shade	-0.13	14.61	14.48

Phoenix, 1 story, 1,616 sf
East Facing 1985 Residence

Single Tree's Shade, Phoenix, 2 story, 1,761 sf, 1992 Residence

1992 Prices

Nat. Gas	(\$/therm):	0.60
Electricity	(\$/kWh):	0.10

Source Energy Use

	Heating Use kBtu/ sf	Cooling Use kBtu/ sf	Total Energy Use	Peak Cool kW
Base Case	6.98	43.50	50.48	7.98
East Shade	7.07	42.25	49.32	7.98
South Shade	7.11	42.67	49.78	7.98
West Shade	7.04	40.87	47.91	6.73

% Saved from Base Case

	Heating Use	Cooling Use	Energy Use	Peak Cool
East Shade	-1.28	2.88	2.30	0.00
South Shade	-1.84	1.91	1.39	0.00
West Shade	-0.87	6.06	5.10	15.66

Annual Energy Use

	Heating kBtu	Cooling kWh
Base Case	11819.10	7482.32
East Shade	11970.28	7267.00
South Shade	12036.54	7339.20
West Shade	11922.37	7028.71

Diff. from Base Case

	Heating	Cooling	Percent Diff. from Base Case	
			Heating	Cooling
East Shade	-151.18	215.32	-1.28	2.88
South Shade	-217.44	143.12	-1.84	1.91
West Shade	-103.27	453.61	-0.87	6.06

1992 \$ Saved from Base Case

	Heating	Cooling	Total
Base Case			
East Shade	-0.91	21.53	20.62
South Shade	-1.3	14.31	13.01
West Shade	-0.62	45.36	44.74

Annual Dollar Savings From Base Case

in 1992 Prices and Dollars, Single Tree's Shade

1,761 sf, 2 story, Phoenix

Cooling Energy Use

Single Tree's Shade

1,761 sf, 2 story, Phoenix

Percent Energy Savings from Base Case

Single Tree's Shade

1,761 sf, 2 story, Phoenix

Percent Peak Cooling Savings from Base Case

Single Tree's Shade

1,761 sf, 2 story, Phoenix

Phoenix, 2 story, 1,761 sf, 1992 Residence

REPORT AND INFORMATION SOURCES

Additional copies of this report, "Impact of Urban Heat Island on Cooling and Environment: A Demonstration Project," are available from:

Publications and Distribution
Public Technology Inc.
1301 Pennsylvania Avenue, SW
Washington, DC 20004

Further information on the techniques and procedures described in this report are available from:

E. Gregory McPherson
USDA Forest Service
Northeastern Forest Experiment Station
5801 N. Pulaski Rd.
Chicago, IL 60646
(312) 539-1363

James R. Simpson
USDA Forest Service
Center for Urban Forest Research
Dept. of Environmental Horticulture
University of California
Davis, CA 95616-8587
(916) 752-9534

Further information about implementation of energy cost reduction practices in the City of Phoenix are available from:

Kris Ahuja
Energy Conservation Engineer
Energy Conservation Unit
2631 South 22nd Ave.
Phoenix, AZ 85009
(602) 261-8504

Publications Price List--UCETF Reports

ITEM #	TITLE	PRICE
90-331	Hydraulic Waste Energy Recovery: A Technical Report	15.00
90-318	A Regulatory Framework for Alternative Fuels and Transportation Management Services	15.00
90-316	Alternative Vehicle Fuels: A Demonstration Project	15.00
90-314	Energy Efficiency in Public Housing	15.00
89-330	Analysis of Programmatic Fleet Conversion to Ethanol Blends	15.00
89-325	An Alternative Fuels Evaluation System for Fleet Vehicles	15.00
89-323	Dual Fuel Conversion Demonstration and Technology Transfer Project	10.00
89-321	Summary of Low and Moderate Income Residential Energy Conservation Programs	15.00
89-315	A Case Study in the Pursuit of Urban Energy Efficiency	15.00
89-314	Communicating with the Public About Environmental Health Risks: A Case Study	13.00
89-313	Evaluation and Comparison of Selected Household Hazardous Waste Collection Facilities	15.00
89-311	Yard Waste Recycling Study: A Pilot Study	15.00
89-310	Sludge Storage Lagoon Biogas Recovery and Use, Volume 1	15.00
89-307	Proceeding: 1989 Electric Utility Franchise Conference	20.00
89-306	Reducing Electricity Demand Through Energy-Related Efficient Construction	15.00
89-304	Modernization of Lighting in Municipal Auditoriums	15.00
89-303	Wastewater Treatment Process Energy Optimization	13.00
89-301	Implementation of Alternative Technologies through the Assessment of Energy Markets	14.00
88-322	Marketing Energy Efficiency Programs to Commercial and Industrial Firms: Lighting Incentives and	15.00
88-321	Urban Energy Management Today: Ten Year Compendium of UCETF Programs	10.00
88-319	Integrating Energy Efficiency Into Municipal Purchasing Decisions: Computerizing Procurement	15.00
88-318	Household Hazardous Waste: Implementation of a Permanent Collection Facility	20.00
88-317	Hazardous Waste as an Energy Manager's Issue	15.00
88-316	Household Hazardous Waste Management Planning	15.00
88-312	Summary of Small Business Energy Conservation Programs	15.00
88-310	The Earth-Coupled Heat Pump: Utilizing Innovative Technology in Single Family Rehabilitation	15.00
88-309	Energy Planning for Economic Development	18.00
88-308	Conversion of Resource Recovery Steam to Hot and Chilled Water Systems	10.00
88-306	HVAC Equipment Replacement for Best Size and Efficiency, Transfer Report	15.00
88-305	Cogeneration and Cooling in Small Scale Applications	15.00
88-304	Energy Master Planning: Innovative Design and Energy Analysis Services for New Commercial	22.00
88-303	Energy Efficient Building Design: Guidelines for Local Government	15.00
88-302	Direct Digital Control of Air Washer Cooling System	15.00
88-301	Feasibility Study of Transportation Management Strategies in the Poplar Corridor, Memphis, Tennessee	18.00
87-327	Energy Efficient Urban Cooling Technologies: 1st National Conf.	20.00
87-324	Memphis Area Rideshare	15.00
87-317	Joint City Government/Utility Partnerships to Reduce Business Costs	15.00
87-314	The Impact of Budgetary Incentives on Energy Management	15.00

Publications Price List--UCETF Reports

ITEM #	TITLE	PRICE
87-313	Computer Assisted Control for Municipal Water Systems, Phase II	20.00
87-312	Economic Development Through Energy Technology Transfer	15.00
87-311	Electric Utility Franchise Guide	20.00
87-310	Hidden Link: The Energy and Economic Development, Phase II	15.00
87-307	Municipal Underground Storage Tanks: An Energy Manager's Guide	18.00
87-306	Integrating Energy Efficiency into Mun. Purchasing Decisions	20.00
87-305	Energy Enhancement in New Residential Construction	40.00
87-302	Thermal Energy Storage: Application Guide for Local Governments	20.00
87-301	HVAC Equipment Replacement for Best Size & Efficiency	20.00
86-315	Balancing Single Pipe Steam Heating Systems	20.00
86-314	Inhibition of Respiration in Activated Sludge by High Carbon Dioxide Concentration	7.50
86-313	Water Supply System Energy Conservation Through Computer Control	18.00
86-312	Energy Cost Reduction Through Wastewater Flow Equalization	20.00
86-311	High Efficiency Gas Furnace Modification in Low Income Housing	15.00
86-310	Hidden Link: Energy and Economic Development, Phase I	15.00
86-307	Disposal Techniques with Energy Recovery for Scrapped Vehicle Tires	20.00
86-306	District Heating Marketing: Analysis of a Twelve City Survey	20.00
86-305	Technology Transfer for Residential Energy Programs in New Construction and Existing Housing	15.00
86-304	Technology Transfer for Residential Energy Efficiency	15.00
86-302	Neighborhood Energy Efficiency & Reinvestment	15.00
86-301	On-Site Municipal Fuel Cell Power Plan: Feasibility and Application Guide	15.00
85-326	Resource Recovery for Urban Yard Waste	18.00
85-323	Energy Monitoring and Controlling in Municipal Facilities	10.00
85-320	Transportation Management for Business Relocation	15.00
85-319	District Heating in Denmark	10.00
85-318	Computer-Assisted Control for Municipal Water Systems, Phase I	18.00
85-317	Financing Energy Efficient Housing as a Community Economic Development Tool	15.00
85-316	Modular District Heating Planning as a Development Tool	15.00
85-314	Alternative Techniques for Dev. of Energy Efficient Residences	15.00
85-312	Shared Savings and Low Income Homeowners	18.00
85-311	Measures and Investment Options for Community Energy Conservation	18.00
85-310	Planning for Energy Efficiency in New Commercial Buildings	15.00
85-308	Residential Space Heating with Wood	15.00
85-307	Thermal Storage Strategies for Energy Cost Reduction	18.00
84-325	Shared Savings in the Residential Market	
84-324	Methanol Use in Vehicle Fleet Operations: Barriers	20.00
84-322	Energy Management and Technology for Urban Governments	15.00
84-321	Hydrate Process for Waste Water Treatment Plant Sludge Dewatering	15.00

Publications Price List--UCETF Reports

ITEM #	TITLE	PRICE
84-320	Development of Computerized Inventory and Maintenance System for Municipal Street Lights	15.00
84-317	Facilities Energy Monitoring System	15.00
84-314	Application of Mini-Van Technology to Vanpool Services	18.00
84-312	Implementation Methods for an Integrated Energy System	10.00
84-311	Feasibility of Water-Based District Heating and Cooling	15.00
84-310	Budgetary Incentives for Municipal Energy Management	22.00
84-309	Central Energy Systems Applications to Economic Development	20.00
84-308	On-Site Cogeneration for Office Buildings	15.00
84-306	Analysis of Municipal Bus Operations for the Advancement of Fuel Cell Technology	15.00
84-305	Computer Based Maintenance	15.00
84-304	Innovative Finance Plans for Privately Owned Waste/Vol. 2	15.00
84-303	Innovative Finance Plans for Privately Owned Waste/ Vol. 1	15.00
84-301	Coordinating Preventive Maintenance with Energy Management	15.00
83-319	The Rehabilitation and Retrofit of Older Houses to Superinsulated Standards	15.00
83-318	Developing Sources and Techniques for Alternative Financing of Energy Conservation	20.00
83-316	Hydrate Process for Dewatering Sewage Sludge	10.00
83-315	Financial Planning for District Heating: Brooklyn Navy Yard	15.00
83-314	Memphis Area Rideshare On-Line Information System	18.00
83-313	Renovation Opportunities for Steam District Heating Systems	18.00
83-312	Initial Assessment of District Heating and Cooling	20.00
83-311	Energy Conservation Through Computerized Automation	18.00
83-309	Development of an Energy Park: Issues and Implementation Options	15.00
83-308	Alternative Uses for Digester Methane Gas	25.00
83-307	Innovative Financing and Incentive Package to Reduce Energy	15.00
83-305	Multi-Jurisdictional Planning for District Heating and Cooling	10.00
83-303	Improving Energy Management and Accountability in Municipal Operations	15.00
82-320	Utilization of Felled City Trees as Supplemental Boiler Fuel	7.50
82-319	Methanol Use in Vehicle Fleet Operations: Comparisons	15.00
82-317	Microcomputer Tools for Trans. and Residential Energy Conservation	20.00
82-316	Reduction of Impediments to Alternative Energy Use	20.00
82-315	Reducing Regulatory and Financial Impediments to Energy Conservation	20.00
82-314	Integrating Energy Management with Economic Development	20.00
82-313	Energy Conservation and Economic Development	10.00
82-310	Municipal Technologies	20.00
82-307	Strategies to Improve Community Energy Use Practices	10.00
82-306	Energy Conservation In Water Treatment	
82-305	Development of an Energy Action Plan: Participating Approach	15.00
82-303	Energy Economic Development	20.00

Publications Price List--UCETF Reports

ITEM #	TITLE	PRICE
82-302	Public Housing Energy Efficiency Through Private Financing	10.00
82-300	Developing an Energy Management Tracking System	
81-328	Matching End Use Energy Needs to Source Possibilities	20.00
81-327	Development of a Hydrogen-Fueled Mass Transit Vehicle s	15.00
81-326	Operational and Maintenance Guidelines for Reducing Energy Consumption	
81-324	Energy Management for Small Business	10.00
81-320	Energy Data Gathering, Analysis, and Review System	20.00
81-318	Fuel Management and Planning System for Local Government	25.00
81-316	Production of Ethanol from Cellulosic Fraction	
81-313	Metro-Dade County Comprehensive Energy Emergency Plan	
81-311	Developing Energy Emergency Preparedness	15.00
81-310	Simplified Methodology for Community Energy Management	20.00
81-309	Energy Management: The Public Sector	15.00
81-307	Municipal Technical Assistance-Energy Monitoring	6.00
81-306	New Technology Demonstration	10.00
81-305	Technology Transfer: Unit Report from the Energy Task Force	15.00
81-304	Development of Local Energy Management Preparedness	10.00
81-303	Municipal Energy Management	10.00
80-314	Methodology for Energy Impact Analysis of Urban Development Projects	15.00
80-313	Evaluation of Landfill Gas as an Energy Source	15.00
80-309	Decision Process for the Retrofit of Municipal Buildings	20.00
80-308	Primary Urban Energy Management Planning Methodology	7.50
80-306	Local Government Use of Thermography for Energy	15.00
79-300	Planning for and Purchasing Computer Technology	6.50

END

**DATE
FILMED**

3/2/94