(CLASSIFICATION)

HANFORD ATOMIC PRODUCTS OPERATION - RICHLAND, WASHINGTON

DE92 005508

TITLE

ISSUING FILE

AUTHOR

[illegible]

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

54-3000-010 (9-56)

A.E.C. - G.E. - RICHLAND, WASH.

1997, 1998, 1999, 2000, 2001, 2002, 2003, 2004, 2005, 2006, 2007, 2008, 2009, 2010, 2011, 2012, 2013, 2014, 2015, 2016, 2017, 2018, 2019, 2020, 2021, 2022, 2023, 2024, 2025, 2026, 2027, 2028, 2029, 2030, 2031, 2032, 2033, 2034, 2035, 2036, 2037, 2038, 2039, 2040, 2041, 2042, 2043, 2044, 2045, 2046, 2047, 2048, 2049, 2050, 2051, 2052, 2053, 2054, 2055, 2056, 2057, 2058, 2059, 2060, 2061, 2062, 2063, 2064, 2065, 2066, 2067, 2068, 2069, 2070, 2071, 2072, 2073, 2074, 2075, 2076, 2077, 2078, 2079, 2080, 2081, 2082, 2083, 2084, 2085, 2086, 2087, 2088, 2089, 2090, 2091, 2092, 2093, 2094, 2095, 2096, 2097, 2098, 2099, 2100, 2101, 2102, 2103, 2104, 2105, 2106, 2107, 2108, 2109, 2110, 2111, 2112, 2113, 2114, 2115, 2116, 2117, 2118, 2119, 2120, 2121, 2122, 2123, 2124, 2125, 2126, 2127, 2128, 2129, 2130, 2131, 2132, 2133, 2134, 2135, 2136, 2137, 2138, 2139, 2140, 2141, 2142, 2143, 2144, 2145, 2146, 2147, 2148, 2149, 2150, 2151, 2152, 2153, 2154, 2155, 2156, 2157, 2158, 2159, 2160, 2161, 2162, 2163, 2164, 2165, 2166, 2167, 2168, 2169, 2170, 2171, 2172, 2173, 2174, 2175, 2176, 2177, 2178, 2179, 2180, 2181, 2182, 2183, 2184, 2185, 2186, 2187, 2188, 2189, 2190, 2191, 2192, 2193, 2194, 2195, 2196, 2197, 2198, 2199, 2200, 2201, 2202, 2203, 2204, 2205, 2206, 2207, 2208, 2209, 2210, 2211, 2212, 2213, 2214, 2215, 2216, 2217, 2218, 2219, 2220, 2221, 2222, 2223, 2224, 2225, 2226, 2227, 2228, 2229, 2230, 2231, 2232, 2233, 2234, 2235, 2236, 2237, 2238, 2239, 2240, 2241, 2242, 2243, 2244, 2245, 2246, 2247, 2248, 2249, 2250, 2251, 2252, 2253, 2254, 2255, 2256, 2257, 2258, 2259, 2260, 2261, 2262, 2263, 2264, 2265, 2266, 2267, 2268, 2269, 2270, 2271, 2272, 2273, 2274, 2275, 2276, 2277, 2278, 2279, 2280, 2281, 2282, 2283, 2284, 2285, 2286, 2287, 2288, 2289, 2290, 2291, 2292, 2293, 2294, 2295, 2296, 2297, 2298, 2299, 2300, 2301, 2302, 2303, 2304, 2305, 2306, 2307, 2308, 2309, 2310, 2311, 2312, 2313, 2314, 2315, 2316, 2317, 2318, 2319, 2320, 2321, 2322, 2323, 2324, 2325, 2326, 2327, 2328, 2329, 2330, 2331, 2332, 2333, 2334, 2335, 2336, 2337, 2338, 2339, 2340, 2341, 2342, 2343, 2344, 2345, 2346, 2347, 2348, 2349, 2350, 2351, 2352, 2353, 2354, 2355, 2356, 2357, 2358, 2359, 2360, 2361, 2362, 2363, 2364, 2365, 2366, 2367, 2368, 2369, 2370, 2371, 2372, 2373, 2374, 2375, 2376, 2377, 2378, 2379, 2380, 2381, 2382, 2383, 2384, 2385, 2386, 2387, 2388, 2389, 2390, 2391, 2392, 2393, 2394, 2395, 2396, 2397, 2398, 2399, 2400, 2401, 2402, 2403, 2404, 2405, 2406, 2407, 2408, 2409, 2410, 2411, 2412, 2413, 2414, 2415, 2416, 2417, 2418, 2419, 2420, 2421, 2422, 2423, 2424, 2425, 2426, 2427, 2428, 2429, 2430, 2431, 2432, 2433, 2434, 2435, 2436, 2437, 2438, 2439, 2440, 2441, 2442, 2443, 2444, 2445, 2446, 2447, 2448, 2449, 2450, 2451, 2452, 2453, 2454, 2455, 2456, 2457, 2458, 2459, 2460, 2461, 2462, 2463, 2464, 2465, 2466, 2467, 2468, 2469, 2470, 2471, 2472, 2473, 2474, 2475, 2476, 2477, 2478, 2479, 2480, 2481, 2482, 2483, 2484, 2485, 2486, 2487, 2488, 2489, 2490, 2491, 2492, 2493, 2494, 2495, 2496, 2497, 2498, 2499, 2500, 2501, 2502, 2503, 2504, 2505, 2506, 2507, 2508, 2509, 2510, 2511, 2512, 2513, 2514, 2515, 2516, 2517, 2518, 2519, 2520, 2521, 2522, 2523, 2524, 2525, 2526, 2527, 2528, 2529, 2530, 2531, 2532, 2533, 2534, 2535, 2536, 2537, 2538, 2539, 2540, 2541, 2542, 2543, 2544, 2545, 2546, 2547, 2548, 2549, 2550, 2551, 2552, 2553, 2554, 2555, 2556, 2557, 2558, 2559, 2560, 2561, 2562, 2563, 2564, 2565, 2566, 2567, 2568, 2569, 2570, 2571, 2572, 2573, 2574, 2575, 2576, 2577, 2578, 2579, 2580, 2581, 2582, 2583, 2584, 2585, 2586, 2587, 2588, 2589, 2590, 2591, 2592, 2593, 2594, 2595, 2596, 2597, 2598, 2599, 2600, 2601, 2602, 2603, 2604, 2605, 2606, 2607, 2608, 2609, 2610, 2611, 2612, 2613, 2614, 2615, 2616, 2617, 2618, 2619, 2620, 2621, 2622, 2623, 2624, 2625, 2626, 2627, 2628, 2629, 2630, 2631, 2632, 2633, 2634, 2635, 2636, 2637, 2638, 2639, 2640, 2641, 2642, 2643, 2644, 2645, 2646, 2647, 2648, 2649, 2650, 2651, 2652, 2653, 2654, 2655, 2656, 2657, 2658, 2659, 2660, 2661, 2662, 2663, 2664, 2665, 2666, 2667, 2668, 2669, 2670, 2671, 2672, 2673, 2674, 2675, 2676, 2677, 2678, 26

(CLASSIFICATION)

DISTRIBUTION RESTRICTED TO U.S. ONLY

TO BE USED ON UNCLASSIFIED AND OFFICIAL USE ONLY DOCUMENTS

THE EFFECT OF CHEMICAL ADDITIVES AND COATING MATERIALS
ON THE ADSORPTION OF RADIONUCLIDE PARENT ELEMENTS
ON ALUMINUM SURFACES

by

R. W. Perkins and D. E. Robertson

Radiological Chemistry
Chemical Research
HANFORD LABORATORIES OPERATION

December 26, 1962

HANFORD ATOMIC PRODUCTS OPERATION
RICHLAND, WASHINGTON

NOTICE!

This report was prepared for use within General Electric Company in the course of work under Atomic Energy Commission Contract AT-(45-1)-1350, and any views or opinions expressed in the report are those of the authors only. This report is subject to revision upon collection of additional data.

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission to the extent that such employee or contractor prepares, handles or distributes, or provides access to, any information pursuant to his employment or contract with the Commission.

THE EFFECT OF CHEMICAL ADDITIVES AND COATING MATERIALS
ON THE ADSORPTION OF RADIONUCLIDE PARENT ELEMENTS
ON ALUMINUM SURFACES

by

R. W. Perkins and D. E. Robertson

ABSTRACT

Laboratory studies have been conducted under simulated reactor operating conditions to determine the effect of various chemical additives and coatings on the adsorption of trace elements on aluminum surfaces. Of the materials tested, silicate additives and organic ink coatings were by far the most effective, reducing the adsorption of arsenic and phosphorus tracers by as much as one to three orders of magnitude. The laboratory techniques and results are discussed.

INTRODUCTION

The radionuclides present in reactor effluent water are produced almost entirely from parent elements which are adsorbed on aluminum tubing or fuel element surfaces from process water and are subsequently eluted and discharged in the effluent water⁽¹⁾. The effluent water radionuclide concentration might, therefore, be greatly reduced if a method of minimizing this adsorption of parent materials could be developed. The factors influencing the adsorption of undesirable parent materials on aluminum surfaces are being studied under simulated reactor conditions with the aim of minimizing their adsorption and retention.

The daughter radionuclides which are of major concern in reactor effluent water are P^{32} and As^{76} . Other radionuclides which are important but of lesser immediate concern are Np^{239} , Na^{24} , Zn^{65} , and Cu^{64} .

Normal process water is a rather high purity water, but it contains significant amounts of several salts (see Table I). The presence of many of these salts is not objectionable as far as the contribution of their daughter products to effluent water radioactivity is concerned; however, their effect on the adsorption and retention of trace amounts of undesirable parent elements could be very significant. The effect of increasing (and decreasing) the concentrations of these major constituents in process water is, therefore, considered important in understanding the contributing factors in adsorption of parent elements on aluminum surfaces. The effect of several other additives is also being investigated.

Summary and Conclusions

The adsorption of the effluent water radionuclide parent elements, phosphorous and arsenic, by aluminum surfaces under simulated reactor conditions has been studied. The effect produced by pretreatment of aluminum surfaces or by continuous addition to process water of about 100 test reagents has been measured.

Of the reagents tested, sodium silicate was the most effective water additive in reducing parent adsorption from process water. Of the coating agents, "Flo-Master" black ink was most effective in reducing adsorption; however, an evaluation of its long term effectiveness is not yet complete.

Increasing the concentrations of the major cations and anions, Ca^{++} , Mg^{++} , CO_3^{--} and SO_4^{--} , which are present in process water did not reduce the adsorption of parent elements on aluminum surfaces. Reducing the overall concentration of process water salts by dilution with distilled water actually increased the fraction of adsorption of parent elements.

Theoretical

When aluminum metal is exposed to hot process water, a dark brown "adsorption film" consisting mainly of aluminum and iron oxides forms on its surface. This

film acts as an adsorption surface for other trace materials in the process water, and an equilibrium between adsorption and desorption plus erosion is approached. In a nuclear reactor this process occurs on the surface of fuel elements and the adjacent process tubing and provides a mechanism for the retention of process water trace elements in the high neutron flux zone of the reactor for long periods of time. Calculations based on the concentrations of parent elements in the influent water and radioactivity in the effluent water indicate that the average reactor residence time of many parent elements is several orders of magnitude greater than that required for the water to pass through the reactor⁽¹⁾.

Our laboratory studies have shown that if the buildup of this surface film on aluminum is inhibited, the adsorption of parent elements of the undesirable effluent water radionuclides is greatly reduced. Also, it has become apparent that many adsorption inhibitors are also corrosion inhibitors. Sodium silicate, a well known corrosion inhibitor for aluminum^(2 - 6), was found to be a very good adsorption inhibitor. Ink coatings which have been observed to reduce aluminum corrosion in the reactors⁽⁷⁾ have proven to be excellent adsorption inhibitors in laboratory tests. It appears that a study of methods for minimizing reactor effluent water radioactivity can well be based on processes for minimizing corrosion. The aqueous corrosion of aluminum is inhibited either by inhibitive treatment of the water or by metal pre-treatment techniques, and a considerable amount of work has been done in these fields.

Many of the standard inhibitive treatments for water are discussed by Evans⁽⁸⁾, and several of these have already been tested in our work. Metal pre-treatment for corrosion protection is also discussed by Evans⁽⁹⁾, and up-to-date reviews on aluminum corrosion control for the past two years have been prepared by Carter^(10,11). Some of the newly developed pre-treatment processes which inhibit aluminum corrosion

and appear promising as adsorption inhibitors include chemical polishing, hard surface anodizing, self coloring anodizing, inorganic and organic fast coloring, conversion filming (sealing Zn, Cr, salts or other materials in anodized surfaces), and aluminum coating of aluminum by vacuum vaporization or other techniques. All of these techniques are designed to give a more inert surface which presumably would not be as likely to form an adsorption film. The adsorption properties of these surfaces are presently being studied.

Experimental

Two experimental setups have been used for laboratory studies of adsorption processes. The first setup is designed for a coupon study and involves the exposure of 1-inch diameter by 1/16-inch-thick aluminum discs to process water in a 4 liter constant temperature bath. (See Figure 1). The bath is maintained at 90 to 95 C, is stirred continuously, and fresh process water is added at a rate of 5 ml/min. The coupons, which are suspended on glass hangers, are exposed to the water for a day, then boiled in a "poison" solution for 10 minutes, returned to the bath, which has now been spiked with a radioactive tracer of the parent element of interest, and allowed to remain for a predetermined time. The coupon is finally removed, washed with distilled water, and its' radioactivity compared with that of an identically exposed coupon which had been boiled 10 minutes in process water. The uptake of radioactivity by the coupon relative to the blank is used as an index of the effectiveness of the poisons in reducing adsorption of the tracers.

The second experimental setup is a "one pass" system designed to simulate a reactor process tube, except that no effort was made to obtain a comparably high flow rate. The setup uses condenser jacketed columns containing aluminum turnings over which process water containing the additive being tested is allowed to flow continuously (Figure 2). The columns are maintained at 90 to 95 C by circulating

hot water through their jackets. For the experiments considered here, the pH of the influent was maintained at 7 ± 0.1 . To determine the effect on the adsorption of parent elements of the various process water additives being tested, the columns were spiked periodically with radioactive tracers and the fraction adsorbed by the aluminum surfaces determined from measurements of the effluents.

In the coupon study, preliminary measurements of about 90 materials were made to determine their effect on the adsorption of As^{76} and P^{32} . These poisons included 0.001 to 0.1 M solutions of the salts normally present in process water, mono-, di-, tri-, and quadrivalent anions and cations mainly as their sodium or nitrate salts, plus about 20 surface-active agents and several coating materials. The effect of most of these reagents on the adsorption of As^{76} and P^{32} was surprisingly small (See Table II). The materials showing the largest effect were sodium metasilicate (pH7), the coatings, and the surface-active agents Antaron FC-34 and octadecylamine acetate. The adsorption of As^{76} and P^{32} with silicate treatment was reduced by factors of 5 and 2, respectively. The various coating materials reduced the adsorption of As^{76} by up to 16 fold. The Antaron FC-34 reduced adsorption of As^{76} by about a factor of 6 and P^{32} by about a factor of 2, while the octadecylamine gave results which varied from a factor of 15 reduction to essentially no effect.

The reagents Antaron FC-34, octadecylamine acetate, and sodium silicate plus several salts containing the major ions present in process water were used as additives at 5 to 100 ppm for the column studies. The amounts of tracers adsorbed were arbitrarily taken as that remaining when 200 ml of the water had passed through the columns after spiking. These values are expressed in terms of fraction adsorbed relative to that adsorbed from normal process water in Table III. Under the conditions of these experiments, about 49 per cent, 56 per cent and 51 per cent

of the As^{76} , P^{32} , and Zn^{65} , respectively, are adsorbed from normal process water. It is evident from the data in Table III that, of the additives tested, only silicate had a marked effect on the adsorption of the tracers. It was also observed in these studies that a gross reduction of the salt content (as obtained by dilution of process water with distilled water) of process water increases the fraction of the tracers which are adsorbed (See Table III). A gross reduction in the salt content which did not reduce a particular parent element might therefore result in an increase in the concentrations of its radioactive daughter in the effluent.

Because of the obvious superiority of silicate, it was studied further at concentrations of 20 ppm and 4 ppm as SiO_2 and also as the ammonium salt and as silicic acid. The ammonium and acid derivatives were prepared by passing dilute sodium silicate solutions through Dowex-50 cation columns in the ammonium and acid forms respectively. Preliminary tests with these reagents are included in Table IV. These data show that neither of the silicate derivatives (at least as prepared by this method) are as effective as the sodium silicate in reducing the adsorption of AsO_4^{3-} and PO_4^{3-} on aluminum surfaces. Also, the effectiveness of sodium silicate drops off considerably in going from 20 to 4 ppm.

When an aluminum turnings column which has been on a normal process water feed for one month is switched to a feed containing 100 ppm SiO_2 as sodium silicate, there is a reduction in the amounts of PO_4^{3-} tracer adsorbed. The relative fraction of PO_4^{3-} which was adsorbed after this treatment is compared in Table V with a column which was originally on 100 ppm SiO_2 .

Although the addition of sodium silicate after a corrosion film has built up will reduce the adsorption of trace elements, the reduction of PO_4^{3-} after 3 days of silicate treatment is about an order of magnitude less than that obtained where silicate addition is started with a new surface. The effect of sodium

silicate addition on aluminum surfaces is impressive both from the reduced adsorption of undesirable parent materials and from actual appearance of the columns. Figure 3 is a photograph showing a column which has been on normal process water and one which has been on process water containing 100 ppm SiO_2 as sodium silicate. The silicate column remains bright and new in appearance while the normal column is corroded and covered with a dark film. Sodium silicate does not have a long term inhibiting effect, but must be added continuously to maintain the desirable reactions.

Discussion

Closely following the laboratory studies, a single tube reactor test of the effect of silicate addition on effluent water radioactivity was conducted⁽³⁾. The reactor test conditions could not be controlled completely, but the test was reasonably successful and showed a 2 to 3 fold reduction in the more important radionuclides. The coating agents have shown definite promise as corrosion inhibitors for aluminum in reactors and are presently being tested in a reactor to determine their adsorption properties for parent elements. Further laboratory tests will evaluate both coatings or pre-filming techniques and the inhibitive treatment of water on the adsorption of parent elements by aluminum surfaces.

REFERENCES

1. Perkins, R. W., Source of Reactor Effluent Water Radioisotopes, HW-69969, May 1961 (Secret).
2. Vail, James G., Soluble Silicates, Vol II, 245-270, Reinhold Publishing Corp., New York, 1952.
3. Robertson D. E. and R. W. Perkins, Reduction of the Effluent Water Radionuclides by Addition of Sodium Silicate to Process Water, HW-75782, Dec. 10, 1962.
4. Kidder, C. P., CMX Final Report, No. 7-4444, July 31, 1946 (Declassified).
5. Bieffer, G. A. and P. G. Anderson, "Corrosion Behavior of Aluminum-Nickel-Iron Alloys in High-Temperature Water: Effect of Dissolved Silica as an Inhibitor", C R Met-859, 1959.
6. Haag, R. M. and F. C. Zyzer, Corrosion of Aluminum in High-Temperature Water. III Inhibition of Corrosion by Sodium Silicate, KAPL-1741, Feb. 28, 1957.
7. Geier, R. G., Personal Communication Concerning Observed Corrosion Inhibition of Ink Treated Aluminum Surfaces Exposed in a Reactor, Dec. 1962.
8. Evans, Ulick R., Metallic Corrosion Passivity and Protection, 133-186, St. Martin's Press Inc., New York, 1960.
9. Ibid, 241-262, Chapter XIV, and Chapter XV.
10. Porter, F. C., "Aluminum and Corrosion. A Review of Progress in 1960." Corrosion Prevention and Control, 7, No. 1, 33-44, 1960.
11. Porter, F. C., "Aluminum and Corrosion. A Review of Progress in 1961", Corrosion Prevention and Control, 8, No. 1, 37-43, 1961.

TABLE I
TYPICAL COLUMBIA RIVER PROCESS WATER ANALYSIS
Concentrations in Parts Per Million

<u>SO₄⁼</u>	<u>Mg</u>	<u>SiO₂</u>	<u>PO₄⁼</u>	<u>Mn</u>	<u>Cl</u>	<u>Cu</u>	<u>Na</u>	<u>Phth</u> <u>Alk.</u>	<u>M.O.</u> <u>Alk.</u>	<u>Hard-</u> <u>ness</u>	<u>Ca</u>	<u>Solids</u>
12	4	10	0.06	0.07	0.5	0.04	1.3	0	65	70	23	80

TABLE II
ADSORPTION OF As⁷⁶ ON CHEMICALLY TREATED
ALUMINUM COUPON SURFACES

	Reagent	pH	Concentration (M)	Relative Effectiveness*
1.	Sodium silicate (S-35)	7.0	0.01	5.2
2.	Sodium dichromate	6.0	0.1	1.3
3.	Sodium fluoride	6.3	0.1	0.20
4.	Sodium iodide	6.5	0.1	0.76
5.	Sodium sulfite	9.5	0.1	0.29
6.	Sodium formate	6.8	0.1	0.66
7.	Sodium potassium tartarate	6.7	0.1	0.44
8.	Sodium hydrosulfite	4.7	0.1	0.28
9.	Sodium bismuthate	7.0	sat'd	0.50
10.	Sodium bromate	6.5	0.1	0.87
11.	Sodium bicarbonate	8.0	0.1	0.80
12.	Sodium nitrate	5.5	0.1	0.97
13.	Sodium oxalate	6.6	0.1	0.34
14.	Sodium sulfate	6.4	0.1	0.67
15.	Sodium thiosulfate	6.4	0.1	0.53
16.	Sodium borate	9.0	0.1	0.42
17.	Sodium arsenate	7.5	0.1	1.6
18.	Potassium permanganate	6.2	0.1	0.39
19.	Sodium nitrite	6.5	0.1	0.39
20.	Potassium ferrocyanide	7.5	0.1	0.49
21.	Potassium ferricyanide	6.5	0.1	0.35
22.	Potassium chlorate	5.8	0.1	1.0
23.	Potassium periodate	6.0	sat'd	0.31
24.	Potassium biphthalate	4.5	0.1	0.46
25.	Potassium perrhenate	6.0	sat'd	0.74
26.	Ammonium thiocyanate	5.8	0.1	0.44
27.	Ammonium citrate	5.2	0.1	1.2
28.	Ammonium chloride	5.7	0.1	0.90
29.	Ammonium molybdate	5.4	0.1	0.31
30.	Ammonium fluorosilicate	3.7	0.1	0.22
31.	Copper (II) sulfate	4.5	0.1	0.23
32.	Barium nitrate	5.3	0.1	0.45
33.	Mercury (II) chloride	3.6	sat'd	0.32
34.	Manganese (II) sulfate	5.6	0.1	0.42
35.	Chromium (III) chloride	3.2	0.1	0.41
36.	Cobalt (II) chloride	6.0	0.1	0.33
37.	Iron (III) chloride	2.0	0.1	0.36
38.	Palladium (III) chloride	3.5	0.001	0.13
39.	Neodymium (III) chloride	5.2	0.1	0.32

TABLE II (CONTINUED)

REAGENT	pH	CONCENTRATION (M)	RELATIVE EFFECTIVENESS*
40. Zirconyl nitrate	2.0	0.05	0.88
41. Tin (II) chloride	3.2	0.001	0.38
42. Lithium nitrate	6.0	0.1	0.60
43. Lanthanum (III) nitrate	6.0	0.1	0.40
44. Cerium (III) nitrate	3.3	0.1	0.42
45. Aluminum nitrate	3.3	0.1	0.53
46. Zinc nitrate	5.0	0.1	0.39
47. Lead (II) nitrate	4.5	0.1	0.41
48. Ferric ammonium sulfate	2.2	0.1	0.54
49. Nickel (II) chloride	6.5	0.1	0.36
50. Magnesium nitrate	5.3	0.1	0.36
51. Strontium (II) nitrate	6.0	0.1	0.67
52. Iron (III) nitrate	2.1	0.1	0.93
53. Chromium (III) nitrate	3.0	0.1	0.99
54. Cobalt (II) nitrate	5.0	0.1	0.21
55. Silver nitrate	4.5	0.1	0.34
56. Bismuth (III) nitrate	1.2	sat'd	0.54
57. Silicotungstic acid	2.1	0.1	0.56
58. Tungstic acid	5.0	sat'd	0.32
59. Magnesium perchlorate	6.0	0.1	1.2
60. Calcium nitrate	5.2	0.1	0.92
61. Iodic acid	2.0	0.1	0.41
62. Urea	6.5	0.1	0.91
63. Chloramine-T	7.0	0.01	1.3

<u>Surface-Active Agents</u>	<u>pH</u>	<u>Concentration</u>	<u>Relative Effectiveness*</u>
1. Sipon L-22	7.1	All surface-active agents	0.44
2. G-263	4.3	were prepared by diluting	0.37
3. Antaron FC-34	8.6	the commercial product	5.5
4. Triton QS-15	10.0	1:2.5 with distilled water.	0.63
5. Aersol OT	2.6		0.64
6. Ceron AN	--		1.9
7. Ceron N	--		2.4
8. Ceron CN	--		1.7
9. Ninex 303	6.6		1.9
10. Stepanate T	--		2.2
11. Sodium lauryl ether sulfate	3.8		0.98
12. Alipal RC 335	6.6		0.59
13. Monad G	6.1		0.78
14. Alipal CO-436	7.0		0.50
15. Hyamine 2389	6.5		0.98
16. Octafilm-120	8.0		1.4
(Octadecylamine acetate)			

TABLE II (CONTINUED)

Painted Coatings	Relative Effectiveness*
1. "Marks-a-Lot" black ink	9.1
2. "Marks-a-Lot" green ink	6.0
3. "Flo-Master" black ink	15.8
4. "Flo-Master" blue ink	3.6
5. "Flo-Master" red ink	7.0
6. Octafilm 120	1.1
7. Sodium silicate baked coating	1.3
8. Krylon (clear)	6.8

$$\text{*Relative effectiveness} = \frac{\text{As}^{76} \text{ Activity on Process Water Treated Coupon}}{\text{As}^{76} \text{ Activity on Chemically Treated Coupon}}$$

TABLE III

ADSORPTION OF RADIONUCLIDES FROM TREATED
PROCESS WATER ON COLUMNS OF ALUMINUM TURNINGS

Additive	Chemical Form	Concentration, ppm	Relative Fraction Adsorbed*		
			As ⁷⁶	P ³²	Zn ⁶⁵
Ca ⁺⁺	Ca(NO ₃) ₂ ·4H ₂ O	100 ppm	1.2	1.1	0.99
CO ₃ ⁼	NaHCO ₃	100 ppm	1.4	1.2	0.99
Mg ⁺⁺	Mg(NO ₃) ₂ ·6H ₂ O	100 ppm	3.8	1.3	----
SO ₄ ⁼	Na ₂ SO ₄	100 ppm	1.1	1.2	1.0
Antaron-FC-34		50 ppm	0.3	0.3	
Octadecylamine Acetate		5 ppm	1.2	1.1	
SiO ₃ ⁼	Na ₂ SiO ₃ ·9H ₂ O	100 ppm	0.01-0.001	0.01-0.001	
10% Process Water - 90% Distilled Water			-	1.7	

$$\text{*Relative Fraction Adsorbed} = \frac{\text{Amount on column from treated water}}{\text{Amount on column from normal water}}$$

TABLE IV

ADSORPTION OF RADIONUCLIDES FROM PROCESS WATER CONTAINING SILICATES

Compound Added	SiO ₂ Concentration, ppm	Relative Fraction Adsorbed	
		As ⁷⁶	P ³²
Na ₂ SiO ₃ ·9H ₂ O	20	0.01-0.001	0.01-0.001
Na ₂ SiO ₃ ·9H ₂ O	4	0.4	
(NH ₄) ₂ SiO ₃ *	20	0.1	0.4
H ₂ SiO ₃	20	0.1	0.3

*Assumed formula

TABLE V

COMPARISON OF THE ADSORPTION OF P³²
ON A ONE MONTH OLD SURFACE AFTER SWITCHING TO A 100 PPM SiO₂ FEED

	Relative Fraction Adsorbed*	
	Original Feed 100 ppm SiO ₂	Normal Feed, Switched to 100 ppm SiO ₂
P ³²	0.01-0.001	0.1

*See Footnote on Table II

FIGURE 1

Experimental Arrangement for Adsorption Measurements on Aluminum Coupons

FIGURE 2
 Experimental Arrangement for Measuring the Adsorption of Tracer
 Elements on Aluminum Surfaces

FIGURE 3

Columns of Aluminum Turnings After Exposure to Process Water

A. Normal Process Water

B. Process Water Treated with Silicate at 50 ppm Si

END

DATE
FILMED
2 120192

I