FOSSIL POWER SYSTEMS

RESEARCH & DEVELOPMENT

COMBUSTION **ENGINEERING**

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DEVELOPMENT OF AN ADVANCED HIGH EFFICIENCY**COAL COMBUSTOR FOR BOILER RETROFIT****TASK 1: COLD FLOW BURNER DEVELOPMENT****FINAL REPORT****Received by OSTI**

OCT 09 1990

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DEVELOPMENT OF AN ADVANCED HIGH EFFICIENCY
COAL COMBUSTOR FOR BOILER RETROFIT

TASK 1: COLD FLOW BURNER DEVELOPMENT
FINAL REPORT

Prepared by

COMBUSTION ENGINEERING, INC.
WINDSOR, CONNECTICUT 06095

OCTOBER 1989

Project Manager

Michael J. Rini

Principal Investigators

R.C. LaFlesh
M.J. Rini
J.G. McGowan

Prepared for

U.S. DEPARTMENT OF ENERGY
PITTSBURGH TECHNOLOGY CENTER

UNDER CONTRACT NO. DE-AC 22-86PC 90275

TABLE OF CONTENTS

	<u>Page</u>
1.0 Introduction	3
2.0 Task 1.1 Project Planning	5
3.0 Task 1.2 Cold Flow Swirler Development	7
A. Introduction/ Background	7
E. Development of Primary Air Swirler Design	14
(1) Establishment of Overall Combustion Requirements	14
(2) Establishment of Range of Swirl Numbers Desired for Burner Assembly	16
(3) Establishment of Combustion Mass Flow Requirements	18
(4) Establishment of Overall Burner Dimension Envelope	19
(5) Establishment of Primary and Secondary Air Velocities	20
(6) Swirler Blade Design Procedure	21
(A) Curved Bladed Swirlers	23
(B) Straight Vane Swirlers	27
(7) Pressure Drop Considerations	30
(8) Geometry Restrictions	31
(9) Establishment of Final Swirler Design	31
C. Secondary Flow Geometry Design	32
D. Swirler Test Facility Program	39
4.0 Task 1.3 Cold Flow Burner Model Testing Program	46
A. Introduction/ Background	46
B. Cold Flow Modeling- Experimental Approach	50
C. Experimental Results	51
5.0 Task 1.4 Burner Scale Up Criteria	64
A. Introduction/ Background	64
B. Design of Pilot Scale Burner	67
6.0 References	71
Appendix A Details of Automatic Probe Traversing Device	A1
Appendix B Results of Flow Visualization Experiments	B1
Appendix C Summary of Velocity Profile Tests	C1

LIST OF FIGURES

<u>FIGURE</u>	<u>PAGE</u>
2.1 Schematic of Overall Burner Development Program	6
3.1 Development of a Flame Stabilizing Aerodynamic Recirculation Zone by a Swirl Generating Device	8
3.2 Typical Axial Swirler	10
3.3 Typical Swirler Tangential Velocity Profiles	12
3.4 Schematic of Primary Air Swirler Design Procedure	15
3.5 Schematic of Flat Vane Axial Swirler	22
3.6 View of Swirl Vanes at a Given Radial Position	26
3.7 HEACC Burner Design	29
3.8 The Fate of Fuel Nitrogen During Combustion	33
3.9 Different Combustion Staging Concepts	34
3.10 NO _x Emissions from a Boiler with Staged Combustion	36
3.11 HEACC with Internal Staging	38
3.12 Plan View of Swirler Test Facility	40
3.13 Swirler Test Facility	41
3.14 Different Swirlers Tested in STF Facility	43
4.1 Prototype HEACC Cold Flow Model	47
4.2 Cold Flow Test Configurations	52
4.3 Representative Cold Flow Test	56
4.4 Summary of Cold Flow Observations	57
4.5 Test Planes for Velocity Profile Tests	62
4.6 Typical Results from Cold Flow Testing	63
5.1 CEGB/ IFRF Scaling Trials: Flame Relationships	66
5.2 Cross Section of Pilot- Scale HEACC	69

LIST OF TABLES

<u>TABLE</u>	<u>PAGE</u>
1.1 Program Outline- "Development of a High Efficiency Advanced Coal Combustor	4
3.1 Swirler Test Configurations	42
3.2 Swirler Test Facility Data	44

EXECUTIVE SUMMARY

Objectives

This report summarizes work carried out by Combustion Engineering under U.S. Department of Energy Contract no. DE-AC 22-86PC90275, "Development of an Advanced High Efficiency Coal Combustor for Boiler Retrofit." The overall objective of this program is to develop a high efficiency advanced coal combustor (HEACC) for coal-based fuels capable of being retrofitted to industrial boilers originally designed for firing natural gas, distillate, and/or residual oil. The HEACC system is to be capable of firing microfine coal water fuel (MCWF), MCWF with alkali sorbent (for SO₂ reduction), and dry microfine coal. Design priorities for the system are that it be simple to operate and will offer significant reductions in NO_x, SO_x, and particulate emissions as compared with current coal fired combustor technology. The specific objective of this report is to document the work carried out under Task 1.0 of this contract, "Cold Flow Burner Development." As are detailed in the report, key elements of this work included primary air swirler development, burner register geometry design, cold flow burner model testing, and development of burner scale up criteria.

Discussion

The overall objective of this project is to develop a firing system (HEACC) for coal-based fuels to enable the replacement of oil and natural gas in boilers and other fuel firing equipment currently using these premium fuels. The primary target for the application of the HEACC is industrial users. In the industrial sector, a significant proportion of total boiler capacity in operation in the year 2000 is expected to be composed of pre- 1980 units . Therefore, any substantial near term increase in the use of coal for producing industrial steam will therefore have to be accomplished through conversion of boilers currently fired by natural gas or oil. The application of coal or coal- based fuels to industrial boilers originally designed for gas or oil firing presents a number of challenges to the combustion engineer. Constraints such as carbon conversion efficiency, emissions control, and coal and ash handling must be

addressed and resolved.

In order to accommodate use in a wide variety of wall-fired industrial boiler sizes and types, the HEACC has been designed to be fully scalable and will also be capable of use in multi- burner arrays. The usable size range encompasses boilers from small package boilers (12,000 lb/hr) to utility boilers up to about 100 MWe. In addition to industrial boiler and small utility boiler retrofits, the HEACC could be potentially applied to cement kilns, mineral processing equipment, and some chemical process heaters. Application to cement kilns and mineral processing equipment (i.e., rotary aggregate dryers, etc.) is very attractive since these applications are very tolerant of coal ash contamination from the fuel. In process heaters, the use of beneficiated coal in a HEACC type system may also be technically feasible and economically practical in some cases.

In general, the burner is designed to feature uncomplicated operation to facilitate boiler retrofit applications and will incorporate technologies designed to control gaseous pollutant emissions of NO_x and SO_2 . In addition the HEACC will target improved aerodynamic efficiency (in the form of reduced combustion air pressure losses) as compared to conventional burner designs.

By definition, burners introduce and mix the fuel and combustion air in a boiler or process heater to obtain a stable flame. A key function of most burner designs is to manipulate the inflowing combustion air stream in such a way as to promote rapid fuel ignition by providing the correct chemical, thermal, and kinetic environment to support combustion of the incoming fuel. Flame stability is normally enhanced by creating static air pressure gradients downstream of the burner exit which intensify fuel/ air mixing and promote a small volume of combustion products to recirculate back towards the burner. This recirculating mass entrains a portion of the combusting air stream; the luminous flame front is then stabilized when the burner flame propagation speed matches the combustion air flow regime. Also, burner operation is simplified by stable flames which are insensitive to small random fluctuations in stoichiometric ratio and fuel composition.

One common method of generating favorable combustion gas recirculation in the near- field is to integrate devices into the burner air register that tend to rotate a portion of the combustion air jet issuing from the burner. If the momentum of the swirling flow is sufficiently large compared to the axial momentum of the air jet, and the tangential velocity profile is correct, then the combustion air jet reverses direction at its core. This results in the recirculation of hot combustion products back to the root of the flame to heat up the incoming fuel and air.

In selecting a specific device for generating swirl, the burner designer must concentrate on achieving a balance between aerodynamic efficiency and the required swirl. As swirl requirements increase, so do swirler mechanical energy losses. These losses are reflected in the combustion air head loss, or pressure drop, across the burner register. In general, there is significant motivation to minimize these pressure losses as they represent a parasitic loss on overall thermal system efficiency, since combustion air fan horsepower requirements increase directly proportional to burner pressure drop. This problem is increased in magnitude in the case of designing burners for coal-water fuels, since their lower reactivity as compared with conventional fuel oils or pulverized coal requires greater degrees of air swirl for flame stability and therefore operation with higher pressure drops than desirable.

While many burner manufacturers have made incremental improvements in the efficiency of conventional swirlers for CWF combustors, the focus of Task 1.0 of this work was to systematically identify and optimize advanced swirl generating devices for integration into the HEACC. Key components of this work included cold flow swirler development, a cold flow burner model testing program, and the establishment of burner scale up criteria.

The cold flow program included the development of primary air swirler designs, the design of the secondary flow geometry, and a swirler test facility program to quantify primary air swirler performance. The end result of this work was the detailed design of a number of test swirlers to be experimentally tested in a swirler test facility (STF), the best of which would be incorporated into the cold flow burner test program. The

combination of the swirler design procedure in concert with the noted pressure drop considerations and geometry restrictions, yielded 4 different designs for curved blade axial vane swirlers (2 free vortex and 2 forced vortex) and 2 different straight vaned swirlers (1 free vortex and 1 forced vortex) that were tested in the swirler test facility (STF). The best two swirler designs, as determined by the STF testing, were to be further characterized in the full scale burner cold flow model. The secondary flow geometry design part of the work made use of the principle of "internal staging" of the burner and the HEACC was designed as an internally staged burner. Based on this type of design, the ability to provide both swirled and unswirled secondary air was designed into the pilot scale burner and was also included in the demonstration scale burner to increase the flexibility of mixing control.

Under the cold flow burner model testing program, the design for the prototype HEACC cold flow model was based on the following design requirements:

- 1) The physical envelope of the HEACC (diameter and length) must be similar to conventional oil burner envelope to facilitate retrofit.
- 2) Primary air swirler stoichiometry (n_p) targeted for a value between 0.3 and 0.4 to minimize NO_x formation, with entrainment air this would give an estimated n_p between 0.6 and 0.7.
- 3) Incorporation of a low pressure loss staged air distribution system for secondary air stream(s)
- 4) Utilization of the most efficient swirler designs for the primary air stream.

The objective of the burner scale up criteria phase of the work was to develop swirler/ burner design and scaling criteria based on information derived from the parametric testing of the two previous work tasks. This criteria was to be used to design both a prototype and full scale burner assembly, as well as to obtain a general understanding of burner scale up to a broad range of industrial sizes.

Results/ Conclusions

Eight different swirlers, with four basic geometric designs were tested in the STF. The

results from this test program, included measured torque from the swirler, the swirler pressure drop (measured at ambient and projected to combustion conditions (500 °F) inlet temperature), and the ratio of the torque to the measured pressure drop. The STF quantitatively measures the torque (rotational force) imparted to the airflow by a given swirler. The torque is proportional to the swirl strength of that airflow, thus a direct and comparable measure of swirler efficiency is obtained. The results from this test program showed that several of the new designs were significantly more efficient at generating swirl than the Tangential Entry Baseline Swirler.

One design, the Forced Vortex (Swirler B) produced the greatest torque at equivalent conditions of any of the configurations tested. It produced 110% more torque than the Baseline Swirler, at an equal pressure drop. Another swirler, Free Vortex (Swirler D) produced 40% more torque than the Baseline Swirler. Two other swirlers (A and C) produced increased swirl over the baseline case, but had excessive projected pressure drops. Two segmented flat blade swirlers generated lower torque values than the Baseline Swirler. Based on these results, Swirlers B and D, shown below, were chosen as the primary air swirler configuration for further testing in the cold flow burner model test program.

SWIRLER B (FORCED VORTEX)

SWIRLER D (FREE VORTEX)

Using a basic HEACC configuration, seven different configurations, and one baseline high swirl wall fired burner were subjected to extensive testing (flow visualization and velocity mapping) in the cold flow burner model testing program. A schematic view of the prototype HEACC cold flow model is shown on the next page. In summary, the results of the cold flow testing program showed:

- 1) The flow patterns generated appear sufficient to maintain flame stability and have the potential to minimize NO_x production via internal staging.
- 2) The burner flow field was dominated by the swirler size and centrality.
- 3) Both the Forced Vortex- Swirler "B" and the Free Vortex- Swirler "D" demonstrated similar overall flow patterns. The Forced Vortex swirler did produce a somewhat larger and stronger recirculation pattern.
- 4) The removal of the outermost of three divergent nozzle rings was required to reduce the burner pressure drop to an acceptable level while maintaining the desired burner flow pattern.
- 5) The burner near field aerodynamics remained generally similar over the range of register adjustability.

Prototype HEACC Cold Flow Model Schematic

DISCLAIMER

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, makes any warranty, express or implied, or assumes any legal responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, mark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

PATENT STATUS

This technical report is being transmitted in advance of DOE patent clearance and no further dissemination or publication shall be made of the report without prior approval of the DOE Patent counsel.

TECHNICAL STATUS

This technical report is being transmitted in advance of DOE review and no further dissemination or publication shall be made of the report without prior approval of the DOE Project/Program Manager.

1. INTRODUCTION

Since the Oil embargo of 1974, there has been a major effort to develop energy systems that are not dependent on petroleum-based fuels. In the United States, with the world's most abundant coal resources, much of this effort has been focused on the expanded use of coal-based fuels by the industrial and utility sectors. The United States Department of Energy has been the leader in fostering this work. Significant progress has been made during the past decade in the fields of coal beneficiation, coal-based alternate fuels, and advanced coal combustion.

In 1986, in response to DOE PRDA DE-RA22-86PC90259, Combustion Engineering (C-E) teamed with the Energy Laboratory of the Massachusetts Institute of Technology (MIT) and assembled a program which addressed Section 1.3.4 of the PRDA, "Advanced Combustors for Boiler Retrofit and Process Heat Applications". DOE awarded to C-E and MIT a contract to develop a High Efficiency Advanced Coal Combustor (HEACC) in a systematic multi-task program.

The objective of this program is to develop an advanced coal-combustion system capable of being retrofitted to industrial boilers originally designed for firing natural gas, distillate, and/or residual oil. Through the use of beneficiated coal fuel and advanced combustion technology, the goal of the program is to produce a combustion system which is reliable, simple to operate, and incorporates significant reductions in NO_x , SO_x , and particulate emissions over a base coal case.

A systematic and coordinated program is being conducted at Combustion Engineering and the Massachusetts Institute of Technology to achieve this goal. An outline of the overall program is given in Table 1.1. Task 1 has been completed and has developed the components needed for Tasks 2.0 and 3.0. This report details the overall engineering analysis and design, and experimental results obtained under Task 1.0, "Cold Flow Burner Development,"

TASK 1.0 COLD FLOW BURNER DEVELOPMENT

- 1.1 Program Planning
- 1.2 Cold Flow Swirler Development
- 1.3 Scale Up Criteria Development
- 1.4 Task 1 Report

TASK 2.0 PILOT SCALE TESTING AT MIT

- 2.1 Test Facility Preparation
- 2.2 Atomization Testing
- 2.3 Combustion Testing at 5×10^6 Btu/hr
- 2.4 Clean Up and Waste Disposal

TASK 3.0 DEMONSTRATION TESTING AT C-E

- 3.1 Test Facility Preparation
- 3.2 Atomization Testing
- 3.3 Combustion Testing at 50×10^6 Btu/hr
- 3.4 Clean Up and Waste Disposal
- 3.5 Task 3 Report

TASK 4.0 PROJECT FINAL REPORT

- 4.1 Data Analysis
- 4.2 Final Report

TASK 5.0 OVERALL PROJECT MANAGEMENT

- 5.1 Project Management

Table 1.1 Program Outline- "Development of a High Efficiency Advanced Coal Combustor"

2. TASK 1.1 PROJECT PLANNING

Under this subtask, detailed plans were developed to address the specific objectives of the project. In order to insure a coordinated project effort, a project kick-off meeting was held at Combustion Engineering's Kreisinger Development Laboratory (CE/KDL) on November 13, 1986. The meeting was attended by four representatives from DOE/PETC, three from MIT, and several project-related CE personnel. The meeting served to formulate project task plans and to receive DOE input for Tasks 1 and 2.

On January 9, 1987 another project meeting was held between C-E and MIT. At this meeting, CWF specifications were developed, burner and swirler concepts were analyzed, and test schedules were discussed. Plans for the overall HEACC burner development program were finalized, and are summarized in Figure 2.1.

Also carried out under this task was a survey of the open literature and personal contacts with CWF manufacturers, coal beneficiation contractors, university researchers, and experts at DOE in order to assess the state-of-the-art as it existed at the start of the contract. In addition to this effort a review of previous CE work on the subject was carried out. A conclusion from this work was that previous CE work on high swirl wall fired burners such as were developed for Sundbyberg, Sweden (Smith and LaFlesh, 1984) and Chatham, New Brunswick (Borio, et al., 1984) would serve as the starting basis for the HEACC design.

Figure 2.1 Schematic of Overall Burner Development Program

3. TASK 1.2 COLD FLOW SWIRLER DEVELOPMENT

A. INTRODUCTION/ BACKGROUND

The objective of this subtask was to develop a high efficiency combustion air swirler for incorporation into the HEACC. By definition, burners introduce the fuel and combustion air streams into a boiler or process heater. A key function of the burner design is to manipulate the inflowing combustion air stream in such a way as to promote diffusion flame stability by rapid fuel ignition.

Flame stability is normally enhanced by creating static air pressure gradients downstream of the burner exit which intensify fuel/ air mixing and promote a small volume of combustion air to recirculate back towards the burner. This recirculating mass of air entrains a portion of the combusting fuel stream; the luminous flame front is then stabilized when the burner propagation speed has been correctly matched to the combustion air flow regime. Safe, unattended burner operation is ensured by stable flames which are insensitive to small random fluctuations in stoichiometric ratio and fuel composition.

One common method of generating favorable combustion air recirculation in the near-field is to integrate devices into the burner air register which tend to rotate a portion of the combustion air issuing from the burner. If the angular momentum of the swirling flow is sufficiently large compared to the axial momentum of the air jet, and the tangential air velocity profile is correct, then the combustion air jet reverses direction at its core and a central, flame stabilizing, torroidal vortex is established as illustrated in Figure 3.1 (Beer, 1972).

In selecting a specific device for generating swirl, the burner designer must concentrate on achieving a balance between aerodynamic efficiency and required swirl. As swirl requirements increase, so does swirler mechanical energy consumption. This is reflected in the combustion air head loss, or pressure drop, across the burner register. There is significant motivation to minimize these pressure

**Figure 3.1 Development of a Flame Stabilizing Aerodynamic
Recirculation Zone by a Swirl Generating Device**

losses as they represent a parasitic loss on overall heating plant efficiency, since combustion air fan horsepower requirements directly increase with increases in burner register pressure drop. The problem is acute in the case of designing burners for coal-water fuels, since their lower reactivity, compared with conventional fuel oils or pulverized coal, requires greater degrees of air swirl for flame stability and, therefore, have operated with higher pressure losses than desirable.

While incremental improvements in the efficiency of conventional swirlers designed for CWF combustors have been made (Rini, et al., 1986), the focus of Task 1.2 was to systematically identify and develop advanced swirl generating devices for integration into the HEACC.

As will be discussed, one promising swirl generation concept derives from aerospace industry research into axial-flow compressor vane cascades for gas turbines. Also, researchers have utilized cascade vane design technology on a swirler concept for application as a flame stabilizer in rocket-ramjet combustors. Swirlers designed and tested in this study were of the axial flow variety, similar to inlet guide blades used in gas turbine compressors. As shown in Figure 3.2, the swirlers are comprised of a series of circular arc blades which surround a long central hub. Test swirlers were designed based on analytical relations and experimental data obtained from two-dimensional vane cascade studies. This design procedure provided an engineering tool for determining optimum axial flow vane geometry given specific swirl requirements. In following sections, this design procedure will be presented.

Using this design methodology and C-E burner experience, a series of six advanced concept swirlers were designed by C-E and fabricated for cold flow testing. Also, in order to evaluate and quantify the mechanical efficiency of these swirlers, a total swirl measurement device was designed and constructed. This swirler test facility (STF) is designed to quantify the total angular momentum of the aerodynamic flow field generated by a test swirler with respect to the static pressure loss across the swirler device. As will be discussed in a following section, the STF is capable of accommodating industrial-scale swirl burner assemblies.

Figure 3.2 Typical Axial Swirler

In addition to swirler efficiency considerations, it should also be noted that most burner swirlers generate one of three distinct tangential velocity profiles in the near-field; these profiles also influence recirculation zone properties and are typically described as free vortex, forced vortex, and Rankine vortex profiles. They are shown schematically in Figure 3.3. Of the three, the free vortex design is most common in industrial boiler burners, however, the forced vortex design has been noted in the literature to have demonstrated potential. The swirlers designed and tested under Task 1 have been configured such that comparative evaluations of the influence of free and forced vortex flow fields on total swirler angular momentum can be made with respect to swirler pressure losses.

The advantages of burner systems that achieve flame stabilization via swirling flows are well documented (e.g., Beer and Chigier (1972), Gupta, et. al. (1984)), thus swirl type burners are used in many industrial applications. As recently noted by Schmid, et. al. (1987), the unique feature of swirl type burners is the vortex generated internal recirculation zone where the products of combustion are carried back towards the burner throat, establishing the flame root within the burner quarl. This leads to very stable ignition and high combustion rates in the burner near field. However, one potential disadvantage of this type of burner is that the intense mixing and combustion in the near field can cause significant NO_x formation. Recognizing the importance of swirl type burners, the International Flame Research Foundation (IFRF) has been involved in research related to this burner type for over 20 years (Schmid, et. al. (1987)), and presently their work is concentrated on the following issues:

- 1) Design of swirl burners for a wide range of different fuels (including coal-water fuels, pulverized wood, coke, charcoal, and lignite) - especially in the context of oil replacement.
- 2) Design of swirl burner systems incorporating air-staging for NO_x control.

In general, swirling air flows in the burner near-field region are typically established by means of tangential injection of a portion of the combustion air stream into the burner register nozzle. The dimensionless ratio of the combustion air angular momentum flux

FREE VORTEX

$$W = \frac{C_1}{r}$$

FORCED VORTEX

$$W = C_2 r$$

RANKINE VORTEX

$$W = \frac{C_3}{r} \left[1 \cdot \exp\left(-\frac{r^2}{r_o^2}\right) \right]$$

WHERE:

**W=TANGENTIAL VELOCITY
COMPONENT**

C₁, C₂, C₃=CONSTANTS

r=RADIAL COORDINATE

r_o=INITIAL r

Figure 3.3 Typical Swirler Tangential Velocity Profiles (Near Field)

(the tangential component) to the combustion air axial momentum flux times the burner exit radius, defines the initial swirl number of the burner which is commonly used to define the relative effectiveness of swirl generation devices. Swirl generators with operating swirl numbers of 0.6 or greater are known to establish highly recirculating aerodynamic regimes which greatly enhance burner flame stability, and general burner performance.

A wide variety of swirl generation devices are in common use today by commercial burner manufacturers. Several manufacturers have centered on the use of swirl generation concepts which employ multi-vaned tangential inlet devices. For example, Combustion Engineering has successfully employed optimized versions of vaned tangential swirlers into every coal/water fuel burner that they have developed. These devices are relatively inexpensive to construct and are capable of generating swirl numbers of 0.6 or greater.

A major drawback to most vaned tangential swirler designs is that they tend to operate with relatively high pressure losses. These losses translate directly into an increase in burner fan head requirements. An increase in required fan head negatively impacts on the overall efficiency of the power system and can increase plant capital equipment cost as well. In this light, it was decided to follow gas turbine combustor design practice (see Lefebvre (1983)) and built the HEACC burner design around the use of axial flow vane type swirlers, with their characteristically lower pressure drops for the same swirl flow generation. In order to explore aerodynamic performance versus fabrication costs, it was decided that both straight and curved vane swirlers would be designed with either forced or free vortex flow leaving the swirlers (Buckley, et. al. (1983, 1980).

Although previous axial flow swirler research had shown that this type of geometry could achieve high levels of swirl efficiently, that is, with minimal pressure drop, additional design information was needed before this concept could be applied to stationary boiler burners. Specifically, burner near-field aerodynamics generated by

an axial vane swirler could differ from the flow fields established by the tangential inlet vane swirlers in common use today. Also, the impact of the potential difference on burner flame stability needed to be established, and it appeared that blade design was critical in minimizing axial flow swirler pressure losses. Therefore, in order to establish the analytical design and scaling criteria required to apply axial flow swirlers to commercial scale commercial boilers, a comprehensive primary air swirler design procedure was needed. This procedure is described in the next section of this report.

B. DEVELOPMENT OF PRIMARY AIR SWIRLER DESIGN

Figure 3.4 presents an overall schematic of the individual steps and inputs required for this phase of the overall program. In the following discussion we will present the technical details of the individual components of the design procedure for the primary air swirlers. As shown, the end result of this work is the complete specification for a number of test swirlers to be experimentally tested in the swirler test facility and the cold flow burner test program.

(1) ESTABLISHMENT OF OVERALL COMBUSTION REQUIREMENTS

This initial phase of the primary air swirler design involves the use of overall combustion mass and energy flow calculations to establish the swirler air flow requirements of the burner assembly. Important inputs to this phase include burner size, maximum pressure drop limitations, coal- water fuel specifications, and burner emissions requirements.

The following calculations for a selected burner design of 50×10^6 BTU /hr illustrate this part of the design procedure.

Assuming OXCE Elk Creek CWF (65% dilution), gives the following fuel analysis:

Figure 3.4 Schematic of Primary Air Swirler Design Procedure

Fractional analysis (by weight):

Moisture - 0.35

H - 0.033

C - 0.528

S - 0.005

N - 0.0098

O - 0.040

Ash- 0.033

HHV = 9418 BTU/ lb

For a 50,000,000 BTU/hr burner, the fuel requirement is:

$$m_{\text{fuel}} = 50 \times 10^6 / 9418 = 5309 \text{ lb/ hr}$$

For stoichiometric conditions, it can be shown that 7.06 lb air/ lb fuel is required, thus

$$m_{\text{air}} = 7.06 \times 5309 = 37,481 \text{ lb/ hr}$$

(2) ESTABLISHMENT OF RANGE OF SWIRL NUMBERS DESIRED FOR BURNER ASSEMBLY.

The swirl number of the burner assembly is an important parameter for determining the performance of a given design. This fact has been noted by numerous researchers and has been the subject of a long term research program at the International Flame Research Foundation (see, for example, Leuckel (1967)). During the development of coal-water slurry burners at Combustion Engineering, variation of the burner swirl number was a key design variable. The resulting burner assembly, named the High Swirl Wall Fired Burner (HSWF), has been the basis for a series of commercial CWF burners ranging in capacity from 25 to 100 x 10⁶ BTU/hr (Rini, et. al. (1986), LaFlesh, et. al. (1986)).

Under this program, the HSWF design was selected as the baseline case for a burner

design, and, a calculation of the swirl number for this particular design follows.

Following conventional practice (Beer and Chigier (1972), Lawn (1987)), the swirl number for a burner is given by:

$$S = G_O / (G_X r_b)$$

where G_O is the tangential angular momentum flux, G_X is the axial momentum flux, and r_b is the inside radius of the swirler.

An approximate calculation, ignoring the vane thickness, for the swirl number of a vane or tangential entry type swirler (for example, see the baseline tangential swirler design in Figure 3.14) can be carried out if we let:

$$G_O = m^2 \sigma / 2\pi\rho B$$

where:

m = combustion air mass flow rate

$\sigma = \tan \alpha / (1 + \tan \alpha \tan (\pi/N))$

N = number of vanes

α = swirled air exit angle

ρ = combustion air density

B = length of swirler

$$\text{and } G_X = m^2 / \rho A$$

where:

A = annular area of throat

Following these relationships, the design swirl number for the CE HSWF burner was

calculated to be approximately 1.0.

For axial type swirlers, the following relationship for swirl number was used (Beer and Chigier (1972), Lawn (1987)).

$$S = \frac{2 (1 - (D_{\text{hub}}/D_{\text{sw}})^3) \tan \alpha}{3 (1 - (D_{\text{hub}}/D_{\text{sw}})^2)}$$

where

D_{hub} = Inner hub diameter

D_{sw} = Swirler diameter

α = Vane angle

Based on this equation, design values of 1.0 and 2.0 were chosen for the burner assemblies using axial type swirlers to be constructed under this test program.

(3) ESTABLISHMENT OF COMBUSTION MASS FLOW REQUIREMENTS

For the design of low NO_x emission burners, an important parameter that quantifies the effects of air staging in such systems is the primary zone stoichiometric ratio, η_p , defined as:

η_p = primary zone combustion air flowrate/ stoichiometric air flowrate

Based on previous work on coal-water fuels and burner development, it was concluded that the burner primary airflow was set at a value equivalent to the amount of air required to burn off all volatiles. Following the work of Nsakal, et. al. (1985), it

was calculated that 35% of the stoichiometric air is required to burn off the volatiles in the OXCE Elk Creek CWF diluted to 65%.

Thus, assuming that $n_p = 0.35$, based on the previous combustion calculations, this gives a value for the primary air flow, m_p , as follows:

$$m_p = 37,481 (0.35) = 13,118 \text{ lb/hr}$$

(4) ESTABLISHMENT OF OVERALL BURNER DIMENSION ENVELOPE

In this part of the design procedure, limits to the overall dimensions of the burner assembly must be established. A key goal of this project was to develop a coal/CWF combustor to fit into an existing burner opening in an oil-fired designed boiler. This would eliminate the need for pressure part modifications and greatly enhance the economics of the retrofit. The major sources of input for these calculations are Combustion Engineering Design Standards and geometry limitations established as a result of recent work on coal-water combustion (LaFlesh, et. al. (1986).

For the 50,000 BTU/hr burner assembly, the following burner dimensions were established:

Maximum windbox depth = 42 in

Maximum throat diameter = 28 in

Maximum diameter of burner assembly = 62.5 in

Maximum quarl depth = 14 in

Diameter of primary swirler = 14 in

(5) ESTABLISHMENT OF PRIMARY AND SECONDARY AIR VELOCITIES

Based on previous Combustion Engineering experience with coal-water fuels (LaFlesh, et. al. (1986), Rini, et. al. (1987b, 1986)), a primary swirler air velocity of approximately 100 ft/s and a secondary air velocity of about 75 ft/s are desirable.

Using the previous mass flow calculations and burner geometry specifications, these velocities can be calculated as follows:

Primary Air velocity:

Assuming a hub diameter of 4.5 in and a maximum swirler diameter of 14 in, the cross sectional area for the primary air, A_p , is found from:

$$A_p = (\pi/4) (14^2 - 4.5^2) = 138.1 \text{ in}^2$$

$$\text{with } m_p = 13,118 \text{ lb/hr}$$

The primary air velocity, V_p , is determined from:

$$V_p = m_p / \rho A_p = 13,118 / [(0.0414)(138.1/144)] = 92 \text{ ft/s}$$

Secondary air velocity:

Assuming a throat diameter of 28 in and a maximum swirler diameter of 14 in, the cross sectional area for the secondary air, A_s , is found from:

$$A_s = (\pi/4) (28^2 - 14^2) = 461.8 \text{ in}^2$$

Assuming 30% excess air, the total air flow (primary + secondary) is equal to:

$$m_t = 1.3 \times 37,481 = 48,725 \text{ lb/hr}$$

Therefore, the secondary air flow rate, m_s , is:

$$m_s = 48,725 - 13,118 = 35,607 \text{ lb/hr}$$

The secondary air velocity, V_s , is determined from:

$$V_s = m_s / \rho A_s = 35,607 / [(0.0414)(461.8/144)] = 75 \text{ ft/s}$$

It should be noted that both these calculated velocities fit within our selected values, and thus satisfy the required primary and secondary air velocity input requirements.

(6) SWIRLER BLADE DESIGN PROCEDURE

Under this task, the geometry of the primary air axial flow swirlers was determined for both curved vane and flat blade designs. Figure 3.5 defines the geometry for a flat bladed design whose vane angle, Θ , is constant. Note that for curved vane swirlers the inlet blade angle is zero and the outlet angle is Θ . The following geometry variables are defined by Figure 3.5:

Θ = Vane outlet angle or airflow turning angle

c = Chord

s = Spacing between blades

D_{hub} = Inner hub diameter

D_{sw} = Swirler diameter

z/c = Aspect ratio

s/c = Space/ Chord ratio

Figure 3.5 Schematic of Flat Vane Axial Swirler

Before proceeding with the description of the design procedure for the curved and straight bladed swirlers it is important to note that previous calculations and burner design input have specified, for a given sized burner, the Inner hub diameter, D_{hub} , the swirler diameter, D_{sw} , the primary velocity to the swirler, $V_{primary}$, the maximum depth of the swirlers, and limits to the pressure drop across the swirler assembly. Flow design variables that can be changed include the downstream flow swirl number, S , and the desired type of tangential velocity profile (forced or free vortex).

A detailed description of the design procedure used for the curved and straight bladed swirlers follows.

(A) Curved Bladed Swirlers

The procedure used to specify the geometry of primary air swirlers follows that of Buckley, et. al. (1983, 1980) that was developed for the design of practical swirlers for integral rockets/ ramjets.

Desired tangential velocity distributions from the outlet of the swirler were either a free vortex or forced vortex flow. They are specified by:

Forced vortex: $w = (\text{Constant}) r = (\tan \Theta) u$

Free vortex: $w = (\text{Constant})/ r = (\tan \Theta) u$

where w = tangential velocity

u = axial velocity

For either of these cases the constant terms can be evaluated for a given hub radius, R_1 , and swirler radius, R_2 , by using the following equation for the swirl number of the flow exiting the swirler, S :

$$S = \frac{\int_{R_1}^{R_2} u w r^2 dr}{R_2 \int_{R_1}^{R_2} u^2 r dr}$$

Substituting into the swirl number equation yields the following results for the airflow turning angle as a function of radial position:

Forced vortex:

$$\Theta = \tan^{-1} \left\{ \left[\frac{(2)(S)(R_2^3 - R_1^2 R_2)}{(R_2^4 - R_1^4)} \right] r \right\}$$

Free vortex:

$$\Theta = \tan^{-1} \left\{ \left[\frac{(S)(R_2^3 - R_1^2 R_2)}{(R_2^2 - R_1^2)} \right] 1/r \right\}$$

Following a procedure similar to that used by Buckley, et. al. (1983, 1980), the swirl vane geometry was designed based on a simplified method for determining the approximate blade angle required to achieve a given airflow turning angle, Θ . This method, described below was made possible via the use of Carter's rule which was based on the use of experimental data from two-dimensional cascades (Gostelow (1984), Johnsen and Bullock (1965)) Figure 3.6 presents a view of the curved swirl vanes at a given radial position, r , and defines the following variables:

Θ = airflow turning angle

ϕ = blade turning angle

δ = deviation angle = $\phi - \Theta$

γ = blade chord angle

R = radius of curvature

c = blade chord length

s = distance between blades

σ = solidity = $c/s = cN/\pi d$

N = number of blades

d = diameter at specified location

From Carter's rule:

$$\delta/\phi = M_C/\sqrt{\sigma}$$

where M_C is a function of the blade chord angle, and may be approximated by:

$$M_C = 0.002\gamma + 0.21$$

With the inner and outer radial positions known, the number of blades, N , and the radius of curvature can be initially specified. Using the following relationships, the chord length can be determined in an iterative fashion:

Geometry:

$$\phi = 2\gamma = 2 \sin^{-1} (c/2R)$$

Carter's rule:

$$\delta = \frac{\phi (0.002\gamma + 0.21)}{(cN/\pi d)^{0.5}}$$

Figure 3.6 View of Swirl Vanes at a Given Radial Position

Combining these two equations:

$$\Theta (cN/\pi d)^{0.5} + 2 \sin^{-1} (c/2R) [0.21 + 0.002 \sin^{-1} (c/2R)] - (cN/\pi d)^{0.5} = 0$$

Once the chord length, c , is calculated, the curved vane design is completely specified; however, due to pressure drop considerations or geometry restrictions on the total number of blades (such as blade overlap or the radius of curvature), the number of swirler blades, N , may have to be changed. Once this was changed, the previous iterative calculational procedure for c was repeated until new values of c were obtained.

For example, for the free vortex vane design, this procedure yields the following design for a specified swirl number, S , equal to 1:

Number of vanes, $N = 26$

Radius of curvature, $R = 4$ in

$R_1 = 2.3$ in

$R_2 = 6.89$ in

Spacing between blades at hub = 0.51 in

$c_{\text{outer radius}} = 3.5$ in

$c_{\text{hub}} = 5.0$ in

(B) Straight Vane Swirlers

Under the design procedure development program for the straight vane type swirlers, designs for both free and forced vortex flows were desired.

Following Mathur and MacCallum (1967), the swirl number for a straight bladed axial flow swirler is given by

$$S = \left[\frac{(2) (R_2^3 - R_1^3)}{(3) (R_2^2 - R_1^2)} \right] \tan \Theta$$

In order to get either a forced or free vortex flow from the exit of the swirler, a multi-annular design, similar to the Multiannular Swirl Burner (MASB) design described by Lew and Toof (1984) and Beer and Vermes (1982).

For the HEACC design, as shown schematically in Figure 3.7, a design based on the use of 4 concentric annuli was chosen, subject to the following geometric constraints:

4.5 in schedule 40 pipe hub (4.5 in O.D.)

Blade height = 1.1 in

16 gauge steel blades (0.0598 in thick)

In the MASB design, blade angles, Θ , were varied from 20 to 70°, and since we had 4 vane sections, we chose blade angles of 20, 40, 60, and 80°.

For the Forced vortex design, Θ at the outer position should be the highest, thus:

SW₁ : $\Theta = 20^\circ$

SW₂ : $\Theta = 40^\circ$

SW₃ : $\Theta = 60^\circ$

SW₄ : $\Theta = 80^\circ$

Figure 3.7 HEACC Burner Design

For the Free vortex design, Θ at the inner position should be the highest, thus:

$$SW_1 : \Theta = 80^\circ$$

$$SW_2 : \Theta = 60^\circ$$

$$SW_3 : \Theta = 40^\circ$$

$$SW_4 : \Theta = 20^\circ$$

For this type of design, an optimum s/c ratio was 0.7

(7) PRESSURE DROP CONSIDERATIONS

In the previous section it was noted that the pressure drop characteristics of the curved blade axial flow swirler could change the design, specially the number of blades, of such components. As summarized by Lefebvre (1983), it is possible to predict the pressure losses through axial swirlers using empirically based expressions, such as those presented by Kilik (1976) or Knight and Walker (1957). Martin (1957) points out that these expressions can generally be written in terms of primary air flow velocity head losses or resistance coefficient, and are very sensitive to very small changes in swirler geometry. For example, Kilik(1976) showed that for both flat and curve vane swirlers, a key parameter was the number of vanes (reflected in the value of the solidity or space to chord ratio of the swirler). He noted that this parameter was especially important for curved vane swirlers due to the lower frictional loss associated with such designs. For this test program, it was decided that the pressure drop coefficients of the swirlers that were designed by the previous methodology would be experimentally determined. Further analytical work in this area would be of great benefit to generalizing the design procedure.

(8) GEOMETRY RESTRICTIONS

As previously noted, the swirler geometry as reflected in the number of swirler blades or swirler solidity, can greatly influence the pressure drop characteristics of a particular swirler design. Furthermore, it was assumed that the blade overlap would be an important variable that should be checked after each potential swirler blade geometry calculation. Specifically, after each swirler blade geometry calculation, a sketch of the resulting swirler, using the assumed number of swirler blades, was checked for blade overlap. If there was no overlap, then a new value of N , $N + 2$, was assumed and the calculations were repeated until a blade overlapping geometry resulted. An opposite type of procedure was used if the initial geometry resulted in an overlapping blade geometry situation, i. e., the number of blades was reduced to $N - 2$.

(9) ESTABLISHMENT OF FINAL SWIRLER DESIGN

The combination of the previously described swirler design procedure in combination with the noted pressure drop considerations and geometry restrictions, yielded 4 different designs for curved vane axial vane swirlers (2 free vortex and 2 forced vortex) and 2 different straight vaned swirlers (1 free vortex and 1 forced vortex) that were to be tested in the swirler test facility (STF). The best two swirler designs, as determined by the STF testing, would be further characterized in the full scale burner cold flow model.

C. SECONDARY FLOW GEOMETRY DESIGN

An important concept used in the development of this burner is that of "internal staging" for NO_x control. This necessitates precise control of the primary/secondary air flows and their rates of mixing.

In general, staging of combustion air, for example, as demonstrated in heavy oil combustion experiments, leads to reduced emissions of NO_x in the case where high nitrogen bearing liquid fuels are burned. The same reduction in NO_x emissions is expected for the rich-lean combustion of coal-water fuels. Specifically, for coal combustion, the fate of fuel nitrogen, the major contributor to NO_x emissions in coal combustion (up to 80% of the total NO_x) is illustrated in Figure 3.8. In a typical coal flame, part of the nitrogen is released with the volatiles in the early stages of combustion and the remainder is retained by the char residue. Rapid devolatilization of the fuel bound species in an oxygen depleted environment promotes the formation of N_2 and Nitrogen bearing hydrocarbon intermediates (CHN , NH_3 , etc.) rather than NO_x since there is a limited amount of oxygen available for NO_x formation.

Controlling the stoichiometric history of the fuel particles can be achieved by regulating the rates of fuel and air stream mixing (Flament, 1982). This is usually accomplished by designing a burner which creates the oxygen depleted environment. The "staged-mixing" burner is a generic design which creates such an environment. In this system, the combustion air is divided into two streams creating an initial fuel rich combustion zone followed by a second combustion zone where the remainder of the combustion air is mixed and combustion is completed. As shown in Figure 3.9 (Flament, 1982), flame staging can be accomplished by two different systems of air/fuel mixing for producing the required fuel-rich and fuel-lean flame zones.

In the first type, called external staging, air (as shown in Figure 3.9) or fuel staging (defined as reburning) can be achieved by spatially separated combustion zones. The furnace zone near the burner may be operated fuel-rich, and secondary (or overfire) air may then be injected at some distance downstream in the combustion chamber to

Figure 3.8 The Fate of Fuel Nitrogen During Combustion

Figure 3.9 Different Combustion Staging Concepts

create a lean furnace zone for completion of combustion. In the reburning process, fuel is injected into fuel-lean burned gas to turn it into locally fuel-rich for NO_x reduction, followed by more air injection necessary to complete combustion. Compared to the second type of staging, internal staging, this system requires more than just a burner redesign for retrofit applications.

In the second type, called internal staging, both the fuel-rich and fuel-lean flame zones are formed aerodynamically by the burner. Fuel rich and fuel-lean zones necessary for NO_x reduction are produced by the appropriate mixing of burner fluid flows. In current retrofit applications for NO_x control, such burners have been called "low- NO_x burners." These burners have yielded improvements when used by themselves in new or retrofitted boilers, but they have also been used in combination with external staging. For the HEACC design, due to the lower potential cost for retrofit applications, the internal staging concept was chosen.

An example of the effect of staging, quantified in terms of primary zone stoichiometry is shown in Figure 3.10 (Flament, 1982). The primary zone stoichiometric ratio, η_p , is defined as:

$$\eta_p = \frac{\text{primary zone combustion air flowrate}}{\text{stoichiometric air flow rate requirements}}$$

The magnitude of the η_p parameter is inversely proportional to the level of combustion air staging. Increasing the staging (reducing η_p) reduces the primary zone combustion air flow rate thereby reducing the quantity of oxygen available for reaction with Nitrogen.

It should also be noted that, in the case of CWF combustion, staging can offer an additional advantage of the viewpoint of ignition and flame stability. That is, staged air introduction effectively reduces the mass of air that must initially be heated along with

Figure 3.10 NO_x Emissions from a Boiler with Staged Combustion

the fuel spray entering the combustion chamber. Provided that upstream radiative and convective heat transfer levels in the fuel-rich zone are maintained relatively high, the ignition time for the fuel can be effectively reduced in this manner. In this respect, another important feature of the HEACC design is the replacement of the high-maintenance refractory quarl of previous designs with an air-cooled perforated plate quarl. This device serves both as a divergent nozzle to aid flame stability and as a staged air distributor to maintain the desired distribution of stoichiometries within the combustion zones.

It should also be noted that the fuel burnout and carbon combustion efficiency, obtained under staged conditions, are expected to be highly dependent on the mode and rate of secondary air mixing. Specifically, the mixing of the secondary air must be sufficiently rapid to achieve acceptable fuel burnout without causing excessive temperature rise that might result in the formation of thermal NO_x .

As shown in Figure 3.11, the HEACC was designed as an internally staged burner making use of the internal staging principle. The ability to provide both swirled and unswirled secondary air was designed into the pilot-scale burner and was also included in the demonstration-scale burner to increase the flexibility of mixing control.

Figure 3.11 HEACC With Internal Staging

D. SWIRLER TEST FACILITY PROGRAM

In order to quantify the swirl generation performance and pressure drop characteristics of the various primary air swirler designs, this phase of the program involved the testing of the full-scale swirlers in a specially constructed swirler test facility (STF). This facility is similar to a smaller scale facility used by the International Flame Research Foundation (Leukel (1967)). A schematic of the plan view of the STF, which was described in a previous technical paper (Rini (1987a)) is given in Figure 3.12. As shown in Figure 3.13, a metered air stream representing total primary combustion air mass flow, enters a cylindrical plenum which contains a test swirler. The experimental output from this facility includes the swirl reactive torque produced by passing the primary air swirler exit flow through a flow straightener, and the pressure drop across the test swirler.

As shown in Table 3.1, eight different swirlers, with four basic geometric designs (see Figure 3.14) were tested in the STF. The design swirl numbers were calculated based on the equations presented in a previous section. Results from this test program, including the measured torque from the swirler, the swirler pressure drop (measured and projected to combustion conditions (500 °F inlet temperature)), and the ratio of the torque to the measured pressure drop (normalized to this ratio for configuration OB) are summarized in Table 3.2.

The results from this test program, as shown in Table 3.2, showed that the Free Vortex - Swirler D generated an equivalent torque to the Tangential Entry Baseline Swirler (Configuration OB) with a 30% reduction in pressure drop. Or, at equivalent pressure drops, Free Vortex- Swirler D generated a greater torque than the Tangential Entry Baseline Swirler (Configuration OB). Both the Forced and Free Vortex Swirlers with a Design Swirl Number of 2.0 (Configurations A and C) had excessive projected pressure drops. Note also that the Forced Vortex- Swirler B generated substantially greater torque at a lower pressure loss than any other configuration. Also note that both the Flat Bladed Swirlers (Free and Forced Vortex) generated lower torque values than any of the other swirler configurations.

Figure 3.12 Plan View of Swirler Test Facility

Figure 3.13 Swirler Test Facility

<u>CONFIG.</u>	<u>BLADE GEOMETRY</u>	<u>VORTEX TYPE</u>	<u>DESIGN SWIRL NO.</u>
OA	Tangential Entry	Forced	1.0
OB	Tangential Entry	Forced	2.0
A	Curved Blade	Forced	2.0
B	Curved Blade	Forced	1.0
C	Curved Blade	Free	2.0
D	Curved Blade	Free	1.0
E	Flat Blade	Forced	1.0
F	Flat Blade	Free	1.0

Table 3.1 Swirler Test Configurations

<u>CONFIGURATION</u>	<u>$\Delta P_{\text{measured}}$</u> (in H ₂ O)	<u>$\Delta P_{\text{projected}}$</u> (in H ₂ O)	<u>Torque</u> (lb/in)	<u>Normalized</u> <u>Torque/$\Delta P_{\text{meas.}}$</u>
OA	1.9	3.8	10.2	1.3
OB	2.6	5.2	10.7	1.0
A	3.1	6.2	20.5	1.6
B	2.1	4.2	18.3	2.1
C	5.1	10.2	29.2	1.4
D	1.9	3.8	10.7	1.4
E	2.7	5.4	9.1	0.8
F	2.3	4.6	8.6	0.9

Table 3.2 Swirler Test Facility Data (Constant Mass Flow)

Based on these results, Swirlers B and D were chosen as the primary air swirler configurations for further testing in the cold flow burner model test program. This program is discussed next.

4. TASK 1.3 COLD FLOW BURNER MODEL TESTING PROGRAM

A. INTRODUCTION/ BACKGROUND

Under this phase of the work, and based on the work summarized in the previous sections, the design for the prototype HEACC cold flow model was based on the following design requirements:

- 1) A physical envelope (diameter and length) similar to a conventional oil burner envelope to facilitate retrofit.
- 2) Primary air swirler stoichiometry (η_p), targeted between 0.3 and 0.4 to minimize NO_x formation, with entrainment air would give a total estimated value between 0.6 and 0.7.
- 3) Incorporation of a low pressure loss staged air distribution system for secondary air stream(s)
- 4) Utilization of the most efficient swirler designs for the primary air stream.

Based on these specifications, a preliminary HEACC design was completed. A schematic view of the initial version of the HEACC cold flow model, based on this design, is given in Figure 4.1, which shows the adjustable feature of the burner and secondary air assemblies. This feature allowed the burner geometry and resulting aerodynamic flow field to be varied in a systematic manner. As will be discussed, a total of seven HEACC configurations were studied, along with a base case using Combustion Engineering's High-Swirl Wall-Fired Burner (HSWF) for comparative purposes.

B. COLD FLOW MODELING- GENERAL BACKGROUND

As summarized in a number of technical papers (see Anderson, et al.,1986, Chapman, et al., 1988), researchers at Combustion Engineering have established the use of isothermal or cold flow modeling techniques for the testing and

Figure 4.1 Prototype HEACC Cold Flow Model

development of major components in full scale furnaces. With direct applicability to this work, these cold flow modeling techniques were a major design tool in the development of a high-turndown coal-fired utility scale burner (Marion and Towle (1985)).

In general, the cold flow modeling techniques used in this study were based on procedures developed by established combustion researchers (see, for example: Beer (1966), Beer and Chigier (1972), Hagiwara and Bortz (1974), and Smoot (1984)) and researchers at Combustion Engineering (Horan (1975, 1979)). These procedures dictate that there be similarity between the processes investigated in the model and those of the prototype. Specifically, one seeks to maintain similarity of geometry, kinematics, dynamics, etc. Similarity of flow between the model and the prototype is established by maintaining equality of the appropriate dimensionless numbers (such as Reynolds number). Isothermal modeling of combustion systems, however, necessitates some compromises to be made because it is not possible to maintain similarity of all the dimensionless physical parameters. This is sometimes referred to as "the art of partial modeling".

For example, aerodynamic modeling of combustion processes involving entire flames should consider the changes in temperature (and density) down the flame length. As noted by Horan (1979), three common approaches used to model such phenomena are:

- 1) The modification of the burner register or jet inlet geometry (Thring-Newby)
- 2) The displacement of, and geometric modification of the burner register (Zelkowski)
- 3) The placement of a gauze panel to artificially simulate the prototype flame front.

For this work, the near field (defined as the flow region just downstream of the burner exit (approximately within three burner diameters)) aerodynamics were of primary interest. It has been established that the flow characteristics of this region significantly influence flame stability and attachment. For this program, the region can be modeled in a non-combusting cold flow situation by the assumption that combustion has only moderately progressed and that the average jet density has yet to significantly change (i.e., due to combustion).

Compensation for density changes resulting from combustion was not modeled. Previous work has shown that the flow field shape is similar, except for some increase in the volume of the internal recirculation zone (IRZ). Therefore, based on past C-E experience, only geometric and kinematic similarity were maintained. Geometric similarity means that all dimensions of the prototype burner assembly should be linearly scaled. For kinematic similarity this meant that the velocity of the simulated combustion air was matched to the 500 °F combustion air. In other words, the burner free areas were directly scaled to the firing rates. For the cold flow model, the scale was selected to be equivalent to the 50×10^6 combustor in order to improve the correlation between the cold flow and combustion testing.

Kinematic similarity in a system with flow implies that the fluid or solid particles follow geometrically similar paths in corresponding intervals of time. This is the same as saying that the streamlines in the model and the prototype are equal. It also means that there is a velocity scale ratio that is maintained constant between corresponding points of the model and prototype.

As a result of the use of these scaling criteria, it was expected that pressure drops and burner swirl numbers of the model and prototype would also remain essentially constant.

B. COLD FLOW MODELING- EXPERIMENTAL APPROACH

Based on the previously described work, two physical modeling approaches were used in the cold flow model testing program. The first approach produced qualitative data via flow visualization using yarn streamers and/or neutrally buoyant helium bubbles. This data was recorded using high resolution black and white photography. Such data was used to depict the overall flow pattern including areas of flow recirculation and areas of high turbulence.

The second approach produced detailed quantitative aerodynamic flow data using a three dimensional pressure and velocity mapping system. As described by Anderson, et al. (1986), this system uses a five hole pitot tube in conjunction with an automatic probe traversing device and associated data acquisition equipment. Details of this system and the associated test procedures are given in Appendix A.

In general, the combination of data obtained from the flow visualization and the three dimensional velocity and pressure mapping was used to interpret the near field aerodynamics of the different burner configurations. A summary of the experimental results follows.

C. EXPERIMENTAL RESULTS

Using the basic HEACC configuration shown in Figure 4.1, seven different configurations were tested, along with a baseline test using the HSWF burner. It should be noted, that due to excessive pressure drops in the burner assembly, the outermost secondary annulus (Ring C) was removed from the burner assembly during shakedown testing- all subsequent testing was with Ring C removed.. The tested configurations consisted of the following: (unless noted the Free Vortex Swirler "D" was installed)

Configuration 1 - This was the baseline HEACC design. Rings A and B were aligned to form a smooth continuous cone inside the windbox.

Configuration 2 - Ring A and the swirler were withdrawn 4" into the burner windbox top to form a deeper cone.

Configuration 3 - Ring A and the swirler were withdrawn 6" into the burner windbox top to form a still deeper cone.

Configuration 4 - Ring A and B were aligned to form a smooth cone, with the entire burner assembly projected forward such that the front edge of Ring B was 2" forward of the windbox front plate.

Configuration 5 - The burner was arranged as Configuration 1, with the addition of a 60 psi compressed air jet used to simulate a fuel spray.

Configuration 6 - The 33% open area plate of Ring A was replaced with a 51% open area perforated plate.

Configuration 7 - The burner was arranged as Configuration 1, with the use of the Forced Vortex Swirler "B".

Configuration 8 - An existing model of the HSWF burner was used.

Detailed schematics of the first seven configurations are given in Figure 4.2. The results of the flow visualization experiments are presented in Appendix B. Figure 4.3 shows a typical flow pattern generated by the HEACC (Configuration 2). A schematic summary of the flow visualization experiments is given in Figure 4.4.

Figure 4.2 Cold Flow Test Configurations

CONFIGURATION 3

CONFIGURATION 4

Figure 4.2 Cold Flow Test Configurations (Continued)

CONFIGURATION 5

CONFIGURATION 6

Figure 4.2 Cold Flow Test Configurations (Continued)

CONFIGURATION 7

Figure 4.2 Cold Flow Test Configurations (Continued)

Neutral Density (Helium Bubble) Flow Pattern

Flow Pattern Using Yarn Streamers

Figure 4.3 Representative Cold Flow Test

**STAGNATION POINT
≈ 20° DOWNSTREAM
OF WINDBOX FACE**

CONFIGURATION 1

**STAGNATION POINT
≈ 20° DOWNSTREAM
OF WINDBOX FACE**

CONFIGURATION 2

Figure 4.4 Summary of Cold Flow Observations

STAGNATION POINT
≈ 20° DOWNSTREAM
OF WINDBOX FACE

CONFIGURATION 3

STAGNATION POINT
≈ 28° DOWNSTREAM
OF WINDBOX FACE

CONFIGURATION 4

Figure 4.4 (Continued) Summary of Cold Flow Observations

STAGNATION POINT
≈ 20° DOWNSTREAM
OF WINDBOX FACE

CONFIGURATION 5

STAGNATION POINT
≈ 20° DOWNSTREAM
OF WINDBOX FACE

CONFIGURATION 6

Figure 4.4 (Continued) Summary of Cold Flow Observations

STAGNATION POINT
≈ 18" DOWNSTREAM
OF WINDBOX FACE

CONFIGURATION 7

Figure 4.4 (Continued) Summary of Cold Flow Observations

The next series of cold flow tests involved the quantitative mapping of the aerodynamic flow fields using the three dimensional pressure and velocity mapping system.

A complete summary of the velocity profile test results is given in Appendix C. The test planes used for this series of tests are shown in Figure 4.5. Note that Plane 3 was not fixed and was located at the approximate location of the stagnation point of the internal recirculation zone (IRZ). For a representative example, Figure 4.6 presents a series of velocity profile information (Configuration 1) obtained from the detailed mapping procedure. Figure 4.6A shows the vertical plane velocity vectors issuing from the burner model. The magnitude and uniformity of direction of the flow in the center of the burner is indicative of strong swirl. The weaker vectors toward the outside of the pattern result from the unswirled secondary air flow. As can be seen, some of this secondary air is entrained into the primary air as intended. Figure 4.6B shows the axial flow along the centerline of the burner. This flow is in the negative direction for the initial 22 inches. This indicates recirculating flow which is required for flame stability. The length of the recirculation zone will increase under hot (combustion) conditions. The flow fields were generally similar for all the tested configurations.

To summarize, the results of the cold flow testing program showed:

- 1) Removal of Ring C reduced the burner pressure drop to an acceptable level while maintaining the desired flow pattern.
- 2) The burner aerodynamics remained generally similar over the range of register adjustability.
- 3) The burner flow field was dominated by the swirler size and centrality.
- 4) Both the Forced Vortex- Swirler "B" and the Free Vortex- Swirler "D" produced a flow pattern that appeared sufficient for flame stabilization. However, the Forced Vortex swirler did produce a larger and stronger recirculation pattern.
- 5) The flow patterns generated appear sufficient to maintain flame stability and have the potential to minimize NO_x production via internal staging.

The results from these tests demonstrated that the initial design concepts were valid. Based on this systematic approach, the pilot scale burner was designed.

Figure 4.5 Test Planes for Velocity Profile Tests

5. TASK 1.4 BURNER SCALE UP CRITERIA

The objective of this task is to develop swirler/ burner design and scaling criteria based on information derived from the parametric testing of the preceding Tasks 1.2 and 1.3. Under this task, the criteria will be used to design a 5×10^6 Btu/ hr HEACC burner for evaluation under Task 2.3 , as well as to obtain a general understanding of scale up to a broad range of industrial sizes.

A. INTRODUCTION/ BACKGROUND

The scaling criteria developed under this task is based on the empirical information obtained under Tasks 1.2 and 1.3 as well as analytical procedures that have been developed by Combustion Engineering for general burner scaling (see Rini, et al., 1987b). Since the burner design is based on the use of swirling flows, additional burner scaling information is based on the work (primarily for heavy fuel- oils) carried out by the International Flame Research Foundation (summarized by Lawn, 1987). Some of this work will be summarized in the following discussion.

As pointed out by Lawn (1987), one reason for understanding flame processes is to be able to interpret the results of tests on small burners in terms of the likely performance of larger ones. This is generally accomplished via the use of "flame scaling" which means the achievement of similarity in all the combustion processes in the scaled domain. In general, compromises are needed because the physical and chemical processes do not scale in the same way. Specifically, since it is impossible to scale all the chemical kinetic rates to the same extent, the spatial distribution of the residence times must be similar and this can only be accomplished if all the velocities are scaled down by the linear scale factor. For atomized fuel firing, it is then necessary for the droplet size distribution to be maintained and for the heat transfer to the droplets to be similar. This will not be the case, however, even if the temperature field were similar (i.e., the droplet surface area, an important heat transfer variable, cannot be scaled).

In practice, burner manufacturers do not use this constant residence time approach when designing burners of different sizes. As noted in Lawn (1987), this occurs for a

number of reasons. The most important is that the range of air velocities would lead to windbox pressures which would extend beyond the operating range of the conventional equipment. For the smaller burners, the windbox pressures would be lower than can be conventionally measured for control purposes; for the largest burners, the windbox pressures would be beyond the capabilities of conventional fan designs. There would also be a difficulty in adjusting the fuel spray momentum to match the air flow.

Therefore, most heavy fuel-oil burners are designed on a constant velocity basis so that windbox pressures and fuel injection velocities are similar at all scales. The consequence is that flames on all sizes of burners tend to have the same length (because evaporation is rate limited), unless lower-throughput flames are deliberately shortened (for example, increasing swirl or decreasing droplet size).

In order to investigate scaling effects in practical burner designs, a joint CEGB/IFRF Scaling Trials program was carried out from 1977 to 1980 (Salvi and Payne, 1981). Three sizes of furnace and four sizes of burner were used and a series of flames from 33 to 0.5 MW thermal input were extensively probed. The relationships between the various flames are shown in Figure 5.1. As shown, the two burners fired in the CEGB facility on residual fuel oil were related by the linear scale factor between the two IFRF furnaces. The larger one was chosen as the datum flame (33.6 MW), and the smaller one was fired at two loads representing constant residence time and constant velocity scaling. Note that constant residence time results in a load proportional to the cube of the scale factor and constant velocity results in a load proportional to the square.

Also, in recent studies (Bortz, 1983), IFRF investigators have sought to develop analytical models capable of predicting the size and strength (defined as percent recirculated mass flow ratio) of a swirl burner's aerodynamic internal recirculation zone (IRZ). A large amount of their effort has centered on attempting to establish a solution of the equations of motion (derived from the Navier Stokes equations) for steady, inviscid cylindrical expanding flow in order to predict the diameter and strength of the IRZ. In addition, based on the results of isothermal burner modeling studies, they have identified a number of key swirler/burner parameters for defining IRZ

Figure 5.1 CEGB/ IFRF Scaling Trials: Flame Relationships

diameter, length, and strength. These parameters include:

- 1) Axial flow Reynolds number
- 2) Swirl number in the burner throat
- 3) Diameter of the burner throat (initial vortex diameter)
- 4) Burner nozzle exit diameter (final vortex diameter)
- 5) Burner nozzle divergence angle

The HEACC scaling efforts were carried out with this type of background and previous C-E experience on the subject. In this respect, it was envisioned that the aspect ratio and strength of the IRZ generated by the 50×10^6 Btu/hr isothermal model (as quantified in Task 1.3) would be replicated in the 5×10^6 Btu/hr burner design via appropriate modeling procedures.

B) DESIGN OF PILOT SCALE BURNER

In order to illustrate the scaling procedure, the details of the scaling calculations for the pilot scale burner follow:

Size of combustor- 5×10^6 Btu/ hr

Burner airflow- 4,873 lb/ hr = 1.354 lb/ sec (Assumes 30% excess air, typical of CWF combustion requirements)

Primary air flowrate, m_p , equals 35% of stoichiometric flow rate =

$$((0.35)/1.3) 1.354 \text{ lb/ sec} = 0.365 \text{ lb/ sec}$$

With 2 in diameter hub and 4.75 in outer swirler diameter, the primary air free flow area, A_p , equals 14.6 in²

Therefore, the primary velocity, V_p , is found from

$$V_p = m_p / ((\rho_{air})(A_p)) = 0.365 (144) / ((0.0415)(14.6)) = 86.7 \text{ ft/ sec}$$

which fits within the design range of 70 to 90 ft/ sec.

For the secondary flow, a velocity, V_S , equal to 85- 110 ft/ sec is desired

The secondary mass flow, m_S , is equal to $(0.73) (1.354) = 0.99$ lb/ sec

Assuming a screen with a blockage of 60% of the free area, and an outer annulus of 12 in diameter, the secondary area, A_S , is equal to 37.4 in²

V_S can be found from

$$V_S = m_S / ((\rho_{air})(A_S)) = 0.99 (144) / ((0.0415)(37.4)) = 91.8 \text{ ft/ sec}$$

which fits within the desired design velocity range

The next step in the overall design process involves the design of the primary air swirler. The details of this process were discussed earlier, and include the following steps:

- 1) Establishment of Overall Combustion Requirements
- 2) Establishment of Range of Swirl Numbers Desired for Burner Assembly
- 3) Establishment of Combustion Mass Flow Requirements
- 4) Establishment of Overall Burner Dimension Envelope
- 5) Establishment of Primary and Secondary Air Velocities
- 6) Swirler Blade Design Procedure

For the pilot scale design, a target swirl number of 2 was selected. Based on previous work in earlier CWF studies (see Borio, et al., 1984) and due to the small scale of the system, a highly efficient, Y-jet style single hole CWF fuel nozzle was used. This twin fluid atomizer utilizes compressed air as an atomizing media. In establishing the overall burner physical envelope for the MIT facility, the dimensions of their fixed windbox arrangement had to be considered. Also, the pilot scale HEACC design had to take into account such important design parameters as available windbox air pressure and available CWF fuel pressure at MIT.

The pilot scale burner designed under this subtask was fabricated and extensively tested at MIT under Task 2. It is shown in Figure 5.2. A separate report details the results of Task 2 "Pilot Scale Combustion Tests".

REFERENCES

- Anderson, D. A., Bianca, J. D., and McGowan, J. G., 1986, "Recent Developments in Physical Flow Modeling of Utility Scale Furnaces," Proc. 1986 Symposium on Industrial Combustion Technologies, American Society for Metals.
- Beer, J. M. and Vermes, G. (1982), "Gas Turbine Combustor for Coal Water Mixtures," Proc. of Engineering Foundation Conference: Combustion of Tomorrow's Fuels, Santa Barbara, Nov. 7- 12.
- Beer, J. M. and Chigier, N. A. (1972), Combustion Aerodynamics, Wiley, New York.
- Beer, J. M. (1966), "The Significance of Modeling," J. of the Inst. of Fuel, Nov.
- Borio, R. W., et al. (1984), "C-E's CWF Experience in Laboratory and Commercial Firing Systems," Proc. 3rd. Int. Coal Liquid Workshop, Halifax.
- Buckley, P. L., et. al. (1983, 1980), "The Design and Combustion Performance of Practical Swirlers for Integral Rocket/ Ramjets," AIAA Journal, p 733 or AIAA Paper 80-1119.
- Bortz, S. (1983), "Background and Programme Outline for the IFRF Burner Near Field Aerodynamics Project," IFRF Study Report, Doc. No. G 14/a/2.
- Chapman, P. C., Bianca, J. D., and McGowan, J. G., (1988), "Physical and Computational Modeling of Large Scale Furnace Systems," Proc. British Flame Days, Sept.
- Flament, G. (1982), "Simultaneous Reduction of NO_x and SO₂ Emissions from Turbulent Flames by Application of Staged Combustion and Direct Injection of Calcium- Based Sorbents," IFRF Report: Doc. nr. K20/a/118te.
- Gostelow, J. P. (1984), Cascade Aerodynamics, Pergamon Press, Oxford.
- Hagiwara, A. and Bortz, S. (1984), "Studies on the Near Field Aerodynamics of Swirl Burners," IFRF Report: Doc. no. F 259/a/1.
- Horan, D. J. (1979), "An Experimental Investigation of Three Tangentially Fired Modeling Techniques," M.S. Thesis, University of Massachusetts, Amherst.
- Horan, D. J. (1975), "Air Model Evaluation of Seven Diffuser Designs for Low Excess Air Operation," CE Internal Report, KDL-75-F-11, Oct.
- Johnsen, I. A. and Bullock, R. O. (1965), Aerodynamic Design of Axial-Flow Compressors, NASA SP-36.
- Knight, H. A. and Walker, R. B. (1957), "The Component Pressure Losses in Combustion Chambers," Aeronautical Research Council R and M 2987, London.

Kilik, E. (1976), "The Influence of Swirl Design Parameters on the Aerodynamics of the Downstream Recirculation Region," Ph. D. Thesis, Cranfield Institute of Technology.

LaFlesh, R. C., et. al. (1986), "Combustion Characteristics of Coal- Water Fuels," Proc. 8th Int. Symposium on Coal Slurry Fuels Preparation and Utilization.

Lawn, C. J. (1987), Principles of Combustion Engineering for Boilers, Academic Press, London.

Lefebvre, A. H. (1983), Gas Turbine Combustion, Hemisphere Press, New York.

Leuckel, W. (1967), "Swirl Intensities, Swirl Types and Energy Losses of Different Swirl Generating Devices," International Flame Research Foundation Report: Doc.nr. G 02/a/16.

Lew, H. G. and Toof, J. L. (1984), "Low Emission Combustor Technology Program," Westinghouse Electric Corporation Report, DOE/MC20228-1653, NTIS.

Martin, C. A. (1987), "Aspects of the Design of Swirlers as used in Fuel Injectors for Gas Turbine Combustors," ASME Paper No. 87-GT-139.

Mathur, M. L. and MacCallum, N. R. L. (1967), "Swirling Air Jets Issuing from Vane Swirlers. Part 1: Free Jets," J. Institute of Fuel, May.

Nysakala, N., et. al. (1985), "Combustion Characterization of Coals for Industrial Applications," Combustion Engineering Report: DOE/PC/40267-5, NTIS.

Rini, M. J., et. al. (1987a), "Development of a High Efficiency Advance Coal Combustor for Boiler Retrofit," Proc. 12th International Conference on Slurry Technology, New Orleans.

Rini, M. J., et. al. (1987b), "Demonstration of the Combustion Engineering 100-MBtu/h Burner for Coal-Water Slurries," EPRI Report: CS-4987.

Rini, M. J., et. al. (1986), "Commercial CWF Burner Development at Combustion Engineering," Proc. 11th International Conference on Slurry Technology, Hilton Head, South Carolina.

Smith, D. A. and LaFlesh, R. C. (1984), "Review of Sundbyberg CWM Firing Tests in a Wall Fired Industrial Boiler," Proc. American Power Conference, Chicago.

Smoot, L. D. (1984), "Modeling of Coal- Combustion Processes," Prog. Energy Combustion Sci., 10.

APPENDIX A

DETAILS OF AUTOMATIC PROBE TRAVERSING DEVICE

APPENDIX A

AUTOMATIC PROBE TRAVERSING DEVICE

Velocity Traversing Device

The APTD (Automatic Probe Traversing Device) is a programmable data acquisition system, which can automatically position and null a five-hole pitot tube and record all pressure readings on magnetic tape and hard copy output forms. A five-hole pitot tube is held in the probe positioning mechanism. There are two incremental stepping motors to position the probe. One stepping motor moves the probe axially along guide rails, in multiples of 0.1" increments, while a second motor rotates the probe in either 0.5° or 1.0° increments. The pitot tube is connected to four (4) Barocels and signal conditioners. In this system, the outputs of the signal conditioners go to the APTD microprocessor.

The APTD processor is programmed by entering the appropriate operational parameters for the particular test. Input parameters include; number of steps or data points along each insertion, number of inches per step, number of hi/lo-speed pressure samples and length of probe travel. Once these operational parameters have been entered, the traverse can be started by indicating the desired Automatic Operational Mode.

These modes of operation are permanently stored in the microprocessor. The processor controls the stepping motors to move the probe to the desired test point and rotate it until the direction of flow is found. The output of all four (4) signal conditioners is then stored on magnetic tape and printed on a terminal.

Three-Dimensional Pitot Tube Probe

The probe used was a commercially available five-hole, directional sensing pitot tube, shown schematically in Figure A-1. As shown, the probe has five pressure measuring holes located on its tip. The centrally located pressure hole P_1 measures the total or impact pressure of the fluid, while the two lateral pressure holes, P_2 and P_3 , measure the static pressure.

3-DIMENSIONAL PITOT TUBE

Figure A-1

If the probe is rotated around its axis until $P_2 = P_3$, the plane of flow can be identified and measured. However, since $P_2 = P_3$ can give two separate planes of flow 180° apart, the correct vector plane is indicated when $P_2 = P_3$ and P_1 has its highest positive value with respect to P_2 and P_3 . If a protractor and pointer are attached to the probe at its base, the angle of this vector plane, commonly called the yaw angle α , can be measured in degrees. The yaw angle α indicates the plane of flow, but does not give the flow angle within this plane. The flow angle, known as the pitch angle θ , is determined by the differential pressure $P_4 - P_5$.

In actual practice, four (4) differential pressure readings are required to fully define the flow at a particular point in the flow field of interest. These pressure differentials are:

$P_1 - P_{AT}$ = Indicated total pressure with respect to atmosphere,

$P_1 - P_2$ = Indicated velocity pressure,

$P_2 - P_3$ = Yaw angle pressure,

$P_4 - P_5$ = Pitch angle pressure.

The calibration curves shown in Figures A-2, A-3 and A-4 must be used to relate these pressure differentials to the actual pressures and pitch angles. As can be seen in the figures, the Pitch Angles Pressure Coefficient, $(P_4 - P_5) / (P_1 - P_2)$, and the Velocity Pressure Coefficient, $(P_1 - P_2) / (P_T - P_S)$, are functions of pitch angle θ , where:

P_T = Actual total (impact) pressure.

P_S = Actual static pressure.

Measured total pressure, P_1 , is independent of pitch angle as seen in the Total Pressure Coefficient vs. Pitch Angle curve of Figure A-2. The curves enable the experimenter to determine the actual velocity head and the pitch angle of the flow at each particular measuring point. Knowing this data and yaw angle, the x, y, and z or the normal, radial and tangential velocity vectors can be determined using simple geometry relationships.

Figure A-2

Figure A-3

Figure A-4

APPENDIX B

RESULTS OF FLOW VISUALIZATION EXPERIMENTS

**Figure B1A Configuration 1: Neutral Density (Helium Bubble)
Flow Pattern**

Figure B1B Configuration 1: Flow Pattern Using Yarn Streamers

**Figure B2A Configuration 2: Neutral Density (Helium Bubble)
Flow Pattern**

Figure B2B Configuration 2: Flow Pattern Using Yarn Streamers

**Figure B3A Configuration 3: Neutral Density (Helium Bubble)
Flow Pattern**

Figure B3B Configuration 3: Flow Pattern Using Yarn Streamers

**Figure B4A Configuration 4: Neutral Density (Helium Bubble)
Flow Pattern**

Figure B4B Configuration 4: Flow Pattern Using Yarn Streamers

**Figure B5A Configuration 5: Neutral Density (Helium Bubble)
Flow Pattern**

(No Photograph Available)

Figure B5B Configuration 5: Flow Pattern Using Yarn Streamers

**Figure B6A Configuration 6: Neutral Density (Helium Bubble)
Flow Pattern**

Figure B6B Configuration 6: Flow Pattern Using Yarn Streamers

**Figure B7A Configuration 7: Neutral Density (Helium Bubble)
Flow Pattern**

Figure B7B Configuration 7: Flow Pattern Using Yarn Streamers

**Figure B8A Configuration 8: Neutral Density (Helium Bubble)
Flow Pattern**

Figure B8B Configuration 8: Flow Pattern Using Yarn Streamers

APPENDIX C

SUMMARY OF VELOCITY PROFILE TESTS

Figure C 1 CONFIGURATION 1- VERTICAL PLANE (X-Y)
VELOCITY VECTORS

Figure C 2 CONFIGURATION 1- BURNER CENTERLINE FLOW PROFILES

Figure C 3 CONFIGURATION 2- VERTICAL PLANE (X-Y)
VELOCITY VECTORS

Figure C 4 CONFIGURATION 2- BURNER CENTERLINE FLOW PROFILES

Figure C 5 CONFIGURATION 3- VERTICAL PLANE (X-Y)
VELOCITY VECTORS

Figure C 6 CONFIGURATION 3- BURNER CENTERLINE FLOW PROFILES

Figure C 7 CONFIGURATION 4- VERTICAL PLANE (X-Y)
VELOCITY VECTORS

Figure C 8 CONFIGURATION 4- BURNER CENTERLINE FLOW PROFILES

Figure C 9 CONFIGURATION 5- VERTICAL PLANE (X-Y)
VELOCITY VECTORS

Figure C 10 CONFIGURATION 5- BURNER CENTERLINE FLOW PROFILES

Figure C 11 CONFIGURATION 6- VERTICAL PLANE (X-Y)
VELOCITY VECTORS

Figure C 12 CONFIGURATION 6- BURNER CENTERLINE FLOW PROFILES

Figure C 13 CONFIGURATION 7- VERTICAL PLANE (X-Y)
VELOCITY VECTORS

Figure C 14 CONFIGURATION 7- BURNER CENTERLINE FLOW PROFILES

Figure C 15 CONFIGURATION 8- VERTICAL PLANE (X-Y)
VELOCITY VECTORS

Figure C 16 CONFIGURATION 8- BURNER CENTERLINE FLOW PROFILES

EXECUTIVE SUMMARY

Objectives

This report summarizes work carried out by Combustion Engineering under U.S. Department of Energy Contract no. DE-AC 22-86PC90275, "Development of an Advanced High Efficiency Coal Combustor for Boiler Retrofit." The overall objective of this program is to develop a high efficiency advanced coal combustor (HEACC) for coal-based fuels capable of being retrofitted to industrial boilers originally designed for firing natural gas, distillate, and/or residual oil. The HEACC system is to be capable of firing microfine coal water fuel (MCWF), MCWF with alkali sorbent (for SO_2 reduction), and dry microfine coal. Design priorities for the system are that it be simple to operate and will offer significant reductions in NO_x , SO_x , and particulate emissions as compared with current coal fired combustor technology. The specific objective of this report is to document the work carried out under Task 1.0 of this contract, "Cold Flow Burner Development." As are detailed in the report, key elements of this work included primary air swirler development, burner register geometry design, cold flow burner model testing, and development of burner scale up criteria.

Discussion

The overall objective of this project is to develop a firing system (HEACC) for coal-based fuels to enable the replacement of oil and natural gas in boilers and other fuel firing equipment currently using these premium fuels. The primary target for the application of the HEACC is industrial users. In the industrial sector, a significant proportion of total boiler capacity in operation in the year 2000 is expected to be composed of pre- 1980 units. ~~Therefore, any~~ substantial near term increase in the use of coal for producing industrial steam will therefore have to be accomplished through conversion of boilers currently fired by natural gas or oil. The application of coal or coal- based fuels to industrial boilers originally designed for gas or oil firing presents a number of challenges to the combustion engineer. Constraints such as carbon conversion efficiency, emissions control, and coal and ash handling must be

END

**DATE
FILMED**

2 / 18 / 92