35 Station 21

ENGINEERING DATA TRANSMITTAL

Page 1 of 1

1. EDT

600916

2. To: (Receiving Organization) 300 AREA UTILITIES AND EFFLUENT TREATMENT		3. From: (Originating Organization) EFFLUENT PROCESS ENGINEERING		4. Related EDT No.: N/A							
5. Proj./Prog./Dept./Div.: EFFLUENT PROGRAMS		6. Cog. Engr.: KJ HAGERTY		7. Purchase Order No.: N/A							
8. Originator Remarks: This Sampling and Analysis Plan (SAP) provides instructions for characterizing the 384 powerhouse effluent streams. Characterization data will be used to certify the constituents in each stream.				9. Equip./Component No.: N/A							
				10. System/Bldg./Facility: PROCESS SEWER/384/300							
				12. Major Assm. Dwg. No.: N/A							
11. Receiver Remarks:				13. Permit/Permit Application No.: N/A							
				14. Required Response Date: N/A							
15. DATA TRANSMITTED				(F)	(G)	(H)	(I)				
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	Approval Designator	Reason for Transmittal	Originator Disposition	Receiver Disposition			
1	WHC-SD-WM-PLN-071	N/A	0	384 POWER PLANT WASTE WATER SAMPLING AND ANALYSIS PLAN	ÆESQ	1	1	1			
16. KEY											
Approval Designator (F)		Reason for Transmittal (G)			Disposition (H) & (I)						
E, S, Q, D or N/A (see WHC-CM-3-5, Sec.12.7)		1. Approval 2. Release 3. Information 4. Review 5. Post-Review 6. Dist. (Receipt Acknow. Required)			1. Approved 2. Approved w/comment 3. Disapproved w/comment 4. Reviewed no/comment 5. Reviewed w/comment 6. Receipt acknowledged						
(G)	(H)	17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)				(G)	(H)				
Reason	Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN	(J) Name	(K) Signature	(L) Date	(M) MSIN	Reason	Disp.
1	1	Cog.Eng. KJ Hagerty L6-04		12/5/94		MJ McCarthy N3-13		12/5/94		1	1
1	1	Cog. Mgr. DL Halgren L6-04		12/5/94		RW Brown L6-79		12/5/94		1	1
1	1	QA MJ Warn H4-16		12/5/94		HM Knotek L6-05		12/5/94		3	-
1	1	Safety DB Tullis N1-78		12/5/94		(OSTI distr. -2copies w/att L8-07)					
1	1	Env. RW Szelmezcza L4-96		12/5/94		CENTRAL FILES (orig. +2) L8-04					
1	1	CD Morrison-Beyer S3-90		12/5/94							
1	1	MS Hendrix H4-23		12/5/94							
18. HM Knotek Signature of EDT Originator		19. JL Da... Authorized Representative for Receiving Organization		20. DL Halgren Cognizant Manager		21. DOE APPROVAL (if required) Ctrl. No. ☐ Approved ☐ Approved w/comments ☐ Disapproved w/comments					

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

RELEASE AUTHORIZATION

Document Number: WHC-SD-WM-PLN-071, Revision 0

Document Title: 384 Power Plant Waste Water Sampling and Analysis Plan

Release Date: December 12, 1994

**This document was reviewed following the
procedures described in WHC-CM-3-4 and is:**

APPROVED FOR PUBLIC RELEASE

WHC Information Release Administration Specialist:

M.N. Boston

12/12/94

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

This report has been reproduced from the best available copy. Available in paper copy and microfiche. Printed in the United States of America. Available to the U.S. Department of Energy and its contractors from:

U.S. Department of Energy
Office of Scientific and Technical Information (OSTI)
P.O. Box 62
Oak Ridge, TN 37831
Telephone: (615) 576-8401

Available to the public from: U.S. Department of Commerce
National Technical Information Service (NTIS)
5285 Port Royal Road
Springfield, VA 22161
Telephone: (703) 487-4650

SUPPORTING DOCUMENT		1. Total Pages 29
2. Title 384 POWER PLANT WASTE WATER SAMPLING AND ANALYSIS PLAN	3. Number WHC-SD-WM-PLN-071	4. Rev No. 0
5. Key Words Sampling, Analysis, Plan, SAP, 300 Area, Process Sewer, 384	6. Author Name: KJ Hagerty/HM Knotek <div style="text-align: right;"> 12/5/94 </div> Signature Organization/Charge Code 86310/A2216	

7. Abstract

This document presents the 384 Power House Sampling and Analysis Plan. The Plan describes sampling methods, locations, frequency, analytes, and stream descriptions. The effluent streams from 384, were characterized in 1989, in support of the Stream Specific Report (WHC-EP-0342, Addendum 1).

**APPROVED FOR
PUBLIC RELEASE**

MASTER

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

8. RELEASE STAMP

**OFFICIAL RELEASE
BY WHC
DATE DEC 13 1994**

35 Station 21

A-6400-073 (08/94) WEF124

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

384 Power Plant Wastewater Sampling and Analysis Plan

CONTENTS

ABBREVIATIONS/ACRONYMS	4
A. SAMPLING OBJECTIVE	5
A.1 INTRODUCTION	5
A.2 OBJECTIVES	5
A.3 APPROACH	6
B. SITE BACKGROUND	7
B.1 FACILITY DESCRIPTION	7
B.2 STREAM DESCRIPTION	7
B.3 SEWER SYSTEMS	8
C. RESPONSIBILITIES	10
D. SAMPLING LOCATIONS AND FREQUENCIES	12
D.1 STEAM CONDENSATE	12
D.2 BOILER BLOWDOWN	12
D.3 WATER SOFTENER REGENERATION	12
D.4 BRINE PIT	12
D.5 SAMPLING FREQUENCIES	17
E. SAMPLE IDENTIFICATION	18
F. SAMPLING EQUIPMENT AND PROCEDURES	19
G. SAMPLE HANDLING AND ANALYSIS	20
H. DATA QUALITY	21
I. REFERENCES	22

LIST OF FIGURES

B-1	LOCATION OF THE HANFORD SITE AND THE 300 AREA	9
D-1	PROCESS SEWER AND TRENCHES	13
D-2	384 WATER SOFTENER REGENERATION SAMPLE POINT	14
D-3	384 BOILER BLOWDOWN SAMPLE POINT	15
D-4	384 STEAM CONDENSATE RETURN SAMPLE POINT	16

LIST OF TABLES

APPENDIX A - ANALYTICAL METHODS

A-1	ANALYTICAL METHOD 6010 (ICP)	23
A-2	ANALYTICAL METHOD 625 (GCMS)	24
A-3	MISCELLANEOUS METHODS	27

APPENDIX B - SCHEDULE OF WATER SOFTENER REGENERATION SAMPLING	28
--	----

ABBREVIATIONS/ACRONYMS

DOE	U.S. Department of Energy
Ecology	Washington State Department of Ecology
EDMC	Environmental Data Management Center
EPA	U.S. Environmental Protection Agency
ETP	Effluent Treatment Programs
FEMP	Facility Effluent Monitoring Plan
HTS	Hanford Technical Services
HEIS	Hanford Environmental Information System
HPT	Health Physics Technician
JHA	Job Hazard Analysis
LEMIS	Liquid Effluent Monitoring Information System
NPDES	National Pollutant Discharge Elimination System
S&ML	Sampling and Mobile Laboratories
SAP	Sampling and Analysis Plan
TEDF	Treated Effluent and Disposal Facility
WAC	Washington Administrative Code
WHC	Westinghouse Hanford Company

A. SAMPLING OBJECTIVES

A.1 Introduction

This Sampling and Analysis Plan (SAP) describes the field activities and methods associated with collection of boiler blowdown, steam condensate, and water softener regeneration samples from the process wastewater stream in the Hanford 300 Area. Sampling location and frequencies are specified in this SAP. The samples, which will be used to enhance process knowledge, will not require EPA protocol during sampling. However, protocol will be necessary during analysis as described in *300 Area Liquid Effluent Facilities Administration*, WHC-IP-1000. Guidelines for sample collection are provided in the *Handbook for Sampling and Sample Preservation of Water and Wastewater* EPA-600-482-029.

The remaining sections of this SAP include the following:

- Section B--Site Background
- Section C--Responsibilities
- Section D--Sample Location and Frequency
- Section E--Sample Identification
- Section F--Sampling Equipment and Procedures
- Section G--Sampling Handling and Analysis
- Section H--Data Quality
- Section I--References

The SAP is to be used in conjunction with the *Hanford Technical Services Procedures*, the *Handbook for Sampling and Sample Preservation of Water and Wastewater* EPA-600-482-029, *300 Area Liquid Effluent Facilities Administration*, WHC-IP-1000, and *Environmental Investigations and Site Characterization Manual*, WHC-CM-7-7 (WHC, 1992a).

A.2 Objectives

Overall objectives for the SAP are to provide characterization of boiler blowdown, steam condensate, and water softener regenerant. Characterization data will be used to certify the stream meets the 300 Area Treated Effluent Disposal Facility (TEDF) waste acceptance criteria.

In summary the characterization information will be used to:

- Provide additional records of the quality and content of discharges to the 300 Area process sewer.

REV. 0

- Provide evidence that the 300 Area boiler blowdown and steam condensate is meeting the waste acceptance criteria for the Treated Effluent Disposal Facility.
- Provide baseline characterization data for water softener regenerant wastewater.

The sampling program is based on addressing these objectives and has been tailored on the basis of available characterization data in the *300 Area Process Wastewater Stream-Specific Report*, WHC-EP-0342 (WHC, 1990a), *Hanford 300 Area Process Wastewater Characterization and Data Report*, WHC-SD-L045H-DP-001, Rev. 0 (WHC, 1992c), and *Columbia River Characterization Data Report in Support of Hanford Project L045H* (WHC 1992). The results of this sampling program should provide representative wastewater characterization data.

A.3 Approach

This SAP has been structured to obtain sampling data that will identify the types of contaminants found in the discharge wastewater from the 384 Powerhouse. The data will come from liquid characterization samples, transportation of the sample media, analysis of the media, the statistical evaluation of the analytical results, and the storing of sample records. All liquid characterization sampling work shall be performed according to guidelines in the *Handbook for Sampling and Sample Preservation of Water and Wastewater* EPA-600-482-029 and *300 Area Liquid Effluent Facilities Administration*, WHC-IP-1000, with the exception of the sample type based on internal memo 86700-94-108.

Personnel associated with collection of liquid characterization samples, processing of the samples, processing of the data, and control of records shall comply with the procedures related to their responsibilities. As appropriate, personnel shall sign a document verifying that they have read and understand the procedures. The signed documents shall become part of the training records.

The liquid characterization samples will be grab samples. The steam condensate, boiler blowdown, and water softener regenerant wastestreams will be sampled at points and times of highest contamination; therefore, composite sampling will not be necessary.

The samples will be analyzed for contaminants suspected to be present and especially for constituents which have limits listed in WHC-IP-1000, Sect. 3.3, *Waste Acceptance Criteria for the 300 Area Process Sewer and the Treated Effluent Disposal Facility*. Characterization resampling will occur whenever chemical additives used in boiler chemistry control are changed or if changes in powerhouse operation occur that could significantly affect the constituent loading of either the steam condensate or softener regenerant.

B. SITE BACKGROUND

B.1 Facility Description

The Hanford Reservation is a U.S. Department of Energy (DOE) facility located in southeastern Washington (see Figure B-1). The 300 Area is located in the southeastern portion of the Hanford Reservation, adjacent to the Columbia River, in southeastern Washington State. A variety of office buildings, research laboratories, and support facilities (e.g., warehouses and shops) are located in the 300 Area. Many of these facilities depend on steam for heat.

The 384 Powerhouse provides heating steam to many 300 Area facilities. A large portion of the steam condensate is returned to the Powerhouse via the condensate return piping system. However, approximately 30% of the condensate is discharged by individual facilities to either the 300 Area Process Sewer or french drains.

Routine operation of the 384 Powerhouse boilers includes both continuous and periodic blowdown. Blowdown is necessary to maintain boiler chemistry within acceptable bounds. The resulting blowdown can be directed to either the sanitary waste system or the process waste water system.

B.2 Stream Description

Steam condensate is discharged to the 300 Area Process Sewer from a number of 300 Area facilities. The exact number is not known due to the age of many of the facilities and the lack of as-built prints. The steam is used only for heating of the facilities; process steam is not utilized in the 300 Area. The steam condensate is expected to contain metals from the corrosion of the boiler, steam delivery piping, and the condensate return system.

Boiler blowdown is required to maintain proper boiler chemistry. Periodic blow downs are performed as necessary to maintain or adjust boiler water chemistry. Additives include sodium sulfite (Dearborn 66, MSDS 15053), and potassium hydroxide (Polyquest 683, MSDS 24176). The sodium sulfite is used to scavenge oxygen from the feedwater reducing its corrosivity. The potassium hydroxide is used to reduce the scale buildup in the boiler tubes. Hydrogenated tallow amines (Superfilm 14, MSDS 12387) are used to passivate the steam piping system. Boiler blowdown is expected to contain the corrosion inhibitors and some of the dissolved solids from the boiler feedwater.

Soft water is used in the boilers to slow the scale build on the boiler tubes. The soft water is produced by passing potable water through a sodium zeolite ion exchange bed. The sodium is displaced by minerals present in the potable water stream. The zeolite is regenerated by first backflushing and then a brine solution is passed through the vessel. The sodium in the brine displaces the collected minerals. The minerals, chlorine, and spent brine in the regenerant are then sent to the process sewer system.

B.3 Sewer Systems

The 300 Area process trenches have been used for disposal of process water from facilities at the 300 Area since 1975. The trenches are located in the northern part of the 300 Area and are designated as the 316-5 process trenches. The liquid effluent disposal facility consists of two parallel trenches approximately 370 meters long and oriented in a north-south direction. The trenches are approximately 3.4 meters deep, 3.0 meters wide at the bottom, and 9 to 11 meters wide at the top. The use of the west trench has been discontinued. All process sewer effluent is discharged to the east trench. The 300 Area Treated Effluent Disposal Facility, which is located north of the 300 Area, will continuously treat the 300 Area Process Sewer System waste water.

Figure B-1
Hanford Site and the 300 Area

C. RESPONSIBILITIES

The organizations listed below have the following responsibilities for implementation of this SAP.

ICF-KH Utilities

- Funding for sampling activities will be provided by the Power Plant Utilities.
- Provides Person in Charge (PIC)/operator support as required during liquid effluent characterization sampling including sampler setup.
- Coordinates health physics support when needed. The 384 facility is currently exempt from radiological release survey (Internal Memo 33830-93-009) and no monitoring support should be required. An authorized individual will confirm that samples were collected in an exempt facility and document this accordingly under health physics direction.
- Selects grab sample time and coordinates with sampling personnel and appropriate facility personnel.

300 Area Facilities Health Physics

- Provide a Health Physics authorized individual to verify samples were obtained from an exempt facility.

Hanford Technical Services (HTS)

- Provide trained samplers for liquid effluent characterization sampling activities. The designated Lead Sampler shall have a WHC Certificate of Qualification from Hanford Technical Services and shall direct liquid effluent characterization sampling and packaging activities.
- Conduct field analysis as requested
- Document sampling activities in a record log book.
- Collect samples
- Transport liquid effluent characterization samples to laboratory or shipping center.
- Initiate Chain of Custody documentation for liquid effluent characterization samples.

Hanford Technical Services (continued)

- Package liquid effluent characterization samples for shipping.
- Ensure copies of field logs and other sampling data sheets are filed with 300 TEDF process engineering.

Analytical Services

- Establish analytical laboratory contracts.
- Ensure laboratories perform analyses in accordance with all required QA procedures.
- Generate Sample Authorization Form
- Provide letter report. Data validation is not required.
- Provide statement of work for lab performing analysis

Process Engineering

- Maintain the Sampling and Analysis Plan.
- Review liquid effluent characterization sampling data for completeness and consistency.
- Initiate scheduling of personnel required for sampling.
- Provide technical support for sampling activities.
- Review chain of custody activities.
- Complete Job Hazard Analysis (JHA) for sampling activities.

D. SAMPLING LOCATION AND FREQUENCIES

The steam condensate, boiler blowdown, and water softener regenerant samples will all be collected in the 384 Powerhouse. The Brine Pit is located outside, on the west end of the Power House.

D.1 Steam Condensate

Rather than sample each individual steam condensate discharge point, samples will be collected at a single location in the 384 powerhouse. This single characterization point will be used to represent steam condensate for all contributing facilities.

The steam condensate sample will be collected from the condensate return collection tank located in the basement of the powerhouse. The condensate return system is used to transport steam condensate from the facilities using steam. The returned condensate is most likely to have the highest levels of contaminants due to the extended contact with piping. The samples will be collected from a 1/4 inch sample line on the condensate return tank.

Care must be taken during sampling of the steam condensate due to the temperature of the sample.

D.2 Boiler Blowdown

The boiler blowdown sample will be collected from the chemical laboratory area of the water softener room just prior to blowdown. In the steam supply system, boiler blowdown is expected to have the highest levels of corrosion inhibiting additives and dissolved solid materials.

D.3 Water Softener Regenerant

The water softener regenerant samples will be collected in the Water Softener room. The contaminants will be highest in brine addition sequence of the regeneration cycle. The samples will be collected from the floor trench in the room.

D.4 Brine Pit

The Brine Pit samples will be collected as dip samples at the brine pit. Sampling of the brine solution is required to determine the contaminant levels of the regenerant feed to the zeolite softeners.

LEGEND

- Process wastewater sewer
- Manhole
- Fence

Figure D-1
300 Area Process Sewer and Trenches

Figure D-2
384 Water Softener Regeneration

Figure D-3
384 Boiler Blowdown

Figure D-4
384 Steam Condensate Return

D.5 Sampling Frequencies

The operational parameters of the 384 Powerhouse do not change frequently. The same kind of corrosion inhibitors and zeolite have been used for several years. The discharges will be characterized for this SAP only one time unless process changes warrant recharacterization. If changes in the chemical additives or the zeolite are made then the discharges will be resampled to identify any significant changes.

Field measurements for water temperature, pH, specific conductance, residual chlorine, sulfide, and sulfite will be taken at the same time that the grab samples are collected. Field conductivity measurements will be taken in 5 minute intervals during backwash and brine addition.

All samples collected will be grab samples. The samples will be collected during normal working hours. Analytical methods and the schedule of water softener regeneration sampling are presented in Appendix B.

E. SAMPLE IDENTIFICATION

Sample labels for liquid effluent characterization samples shall be furnished by the sampling team from Hanford Technical Services. The labels will require the following information to be recorded by a member from the sampling team: identification of the person in charge of collecting the sample; unique sample identification number; date and time the sample was collected; the place the sample was collected; preservative added; and the analysis to be performed on the sample. The unique sample number shall be obtained from the Hanford Environmental Information System (HEIS). In addition, each bottle shall be identified with a bar code sticker attached to the bottle by the bottle manufacturer. The bar code shall identify the bottle lot number and individual bottle number.

F. SAMPLING EQUIPMENT AND PROCEDURES

The process wastewater samples will be analyzed for organics, inorganics, and water quality characteristics plus the field parameters pH, specific conductance, temperature residual chlorine and sulfite.

In order to collect grab samples of the wastewater, a bailer or a dip sampler with stainless steel beaker attached will be used. For grab samples, wastewater will be poured directly from the sampling device (dip sampler or bailer) into a sample bottle. Sample bottles shall be new, commercially available, certified precleaned containers. The certificates of precleaned condition shall accompany the containers.

Containers for semi-volatiles shall be filled without bubble formation and without leaving a head space. Volatile organics are not of concern so trip blanks will not be necessary. Samples will be taken directly into sample bottles therefore field blanks are not needed. Field duplicates obtained at a minimum 10 percent or one-per-batch frequency will be used to assess method variation.

The sample bottles will not require a survey for surface radioactivity prior to shipment; the 384 Powerhouse is an exempt facility (Internal Memo "Exemption from Radiological Release Surveys" 33830-93-009). An health physics authorized representative shall provide a signature verifying the exempt status. The samples will be packaged in accordance with "Environmental Investigations and Site Characterization Manual," procedure EII 5.11, "Sample Packaging and Shipping" and "Hazardous Material Packaging and Shipping," WHC-CM-2-14 Rev. 9, Effective 4/30/93. The samples will be placed in a cooler containing ice. The cooler shall become part of the sample packaging.

Process wastewater temperature, pH, specific conductance, residual chlorine, and sulfite will be field monitored with a water quality meter(s) or equivalent HTS procedure. The unit(s) will be field calibrated before use and checked against appropriate standard solutions according to the manufacturer's recommendations at the beginning of each sampling event. Calibration measurements will be recorded in the field log book. Preventive maintenance for field equipment will be carried out in accordance with the manufacturer's recommended procedures and schedules. Spare parts should include batteries and replacement pH and conductivity probes. The written guidance for controlling field measurement equipment can be found in "Environmental Investigations and Site Characterization Manual," WHC-CM-7-7, procedure EII 3.2 "Calibration and Control of Monitoring Instruments"

Field logs will be completed per the "Environmental Investigations and Site Characterization Manual," WHC-CM-7-7, procedure EII 1.5 "Field Logbooks" at the time of sampling by the sampling team. A field logbook shall be maintained which contains information pertinent to the sampling and the information shall become part of the quality control record documents.

G. SAMPLE HANDLING AND ANALYSIS

The handling and preparation of samples will comply with the procedures found in the *Environmental Investigations and Site Characterization Manual*, WHC-CM-7-7 (1992a) and the *300 Area Liquid Effluent Facilities Administration*, WHC-IP-1000, Section 3.3, with the exception of the sample type based on internal memo 86700-94-108. A chain of custody form will be initiated at the time of sampling and will accompany each liquid effluent characterization sample per lab procedure LO-050-443. A sample may consist of several containers. The chain of custody will account for each container. The preparation of either a single or a group of samples for shipment to a laboratory shall comply with the procedure EII 5.11 "Sample Packaging and Shipping."

Once a sample has been drawn, it must be in the physical control or view of the custodian, located in an area where it cannot be tampered with, and prepared for shipping with tamper-proof tape applied. Physical control includes being in the sight of the custodian, being in a room which will signal an alarm when entered, or locked in a cabinet. When more than one person is involved in sampling, one person shall be designated and only that person signs as sampler. This person is the custodian until the samples are transferred to another location or group and shall sign when releasing the samples to the designated receiver.

The approved laboratory shall designate a sample custodian and a designated alternate responsible for receiving all samples. The sample custodian or his alternate shall sign and date all appropriate receiving documents at the time of receipt and at the same time initiate an internal Chain of Custody form using documented procedures per the Chain of Custody/Sample Analysis Request Procedure, WHC-CM-7-7, EII 5.1, Rev. 6. A continuous chain of custody will be maintained from the time of sampling until final disposition of all samples.

The procedures to be used for analysis are listed in Appendix A. The Statement of Work for completing the analysis shall require the approved laboratories to have existing standard operating procedures and to submit any changes in their procedures during the contract term for approval. The approved laboratory procedures shall describe data reduction, verification, and reporting.

The data will be considered representative so long as at least 90 percent of the data points meet the established requirements in the laboratory contract for precision and accuracy. Data which do not meet this objective will be reviewed to determine whether the data can be used or whether corrective action should be taken. The PIC or task leader will be responsible for developing, initiating, and tracking corrective action(s) if needed.

Equipment used to collect grab samples of the process wastewater will be decontaminated per Westinghouse procedure WHC-CM-7-7, EII 5.5 at 1706 K east cleaning facility. If a field decontamination is needed, HTS will follow WHC-CM-7-7, EII 5.4 and document it in the field log book.

H. DATA QUALITY

H.1 Data Quality Objectives

The objectives for the SAP are to provide characterization of boiler blowdown, steam condensate, and water softener regenerant. Characterization data will be used to certify the constituents in each stream. The data will need to be of sufficient quality to satisfy the requirements of the following:

- *300 Area Liquid Effluent Facilities Administration*, WHC-IP-1000, Section 3.3.

The data quality objectives will be met through controlled field work, adequate documentation of field activities and use of approved laboratories and methods for analysis and letter report of the analysis results. The results of this sampling program should provide representative wastewater characterization data. Analytical results will not be validated.

I. REFERENCES

- EPA 1982 *Handbook for Sampling and Sample Preservation of Water and Wastewater*, EPA-600-482-029
- WHC 1990a *300 Area Process Wastewater Stream-Specific Report*, WHC-EP-0342, Prepared for the U.S. Department of Energy, Richland Washington.
- WHC 1992a *Environmental Investigations and Site Characterization Manual*, WHC-CM-7-7, Richland, Washington.
- WHC 1992c *Hanford 300 Area Process Wastewater Characterization Data Report*, WHC-SD-L045H-DP-001, Revision 0, Richland Washington.
- WHC 1993a Internal Memo, 33830-93-009, *Exemption from Radiological Release Surveys*.
- WHC 1993b *300 Area Liquid Effluent Facilities Administration Procedures*, WHC-IP-1000, Section 3.3, Revision 0.
- WHC 1993c *Environmental Investigations and Site Characterization Manual*, WHC-CM-2-14 Rev. 9, Effective 4/30/93.
- WHC 1994 Internal Memo, 86700-94-108, D.W. Lindsey to D.L. Halgren, *Waiver of Composite Sampling of the 384 Power Plant Liquid Effluent*, November 21, 1994.

**APPENDIX A
ANALYTICAL METHODS**

This appendix contains the analytical methods that will be utilized in the Liquid Effluent Characterization Program. The required analytical methods for total metals and total recoverable metals are listed in *300 Area Liquid Effluent Facilities Administration*, WHC-IP-1000, Section 3.3: Total Metals and Total Recoverable Metals.

Table A-1. Inductively Coupled Plasma Atomic Emission Spectroscopy

Analyte	Method	CASN ^a	EDL ^b	% Ac ^c	% RSD ^d
Aluminum	200.7	7429-90-5	45	87	11
Antimony	200.7	7440-36-0	32	87	11
Arsenic	206.3	7440-38-2	53	87	11
Barium	200.7	7440-39-3	2	87	11
Beryllium	200.7	7440-41-7	0.3	87	11
Boron	200.7	7440-42-8	58	87	11
Cadmium	213.2	7440-43-9	4	87	11
Chromium	SM312 ^e	7440-47-3	7	87	11
Cobalt	200.7	7440-48-4	7	87	11
Copper	200.7	7440-50-8	6	87	11
Iron	200.7	7439-89-6	7	87	11
Lead	239.2	7439-92-1	42	87	11
Magnesium	200.7	7439-95-4	36	87	11
Manganese	200.7	7439-96-5	2	87	11
Molybdenum	200.7	7439-98-7	8	87	11
Nickel	200.7	7440-02-0	15	87	11
Potassium	200.7	7440-09-7	5000	87	11
Selenium	270.2	7782-49-2	75	87	11
Silicon	200.7	7440-22-3	58	87	11
Silver	272.2	7440-22-4	7	87	11
Sodium	200.7	7440-23-5	29	87	11
Thallium	200.7	7440-28-0	40	87	11
Vanadium	200.7	7440-62-2	8	87	11
Zinc	200.7	7440-66-6	3.8	87	11

Footnotes:

- a) Chemical Abstract System Registration Number
- b) Estimated Detection Limit (EDL) (ppb)
- c) % Accuracy
- d) Relative Standard Deviation
- e) Method from APHA-AWWA-WPCF

Table A-2 Method 624:
GCMS for Semivolatile Organics

NAME OF ANALYTE	C.A.S. NUMBER	MDL WATER PPB	Percent * Accuracy and % RSD
Acenaphthene	83-32-9	3.3	96 ± 19%
Acenaphthylene	208-96-8	3.5	90 ± 23%
Anthracene	120-12-7	2.8	81 ± 20%
Benzo(a)anthracene	56-55-3	7.8	87 ± 22%
Benzo(b)fluoranthene	205-99-2	23.9	89 ± 28%
Benzo(k)fluoranthene	207-08-9	23.9	84 ± 30%
Benzo(g,h,i)perylene	191-24-2	4.4	96 ± 48%
Benzo(a)pyrene	50-32-8	3.9	89 ± 31%
Bis(2-chloroethoxy) methane	111-91-1	5.3	102 ± 30%
Bis(2-chloroethyl)ether	111-44-4	5.7	83 ± 29%
Bis(2-chloroisopropyl)ether	39638-32-9	5.7	98 ± 27%
Bis(2-ethylhexyl)phthalate	117-81-7	4.1	82 ± 31%
4-Bromophenyl phenyl ether	101-55-3	3.9	88 ± 16%
Butyl benzyl phthalate	85-68-7	4.6	63 ± 34%
2-Chloronaphthalene	91-58-7	3.4	89 ± 12%
4-Chloro-3-methyl phenol	59-50-7	3.0	84 ± 27%
2-Chlorophenol	95-57-8	3.3	78 ± 24%
4-Chlorophenyl-phenyl ether	7005-72-3	4.2	92 ± 27%
Chrysene	218-01-9	3.3	91 ± 30%
Dibenz(a,h)anthracene	53-70-3	3.0	97 ± 58%
Di-n-Butylphthalate	84-74-2	4.2	60 ± 25%
1,2-Dichlorobenzene	95-50-1	2.6	80 ± 21%
1,3-Dichlorobenzene	541-73-1	3.0	85 ± 35%
1,4-Dichlorobenzene	106-46-7	4.4	70 ± 21%
2,4-Dichlorophenol	120-83-2	2.7	87 ± 21%
Diethylphthalate	84-66-2	9.2	45 ± 24%

NAME OF ANALYTE	C.A.S. NUMBER	MDL WATER PPB	Percent * Accuracy and % RSD
2,4-Dimethylphenol	105-67-9	9.4	80 ± 20%
Dimethylphthalate	131-11-3	8.1	22 ± 21%
4,6-Dinitro-2-methylphenol	534-52-1	24	48 ± 58%
2,4-Dinitrophenol	51-28-5	42	44 ± 71%
2,4-Dinitrotoluene	121-14-2	5.7	82 ± 21%
2,6-Dinitrotoluene	606-20-2	3.2	99 ± 21%
Di-n-octylphthalate	117-84-0	4.9	74 ± 30%
Fluoranthene	206-44-0	3.3	83 ± 22%
Fluorene	86-73-7	3.7	90 ± 13%
Hexachlorobenzene	118-74-1	4.0	75 ± 32%
Hexachlorobutadiene	87-68-3	3.8	69 ± 19%
Hexachlorocyclopentadiene	77-47-4	6.1	NL
Hexachloroethane	67-72-1	3.7	71 ± 14%
Indeno(1,2,3-cd)pyrene	193-39-5	4.4	72 ± 35%
Isophorone	78-59-1	3.2	115 ± 39%
Naphthalene	91-20-3	3.2	79 ± 23%
Nitrobenzene	98-95-3	4.3	102 ± 28%
2-Nitrophenol	88-75-5	3.6	68 ± 23% **
4-Nitrophenol	100-02-7	27.6	60 ± 28%
N-Nitrosodiphenylamine	86-30-6	8.2	NL
N-Nitrosodipropylamine	621-64-7	ND	100 • 44%
Pentachlorophenol	87-86-5	3.6	94 ± 30%
Phenanthrene	85-01-8	5.4	87 ± 14%
Phenol	108-95-2	2.6	45 ± 17%
Pyrene	129-00-0	4.3	84 ± 13%
1,2,4-Trichlorobenzene	120-82-1	3.2	92 ± 20%
2,4,6-Trichlorophenol	88-06-2	2.7	91 ± 23%

Table A-2 Footnotes:

The MDL's (Method Detection Limit) listed were obtained from the published 624 procedure and should be considered estimates. The individual laboratories' MDLs will vary depending on sample matrices, sample concentrations, and instrumental capabilities.

* The percent and percent relative standard deviation (%RSD) data have been generated from the information within method 624 in Table 7 " Method Accuracy and Precision as a Function of Concentration - Method 624", by using the concentration of 50 ppb for each analyte.

** The accuracy and overall precision data for 2-Nitrophenol was based on the formula 0.70 - 1.15 instead of 0.07 - 1.15. It is believed that the .07 is a typographical error and should be instead 0.70 in order to obtain meaningful data.

Table A-3 Miscellaneous Methods

Method ^e	Analyte ^e	CASN ^a	DL ^b	%Ac ^{c,g}	%RPD ^{d,g}
415.1/415.2	Total Organic Carbon (TOC)		1 ppm	75-125	20
413.1/413.2	Oil and Grease, total recoverable		5 ppm	75-125	20
375.4	Sulfate		1 ppm	75-125	20
353.1/353.3	Nitrogen, Nitrate, Nitrite		50 ppm	75-125	20
350.1/350.2/350.3	Ammonia (as N)	7664-41-7	50 ppm	75-125	20
325.2/325.3	Chloride		1 ppm	75-125	20
310.1	Alkalinity		1 ppm	75-125	20
200.7	ICP for trace elements			75-125	20
160.1	Total Dissolved Solids		10 ppm	75-125	20

Footnotes:

- a) Chemical Abstract System Registration Number
- b) Detection Limit (units specified)
- c) Percent Accuracy
- d) Relative percent Deviation (plus or minus amount given)
- e) Unless otherwise specified, all analytes use methods defined in *Methods for Chemical Analysis of Water and Wastes*, EPA-600/4-79-020, U.S. EPA/Environmental Monitoring and Support Laboratory, Cincinnati, Ohio.
- f) *Standard Methods for the Examination of Water and Wastewater*, APHA-AWWA, WPCS, Fed 1989, 17th edition.
- g) When %Ac or %RSD are listed as NL or absent, the analyte may not be properly quantitated. It is expected that the lab will be unable to produce sufficient data to prove the sample preparation could adequately extract the analyte from the matrix. It is also expected that the lab will be unable to produce sufficient data to prove the analytical instrumentation was calibrated for these analytes.

APPENDIX B

SCHEDULE OF WATER SOFTENER REGENERATION SAMPLING

This appendix contains the sequence, time, analytical methods/additional analyses, and matrix of the water softener regeneration sample parameters that will be used in the Liquid Effluent Characterization Program.

Sequence	Time	Sample Number	Analysis	Matrix
Backwash	N/A	1	TDS, Alkalinity Conductivity, TSS, TOC	Sanitary Water
Salt Regeneration	0:02	2	200.8 (ICP/MS), TB, AT, TDS, Alkalinity, Conductivity	Up to 5 wt% NaCl brine and 9 wt% TDS
Salt Regeneration	0:04	3	200.8 (ICP/MS), TB, AT, TDS, Alkalinity, Conductivity	Up to 5 wt% NaCl brine and 9 wt% TDS
Salt Regeneration	0:06	4	200.8 (ICP/MS), TB, AT, TDS, Alkalinity, Conductivity	Up to 5 wt% NaCl brine and 9 wt% TDS
Salt Regeneration	0:08	5	200.8 (ICP/MS), TB, AT, TDS, Alkalinity, Conductivity	Up to 5 wt% NaCl brine and 9 wt% TDS
Salt Regeneration	0:10	6	200.8 (ICP/MS), TB, AT, TDS, Alkalinity, Conductivity	5 wt% NaCl and 9 wt% TDS
Salt Regeneration	0:12	7	200.8 (ICP/MS), TB, AT, TDS, Alkalinity, Conductivity	Up to 5 wt% NaCl brine and 9 wt% TDS
Salt Regeneration	0:14	8	200.8 (ICP/MS), TB, AT, TDS, Alkalinity, Conductivity	3 wt% NaCl, 5 wt% TDS
Slow Rinse	0:30	9	200.8 (ICP/MS), TB, AT, TDS, Alkalinity, Conductivity	1 wt% NaCl, 2 wt% TDS
Fast Rinse	1:30	10	200.8 (ICP/MS), TB, AT, TDS, Alkalinity, Conductivity	< 0.5 wt% TDS