PAP0-89-18

OAK RIDGE NATIONAL LABORATORY
OPERATED BY MARTIN MARIETTA ENERGY SYSTEMS, INC.

POST OFFICE BOX 2009
OAK RIDGE, TENNESSEE 37831-8050

NE-F--1-2T

DE93 011209

NUCLEAR STANDARDS TRANSMITTAL

ATT.	DISTRIBUTION	RETURN COMMENTS TO ORNL Standards Coordinator	DATE February 17, 1989	
	List 01 05	NO LATER THAN	TYPE SUBMISSION	TYPE ACTION
		COGNIZANT ENGINEER	☐ 1. TENTATIVE	☒ A. TRIAL USE
			☐ 2. DRAFT	☐ B. INFORMATION
			☐ 3. AMENDMENT	☐ C. COMMENTS
		PHONE Com. 615-574-7886 FTS 624-7886	☒ 4. REVISIONS ☐ 5.	☐ D.
		NUMBER	DESCRIPTION	ACTION
		F 1-2T	Preparation of Plant and System Design Description Documents	A
			<p style="text-align: center; font-size: 2em; font-weight: bold;">MASTER</p> <p style="text-align: center;">DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED</p>	

SIGNATURE

William L. Cooper, Jr.

William L. Cooper, Jr., Manager
Performance Assurance Project Office

FOREWORD

This standard supersedes the December 1975 and Reaffirmed April 1981 issues of NE F 1-2T and incorporates those changes to the standard that were approved and published. This revision is a result of input from the Department of Energy Working Group on Standards.

January 1989

i

i

PREPARATION OF PLANT AND SYSTEM DESIGN DESCRIPTION DOCUMENTS

TABLE OF CONTENTS

	<u>Page</u>
1. SCOPE.....	1
2. PLANT DESIGN REQUIREMENTS DOCUMENT	1
2.1 Purpose of Plant Design Requirements Document	1
2.2 Application of Plant Design Requirements	1
2.3 Content of Plant Design Requirements Documents	2
3. SYSTEM DESIGN DESCRIPTIONS	2
3.1 Purpose of System Design Descriptions	2
3.2 Application of System Design Descriptions	3
3.3 Content of System Design Descriptions	5
APPENDIX X1--EXAMPLE LIST OF PLANT SYSTEMS	16
APPENDIX X2--DETAILED OUTLINE FOR HEAT TRANSPORT SYSTEM.....	17
APPENDIX X3--DETAILED OUTLINE OF SECTIONS 1 AND 2 FOR REACTOR SYSTEM	22

January 1989

1

23

PREPARATION OF PLANT AND SYSTEM DESIGN DESCRIPTION DOCUMENTS

1. SCOPE

This standard prescribes the purpose, scope, organization, and content of plant design requirements (PDR) documents and system design descriptions (SDDs), to provide a unified approach to their preparation and use by a project as the principal means to establish the plant design requirements and to establish, describe, and control the individual system designs from conception and throughout the lifetime of the plant. The Electric Power Research Institute's *Advanced Light Water Reactor (LWR) Requirements Document* should be considered for LWR plants.

2. PLANT DESIGN REQUIREMENTS DOCUMENT

2.1 Purpose of Plant Design Requirements Document.

2.1.1 Scope and Use. The Plant Design Requirements (PDR) document defines the principal design requirements for a plant consistent with the design approach that has been adopted and in sufficient detail as to permit definition of, and allocation of requirements to, the systems which comprise the plant. The design requirements for those systems are defined in individual System Design Description (SDD) documents.

2.1.2 Use for Design Control. The PDR is established at the time that the program is defined and the conceptual approach has been selected. Its implementation on a program provides the basis for conceptual design studies of the plant's systems and major components, following through to preliminary and final design and ultimately to construction and operation of the plant.

It is important that the PDR clearly distinguish between design goals and design requirements such that it is apparent as to what features and characteristics are desirable versus those that must be provided.

2.2 Application of Plant Design Requirements.

2.2.1 Reactor Plants and Test Facilities. A PDR should be prepared to define the principal design criteria for a reactor plant or test facility such that all appropriate requirements are encompassed and the design process can proceed in a controlled and coordinated manner.

2.2.2 Responsibility for Preparation and Updating. The initial PDR and all subsequent changes are prepared by the design organization having responsibility for the overall design of the plant.

The PDR is maintained current with the design throughout the entire process of design evolution. No criteria in sub-tier documents should be in conflict with requirements in the PDR. Thus, any proposed changes to sub-tier documents that impact requirements in the PDR should identify any such conflict with the PDR and further should identify how the PDR should be revised to resolve the conflict. Proposed changes to the PDR should be accompanied by suitable technical justification, and the specific changes from the previously approved issue of the PDR should be clearly identified. When the approved changes to the PDR are issued, the latest set of changes should be readily identifiable.

2.3 Content of Plant Design Requirements Documents.

2.3.1 General. The PDR is a comprehensive design document meeting the purpose and application requirements contained in sections 2.1 and 2.2. PDR's should conform to the following basic outline which may be varied as necessary to adequately define a particular plant design:

Section 1	Scope
Section 2	Design Goals
Section 3	Economic Requirements
Section 4	Safety and Licensing Requirements
Section 5	Operation and Maintenance Requirements
Section 6	Plant System Design Requirements
Section 7	Quality Assurance Program Requirements
Section 8	External Interface Requirements
Section 9	Surveillance and Acceptance Test Requirements
Section 10	Decommissioning Requirements
Section 11	Fuel Reprocessing and Fabrication Requirements

The information contained in these sections should be limited to that which is necessary to define what the plant and its systems are required to do but not so detailed as to unduly or unnecessarily constrain the design process at the systems or lower tier levels. Specific information that should be contained in appropriate sections includes the following:

- Principal design requirements, criteria and guidelines
- Principal plant operating modes and related design parameters
- Overall plant cycle diagram and energy balance
- List of all systems, services, and facilities comprising the plant, and their corresponding SDD's (Appendix X1).
- Maintenance requirements and the systems and facilities needed for maintenance

3 SYSTEM DESIGN DESCRIPTIONS

3.1 Purpose of System Design Descriptions.

3.1.1 Scope and Use. The SDD presents the specific system design requirements and shows how these requirements are satisfied by the design. It includes the design requirements and a complete description of the system design features, such as flow path and performance, system operating and design parameters, system arrangement, component principal design features, and system operation and maintenance and quality requirements. The SDD provides the principal requirements for the components of which it is comprised. The description of system operation and maintenance in the SDD should be sufficiently explicit to confirm that the system can be operated to meet the design requirements; it also provides the basis for preparation of the plant and individual system operating procedures, maintenance procedures, test procedures, and casualty recovery procedures. The SDD describes the required supporting services which impose design functions and requirements on interfacing systems. The SDD also identifies the level of quality assurance, reliability critical items, codes, and standards to be applied to system and component design, construction, testing, and operation. The SDD also provides the design basis used for preparation of safety analysis reports and technical specifications.

While the SDD is periodically updated to describe the system design in progressively greater detail as the design evolves, it is not intended to be a historical document. Specifically, it does not trace the design alternatives that may have been considered and ultimately rejected in favor of the selected design, and it does not describe the development program that may be necessary to establish or verify the design. This essential information is provided by separate evaluations, trade studies, or program documents as appropriate to particular aspects of the design.

3.1.2 Use for Design Control. Implementation of the system design and related project activities, such as component procurement, should proceed only in conformance with approved SDDs.

3.2 Application of System Design Descriptions.

3.2.1 Reactor Plants and Test Facilities. A SDD is usually applied to a set of components that perform in a coordinated fashion to produce a coherent set of functions. A SDD should be prepared for each reactor plant system, with the exception of those utilities, structures, and site service or process systems which are not contiguous to the plant or are not a direct functional part of plant operation. Individual SDDs are recommended for the fluid systems, instrumentation and control systems, and electrical systems, the reactor vessel and head cavity, the reactor core and internals, the fuel handling system, and the reactor plant structures, including the containment design. Some SDDs for complex systems, such as reactor refueling or process monitoring and control, may be arranged in units corresponding to individual subsystems. In such cases, each unit shall be complete and prepared and submitted for approval separately.

Each project should reach agreement at the inception of the project design phase on the specific SDDs to be prepared. For this purpose, an index should be prepared to define the individual systems or grouping of subsystems to be covered by each SDD which will best meet the needs of the specific project (Appendix X1). The set of SDDs that define a plant should interface to cover the complete plant, and there should be no duplication of SDD coverage.

3.2.2 Responsibility for Preparation and Updating. SDDs should be prepared by the cognizant system design organization. Within that organization, the engineer assigned system design responsibility also should be responsible for the preparation and timely revision of the SDD for that system. Each project should have suitable procedures to assure that SDD approval and change control are effectively implemented according to the needs of the project.

SDD's should be prepared as early as feasible during the conceptual design as a means of enabling project participants to reach agreement on systems designs. As the design work progresses, more detailed design information should be provided by the system designer through timely updates to the SDDs. Effective control of the system design evolution is assisted by maintaining the SDD technically current. Proposed changes to a SDD should be accompanied by suitable technical justification, and the specific changes from the previously approved issue of the SDD should be clearly identified. When the approved changes to the SDD are issued, the locations of the latest set of changes should be suitably identified. Any system design change in an SDD should be reflected simultaneously in revision of all sections of the SDD to which it applies. Where a drawing is an integral part of the SDD, changes to that drawing should be processed as an SDD change.

It is important that the SDD present a complete and accurate description of the current status of the design. Therefore, particularly in drawings, any feature that is not recommended for approval because of existing uncertainties should be specifically identified by "hold" markings. In addition, the text of the SDD should clearly identify any descriptive information that is not applicable to the current design and is therefore not approved. Thus, the content of the SDD will progressively change throughout the system design process, and may change further as a result of construction, and acceptance testing. Following completion of the plant or facility design, construction, and acceptance testing, project assignments may require that the responsibility for maintaining SDDs current be transferred from the design organization to the cognizant engineering activity of the responsible plant operating organization to permit the SDD to be maintained current throughout its operating life.

3.3 Content of System Design Descriptions.

The information appearing in 3.3.1 through 3.3.9 applies to the scope and content of individual SDDs.

3.3.1 General. The SDD is a comprehensive design document that meets the purpose and application requirements discussed in 3.1 and 3.2. SDDs should conform to the following basic outline, although this format may be varied if necessary to adequately describe a particular system:

Summary

Section 1 Functions and Design Requirements

Section 2 Design Description

Section 3 Operation

Section 4 System Limitations, Set Points, and Precautions

Section 5 Casualty Events and Recovery Procedures

Section 6 Maintenance

Appendixes

The following subsections describe the content of each section of the SDD in more detail, using an outline developed for a reactor plant fluid system. However, the breakdown of subsections within each section of the SDD may be varied, depending on the particular type of system, in order to provide the most effective, complete, and logical presentation sequence of design information for that system.

An example of a typical outline for a sodium cooled reactor heat transport SDD is included in Appendix X2. For comparison and to illustrate the intended flexibility of the SDD format to accommodate different types of systems, an outline of Sections 1 and 2 for a sodium cooled reactor SDD is shown in Appendix X3. The latter SDD is organized somewhat differently from the former SDD to better describe the functional relationship of component and system elements which comprise the reactor system. This is accomplished by providing both system and component subsections in the design requirements and design description sections.

3.3.2 Summary. This section contains a brief summary of the functions and scope of the system, and is recommended to not exceed one page in length.

3.3.3 Functions and Design Requirements. This section contains the specific functions and design requirements to be satisfied by the system, however, the technical basis for these specific functions and requirements should be contained in supporting documents and not included in the SDD. Typical content of the various subsections of Section 1 is provided in the following discussion.

3.3.3.1 Functions. The individual functions of the system should be concisely and specifically stated, preferably in itemized format. This subsection is recommended to not exceed one page in length.

3.3.3.2 Design Requirements. The subsections which follow the system functions cover the system design requirements and should be combined into common groups such as process requirements, structural requirements, etc. The information should be specific, definitive, and concise; generalities and platitudes should be avoided (e.g., that the system is to be reliable or safe). A statement similar to that shown in Example 1 should be given rather than stating "activation of secondary sodium should be minimized":

Example 1.

Radioactivity in the secondary loops should be limited to 4×10^{-10} curies/cm³ (0.2 mrem/h) by shielding and layout directed toward minimizing the activation of secondary sodium.

As a minimum, the following subsections should be included, but the order of these subsections may be changed and other subsections may be added to completely characterize a particular system.

3.3.3.2.1 Process Requirements (or Operational Requirements). This subsection identifies items such as thermal power rating, operating temperatures, required operating modes, and requirements associated with unique functions of the system (e.g., decay heat removal for a reactor heat transport system).

3.3.3.2.2 Structural Requirements. This subsection provides such design requirements as design pressure and temperature, design thermal transients, seismic design requirements, load combinations, design for natural phenomena such as wind loads, basic materials for construction, etc. The specific values for such parameters should be included in the SDD, if necessary by reference where there is extensive information.

3.3.3.2.3 System Configuration and Essential Features. This subsection provides requirements for the unique features, arrangements, constraints, etc. that physically characterize the system configuration and its location. For a reactor heat transport system, as an example, this might include the fact that there should be three primary loops, each with an associated secondary loop; that individual loop isolating valves are to be provided; or that a hot leg (or cold leg) primary pump is to be provided.

3.3.3.2.4 Maintenance. This subsection identifies items such as access and space requirements for maintenance, shielding requirements and maximum allowable radiation levels in various areas.

3.3.3.2.5 Surveillance and In-Service Inspection. This subsection identifies items such as required access provisions and periodic inspection requirements for vessels and piping, and monitoring instrumentation for specific components, etc.

3.3.3.2.6 Instrumentation and Control. This subsection provides instrumentation and control requirements for system operation and control with identification of those specific access, redundancy, and calibration requirements or constraints that apply.

3.3.3.2.7 Interfacing Systems. This subsection provides a list of the functions and services that are to be provided by interfacing systems.

3.3.3.2.8 Quality Assurance. This subsection defines quality assurance requirements for design, construction, test, and operation of the system.

3.3.3.2.9 Codes and Standards. This subsection provides a list of codes and standards, to be applied to the system design, construction, and operation and to the individual components of that system.

3.3.3.2.10 Reliability Assurance. Reliability requirements should be included for systems, subsystems, and components which are identified as items critical to reliability. These requirements should be stated as specifically as practical for the particular system involved (e.g., 100 percent redundant capacity is to be provided for the emergency feedwater supply to the steam generators).

3.3.4 Design Description. This section contains a description of the system, its components, the system arrangement, and the system performance characteristics. The design description should be of sufficient depth to show how the design satisfies the system functions and design requirements. These items are described in more detail in the following subsections.

3.3.4.1 Summary. The summary gives a brief general description of the system and its configuration. The relationship of the system to the entire reactor plant or facility should be given, including plot plans, if appropriate.

3.3.4.2 Detailed System Description. This subsection contains a detailed discussion of the system design. The system flow paths for its various operating modes should be completely described to clearly show how the system functions and how it satisfies the design requirements. In this description, the operating and design data should be included, and reference should be made to the system process and

instrument drawing, and to other drawings needed for effective design description. A portion of the description of the flow path for a sodium heat transport loop follows as Example 2.

Example 2.

Heated sodium flows from the reactor outlet nozzle through the hot leg isolation valve to the suction of a centrifugal, free surface pump. Sodium from the pump discharge is circulated to the shell side of the intermediate heat exchanger where the heat is transferred to secondary sodium. From the intermediate heat exchanger outlet, the primary sodium flows through a check valve, a cold leg isolation valve and then to the reactor vessel inlet and through the reactor, thus completing the flow cycle. Sodium flow rate is measured by a permanent magnet flowmeter located downstream of the IHX outlet and is adjustable by variable-speed pump drives.

Specific design features and sizing parameters should be included in the text or by tabulations and drawings (e.g., the volume of coolant in individual loops should be included when describing a heat transport system). Examples 3 and 4 are excerpts from a sodium cooled reactor heat transport SDD further illustrate specific design information to be included.

Example 3.

The size of the 28-inch-diameter reactor outlet pipe has been governed mainly by the frictional pressure losses in this line which, with the frictional loss through the hot leg isolation valve, determines the drawdown (sodium level change) in the primary pump.

Example 4.

Table 2.1 shows the allocated pressure drop for the primary piping system consistent with the allocations for the components and the reactor and the maximum TDH limitation of 500 feet for the single stage pump.

3.3.4.3 System Performance Characteristics. This subsection provides the system performance characteristics under the various normal and infrequent operating modes and off-normal operating conditions. Typical items to be included in this section for a heat transport system are the system head-flow characteristic curves, natural circulation performance curves, and the system hydraulic profile. Example 5 is an excerpt from a sodium heat transport SDD and provides a discussion of system performance to minimize thermal transients to the reactor when the reactor is scrammed.

Example 5.

The main drives to the primary and secondary pumps and to the heat dump fans are immediately tripped to minimize the rate of change of system temperatures. The pumps coast down to pony motor operation as shown in Figures 2-5 and 2-6. Changeover from main to pony motor drive is automatic. The heat dump inlet air flow control vanes are also automatically closed to prevent excess heat rejection following the scram. The thermal transients at reactor core outlet are considerably attenuated before reaching the reactor vessel outlet piping by the mixing and heat capacity of the large volume of sodium in the reactor outlet plenum.

3.3.4.4 System Arrangement. This subsection provides a description of the system arrangement with reference to the included system drawings. The system piping arrangement and the location of operating stations should be described. Such features as the provision of inerted cells to house the system, the means and conditions of access, and any special provisions for maintenance access or inspection should be included.

3.3.4.5 Component Design Descriptions. This subsection provides a description of the individual system components. The design parameters and the principal design features of each component should be identified and component operation should be described. Simplified outline drawings of the components should be included in the text to facilitate understanding of the component design and operation. Detailed component drawings may be included in the list of references. Component data sheets may be included in this section or reference made to appendices for detailed information, such as valve, piping, and instrument lists.

Alignment, tolerances, and stackup of system components important to the system design should be identified in this subsection. Analyses and drawings that show how the system design satisfies these dimensional interfaces should be included as a reference or appendix to the SDD.

3.3.4.6 Instrumentation and Control. This subsection provides a description of the system instrumentation, controls, and interlocks. Such controls and interlocks as variable speed control of a primary coolant pump or primary pump trip on a reactor scram should be covered. The instrumentation associated with operation of the system should be defined, including the type, range, accuracy, set point, and location of sensor and instrument readout, with appropriate reference to the process and instrument drawing. Instrumentation readout and control location should be clearly identified (e.g., in the control room, or at specified local control stations). Instrument and control component performance information should be provided when it will aid in understanding the system design, operation, and maintenance. Reference

should be made to the instrumentation list which itemizes the instrument sensing elements, type, range, set point, whether indicating control or alarm, and readout location. This list is included as an appendix to the SDD as noted in 3.3.9.4

3.3.4.7 System Interfaces. This subsection of the SDD identifies and describes the system interfaces with other systems. These interfaces impose functional and physical requirements on each of these associated systems, and identification in the SDD facilitates control of these system interfaces. This section also should indicate how the system design satisfies the system interfaces that impose functional requirements on the subject system. The SDDs may have detailed lists of system interfaces in tabular form, and these lists may be included in an appendix.

3.3.5 Operation. This section includes various subsections which provide outlines for all system operating procedures. These subsections should provide sufficient detail to confirm that the design provides for the required modes of system operation and also should be a sufficient basis for preparation of detailed operating procedures. There should be a direct relationship between the individual operating procedures outlined in the SDD and the corresponding detailed operating procedures.

Each operating procedure outlined in the SDD should be sufficiently detailed to clearly identify the individual flow paths used, the instruments used to control these operations, and the proper sequence of steps to accomplish the operations. The operating stations where the procedures are performed also should be identified.

Each operating procedure outline should be written in an itemized (step-by-step) format. Reference should be made to the system schematic diagram (component name and number) and to such tabular summaries and graphs of operating conditions as may be required.

Typical groupings of operating procedure outlines for a fluid system are provided below; however, these groupings may be altered, and others that may be unique to a particular system should be added to provide complete coverage of the operating procedures for that system.

3.3.5.1 Initial Fill. This outlines the prerequisites and those procedures required to prepare and initially fill the system. In the case of an auxiliary or service system, procedures for its use in the initial fill of the main heat transport system should be included.

3.3.5.2 Startup. This outlines the operations necessary to bring the system from the filled condition to a normal operating condition. Depending upon the particular system, several procedures generally will be necessary in this group, including system heatup and nuclear startup for the principal reactor plant systems.

3.3.5.3 Normal Operation. This outlines the procedures associated with normal steady-state, full-power, and reduced-power operation and design transient or maneuvering conditions. Operating condition envelopes showing the allowable operating ranges and appropriate limitations should be included.

3.3.5.4 Shutdown. This outlines the procedures for system shutdown, including shutdown to hot standby, shutdown and cooldown, establishment of refueling conditions, and the maintenance of elevated or reduced temperature shutdown conditions as appropriate to the specific design requirements.

3.3.5.5 Draining. This covers operations for draining the entire fluid system and portions of the system. The end condition of draining and constraints on operation should be specified.

3.3.5.6 Refilling. This outlines the steps for refilling a fully or partially drained fluid system. In the case of an auxiliary or service system, procedures for the use of this system in refilling the main heat transport system should be included.

3.3.5.7 Infrequent Operations. This covers those operations which are used infrequently or under unique conditions, such as reactor plant operation with an isolated main heat transport loop.

3.3.6 System Limitations, Set Points, and Precautions. This section of the SDD should provide a consolidated list of system limitations, set points, and precautions that will provide a better understanding of system operation, and response to casualties, and maintenance which are described in later sections of the SDD. Under operating limits, the SDD should include in summary form the high and low limits for all controlled variables. The dead band and overshoot for both manual and automatic control also should be included. Appropriate limits, such as relief valve settings, maximum liquid level, etc., should be identified. The set points or nominal settings for automatic and manual controls for all anticipated operating modes should be provided.

This section should provide precautions to be observed by operations and maintenance personnel. Design precautions such as interlocks and alarms also should be included. The system status checks needed for changing set points should be defined. Where appropriate, detailed tabular lists may be included in an appendix of the SDD and referenced in this section.

3.3.7 Casualty Events and Recovery Procedures. This section identifies the possible casualty events that could affect the system and the protection provided against those casualties by the system design. It also outlines the system design features and recovery procedures which will mitigate the consequences of the casualties and restore the system and plant to a known, confirmed safe condition.

3.3.7.1 Casualty Events. A casualty event is defined as an abnormal system or plant condition which affects the safety, integrity, or proper functional operation of the system or plant; could produce system or plant degradation or affect personnel safety; and which requires action to restore the system or plant to a known, confirmed safe condition or to mitigate the consequences of the casualty event.

In this subsection, the casualty events which can be experienced by the system should be identified. Some examples of casualty events to be included are:

1. Loss of cooling.
2. System leakage.
3. High radiation level.
4. Complete loss of electrical power.
5. Fires and chemical reactions.
6. Scram.
7. Abnormal chemistry.
8. Missile damage.
9. System or control malfunctions.

3.3.7.2 Design Features to Mitigate Effects of Casualty Events. This subsection should outline briefly the design features which provide protection and mitigate the effects of the casualty events. The instrumentation which discloses the casualty event and its location should be identified. Where appropriate, the resultant system performance characteristics and parameters under the casualty conditions should be provided.

3.3.7.3 Recovery Procedures. This subsection outlines the recovery procedures performed by plant operating personnel to restore the system or plant to a known, safe condition, prevent propagation of and mitigate the effects of a casualty event, and assure personnel safety. The specific instrument indications, alarms, or both, which signal the casualty event should be stated, and the applicable recovery procedure should be outlined. Any follow-up and diagnostic action necessary to identify the cause of the casualty and the required permanent corrective action also should be specified.

3.3.8 Maintenance. This section defines the maintenance philosophy; outlines the procedures for corrective maintenance, preventive maintenance, and in-service inspection and surveillance; and identifies interfacing systems needed to support maintenance operations, as described in more detail in the following paragraphs. This section provides the basis for preparation of detailed maintenance procedures.

3.3.8.1 Maintenance Approach. This subsection defines the specific design approach that will be followed for system maintenance. Specific design philosophy taken from the SDD for a heat transport system is shown in Example 6.

Example 6

Routine maintenance activities must be performed during reactor outages. The system design will consider maintenance activities in the following order of preference:

- adjust or repair in place.
- repair components by contact maintenance to the extent permissible (consistent with personnel exposure and safety needs).
- replace component with spare unit (and then repair and requalify the disabled unit).
- remove component for decontamination, repair or both by contact maintenance and replace same component.
- remote replacement of components.
- repair components in place by remote maintenance (using manipulators and other remote-operated tools).

3.3.8.2 Corrective Maintenance. This subsection outlines the procedures for placing the system in a condition suitable for corrective maintenance or replacement of the individual system components. It also identifies those special tools and equipment needed to permit performance of the maintenance operation, to maintain system cleanliness, and to maintain other specified conditions on the system and plant during the maintenance period. It references, but does not repeat, those system operating procedures in Section 3 of the SDD which are used to obtain the required system condition (such as system drainage). The design requirements that are imposed on interfacing systems to enhance maintenance capability should be defined. If another system is used for transporting a component outside the plant for repair, the appropriate reference to the SDD for that system should be included.

Individual corrective maintenance procedures should be outlined for each component of the system. This may be provided in tabular form if convenient. Reference should be made to the component operation and maintenance manual for those detailed steps and procedures dealing with maintenance within that component, such that there is no duplication of coverage.

3.3.8.3 Preventive Maintenance. An outline of preventive maintenance procedures for the system and each component in the system should be included. However, reference should be made to the appropriate component operation and maintenance manual for those detailed steps involving work within that component, such that there is no duplication of coverage.

3.3.8.4 In-Service Inspection. The conditions for performing inspection of the system during operation or shutdown should be

defined. The system design features to accomplish the required inspections should be identified. Specific equipment and access needed for the inspections also should be identified.

3.3.8.5 Surveillance. The necessary instrumentation for surveillance of the system and its components during the lifetime of the plant should be identified in this section.

3.3.9 Appendixes. The appendices may include, system drawings, parameter lists, equipment lists, and other essential material but which is not convenient to include in the previous text of the SDD.

The following are examples of typical materials that may be included as appendices:

3.3.9.1 References. Each SDD should have two reference lists. The first list should include references to that information which is an integral part of the SDD, such as design thermal transient data or seismic design data. The second list should cover those supporting analyses, evaluations, trade studies, etc., which provide background information but are not essential to define the selected design.

3.3.9.2 Parameters List. This includes the complete system and component operating and design parameters (pressure, temperature, flow, volume, size, capacity, material, etc.), and clearly distinguishes between the nominal operating and design parameters.

3.3.9.3 Typical Drawings. The following are typical drawings for inclusion in appendices.

a. Process and Instrument Drawings. These are included in all fluid system descriptions and should show schematic representation of the system piping and instrumentation.

b. Schematic Drawings and Block Diagrams. These are included in SDDs for instrumentation and control systems and electrical systems.

c. Hydraulic Profile Drawings. These are included where specification of the relative elevations of system components and piping is necessary to satisfy the system design or operating requirements.

d. Arrangement or Equipment Location Drawings. These are included where necessary to show the location and configuration of system components within the facility.

e. Piping Drawings. These drawings, preferably isometric drawings, are included for the principal fluid systems.

f. Other Drawings. A list of drawings should be provided which are not included in the SDD but which are important to the system and related to its functions.

3.3.9.4 Instrument List. This list includes each sensing element, type, range, accuracy, set point, function (whether indicating, control, alarm, or combination of these), and where indicated (i.e., what panel).

3.3.9.5 Valve List. This list includes individual valve function, size, type, pressure and temperature rating, American Society of Mechanical Engineers' Code classification, operator requirement, and specification number.

3.3.9.6 Equipment List. This includes component name and number, major design parameters (e.g., capacity), and specification number.

APPENDIX - NONMANDATORY

X1. EXAMPLE LIST OF PLANT SYSTEMS

<u>SDD No.</u>	<u>Description</u>
11	Power Transmission System
12	Building Electrical Power System
15	Communications System
19	Site Work
20	Balance of Plant (BOP) Buildings
21	Reactor Support Buildings
22	Compressed Air System
23	Chilled Water System
24	Radioactive Waste System
25A	Nuclear Island (NI) Heating, Ventilating, and Air Conditioning (HVAC) System
25B	Balance of Plant (BOP) Heating, Ventilating, and Air Conditioning (HVAC) System
26	Plant Fire Protection System
27	Reactor Containment System
28	Recirculating Gas Cooling System
31	Reactor System
32	Reactor Enclosure System
39	Fuel Cycle Facility
41	Reactor Refueling System
44	Nuclear Island Maintenance and Inspection
45	Balance of Plant (BOP) Maintenance System
51A	Primary Heat Transport System
51B	Intermediate Heat Transport System
53	Steam Generator System
56	Heat Transport Instrumentation System
66	Liquid Metal Leak Detection System
68	Liquid Metal Piping and Equipment Heating and Insulation System
71	Feedwater and Condensate System
72	Main and Auxiliary Steam System
73	Heat Rejection System
74	Water Source System
75A	Plant Service Water System
75B	Treated Water System
76	Waste Water Treatment System
81	Liquid Metal Auxiliaries System
82	Inert Gas Receiving and Processing System
85	Impurity Monitoring and Analysis System
90	Data Handling and Transmission System
92	Reactor Instrumentation System
94	Failed Fuel Element Detection and Location System
96A	Flux Monitoring System
96B	Radiation Monitoring System
99	Plant Protection System

APPENDIX - NONMANDATORY

X2. DETAILED OUTLINE FOR HEAT TRANSPORT SYSTEM

1. FUNCTION AND DESIGN REQUIREMENTS

- 1.1 Functions
- 1.2 Process Requirements
- 1.3 Structural Requirements
 - 1.3.1 Steady State
 - 1.3.2 Thermal Transients
 - 1.3.3 Seismic Design Requirements
 - 1.3.4 Hypothetical Core Disruptive Accident
 - 1.3.5 Natural Phenomena
 - 1.3.6 Construction Material
- 1.4 System Configuration and Essential Features
- 1.5 Decay Heat Removal
- 1.6 Design Life
- 1.7 Design Safety Requirements
- 1.8 Maintenance
- 1.9 Surveillance and In-Service Inspection
- 1.10 Heat Transport System (HTS) Instrumentation and Controls
- 1.11 Interfacing Fluid Systems, Electrical Systems and Structures
- 1.12 Quality Assurance
- 1.13 Codes and Standards

2. DESIGN DESCRIPTION

- 2.1 Summary Description
- 2.2 Primary Sodium Loops
- 2.3 Secondary Sodium Loops
- 2.4 System Performance
- 2.5 Off-Normal Decay Heat Removal
 - 2.5.1 Leak Within a Guard Vessel
 - 2.5.2 Leakage from the Elevated Piping
 - 2.5.3 Natural Circulation
- 2.6 Detailed Primary Sodium Loop Description
 - 2.6.1 Primary Loop Arrangement
 - 2.6.2 Primary Coolant Pump
 - 2.6.3 Intermediate Heat Exchanger (IHX)
 - 2.6.4 Isolation Valves
 - 2.6.5 Check Valves
 - 2.6.6 Primary Loop Flowmeter
 - 2.6.7 Guard Vessels
 - 2.6.8 Primary Loop Strainer
- 2.7 Detailed Secondary Sodium Loop Description
 - 2.7.1 Secondary Loop Arrangement
 - 2.7.2 Secondary Coolant Pump
 - 2.7.3 Dump Heat Exchanger (DHX)
 - 2.7.4 Secondary Loop Expansion Tank

- 2.7.5 Secondary Loop Valves
- 2.7.6 Secondary Loop Flowmeters
- 2.7.7 Secondary Loop Strainers
- 2.8 Preheating
- 2.9 Insulation
- 2.10 Piping and Penetrations
 - 2.10.1 Primary Loop Piping
 - 2.10.2 Secondary Loop Piping
 - 2.10.3 Piping Penetrations
- 2.11 Leak Detection
- 2.12 Fire Protection
- 2.13 Sodium Auxiliary Requirements
 - 2.13.1 Sodium Makeup and Level Control
 - 2.13.2 Sodium Filling and Draining
- 2.14 Inert Gas Requirements
 - 2.14.1 Cover Gas Pressure Control
 - 2.14.2 Cover Gas Feed and Vent for Filling and Draining
- 2.15 Instrumentation and Control
 - 2.15.1 System Requirements
 - 2.15.2 Component Requirements
- 2.16 Interfacing Systems
 - 2.16.1 Service to be Provided by Others
 - 2.16.2 Principal Interfacing Requirements for Decay Heat Removal

3. OPERATION

- 3.1 Introduction
 - 3.1.1 Operating Design Basis
 - 3.1.2 Operating Systems
 - 3.1.3 Operator Functions
- 3.2 Normal Steady State Operation with Three Loops
 - 3.2.1 Full Power
 - 3.2.2 Part Load
 - 3.2.3 Hot Standby
 - 3.2.4 Refueling
- 3.3 Normal Non-Steady State Operation with Three HTS Loops
 - 3.3.1 Transition from Refueling to Hot Standby Temperatures
 - 3.3.2 Power Ascent from Hot Standby (Normal Startup)
 - 3.3.3 Power Reduction to Part Load or Hot Standby (Normal Shutdown)
 - 3.3.4 Scram
 - 3.3.5 Temperature Reduction to Refueling Condition
 - 3.3.6 Restarting HTS Pumps Following a Scram
- 3.4 Infrequent Operation
 - 3.4.1 Preoperation Testing
 - 3.4.2 System and Component Requalification
 - 3.4.3 Activating and Deactivating a DHX Module

- 3.5 Preheating Operation
 - 3.6 Two-Loop Operation
 - 3.6.1 Isolated Loop - Primary and Secondary Fill
 - 3.6.2 Isolated Loop - Secondary Loop Partially Drained
 - 3.6.3 Isolated Loop - Primary Loop Drained
 - 3.6.4 Non-Isolated Primary Loop
 - 3.7 Primary Fill and Drain Operation
 - 3.7.1 Primary System Fill
 - 3.7.2 Normal Isolated Loop Fill
 - 3.7.3 Normal Unisolated-Loop Fill
 - 3.7.4 Fill from Primary Overflow Tank
 - 3.7.5 Reactor Vessel Fill
 - 3.7.6 Normal Isolated Loop Drain
 - 3.7.7 Normal Unisolated Loop Drain
 - 3.7.8 Drain to Primary Overflow Tank
 - 3.7.9 Reactor Vessel Drain
 - 3.7.10 Rapid Drain
 - 3.7.11 Draining and Filling of Major Primary HTS Components
 - 3.7.12 Guard Vessel Drain
 - 3.8 Secondary Fill and Drain Operation
 - 3.8.1 Inerting the Secondary Components and Piping
 - 3.8.2 Secondary Loop Fill (Western Loop)
 - 3.8.3 Filling the East or South Secondary Loop
 - 3.8.4 Degassing the Secondary Loop
 - 3.8.5 Venting the Fill/Drain Lines
 - 3.8.6 Fill of a Single DHX Module
 - 3.8.7 Drain of the Secondary Loop
 - 3.8.8 Drain of a Single DXH Module
 - 3.8.9 Rapid Drain of the Secondary Loop
 - 3.8.10 Rapid Drain of a DHX Module
 - 3.8.11 Rapid Drain of the Secondary Loop (Excluding the DHXs)
 - 3.9 Natural Circulation
4. SYSTEMS LIMITATIONS, SET POINTS, AND PRECAUTIONS
- 4.1 Operating Limits and Set Points
 - 4.2 Precautions
5. CASUALTY EVENTS AND RECOVERY PROCEDURES
- 5.1 Casualty Events
 - 5.2 Design Features to Mitigate Casualty Events
 - 5.3 Radiation Hazards to Personnel and Equipment
 - 5.4 Gas Entrainment
 - 5.5 Fire and Chemical Reaction
 - 5.6 Missiles
 - 5.7 Effect of Natural Elements
 - 5.8 System Malfunctions

- 5.8.1 Reduction in Reactor Cooling
- 5.8.2 Increase in Reactor Coolant
- 5.8.3 Sodium Boundary Leak
- 5.8.4 Internal Leak in an IHX
- 5.8.5 Blockage or Failure of the IHX Vent Line
- 5.8.6 Abnormal Chemistry
- 5.8.7 Sodium Freezing
- 5.9 Component Malfunctions
 - 5.9.1 Primary Pump
 - 5.9.2 IHX
 - 5.9.3 Isolation Valves
 - 5.9.4 Check Valve
 - 5.9.5 Primary Flowmeter
 - 5.9.6 Primary Piping Penetrations
 - 5.9.7 Secondary Pump
 - 5.9.8 DHX
 - 5.9.9 Secondary Valve
 - 5.9.10 Expansion Tank
 - 5.9.11 Secondary Flowmeter
- 5.10 Recovery Procedures

6. MAINTENANCE

- 6.1 HTS Maintenance Philosophy
- 6.2 Personnel Exposure to Radiation
 - 6.2.1 Occupational Exposure Limits
 - 6.2.2 Sources
 - 6.2.3 Radiological Zone Classifications
- 6.3 Corrective Maintenance
 - 6.3.1 IHX
 - 6.3.2 Primary Pump
 - 6.3.3 Primary Isolation Valves
 - 6.3.4 Primary Check Valve
 - 6.3.5 Primary Flowmeter
 - 6.3.6 Secondary Pump
 - 6.3.7 DHX
 - 6.3.8 Secondary Valves
 - 6.3.9 Primary Sodium Boundary
 - 6.3.10 Secondary Sodium Boundary in Containment
 - 6.3.11 Secondary Sodium Boundary Ex-Containment
 - 6.3.12 Primary Loop Strainer
 - 6.3.13 Secondary Loop Strainer
 - 6.3.14 Secondary Magnet Flowmeter
 - 6.3.15 Secondary Venturi Flowmeter
 - 6.3.16 Secondary Loop Expansion Tank
 - 6.3.17 Pipe Hangers, Supports, and Snubbers
 - 6.3.18 Piping Penetrations
 - 6.3.19 IHX Bypass Flowmeter
 - 6.3.20 Preheaters
 - 6.3.21 Leak Detectors
 - 6.3.22 Instrumentation

- 6.4 Preventive Maintenance
- 6.5 In-Service Inspection
 - 6.5.1 HTS Sodium Boundary
 - 6.5.2 HTS Cells and Pipeways
- 6.6 Surveillance

APPENDIXES

- A. REFERENCES
- B. DRAWINGS
- C. PARAMETER LIST
- D. EQUIPMENT LIST
- E. LIST OF SDDs
- F. INTERFACING SYSTEMS
- G. LEAK DETECTORS
- H. SEISMIC RESPONSE CURVES
- I. INSULATION DATA
- J. HTS INSTRUMENTATION

APPENDIX - NONMANDATORY

X3. DETAILED OUTLINE OF SECTIONS 1 AND 2 FOR REACTOR SYSTEM

1. FUNCTIONS AND DESIGN REQUIREMENTS

- 1.1 Functions
- 1.2 System Design Requirements
 - 1.2.1 Configuration
 - 1.2.2 Reactor Performance
 - 1.2.3 Test Capability
 - 1.2.4 Thermal/Hydraulic/Shielding
 - 1.2.5 Mechanical and Materials
 - 1.2.6 Design Load Conditions
 - 1.2.7 Instrumentation and Control
 - 1.2.8 Interfaces
 - 1.2.9 Codes and Standards
 - 1.2.10 Surveillance and In-Service Inspection
 - 1.2.11 Quality Assurance
 - 1.2.12 Reliability Assurance
 - 1.2.13 Initial Installation
- 1.3 Component Design Requirements
 - 1.3.1 Components* (other components would follow as 1.3.2, 1.3.3, etc.)
 - 1.3.1.1 Configuration
 - 1.3.1.2 Performance
 - 1.3.1.3 Installation
 - 1.3.1.4 Thermal/Hydraulic/Shielding
 - 1.3.1.5 Mechanical and Materials
 - 1.3.1.6 Design Life, Load Conditions, and Fluence Limits
 - 1.3.1.7 Safety
 - 1.3.1.8 Instrumentation
 - 1.3.1.9 Interfaces
 - 1.3.1.10 Operability
 - 1.3.1.11 Maintainability
 - 1.3.1.12 Codes and Standards
 - 1.3.1.13 Surveillance and In-Service Inspection
 - 1.3.1.14 Quality Assurance
 - 1.3.1.15 Reliability Assurance
- 1.4 System Safety Requirements
 - 1.4.1 Quality Standards
 - 1.4.2 Reliability Assurance
 - 1.4.3 Performance Standards

*Components logically fitting into the reactor system are fuel assembly, nuclear control system, reflectors, restraint mechanism, shielding, and core support structure, and depending on the design, in-core instrumentation (mechanical) may also be included.

- 1.4.4 Records
- 1.4.5 Reactor Core Design
- 1.4.6 Power Oscillations
- 1.4.7 Power Coefficient
- 1.4.8 Instrumentation and Control
- 1.4.9 Reactivity Control
- 1.4.10 Off-Normal Decay Heat Removal
- 1.4.11 Fuel and Waste Storage
- 1.4.12 Release of Radioactivity
- 1.4.13 Hypothetical Core Disruptive Accident
- 1.4.14 Cooling of In-Core Assemblies During Handling
- 1.5 System Maintenance Requirements
 - 1.5.1 Design to Minimize Maintenance
 - 1.5.2 Requirements for Special Tools and Equipment
 - 1.5.3 Development of Maintenance Procedures

2. DESIGN DESCRIPTION

- 2.1 Summary Description
- 2.2 System Description
 - 2.2.1 Configuration
 - 2.2.2 Reactor Performance
 - 2.2.3 Test Capability
 - 2.2.4 Thermal/Hydraulic/Shielding
 - 2.2.5 Mechanical and Materials
 - 2.2.6 Design Load Conditions
 - 2.2.7 Instrumentation and Control
 - 2.2.8 Interfaces
 - 2.2.9 Codes and Standards
 - 2.2.10 Surveillance and In-Service Inspection
 - 2.2.11 Quality Assurance
 - 2.2.12 Reliability Assurance
 - 2.2.13 Initial Installation
- 2.3 Component Design Description
 - 2.3.1 Component (other components would follow as 2.3.2, 2.3.3, etc.)
 - 2.3.1.1 Configuration
 - 2.3.1.2 Performance
 - 2.3.1.3 Installation
 - 2.3.1.4 Thermal/Hydraulic/Shielding
 - 2.3.1.5 Mechanical and Materials
 - 2.3.1.6 Design Life, Load Conditions, and Fluence Limits
 - 2.3.1.7 Safety
 - 2.3.1.8 Instrumentation
 - 2.3.1.9 Interfaces
 - 2.3.1.10 Operability
 - 2.3.1.11 Maintainability
 - 2.3.1.12 Codes and Standards
 - 2.3.1.13 Surveillance and In-Service Inspection
 - 2.3.1.14 Quality Assurance

END

**DATE
FILMED**

5/04/93