NRTSC
Technology
On Time
On Target

WSRC-TR--91-427

DE92 014361

**NUCLEAR REACTOR TECHNOLOGY
AND SCIENTIFIC COMPUTATIONS**

KEY WORDS: Safety
Rod
Boron Carbide
Reactor
Shutdown
NTG

RETENTION PERIOD: Lifetime

**SUBSTITUTE SAFETY RODS--PHYSICS DESIGN
AND NTG CALIBRATION (U)**

By

N. P. Baumann

ISSUED: July 1991

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

MASTER

SAVANNAH RIVER LABORATORY, AIKEN, SC 29808

Westinghouse Savannah River Company

Prepared for the U. S. Department of Energy under Contract DE-AC0989SR18035

DOCUMENT: **WSRC-TR-91-427**

TITLE: Substitute Safety Rods--Physics Design and NTG Calibration (U)

TASK: **QA Task No. 91-003-1**

APPROVALS

M. R. Buckner

M. R. BUCKNER, MANAGER
SCIENTIFIC COMPUTATIONS SECTION

DATE: 8/13/91

T. G. Williamson
T. G. WILLIAMSON, TECHNICAL REVIEWER

DATE: 8/13/91

INTRODUCTION

Under certain assumed accident conditions, an SRS reactor may lose most of its bulk moderator while maintaining flow to fuel assemblies. If this occurs immediately after operation at power, components normally dependent on convective heat transfer to the moderator will heat up with the possibility of melting that component. One component at risk is the safety rod. Tests have shown that the current cadmium safety rod, which contains aluminum as well as cadmium, can fail at temperatures only slightly in excess of 500 deg C. Computations indicate that such temperatures can be reached with operating powers well below the 50% power limit now imposed by other accident scenarios. Safety rod melting would thus establish a new lower operating limit (References 1 and 2). A substitute safety rod that could tolerate much higher temperatures would eliminate this limit. This memorandum details the physics characteristics of a suitable replacement rod.

SUMMARY

The design given here was judged best of various proposed designs, consistent with the restraint of a very short time for installation. The design is simple and can be implemented with technology and materials that are both proven and readily available. For the long term (5 years), consideration is being given to development of an even better design.

Design considerations require that a substitute rod match the current rod as closely as practical in externally observable mechanical properties. In addition it is required that the reactivity worth for shutdown purposes slightly exceed that of the current rods throughout the cycle. The following design meets these requirements.

- * External sheath of 304 or 304-L stainless steel with an OD of 0.940 inch and a nominal ID of 0.836 inch.
- * Active core material of right cylindrical pellets of sintered boron carbide.
 - # Length 1.00 inch
 - # Diameter 0.795 inch
 - # Density 71% of theoretical (1.79 g/cc)
- * Core filler material of right cylindrical pellets of 304 or 304-L stainless steel.
 - # Length 0.625 inch
 - # Diameter 0.795 inch

Boron carbide and stainless steel pellets are stacked alternately in the sheath in what is termed a "striped" design. This combination matches the weight per unit length of the cadmium rods and gives a near optimum reactivity worth. The estimated worth in the Mark 22 lattice, relative to cadmium rods, is 1.316 at start of cycle and about 1.20 at end of cycle.

As part of the Quality Assurance for the nuclear properties of these rods, supporting computations of interstitial rod worths in the Mark 22 lattice were performed at Argonne National Laboratory (ANL). These gave good agreement with the SRL results for relative rod worths, the quantity required for this study. Their Monte Carlo results, however, indicated lower absolute worths for all rods. This discrepancy is discussed further in Appendix C.

Computations are provided which predict the response of the 320-M NTG to insertion of the striped rods, relative to Li-Al control rods and the cadmium rods. An NTG calibration procedure and interim acceptance criteria are proposed.

DISCUSSION

Reactivity Worth in Mark22 Lattices

The choice of alternating pellets of boron carbide and stainless steel provides great simplicity and convenience in fabrication and assembly. The same cannot be said for computation of reactivity worth. Such a rod in a Mk22 supercell gives a geometrical complexity beyond that of any single analytical neutron transport code at SRL. Monte Carlo codes have this capability but are very cumbersome to set up and require inordinately long running times. Because of statistical uncertainties in Monte Carlo computations, differential rod worths such as those of this report are notoriously difficult to derive. Nonetheless, Monte Carlo confirmatory computations have been made under contract at Argonne National Laboratory.

SRL has developed its own integral transport code, GLASS, which is tailored to the the special problems of SRP heavy water lattices (Reference 3). It handles the complex geometries of tubes and rods very well but only in two dimensions, i.e., axial variations are not allowed. SRL also has a two-dimensional Sn transport code, TWOTRAN, which in R-Z geometry can correctly model the vertical striping of a central rod (References 4 and 5). To compute the worth of the striped rods in the Mark 22 lattice, the procedure used was to couple the two codes in such a way as to reduce overall error. GLASS cases used the 21 cell SMALCELL lattice pattern developed by W. E. Graves specifically for evaluating uniform safety rods.

A detailed description of this lattice pattern is given in Reference 1. Typical GLASS input for the Mark 22 lattice is given in Appendix A. The following cases were run in GLASS.

1. Reference, no safety rods
2. Cadmium rod using each of two available cadmium cross section sets (sum of individual cadmium isotopes, taken as reference, and elemental cadmium)
3. Full B4C rods, no stainless steel (SS)
4. Full SS rods, no B4C
5. Mixed B4C/SS rods, homogenized densities

The reactivities and rod worths determined from these runs are given in Table I. The GLASS runs were also used to generate few-group (STD10GRP) macroscopic records which were written to a JOSHUA User Data Set that could be read by TWOTRAN. These cross sections included:

1. Supercell average (Case 1 above)
2. Bulk D2O moderator
3. Aluminum
4. Air
5. Stainless steel (iron equivalent)
6. B4C (no stainless steel)
7. B4C/SS homogenized mix

The TWOTRAN model consisted of a central rod with D2O annulus out to a radius of 2 cm, and supercell average (homogenized Mk22) out to a radius of 24.7 cm. The axial direction consisted of two zones with a steel-to-carbide thickness ratio of 0.625. The central rod, including the sheath, had a radius of 1.1938 cm (0.940 inch D). Reflecting boundary conditions were imposed at both radial boundaries; repeating boundary conditions at top and bottom. Except for the cadmium rod, all cases computed by GLASS were duplicated with TWOTRAN. The results are included in Table II.

Rod worths are normally expressed in deltaK (or deltaRHO) units where deltaK is the difference in K for the no-rod, or D2O, case and the K for the rodged case. For this report, the worth in these units is of less interest than how the worth compares to that of the cadmium rod it is to replace. Consequently, worths are expressed as the ratios of individual rod worths in deltaK units to that of the cadmium rod.

Although GLASS cannot calculate the striped rod, it can calculate three related cases of interest; B4C pellets alone, steel pellets alone, and a homogeneous mixture of B4C and steel. The latter value is of special importance because it is the closest approximation to the striped rod that GLASS is capable of evaluating.

Worths computed by TWOTRAN differ slightly from those computed by GLASS for the various uniform rod cases. GLASS values are judged most accurate. In order to maintain a close match to the GLASS scale, the TWOTRAN relative rod worths are normalized so that the TWOTRAN worth for the B4C/SS homogenized rod is 1.498, the value computed by GLASS. With this normalization, the TWOTRAN worths for uniform rods of B4C and SS also compare well with those from GLASS (See Table III). This close agreement supports the adequacy of the normalization for establishing the worth of the striped rod.

For the striped rod, a lower worth limit of 1.114 and an upper limit of 1.498 can be set from the GLASS computations alone. The upper limit is the value computed for the homogeneous mix of B4C and SS. The lower worth is set by the volume weighted average of the worth of the full strength B4C rod and the SS rod. These cases represent extremes in the amount of neutron self-shielding experienced by the specified inventory of boron atoms. The actual (normalized) worth computed by TWOTRAN was 1.316, about halfway between the two limits. To demonstrate that the interpolated value is reasonable, additional TWOTRAN cases were run with various assumed B4C pellet lengths, keeping the same 0.625 steel-to-boron length ratio, i.e., the axial average concentration of atoms was maintained. The results are included in Table II and are shown graphically in Figure 1. The validity of the striped rod computations is supported by the fact that, over the range of the computations, the striped rod results tend cleanly toward the proper limit at both extremes (Numerical convergence problems in TWOTRAN at very small and very large spacings prevented analysis very close to the end points).

Supporting computations were performed at Argonne National Laboratory (ANL) under contract (See attachment). Part of the ANL program was to replicate the SRL GLASS cases using the ANL version of GLASS. The second part of the program was to perform Monte Carlo computations using VIM. VIM is a continuous energy, generalized geometry Monte

Carlo code. The comparison to the SRL results is shown in Table III. The GLASS intercomparison is identical to three digits for the SRL case using the cross sections for mixed cadmium isotopes. The agreement with the VIM results is well within the listed one-sigma uncertainty.

NTG Calibration

The thermal neutron flux response of the NTG (Nuclear Test Gage) is expressed in Index units (I). The index is the fractional change in neutron flux from insertion of a test component, with the flux level for the empty test port as reference. A calibration curve is established for a given component in terms of Index versus isotopic content of the active component. It is derived from K values computed by a code such as GLASS. Two normalizations are required. The first normalization is to scale the computed K values so that the value for the empty test port is the nominal 0.859 value. A trial index is then computed from the normalized K's assuming point-reactor kinetics:

$$1. \text{ Trial Index} = ((1 - 0.859)/(1 - K)) - 1$$

For the final normalization, the preliminary indices are multiplied by a scale factor so that the index matches that measured for a known standard. For Table IV the normalization is at a Li-6 content of 2.00 g/ft which is assigned a measured value of -0.1199 (Reference 7). The GLASS input data for Table IV is detailed in Appendix B.

As with the Mark 22 lattice, the GLASS model cannot calculate the striped rod for the NTG model. In the GLASS column of Table IV, the worth of the striped rod is derived from the computed value of the worth of the B4C/SS by assuming that the ratio of indices of the striped rod to that of the B4C/SS rod is equal to the ratio of the same rod worths in Table II. A TWOTRAN model was set up using the geometry of Appendix B in order to take the striping explicitly into account. Radii were the same as for the GLASS model. Few-group cross sections were generated by three different methods. Ten-group GLASS cross sections were derived by the same procedure that was used for rod worths in the Mark 22 lattice. The KOKO version of TWOTRAN (Reference 5) utilizes Hansen-Roach 16-group cross sections. Attempts to use the KOKO version of TWOTRAN for the NTG model were unsuccessful because the built-in zone allocation in KOKO would not permit convergence. The KOKO version can however generate cross section sets which can be read by the stand-alone TWOTRAN. The stand-alone version permits full user control of zone allocation as well as permitting a more generalized geometry. Two sets of TWOTRAN cross sections were generated by KOKO TWOTRAN and written and copied to a JOSHUA User Data Set. The two sets consisted of the full 16 groups and a collapsed 3 group set. These were then used in the stand-alone version.

The results are listed in Table IV. The K values are those from the calculations; the indices, I, are all negative. In this table, where indices are indicated without associated K values, indices are inferred from the GLASS values and the relation of the indices where computations overlap. No great significance should be given to these inferred values: they are given only to plot the approximate calibration curves shown in Figure 2. These curves also give representative measured indices from earlier control rod calibrations (Reference 7). These values are tabulated in Table V.

As seen from figure 2, the different methods of estimating the expected index of the striped rod are quite uniform. All indicate that the index should lie midway between those for the 2.0 and 6 g/ft Li-Al rods and that the index should slightly exceed that for the cadmium rod.

NTG Acceptance Criteria (Proposed)

Calibration of the NTG for the striped rods will involve two stages. The first is qualification of a permanent reference striped rod standard. The second is setting acceptance criteria for the actual production rods slated for reactor use. The standard need not have full mechanical qualification, e.g., helium backfill, weld quality, total weight, surface finish, etc., but it should be fully qualified with respect to nuclear qualities such as number, density, and dimensions of B₄C and SS pellets. The measured average index of the standard should lie between -.11 and -.15. Failure to do so should be brought to the attention of RME&T and SCS for resolution. For a test of axial uniformity of the standard multiple passes should be made and the average index obtained at eight or more uniformly spaced intervals over the flat response region. An acceptance band of 5% max-to-min in these average indices appears reasonable.

For routine tests of production rods, the reference rod should first be run through the NTG several times to establish a statistical basis for the average index. A single run for the test production rods is adequate. For the test rods, indices should be obtained at each of eight or more uniformly spaced intervals. Each of these indices should then agree with the average index of the reference rod to within 5% (or about 0.006 in Index). The average value over the full length should be within 2.5% of that for the standard. This will assure adequate control for average value and axial variation, and will detect gross errors in the location of active end points. Experience may show that tighter restrictions may be possible, but at the present time there are no operational or safety reasons for doing so.

References:

1. S. E. Aleman, "Calculation of Gamma Heating Assembly Deposited Power Limits for the K-14.1 Subcycle", NES-CDG-910080, July 19, 1991.
2. R. E. Cooper and N. H. Kuehn, "Power Heat Input for Gamma Heat Limits", July 11, 1991.
3. W. E. Graves, "GLASS User's Manual", DPSTM-90-100-1, March, 1989.
4. A. N. Mallen, "A Two Dimensional Transport Theory Code for JOSHUA", DPST-75-203, January 7, 1975.
5. H. K. Clark, "JOSHUA Nuclear Criticality Safety Modules", DPSTM-86-700-3, March, 1987.
6. W. R. Ferrara, "GLASS-GILDA Cross Section Values, Rapid Shutdown System" (He-3)", DPST-88-454, June, 1988.
7. E. T. Sadowski, "Measured 320-M NTG Indices for Cd and Li-Al Control Rods", Personal Communication, June 26, 1991.

Fig 1 Worth of Striped B4C S-Rods
(Relative to Cd at start of Mk22 cycle)

GLASS and 10 gp TWOTRAN Computations

**Substitute Safety Rods—Physics
Design and NTG Calibration (U)**

**WSRC-TR-91-427
July 1991
Page 9 of 18**

Table I Rod Worths in Mark 22 by 84-Group GLASS

Case	K	deltaK	Worth
D2O Reference	1.09038	0.00000	NA
Cd (Mixed Isotopes)	1.05118	0.03920	1.000
Cd (Elemental)	1.05262	0.03776	0.963
SS	1.07768	0.01270	0.324
B4C	1.02737	0.06301	1.607
B4C/SS	1.03167	0.05871	1.498

Table II Ten-Group TWOTRAN Rod Worths in Mark 22

Case	K	deltaK	Rod Worth**
D2O Reference	1.09941	0.00000	NA
B4C/SS Homogeneous	1.04765	0.05176	1.498
B4C	1.04378	0.05563	1.610
SS	1.08777	0.01164	0.337
0.5" Striped	.05180	0.04760	1.378
1.0" Striped	1.05395	0.04546	1.316
2.0" Striped	1.05594	0.04347	1.258
4.0" Striped	1.05795	0.04146	1.200
6.0" Striped	1.05831	0.04110	1.189
12.0" Striped	1.05929	0.04012	1.161

** Normalized to SRL GLASS for B4C/SS Rod

Table III SRL/ANL Comparison of Relative Rod Worths

Case	SRL		ANL	
	GLASS	TWOTRAN**	GLASS	VIM
Cd (Ref)	1.000	1.000	1.000	1.00
B4C	1.607	1.610	1.607	1.63 + 0.08
B4C/SS	1.498	1.498	1.495	1.47 + 0.07
SS	0.324	0.337	-----	-----
Striped	-----	1.316	-----	1.38 + 0.07

** Normalized to SRL GLASS for B4C/SS Rod

Fig 2 NTG Calibration for Striped Safety Rods

**Substitute Safety Rods—Physics
Design and NTG Calibration (U)**

WSRC-TR-91-427

July 1991

Page 11 of 18

Table IV NTG Calibration Data for Substitute Safety Rods

CASE	GLASS		10 Gp TWTR/GLASS		16 Gp TWTR/HRXN		3 Gp TWTR/HRXN	
	K	-I	K	-I	K	-I	K	-I
Empty	.96261	.0000	1.10059	.0000	1.00444	.0000	1.03991	.0000
Cd Rod	.93106	.1247	1.05726	.1264	.96451	.1265	1.00094	.1215
B4C/SS	.92358	.1485	1.04914	.1495	-----	-----	-----	-----
Striped	-----	.130	1.05562	.1310	.96091	.1365	.99791	.1291
B4C	.92190	.1535	1.04671	.1565	-----	-----	-----	-----
.125 g/ft	.95567	.0322	-----	.0320	-----	.0319	-----	-----
.25 g/ft	.95121	.0526	-----	.0512	-----	.0501	-----	-----
.50 g/ft	.94511	.0746	1.07562	.0740	-----	.0730	1.01585	.0806
1.0 g/ft	.93835	.0996	1.06693	.0988	-----	.1012	1.00776	.1036
2.0 g/ft	.93247	.1199	1.05952	.1199	.96708	.1199	1.00158	.1199
4.0 g/ft	.92827	.1338	1.05446	.1343	.96196	.1329	.99798	.1292
8.0 g/ft	.92524	.1433	1.05076	.1449	-----	.1432	.99489	.1365
16 g/ft	.99258	.1515	1.04679	.1562	-----	-----	.99099	.1458
32 g/ft	.91990	.1595	-----	-----	-----	-----	-----	-----

Table V Measured NTG Indices for Various Control Rods

Rod Case	Index
Li-Al, 0.168 g/ft	-0.03614
Li-Al, 0.548 g/ft	-0.07801
Li-Al, 2.021 g/ft	-0.12002
Li-Al, 6 g/ft	-0.14570
<u>Cd</u>	<u>-0.12461</u>

Substitute Safety Rods—Physics
Design and NTG Calibration (U)

WSRC-TR-91-427
July 1991
Page 12 of 18

APPENDIX A
GLASS Input Data

* MK22 Lattice

```
L      A A      T T T T T I I I I C C C C E E E E      S S S S P P P P E E E E C C C C I I I F F F F I I I C C C C      A T T T T I I I 0 0 0 0 0 M M S S S S
L      A A A A A      T      I      C      E      E E E      S S S S P P P P E E E C      I      F F F I      C      A A A A      T      I      O      O M M S S S S
L      A A A A A      T      I      C      E      E E E      S S S S P P P P E E E C      I      F F F I      C      A A A A      T      I      O      O M M S S S S
L L L L A A A A      T      I I I I I C C C C E E E E      S S S S P      E E E E C C C C I I I F      I I I C C C C A      A T      I I I 0 0 0 0 0 M M S S S S
```

LATTICE NAME WPB
LATTICE VERSION WPB-CALC

LATTICE DESCRIPTIONS

*****VERSION OF**** MULTIGRP	NUCPARAM	PATTERN NAME	*****CELL NUMBER	NAME	NAME VERSION	HAM/VERS
STANDARD	STANDARD	SAFETY	1	D2C	SMALCELL	D20NNNN1
			2	D20	SMALCELL	D20NNNN2
			3	MK22	SMALCELL	MK22NNN3
			4	MK22	SMALCELL	MK22NNN4
			5	D20	SMALCELL	D20NNNN5
			6	D20	SMALCELL	D20NNNN6
			7	D20	SMALCELL	D20NNNN7
			8	TEST	SMALCELL	TESTNNN8

NO REGION HOMOGENIZATION REQUESTED.

LATTICE METHOD RECORD

ZONE=(1,2,4,6,7,8,9,11),DH=.09/
ZONE=(3,5),DH=.12/
ZONE=(10),DH=.012/

ISOTOPE SPECIFICATION DATA

CNT	***ISOTOPE NAME*** ORIGINAL	NEW	SPECTRUM OPTION	***VERSION NAME*** MULTIGRP	NUCPARAM
1	T		2		
2	U239		2		
3	HP240		2		
4	I135		2		
5	MD147		2		
6	PM147		2		
7	PM148		2		
8	PM148M		2		
9	PM149		2		
10	LI7		2		

```
*****
*****
*****
CELL NAME= D2C      * CELL VERSION= SMALCELL * * CONCAT CELL NAME/VER= D20NNNN2 *
*****
*****
```

GEOMETRY DATA

HEXAGON DATA

NO INNER SUB-ASSEMBLY 5
*****SUB-DIVISION***
REG NAME MAT NAME PITCH RADIAL AZMUTHAL
MO-01-01 D2C790C 4.04145 0 0

MATERIAL DATA

MAT NAME	MAT TENDS (CM/CC)	MAT NAME ENGINEER	TEMP CENT	*****ISOTOPE DATA***** NAME	CONCENTRATION	UNITS
D2C790C	1.17860		90	D-D2O	0.99750E+02	ATM-RATO
				H-H2O	0.35000E+00	ATM-RATO
				O	0.50000E+02	ATM-RATO

Substitute Safety Rods—Physics
Design and NTG Calibration (U)

WSRC-TR-91-427
July 1991
Page 13 of 18

* MK22 Lattice (Continued)

*CELL NAME= MK22 * *CELL VERSION= SMALCELL * *CONCAT CELL NAME/VERN= MK22***4 *

GEOMETRY DATA

ANNULAR DATA

REG NAME	REG O.D.	MAT NAME	MO INNER SUB-ASSEMBLY		RIB WIDTH	RIB O.D./I.D.	**INCLUDING OD(INCH)	RIBS*** RAD (CM)	**SUB-DIVISION**	
			NO.	RIBS					RADIAL	AZMUTHAL
DS-01-11	1.23500	D20T61C	0	0.0	0.0	0.0	1.23500	1.56845	0	0
CL-01-11	1.29500	ALUM1100	0	0.0	0.0	0.0	1.29500	1.64465	0	0
TT-01-11	1.53000	TT-22-1X	0	0.0	0.0	0.0	1.53000	1.94310	0	0
CL-01-12	1.59000	ALUM1100	4	0.06000	1.96500	1.60792	2.04205	0	0	0
CO-01-11	1.99500	D20T60C	0	0.0	0.0	0.0	1.99500	2.53365	0	0
CL-02-11	2.35500	ALUM8001	0	0.0	0.0	0.0	2.05500	2.60985	0	0
FT-01-11	2.29500	FT-22-D1	0	0.0	0.0	0.0	2.29500	2.91211	0	0
CL-02-12	2.35500	ALUM8001	4	0.07000	2.86200	2.37220	3.01270	0	0	0
CO-02-11	2.89200	D20T60C	0	0.0	0.0	0.0	2.89200	3.67284	0	0
CL-03-11	2.95200	ALUM8001	0	0.0	0.0	0.0	2.95200	3.74904	0	0
FT-02-11	3.14000	FT-22-D2	0	0.0	0.0	0.0	3.14000	3.98780	0	0
CL-03-12	3.20000	ALUM8001	0	0.0	0.0	0.0	3.20000	4.06400	0	0
CO-03-11	3.54000	D20T60C	0	0.0	0.0	0.0	3.53129	4.48474	0	0
CL-04-11	3.60000	ALUM1100	4	0.07800	3.23800	3.60000	4.57200	0	0	0
TT-02-11	3.64200	TT-22-0X	0	0.0	0.0	0.0	3.64200	4.62534	0	0
CL-04-12	3.70000	ALUM1100	0	0.0	0.0	0.0	3.70000	4.69900	0	0

HEXAGON DATA

INNER DIAMETER IS 3.700 INCHES

REG NAME	MAT NAME	PITCH	**SUB-DIVISION**
MO-01-12	D20T90C	4.04145	0

MATERIAL DATA

MAT NAME	MAT DEHSO (G/CC)	MAT NAME ENGINEER	TEMP CENT	*****ISOTOPE DATA***** NAME CONCENTRATION UNITS
----------	---------------------	----------------------	--------------	--

TT-22-1X	0.0	60	AL27 L16 ONE/V UNIT-CAP	0.57643E-01 0.29536E-02 0.10000E-14 0.13000E-14	ATM/B-CM ATM/B-CM ATM/B-CM ATM/B-CM
FT-22-D1	0.0	150	AL27 XE135 SM149 U234 U235 U236 U238 ONE/V UNIT-CAP	0.52080E-01 0.20300E-07 0.15000E-06 0.34100E-04 0.19335E-02 0.56037E-03 0.39350E-03 0.10000E-14 0.10000E-14	ATM/B-CM ATM/B-CM ATM/B-CM ATM/B-CM ATM/B-CM ATM/B-CM ATM/B-CM ATM/B-CM ATM/B-CM
FT-22-D2	0.0	150	AL27 XE135 SM149 U234 U235 U236 U238 ONE/V UNIT-CAP	0.52636E-01 0.19700E-07 0.13800E-06 0.33335E-04 0.18883E-02 0.34603E-03 0.38753E-03 0.10000E-14 0.10000E-14	ATM/B-CM ATM/B-CM ATM/B-CM ATM/B-CM ATM/B-CM ATM/B-CM ATM/B-CM ATM/B-CM ATM/B-CM
TT-22-0X	0.0	60	AL27 L16 ONE/V UNIT-CAP	0.58675E-01 0.19275E-02 0.10000E-14 0.10000E-14	ATM/B-CM ATM/B-CM ATM/B-CM ATM/B-CM
D20T61C	1.39040	60	D-D20 H-H20 O	0.65457E-01 0.16405E-03 0.32810E-01	ATM/B-CM ATM/B-CM ATM/B-CM
ALUM1100	2.71000	60	AL27 B10	0.60512E-01 0.32979E-06	ATM/B-CM ATM/B-CM
ALUM8001	2.71000	60	AL27 B10	0.60512E-01 0.39059E-06	ATM/B-CM ATM/B-CM
D20T60C	1.39040	60	D-D20 H-H20 O	0.65457E-01 0.16405E-03 0.32810E-01	ATM/B-CM ATM/B-CM ATM/B-CM
D20T90C	1.37060	90	D-D20 H-H20 O	0.64268E-01 0.16107E-03 0.32215E-01	ATM/B-CM ATM/B-CM ATM/B-CM

WSRC-TR-91-427
July 1991
Page 14 of 18

```

*****
CELL_NAME=TEST      ,  *CELL_VERSION=SMALCELL ,  *CONCAT_CELL_NAME=VERN TEST*
*****

```

ANNUAL DATA

NO INNER SUB-ASSEMBLY

HEXAGON DATA

INNER DIAMETER IS 3.700 INCHES

MATERIAL DATA

```
#####
#                                     #
# CELL NAME TEST                      # 4CELL VERSION 0.98          # CONCAT CELL NAME VERM TEST####
#####
```

ANNULAR DATA

NO INNER SUB-ASSEMBLY

HEXAGON DATA

INNER DIAMETER IS 3.700 INCHES

MATERIAL DATA
111111111111

MAT NAME	MAT DENS (G/CC)	MAT NAME ENGINEER	TEMP CENT	NAME	ISOTOPE DATA CONCENTRATION	UNITS
ALUMINUM	2.71000		60	AL27 010	0.60512E-01 0.32979E-06	ATM/B-CM
D2O190C	1.07060		90	D-D2O H-H2O 0	0.64268E-01 0.16107E-03 0.32215E-01	ATM/B-CM ATM/B-CM ATM/B-CM
STAINLESS	0.0		20	FE	0.64600E-01	ATM/B-CM
CADMIUM	0.0		20	CD	0.46400E-01	ATM/B-CM

APPENDIX B

NTG Computational Model, Materials and Radii

Table IB - Material Contents

Material with isotopic content in A/bcm X 100

Isotope	Core	CH2	WEP	Al	SS	B4C	Cd	Air
N								0.0045
H	3.77	7.88	5.779					
O	1.12		1.445					0.0008
C	1.85	3.94	3.621			1.95		
Al	1.52			6.01				
Fe					8.48			
Cd							4.64	
B						7.80		

Table IIB NTG Radii (with Cd rod)

Region	Radius, cm
Al	0.0960
Cd	1.0871
SS	1.1938
Air	5.1587
CH2	5.7937
Core	17.5707
WEP	30.4797

APPENDIX C

Comparison of ANL to SRL Results

As indicated in Table III, the MONTE CARLO results from VIM agree well with GLASS predictions so far as relative rod worths are concerned. VIM however predicts absolute worths in reactivity units about 8% lower for all rods. In an attempt to reconcile this difference, two additional sets of GLASS problems were run at SRL. In the first set, the integral transport computations were repeated with the the regions in the rod cell divided into much smaller subregions (fine-grid of table C-1). In the second set, the Monte-Carlo option in GLASS was used to recompute all of the ANL cases. These results and the earlier SRL and ANL cases are summarized as K values in Table C-1). The lower values for VIM are largely ascribable to the inclusion of the Mark 22 process tubes. They are not included in any of the GLASS cases. ANL compares worths on the basis of reactivity units, $\Delta K/K$, rather than the ΔK units used in this report. To follow the the ANL procedure, for each case the reactivity is defined as:

1. $\text{Reactivity} = \Delta K/K = (K-1)/K$.

Table C-2 gives the derived reactivity values for each case. Table C-3 gives the final comparison of rod worths in reactivity units, i.e., the reactivity difference between the reference no-rod case and the rodged case. As seen from Table C-3, the fine-grid treatment improves the agreement but still leaves a systematic difference. The GLASS Monte Carlo agrees with VIM within the combined uncertainties. The results suggest that a major part of the discrepancy between VIM and the original GLASS values is due to the difference in transport treatment. If a residual difference remains, the difference is likely due to differences in cross sections. Thermal neutron scattering cross sections, i.e., those relating to energy exchange, are known to differ in GLASS and VIM.

Table C-1 SRL and ANL Values of K for Safety Rods in Mark 22

Case	Text	SRL GLASS		ANL	
		Fine Grid	Monte Carlo	GLASS	VIM
D2O	1.0904	1.0904	1.0902±0.0009	1.0914	1.0829±0.0014
Cd	1.0512	1.0524	1.0543±0.0009	1.0552	1.0475±0.0015
B4C	1.0274	1.0291	1.0297±0.0010	1.0284	1.0251±0.0014
B4C/SS	1.0317	1.0332	1.0339±0.0013	1.0328	1.0310±0.0014

Table C-2

SRL and ANL Reactivities ($\Delta K/K$) in Mark 22

Case	Text	SRL GLASS		ANL	
		Fine Grid	Monte Carlo	GLASS	VIM
D2O	0.0829	0.0829	0.0827 $\pm$ 0.0008	0.0837	0.0766 $\pm$ 0.0013
Cd	0.0487	0.0498	0.0515 $\pm$ 0.0009	0.0496	0.0453 $\pm$ 0.0014
B4C	0.0267	0.0283	0.0288 $\pm$ 0.0010	0.0276	0.0245 $\pm$ 0.0014
B4C/SS	0.0307	0.0321	0.0328 $\pm$ 0.0013	0.0218	0.0301 $\pm$ 0.0014

Table C-3

SRL and ANL Rod Worths in Reactivity Units

Case	Text	SRL GLASS		ANL	
		Fine Grid	Monte Carlo	GLASS	VIM
Cd	0.0342	0.0331	0.0312 $\pm$ 0.0012	0.0341	0.0313 $\pm$ 0.0019
B4C	0.0562	0.0546	0.0539 $\pm$ 0.0013	0.05610	0.0521 $\pm$ 0.0019
B4C/SS	0.0522	0.0508	0.0495 $\pm$ 0.0015	0.0519	0.0465 $\pm$ 0.0019

END

**DATE
FILMED**

7 / 10 / 92