






AIM

Association for Information and Image Management




1100 Wayne Avenue, Suite 1100
Silver Spring, Maryland 20910
301/587-8202



Centimeter



Inches



MANUFACTURED TO AIM STANDARDS
BY APPLIED IMAGE, INC.

1

O

1

1

**Cover Sheet for a Hanford
Historical Document
Released for Public Availability**

Released 1994

**Prepared for the U.S. Department of Energy
under Contract DE-AC06-76RLO 1830**

**Pacific Northwest Laboratory
Operated for the U.S. Department of Energy
by Battelle Memorial Institute**



DISCLAIMER

This is a **historical document** that is being released for public availability. This was made from the best available copy. Neither the United States Government nor any agency thereof, nor Battelle Memorial Institute, nor any of their employees, makes any **warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights.** The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DECLASSIFIED

Classification Cancelled and Changed To

DECLASSIFIED

HW-57387

By Authority of CG PR-2 (PR24),

DS Reno, 12-10-93.

By Gerri Maly 1-3-94.

Verified By DK Hanson, 1-14-94

This document consists of 3011 pages. No. 7 of 1000 copies. Series

DISTRIBUTION: #1 - R. E. Fearnow, Phillips Petroleum Company
Idaho Falls, Idaho

- #2 - J. J. Cadwell
- #3,4,5 - A. T. Gifford, AEC-HOO
- #6 - E. A. Evans
- #7 - D. C. Kaulitz
- #8 - J. E. Minor
- #9 - R. Neidner, c/o Phillips Petroleum Company
- #10 - J. W. Talbott
- #11 - L. D. Turner
- #12 - 300 Files
- #13 - Records Center

GEH-4-32, BONDED SEGMENTED FUEL ELEMENT IRRADIATION
(Letter to R. E. Fearnow by R. Neidner.)

R. Neidner

September 16, 1958

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

This document
Approved 1954.
inanner to an

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DECLASSIFIED

HW-57387
9/16/58

Mr. R. E. Fearnow
Project Engineering
Materials Testing Reactor
Phillips Petroleum Company
Idaho Falls, Idaho

Dear Ralph:

GEH-4-32, Bonded Segmented Fuel Element Irradiation

We have prepared what we call a bonded segmented fuel element. This fuel element has characteristics which make it an attractive prospect for high specific power operation at relatively low uranium temperatures. The fuel slug is made up of six longitudinal segments; each segment being bonded to the aluminum webbing and tubing which encases it. You will note from the figure of Appendix III that the can, or jacket, is the same type as that used in fabricating the "garbage can" fuel element, irradiated as GEH-4-I (HW-48747).

We are interested in the operating characteristics of this new fuel element. We want to learn the relation of power output to environmental flux; this will be done with special thermocouples to monitor the power output and attached flux wires. Further, by post irradiation analysis, we will be able to study bond stability, segment warpage, and possibly maximum uranium temperatures from changes in the grain structure.

The pertinent information for this irradiation is summarized below while the details are appended in the following order:

Appendix I Fabrication Details & Hazards
Appendix II Thermal Aspects and Calculations
Appendix III Figures

Summary of Proposed Conditions

Maximum Fuel Temperature, °F	537
Maximum Surface Temperature, °F	200
Weight of Natural-U, gm/inch	295
Total Weight of Natural-U, gm	2360
Maximum Power Generation, KW/in	5.2
Maximum Heat Flux, BTU/hr-ft ²	388,000
Water Flow Rate, gpm	17
Water Velocity, ft/sec. Outer Annulus	14.1
Inner Annulus	14.6
Film Coefficient, BTU/hr-ft ² °F	4270
Outside Dimensions, Inches	1.535 O.D. x 0.563 I.D. x 8-3/4 lg
Cycles of Exposure	1

DECLASSIFIED

-2-

HW-57387
9/16/58

General

Please arrange for the necessary approvals as soon as practical. The fuel element will be assembled in a standard, but expanded to 1.650" I.D., GEH-4 basket at Hanford along with two chromel-alumel thermocouples. The assembled basket will be shipped to the MTR early in September. Before insertion in the reactor, a 0.1% Co-Al flux wire should be attached to the outside of the basket adjacent to the fuel element. No maintenance time will be required prior to insertion. In addition to inserting the test assembly, please arrange to have two flux monitoring wires placed in the appropriate holes of the new B-3 block. We will supply the flux wires in the holders for operations to insert.

If you need any further information Ralph, please let me know and I will be glad to obtain it for you.

Very truly yours,

Robert Neidner

R. Neidner
HAPO Sponsor Representative
General Electric Company

RN:lh

Distribution:

1. R. E. Fearnow - PPGCo.
2. J. J. Cadwell
3. A. T. Gifford, AEC-HOO
4. E. A. Evans
5. D. C. Kaulitz
6. J. E. Minor
7. R. Neidner
8. J. W. Talbott
9. L. D. Turner
10. 300 Files
11. File Copy

[REDACTED]

DECLASSIFIED

HW-57387

APPENDIX I

A. Fabrication Details

The fuel element is composed of six pie shaped natural uranium rods, each eight inches long. Each rod, or segment, weighs 394 grams, giving a total uranium weight to the entire fuel element of 2360 grams (5.2#). Each uranium segment was coated with one mil of nickel over its entire surface. The plated segments were then pressed into the compartments of a special aluminum can. The special can resembles two concentric tubes united by six full length fins. The end cap was then welded in place. The fuel segments and cladding were then bonded by placing in an autoclave for eight hours at conditions of 550°C and 1500 psi. Destructive tests of identical fuel elements have shown complete bonding on all surfaces of each uranium segment.

The outside diameter of the bonded element is 1.535", being a little larger than our standard slugs. To accommodate the hydraulic and heat transfer requirements, it was necessary to expand a standard GEH-4 basket to an I.D. of 1.650". Also for the same reason, a flow restrictor was positioned in the center of the fuel element hole, thereby forming an annulus, hydraulically compatible to the slug-basket annulus.

Assembling of the basket for shipment was done the same as with our previous tests in which basket thermocouples have been used. Two basket thermocouples were installed with this test, one for measuring the inlet water temperature just above the fuel, the other the exit water temperature at the bottom of the basket. Chromel-Alumel, 30 gauge, couples, swaged in 0.062" diameter stainless steel tubing with zirconium oxide as an insulator were the type used. The thermocouple leads are about 27 feet long, the excess length above the top of the basket being coiled up for shipment. As before, it will be necessary to splice a 12 foot length of 1/4" stainless tube over the two couples prior to reactor insertion for protection and a means of penetrating the access flange at the top of the reactor tank.

The fuel element is supported by a 5-3/4" spacer. This arrangement will place the center of the fuel about 1-1/2" below the midplane of the reactor.

B. Hazards

Because of the low uranium temperatures and the compartmental technique of fabrication, fission products release in case of a rupture would be extremely small, probably only enough to trip the GEH-4 fission break monitor. Further, because of the severe autoclaving involved in the bonding process, the cladding is assured to be complete and sound; thus the possibility of a fission break is very remote.

DECLASSIFIED

HW-57387

APPENDIX II

A. Thermal Aspects

The basis of the fuel element is to maintain relatively low uranium temperatures at high specific power generations. The power generation predicted for this fuel element was based on actual data from our GEH-4 irradiations. GEH-4-31, which was also a natural uranium irradiation, generated a maximum power of 85 KW/ft. Since 10.7#ft of uranium were involved, the maximum specific power was about 8 KW/# of natural-U. Therefore the expected power generation for this test is predicted to be about 8 KW/# x 7.8 #/ft = 62.5 KW/ft of fuel. The maximum temperature calculated for each uranium segment is 537°F and that of the cladding surface to be about 200°F. Agreeably the method of calculation is approximate, as shown below, but nevertheless should be reasonable for this particular configuration. Both of these pertinent temperatures are far below anything critical (water saturation temperature is 409°F @ 250 psig, uranium melting temperature is about 2240°F). Therefore refinement of the calculations was not warranted.

B. Sample Calculations

Following is a summary of the calculations which were made. The final balanced conditions are presented, although several trial and error solutions were previously tried:

Cross-Sectional Flow Areas

$$\begin{aligned} \text{Basket} &= \pi/4 (1.650)^2 = 2.14 \text{ in}^2 \\ &= 0.01485 \text{ ft}^2 \end{aligned}$$

$$\begin{aligned} \text{Outer Annulus} &= \pi/4 (1.650)^2 - (1.535)^2 = 0.282 \text{ in}^2 \\ &= 0.00196 \text{ ft}^2 \end{aligned}$$

$$\begin{aligned} \text{Inner Annulus} &= \pi/4 [(0.573)^2 - (0.426)^2] = 0.102 \text{ in}^2 \\ &= 0.00071 \text{ ft}^2 \end{aligned}$$

Peripheries

$$\begin{aligned} \text{Basket} &= \pi(1.650) = 5.18 \text{ in} \\ &= 0.431 \text{ ft} \end{aligned}$$

$$\begin{aligned} \text{Outer Diameter} &= \pi(1.535) = 4.82 \text{ in} \\ &= 0.401 \text{ ft.} \end{aligned}$$

$$\begin{aligned} \text{Inner Diameter} &= \pi(0.563) = 1.77 \text{ in} \\ &= 0.147 \text{ ft.} \end{aligned}$$

DECLASSIFIED

HW-57387
9/16/58

Power Generation

Specific power generation taken from GEH-4-31 was measured to be 8 KW/# of natural U.

$$Q = 5.2 \# \frac{\text{nat. U}}{8 \text{ in.}} \times 8 \frac{\text{KW}}{\#} \times 12 \text{ in/ft}$$

$$Q = 62.5 \text{ KW/ft}$$

$$= 213,000 \text{ Btu/hr-ft.}$$

Heat Flux (Assumed essentially equal for all surfaces)

$$H = \frac{213,000}{(0.401 \div 0.147) \times 1} = 388,000 \text{ Btu/hr-ft}^2$$

Film Coefficient - (Assumed film drop to be 65° (117°F))

$$h_f = \frac{H}{\Delta t} = \frac{388,000}{\Delta 117^\circ} = 3320 \text{ Btu/hr } ^\circ\text{F-ft}^2$$

Flow Rate Required to Maintain Assumed Film Drop

Outer Annulus

$$De = 4 \frac{A}{S} = \frac{4(0.282)}{5.18 \div 4.82} = 0.113 \text{ in}$$

$$h_f = 150 \left[1 \div 0.011 (t_b) \right] \frac{v_o^{0.8}}{De^{0.2}} \quad (\text{P. 228 McAdams 3rd Edition})$$

$$v_o^{0.8} = \frac{3320 (0.113)^{0.2}}{150 (1 \div 0.011 \times 108^\circ)} = \frac{3320(0.647)}{328}$$

$$v_o^{0.8} = 6.35$$

$$v_o = 10.1 \text{ ft/sec} \quad \begin{matrix} 61.99 \\ 1.99 \end{matrix}$$

$$\text{Flow } Q_o = VA \quad \left(60 \frac{\text{sec}}{\text{min}} \times 62 \frac{\#}{\text{ft}^2} \times \frac{\text{gal}}{8.33\#} \right)$$

$$Q_o = 10.1 (0.00196)(448)$$

$$Q_o = 8.86 \text{ gpm}$$

Inner Annulus

$$De = \frac{4(0.102)}{(1.77 \div 0.426)} = 0.131 \text{ in.}$$

DECLASSIFIED

HW-57387
9/16/58

$$v_1^{0.8} = \frac{3320(0.131)^{0.2}}{328}$$

$$v_1^{0.8} = 6.55$$

$$v_1 = 10.5 \text{ ft/sec}$$

$$\text{Flow } Q_1 = 10.5 (0.0071 \text{ ft}^2) 448$$

$$Q_1 = 3.34 \text{ gpm}$$

The pressure balance of each channel follows. The "Velocity Head" method of determining pressure drops was used. Reference was made to the Reactor Handbook - Engineering Volume.

Velocities

$$\text{Outer Annulus} = 10.1 \text{ ft/sec.}$$

$$\text{Inner Annulus} = 10.5 \text{ ft/sec.}$$

$$\text{Velocity Head} = \frac{v^2}{2g}$$

$$\text{Outer Annulus} = \frac{(10.1)^2}{64.4} \frac{(62)}{(144)} = 0.685 \text{ psi}$$

$$\text{Inner Annulus} = \frac{(10.5)^2}{64.4} \frac{(62)}{(144)} = 0.740 \text{ psi}$$

$$\text{Reynolds Number} = \frac{DV}{\mu}$$

$$\mu \text{ for water at } 108^\circ\text{F} = 4.22 \times 10^{-4} \text{ #/ft-sec.}$$

$$\begin{aligned} \text{Outer Annulus} &= \left(\frac{0.113}{12} \right) \frac{(10.1)}{4.22 \times 10^{-4}} \frac{(62)}{144} \\ &= 1.4 \times 10^4 \end{aligned}$$

$$\begin{aligned} \text{Inner Annulus} &= \frac{0.131}{12} \frac{10.5}{4.22 \times 10^{-4}} \frac{62}{144} \\ &= 1.68 \times 10^4 \end{aligned}$$

Friction Factor, f

$$\text{Outer Annulus} = 0.028$$

$$\text{Inner Annulus} = 0.027$$

DECLASSIFIED

-7-

HW-57387
9/16/58

Friction Loss, $\Delta P = \frac{f L}{D_e}$ (Vel. Head)

$$\text{Outer Annulus} = \frac{0.028 (9)}{0.113} (0.685)$$

$$= 1.53 \text{ psi}$$

$$\text{Inner Annulus} = \frac{0.027 (9)}{0.131} (0.740)$$

$$= 1.38 \text{ psi}$$

Contraction and Expansion Loss, $\Delta P = K$ (Vel. Head)

Outer Annulus

$$\text{Contraction at end } \frac{A_o}{A_b} = \frac{0.282}{2.14} = 0.13$$

$$K_c = 0.394$$

$$\Delta P = 0.398 (0.685) = 0.272 \text{ psi}$$

Expansion from end

$$K_e = 0.75$$

$$\Delta P = 0.75 (0.685) = 0.514 \text{ psi}$$

Inner Annulus

$$\text{Contraction at end } \frac{A_1}{A_b} = \frac{0.102}{2.14} = 0.048$$

$$K_c = 0.398$$

$$\Delta P = 0.398 (0.740) = 0.294 \text{ psi}$$

Expansion from end

$$K_e = 0.90$$

$$\Delta P = 0.90 (0.740) = 0.294 \text{ psi}$$

DECLASSIFIED

HW-57387
9/16/58

Total Pressure Drop, ΔP

<u>Loss</u>	<u>Outer Annulus</u>	<u>Inner Annulus</u>
Contraction	0.272	0.294
Expansion	0.514	0.666
Friction	1.530	1.380
Total	2.316 psi	2.340 psi

Temperature Drop Through Cladding

$$\Delta t_c = \frac{H(\text{Btu/hr-ft}^2) \times \text{thickness}(\text{ft})}{K \text{ Btu/hr-ft-}^\circ\text{C}}$$

$$\Delta t_c = \frac{388,000}{216} \times \frac{(0.0625)}{12}$$

$$= 9.4^\circ\text{C} \quad (17^\circ\text{F})$$

Temperature Drop Across Bonded Interface

$$H_c = 40,000 \text{ Btu/hr-ft}^2\text{-}^\circ\text{F}$$

$$\Delta t_b = \frac{H}{h_c} = \frac{388,000}{40,000(1.8)} = 5.4^\circ\text{C} \quad (9.7^\circ\text{F})$$

Surface Temperature of U-Segments

$$t_s = \text{Water } t + \Delta t_f + \Delta t_c + \Delta t_b$$

$$t_s = 108^\circ + 117^\circ + 17^\circ + 10^\circ$$

$$t_s = 252^\circ\text{F} \quad (122^\circ\text{C})$$

Temperature Drop Through U-Segment

Assume heat to flow effectively out of a small natural-U, 0.45" dia. rod for each of the six segmented sections.

Power per section

$$q = \frac{Q}{6} = \frac{62.5 \text{ KW/ft}}{6} = 10.4 \text{ KW/ft}$$

$$K_u = \frac{1196 \text{ ft}^\circ\text{C}}{83.4} = \frac{1196 \text{ ft}^\circ\text{C}}{83.4}$$

$$K_u = 17.7 \text{ Btu/hr ft}^\circ\text{F}$$

DECLASSIFIED

HW-57387
9/16/58

$$\Delta t = \frac{q}{4 \pi K} = \frac{10.4 (3412)}{4 K (17.7)}$$

$$\Delta t = 160^\circ \text{F} (89^\circ \text{C})$$

Temperature Distribution Summary

Water	108°F
Clad Surface	225°F
Clad Inside	242°F
Uranium Surface	252°F
Uranium Maximum	504°F

The flow rate required to maintain the satisfactory film drop of 117°F only totals about 12 gpm. However, since the standard flow rate for the GEH-4 irradiations is 17 gpm, it is recommended that this higher flow rate be used so as not to cause operational confusion. By using 17 gpm, the film drop will be reduced by approximately the following:

$$\left(\frac{12.2}{17}\right)^{0.8}; \text{ or } \Delta t_{\text{actual}} = 117^\circ (.77) = 91^\circ \text{F}$$


Therefore the actual surface temperature will be approximately 200°F instead of 225°F. Other internal temperatures, of course, will also be reduced by about the same amount.

UNCLASSIFIED

-10-


HW-57387

DECLASSIFIED



1.533 O.D.

.615 I.D.



2S ALUM. RIBBED CAN

.010

3/8

URANIUM SEGMENTS Ni PLATED .0008" THK.

H. L. O. FACILITIES ENG'R'G

SEP 19 1958

AM 7,8,9,10,11,12,1,2,3,4,5,6 PM

APPROVED

No.	REVISIONS	REV. BY DATE	APPD. BY	FOR	DATE
SCALE FULL		NEXT USED ON SK-3-7771			
APPROVALS	FOR	DRAWN R. Carlson DATE 9/18/58			
OK	HLO	CHECKED Rcc		PROJ. NO.	
		ISSUED Rcc		INST. NO.	
		DES. ENG. Kaulitz		UNIT HLO	
BLDG. NO.	326	INDEX NUMBER	4907		
DWG. NO.	SK-3-7990		SHEET NO.	SHEETS	

DWG. NO.	DRAWING TITLE	
REFERENCE DRAWINGS		
CLASSIFICATION	CLASS. BY	DATE
NONE	R. Carlson	9/18/58
U. S. ATOMIC ENERGY COMMISSION		
HANFORD ATOMIC PRODUCTS OPERATION		
GENERAL ELECTRIC		
SEGMENTED URANIUM I&E FUEL ELEMENT		

DATE

FILMED

6 / 16 / 94

END

