**PUBLISHED ASSESSMENTS BEARING ON THE FUTURE USE OF CERAMIC
SUPERCONDUCTORS BY THE ELECTRIC POWER SECTOR**

by R.F. Giese and A.M. Wolsky

Argonne National Laboratory, 9700 South Cass Avenue, Argonne, Illinois 60439
United States of America

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

August 25, 1992

Work done for and sponsored by the signatories of the International Energy Agency

*Implementing Agreement for a Cooperative Programme for Assessing the Impacts
of High-Temperature Superconductivity on the Electric Power Sector*

MASTER

TABLE OF CONTENTS

I. PREFACE	I-1
I.1 Content and Purpose	I-1
I.2 Scope	I-1
I.3 Sponsorship	I-1
I.4 How to Use This Document	I-3
I.5 Further Sources of Information	I-4
II. INTRODUCTION	II-1
III. COMPREHENSIVE ASSESSMENTS	III-1
IV. ASSESSMENTS BEARING UPON CABLE	IV-1
V. ASSESSMENTS BEARING UPON FAULT CURRENT LIMITERS	V-1
VI. ASSESSMENTS BEARING UPON GENERATORS	VI-1
VII. ASSESSMENTS BEARING UPON MOTORS	VII-1
VIII. ASSESSMENTS BEARING UPON SMES	VIII-1
IX. ASSESSMENTS BEARING UPON TRANSFORMERS	IX-1

TABLES

Table 1.1	Members of the Executive Committee of the Implementing Agreement for a Co-Operative Programme for Assessing the Impacts of High-Temperature Superconductivity on the Electric Power Sector.....	I-2
Table 3.1	KfK Workshop Presentations	III-6
Table 4.6-2	Cost Comparison of Conventional and Superconducting 77K-ac Power Cables according to G.Bogner	III--12
Table 4.6-5	Comparison of a conventional 850 MVA (27/420 kV) Generator Transformer with a 77 K Superconducting Transformer (single phase type) according to G.Bogner.....	III-13
Table 3.2	Conductor Requirements According to Y. Sekine et al.	III-17
Table 5	Break-Even Size of Motor Versus Refrigeration Load According to B.W.McConnell.....	III-23
Table 6	Economic Evaluation of HTSC Motors According to B.W.McConnell	III-23
Table 7	Summary of HTSC Motor Issues According to B.W.McConnell.....	III-24
Table 4.1	Comparison of Conventional and Alternative.....	III-33
Table 6.1	Comparison of Losses and Costs of Service.....	III-36
Table 7.1	Potential Savings with 77-K SMES.....	III-37

I. PREFACE

I.1 Content and Purpose

This report lists and provides abstracts for various technical and economic assessments related to applications of High-Temperature Superconductors (HTS) to the electric utility sector. Those studies deemed most important are identified and summarized. This report is intended for R&D managers in government, electric utilities, firms, and national laboratories who want access to what has been done and what remains to be done. It is assumed that the reader is acquainted with superconductivity, but not expert in the topics discussed here. Indeed, it is the author's aim to enable the reader's attention, support or funding. This report may also inform scientists and engineers who, though expert in particular areas, wish to know what has been written about future applications of their work.

I.2 Scope

The assessments, described on the following pages, include those published in the archival literature, presented at meetings, and written for government agencies. The assessments include brief ones made by single authors and lengthy ones made by teams of authors. As is natural to a field with many new participants, many authors have considered a few topics and found similar answers. We have tried to be inclusive in our list, so that the user can be aware of and confirm the rough consensus that has emerged, as well as be aware of the various authors who have assessed future applications.

I.3 Sponsorship

The effort to write this report was sponsored by institutions in Canada, Denmark, Finland, Germany, Italy, Japan, the Netherlands, Norway, Sweden, Switzerland, Turkey, the United Kingdom, and the United States. These institutions are signatories to an International Energy Agency (IEA) Implementing Agreement, entitled *Implementing Agreement for a Co-Operative Programme for Assessing the Impacts of High-Temperature Superconductivity on the Electric Power Sector*. We are pleased to note that Belgium and Israel have expressed their intent to become signatories to the Implementing Agreement.

The names and addresses of members of the sponsors' Executive Committee for the project from participating countries are given in Table 1.1.

**Table 1.1 Members of the Executive Committee of the
Implementing Agreement for a Co-Operative Programme for
Assessing the Impacts of High-Temperature Superconductivity on
the Electric Power Sector.**

Dr. F.Y. Chu
Section Head
Science Research Division
Ontario Hydro
800 Kipling Avenue
Toronto, Ontario
M8Z5S4, CANADA

Dr. Fred Steennis
Group Leader, Power Applications
KEMA
P.O. Box 9035
6800 Arnheim
NETHERLANDS

Dr. Raymond Roberge
Hydro-Quebec
1800 Montée Ste. Julie
Varenes, Quebec
J3X1S1
CANADA

Dr. John Kulsetås
Research Director
Norwegian Electric Power Research Institute (EFI)
7034 Trondheim
NORWAY

Mr. Frank Rasmussen
Head, Electrical Section of Power System
Evaluation Dept.
Elkraft Power Co., Ltd.
Lautruphøj 5
2750 Ballerup
DENMARK

Mr. Håkan Håkansson
National Energy Administration
Liljeholmsväg 30
S-11787 Stockholm
SWEDEN

Mr. Jarl-Thure Ericksson
Professor
Electrotechnical Department
Tampere University of Technology
P.O. Box 527
SF-33101 Tampere 10
FINLAND

Dr. Georg Vécsey
Head of the Technical Physics Laboratory
Paul Scherrer Institute (PSI)
Wurlenlingen and Villingen
CH-5232 Villigen PSI
SWITZERLAND

Mr. Sigfrid Wennerberg
Office of Energy Technology
Research and Development
International Energy Agency
2 rue André-Pascal
75775 Paris Cedex 16
FRANCE

Mr. Ömer Kaymakçalan, President
Marmara Research Centre
Tübitak
P.O. Box 21
41470 Gebze-Kocaeli
TURKEY

Table 1.1 (Cont'd)

Prof. Dr. Peter Komarek
Director of Institute for Technical Physics
Nuclear Research Centre Karlsruhe (KfK)
D-7500 Karlsruhe
P.O. Box 3640
GERMANY

Mr. Noboru Horie
Director General
Superconductivity Project Team
New Energy and Industrial Technology
Development Organization
Sunshine 60, 1-1 Higashi-Ikebukuro
3-chome
Toshima-ku
Tokyo 170
JAPAN

Prof. Guy Deutscher
Tel Aviv University
Ramat Aviv 69978
Tel Aviv
ISRAEL

Mr. Fergus Morley
Manufacturing Technology Division
The Department for Enterprise
Department of Trade and Industry
151 Buckingham Palace Road
London SW1W9SS
UNITED KINGDOM

Mr. Giancarlo Manzoni
ENEL-CREL
Via Volta 1
20093 Cologno Monzese
Milano, ITALY

Dr. James G. Daley
U.S. Department of Energy
Conservation and Renewable Energy
CE-142 5E-036
1000 Independence Ave., SW
Washington, DC 20585
UNITED STATES

Dr. Gabriele Botta
ENEL-CREL
Via Volta 1
20093 Cologno Monzese
Milano, ITALY

Dr. Alan M. Wolsky
Task Operating Agent
Argonne National Laboratory
9700 South Cass Avenue
Argonne, IL 60439
UNITED STATES

I.4 How to Use This Document

If the reader is seeking assessments addressing one of the topics listed (i.e. cables, fault-current limiters, generators, motors, superconducting magnetic energy storage, or transformers), it is only necessary to turn to the appropriate chapter and scan the abstracts. They are arranged chronologically. The reader should also read Section III to learn of the topic of interest was addressed in one of the comprehensive assessments summarized there.

I.5 Further Sources of Information

While published assessments represent the considered views of their authors at the time of writing, further views may be available by contacting them and others who work in the field. Access to them can be facilitated by referring to the "Directory of Ceramic Superconductor Research and Related Research Bearing upon the Electric Power Sector", another report prepared by Argonne National Laboratory for the signatories of the International Energy Agency *Implementing Agreement for a Co-Operative Programme for Assessing the Impacts of High-Temperature Superconductivity on the Electric Power Sector*. Copies of that report can be obtained by requesting it from the member of the sponsors' Executive Committee who represents the country of the requester. As noted above, the name and address of each member of the Executive Committee is listed in Table 1.1.

II. INTRODUCTION

Much has been written about ceramic superconductors since their discovery in 1986. Most of this writing reports and describes scientific research. However, some authors have sought to put this research in context: to assess where the field stands, what might be technically feasible, what might be economically feasible, and what potential impacts ceramic superconductors will bring to the electric power sector. This report's purpose is to make the results of already published assessments readily available.

To that end, this report lists and provides abstracts for various technical and economic assessments related to applications of High-Temperature Superconductors (HTS) to the electric power sector. Those studies deemed most important are identified and summarized.

These assessments were identified by two means. First, members of the Executive Committee identified some reports as worthy of consideration and forwarded them to Argonne National Laboratory. Twelve assessments were selected. Each of these is listed and summarized in the following section.

Second, a bibliographic search was performed on five databases: INSPEC, NTIS, COMPENDEX, Energy Science & Technology, and Electric Power Database. The search consisted of first selecting all papers related to High Temperature Superconductors. Then papers related to SMES, cables, generators, motors, fault current limiters, or electric utilities were selected. When suitable variants of the above terms were included, this resulted in a selection of 493 citations. These citations were subjected to review by the authors. A number of citations were determined to be inappropriate (e.g. a number referred to digital transmission lines for electronics and communications applications). The reduced list consisted of 200 entries. Each of these citations, with an abstract, is presented in the following sections.

After reviewing the assessments that have been published, several emphases have become apparent. The following comments about them may orient the reader to what is and is not available from the literature.

First, soon after ceramic superconductors were discovered, a series of assessments were begun in Asia, Europe and North America. These assessments sought to identify what performance would be needed from the new materials in order to compete with NbTi and Nb₃Sn.

Their results were usually expressed as the desired current density in the magnetic field thought appropriate to the application under discussion. Implicitly or explicitly, a design for a device was assumed. These designs were the result of earlier work on LTS. In effect, what was done was to assess a 77 °K version of NbTi.

Second, later assessments emphasized the technical feasibility and attendant difficulties of incorporating ceramic superconductors in various devices that would operate at 77 °K. Much attention was given to technical progress, little attention was given to economics and utility systems studies. The latter was judged premature by most potential sponsors. This continues to be the case.

Third, recently a few assessments have appeared that consider two issues: (a) the possibility of operating ceramic superconductors at 20 K and (b) how much the new superconductors could cost.

These considerations are important. At this time, several issues have not yet been fully explored. Assessments of the benefits and costs of operating at various temperatures have not yet been published. Such assessments could consider the state-of-the-art for cryo-coolers and for insulation. Neither has a new generation of designs for various devices been published. These designs might address smaller devices than previously considered and ones for which efficiency does not carry the same premium as it does when operating at 4.2 K. Such designs and devices are being considered in a few places, but they have not been broadly discussed and assessed. That remains for the future.

III. COMPREHENSIVE ASSESSMENTS

This section presents summaries of several assessments. Most were the combined result of the work of many authors and are comprehensive, that is they address most applications of interest to the power sector. A few assessments address a single topic, superconducting magnetic energy storage (SMES), giving it the emphasis appropriate to current interest.

The earliest summarized assessment was published in 1988 and the most recent was published in 1992. They were selected for summary for several reasons:

- a) the topics addressed are of interest to the power sector
- b) much of what was written about those topics is still reliable
- c) taken together the assessments are fully representative of what has been published.

These assessments may inform the setting of research direction and goals. A few remarks within some of them directly address the economic efficiency, reliability and safety of the electric power sector. However, technical progress has not yet plateaued and utilities are too varied for many authors to publish on these topics. Even more so, no systematic market surveys of future equipment sales have been published. These must wait until the performance of future devices is better defined.

The twelve assessments listed below are summarized in this section.

1. *Design Considerations for High-Temperature (High- T_c) Superconductive Magnetic Energy Storage (SMES) Systems*, Advances in Cryogenic Engineering, Vol. 37, part A (Plenum Press, N.Y.) 1992
2. *Conceptual Design Study of Superconducting Magnetic Energy Storage Using High Temperature Superconductors*, November 1991
3. *Proceedings of the First International SMES Workshop*, June 19-21, 1991 KfK Karlsruhe, Germany
4. *The Potential Impact of Developing High T_c Superconductors on Superconductive Magnetic Energy Storage (SMES)*, 1987, Applied Superconductivity Center University of Wisconsin-Madison, Madison, Wisconsin
5. *Superconductivity in Energy Technologies: Assessment, Concepts and New Aspects*, VDI-Verlag GmbH, Verlag des Vereins Deutscher Ingenieure - Düsseldorf, 1990.
6. *CIGRE 1990 Session (26 August-1 Sept.) Panel Discussion Impact of Superconductivity Technology on the Future Power Systems Technology*
 - 6a. *The Impact of Warm Superconductors (A Proposal for CIGRE Study Activities*
 - 6b. *Superconductivity: Problematics and Risks as Seen by Electricite de France*

- 6c. *Investigations and Developments in the field of Superconductive Turbogenerators*
- 6d. *Considerations about Superconductive Power Transformer Design*
- 6e. *Development of Superconducting Materials and Superconductivity - Applied Electric Power Apparatuses*
- 6f. *Current Limitation by Superconductive Transition*
- 6g. *Superconducting Devices for the Transmission, Conversion and Storage of Energy in Electric Systems*
- 6h. *Superconducting Magnetic Energy Storage (SMES) - Aspects of Technical Applications*
- 7. *Energy Applications of High-Temperature Superconductivity*, ER-6682, Vol. 1 (February, 1990) and ER-6682 Vol. 2 (November, 1990), Electric Power Research Institute, 3412 Hillview Ave, Palo Alto, CA 94303.
- 8. *Engineering Evaluation of High- T_c Superconducting Cables by Bean Model and its Assessment of Application to Urban Power System*, Electrical Engineering in Japan, 1991 Vol. 111 (no.1).
- 9. *Application Considerations for HTSC Power Transmission Cables*, Fifth Annual Conference on Superconductivity and Applications, September 24-26, 1991, Buffalo, N.Y. (USA)
- 10. *Compilation of International Progress in 1989 on High- T_c Superconductors*, KEMA Scientific & technical Reports, December 1990.
- 11. *Technological Impact of Superconductivity at Liquid Nitrogen Temperature Analysis of Opportunity Cases*, Canadian Electrical Association, Report 714 U 628, December 1989.
- 12. *Advances in Applied Superconductivity: A Preliminary Evaluation of Goals and Impacts*, published by Argonne National Laboratory, ANL/ CNSV-64 (January 1988).

Most of the assessments, listed above, are organized into sections which address specific topics.

Citation 1: *Design Considerations for High-Temperature (High- T_c) Superconductive Magnetic Energy Storage (SMES) Systems*, Advances in Cryogenic Engineering, Vol. 37, part A (Plenum Press, N.Y.) 1992

Authors: Y.M. Eyssa, X. Huang and R.W. Boom

Language: English

Summary:

This is an eight page paper. Its purpose is to present design considerations for small SMES, 0.1-100.0 MWh, with emphasis on large magnetic fields (e.g. 20 Tesla). Low aspect ratio solenoids ($\beta=0.1$) and toroids are described. The authors consider SMES configuration, structure, refrigeration stability and protection. A few of their salient observations follow.

One major challenge in the structural design of high- T_c SMES is the brittleness of the materials; the tensile strain in the conductor must be kept very small. We believe that precompression through cooldown is the best design solution. We select a structural material with a higher thermal contraction, α_s , from 300 K to 77 K than the superconducting material, α_c . The conductors are fixed to the structure at room temperature. During cooldown the much stiffer structure forces the conductor to undertake the structure's contraction. At 77K, structure is essentially stress free whereas conductors are compressed. If the difference in thermal contractions, $\alpha_s - \alpha_c$, is the structure strain limit under magnetic pressure, then the magnetic loading would partially release the conductor's precompressed stress and the conductor would never go into tension during operation. The major refrigeration loads for small SMES magnets are electrical leads and thermal radiation. The lead loss in small SMES is the major loss. As shown, SMES at 77 K as small as 1 MWh, can be efficient if cycled once a day. If high T_c -SMES is cycled several times per day then units smaller 1 MWh are acceptable. Cryostability at 77 K is an expensive option for SMES as it requires a large amount of stabilizing materials. Fortunately, intrinsic stability under adiabatic conditions of superconductors at 77 K is very high, because the large specific heat, C at 77 K makes the superconductor highly stable against both internal and external disturbances. The protection of high- T_c should be similar to low T_c magnets. The major difference is that the propagation speed is about 2 to 3 times of magnitude smaller for the high T_c coils. Thus protection using dump resistors is as safe for high T_c magnets as it is for low T_c magnets unless very large values of J_0 are used at small currents and higher energy stored. This may necessitate the use of a passive protection scheme such as quench back.^{10,11} Small high T_c coils must use one of the above protection schemes. The authors conclude that high T_c SMES magnets at 77 K are one order of magnitude more efficient than helium cooled magnets. Small coils can be supported by cold structure that is biaxially stressed to minimize structural mass. Precompression is used to avoid tensile stresses in winding. The use of external dump resistor is shown to be safe scheme for protection.

Citation 2: *Conceptual Design Study of Superconducting Magnetic Energy Storage Using High Temperature Superconductors*, W.J. Schafer Associates, Inc., 6140 Stoneridge Mall Road, Suite 385, Pleasanton, CA 94566, (February 1992)

Authors: S.M. Schoenung, W.R. Meier, W.J. Schafer, R.L. Fagaly, M. Heiberger, R.B. Stephens, J.A. Leuer, R.A. Guzman, E.R. Johnson, J. Purcell, L. Creedon, and J.R. Hull

Language: English

Summary:

This assessment is 158 pages. It was prepared for the U.S. DOE who sponsored this study to assess a SMES design that takes account of both positive and limiting features of today's HTS materials. The major elements of this conceptual design study addressed coil configuration, HTS conductor configuration and parameters, mechanical modeling and analysis, thermal modeling and analysis, and cost estimates of major components. Section 2, Design Criteria, describes the initial assumptions of this study. Section 3, Baseline Configurations, describes the modular approach, scaling, and physical parameters of the torus and solenoid. Section 4, HTS conductor, presents our projections of the state-of-the-art in HTS applied to SMES, calculations of stability and losses, and conclusions regarding HTS development needs. Section 5 describes our mechanical model and mass results. Section 6 describes our thermal model and refrigeration results. Section 7 presents estimates of relative material costs for HTS and LTS toroids and HTS solenoids. Section 8 summarizes our recommendations and conclusions.

A conceptual design for SMES using HTS has been analyzed for design features, refrigeration requirements, and estimated costs of major components. The study covered the energy storage range from 1 to 250 MWh at power levels sufficient for charge or discharge within a half hour. This range covers utility applications from transit and power stabilization to spinning reserve and load leveling. A 20 MWh unit was analyzed in detail. A conventional system would use liquid helium as coolant at either 4.2 Kelvin (K) or 1.8 K. The design for HTS uses gaseous helium at 20 K. Future systems might use liquid nitrogen at 77K.

The assessment was done for a cold-supported, modular torus, and for comparison, a cold-supported modular solenoid. The toroidal configuration was chosen for analysis because it has minimal external magnetic field, which could be an advantage in locating a small unit near a utility or customer load. The comparison shows that for most cases the solenoid is less expensive, but has an external magnetic field which must be accommodated. The modular approach was selected primarily as a way to wind the coil and keep the brittle oxide superconductor under compression at all operating conditions to avoid breakage. The present state of the art in high T_c superconductors was projected to the kilometer long wires needed for a cycling SMES device. Silver-clad Bismuth based superconductor is the only form which is likely to be available in the near future. This wire should have a cross-section of approximately 1 cm² and carry 10 kA in fields up to 10 Tesla (T) and operate at up to 0.2% strain. For satisfactory performance it must be made in the form of twisted multifilaments rather than the flat tape form which is presently receiving the most attention.

The results show that an HTS-SMES system operating at high magnetic field (e.g., 10T), can be more compact than a comparable, conventional low-temperature device at lower field. The refrigeration power required for a high temperature unit (20 to 77 K) will be less by 60 to 90%. The improvement in energy efficiency is significant for small units, but less important for large ones. The material cost for HTS units is dominated by the cost of superconductor, so that the total cost of an HTS system will be comparable to an LTS system only if the superconductor price in

\$/Ampere-meter is made comparable (within a factor of 2) by increasing current density or decreasing wire cost.

Citation 3: *Proceedings of the First International SMES Workshop*, June 19-21, 1991 KfK Karlsruhe, Germany

Authors: edited by K.P. Jungst, P. Komarek, and W. Maurer

Language: English

Summary:

The proceedings of this meeting consists of two volumes, including 532 pages. The proceedings document 27 talks by participants from Asia, Europe, and North America. An executive summary and summaries of three round table discussions are also included. Collectively the proceedings provide a comprehensive introduction to present activity SMES. The individual talks are shown below.

Talks #1 and #3 introduce the service to be performed by SMES and its economic roles in the utility system. Each utility has its particular need for storage and power; these can vary from negligible energy and high power (i.e. load conditioning) to a need for an intermediate power (i.e. 5 GWH, 1GW). Talk #12 emphasized the possibility of using BSSCO to make a SMES that operates at LH₂ temperature. Talk #13 reported progress on the study whose report is summarized on p. III-4 of document before the reader. Talk #17 reported that Siemens is evaluating small and medium sized SMES incorporating HTS. Talk #23 suggested the possibility of using arrays of small, HTS coils whose combined behavior would be that of a large magnet.

Table 3.1 KfK Workshop Presentations

Talk # Session 1

1	The Role of Energy Storages in Large Electric Systems	E. Hoffmann
2	The SMES Viewed from Electric Power Utility	F. Fukui
	Additional paper: Some Results of System Dynamic Tests with a SMES Connected to Ariuragawa Power Station	O. Katahira
3	Wisconsin SMES-The Utility Benefits	D.E. Ellestad
4	The EPRI Perspective on SMES	W. Hassenzahl
5	SMES Engineering Test Model Program Update	S. Schoenung

Session II

6	Perspectives on the Bechtel SMES/ETM	T.E. Walsh
7	The EBASCO/SMES Team-An integrated system approach to the Superconducting Magnetic Energy Storage - Engineering Test Model (smes-ETM) and beyond	B.J. Lowe R. Verga
	Addition paper: SMES - A powerful Approach to Energy Conservation	B.J. Lowe, R. Scully

KfK Workshop Presentations (Cont'd)

Session III

8	Introduction and Remarks on Japanese Activities	M. Masuda
9	Research Activity of SMES in ISTEK	E. Masada
10	RASMES Research Activity of Research Association of SMES	T. Tanaka
	Additional paper: Research Activity of Research Association of SMES	T. Tanaka
11	Research Activities on SMES in USSR	V.B. Zenkevitch
12	The Impact of High T_c Superconductivity on Large Scale SMES, Economics and Technology	M. Iwamoto
13	Conceptual Design Study of Superconducting Magnetic Energy Storage Using High Temperature Superconductors	S. Schoenung
14	Design Considerations for Small-Scale SMES A Superconductivity Pilot Center Program	S. Schoenung

Session IV

15	SMES Size Considerations for Bulk Storage	R. Boom
16	Energy Conservation and Environmental Benefits to be Derived from SMES Implementation	Ph. Baumann
	Additional paper: Superconducting Magnetic Energy Storage: A Commercial Opportunity	P.D. Baumann
17	Economical Aspects of Medium Sized Superconducting Energy Storage Systems (SMES) in the Electric Power Supply	H.-E. Vollmar
18	SMES-Use for Photovoltaic Solar Generators	K.-P. Jüngst
19	Industrial Use of Small SMES, Economical and Technological Aspect	M. Masuda
	Additional paper: Economical and Technological Aspect of Small SMES	M. Masuda
20	Industrial Activities Relevant to SMES Technology	N. Asami
21	The Experimental Study of Electric Power Network Stabilization by SMES	H. Fujita
22	SMES activities at Toshiba	T. Fujikura

KfK Workshop Presentations (Cont'd)

23	Activity in UK for High T_c Superconductivity	A.D. Appleton
24	Joint works done in Quebec and France on a 300 MJ 300 MVA SMES	I.L. McDougal J.-L. Sabrié G. Begin
25	The 50 kWh-SMES Demonstration at the Paul-Scherrer-Institute - A joint Swiss Project between PSI and ABB	E. Halder G. Vecsey M. Häusler
26	Electromechanical research on small SMES systems	H.W. Lorenzen
27	Recent Activity of Hitachi LTD	N. Suzuki
	Additional paper: Power Control Experiments Using a 5 MJ Superconducting Magnetic Energy Storage System	Y. Ishigaki

Citation 4: *The Potential Impact of Developing High T_c Superconductors on Superconductive Magnetic Energy Storage (SMES)*, 1987, Applied Superconductivity Center University of Wisconsin-Madison, Madison, Wisconsin

Authors: Y.M. Eyssa, M.K. Abdelsalam, R.W. Boom and G.E. McIntosh

Language: English

Summary:

This is a six page paper, written in 1987. Its purpose is to evaluate the impact of recent discoveries of high T_c superconductors on SMES technology for electric utility load leveling. The authors consider a family of low aspect ratio ($\beta=0.02$) solenoids having 3.73 Tesla mid plane magnetic field. The smallest member of the family stores 10 MWH and the largest stores 10,000 MWH. Several tables present numerical results as a function of stored energy. Three areas are addressed: refrigeration power requirements, SMES design and economics. With regard to refrigeration, the authors conclude that for SMES or other superconducting magnets operating at high temperatures there is no need for continuous or discrete cooling for either electrical leads, low conductivity mechanical supports or superinsulation. Cold end ac losses which are inversely proportional to normal conductor resistivity, such as eddy current and coupling losses, are extremely small and can be neglected compared to lead, strut or radiation load. With regard to stability design, the authors observe the a major factor that would enhance the stability of high T_c superconductors is the very high specific heat of metals at 77 K which is 3 orders of magnitudes higher than at 4 K. Large energy disturbances should not raise the conductor temperature beyond one or two degrees. The use of copper or aluminum with high T_c superconductors should be aimed toward protection rather than stability. With regard to Dewar and Structure there will be strong motivation to build a simple, reliable insulated structure with minimum cryogenic technology requirements. For instance, it may be cost effective to use non-vacuum purged perlite insulation instead of a conventional evacuated dewar. Use of a non-vacuum insulation system reduces the liquid container and vacuum jacket cost as well because it eliminates 1 atm of pressure differential. Another possibility is to combine struts and insulation into powder-filled fiberglass/epoxy honeycomb. This configuration would greatly simplify the struts and uniformly distribute radial loads but it would probably require a vacuum because of cracks and fit-up problems. Because cool down forces at 77 K is not much different than at liquid helium temperature, we do not expect that the basic structure of a SMES unit should be different for liquid nitrogen superconductors. With regard to economics, the authors discuss how refrigeration costs scale with size. They conclude that high T_c SMEs are to be expected to be more economically attractive to utility applications specially for small units. Thermal analytical analysis shows no need for heat intercepts to reduce the refrigeration power. High T_c conductors would impact the dewar more than the structure design of SMES. SMES should be more reliable at 77 K than 1.8 K.

Citation 5: *Superconductivity in Energy Technologies: Assessment, Concepts and New Aspects*, VDI-Verlag GmbH, Verlag des Vereins Deutscher Ingenieure - Düsseldorf, 1990.

Authors: C. Albrecht, R. Altpeter; G. Bogner; W. Engl; R. Flükiger, P. Frey, H.P. Gröter, E. Handschin, E. Häuber, L. Intichar, B. Jahnke, K.W. Kanngießer, J. Kärner, P. Komarek, H. Krauth, D. Krischel, D. Lambrecht, H. Lennertz, H.W. Lrenzen, H. May, U. Nienaber, H. Quack, W. Rehm, H. Rietschel, J. Schaller, W. Seele, A. Stephan, P. Stöber, A. Ulbricht, K.-H. Unkelbach, H.-E. Vollmar, H. Weh.

Language: English

Summary:

This is a 266 page book. It was written by and for scientist and engineers working in industry, large-scale research institutions, universities and other research and application fields to help further their knowledge in this field. Apart from the current state of the art, the book also describes future application and development possibilities for the superconductor in power engineering. The various components of current conversion and transmission for power station engineering and current transportation are also investigated, not to mention the limits of the practical restructuring of today's highly efficient high-voltage network.

The book focuses on the following topics:

- general introductions
- materials: requirements, properties, manufacture, processing
- cryotechnology
- machines, cables, switches, transformers
- energy storage
- magnetic engineering for fusion, transport and mass separation
- magnets for particle accelerators
- promotional activities, economy, patents

Each of these topics is addressed in several sections by one or more authors. Below, are some salient remarks on HTS by several of these authors.

Concerning the manufacture and properties of oxide superconductors, B. Jahnke writes that , "if it should be possible to develop thin-layer processes with sufficient current densities on polycrystalline substrates which can be used technologically, the assumption that only thick-layer processes or massive materials such as wires or massive fibers are significant for energy technology must be reconsidered, since the proportion of superconductor material compared to a wire of 1 mm diameter is only about a factor 0.5 in a coating of fibers of a few micrometers diameter. If it should hence be possible to deposit thin films on technically utilizable substrates with current densities of the order of 10^5 A/cm², this would correspond to an effective current densities of massive material of about $5 \cdot 10^4$ A/cm². The fields of advanced ceramic technologies with strong texture and the thin-layer technique would thus overlap and other properties of the materials and the further process steps would attain greater significance. In addition, the extreme brittleness of the oxide materials in thin-layer processes plays hardly any role. Thus coated fibers with diameters of 5-10 µm and layers of about 1 µm should still permit bending radii of a few centimeters. Beside the problems considered up to now, the questions of further process steps, e.g. joining processes with their contact problems, the longterm stability as well as the alternating current losses and pinning behavior are still largely unclarified today. However, they should be

investigated as soon as possible in terms of a rapid technology transfer and for further appraisal of the possible processes."

Concerning cryogenic refrigeration for HTS, H. Quack writes that, "This temperature range [80 K] had been neglected by the manufacturers of refrigeration plants in the last years since there exists a large competition with the shipped-in supply of liquid nitrogen from large air separation plants. When is an own refrigeration plant cheaper and when the shipped-in supply? The following table shows some characteristic fields of application:

Shipped-in supply of the liquid nitrogen	Local production of the refrigeration
Cooled object with contact to air Load peaks Short-term refrigeration requirement	Thermally insulated cooled object Constant load Long-term refrigeration requirement

Concerning generators, L. Intichar and D. Lambrecht write that, "If they [*i.e.* HTS] could be used in generators, the refrigerator could be reduced in size, - being thus less expensive -, provoking in such a way a development culminating in shifting of the commercial efficiency limits for superconducting generators to smaller ratings. There were practically no changes regarding electrical design. The mechanical problems, as e.g. the tight attachment of the superconducting winding will also remain the same or will get even more demanding, if a possible lower ductility of the superconductors is taken into consideration. Each operation far below ambient temperature still requires an excellent thermal insulation if the refrigeration power and such, the refrigerator, are to be actually smaller. The thermal shrinkage of all materials down to 77 K is nearly equivalent to that of 4 K, *i.e.* the problems are the same. As calculations have shown the total refrigeration system would function with nitrogen equivalently well and with absolutely comparable values as with helium. Accordingly, rotor design would remain nearly the same, there were only a few facilitation's with regard to some details: e.g., the radiation shields could be dispensed with. Something which would also not be changed were the requirements on the appropriate superconductors, especially regarding mechanical properties and current density. The new ceramic conductors are currently far from complying with these requirements.

Concerning shaping the magnetic field by passive use of HTS, H. Weh and M. May write that, "with the aid of high-temperature superconductor (HTSC) screens, one can affect the field distribution and thus the force generation. The exploitation of the magnetic circuits becomes more efficient....improvements are possible in the operation of the reluctance machine based on the edge effect. For transverse flux machines, the application of HTSC screens and coils leads to considerable improvements in the force density. Estimates show that, by using high-energy permanent magnets, an even larger potential is created for the reduction of machine dimensions and masses."

Concerning cables, G. Bogner writes that, "The change to the 77 K superconductivity [*from 4 K*] shifts the competitiveness to the 1,000-2,000 MVA range [*from 4,000 MVA for 3 phase AC cable*]" He further writes, "changing over from the 4 K to the 77 K superconductivity results in a noticeably smaller and simpler cryogenic envelop. if the lower costs of the cooling stations (the distance in approximately 10-20 km was in the case of 4 K cables) and the coolant are also taken into account, the investment costs for 77 K cables at equal costs for the cable cores are about 25% lower than for 4 K cables with the same load rating." According to Table 4.6-2, the investment costs for 77 K cables in the 1000 to 2000 MVA power range are nevertheless 10 to 20% higher than for conventional cables. The superconducting systems only have the edge, and this even in the 1000 MVA power range, when the capitalized loss costs are taken into account. These are a factor of 7 to 8 lower for 77 K cables than for conventional cables. In estimating the

50 Hz current losses, it was assumed that the current density in the superconductor was $j_c \approx 10^5$ A/cm², superconductor layer thicknesses or filament diameters were 20 μ m and the loss factor for the wound nitrogen-impregnated PE tape insulation was $\tan \delta \approx 3 \cdot 10^{-4}$. The efficiency of the refrigerating system was included as being 10%. Not included are the sealing end losses of the 77 K cables which have been estimated to be approx. 20 kW per 1000 MVA.

Table 4.6-2 Cost Comparison of Conventional and Superconducting 77K-ac Power Cables according to G.Bogner

Cable Type	380 kV Single Conductor Oil Cables in Parallel External H ₂ O Cooling		110 kV 77 K Superconducting Cable, Semiflexible	
Rated power per circuit MVA	1000	2000	1000	2000
Investment costs inclusively cooling; but without cable trench 10 ⁶ DM/km	4.8	6.2	5.2	7.3
Transmission losses kW/km	210	300	25	40
Capitalized losses 10 ⁶ DM/km (10 ⁴ DM/kW)	2.1	3.0	0.25	0.40
Total costs (without trench) 10 ⁶ DM/km	6.9	9.2	5.5	7.7

Concerning transformers, Bogner writes, "[The impacts of 77 K superconductivity] were studied on the basis of a single-phase model 850 MVA generator transformer. Table 4.6-5 compares the results with a conventional 5-leg transformer. 220 V was selected as the effective winding voltage for the superconducting version; at the input end this results in a nominal current of 10.5 kA and 136 turns. The following assumptions were made regarding the high-temperature superconductor: Critical current density at 0.3-0.5 T and 77 K: 10^5 A/cm². Filamentary conductor with about 260,000 filaments each 10 μ m in diameter. A suitable conductor is, for example, a band-shaped conductor with filament bundles wound around a carrier tape, of steel for example. $2.5 \cdot 10^3$ A/cm² were assumed as the overall current density in the windings; the space needed for armour, stabilization and cooling was taken into account. 200 kW/m³ was estimated for the 50 Hz steady-state losses in the conductor. In addition was assumed that, when a short-circuit occurs, either the transformer windings themselves or other current-limiting devices (see Section 4.6.2) limit the short-circuit current in the network to 2 to 3 times the nominal current.

Where the investment costs in the comparison in Table 4.6-5 are concerned, we assumed that the material savings in the superconducting version are at least compensated by the more

complicated technology. The possible economic advantage of the superconducting type therefore results solely from the capitalization of the far lower 50 Hz losses."

Table 4.6-5 Comparison of a conventional 850 MVA (27/420 kV) Generator Transformer with a 77 K Superconducting Transformer (single phase type) according to G.Bogner

	Conventional	77 K-Superconductor
Investment costs	12 Mio DM	≥ 12 Mio DM
Iron mass	280 t	80t
Mass of windings	60 t	10 t incl. cryostat
Total mass	520 t	100 t incl. LN ₂ without coil
Iron losses (at 300 K)	370 kW	100 kW
Winding losses (at full load and 300 K)	1450 kW	100 kW
Cryostat losses inclusively bushings referred to 300 K*)	-	40 kW
Capitalized iron losses ¹	4.5 Mio DM	1.2 Mio DM
Capitalized winding losses ²	7.3 Mio DM	0.5 Mio DM
Capitalized cryogenic losses ³	-	0.4 Mio DM
Total capital costs	23.8 Mio DM	≥ 14.1 Mio DM

*Efficiency of refrigerator: 10%

¹12000 DM/kW

²5000 DM/kW

³10000 DM/kW

Concerning the economic and technical consequences of HTS, H. Lennertz compares ohmic losses to refrigeration losses. (No account is taken of other issues, such as power density.) He writes, "in the long run economical solutions stand out only with superconducting generators and possibly with generator transformers. Today's common three-phase power supply with hierarchical voltage levels will endure also with superconductivity. An introduction of power transport by high-voltage D.C.-grids can be excluded because of economical reasons. Superconductive power storage and switchgear are not discussed in this essay."

Citation 6: **CIGRE 1990 Session (26 August-1 Sept.)**
 Panel Discussion
 Impact of Superconductivity Technology on the Future
 Power Systems Technology

Every other year, CIGRE convenes an international meeting. At its most recent meeting, in 1990, the subject panel discussion was held. Nine papers were presented. Some addressed HTS; others mentioned HTS while reporting work on LTS. Below we summarize these papers, giving most attention to what was written about HTS.

Title 6a: *The Impact of Warm Superconductors (A Proposal for CIGRE Study Activities)*

Author: E.F. Steennis

Language: English

Summary:

This 12 page paper discusses in general terms the impact of HTS on various proposed electric power applications and concludes with a proposed action plan for future CIGRE activity in the field of HTS. For each application, a summary of past and ongoing activities is presented along with a list of the relative advantages associated with each superconducting application.

The paper concludes that an HTS generator could produce efficiency gains of .03-.2 % relative to an LTS generator, operate at higher voltages, and have a simpler design leading to a reduced break-even point (below 300 MVA). The paper calls for further study of network stability issues, quantification of the break-even point, and continued work on understanding the consequences of quenching and reliability.

The paper concludes that an HTS transformer should be more efficient and have a simpler structure than an LTS transformer leading to a lower break-even point. The paper calls for further work in understanding operation during a quench, possible current-limiting action, reliability, and quantification of the break-even point for LTS and HTS transformers.

The paper concludes that the economic feasibility of SMES is still uncertain. An HTS-based SMES could have reduced construction and insulation problems. However, the economic impact is likely to be small, 3-8 % relative to an LTS-based SMES. The paper calls for further study of the likely economic feasibility of SMES, impacts on network reliability and environmental problems associated with the magnetic field.

The paper concludes that the likely break-even point for either an LTS-based or HTS-based AC cable is too high (in excess of 2 GVA). Further studies are needed to quantify the likely break-even point of an HTS-based cable. An HTS-based DC cable is likely to find application only with DC-sources such as solar energy and MHD or DC-loads such as electrolysis and traction.

The papers concludes that because of the potential for large heat leaks the economic impact of an HTS-based fault-current limiter (FCL) could be large. Since present prototype FCLs are very far from practical use, economic feasibility studies are impractical. However, system studies of network behavior with FCLs should be performed (particularly with other superconducting elements in the network).

Additional studies are needed to indicate the economic feasibility of LTS-based and HTS-based, small-scale SMES applications such as power regulation. System studies are required to determine the effect of small-scale SMES on network stability and power regulation.

The paper recommends that CIGRE not investigate the impact of HTS on magnets for various application because of the relatively small impact such devices will have on electric supply.

The paper also recommends system studies on the technical and economic impacts of introduction of one or more superconducting components on the power network, study of the behavior of electrical insulating materials under cryogenic conditions, and development of test procedures, specifications, and normalization for the various components mentioned above. The paper concludes with a recommendation for CIGRE to coordinate the cooperate with the IEA Superconducting Expert Group.

Title 6b: *Superconductivity: Problematics and Risks as Seen by Electricite de France*

Author: G. Le Roy and F. Meslier

Language: English

Summary:

This 5 page paper discusses Electricite de France's (EDF's) views concerning applications of superconductivity to their system. EDF views superconducting devices (both LTS-based and HTS-based) as providing the potential for evolutionary, not revolutionary, changes to their system in the 2010-2020 time frame. The paper summarizes the status of LTS and HTS conductor development in general terms and listed a number of outstanding issues related to conductor development.

The paper briefly summarizes five applications -- synchronous machines, transformers, current limiters, energy storage, and superconductive links --, identifies issues that could affect their operation within an utility network, and indicates what effect successful development of HTS conductors might have. EDF considers fault-current limiters and synchronous generators as the most promising near-term applications of superconductivity to their system and suggest the need for system studies to determine the impact of various generator designs upon network performance.

The paper concludes with five guidelines for continued research and development: (1) study issues related to 50/60 Hz conductors including mechanical behavior, insulation properties, cooling, aging studies, and current leads, (2) issues relate to superconducting, rotating machinery such as mechanical problems, generator modeling, machine dimensioning, and the effect of insertion on network performance, (3) issues related to SMES (large and small) including magnetic field strength, analysis of technical and economic advantages, conductor design, operational modes, sizing, and power electronics, (4) issues related to fault-current limiters including analysis of technical and economic advantages and reduction of time delay for return to superconducting operation, and (5) issues relate to HTS conductors including studies of J_c limitations, how to shape conductors, analysis of return to superconducting state, and design studies to optimize device performance and cost using HTS conductors.

Title 6c: *Investigations and Developments in the field of Superconductive Turbogenerators*

Author: I.A. Glebov and L.I. Chubraeva

Language: English

Summary:

This 4 page paper describes the efforts of the USSR to develop a superconducting generator. The paper describes the design and tests of a 20 MVA generator, design and construction of a 300 MVA generator, and computer modeling of a 1200 MVA generator. Also, the paper briefly describes several novel, small-scale, HTS electric motors built in the USSR. In early 1989, three machines were built, using YBCO. They were an induction motor with permanent magnetic field, induction motor with rotating magnetic field, and a flux pump. No information about size or economics is presented. However the following is written:

Novel motor of the first type consists of two rotating discs. One of the discs bears permanent magnets and is rotated from an external motor. On the other disc hollow cylinders of Y-Ba-Cu-O ceramics are positioned. When the circular duct of the latter disc is filled with liquid nitrogen, the ceramic cylinders become superconducting. The current induced in the cylinders interacts with the permanent magnets and creates the torque which rotates the second disc with a synchronous speed.

Motor of the second type incorporates a stationary cylindrical copper three-phase winding producing rotating magnetic field. The rotor is a combination of a cylinder made of glass-reinforced plastic and another cylinder of Y-Ba-Cu-O ceramics positioned inside the first one. The inner space is filled with liquid nitrogen. Due to the SC state of a ceramic cylinder it is accelerated by a magnetic field up to the field speed and operates with a zero slip. Thus, we have a synchronous motor with no external supply for the rotor winding.

A specific feature of the third type machine, i.e. the flux pump, is the fact that its armature is a hollow cylinder made of HT SC ceramics. Excitation coils create a homopolar magnetic field on its surface which is concentrated by means of rotating poles.

Title 6d: *Considerations about Superconductive Power Transformer Design*

Author: W. Müller

Language: English

Summary:

This 5 page paper discusses the design of an LTS-based superconducting transformer. The paper contains no discussion of HTS conductors nor any discussion of the relative economics of a superconducting transformer. The paper concludes that a superconducting transformer would be more compact and have lower losses than a conventional transformer (the capitalized value of losses in a conventional transformer is comparable to its capital cost).

Title 6e: *Development of Superconducting Materials and Superconductivity - Applied Electric Power Apparatuses*

Author: Y. Sekine, K. Uyeda, H. Katsuya, and M. Iwasaki

Language: English

Summary:

This 4 page paper summarizes Japan's efforts related to superconducting technology for the electric power sector. The paper provides a discussion of feasibility studies performed for generator and SMES and determines conductor requirements for several applications. The paper states that the requirements for LTS (LHe) and HTS (LN₂) are not much different.

Table 3.2 Conductor Requirements According to Y. Sekine et al.

Applied Apparatus	Apparatus Capacity	Requirements		
		Current Density (A/mm ²)	Magnetic Field (T)	AC Loss
Generator	0.3-1 GW 20-30 kV	150-225	5.7-6.9	10-40 kW/m ³
Transformer	1 GVA 22/500 kV	100	<0.5	50 kW/m ³ at 1 T
Power Cable	1-3 GW 66 kV	100-200	0.3	0.2 W/m ²
SMES	5 GWh 3.6 kV	30	8.0	-

This paper includes a discussion of design tradeoff for a superconducting generator. The paper includes no economic assessments.

Title 6f: *Current Limitation by Superconductive Transition*

Author: V.D. Pham, Y. Laumond, T. Verhaege, A. Fevrier, M. Collet, and M. Bekhaled

Language: English

Summary:

This 6 page paper begins with an overview of fault-current limiter concepts. It presents work by ALSTHOM. The paper concludes by stating that: For future networks equipped with superconducting generators and transformers, the presence of superconducting current limiting devices will be more than necessary in order to avoid harmful transitions on these large machines, owing to faults on the line. The use of superconducting limiting devices on future multiterminal HVDC networks will be useful for the rapid limitation of high fault currents. Although the paper does not discuss HTS, it does emphasize the importance of small AC losses - a topic that has not attracted attention among those engaged in HTS research.

Title 6g: *Superconducting Devices for the Transmission, Conversion and Storage of Energy in Electric Systems*

Authors: Yu.A. Bashkirov, I.V. Yakimetz, Yu.V. Skobarikhin, G.G. Svalov, V.Ye. Sytnikov, K.I. Seryakov, M.S. Lazarev, Yu.N. Astakhov, A.G. Ter-Gazaryan, Yu.N. Vershinin, V.V. Andrianov

Language: English

Summary:

This four page paper presents the performance and the results of experimental research on pilot and mock-up models of superconducting cables, resistive - and inductive-type switching devices, converters for superconducting magnetic system supply and magnetic energy storage in the USSR. The authors remark that the economy of superconducting transmission cables can be substantially improved due to the discovery of high- T_c materials and, no less importantly, a lower break-down point can be ensured (according to many estimates, 1.5 to 2.0 GVA). The authors also report that the Power Engineering Institute and the Electrotechnical Institute conducted theoretical and experimental research on the simplest model of a fault-current limiter. Superconducting devices for the transmission, conversion and storage of energy in electric systems mock-up was built of a fault current limiter, using a YBCO shield around a ferro-magnetic core. The experiments with such a reactor confirmed current-limiting characteristics with transition from low to high inductance.

It is essential that current limitation do not destroy superconductivity in the shield. A possibility appears of high-speed suppression of shielding currents by applying control current pulse, because in bulky high- T_c ceramic devices the shielding of a.c. magnetic fields is secured due to the passage of superconducting transport current across weak links between the superconductor grains[3].

The feasibility of a resistive-type high- T_c current limiter of series connection to the protected circuit was studied. The contradictory requirements demanding a minimum magnetic field at a rated current and a rather high one under current limitation can be met by bifilar arrangement of the high- T_c element inside the normal metal coil connected in parallel. If the critical current is exceeded, the resulting voltage drop in the high- T_c element will lead to the appearance of

current in the coil and, accordingly, of magnetic field, which will cause further voltage rise in the current limiter. The obtained current-voltage curve for such a current limiter is of a jumpy nature - after attaining a certain current exceeding the critical one it turns into a negative unstable branch, and further current growth must result in abrupt transition to a resistance which is evidently close to the normal-phase resistance of the high- T_c superconductor.

If manufacturing methods for high T_c bulky devices are developed with critical current densities of at least 10^8 A/cm² in fields of the order of 1 T at liquid-nitrogen temperatures and above (which is quite realistic) in the next few years, the prospects of their extensive use in electric systems for current-limitation purposes can be rather favorable even at the end of the decade.

Title 6h: *Superconducting Magnetic Energy Storage (SMES) - Aspects of Technical Applications*

Authors: J.F. Kärner, H.W. Lorenzen, W. Rehm

Language: English

Summary:

HTS was not discussed. This paper presents some technical aspects and criteria being important for application and operation of superconducting magnetic energy storages (SMES). Coil design and external field of SMES are briefly described and evaluated relating to storable magnetic energy and impacts on environment. A particularly important quantity concerning economic operation of energy storages is the so-called cycle efficiency. Finally the range of application is deduced from a comparison of the advantages and disadvantages of SMES - plants, and possible applications are listed.

Title 6i: *Prospects Offered by New High Critical Temperature Superconducting Materials for Electrical Power Transmission*

Author: I. Deschamps, JC Bobo, G. Bogner, S. Isojima, Z. Iwata, D. Jacobson, K. Kriechbaum, H. Mayer, P. Metra, E. Occhini, R. Roberoe, and R. Samm

Language: English

Summary:

This 9 page paper begins with a brief summary of HTS properties including: crystalline structure, critical current density, AC losses, and thermo-mechanical properties. Various manufacturing techniques used to process HTS materials are summarized. The balance of the paper discusses desired conductor characteristics, prospects for application of HTS to power cables, and technical and economic factors affecting power cables.

The paper summarized several recent economic analyses performed in Japan, Canada, and the United States. The paper then qualitatively examines the likely technical and economic impact of HTS on power cable design such as voltage, current, and power levels, transmission distances, voltage control and stability, short-circuit operation, and reliability and availability. HTS power cables will likely operate at lower voltage and higher current and power levels than conventional

underground cables. Due to a lower surge impedance, HTS cables will operate more like overhead lines and require little compensation. The paper concludes that: (1) a current density of at least $1,000 \text{ A/mm}^2$ ($100,000 \text{ A/cm}^2$) at 0.1 Tesla and 77 K will be required for an AC cable; (2) Refrigeration losses will be substantially lower than for an LTS cable leading to possible economic savings of 20 to 40 %; (3) Global optimization of the network to account for differing characteristics of HTS-based power cables needs to be performed; and (4) discovery of a room-temperature superconductor could revolutionize network design and operation.

Citation 7: *Energy Applications of High-Temperature Superconductivity*, ER-6682, Vol. 1 (February, 1990) and ER-6682 Vol. 2 (November, 1990), Electric Power Research Institute, 3412 Hillview Ave, Palo Alto, CA 94303.

Authors: S.J. Dale, S.M. Wolf, and T.R. Schneider

Language: English

Summary:

This assessment was published in two volumes. The first volume appears on 89 pages and is subtitled, *Extended Summary Report*. The second volume appears on 521 pages and is subdivided into 11 Chapters. The second volume is subtitled *Detailed Assessment*.

These two volumes are the result of work sponsored by the U.S. DOE and EPRI. The second volume is an anthology. More than 25 individuals at four national laboratories and several nongovernment laboratories and consultants performed the work. An industry advisory team provided constructive comments throughout the project and in reviewing the chapter reports. Each chapter of the second volume was prepared by one or more authors and each chapter deals with a distinct topic. These topics are Electric Motors, Power Electronics, Transportation, Magnetic Heat Pumping, Electromagnetic Pumps, Materials Fabrication, Materials Production, Separations, and Lighting. Although most of these refer to the uses of electricity on the customers' side of the meter, two topics, Electric Motors and Power Electronics, are of direct interest to utilities.

The assessment of Power Electronics was prepared by C.H. Nowlin. His abstract follows.

This study recommends immediate research and development of an electric-field-controlled thin-film superconducting switch for power applications. The principal application area for such a switch would be in motor controllers for superconducting motors of >500 hp. currently, 61×10^9 kWh/yr are consumed by such motors, and they would likely be the first motors replaced by superconducting motors.

Superconducting motors will likely be similar to permanent magnet motors, with the permanent magnets on the rotor replaced by superconducting coils in which flow permanently circulating currents. Motor controllers will be needed for each of these motors to switch currents in superconducting stator coils that generate a rotating magnetic field of the appropriate frequency. Without superconducting switches, \$170 million of electric power will be dissipated each year in semiconductor motor controllers, for just the motors of greater than 500 hp.

Josephson junction type switches cannot control the needed voltages and currents because they are limited to milliamperes and millivolts. a superconducting thin-film-type switch is the most promising because it is the only type that can carry the necessary "on" current and withstand the required "off" voltages.

The operating principle of a thin-film superconducting switch is the quenching of the superconductivity to turn the switch "off". The insertion resistance of the thin film is thus changed from zero to its normal state resistance.

Two technical achievements are needed to immediately construct an economically viable superconducting switch from the 90-K superconductors. The first is increase of the $\rho_0 J_c$ product, where ρ_0 is the thin-film normal state resistivity and J_c is the thin-film critical

current density, by a factor of 10 to a value of 10^4 A/cm. Such an achievement would result in such low superconducting switch losses that superconducting power switches would be economically superior to semiconducting power switches even when cooling costs are included. The second is development of a practical method of quenching thin-film superconductivity.

Superconductivity can be quenched in thin films by any one of three techniques. The first method, thermal quenching, is accomplished by simply raising the thin-film temperature above the material's critical temperature. However, this method wastes energy, and turning the switch back "on" requires lowering of the material temperature again.

A second way to quench superconductivity is by increasing the magnetic field in the superconductor above its critical field. However, extremely large currents are needed to switch a high-power switch because such a switch inherently requires a large volume of superconducting material.

The most practical way to quench superconductivity, but also the most poorly researched way, is to apply an electric field across a very thin superconducting film. We recommend research into this method.

Successful development of a 90-K superconducting thin-film switch would have immediate application when high-power superconducting motors are deployed. Further, the technology could be transferred to higher-temperature superconductors as they become available.

The assessment of motors was prepared by B.W. McConnell. His abstract and conclusions follow. These conclusions are further elaborated in three tables, prepared by McConnell and shown below.

Previous experience in applying superconductors to electric motors and the difficulties encountered are reviewed. Although motors and generators have common basis, several differences exist that have significant impacts on motor design. The application of high-temperature superconductors to the major electric motor types is discussed and expected difficulties are presented. A set of desired performance features is developed and the known types of superconducting motors are evaluated subjectively against these features. The five most promising motor types are further evaluated both technically and economically. The limitations imposed by various motor designs are reflected in a statement of the desired material properties for high-temperature superconductor electric motor applications. The economics of superconducting motors is then examined based on the time required for break-even costs and for the break-even size for different motor types with both open- and closed-cycle cooling.

The following tables were presented by McConnell.

**Table 5 Break-Even Size of Motor Versus Refrigeration Load
According to B.W.McConnell**

General Motor ^a Type	Cooling ^{b,c} Load (W)	Refrigeration Cycle	Break-Even Size (kW)	Load (h/year)	General Use
Small dc	10	Open	3.5	1000	Commercial
Commutator	20	Open	28.0	1000	Commercial
Small, synchronous ac	40	Open	225.0	1000	Commercial
Large, synchronous ac	40	Closed	1750.0	4000	Industrial
Large, fully ac	70	Closed	4500.0	4000	Industrial
Homopolar dc	7	Closed	140.0	4000	Industrial

^aThe motor types are generic in that a dc or ac refers to the current input to the superconducting material. The loss values are for the base case of 40 kW. The small and large synchronous ac machines have moderately high loss values, and smaller values of 20 W might be more reasonable for the large, well-designed machine.

^bThe absolute cooling loads listed, in order, were 2, 16.5, 126, 496, 1631, and 16.3 W for the break-even size. The dc homopolar value is scaled for that for the Fawley motor.

^cThe values used may be taken as best estimates or target values for a well-designed cryostat and refrigeration system.

**Table 6 Economic Evaluation of HTSC Motors According to
B.W.McConnell**

Device	Conventional	Superconducting Technology		Basis of Evaluation.	Benefits
		Low-Temp.	High-Temp.		
ac synchronous with SC rotor	Competitive with induction motors for large sizes	Demonstrated at large sizes	Should improve economics, but is more complicated	Break-even calculations	Smaller; lower cost
ac reluctance (uses Meissner effect)	Smaller size (usually <25 hp)	Demonstration of concept only	Should work for small synchronous, high rpm, low torque	Early GE work	May be basis of room temperature SC motor
ac homopolar inductor with SC stator	Limited availability, some generator work	Untried	May be very viable; dc in stator; no controller	Break-even calculations; no stability problems	Small; lighter; stable; simple
dc homopolar	Available, but high brush maintenance and low efficiency	Most-demonstrated SC motor	Should improve economics, but brush loads cut efficiency	Break-even calculations; Fawley design	Adjustable speed drive (ASD); high torque
Axial-gap commutator	Similar to dc commutator	Untried	Should perform as well as ac homopolar inductor	Design and break- even calculations	Simple; ASD; lower/in rotor

Table 7 Summary of HTSC Motor Issues According to B.W.McConnell

Device	Technology Issues	Economic Issues	Benefits
ac synchronous	Mechanical stress, cooling, control and ac shielding	If power electronics controllers available in larger sizes, then good choice	Established design for generator exists
ac reluctance	Limited size, rotor fabrication, probably needs room-temperature SC to penetrate market	Only smaller sizes without major break-through in both conventional and SC systems	Simplicity, need for ASD ^a controller are advantages
ac homopolar inductor	United in SC config.; ac field effects on dc stator; needs study	Should be simple; lower cost	May not need controller
dc homopolar	Brush design; high/in rotor; VSD with ac dominates market, so penetration in unlikely	Low efficiency seems inherent (80%); higher operating and maintenance cost	Good for ship drive, simple magnet, and cryo system
Axial-gap, dc commutator	Untried design, power electronic controller and commutator; determination of design configuration needed	Should be efficient; may be sized downward, but needs further work	Simple; ASD is a plus

McConnell concludes as follows:

In summary, for this evaluation it was assumed that the new high- T_c superconducting materials can be made to perform at least as well as low- T_c superconducting materials in their magnetic, current-density, and material properties. Specifically, the ac properties of the high- T_c superconductor materials have not yet been determined but are expected to be similar to those of the earlier Type II superconductors. If this is indeed the case, ac power applications may not be so easily obtained. However, the additional cooling margins for high- T_c superconductors at liquid nitrogen temperatures may make higher ac losses acceptable in exchange for extended performance characteristics. Scaling to smaller sizes may be possible with the reduced cost of liquid nitrogen cooling and with the decreased insulation levels required for comparable performances. Consideration of other motor configurations and concepts that accommodate a dc superconducting stator and more uniform air-gap field should further reduce the break-even motor sizes.

Citation 8: *Engineering Evaluation of High- T_c Superconducting Cables by Bean Model and its Assessment of Application to Urban Power System*, Electrical Engineering in Japan, 1991 Vol. 111 (no.1).

Authors: T. Hara and M. Nakamura

Language: English

Summary:

This is a sixteen page summary of a forty page Tokyo Electric Power Company (TEPCO) internal report. The paper examines the feasibility of using an HTSC-based, superconducting power transmission cable within a part of TEPCO's existing underground tunnel and duct system to provide double the capacity (1,000 MVA) of the existing conventional system.

The authors demonstrate that because of the limited size of the ducts, 150 mm in diameter, neither conventional technology nor LTSC-based cables would fit. Furthermore, because H_{c1} is so small in HTSC materials, an HTSC-based cable would have to operate above H_{c1} and be subjected to hysteretic losses. Assuming that the Bean model of hysteretic losses applies to HTSCs, the authors examine the required cable diameter of a coaxial cable with a cold dielectric (similar to the Brookhaven National Laboratory design for a Nb_3Sn superconducting cable) as a function of operating voltage. For voltages greater than 100 kV, the thickness of the dielectric required to withstand the voltage results in a cable diameter in excess of 150 mm. For voltages less than 30 kV, the cooling flow rates required to dissipate ac losses results in a cable diameter in excess of 150 mm. The minimum conductor size is approximately 130 mm which occurs for a voltage of 66 kV and a current density of at least 1,000,000 A/cm².

Finally, they compare the cost of using the HTSC option with using conventional technology. The conventional option requires construction of two new tunnels, two new ducts, and an additional substation compared to the HTSC option. Assuming that the cost of HTSC wire/tape is equal to that of Nb_3Sn tape, the HTSC option is 21 percent cheaper than the conventional option (both capital costs and the capitalized value of losses is considered). If the cost of HTSC wire/tape is only half that of Nb_3Sn tape, the savings are 31 percent. The report concludes with an analysis of voltage stability, short-circuit current, stability, and shunt capacitor requirements.

They conclude that although voltage stability deteriorates it still remains within acceptable limits. Short-circuit current gets larger but is still acceptable. Stability also deteriorates but remains within acceptable limits. Finally, the amount of compensation required for the superconducting cable is only six percent of the amount required for a convention cable.

Citation 9: *Application Considerations for HTSC Power Transmission Cables*, Fifth Annual Conference on Superconductivity and Applications, September 24-26, 1991, Buffalo, N.Y. (USA)

Authors: J.S. Engelhardt, D. Von Dollen, and R. Samm

Language: English

Summary:

This twenty page paper examines the potential use of HTSCs for applications of underground transmission cables, discusses the issues affecting their use, and identifies a number of potential niche markets. Two design concepts for an underground ac cable based upon HTSC materials are presented.

The paper begins with a historical perspective concerning early efforts during the 1960s to develop an underground cable based upon LTSC materials. They point out that following the "oil crises" during the 1970s, the rate of growth in electricity demand declined and interest in large energy parks evaporated. Consequently, there was no longer a need for a superconducting transmission line capable of transmitting the 10,000 MVA upon which the LTSC designs were based.

The paper continues with an overview of the present transmission network (both overhead and underground) in North America. It presents several table giving circuit-miles, growth rates, and capacity ranges for overhead and underground transmission lines. Next factors limiting capacity are discussed. For overhead lines voltage fluctuations and stability issues limit capacity while underground lines are limited by thermal effects due to ohmic and dielectric losses.

Next the paper reviews designs for a cable based upon LTSC materials. In each case, the designs were driven by two factors: (1) the refrigeration energy cost for cooling cables operating below 10 K placed the utmost demands on minimization of losses, and (2) system capacity targets were set very high in anticipation of continued growth and economies of scale. Consideration of these two factor led to the Brookhaven coaxial design for an ac cable. The paper concludes that this design may well be appropriate for very high current application in the future, but for now, lower power levels and reduced refrigeration penalties associated with operating at 77 K allow more losses to be tolerated. Consequently, the paper proposes a design incorporating a room-temperature PPP dielectric instead of the cryogenic dielectric used in the Brookhaven design. This greatly simplifies the design and the resulting superconducting cable has the look and feel of a conventional underground cable.

One of the major advantages of this design is that a new dielectric system is not required. The new design is capable of carrying currents in the 2,000 to 2,500 range. By substituting an HTSC-based superconducting cable for a conventional underground cable, both operating at the same voltage, a doubling in cable capacity and a lower percentage energy loss can be achieved.

This suggests several near-term applications. First, HTSC cables could be retrofit into existing HPOF pipes to replace aging cables and providing three to six times the capacity of existing systems in crowded urban corridors. Another potential market is to retrofit existing pipes where new inter- and intra-regional transfers of energy are required. Another scenario is where undergrounding of overhead lines occurs. Because of thermal limits on existing underground cables, these systems do not match the capacity of overhead lines well, requiring installation of multiple underground circuits for each overhead circuit. A single HTSC circuit could provide a better match to overhead capacity.

Citation 10: *Compilation of International Progress in 1989 on High- T_c Superconductors*, KEMA Scientific & technical Reports, December 1990.

Authors: R.G.I. Leferink and H. Barten

Language: English

Summary:

This fifteen page paper summarizes developments in High- T_c superconductors during 1989 with an emphasis on aspects related to power applications in the electricity sector. The paper reviews scientific progress and progress toward making conductors, concluding with a discussion of HTSC design issues related to power applications. They discuss stability, minimum propagation zones and the need for new protection methods. Work at Reliance Electric Company to develop large (7500 kW) motors for power plant applications and work by Hassenzahl related to use of HTSCs in large-scale SMES is summarized. The report ends with brief discussions of potential electron applications of HTSCs: SQUIDs, switches, magnetometers, bolometers, and microwave equipment.

Citation 11: *Technological Impact of Superconductivity at Liquid Nitrogen Temperature Analysis of Opportunity Cases*, Canadian Electrical Association, Report 714 U 628, December 1989.

Authors: G. Bégin, P. Critchlow, R. Roberge

Language: English

Summary:

This 209 page report was prepared by Hydro Québec's Groupe Technologies, Affaires Internationales (IREQ). The objectives of the study were threefold: (a) to establish the impact of the discovery of high temperature superconductivity (HTSC) on the design and cost of power engineering equipment such as transmission cables, transformers, generators, etc., (b) to identify the most viable applications of the high temperature technologies for Canadian utilities, and (c) to evaluate the potential impact on electricity consumption.

To accomplish these objectives, a comprehensive literature search was undertaken to locate designs of electrical equipment conceived to incorporate low-temperature superconducting (LTSC) materials. These designs were then modified by substitution of the HTSC materials for the LTSC materials, replacing helium refrigeration with nitrogen systems, and making simple modifications to eliminate now redundant features. Cost and performance of the altered designs were determined, in many cases using information given in the original article. In each case, it was assumed that the HTSC had conductor properties comparable to the corresponding NbTi or Nb₃Sn conductor: flexibility, stability, high current capability with low ac losses and cost.

A wide range of utility equipment was studied: generators, transmission cables, large- and small-scale superconducting magnetic energy storage (SMES), transformers and the most prominent utilization systems. In each case, design modifications were restricted to the simple elimination of features which are no longer required (e.g. thermal shield and supports operating below 77 K), and replacing helium refrigerators by nitrogen refrigerators. Both savings in capital expenditure and life-cycle costs were usually evaluated or quoted from other sources.

In general, operation at 77 K increases system efficiency and reliability and reduces the break-even size of superconducting devices in relation to conventional devices. The report cautions that even in the case of many LTSC designs, proof of engineering feasibility is lacking. In the case of HTSC designs, there is no experience at all.

The report begins with an overview of the electric utility sector and where in the system losses occur. Starting with shaft power (either in a steam/gas/hydro turbine) about 2 percent is lost in the generator, another 3-5 percent is lost in transmission, and another 3-5 percent is lost in distribution. Average annual losses for Hydro-Québec are approximately 8.5 percent; Ontario Hydro's has 8 percent loss; and Niagara-Mohawk experiences losses of approximately 6.3 percent. Although the magnitude of losses appears to be small, even a one percent improvement in efficiency applied throughout Hydro-Québec's network in 1986 would have been worth about 48 million Canadian dollars.

The report points out that reduction of losses is not the only advantage that could be provided by superconducting devices and that the most economic system may not be the one with lowest losses. Compactness and high energy density could produce significant savings. For example, reducing the size of generators, by increasing energy density, could reduce civil engineering and the cost of accessories such as cranes. Underground, superconducting cables could lead to a reduction in the number and size of trenches, ducts, and tunnels.

This section is followed by a thirty page summary on superconductivity and cryogenic technology. The remainder of the report consists of seven chapters on specific devices. Each chapter contains a summary of previous LTSC-related research, ongoing efforts, and an analysis of the likely impact of HTSC on the device. The report ends with a set of general conclusions and recommendations.

1. At the present time, it is premature to consider any detailed design studies. However, continued monitoring HTSC research and development is warranted.
2. Case study analyses should be performed to evaluate the likely economic competitiveness of superconducting transmission lines (e.g. crossing of St. Lawrence river by 450 kV, 2000 MW dc line from James Bay to New England).
3. The need for permanent vacuum pumping stations, aluminum stabilization requirements, and pumping losses over long distances should be investigated.
4. Gather information on ultrafine, multifilamentary NbTi for use in fault-current limiters, switches, transformers, etc.
5. Estimate potential saving over a range of capacity to estimate potential total savings to utilities.
6. Estimate breakeven capacity for HTSC-based devices.
7. Perform more detailed studies as properties of HTSC materials improve.
8. Expand the number and enlarge scope of studies of LTSC devices such as fault-current limiters and small SMES systems.
9. Integrate an LTSC-based, regulating SMES system in network stabilization studies and install on system.
10. Explore possibilities for joint ventures with equipment manufacturers for designing, manufacturing, and testing prototype LTSC-based fault-current limiter and regulating SMES devices.

A summary of certain conclusions related to selected devices follows.

Summary Generators:

Conventional generator efficiency can be improved progressively by use of superconductors. Superconducting rotors in a 1200 MW generator at 4.2 K reduce generator losses by about 45 percent relative to a conventional machine. At 77 K the improvement would be 50 percent. Superconducting rotors and armatures would increase these improvements to 64 percent and 79 percent respectively. Capital costs of a conventional generator, a generator with a superconducting rotor, and a generator with a superconducting rotor and armature would be comparable, approximately 36 million dollars. The annual value of the reduced losses would range from 1.5 million dollars for a generator with a superconducting rotor operating at 4.2 K to 2.55 million dollars for a fully superconducting generator operating at 77 K.

Transmission:

Based upon an 1976 analysis carried out by Philadelphia Electric Company for a 10 GVA line 106 km in length operating between a generating park into Philadelphia. By modifying the design of a 230 kV, ac, helium-based, superconducting cable to operate at 77 K, the study estimates savings of 13 percent in installation (cheaper refrigeration) and a total of 19 percent when capitalized losses are included.

Superconducting Magnetic Energy Storage (SMES):

The analysis of SMES for load-leveling purposes follows that of the report published by Bechtel and GA Technologies for a large SMES, 784 m in diameter and 24 m high in a trench excavated from bedrock. The SMES is connected to the utility through an ac/dc converter. Using an HTSC conductor could allow the trench to be narrower, resulting in a capital savings of 6 to 7 percent. No estimate was made of operating cost savings.

The report also considered a small SMES for network stabilization, peak load control, etc. Such a device could be from 20-40 percent cheaper, due to reduced refrigeration load, if operated at 77 K.

Transformers:

This study re-estimated savings determined by B.W. McConnell as part of the Argonne National Laboratory Assessment. In both cases, a Westinghouse design for a 1000 MVA, 500/22 kV transformer was used as the starting point. McConnell estimated that the transformer efficiency would rise from 99.85 percent to 99.92 percent if its operating temperature was raised from 4.2 K to 77 K (a conventional transformer has an efficiency of 99.7 percent). On the basis of these numbers, this study estimated savings in life-cycle costs for the two superconducting units at 17 percent and 39 percent, corresponding to a payback of 5 years and 1 year. (McConnell had estimated the savings to be 38 percent (HTSC) and 60 (LTSC) percent [subsequent discussions between McConnell and Hydro Quebec discovered a numerical error in this analysis resulting in savings closer to those of Hydro Quebec] while Schauer, et al forecast a life-cycle savings of 65 percent for an HTSC transformer).

Utilization:

HTSC could impact devices such as high gradient magnetic separation (HGMS), magnetic resonance imaging (MRI), and magnetically levitated trains (MAGLEV) on the customer-side of the meter. However, in the case of HGMS and MRI, these represent only small utility loads, and MAGLEV faces many implementation hurdles. Superconducting motors could have a large impact. Large electric motors using superconducting rotors at 4.2 K would be more efficient. HTSC could reduce the breakeven rating for motors. The study estimated that the savings from converting large motors (> 1 MW) in Quebec and Canada at 20 million dollars per year and 50 million dollars per year respectively.

Citation 12: *Advances in Applied Superconductivity: A Preliminary Evaluation of Goals and Impacts*, published by Argonne National Laboratory, ANL/ CNSV-64 (January 1988).

Authors: A.M. Wolsky, E.J. Daniels, R.F. Giese, J.B.L. Harkness, L.R. Johnson, D.M. Rote, and S.A. Zwick

Language: English

Summary:

This assessment was published twice. Argonne National Laboratory distributed it as a 192 page report and Noyes Publishing Company published it and an assessment HTS electronics in the same volume. The subject assessment was one of the first done. Its goal was to identify the performance needed from an LN₂ superconductor in each of several applications. Each of these topics was considered by a single author or a team of authors. However, a distinguishing feature of the report is that each team used the same economic assumptions (e.g. cost of capital) when considering what performance would be required of ceramic superconductors to make them economic at 77 K.

This assessment is organized to make its contents accessible to various readers, each with his or her own interest and background. The Overview introduces the principal challenges facing applied research on superconductivity and the economic benefits that may result from success. The sections that follow the Overview, prepared by different teams of experts, each address a particular topic: Renewable Sources for Electricity Generation, Generators, Transformers, AC Transmission, Superconducting Magnetic Energy Storage, Motors, Industrial Separations and Material Handling, and Magnetic Levitation for Transportation. Because these sections vary in length and technical detail, a summary of each is included to serve as its introduction. Finally, the base economic assumptions used by the authors and information about the properties of one bulk sample of YBa₂Cu₃O_{7-x} (one of the new superconductors) are presented in Apps. A and B, respectively.

Following are summaries of some findings of the assessment.

Summary Generators

This assessment indicates the following:

1. Compared to a conventional 300-MW generator, a liquid-helium-cooled generator is projected to be more cost-effective (due to its higher efficiency); this would be the case even if the capital cost of the conventional generator were zero.
2. The gain in efficiency due to reduction of refrigeration power requirements for a high-temperature superconductor is a modest 0.2%. However, the capital cost of the higher-temperature superconducting generator would be reduced significantly by the reduction in refrigeration system costs. If the refrigeration cost is proportional to refrigeration power, the cost of the \$500,000 refrigeration system could be virtually eliminated.
3. Unless the current density of wire, including both copper stabilizer and high-temperature superconductor, is on the order of 10^4 A/cm² (i.e., equivalent to that of the low-temperature conductor), the cost savings due to elimination of the helium refrigeration system will be offset by increased superconductor materials costs to

achieve the 300-MW rated power. For example, at 10^3 A/cm², the higher-temperature superconductor machine would have a cost of \$800,000 in excess of that of a machine based on the lower-temperature superconductors.

Therefore, the conclusions regarding economics are that superconducting machines are more cost-effective than conventional machines and higher-temperature superconducting machines are more cost-effective than lower-temperature superconducting machines at current densities of 10^4 A/cm².

The analyses leading to these conclusions are summarized in Table 4.1, which presents five 300-MW generators: a conventional system, a helium-cooled system, and three nitrogen-cooled systems at different current densities. The costs and losses are those estimated by Kirtley. The value of losses is based on a 65% capacity factor, rather than the 80% used in the Kirtley analysis, and is presented on an annual basis. As shown, the total annual value of the conventional machine losses is \$1.4 million. The total annual costs of the helium-cooled superconducting machine are more than \$0.9 million less, including the annual capital costs at an 18.7% fixed charge rate. Even if the cost of the conventional machine were zero, the value of the annual losses of the conventional machine would exceed the materials cost and losses of the helium-cooled superconducting machine by \$0.75 million. At a current density for 0.075×10^4 A/cm², the annual value of losses for the higher-temperature superconductors is somewhat lower than that for the helium-cooled generator. However, this gain is offset by increased materials costs. At a current density of 0.75×10^4 A/cm², the reduction in materials costs makes the higher-temperature superconducting system more cost-effective than the lower-temperature system. If the current densities of the two superconductors are equivalent, the higher-temperature system will have a cost advantage of about \$250,000/yr.

This assessment also points out that the advantage of superconductors with higher transition temperatures would also be enhanced by expected improvements in reliability and availability when operating at liquid nitrogen temperatures relative to liquid helium temperatures. Higher-temperature superconducting machines may be cost-effective compared with conventional machines at smaller capacities. This is apparently attributable to the consideration that the capital cost of higher-temperature superconducting machines is significantly lower than that of the machines based on helium-cooled superconductors. Therefore, a smaller absolute difference in losses (associated with the use of smaller machines) would be adequate to justify the capital cost premium of a higher-temperature superconducting machine relative to a conventional generator.

**Table 4.1 Comparison of Conventional and Alternative
Superconducting 300-MVW Generators
According to J.B.Kirtley**

Parameter	Conventional System	Helium Cooled System ^a	Nitrogen-Cooled Systems ^b		
			0.075×10^4 A/cm ² (M1)	0.75×10^4 A/cm ² (M3)	0.80×10^4 A/cm ² (M5)
Rating (MW)	298.23	298.23	296.70	296.22	298.23
Efficiency (%)	98.6	99.57	99.67	99.71	99.72
Materials cost (\$10 ³)	884 ^c	1,238	3,200	879	739
Losses (MW)	4.17	1.28	0.98	0.86	0.84
Levelized value of losses (\$10 ³ /yr)	1,411	433	331	290	283
Annual capitalized materials cost (\$10 ³ /yr)	165	231	598	164	138
Total annual cost (\$10 ³ /yr)	1,576	664	929	454	421

^aCurrent density = 0.80×10^4 A/cm².

^bThe five hypothetical superconductors (M1 through M5) are fully described in Sec. 4.4.

^cEstimated on the basis of a capital cost multiplier of 1.4 for a helium-cooled superconducting machine relative to a conventional machine.

Summary Motors

The attractiveness of superconductors for motors is similar to their attractiveness for generators. Superconductors offer an increase in motor efficiency, which must be balanced against the capital cost premium for the superconducting motor (including its refrigeration system). However, as is pointed out in Sec. 8 and detailed in a supplement to that section, start-up produces large forces in motor windings, and these forces may preclude the use of "brittle" superconductors. In the review of six different types of motors provided in the supplement, Lipo concludes that a homopolar inductor motor in which the superconducting field winding is stationary (rather than rotating, as in other designs) may be the most suitable design for superconducting materials. Not only would the rotational forces acting on the windings be eliminated, but the practical feasibility of cooling a stationary winding would be greater than that for a rotating winding.

As a first approximation, the cost of a liquid-nitrogen-cooled motor was analyzed relative to a conventional 1,500-hp motor. The capital cost of the high-temperature superconductor (HTSC) machine is based on the cost of superconducting generators, relative to conventional generators, reported by Westinghouse Electric Corp. As stated in the main text, the analysis probably overestimates the capital cost of the HTSC motor because it takes no credit for expected cost reductions in the refrigeration system when operating on

liquid nitrogen (LN₂) instead of liquid helium (LHe). The motor efficiency for the HTSC is based on the expected reduction in losses, as follows:

- 30% by elimination of rotor copper losses,
- 5% by reduction in stator copper losses, and
- 5% by reduction in stray losses.

The power requirements of LN₂ refrigeration, which are expected to be negligible, do not diminish the efficiency of the HTSC motor.

As the following analysis shows, the HTSC motor would have an expected savings of about 11% compared with the capitalized costs of a conventional motor, because of the increased efficiency of the HTSC motor and the consequent reduction of losses. No credit was taken in capital cost reduction for the HTSC motor due to LN₂ refrigerant relative to LHe, although the referenced capital cost multiplier is based on LHe refrigeration. The potential cost savings would exceed 20% if the use of LN₂ refrigerant reduces the system capital cost by 20%.

Summary Transformers

One-sixth of the annual losses associated with transmitting electricity over the US grid occur in power transformers. Losses in power transformers are equal in magnitude to the output of five large-scale, base-load power plants. Installation of superconducting power transformers could reduce these losses.

Section 5 considers a design for a 1,000-MVA generation step-up transformer with superconducting windings incorporating Nb₃Sn developed by Westinghouse Electric Corp. under contract to DOE in 1981. This design, together with the cost assumptions, formed the basis of B.W. McConnell's following evaluation of the potential impact of the new high-temperature superconductors (HTSCs) on power transformers. Since almost nothing is known concerning the AC properties of the new HTSCs, Nb₃Sn properties were assumed (except for the high critical temperature). The results of this analysis indicate that use of the new HTSCs will result in total life-cycle costs that are 35% lower than for Nb₃Sn and 60% lower than for conventional power transformers of this size.

To date, no full-scale superconducting power transformer has been built or tested. This is probably due in large part to the high value electric utilities assign to reliability; failure of the power transformer could result in a shutdown of the entire generating plant. Furthermore, although the cost savings associated with the superconducting power transformer appear to be substantial, the power transformer itself represents only a small part of the entire generating plant.

Summary Transmission Lines

The annual losses associated with transmitting electricity over the US grid are equal to about one quad.* One-third of these losses (equal in magnitude to the output of ten large-scale, base-load power plants) occur in the transmission system. Installation of a superconducting transmission grid could greatly reduce these losses.

Both AC and DC superconducting systems have been proposed. The DC system requires the use of AC-to-DC and DC-to-AC converters. The combined losses of these converters may exceed the losses of a conventional transmission line shorter than several hundred miles. Therefore, current research is concentrating on development of a superconducting AC transmission line.

Recently, Brookhaven National Laboratory (BNL) has designed, built, and tested a helically wound, superconducting, coaxial cable 115 m in length and made of Nb₃Sn. The cable system exhibits three types of losses: (1) current-induced losses in the superconducting cable, (2) voltage-induced losses in the dielectric, and (3) "losses" associated with refrigeration. In order to keep the current-induced losses at an acceptable level, current must be a factor of 8-10 lower than the critical current.

This section presents an analysis of the potential impacts of high-temperature superconductors on superconducting transmission lines that is based upon a DOE-sponsored analysis performed by the Philadelphia Electric Company (PECO) in 1977. Almost nothing is known concerning the AC properties of the new high-temperature superconductors, so this analysis assumed AC properties identical to those of Nb₃Sn. Because the refrigeration losses exhibit strong economies of scale (due to surface-to-volume effects), the PECO analysis is based on a very large transmission line (10,000 MVA). The required critical current for this system is 200×10^4 A/cm². Modifying the PECO analysis to account for the higher critical temperature (77 K) results in a reduction of the system cost, including capitalized energy costs, of about 30%. Table 6.1 summarizes the losses and transmission costs of service for the new superconducting material and two conventional systems: (1) an underground high-pressure, oil-filled-pipe transmission (HPOPT) line and (2) a combined aerial/underground system. Each system is 66 mi in length, has a capacity of 10,000 MVA, and has a substation at each end. The superconducting system has the lowest losses and a cost of service that is higher than that of the aerial/underground system, but lower than that of the HPOPT system.

Recent studies have indicated possible adverse health effects associated with high-intensity electromagnetic fields. If this finding should lead to the requirement that all future transmission lines be placed underground, superconducting transmission lines could turn out to be the lowest-cost alternative.

The losses associated with a transmission line of more typical size (1,000 MVA, 100 km) were also analyzed. In this case, several systems designed for a variety of voltage-current conditions were all found to have refrigeration losses of less than 0.2%. The cost-effectiveness of these systems was not analyzed.

*One quad = 10^{15} Btu.

**Table 6.1 Comparison of Losses and Costs of Service
for Superconducting and Conventional
Transmission Systems
according to R.A.Thomas and E.B.Forsyth**

System	Loss	Cost of Service Transmission Only (mills/kWh)
77 K superconducting (underground)	0.73	3.46
High-pressure, oil-filled pipe (underground)	3.60	6.05
Aerial/underground	1.68	2.08

Summary SMES

A number of prospective features make the use of HTSCs in SMES attractive. For utility applications, these may be reduced to reliability, which can be much more important than a cost saving for the capital plant.

The refrigeration system for operation at liquid nitrogen temperature, for instance, is greatly simplified. Operating efficiency for SMES could rise to as much as 94-95%. Stability of the superconductor would be enhanced by the higher heat capacity of a liquid nitrogen system. The protective energy dump system to exhaust the cryogen could be less elaborate, but it could not be eliminated. Because of the short time required to exhaust the liquid nitrogen, the requirement that the cryogen must be drained from the bottom of the SMES drawer will most likely remain. To exhaust the waste the nitrogen to atmosphere at the top would require a thicker inner drawer vessel to overcome the higher density liquid nitrogen gravity head. Thus, an offsetting cost increase will occur. A detailed engineering analysis is required.

Stabilizing material associated with the new superconductor might be decreased in quantity because of the matrix material's higher heat capacity at the initial higher temperature, when a transition to the normal conducting state might occur, as compared with the heat capacity in liquid helium.

The complexities introduced by an HTSC will require an extensive analysis of SMES to ascertain the engineering design and economic trade-offs. Even some rather profound design modifications may prove to be fundamental to the use of the new superconductors. Perhaps the detailed and intricate superconductor designs used today will become unnecessary because of the increased stability potential. These new ceramic-like materials might be cold-drawn in thin-walled metal tubes to be wire-like, and subsequently bundled together and cooled by conduction or forced convection.

The obvious features of SMES that provide cost savings by the use of HTSCs with the foregoing property assumptions are in the areas of refrigeration and cryogenic piping, thermal heat leaks (struts and radiation shields), substation size for auxiliary equipment, coil protection, and helium storage. Reference 3 provides a sound basis from which to examine cost reductions for the items listed in Table 7.1.

The capital cost from the last Bechtel study for a 1,000-MW, 5,000-MWh SMES unit was \$980 million (1985 dollars). Thus, the HTSC system cost becomes \$950 million. Even at best, then, if the savings estimate is off by as much as a factor of two, which is unlikely, the cost is \$920 million. This estimate does not take into account replacing the superconductor.

Now let us consider the high-temperature superconductor. Because SMES uses current-density values of 80-85% of the critical current density, 70×10^4 A/cm² at 3 T and 1.8 K for NbTi, the assumption that the HTSC can replace NbTi requires extreme speculation about its probable ultimate current density. In the most optimistic view, assuming that IBM's value of 100×10^4 A/cm² applies at 77 K and at 1.6-5 T, then for the same SMES plant cost for the superconductor, the HTSC could be allowed to cost close to 22¢/g.

**Table 7.1 Potential Savings with 77-K SMES
(1,000 MW, 5,000 MWh) according to J.D.Rogers**

Item	Savings (\$10 ⁶)
	9.9
Refrigerators	
Struts	2.3
Thermal shields	8.6
Coil protection system	1.3
Cryogenic piping	5.8
Diesel standby generators	0.4
Substation	0.7
Helium storage	0.5
Instrumentation	0.5
Total	30.0

IV. ASSESSMENTS BEARING UPON CABLE

The following pages provide citations and abstracts for 45 reports, each bearing upon the use of ceramic superconductors in electrical cable. Some reports describe more than one topic; in that case the report is listed in this section and in other appropriate sections. The most recent reports are from 1991 and the earliest is from 1987.

Cables

Title: Current activities of superconducting wires and cables

Author(s): Matsumoto, K.; Tanaka, Y.

Author Affiliation: Yokohama R&D Labs., Furukawa Electr. Co. Ltd., Japan

Journal: AIP Conference Proceedings no.219 p.668-77

Publication Date: 1991

Country of Publication: USA

Conference Title: Fourth Annual Conference on Superconductivity and its Applications

Conference Date: 18-20 Sept. 1990

Conference Location: Buffalo, NY, USA

Language: English

Document Type: Conference Paper (PA); Journal Paper (JP)

Treatment: General, Review (G)

Abstract: The state of the art and recent progress in the development of superconducting wires and cables are reviewed and discussed. Excellent superconducting properties of practical superconducting wires are of special interest in applications such as MRI, NMR spectrometers, particle accelerator, and SMES. Practical superconducting wires for DC applications have been developed. Under well controlled conditions, the critical current densities of Nb-Ti wire and bronze-processed Nb/₃/Sn/₂/ wire have reached over 3.8×10^5 A/cm² at 5T and 3.15×10^4 A/cm² at 16T, respectively. On the other hand, the Ag-sheathed oxide superconducting wires such as YBCO and BSCCO have been developed. The transport critical current densities reached over 3.5×10^4 A/cm² at 77 K and zero magnetic field for a c-axis oriented BSCCO wire. (10 Refs)

Title: Mechanical damage assessment in prototype superconducting cable components

Author(s): Hilty, R.D.; Wright, R.N.

Author Affiliation: Dept. of Mater. Eng., Rensselaer Polytech. Inst., Troy, NY, USA

Journal: AIP Conference Proceedings no.219 p.678-85

Publication Date: 1991 Country of Publication: USA

Conference Title: Fourth Annual Conference on Superconductivity and its Applications

Conference Date: 18-20 Sept. 1990 Conference Location: Buffalo, NY, USA

Language: English Document Type: Conference Paper (PA); Journal Paper (JP)

Treatment: Experimental (X)

Abstract: The use of high T_c superconductors, namely YBa/₂/Cu/₃/O/_{7-x}/, in the design of electrical componentry shows a great potential for energy savings in the transmission and generation of electrical power. Through characterization of the physical and mechanical properties of these materials, their usefulness in engineering practices can be predicted. The strain required to form and propagate cracks has been considered. The role of crystallographic texture in achieving optimum mechanical and electrical properties will also be discussed. (6 Refs)

Title: Engineering evaluation of high-T_c superconducting cables by Bean model and its assessment of application to urban power system

Author(s): Hara, T.; Nakamura, M.

Author Affiliation: Tokyo Electr. Power Co., Japan

Journal: Electrical Engineering in Japan vol.111, no.1 p.44-60

Publication Date: 1991 Country of Publication: USA

U.S. Copyright Clearance Center Code: 0424-7760/91/0001-0044\$7.50/0

Language: English
Document Type: Journal Paper (JP)
Treatment: Fractical (P)

Abstract: From the viewpoint of the electric power system, the expansion of underground cables will be in greater demand so it is necessary to make a compact high-capacity power line using high-temperature superconducting materials which can be installed in existing underground ducts and tunnels. The future model system is developed and the conceptual design of compact high-temperature superconducting cables to cope with this situation is carried out by using Bean's model. To evaluate the validity of Bean's model, the hysteresis curve of an yttrium-based silver sheath wire is measured. Using the result, the design rule of a compact high-temperature superconducting cable is proposed. (13 Refs)

Title: Superconducting power transmission that has come this far
Original Title: Kokomade kita chodendo soden
Author(s): Imajo, N. (Central Research Institute of Electric Power Industry, Tokyo (Japan))
Source: Energy (Tokyo) (Japan) v 24:11
Publication Date: 1 Nov 1991 p 62-66
Language: In Japanese

Abstract: Superconducting cables capable of especially large capacity transmission have been expected strongly as a result of the recent sharp increase in power demand. Since the emergence of high temperature (or oxide) superconductors which show a superconducting phenomenon at the liquid nitrogen temperature (-196°C), its research and development has been carried out actively in a number of countries. The oxide based superconductors, which were discovered in 1986 and do not require cooling by liquid helium, are of the Y, Bi and Te systems containing yttrium as the raw material. Its conceptual design and the economy as the cable material are under evaluation. Their advantages are that they do not require helium cooling, can be structured compactly, and are assumed that their current density can be remarkably low under a high magnetic field. Added to these, they are low in losses, and capable of large capacity transmission. On the other hand, however, the largest problem is to give flexibility to such ceramics as used in the system. Electrical insulation, cable end disposition, and changes with time in a long term operation also remain unsolved. 7 refs., 4 figs., 3 tabs.

Title: Skin effect in a high-T/sub c/ flux-flow superconducting wire
Author(s): Ando, Y.; Akita, S.
Author Affiliation: Komae Res. Lab., Central Res. Inst. of Electr. Power Ind., Tokyo, Japan
Journal: Journal of Applied Physics vol.70, no.8 p.4415-20
Publication Date: 15 Oct. 1991
Country of Publication: USA
U.S. Copyright Clearance Center Code: 0021-8979/91/084415-06\$03.00
Language: English Document Type: Journal Paper (JP)
Treatment: Applications (A); Theoretical (T)

Abstract: As a candidate for a low AC-loss bulk power transmission cable, a high-T/sub c/ superconducting wire in a flux-flow state, which is called a flux-flow superconductor here, is theoretically studied. The electrodynamics of such a wire in a self-excited AC field is formulated, where the governing equation is nonlinear because of the magnetic field dependence of the flux-flow resistivity. The current distribution inside the wire and the AC loss are numerically calculated to investigate the influence of the skin effect in such a nonlinear system. The AC loss is enhanced by the skin effect, and it is found that the amount of this enhancement can be scaled by a nondimensional parameter which depends not only on the frequency and the radius of the wire but

also on the peak current. As a means to reduce the AC loss in the presence of the skin effect, it is shown to be effective to divide the wire into many coaxial layers and to set the current distribution between the layers artificially. It is also shown that, if an optimized current distribution is settled between the layers, the AC loss can be reduced to a smaller value than that for a nondivided wire neglecting the skin effect. (11 Refs)

Title: Development of elements of a high-T_c superconducting cable. Quarterly report, 1 Jul-30 Sep 91

Author(s)/Editor(s): Lay, K.W.

Corporate Source: General Electric Co., Schenectady, NY (United States). Corporate Research and Development Center

Publication Date: 30 Sep 1991 (10 p)

Report Number(s): AD-A-242479/4/XAB

Contract Number (Non-DOE): N00014-88-C-0681

Language: In English

Availability: NTIS

Abstract: The program is aimed at the development of long lengths of silver-clad BSCCO. The material of choice is BSCCO-2223 with 20K the operating temperature goal. Such a tape conductor ultimately could be used in a coil for a magnet, motor or generator. The program is designed to tackle several key problems with parallel tasks. A large variety of BSCCO powders are under investigation. Silver tubes are packed with superconductor powder and deformed to form tape conductors. An alternate method of making silver-encapsulated superconducting tape is also being pursued. Variations in the powders and processing parameters are used to optimize the tape J_c.

Title: Superconductivity: Supply-side management

Author(s): Greenberger, L.S.

Source: Public Utilities Fortnightly (United States) v 128:3

Publication Date: 1 Aug 1991 p 38-40

Language: In English

Abstract: This article examines the role of high-temperature superconducting cables (HTSC) in the distribution of electricity. Topics discussed include the need for federal support and organization in commercializing HTSC, a plan for development, a new look at an old idea, other applications of HTSC including improved motors, transportation systems, bearings, magnetic refrigeration and supercomputers.

Original Title: Denryokuter dot energy bun prime ya ni okeru cho dendo gijutsu oyo no doko to shorai tenbo

Author(s): Ueda, K. (Central Research Inst. of Electric Power Industry, Tokyo (Japan))

Source: Denki Gakkai Ronbunshi, B (Transactions of the Institute of Electrical Engineers of Japan) (Japan) v 111:4

Publication Date: 20 Apr 1991 p 339-343

Language: In Japanese

Abstract: Japan in 1987 programmed a nation-wide research project by collecting the basic power of the universities, research institutions and the industries. Research union of superconductive power generation-related equipments and the materials (Super-GM) and the International Superconductive Industry Research Center (ISTEC) were established to promote the applications to low/high temperature superconductive material, generators and power storage. This report

attempts to summarize and prospect the introductory effect or the research and development status towards the current system: Activities are outlined on the activities of the superconductivity experts in the International High Power System Conference (CIGRE), International Electric Standard Conference, Superconductive Technology Sector (IEC/TC 90) and the International Energy Association (IEA). By the end of this century, cables and compact motors which gives high effect of introduction will be completed in trial making thereof. Especially the cables will be expected to omit the use of a large ultra high voltage transforming station by the renovation wherein the large current low voltage single stage system replace the 275 kV multistage ultra high voltage metropolitan cable system. 1 fig., 4 tabs.

Title: Development of elements of a high-T_c superconducting cable. Rept. for 1 Jan-31 Mar 91

Author(s)/Editor(s): Lay, K.W.

Corporate Source: General Electric Co., Schenectady, NY (United States). Corporate Research and Development Center

Publication Date: 31 Mar 1991 (7 p)

Report Number(s): AD-A-236151/7/XAB

Contract Number (Non-DOE): N00014-88-C-0681

Language: In English

Availability: NTIS

Abstract: The redirected program is aimed at the development of long lengths of silver-clad BSCCO. BSCCO-2223 is the material of choice with 20K the operating temperature goal. Such a tape conductor ultimately could be used in a coil for a magnet, motor or generator. The program is designed to tackle several key problems with parallel tasks. A large variety of BSCCO powders will be prepared. Silver tubes packed with superconductor powder will be cold deformed to form tape conductors. Alternate methods of making silver-encapsulated superconducting tape will be explored. Variations in the powders and processing parameters will be used to optimize the tape J_c. It has been convincingly demonstrated that the highest J_c tapes are prepared from powder which is not fully reacted to BSCCO-2223. The superiority of pressing over rolling for the final deformation of the tapes has been proven and tentatively explained. Equipment is now available to measure currents up to 240A at 20K in fields as high as 9T. A low J_c degradation of bent tapes will allow coiled lengths to be processed.

Title: Feasibility study of compact high-T_c/superconducting power cables

Author(s): Tanaka, S.; Ichiyanagi, N.; Iwata, Z.; Nakade, M.

Author Affiliation: Furukawa Electr. Co. Ltd. Chiba, Japan

Conference Title: Proceedings of 39th International Wire and Cable Symposium p.513-19

Publisher: Int. Wire Cable Symposium, Shrewsbury, NJ, USA

Publication Date: 1990

Country of Publication: USA xx+766 pp.

Conference Sponsor: IWCS

Conference Date: 13-15 Nov. 1990

Conference Location: Reno, NV, USA

Language: English

Document Type: Conference Paper (PA)

Treatment: Practical (P)

Abstract: The authors determined the magnetization curves by the AC magnetization method to evaluate quantitatively the AC loss in high-T_c/superconducting bulk and wire samples. In the region of small applied maximum fields, the AC loss increased in proportion to the third power of the applied maximum field as indicated by the Bean model. A conceptual design was developed for

a compact high-T/sub c/ superconducting power cable that could be installed in existing cable ducts (150 mm in diameter). It was found that the use of such cables permits a reduction of transmission costs. (12 Refs)

Title: Prospects offered by new high critical temperature superconducting materials for electrical power transmission

Conference Title: CIGRE. Proceedings of the 33rd Session. International Conference on Large High Voltage Electric Systems p.1-1.1/1-8 vol.2

Publisher: CIGRE, Paris, France

Publication Date: 1990

Country of Publication: France 2 vol. 2772 pp.

Conference Date: 26 Aug.-1 Sept. 1990

Conference Location: Paris, France

Language: English

Document Type: Conference Paper (PA)

Treatment: Practical (P)

Abstract: The essential advantage of high temperature superconducting materials is their functioning in liquid nitrogen at 77 K. The cryogenic system in liquid nitrogen indeed offers many advantages compared with that used at 4.2 K with conventional superconducting materials. The authors discuss the state of the technique concerning the development of new high temperature superconducting materials for electrical power transmission. The different points discussed include: characteristics of the new materials; manufacturing techniques; characteristics of the conductors; prospects for application of these new materials to power cables; technical and economic fields of interest; and the possible impact of new superconducting cables on network structure and operation. (13 Refs)

Title: Investigation of superhigh molecular polyethylene for cryogenic cable insulation

Author(s): Wei-Han U; Fen-Nyan Hao

Author Affiliation: Tsinghua Univ., Peking, China

Journal: Elektrotehnika vol.61, no.12 p.66-9

Publication Date: 1990

Country of Publication: USSR

Translated in: Soviet Electrical Engineering vol.61, no.12 p.100-5

Publication Date: 1990

Country of Publication: USA

Language: English

Document Type: Journal Paper (JP)

Treatment: Experimental (X)

Abstract: In conjunction with the development of new high-temperature superconductors, an investigation of cryogenic power cables at the temperature of liquid nitrogen is of major interest. Polymers can be used as insulation for cryogenic cable. However, cooling of the polymer to cryogenic temperatures is associated with the transition of the polymer from the highly elastic state to the vitreous state, which is accompanied by rearrangement of the structure and the development of sharp internal stresses. In recent years superhigh molecular polyethylene (SHM-PE) has been widely developed for such applications. Difficulties were overcome in the process and methods for extrusion have been developed. The cost of SHM-PE is close to that of ordinary polyethylene and much lower than the cost of materials used in cryogenic devices, for example,

polytetrafluoroethylene. The authors describe research at Tsinhua University in Peking which showed that SHM-PE possesses satisfactory electric insulation and mechanical properties for cryogenic cable at the temperature of liquid nitrogen. (7 Refs)

Title: The high voltage design of superconducting power transmission systems

Author: Forsyth, E. B.

Corporate Source: Associated Universities Inc

Source: IEEE Electrical Insulation Magazine v 6 n 4 Jul-Aug 1990 p 7-16

Publication Year: 1990

Language: English

Document Type: JA; (Journal Article)

Treatment: A; (Applications)

Journal Announcement: 9109

Abstract: The special problems that arise when designing a superconducting system are examined. These are: (1) that the voltage and current levels chosen must permit economic integration into existing transmission and generation facilities; (2) the mechanical design of components that get cold must permit relatively large absolute contraction and possibly differential contraction without damage that may affect successful operation, and cool-down and warm-up cycles throughout the life of the system should not cause deterioration of the dielectric insulation; and (3) the dielectric losses of the insulation must be carefully controlled in AC systems. Basic research on cryogenic dielectrics is briefly reviewed, and 11 projects around the world that have engaged or are engaging in electrical insulation testing of prototype cables are described. The development of accessories is discussed. 39 Refs.

Title: Superconductivity in energy technologies. Assessment, concepts and new aspects

Corporate Source: Verein Deutscher Ingenieure (VDI) - Gesellschaft Energietechnik, Duesseldorf (Germany, F.R.)

Publisher: Duesseldorf (Germany, F.R.) VDI-Verl.

Publication Date: 1990 (274 p)

Language: In English

Abstract: Four years after the sensational discovery the purpose of this book is to show the current state of the art, the technical-physical concepts and new aspects of the technical application and use of superconductors, in the field of energy technologies. The book will focus primarily on the following topics: general introductions; materials: requirements, properties, manufacture, processing; cryotechnology; machines, cables, switches, transformers; energy storage; magnetic engineering for fusion, transport and mass separation; magnets for particle accelerators; promotional activities, economy, patents. This book has been written by and for scientists and engineers working in industry, large-scale research institutions, universities and other research and application fields to help further their knowledge in this field. Apart from the current state of the art, the book also describes future application and development possibilities for the superconductor in power engineering. (orig.).

Mitsubishi Cable Industries Review, No. 80, October 1990 Mitsubishi Cable Industries Ltd., Tokyo (Japan)

c1990 73p

Languages: Japanese

Text in Japanese with English abstracts. See also PB91-150656, PB91-150664 and PB90-267832

Country of Publication: Japan

Partial contents: Preparation of Superconducting Bi-Pb-Sr-Ca-Cu-O Rods by Melt-quenching Method; Fabrication and Evaluation of Current Limiting Elements Using Oxide Superconductors; Development of Very Thin Insulated Wires for Automobiles; Development of Road-heating Control System for Energy Saving; Application of Network Tester for Ethernet; Temperature Monitoring System for Underground Power Cables in Tunnels; Development of Pre-molded Normal Straight Joint for 66kV XLPE Cables for Short-term Use; On the Characterization of Crosslinked Polyethylene.

Title: Development of elements of a high-Tc superconducting cable. Rept. for 1 Oct-31 Dec 90
Author(s)/Editor(s): Lay, K.W.
Corporate Source: General Electric Co., Schenectady, NY (United States). Corporate Research and Development Center
Publication Date: 31 Dec 1990 (7 p)
Report Number(s): AD-A-233270/8/XAB
Contract Number (Non-DOE): N00014-88-C-0681
Language: In English
Availability: NTIS

Abstract: The realigned program is aimed at the development of long lengths of silver-clad BSCCO. A variation on the powder in tube technique will be used to make silver-clad BSCCO tapes. BSCCO-2223 is the material of choice with 20K the operating temperature goal. Such a tape conductor ultimately could be used in a coil for a magnet, motor or generator. A key element of the program is the development of processes with the potential of fabrication of very long conductors. A novel process for making silver clad tapes (SCT) is under study. In this process extruded BSCCO is wrapped with silver foil which is then pressure welded. This technique has the potential for fabrication of continuous lengths and also avoids the extensive size reduction and attending potential for non-homogeneity involved with the more conventional powder-in-tube (PIT) process. A parallel PIT study is also underway to use for comparison purposes and as a back-up process to the SCT process.

Title: Development of elements of a high-Tc superconducting cable. Report for 1 July-30 September 1990
Author(s)/Editor(s): Lay, K.W.
Corporate Source: General Electric Co., Schenectady, NY (USA). Corporate Research and Development Center
Publication Date: 30 Sep 1990 (6 p)
Report Number(s): AD-A-228558/3/XAB
Contract Number (Non-DOE): N00014-88-C-0681
Language: In English
Availability: NTIS

Abstract: No abstract available.

Title: Superconductivity in electrical engineering
Original Title: Elektrotechnische Anwendungen der Supraleitung
Author(s): Zeller, H.R. (Asea Brown Boveri AG, Baden (Switzerland). Forschungszentrum)
Source: Bulletin des Schweizerischen Elektrotechnischen Vereins (und) des Verbandes Schweizerischer Elektrizitätswerke (Switzerland) v 81:15
Publication Date: 4 Aug 1990 p 20-22
Language: In German

Abstract: The article discusses the applications of ceramic high-temperature superconductors, e.g. superconducting generators, transformers, transmission cables, current limiters, and magnetic separators. (MM).

Title: Composite ceramic superconducting wires for electric-motor applications. Annual report No. 2, 1 July 1989-30 June 1990

Author(s)/Editor(s): Halloran, J.W.

Corporate Source: Ceramics Process Systems Corp., Milford, MA (USA)

Publication Date: 30 Jul 1990 (153 p)

Report Number(s): AD-A-225859/8/XAB CPS--90-020

Contract Number (Non-DOE): N00014-88-C-0512

Language: In English

Availability: NTIS

Abstract: Several types of HTSC wire have been produced and two types of HTSC motors are being built. Hundreds of meters of Ag-clad wire were fabricated from $\text{YBaCu}_3\text{O}_{7-x}$ (Y-123) and $\text{Bi}_2\text{Ca}_2\text{Sr}_2\text{Cu}_3\text{O}_{10}$ (BiSCCO). The DC homopolar motor coils are not yet completed, but multiple turns of wire have been wound on the coil bobbins to characterize the superconducting properties of coiled wire. Multifilamentary conductors were fabricated as cables and coils. The sintered polycrystalline wire has self-field critical current densities (J_c) as high as 2800 A/sq cm, but the J_c falls rapidly with magnetic field. To improve J_c , sintered YBCO wire is melt textured with a continuous process which has produced textures wire up to 0.5 meters long with 77K transport J_c above 11,770 A/sq cm² in self field and 2100 A/sq cm² at 1 tesla. The Emerson Electric DC homopolar HTSC motor has been fabricated and run with conventional copper coils. A novel class of potential very powerful superconducting motors have been designed to use trapped flux in melt textures Y-123 as magnet replicas in an new type of permanent magnet motor. The stator element and part of the rotor of the first prototype machine exist, and the HTSC magnet replica segments are being fabricated.

Title: Development of elements of a high- T_c superconducting cable. Report for 1 January-31 March 1990

Author(s)/Editor(s): Lay, K.W.

Corporate Source: General Electric Co., Schenectady, NY (USA). Corporate Research and Development Center

Publication Date: 31 Mar 1990 (5 p)

Report Number(s): AD-A-221300/7/XAB

Language: In English

Availability: NTIS, PC A01/MF A01

Abstract: The goal of the program is the development of materials and processes for the fabrication of a composite high T_c superconductor element made of a superconducting coating in a supporting fiber.

Title: Feasibility study of high $T_{sub c}$ superconducting power cable

Original Title: Koon chodendotai no denryoku cable eno oyo to sono kadai

Author(s): Ichiyanagi, Naotaka; Tanaka, Satoru; Enokubo, Fumiaki; Furuto, Yoshio (Furukawa Electric Co. Ltd., Tokyo (Japan))

Source: Teion Kogaku (Cryogenic Engineering) (Japan) v 25:1

Publication Date: 25 Feb 1990 p 12-17

Language: In Japanese

Abstract: Conceptional design of high T_c superconducting power transmission cable was developed, and the critical current density required for the cable material was studied. Superconducting oxides have smaller lower-critical field values H_{c1} (prime) and larger upper-critical field valued H_c compared with metallic superconductors. In conventional way of designing superconducting cable, the surface current region ($\sim H_{c1}$) where very low AC loss can be expected was employed, and smaller H_{c1} causes a big problem for large current transmission. To solve the problem, the surface field applied to the cable was made larger than H_{c1} , and a design method which uses the Bean model for the calculation of AC loss is proposed. The result indicates that critical current densities of equal to or larger than 10^4 and 10^5 A/cm² are required for 5,000 and 10,000A superconductors respectively for high temperature superconducting cables.. 4 refs., 8 figs., 4 tabs.

Title: Application of superconductors in power transmission and storage

Author(s): Raychaudhuri, A.K.

Author Affiliation: Indian Inst. of Sci., Bangalore, India

Journal: Indian Journal of Cryogenics vol.13, spec. issue. p.186-7

Publication Date: 1989

Country of Publication: India

Conference Title: National Workshop on High T_c Superconductors

Conference Sponsor: Indian Inst. Sci.; Dept. Sci. Technol.; et al

Conference Date: 27-31 March 1988

Conference Location: Bangalore, India

Language: English

Document Type: Conference Paper (PA); Journal Paper (JP)

Treatment: Applications (A); General, Review (G); Practical (P)

Abstract: Discovery of high transition temperature superconductors has created a unique challenge for the electrical power industry. It holds the promise of a new technology which becomes economically viable only in the area of large scale power generation and distribution. The author points out certain areas where large scale application of 'conventional' superconductors (those needing liquid helium) have gone beyond the stage of conceptual design and have entered the domain of prototype design with commercial viability. The large scale application of superconductors in power industry depends on two basic properties: (1) its ability to carry a very high current with no loss or very little loss. (2) its ability to produce medium to high magnetic field. The first property is used in power transmission while the second is used in power generation and storage. (0 Refs)

Title: The design of a superconducting power cable using high T_c superconductors

Author(s): Ichiyanagi, N.; Enokubo, F.; Furuto, Y.

Author Affiliation: Furukawa Electr. Co. Ltd., Chiba, Japan

Conference Title: International Symposium on New Developments in Applied Superconductivity p.343-7

Editor(s): Murakami, Y.

Publisher: World Scientific, Singapore

Publication Date: 1989

Country of Publication: Singapore xix+808 pp.

Conference Date: 17-19 Oct. 1988

Conference Location: Osaka, Japan

Language: English

Document Type: Conference Paper (PA)

Treatment: Practical (P)

Abstract: The feasibility of a 66 kV High T_c superconducting cable was studied. Since the H_{c1} of high T_c superconductor is small, it has to be used between H_{c1} and H_{c2} in order to transmit a large current. Therefore AC losses due to the penetration of magnetic field is a very important problem for such a cable. The loss depends on the critical current of material and the transmission current. The authors feasibility study reveals that $J_c > 10^4$ A/cm² is required for 5000 A class and $J_c > 10^5$ A/cm² for 10000 A class. (1 Refs)

Title: A new proposal of application of liquid nitrogen cooled superconducting power cables to electric power systems

Author(s): Fukagawa, H.; Suzuki, H.; Ichinose, A.; Akita, S.

Author Affiliation: Central Res. Inst. of Electr. Power Ind., Kanagawa, Japan

Conference Title: International Symposium on New Developments in Applied Superconductivity p.337-42

Editor(s): Murakami, Y.

Publisher: World Scientific, Singapore

Publication Date: 1989

Country of Publication: Singapore xix+808 pp.

Conference Date: 17-19 Oct. 1988

Conference Location: Osaka, Japan

Language: English

Document Type: Conference Paper (PA)

Treatment: Applications (A); Economic aspects (E); Practical (P)

Abstract: Superconducting wires which are available at liquid nitrogen temperature have not been developed yet. Therefore, assuming that new types of high T_c superconducting tapes or filaments for AC current can be developed in the near future, the authors performed a conceptual design and cost evaluation of liquid nitrogen cooled superconducting cables and proposed their concrete application to power systems. (0 Refs)

Title: Problems of a transformer with high-temperature superconductors

Original Title: Probleme eines Transformators mit Hochtemperatur-Supraleitern

Author(s): Mueller, W. (Siemens AG Unternehmensbereich KWU, Nuernberg (Germany, F.R.). Transformatorenwerk)

Title: Magnetic materials, varistors and superconductors: Applications and development trends. Proceedings

Original Title: Magnetische Werkstoffe, Varistoren und Supraleiter: Anwendungen und Entwicklungstendenzen. Vortraege

Original Series Title: ETG-Fachbericht

Corporate Source: Energietechnische Gesellschaft im VDE, Frankfurt am Main (Germany, F.R.)

Conference Title: ETC technical meeting on magnetic materials, varistors and superconductors: applications and development trends

Original Conference Title: ETG-Fachtagung ueber Magnetische Werkstoffe, Varistoren und Supraleiter: Anwendungen und Entwicklungstendenzen

Conference Location: Baden-Baden (Germany, F.R.)

Conference Date: 27-28 Sep 1989

Publisher: Berlin (Germany, F.R.) VDE-Verl. v no. 29.

Publication Date: 1989 p 149-158 (171 p)

Report Number(s): CONF-8909323--

Language: In German

Abstract: Fundamental reflections are made on the demands which have to be made on the short-circuit current limitation in the network on the one hand and on the admissible magnetic boundary field strengths of high-temperature superconduction on the other hand. The aim to develop mechanically self-supporting windings led for conventional core-type transformer designs to the construction of concentric-lay winding arrangements with magnetic stray field strengths, which seem to be realizable with regard to material development. Due to the further aim of avoiding core losses, a design study on a coreless high-temperature superconduction transformer was drawn up the windings of which are united in a coaxial cable which is wound up to a toroidal coil. The factors of influence which are relevant for the rating, operating characteristics and the application of a transformer like this are discussed. (orig.).

Title: Design study for a high-temperature superconductor

Original Title: Entwurfstudie zu einem Hochtemperatur-Supraleiter

Author(s): Mueller, W. (Siemens AG Unternehmensbereich KWU, Nuernberg (Germany, F.R.). Transformatorenwerk)

Title: Magnetic materials, varistors and superconductors: Applications and development trends. Proceedings

Original Title: Magnetische Werkstoffe, Varistoren und Supraleiter: Anwendungen und Entwicklungstendenzen. Vortraege

Original Series Title: ETG-Fachbericht

Corporate Source: Energietechnische Gesellschaft im VDE, Frankfurt am Main (Germany, F.R.)

Conference Title: ETC technical meeting on magnetic materials, varistors and superconductors: applications and development trends

Original Conference Title: ETG-Fachtagung ueber Magnetische Werkstoffe, Varistoren und Supraleiter: Anwendungen und Entwicklungstendenzen

Conference Location: Baden-Baden (Germany, F.R.)

Conference Date: 27-28 Sep 1989

Publisher: Berlin (Germany, F.R.) VDE-Verl.

v no. 29.

Publication Date: 1989 p 159-160 (171 p)

Report Number(s): CONF-8909323--

Language: In German

Abstract: For linking practically loss-free transformation and reactive power compensation, a design study on a coreless high-temperature superconduction transformer is drawn up the windings of which are united in a coaxial cable which is wound up into a toroidal coil. The influencing parameters which are relevant for the rating, operating characteristics and the application of a transformer like this are discussed. (orig./MM).

Title: Superconductivity in power engineering. Status, concepts, new aspects

Original Title: Supraleitung in der Energietechnik. Stand, Konzepte, neue Aspekte

Original Series Title: VDI-Berichte

Corporate Source: Verein Deutscher Ingenieure (VDI) - Gesellschaft Energietechnik, Duesseldorf (Germany, F.R.)

Conference Title: Technical meeting on superconductivity in power engineering: Status, concepts, new aspects, with exhibition

Original Conference Title: Fachtagung Supraleitung in der Energietechnik: Stand, Konzepte, Neue Aspekte und Ausstellung

Conference Locaton: Karlsruhe (Germany, F.R.)

Conference Date: 14-15 Jun 1989

Publisher: Duesseldorf (Germany, F.R.) VDI-Verl.

v no. 733.

Publication Date: 1989 (442 p)
Report Number(s): CONF-8906339--
Language: In German

Abstract: This proceedings volume presents 24 conference papers and 15 posters dealing with the following aspects: (1) Principles and elementary aspects of high-temperature superconductivity (3 plenary lectures); (2) Preparation, properties and materials requirements of metallic or oxide superconductors (critical current behaviour, soldered joints, structural studies); (3) Magnet technology (large magnets for thermonuclear fusion devices; magnets for particle accelerators and medical devices); (4) Magnetic levitation and superconductivity; (5) Cryogenics; (6) Energy storage systems using superconducting coils (SMES); (7) Superconducting power transmission cables, switches, transformers, and generator systems for power plant; (8) Supporting activities, industrial aspects, patents. There are thirty-eight records in the ENERGY database relating to individual conference papers. (MM).

Title: Present status and survey of superconducting technology application to power energy system

Title: Design study of a high-T_c superconducting transformer

Original Title: Entwurfsstudie zu einem HTSL-Transformator

Author(s): Mueller, W.

Title: Superconductivity in power engineering. Status, concepts, new aspects

Original Title: Supraleitung in der Energietechnik. Stand, Konzepte, neue Aspekte

Original Series Title: VDI-Berichte

Corporate Source: Verein Deutscher Ingenieure (VDI) - Gesellschaft Energietechnik, Duesseldorf (Germany, F.R.)

Conference Title: Technical meeting on superconductivity in power engineering: Status, concepts, new aspects, with exhibition

Original Conference Title: Fachtagung Supraleitung in der Energietechnik: Stand, Konzepte, Neue Aspekte und Ausstellung

Conference Location: Karlsruhe (Germany, F.R.)

Conference Date: 14-15 Jun 1989

Publisher: Duesseldorf (Germany, F.R.) VDI-Verl.
v no. 733.

Publication Date: 1989 p 423-429 (442 p)

Report Number(s): CONF-8906339--

Language: In German

Abstract: The design study compares the network operating conditions for conventional and for superconducting transformers. The results indicate that high-T_c superconducting transformers require short-circuit current limitation by way of high-T_c superconducting switches. This would permit the short-circuit voltage of the transformers to be indefinitely low. Another task investigated in the study is prevention of core losses, and a draft design is presented of a coreless high-T_c superconducting transformer, whose windings are placed in coaxial cable wound up to form a toroidal coil. The parameters are given that determine the dimensioning, operating behaviour, and applications of such a transformer. (orig.).

Title: 'Hot superconductors' in power-cables?

Author(s): Rasquin, W.

Author Affiliation: Univ.-GH-Duisburg, West Germany

Journal: ETZ Archiv vol.11, no.3 p.99-102

Publication Date: March 1989

Country of Publication: West Germany

Language: German
Document Type: Journal Paper (JP)
Treatment: Theoretical (T)

Abstract: Even if superconductors without AC losses could be found no underground power transmission would be possible without remarkable losses. This is because of the friction losses of the cooling fluid, the dielectric losses of the electrical insulation, the heat entrance from outside and the poor efficiency of the refrigerators. Therefore, it has been calculated how far the critical temperature of a superconducting material must be increased before a superconducting cable could reach the efficiency of naturally cooled cables without overshooting permissible transmission power of the existing supply systems. These calculations show that the critical temperature must reach at least a temperature of 250 K. (7 Refs)

Title: The design of superconducting power cable using high-T_c superconductors
Author(s): Ichiyangi, N.; Enokubo, F.; Furuto, Y. (Furukawa Electric Co. Ltd. (JP))
Title: New developments in applied superconductivity
Author(s)/Editor(s): Murakami, Y. (Lab. for Applied Superconductivity, Faculty of Engineering, Osaka Univ., Osaka (JP))
Conference Title: International symposium on new developments in applied superconductivity
Conference Location: Suita (Japan)
Conference Date: 17-19 Oct 1988
Publisher: Teaneck, NJ (USA) World Scientific Pub. Co.
Publication Date: 1988 p 343-347 (807 p)
Report Number(s): CONF-8810245--
Language: In English
Availability: World Scientific Pub. Co., 687 Hartwell Street, Teaneck, NJ 07666 (USA)

Abstract: The feasibility of 66 kV high {T_c} superconducting cable was studied. Since the H_{c1} of high {T_c} superconductor is small, it has to be used between H_{c1} and H_{c2} in order to transmit a large current. Therefore AC loss due to the penetration of magnetic field is a very important problem for such a cable. The loss depends on the critical current of material and transmission current. This feasibility study reveals that J_c > 10⁴ A/cm² is required for 5000 A class and J_c > 10⁵ A/cm² for 10000 A class.

Title: Properties required for superconductive wires if they are applicable to energy systems and the present situation of the technologies necessary for making superconductive wires
Author(s): Tomiyama, Sakutaro
Title: Assessing the impact of high-temperature superconductivity on electric power
Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power
Conference Location: Tokyo (Japan)
Conference Date: 1-2 Sep 1988
Publisher: Paris (FR) International Energy Agency
Publication Date: 1988 p 137-143 (284 p)
Report Number(s): CONF-8809518--
Language: In English

Abstract: The effort of application of high temperature superconductors for electric machines are in progress but investigators have not yet acquired enough information to evaluate their roles in the said field. Though their known thermal Properties give some insight about the design of future nitrogen cooled machine, the approach is a limited one because of the lack of crucial knowledge on electro-magnetic properties. Some already discovered. Peculiarities of the new materials seems to

urge us to adopt completely different criterions on evaluation. The remarkable recent improvement of AC characteristics of superconducting wires was a chief impetus for the renewed effort to apply superconducting machineries to power industry, where the application for generators was the primary target. The paper describes the technology of generators with superconductors.

Title: Superconductor projects with power utilities in Denmark

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 26-30 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: The Danish Power Utilities ELSAM and ELKRAFT support two projects on superconducting cables using high $\{T_c\}$ ceramic materials. The aim is to develop and test bulk cables and thin film for high current purpose. The methods considered are: drawing in silvertubes, extrusion process of cables, silver superconducting alloy, melt spinning, oxidation of treads of metalalloy, coating of ceramic treads and sputtering on continuous tape. Both projects are described. It is anticipated that the two projects will be followed by additional projects in which the high $\{T_c\}$ superconducting cables can be tested by using them in components such as a transmission cable, a fault current limiter, or a Superconducting Magnetic Energy Storage System.

Title: Presentation of activities by Germany

Author(s): Klose, W.

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 31-66 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: Applications of superconductivity may be classified in two categories: systems where superconductors are practically indispensable for achieving the system's objectives; and superconductor systems have to compete with highly developed conventional technologies. Systems with superconductors as indispensable components include systems where Cryogenic costs are a small fraction of total costs (e.g., fusion reactors and MHD generators) and systems where Cryogenic costs are a significant fracture of total overall costs (e.g., particle accelerators, storage rings, research magnets, and NMR-spectroscopy). The paper mostly discusses the application of superconductivity to developed conventional technologies: AC-power cables, transformers, energy storage systems, AC generators, and magnetic are separation.

Title: Activities within the field of superconductivity in Sweden

Author(s): Claeson, T. (Chalmers Univ. Technology, Gothenburg (Sweden))

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 220-224 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: The new oxide superconductors may have an impact on the power sector. However, the time scale of introducing new components or systems in the utilities is long and many basic materials problems remain to be solved. A persistence and continuously revised assessments as new progress is obtained are needed as well as a parallel development of materials and components. This paper reviews the conclusions to date on the application of superconductivity and possible time frame to the following: fusion, MHD, and AC electric generators; cables; transformers; magnetic energy storage; power stabilization; electric motors; high speed trains; and magnetic separation.

Title: High- Tc superconductors in electric power applications

Author(s): Steennis, E.F.

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 189-219 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: This report describes the possible implications of the discovery of High-Temperature Superconductors in the Electric Power sector in The Netherlands. In particular the material $\text{YBa}_{\text{sub } 2}\text{Cu}_{\text{sub } 3}\text{O}_{\text{sub } 7}$ is discussed. Assuming High-Tc superconducting wires and tapes become available for a reasonable price, the main consequences are as follows. (1) High-Tc superconductors may lead to important possibilities for transformers, generators, motors and magnets for separation. On the long term these superconductors may positively influence the development of MHD generators and fusion reactors. (2) The application of magnetic shielding is obvious. (3) In The Netherlands a large scale application like SMES or a MAGLEV-train is not attractive. Moreover there is no need for power regulation and stabilization. (4) High-Tc superconducting cables are not interesting from an economic point of view. (5) High-Tc superconducting overhead lines will not be accepted for practical reasons. (6) The introduction of rather specific components like current-limiters and switches can improve the dimensioning of the power transmission network. For instance it will lower the level of the short circuit current in a high extent. Such components are therefore very attractive but the technological and economical perspectives can hardly be given now. (7) High-Tc superconducting fuses for power applications are not attractive for practical reasons. (8) Test facilities, based on High-Tc superconductors, like impuls-current generators and compensation coils for cable testing, are very attractive. Here the application of a High-Tc superconductor offers new possibilities.

Title: The main actors in the power sector in Italy

Author(s): Vivaldi, F.; Dufour, A.

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy agency

Publication Date: 1988 p 119-123 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: The paper consists of a series of viewgraphs which review the following: organizations conducting research on superconductivity; power sector applications of low temperature superconductivity (turbogenerators; superconducting cables and magnets, and magnets for MHD conversion); research programs for high temperature superconductivity; superconductivity applications to power sector (power generation, power transmission, energy storage, electrical machinery, and magnets for physics research).

Title: 1987 report of the Committee for Study of Superconduction Technology in Japan

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 167-182 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: The superconductivity oriented cryogenic technology is going to plunge into the phase of practical use after studies made for the past more than 30 years. However, recent sudden progress of research about the findings of oxide based high temperature superconductors may bring about a remarkable revolution in the future technological system. For this reason, it is currently required to review the basic evaluation items concerned with refrigeration techniques, stabilization techniques, etc. in the superconducting technology, repercussive effect mainly on the electric power technology, scale merit in view of economic efficiency, and so on. Working groups were established for electric power systems, generators, transformers, power transmission (power cables), power storage and magnet application (various magnets using superconduction), discuss the following: Necessity and merits (introduction effect) of applying superconducting technology; Technical subjects and solutions in the application of superconducting technology; Technical requirements for superconduct or superconductor; Effect of introducing oxide based high temperature superconductive materials. For the subject of research and development of oxide based high temperature superconductive materials, a working group for conductor production techniques was established to discuss the subject. This report summarizes the results of discussion in the respective working groups.

Title: High T sub c materials in the electric network Why or why not

Author(s): Klein, K.W. (Office of Energy Storage and Distribution, US DOE, Washington, DC (US))

Title: Energy technology XV

Conference Title: 15. annual energy technology conference and exposition

Conference Location: Washington, DC (United States)

Conference Date: 17-19 Feb 1988

Publisher: Rockville, MD (USA) Government Institutes Inc.

Publication Date: 1988 p 844-852 (960 p)

Report Number(s): CONF-880212--

Language: In English

Availability: Government Institutes Inc., 966 Hungerford Dr. No. 24, Rockville, MD 20850 (USA)

Abstract: This paper reports on the new high temperature superconducting ceramics could revolutionize the design of some electrical power systems if major obstacles are cleared. The obstacles include improving the critical current density with applied magnetic fields, improving mechanical properties and chemical stability. For over a decade, the Office of Energy Storage and Distribution (OESD) has supported three applications of superconducting materials superconducting generator; superconducting transmission cable; and superconducting magnetic energy storage (SMES). The future prospects for these and other power system applications depend, first and foremost, on the material properties of the superconductor. For most power applications, the critical current density is the crucial property. An understanding of the properties of the high temperature materials will suggest which applications may be the easiest to realize and which may have the greatest potential. This desired understanding can help formulate research goals and priorities.

Title: Energy loss mechanisms of superconductors used in alternating-current power transmission systems

Author(s): Forsyth, E.B.

Author Affiliation: Brookhaven Nat. Lab., Associated Univs. Inc., Upton, NY, USA

Journal: Science vol.242, no.4877 p.391-9

Publication Date: 21 Oct. 1988

Country of Publication: USA

Language: English

Document Type: Journal Paper (JP)

Treatment: Applications (A); Economic aspects (E); Practical (P)

Abstract: The intrinsic hysteretic loss of superconductors carrying alternating current has been derived from simple models and verified experimentally. In practical cable designs the losses are increased by surface roughness, conductor configuration, and added metallic components. When possible applications by electric utility companies are being considered, such losses are only one of many factors that must be adjusted in an optimization that produces the lowest cost (including both capital and operating expenses) during the lifetime of the system. (48 Refs)

Title: Superconducting transmission line with high-temperature superconductor. Case study

Author(s): Yamamoto, Junya (Osaka Univ. (Japan))

Source: Osaka Daigaku Chodendo Kogaku Jikken Senta Hokoku (Japan) v 7

Publication Date: Aug 1988 p 96-103

Language: In Japanese

Abstract: Specifications of high-/sub c/ superconducting power transmission in a city area were examined, and its profitability was evaluated on the basis of assumed conductor structure and cooling systems, and the current price of superconducting material. Two parallel circuits of a three phase underground transmission line between a power pool in the suburbs and a transformer station in the central area was assumed. Conductor characteristics were assumed as same as those of Nb₃Sn tape. Three conductors of 97.6mm in diameter were housed in a cable of 258.1mm in bore, and the cable was cooled by pump circulation of liquid nitrogen recondensed by a refrigerator or open-cooled by vaporization latent heat of liquid nitrogen. Since the tunnel cross section was smaller than that of OF cables, the construction cost was reduced by half, however, if

the conductor price was assumed as same as that of Nb₃Sn, the cable cost was about 4 times that of OF cables, and the initial cost thus increased by 30% and operation cost by 19%. 6 figs., 9 tabs.

Ekitai chisso reikyaku koryu chodendo cable no gainen sekkei to keizaisei hyoka. (Conceptual design of high T_c superconducting power cable and its economic evaluation)

Suzuki, H. ; Inchinose, A. ; Fukagawa, H. ; Akita, S.

Central Research Inst. of Electric Power Industry, Tokyo (Japan)

Report No.: CRIE-W-88004

Aug 88 45p

Languages: Japanese

Journal Announcement: GRAI9011; ERA9018

In Japanese

U.S. Sales Only. Portions of this document are illegible in microfiche products

NTIS Prices: PC A03/MF A01

Country of Publication: Japan

The authors performed a conceptual design and the cost evaluation of liquid nitrogen cooled superconducting power cables. They showed the results and clarified the concrete application of high T_c superconducting cables to electric power systems. They designed two types of cables, which have semi-flexible structure of three cable cores within one pipe. The optimum transmission voltage is 66kV for 2.5GVA/cct or 154kV for 5.0GVA/cct. This means an excellent economical merit of neglecting underground power substations in the metropolitan cities. Instead of 6ccts of 275kV conventional OF cables installed in a culvert, only one circuit of 66kV liquid nitrogen cooled superconducting cable can transmit the same capacity. They clarified that if all conventional cables in one culvert can be replaced by new cables, the transmission capacity can be increased 5-6 times or maximum 7.5 times. 11 refs., 10 figs., 12 tabs.

Title: Conceptual design of high T_c superconducting power cable and its economic evaluation

Original Title: Ekitai chisso reikyaku koryu chodendo cable no gainen sekkei to keizaisei hyoka

Author(s)/Editor(s): Suzuki, Hiroshi; Ichinose, Ataru; Fukagawa, Hirotsada; Akita, Sirabe

Corporate Source: Central Research Inst. of Electric Power Industry, Tokyo (Japan)

Publication Date: Aug 1988 (45 p)

Report Number(s): CRIE-W-88004

Order Number: DE90734940

Language: In Japanese

Availability: NTIS (US Sales Only), PC A03/MF A01

Abstract: The authors performed a conceptual design and the cost evaluation of liquid nitrogen cooled superconducting power cables. They showed the results and clarified the concrete application of high T_c superconducting cables to electric power systems. They designed two types of cables, which have semi-flexible structure of three cable cores within one pipe. The optimum transmission voltage is 66kV for 2.5GVA/cct or 154kV for 5.0GVA/cct. This means an excellent economical merit of neglecting underground power substations in the metropolitan cities. Instead of 6ccts of 275kV conventional OF cables installed in a culvert, only one circuit of 66kV liquid nitrogen cooled superconducting cable can transmit the same capacity. They clarified that if all conventional cables in one culvert can be replaced by new cables, the transmission capacity can be increased 5-6 times or maximum 7.5 times. 11 refs., 10 figs., 12 tabs.

Title: Application of superconductivity to electric power technology
Author(s): Tanaka, Toshikatsu
Affiliation: Central Research Inst. of Electric Power Industry, Tokyo, Japan
Source: Nippon Kikai Gakkaishi (Japan) v 91:835
Publication Date: 5 Jun 1988 p 46-50
Language: Japanese

Abstract: Application of the superconductivity to the electric power technology is described. Whereas the cooling efficiency of liquid He is lower than 0.2%, that of liquid nitrogen is 10%, or more than 50 times larger than liquid He. As the evaporation potential heat is 63 times, the thermal conductivity is 7.2 times larger, the insulation breakdown strength is high and the price is one-fiftieth lower, reducing the economic scale greatly. The capacity of superconducting generators that are competitive with conventional machines are 1000 MVA with the liquid He and 500 MVA when the superconductivity at high temperature is possible with the liquid nitrogen. For the transformers, the AC wire of high temperature superconducting material is required but the research on it is not yet started. While the loss of superconducting power cable is low and it is suitable for large capacity DC power transmission, it is advantageous even with 2 million KVA if the liquid nitrogen cooling is possible. The superconducting magnetic energy storage (SMES) is useful in the system power pooling and storage, and it is competitive with the pumped storage power generation at 4 million KWh with He and 1 million KWh is allowable if the liquid nitrogen can be used. The impact of high temperature superconducting material to the power technology is high and the superconducting cable and SMES are promising. (3 figs, 3 tabs, 3 refs)

Title: Superconductivity and its application on electric power technology
Author(s): Hasegawa, Jun
Affiliation: Hokkaido Univ., Faculty of Engineering, Sapporo, Japan
Source: Karyoku Hatsuden (Japan) v 39:2
Publication Date: 15 Feb 1988 p 9-17
Language: Japanese

Abstract: This report describes the following items. 1. Superconductivity phenomena (Temperature dependency of electric resistance of metals. Important properties of superconductivity (Perfect conductivity. Perfect anti-magnetism. Quantum effect). Second class superconductive material (Magnetic flux flow. Pin-stop effect. Critical current). High temperature superconductive material (Properties of ceramic superconductive material. Basic requirement of commercialization). 2. Application of superconductivity technology to power industry (Electric power, electronics and communication, transportation, etc.). Superconductive electric power transmission cable. Superconductive transformer. Superconductive energy storage. Fundamental conditions for the commercialization of the new superconductive material are the following three: Electric resistance is really zero at the temperature below the critical temperature (liquid nitrogen). Critical current density reaches the level of 10^5 - 10^6 A/cm². Production cost of the superconductive wire reaches the same level as the present superconductive wire. (7 figs, 4 tabs, 7 refs)

Title: Technical applications of superconductors-requirements on new high temperature superconductors
Author(s): Bogner, G.
Author Affiliation: Siemens AG, Erlangen, West Germany
Conference Title: Commission of the European Communities European Workshop on High T_c/ Superconductors and Potential Applications. Proceedings p.217-18
Publisher: Comm. Eur. Communities, Brussels, Belgium
Publication Date: 1987

Country of Publication: Belgium 465 pp.
Conference Date: 1-3 July 1987
Conference Location: Genova, Italy
Language: English
Document Type: Conference Paper (PA)
Treatment: Applications (A); Economic aspects (E); General, Review (G)

Abstract: The paper demonstrates with three examples of possible applications the technical requirements which have to be fulfilled by the new high T_c superconductors and what cost savings can be expected compared with conventional superconductors (NbTi and Nb₃Sn). The areas of applications chosen are: magnets for magnetic resonance imaging (MRI), AC power cables and turbogenerators. The reasons for this choice were: MRI today has the largest market potential for SC magnets on a NbTi basis; with AC power cables it is possible to use a thin film superconductor in a comparatively small magnetic field; SC turbogenerators are of great interest even with NbTi fieldwindings. It is assumed that the high T_c superconductors have to be cooled with liquid nitrogen at about 77 K. (0 Refs)

Title: Application of high temperature superconducting materials
Author(s): Tanaka, Toshikatsu
Affiliation: Central Research Inst. of Electric Power Industry, Tokyo, Japan
Source: Kagaku Kogaku (Japan) v 51:11
Publication Date: 5 Nov 1987 p 35-39
Language: Japanese

Abstract: As for superconducting materials, there are still many problems such as their natures, etc. to be clarified. However, because of such merits that a large amount of electric current can be transferred with an extremely small loss and a strong magnetic field can be generated, the development of the application researches is in progress. In this article, the application to the electric power fields is explained. In the field of superconducting generators, many countries are conducting its research and development and in Japan, in accordance with the Moonlight Project, its research and development are planned to be conducted for 8 years from 1988 and the stage of a 70MVA model machine has already been over. Currently, wire rods of NbTi or Nb₃Sn as well as a cooling device are the subjects for study. Concerning superconducting transformers, it has been experimentally calculated that in comparison with the conventional transformers, the loss will be decreased by half and the weight be decreased down to 50-60%, but the increase of the critical electric current density is considered to be solved first. With respect to superconducting cables, studies are being made on liquid nitrogen cooled cables in addition to liquid helium cooled ones. In the field of superconducting energy storage, the conceptual design of a 5 million KWh SMES was completed in 1985 as a commissioned project of NEDO. (6 figs, 3 tabs, 7 refs)

V. ASSESSMENTS BEARING UPON FAULT CURRENT LIMITERS

The following pages provide citations and abstracts for 10 reports, each bearing upon the use of ceramic superconductors in fault current limiters. Some reports describe more than one topic; in that case the report is listed in this section and in other appropriate sections. The most recent reports are from 1991 and the earliest is from 1988.

Fault Current Limiters

Title: High-temperature superconductor for microelectronics and energy technology
Author(s): Adrian, G.; Fischer, R.; Schneider, R.
Journal: Elektrotechnik vol.69, no.5 p.432-4
Publication Date: May 1991
Country of Publication: Netherlands
Language: German
Document Type: Journal Paper (JP)
Treatment: Practical (P)

Abstract: The recent development of copper oxide ceramics, with critical temperatures above 77 K, offers new possibilities for the production and uses of high-temperature superconductors. A research group including Daimler-Benz, Siemens and KFA Julich is investigating new applications of high temperature superconductors. These include components for high-frequency technology, active superconductor components, and components combining superconductors and semiconductors. The creation and microstructuring of $Y_{1-x}Ba_xCuO_{7-y}$ layers by cathodic sputtering and by laser ablation are also under consideration. Applications of high temperature superconductors in other areas, including short-circuit current limiters, are listed. (0 Refs)

Title: Current-limiting reactor based on high-T_c superconductors
Author(s): Bashkirov, Y.A.; Fleishman, L.S.; Patsayeva, T.Y.; Sobolev, A.N.P.; Vdovin, A.B. (Khrizhzhansky Power Engineering Inst., Leninsky prospect, 19, Moscow 117927 (SU))
Conference Title: 1990 applied superconductivity conference
Conference Location: Snowmass, CO (United States)
Conference Date: 24-28 Sep 1990
Source: IEEE Transactions on Magnetics (Institute of Electrical and Electronics Engineers) (United States) v 27:2
Publication Date: Mar 1991 p 1089-1092
Report Number(s): CONF-900944--
Language: In English

Abstract: This paper deals with one of the possible applications of high-temperature superconductors in power devices with superconducting shields. The behavior was analyzed of a current-limiting reactor combining a high-T_c shield and an iron core in an a.c. circuit. The model of the device was built comprising a stack of yttrium ceramic rings. The experiments with such a reactor confirmed the presence of nonlinear characteristics with transition from low to high impedance.

Title: Inductive current limiter when using ceramic high temperature superconductors
Original Title: Induktiver Strombegrenzer unter Verwendung von keramischen Hochtemperatur Supraleitern
Author(s)/Editor(s): Dersch, H. (ABB Forschungszentrum, Baden-Daettwil (CH))
Corporate Source: Bundesamt fuer Energiewirtschaft, Bern (Switzerland)
Publication Date: Dec 1990 (29 p)
Report Number(s): ENET-8900075/3
Order Number: DE92789841

Contract Number (Non-DOE): NEFF Projekt 406

Language: In German

Availability: OSTI; NTIS (US Sales Only); ENET, Elfenaueweg 29, CH-3006 Bern (CH)

Abstract: As an inherently safe component, the current limiter in high temperature superconductors is intended to prevent and limit damage in the case of short circuits in electrical networks. It achieves both an increase in the safety of the installations and thus ensures the availability of the energy supply, as well as reducing costs, as switches and installations no longer need to be dimensioned for loads caused by short circuits. In addition to this, current limiters represent an early implementation of the high temperature superconductor which can be applied in energy technology and thus act as a valuable pacesetter for further applications of these materials. During the period covered by the reports a limiter of average output (20 kVA) was built and tested as an important development step. Producing the switch winding in superconductive rings with 20 cm diameter and 100 A current carrying capacity respectively has led to the largest application of high temperature superconductors to-date. The dynamic tests have, however, revealed an unexpected problem, namely the formation of hot spots during the switching process. Structural measures to solve this are currently undergoing tests. It is planned, to start immediately after completion of this work to build a prototype with full output (20 MVA). 17 figs.

Title: Superconducting technology for current limiters and switchgear

Author(s): Damstra, G.C.; Greenwood, A.; Sabot, A.; Schramm, H.-H.

Conference Title: CIGRE. Proceedings of the 33rd Session. International Conference on Large High Voltage Electric Systems p.1-1.1/1-7 vol.2

Publisher: CIGRE, Paris, France

Publication Date: 1990

Country of Publication: France 2 vol. 2772 pp.

Conference Date: 26 Aug.-1 Sept. 1990

Conference Location: Paris, France

Language: English

Document Type: Conference Paper (PA)

Treatment: Applications (A); Practical (P)

Abstract: The authors attempt to review the status and the perspective of using superconductors for current limitation and switching. The considerations apply to both 'conventional' low temperature superconductors as for the various high temperature superconductors (HTSC). However, the possible economic advantages of HTSC are taken into account. While in other equipment the superconductor is operating under stationary conditions and remains superconducting continuously, current limiters and switchgear use the transition to normal conductivity. By means of this transition a superconducting element can only act as a current limiting device, with the current limited to a value determined by the resistance of the superconductor in the normal conducting state. For final interruption of the residual current and voltage withstand an additional switching device in series with the superconductor is needed. Also, this switching device has to be able to break all currents which are below the critical current of the superconductor, such as the different types of load currents. (14 Refs)

Title: YBaCuO thin films used as electrical switch or current limiter

Author(s): Baixeras, J.; Carrie, F.; Chabrierie, J.P.; Teherani, F.H.; Kreisler, A.; Pech, T.; Poullain, G.; Hamet, J.F.; Muniesa, J.; Rapeaux, M.; Aymami, J.

Author Affiliation: Lab. de Genie Electr. de Paris, Ecole Supérieure d'Electr., Gif sur Yvette, France

Journal: Proceedings of the SPIE - The International Society for Optical Engineering vol.1287 p.104-15

Publication Date: 1990
Country of Publication: USA
Conference Title: High T/sub c/ Superconductivity: Thin Films and Applications
Conference Sponsor: SPIE
Conference Date: 20-21 March 1990
Conference Location: San Diego, CA, USA
Language: English
Document Type: Conference Paper (PA); Journal Paper (JP)
Treatment: Practical (P); Experimental (X)

Abstract: The authors have studied the ability of high T/sub c/ superconductors to operate as electrical switches or current limiters. For this purpose, they have used YBaCuO films, deposited on polycrystalline zirconia slabs by various techniques: conventional two-step processes as well as rapid thermal annealing have been considered. The main results are that with a T/sub c/ (onset) of 91 K, the variation of the critical current density versus frequency shows that it will be possible to use the films at 50-60 Hz, although there is a need to improve the low current density films to demonstrate this. (15 Refs)

Title: High-temperature superconductors Their potential role in electric utility applications and what must be done to use them
Author(s): Giese, R.F.; Sheahen, T.P.; Wolsky, A.M. (Argonne National Lab., IL (United States)); Sharma, D.K. (Electric Power Research Inst., Palo Alto, CA (United States))
Sponsoring Organization: EPRI Electric Power Research Inst., Palo Alto, CA (United States)
Conference Title: 52. American power conference
Conference Location: Chicago, IL (United States)
Conference Date: 23-25 Apr 1990
Source: Proceedings of the American Power Conference (United States) v 52
Publication Date: 1990 p 776-782
Report Number(s): CONF-9004133--
Contract Number (Non-DOE): Agreement RP7911-1
Language: In English

Abstract: This paper describes a number of proposed applications of superconductivity for the electric utility sector. The current status of their development is summarized, and the potential impact of successful development of high-temperature superconductors (HTSCs) is discussed. Performance goals for development of HTSCs are presented and compared with the current status of development of HTSCs. Applications discussed include large-scale generators, motors, transmission lines, magnetic storage, transformers, power electronics, and fault-current limiters.

Title: Comparative analysis of nonlinear reactors with screens of low-temperature and high-temperature (approx 90 K) superconductors
Original Title: Sravnitel'nyj analiz nelinejnykh reaktorov s ehkranami iz nizkotemperaturnykh i vysokotemperaturnykh (approx 90K) sverkhprovodnikov
Author(s): Vershinin, Yu.N.; Meerovich, V.M.; Naumkina, I.E.; Novikov, N.L.; Sokolovskij, V.L.
Source: Elektrichestvo (USSR) v 1
Publication Date: Jan 1989 p 1-6
Language: In Russian

Abstract: Design features of current-limiting reactors with superconducting screens, designated for limiting currents of short circuit in power systems are considered. Comparative analysis of technical and economical characteristics of nonlinear reactors with screens and cryogenic supply systems of various types is conducted. Relations for calculating optimal parameters of reactors with closed and open screens and helium and nitrogen refrigeration systems are obtained.

Title: Network coupling via a current-limiting throttle with a high-T_c superconductor core

Original Title: Netzkupplung ueber eine strombegrenzende Drossel mit Hoch-T_c-Supraleiter-Kern

Author(s): Bochenek, E.; Fischer, R.; Lampen, U.; Voigt, H. (Daimler-Benz AG, Frankfurt am Main (Germany, F.R.). Forschungsinstitut Frankfurt)

Title: Magnetic materials, varistors and superconductors: Applications and development trends. Proceedings

Original Title: Magnetische Werkstoffe, Varistoren und Supraleiter: Anwendungen und Entwicklungstendenzen. Vortraege

Original Series Title: ETG-Fachbericht

Corporate Source: Energietechnische Gesellschaft im VDE, Frankfurt am Main (Germany, F.R.)

Conference Title: ETC technical meeting on magnetic materials, varistors and superconductors: applications and development trends

Original Conference Title: ETG-Fachtagung ueber Magnetische Werkstoffe, Varistoren und Supraleiter: Anwendungen und Entwicklungstendenzen

Conference Location: Baden-Baden (Germany, F.R.)

Conference Date: 27-28 Sep 1989

Publisher: Berlin (Germany, F.R.) VDE-Verl.

v no. 29

Publication Date: 1989 p 161-166 (171 p)

Report Number(s): CONF-8909323--

Language: In German

Abstract: A current-limiting concept is tested by means of a choke with a current-responsive inductivity for linking three-phase current supplies. The choke has a core of a material with a high transition point T_{c} . In the case of nominal current, the core is superconductive and keeps the resulting inductance of the choke low by shield currents. In the case of overload, the core passes into the normal conductive state due to the increased magnetic field of the winding. The resulting inductance of the choke rises and, in doing so, effects current limitation. (orig.).

Title: Current-limiting coils with high-temperature superconductors

Original Title: Strombegrenzende Drossel mit Hochtemperatur-Supraleitern

Author(s): Voigt, H.; Bochenek, E.; Fischer, R.; Lampen, U.

Title: Superconductivity in power engineering. Status, concepts, new aspects

Original Title: Supraleitung in der Energietechnik. Stand, Konzepte, neue Aspekte

Original Series Title: VDI-Berichte

Conference Title: Technical meeting on superconductivity in power engineering: Status, concepts, new aspects, with exhibition

Original Conference Title: Fachtagung Supraleitung in der Energietechnik: Stand, Konzepte, Neue Aspekte und Ausstellung

Conference Location: Karlsruhe (Germany, F.R.)

Conference Date: 14-15 Jun 1989

Publisher: Duesseldorf (Germany, F.R.) VDI-Verl.

v no. 733

Publication Date: 1989 p 405-413 (442 p)

Report Number(s): CONF-8906339--

Language: In German

Abstract: A current-limiting coil with a core made of superconducting high-T_c material is tested with a view to application as a short-circuit current limiter in a three-phase network. According to the current limiter concept, the coil core is a superconductor during rated current operation, and thus keeps the coil inductance low by means of the screening effects. Under overload conditions, the magnetic field of the core winding reduces the core to normal conductivity, which eliminates the screening effects, increases the inductance, and thus results in current limitation. (orig.).

Title: Superconductor projects with power utilities in Denmark

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 26-30 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: The Danish Power Utilities ELSAM and ELKRAFT support two projects on superconducting cables using high (T_c) ceramic materials. The aim is to develop and test bulk cables and thin film for high current purpose. The methods considered are: drawing in silvertubes, extrusion process of cables, silver superconducting alloy, melt spinning, oxidation of treads of metalalloy, coating of ceramic treads and sputtering on continuous tape. Both projects are described. It is anticipated that the two projects will be followed by additional projects in which the high (T_c) superconducting cables can be tested by using them in components such as a transmission cable, a fault current limiter, or a Superconducting Magnetic Energy Storage System.

VI. ASSESSMENTS BEARING UPON GENERATORS

The following pages provide citations and abstracts for 85 reports, each bearing upon the use of ceramic superconductors in generators. Some reports describe more than one topic; in that case the report is listed in this section and in other appropriate sections. The most recent reports are from 1992 and the earliest is from 1987.

Generators

Title: Super reality (superconductors in power engineering)

Author(s): Sacks, T.

Journal: Electrical Review vol.225, no.5 p.24-6

Publication Date: 6-19 March 1992

Country of Publication: UK

Language: English

Document Type: Journal Paper (JP)

Abstract: The author discusses some of the problems of high temperature superconductors (HTS) when applied to power engineering applications. The author then briefly summarises the areas in which HTS may be used in the future and upon which work is being carried out. These are: DC motors, AC generators, power transformers, fault current limiters, energy storage, magnetic separators, power cables, and transportation. (0 Refs)

Title: Investigations and developments in the field of superconductive turbogenerators.

Author: Glebov, I. A.; Chubraeva, L. I.

Corporate Source: All Union Research Inst for Electrical Machinery, Leningrad, USSR

Source: Cryogenics v 31 n 6 Jun 1991 p 450-452

Publication Year: 1991

Language: English

Document Type: JA; (Journal Article)

Treatment: G; (General Review); X; (Experimental)

Journal Announcement: 9111

Abstract: Investigations and developments in the field of superconductive electrical machines have been given high priority in the USSR. Having constructed and tested small capacity generators of 5, 18 and 1200 kW, work was carried out on 20 and 300 MVA superconductive turbogenerators. At the present time developmental studies and investigations are in progress concerning the structural elements of a future 1200 MW machine and the simulation of its normal and transient processes. These studies are part of the development of a new class of large electrical machines with high efficiency, smaller masses and higher reliability, compared to the conventional machines. (Author abstract) 3 Refs.

Title: Proceedings of the 26th Intersociety Energy Conversion Engineering Conference - IECEC '91.

Author: Anon (Ed.)

Conference Title: Proceedings of the 26th Intersociety Energy Conversion Engineering Conference - IECEC '91

Conference Location: Boston, MA, USA

Conference Date: 1991 Aug 4-9

Sponsor: SAE; ANS; AIChE; IEEE; ASME; et al

E.I. Conference No.: 15187

Source: Proceedings of the Intersociety Energy Conversion Engineering Conference v 4 1991

Publ by IEEE, IEEE Service Center, Piscataway, NJ, USA. 575p

Publication Year: 1991

Language: English

Document Type: CP; (Conference Proceedings)
Treatment: T; (Theoretical) ; A; (Applications); X; (Experimental)
Journal Announcement: 9202

Abstract: The Proceedings of the Conference contains 98 papers dealing with energy conservation, policies and environment, energy systems and alternative fuels, innovative and advanced systems. Individual papers deal with a laminar flow heat exchanger; a possible utilization of the thermal energy discharged from sintering plants of steel works; energy for developing countries; U.S. domestic energy policy; advanced fuels, including acetylene and water as fuels for spark ignition engines; conversion technology; mechanical and thermal storage, including: lithium fluoride, aquifer thermal storage, phase change polymers, ice-on-coil type ice energy storage, cryogenic magnetic bearing systems, magnetically suspended flywheel energy storage; automotive natural gas, methanol engines, innovative spacecraft thermal storage devices, liquid metal heat pipes, innovative railroad propulsion, range extended hybrid vehicles; advanced energy concepts, including regenerative free energy technology, worldwide wireless power transfer, zero-point energy, vacuum energy, muller motor/generator, nonlinear dynamics, particle beam weapons based on Nikola Tesla's design, tank circuits, Bedini free energy generator, WIN process, Methernitha free energy machine, one piece Faraday generator, PODMOD power generation, Reed magnetic motor. Further sections deal with high temperature superconductivity and thermal magnetic stability, superconducting magnetic energy storage, superconducting power and magnetic devices at high temperature.

Title: Implications of high temperature superconductors for power generation

Author: Fingers, R. T.; Oberly, C. E.

Corporate Source: Aero Propulsion and Power Directorate, Wright-Patterson Air Force Base, OH, USA

Conference Title: Proceedings of the 26th Intersociety Energy Conversion Engineering Conference - IECEC '91

Conference Location: Boston, MA, USA

Conference Date: 1991 Aug 4-9

Sponsor: SAE; ANS; AIChE; IEEE; ASME; et al

E.I. Conference No.: 15187

Source: Proceedings of the Intersociety Energy Conversion Engineering Conference v 4

Publ by IEEE, IEEE Service Center, Piscataway, NJ, USA. p 564-569

Publication Year: 1991

Language: English

Document Type: PA; (Conference Paper)

Treatment: X; (Experimental)

Journal Announcement: 9202

Abstract: Superconducting generators for high power applications have been of interest for a number of years. Superconducting generators using low temperature superconductors (LTS) have been manufactured to produce up to 20 MW of electrical power and have been configured in either synchronous alternators which have an AC output that may be subsequently rectified to produce DC and homopolar generators which produce low voltage DC. Typically these generators require scrupulous attention to vacuum integrity for cryogenic insulation at 4.2L and tend to be somewhat fragile because of extensive thermal and magnetic shields that are not required in conventional power generators. Recently, high purity aluminum composites have been developed for a high power AC generator that is cooled by cryogenic hydrogen at 21K. This aluminum generator is very compact and lightweight and is much more robust than a generator made with LTS because extensive thermal and magnetic shields are not required internally. The advent of high temperature superconductors (HTS) has resulted in new potential for the superconducting generator because HTS can operate at and above 21K in a generator that does not require elaborate thermal and

electromagnetic shields similar to the aluminum generator. Since the great advantage of cryogenic generators is gained at high power, this discussion will be limited to generators of roughly one megawatt and greater. The implications of HTS for high power generator applications will be discussed with emphasis on conceptualizing an early feasibility demonstrator that will benefit from rudimentary HTS that exist now or in the near future. While the technology of HTS is in its infancy, the successful early demonstration of the feasibility of a powerful generator employing HTS should lead to future applications. (Author abstract) 23 Refs.

Title: Energy applications of superconductivity
Author(s): Schneider, T.R.; Dale, S.J.; Wolf, S.M.
Author Affiliation: EPRI, Palo Alto, CA, USA
Journal: AIP Conference Proceedings no.219 p.635-45
Publication Date: 1991
Country of Publication: USA
Conference Title: Fourth Annual Conference on Superconductivity and its Applications
Conference Date: 18-20 Sept. 1990
Conference Location: Buffalo, NY, USA
Language: English
Document Type: Conference Paper (PA); Journal Paper (JP)
Treatment: General, Review (G)

Abstract: Recent progress in developing high-temperature superconductors has enhanced the economic viability of energy applications such as power systems, motors, material processing and handling, refrigeration, transportation, and power electronics. This paper discusses the technical and economic issues associated with these applications. (0 Refs)

Title: Present status and survey of superconducting technology application to power energy system
Original Title: Denryokuter dot energy bun prime ya ni okeru cho dendo gijutsu oyo no doko to shorai tenbo
Author(s): Ueda, K. (Central Research Inst. of Electric Power Industry, Tokyo (Japan))
Source: Denki Gakkai Ronbunshi, B (Transactions of the Institute of Electrical Engineers of Japan) (Japan) v 111:4
Publication Date: 20 Apr 1991 p 339-343
Language: In Japanese

Abstract: Japan in 1987 programmed a nation-wide research project by collecting the basic power of the universities, research institutions and the industries. Research union of superconductive power generation-related equipments and the materials (Super-GM) and the International Superconductive Industry Research Center (ISTEC) were established to promote the applications to low/high temperature superconductive material, generators and power storage. This report attempts to summarize and prospect the introductory effect or the research and development status towards the current system. Activities are outlined on the activities of the superconductivity experts in the International High Power System Conference (CIGRE), International Electric Standard Conference, Superconductive Technology Sector (IEC/TC 90) and the International Energy Association (IEA). By the end of this century, cables and compact motors which gives high effect of introduction will be completed in trial making thereof. Especially the cables will be expected to omit the use of a large ultra high voltage transforming station by the renovation wherein the large current low voltage single stage system replace the 275 kV multistage ultra high voltage metropolitan cable system. 1 fig., 4 tabs.

Title: 1990 Applied Superconductivity Conference
Journal: IEEE Transactions on Magnetics vol.27, no.2, pt.2
Publication Date: March 1991
Country of Publication: USA
Conference Title: 1990 Applied Superconductivity Conference
Conference Sponsor: IEEE
Conference Date: 24-28 Sept. 1990
Conference Location: Snowmass, CO, USA
Language: English
Document Type: Conference Proceedings (CP); Journal Paper (JP)

Abstract: The following topics are dealt with: phenomenology and tunneling; surface impedance; wires and tapes; melt texturing; grain boundaries; bulk synthesis and properties; HTS (high-temperature superconductor) techniques; thin films; spectroscopy; proximity effects; surfaces and interfaces; multilayers; critical currents; surface resistance and photoresponse; MRI magnets; SMES I and II; accelerator magnets; conductors and leads; switches; shields; AC losses, stability, and quench; detector magnets; high-filled conductor processing and properties; spectrometer magnets; miscellaneous magnets; magnetic bearings; HTS microwave filters; HTS SQUIDS; novel electronic devices; digital electronics; LTS (low-temperature superconductor) microwave devices; SQUIDS for biomagnetism; HTS analog devices; LTS SQUIDS; HTS microwave devices; HTS tunneling; SNS structures; LTS fabrication; HTS microbridges; solitons and arrays; LTS microwave detectors. Abstracts of individual papers can be found under the relevant classification codes in this or other issues.

Title: Panel discussion on the impact of superconducting technologies on future power systems and equipment-superconducting generators
Author(s): Lambrecht, D.
Conference Title: CIGRE. Proceedings of the 33rd Session. International Conference on Large High Voltage Electric Systems p.1-1.1/1-8 vol.2
Publisher: CIGRE, Paris, France
Publication Date: 1990
Country of Publication: France 2 vol. 2772 pp.
Conference Date: 26 Aug.-1 Sept. 1990
Conference Location: Paris, France
Language: English
Document Type: Conference Paper (PA)
Treatment: Practical (P)

Abstract: When comparing the status of the development and the prospects of application of the various electric power system equipment, superconducting (SC) generators are the most promising candidates for future application on a broad scale. They have already highly developed with respect to both size and technological maturity. This refers to turbine generators with a superconducting field winding and a normal-conductive air-gap stator winding. The author discusses the advantages and disadvantages of such generators and the problems which need to be solved. Future developments and application of high temperature superconductors are also discussed. (12 Refs)

Title: Application of superconductivity in power engineering-main activities in the Federal Republic of Germany
Author(s): Bogner, G.
Conference Title: CIGRE. Proceedings of the 33rd Session. International Conference on Large High Voltage Electric Systems p.1-1/1-11 vol.2

Publisher: CIGRE, Paris, France
Publication Date: 1990
Country of Publication: France 2 vol. 2772 pp.
Conference Date: 26 Aug.-1 Sept. 1990
Conference Location: Paris, France
Language: English
Document Type: Conference Paper (PA)
Treatment: Applications (A); Practical (P)

Abstract: The activities in the FRG with respect to the application of superconductivity in power engineering are characterized by two aspects: first, large efforts are under way concerning the application of existing, commercially available metallic superconductors (NbTi, NbSn); and secondly, strong emphasis is put on the development of the new high T_c superconductor (HTSC) to a technically usable product, and to clarify their future significance for power engineer. In the first category the author discusses an 850 MVA superconducting generator, SMES, and tokamak magnet system. In the second category the author discusses long length HTSC conductors and a 20 km, 1000 MVA grid to load interconnections. (15 Refs)

Title: Proceedings of the Low Temperature Engineering and Cryogenics Conference 1990. LTEC90
Editor(s): Burton, M.J.; Richardson, R.N.
Publisher: Univ. Southampton, Southampton, UK
Publication Date: 1990
Country of Publication: UK 338 pp.
Conference Date: 17-19 July 1990
Conference Location: Southampton, UK
Language: English
Document Type: Conference Proceedings (CP)

Abstract: The following topics were dealt with: cryogenics; low temperature techniques; railways; magnetic levitation; superconducting magnets; switches; synchronous generators; superconducting machines; machine testing; thermodynamics; kinetic theory of gases; superconducting magnetic energy storage; heat exchangers; liquefaction of gases; refrigerators; refrigeration; magnetic separation; storage rings; synchrotron radiation; distillation; high temperature superconductors; superconducting cables; power apparatus; cryopumping; instrumentation; wind tunnels; enthalpy; aerospace instrumentation.

Title: Power engineering applications of high T_c superconductors
Author(s): Appleton, A.D.
Conference Title: Proceedings of the Low Temperature Engineering and Cryogenics Conference 1990. LTEC90 p.00.5/1-7
Editor(s): Burton, M.J.; Richardson, R.N.
Publisher: Univ. Southampton, Southampton, UK
Publication Date: 1990
Country of Publication: UK 338 pp.
Conference Date: 17-19 July 1990
Conference Location: Southampton, UK
Language: English
Document Type: Conference Paper (PA)
Treatment: Applications (A); Practical (P)

Abstract: The challenge to power engineers presented by the development of high temperature superconductors is that new generations of power equipment are going to become possible and a decision must be made on when to start on the necessary development programmes. Is it better to wait until the new materials are in the form which will ultimately be desirable? or should the developments start in anticipation of the availability of the materials? This paper attempts to assist in the making of this decision. (0 Refs)

Title: High-temperature superconductors: their potential role in electric utility applications and what must be done to use them

Author(s): Giese, R.F.; Sheahen, T.P.; Wolsky, A.M.; Sharma, D.K.

Author Affiliation: Argonne Nat. Lab., IL, USA

Conference Title: Proceedings of the American Power Conference p. 776-82

Publisher: Illinois Inst. Technol, Chicago, IL, USA

Publication Date: 1990

Country of Publication: USA xxxiv+1050 pp.

Conference Sponsor: Illinois Inst. Technol

Conference Date: 23-25 April 1990

Conference Location: Chicago, IL, USA

Language: English

Document Type: Conference Paper (PA)

Treatment: Applications (A)

Abstract: A number of proposed applications of superconductivity for the electric utility sector are described, the current status of their development is summarized, and the potential impact of successful development of high-temperature superconductors (HTSC) is discussed. Performance goals for development of HTSC are presented and compared with the current status of development of HTSC. Applications discussed include large-scale generators, motors, transmission lines, magnetic storage, transformers, power electronics, and fault-current limiters. (15 Refs)

Title: Superconductivity. Dealing in futures

Author: Anon

Source: EPRI Journal v 15 n 1 Jan-Feb 1990 p 18-27

Publication Year: 1990

Language: English

Document Type: JA; (Journal Article)

Treatment: A; (Applications)

Journal Announcement: 9007

Abstract: Utility interest in the development of the new, high temperature superconductors-HTSCs goes beyond their possible application in the power grid. The introduction of HTSCs in customer applications is likely to have an even greater impact on utilities, increasing the value of electricity and expanding its use in virtually every area of life. According to a recently completed EPRI/DOE assessment, HTSCs could open a window of opportunity for many new uses of superconductivity-from powerful but compact electric motors to high-speed computers to magnetically levitated trains. Researchers are now working to narrow the gap between the potential of HTSCs and their engineering practicality and are looking for ways to shape the brittle ceramic materials into useful forms. Recognizing the enormous potential of these revolutionary materials for both customer and utility applications, EPRI continues to monitor and support the national effort to put HTSCs to work. (Author abstract) 1 Ref.

High-temperature superconductors: Their potential for utility applications

Giese, R. F. ; Sheahen, T. P. ; Wolsky, A. M. ; Sharma, D. K. Argonne National Lab., IL.
Sponsor: Department of Energy, Washington, DC.
Report No.: CONF-901062-1
1990 7p
Languages: English
Document Type: Conference proceeding
Journal Announcement: GRAI9101; ERA9052
Joint IEEE/PES international power meeting (1st), New Delhi (India), 28 Oct - 1 Nov 1990
Sponsored by Department of Energy, Washington, DC
Portions of this document are illegible in microfiche products
Country of Publication: United States
Contract No.: W-31109-ENG-38

A number of proposed applications of superconductivity for the electric utility sector are described, the current status of their development is summarized, and the potential impact of successful development of high-temperature superconductors (HTSC's) is discussed. Performance goals for development of HTSCs are presented and compared with the current status of development of HTSCs. Applications discussed include large-scale generators, motors, transmission lines, magnetic storage, transformers, power electronics, and fault-current limiters. 15 refs., 1 fig., 3 tabs.

Title: High-temperature superconductors Their potential role in electric utility applications and what must be done to use them
Author(s): Giese, R.F.; Sheahen, T.P.; Wolsky, A.M. (Argonne National Lab., IL (United States)); Sharma, D.K. (Electric Power Research Inst., Palo Alto, CA (United States))
Sponsoring Organization: EPRI Electric Power Research Inst., Palo Alto, CA (United States)
Conference Title: 52. American power conference
Conference Location: Chicago, IL (United States)
Conference Date: 23-25 Apr 1990
Source: Proceedings of the American Power Conference (United States) v 52
Publication Date: 1990 p 776-782
Report Number(s): CONF-9004133--
Contract Number (Non-DOE): Agreement RP7911-1
Language: In English

Abstract: This paper describes a number of proposed applications of superconductivity for the electric utility sector. The current status of their development is summarized, and the potential impact of successful development of high-temperature superconductors (HTSCs) is discussed. Performance goals for development of HTSCs are presented and compared with the current status of development of HTSCs. Applications discussed include large-scale generators, motors, transmission lines, magnetic storage, transformers, power electronics, and fault-current limiters.

Title: Superconductors in power systems
Author(s): Pai, M.G.; Parikh, J.K.
Author Affiliation: Indira Gandhi Inst. of Dev. Res., Bombay, India
Conference Title: VI NPSC 90. Power Systems for the Year 2000 and Beyond. Proceedings of the Sixth National Power Systems Conference p.371-6
Editor(s): Hariharan, M.V.; Parikh, J.K.
Publisher: Tata McGraw-Hill, New Delhi, India
Publication Date: 1990
Country of Publication: India xvi+704 pp.
Conference Date: 4-7 June 1990

Conference Location: Bombay, India
Language: English
Document Type: Conference Paper (PA)
Treatment: Applications (A); Practical (P)

Abstract: The authors focus on the superconductors (SC) generators, SC storage of electricity and SC transmission lines. Prototypes of SC generators exist in the size range of a few MW to 300 MW. They are 50% smaller therefore light weight and have 1% higher efficiency. SC storage in the range of 20 MWh to 5000 MWh is a primary storage device and therefore almost 20% more efficient than conventional pumped storage. On the other hand, SC transmission lines have virtually unlimited transmission capacity and therefore, reduced right of way problems. Three phase SC transmission lines with the transmission capacity in the range 500 to 2000 MW have been proposed. The relevance of each of these applications in the context of India's power sector is discussed. When high temperature superconductors become available, the application potential is expected to change. The impacts of HTSC on each of the applications is considered. (9 Refs)

Title: A study of application of high T_c superconductors to superconducting generators
Author(s): Maki, N.; Yamaguchi, K.; Yagi, Y.
Author Affiliation: Res. Lab., Hitachi Ltd., Ibaraki, Japan
Conference Title: 11th International Conference on Magnet Technology (MT-11) p.574-9 vol.1
Editor(s): Sekiguchi, T.; Shimamoto, S.
Publisher: Elsevier Applied Science, London, UK
Publication Date: 1990
Country of Publication: UK 2 vol. xxxvi+1540 pp.
Conference Date: 28 Aug.-1 Sept. 1989
Conference Location: Tsukuba, Japan
Language: English
Document Type: Conference Paper (PA)
Treatment: Applications (A); Practical (P)

Abstract: Conceptual designs of 100 MW superconducting generators, in which field windings are cooled by helium (approximately 4.2 K), nitrogen (approximately 77 K), air (approximately 300 K), were carried out. Structural features and performance of these generators were clarified by comparing design results of superconducting and conventional generators. Technical problems of high T_c superconducting generators, e.g. improvement of filament current density, winding method and stabilization, are discussed. (7 Refs)

Title: 11th International Conference on Magnet Technology (MT-11)
Editor(s): Sekiguchi, T.; Shimamoto, S.
Publisher: Elsevier Applied Science, London, UK
Publication Date: 1990
Country of Publication: UK 2 vol. xxxvi+1540 pp.
Conference Date: 28 Aug.-1 Sept. 1989
Conference Location: Tsukuba, Japan
Language: English
Document Type: Conference Proceedings (CP)

Abstract: The following topics were dealt with: magnet technology in high energy physics; energy storage, power applications and MHD magnets; SC generators and motors; fusion magnets; hybrid magnets; mechanical design and materials; conductor development; characteristics at pulsed

operation; stability and reliability; instrumentation and measurements; imaging magnets; magnet technologies for researches; cryogenic systems and components; and high T/sub c/ superconductors.

Title: Development of elements of a high-T_c superconducting cable. Rept. for 1 Oct-31 Dec 90
Author(s)/Editor(s): Lay, K.W.
Corporate Source: General Electric Co., Schenectady, NY (United States). Corporate Research and Development Center
Publication Date: 31 Dec 1990 (7 p)
Report Number(s): AD-A-233270/8/XAB
Contract Number (Non-DOE): N00014-88-C-0681
Language: In English
Availability: NTIS

Abstract: The realigned program is aimed at the development of long lengths of silver-clad BSCCO. A variation on the powder in tube technique will be used to make silver-clad BSCCO tapes. BSCCO-2223 is the material of choice with 20K the operating temperature goal. Such a tape conductor ultimately could be used in a coil for a magnet, motor or generator. A key element of the program is the development of processes with the potential of fabrication of very long conductors. A novel process for making silver clad tapes (SCT) is under study. In this process extruded BSCCO is wrapped with silver foil which is then pressure welded. This technique has the potential for fabrication of continuous lengths and also avoids the extensive size reduction and attending potential for non-homogeneity involved with the more conventional powder-in-tube (PIT) process. A parallel PIT study is also underway to use for comparison purposes and as a back-up process to the SCT process.

Title: Development of superconductivity technology applied to power generation system. Study on a refrigeration system (development of a conventional refrigeration system with high reliability)
Original Title: Chodendo denryoku oyo gijutsu kaihatsu. Reito system no kenkyu kaihatsu (juraigata reito system no koshinraika no kenkyu kaihatsu)
Title: 1989 NEDO annual summary of studies. (2).
Corporate Source: New Energy Development Organization, Tokyo (Japan)
Publication Date: Oct 1990 p 576-579 (643 p)
Report Number(s): ETDE/JP-mf-1513221
Order Number: DE91513221
Language: In Japanese
Availability: OSTI; NTIS (US Sales Only)

Abstract: In order to develop a refrigeration system with high reliability demanded for superconductive equipment, research on elementary technology and a prototype refrigeration system was conducted. A partial trial product of a compressor was constructed and the highest performance was achieved among machines at the same level. A repeat test of 500 times starting and stopping the compressor unit was carried out and durability and possible problems were examined. A {1/4}-sized model of the high temperature cold box was produced and tested. The model showed sufficient removability of impurity. As for the low temperature cold box, three different types of turbine blades were tested and the blade with the smallest reaction showed the best effectiveness. The flow control system of precooling of the refrigeration system was evaluated by adding a by-pass of a power generator. As a result, flow rate of cold gas from the refrigerator became constant, reliability was improved, thus quick response to demands from the power generator side was achieved. 1 fig., 1 tab.

Title: Thirteenth International Cryogenic Engineering Conference ICEC 13
Journal: Cryogenics vol.30, suppl.
Publication Date: Sept. 1990
Country of Publication: UK
Conference Title: Thirteenth International Cryogenic Engineering Conference ICEC 13
Conference Date: 24-27 April 1990
Conference Location: Beijing, China
Language: English
Document Type: Conference Proceedings (CP); Journal Paper (JP)

Abstract: The following topics were dealt with: refrigeration equipment; SQUID magnetometers; He gas purification; cooling for superconducting systems; cryocoolers; flow regenerators; Stirling refrigerators; pulse tube refrigerators; Gifford-McMahon & Vuilleumier refrigerators; heat transfer & flow resistance; two-phase flow; perforated plate & wire-mesh heat exchangers; stratification in cryogenic multicomponent liquids; thermal insulation; He II; cryogenic fluids; standards; thermometry; cryostats; space cryogenics; cryopumping; cryobiology; low temperature electronics; superconducting magnets; field distortion; magnet power supply; superconducting conductors; superconducting machines; magnetic separation; high-T/sub c/ superconductivity; thin films; and SQUIDS.

Title: Superconductivity in electrical engineering
Original Title: Elektrotechnische Anwendungen der Supraleitung
Author(s): Zeller, H.R. (Asea Brown Boveri AG, Baden (Switzerland). Forschungszentrum)
Source: Bulletin des Schweizerischen Elektrotechnischen Vereins (und) des Verbandes Schweizerischer Elektrizitaetswerke (Switzerland) v 81:15
Publication Date: 4 Aug 1990 p 20-22
Language: In German

Abstract: The article discusses the applications of ceramic high-temperature superconductors, e.g. superconducting generators, transformers, transmission cables, current limiters, and magnetic separators. (MM).

Title: Key technologies of superconducting generator
Author(s): Maki, N.; Yamaguchi, K.
Author Affiliation: Res. Lab., Hitachi Ltd., Tokyo, Japan
Journal: Hitachi Review vol.39, no.1 p.25-30
Publication Date: Feb. 1990
Country of Publication: Japan
Language: English
Document Type: Journal Paper (JP)
Treatment: Practical (P)

Abstract: A superconducting AC generator (SCG) is expected to be the next advancement of turbine generators, and plans for a 200 MW class generator are being carried out in Japan. A 120/400 MVA generator in West Germany and a 300 MW generator in the Soviet Union are under development. In the SCG, a cryogenic multi-cylinder rotor and an air gap winding stator, which differ significantly from the conventional ones, are used. Accordingly, it is necessary to verify the operational characteristics and reliability of the SCG for practical application. To this end, a 50 MVA generator was manufactured and tested. Major technical problems were identified and solutions were proposed for the design of a larger scale generator. Furthermore, the structure.

merits and technical problems of future SCGs using high-T/sub c/ superconductors are discussed. The development of superconductors, which have almost the same B-J/sub c/ performance as the low-T/sub c/ superconductors, appears to be the most suitable target for future work. (5 Refs)

Hitachi Review, Vol. 39, No. 1, February 1990. Superconducting Technology Hitachi Ltd., Tokyo (Japan).

cFeb 90 82p

Languages: English

Journal Announcement: GRAI9020

See also PB90-251422 through PB90-251455 and PB90-212408

Country of Publication: Japan

Contents: High-Field Superconducting Magnets and Related New Technologies; LCT Superconducting Magnets for FusionPower; Development of 10-T (Nb,Ti)₃Sn Forced-Flow Cooled Superconducting Coils; Key Technologies of Superconducting Generator; Compact Superconducting Magnets for Magnetic Resonance Imaging; The Field-Effect Superconducting Transistor; The Dynamics of Fluxons in High-Temperature Superconductors; Preparation and Structural Characterization of Tl-Sr-Ca-Cu-O Superconducting Materials; Development of High-T(c) Superconducting Wire with High Critical Current Density; High-Temperature Superconductor Films.

Title: Superconductivity: dealing in futures

Author(s): Cohen, J.

Journal: EPRI Journal vol.15, no.1 p.18-27

Publication Date: Jan.-Feb. 1990

Country of Publication: USA

ISSN: 0362-3416

Language: English

Document Type: Journal Paper (JP)

Treatment: General, Review (G)

Abstract: Utility interest in the development of the new, high-temperature superconductors-HTSCs-goes beyond their possible application in the power grid. The introduction of HTSCs in customer applications is likely to have an even greater impact on utilities, increasing the value of electricity and expanding its use in virtually every area of life. The author shows that according to a recently completed EPRI/DOE assessment, HTSCs could open a window of opportunity for many new uses of superconductivity-from powerful but compact electric motors to high-speed computers to magnetically levitated trains. (1 Refs)

Title: Energy productivity applications of superconductivity. Preliminary summary and highlights

Author(s): Schneider, T.R.; Dale, S.J.

Author Affiliation: Electric Power Res. Inst., Palo Alto, CA, USA

Conference Title: Proceedings of the American Power Conference p. 466-72

Publisher: American Power Conference, Chicago, IL, USA

Publication Date: 1989

Country of Publication: USA xxviii+1115 pp.

Conference Sponsor: Illinois Inst. Technol

Conference Date: 24-25 April 1989

Conference Location: Chicago, IL, USA

Language: English
Document Type: Conference Paper (PA)
Treatment: Applications (A)

Abstract: In view of the potentially large impact of the new superconductors on energy systems and the need for a comprehensive understanding of this impact, the DOE Office of Conservation and Renewable Energy, Energy Conversion and Utilization Technologies (ECUT) Program, the DOE Office of Fossil Energy and the Electric Power Research Institute (EPRI), Office of Exploratory Research co-sponsored a major assessment of the technological opportunities for cost-effective and energy-efficient applications of the new superconductors. This assessment was undertaken in order to: assess the potential technical and economic benefits of applying the high superconductors to a number of energy technologies; determine system characteristics and superconductor materials parameters required for the application of the high temperature superconductors; and provide DOE and EPRI with a basis for future directions in research on superconductivity. The authors discuss the results of this assessment as applied to motors, EM pumping, magnetic heat pumping, materials production, transportation and power electronics. (0 Refs)

Title: Development of superconducting generators for power plant
Original Title: Entwicklung supraleitender Kraftwerksgeneratoren
Author(s): Intichar, L.; Lambrecht, D.
Title: Superconductivity in power engineering. Status, concepts, new aspects
Original Title: Supraleitung in der Energietechnik. Stand, Konzepte, neue Aspekte
Original Series Title: VDI-Berichte
Corporate Source: Verein Deutscher Ingenieure (VDI) - Gesellschaft Energietechnik, Duesseldorf (Germany, F.R.)
Conference Title: Technical meeting on superconductivity in power engineering: Status, concepts, new aspects, with exhibition
Original Conference Title: Fachtagung Supraleitung in der Energietechnik: Stand, Konzepte, Neue Aspekte und Ausstellung
Conference Location: Karlsruhe (Germany, F.R.)
Conference Date: 14-15 Jun 1989
Publisher: Duesseldorf (Germany, F.R.) VDI-Verl.
v no. 733
Publication Date: 1989 p 121-135 (442 p)
Report Number(s): CONF-8906339--
Language: In German

Abstract: Turbogenerators with a superconducting magnetic field already at today's level of technical development represent for large-system applications an interesting alternative to conventional generators. An experimental system is being installed within the framework of a development programme. The superconductors intended for use in generators will have to satisfy special requirements, and the same applies to the novel high-T_c superconductors. If the ongoing development work will have achieved the technical maturity, also smaller size superconducting turbogenerator systems will be of interest from an economic point of view. (orig.).

Kema Scientific and Technical Reports, Volume 7, Number 4. Special Issue: High-(T sub c) Superconductivity for Power Applications
Barten, H.
Keuring van Electrotechnische Materialen N.V., Arnhem (Netherlands).
Report No.: ISBN-90-353-0075-0
c1989 70p

Languages: English
Document Type: Journal article
Journal Announcement: GRAI9002
See also PB89-220370.
Pub. in Kema Scientific and Technical Reports, v7 n4 p199-265 Aug 89.
Country of Publication: Netherlands

Contents: Inventory of possible electrical-power application of high-T(c) superconductors for the Dutch situation; The impact of high-T(c) superconductors - a worldwide review; High-T(c) superconductors -- the Dutch scene; Compilation of international progress in 1988 on high-T(c) material studies relevant to power applications.

Title: Assessment of potential advantages of high T/sub c/-superconductors for technical application of superconductivity
Author(s): Schauer, F.; Jungst, K.P.; Komárek, P.; Maurer, W.
Author Affiliation: Inst. für Tech. Phys., Kernforschungszentrum, Karlsruhe, West Germany
Conference Title: CAS Cern Accelerator School: Superconductivity in Particle Accelerators. Proceedings (CERN 89-04) p.299-319
Editor(s): Turner, S.
Publisher: CERN, Geneva, Switzerland
Publication Date: 1989
Country of Publication: Switzerland xi+322 pp.
Conference Sponsor: Brown Boveri; Dornier
Conference Date: 30 May-3 June 1988
Conference Location: Hamburg, West Germany
Language: English
Document Type: Conference Paper (PA)
Treatment: Applications (A); Economic aspects (E); General, Review (G)

Abstract: A first assessment of the technical and economical consequences of liquid nitrogen cooling of new superconductors is given. For the investigation the applications of superconductivity are classified in two categories: first, systems where superconductors are practically indispensable for achieving the system's objectives; second, superconductor applications in competition with highly developed conventional technologies. Further development of those superconducting systems in the first category for which the cost of cryogenic equipment is a smaller fraction of the total system cost (e.g. fusion reactor or MHD generator) will hardly be affected. However, for systems like particle accelerators, research magnets, and NMR spectroscopy and imaging systems, the cryogenic equipment expenditures are significant and LN/sub 2/ cooling leads here to a reduction of investment and operating costs, to simplified handling and maintenance, to better reliability and availability, and will thereby improve the acceptance and further spread of these systems. In the second category each application of superconductivity has to be compared with its conventional counterpart, separately. Here, electronic components, power switches, resistive current limiters, and especially the power transmission cables are those applications which look most promising. For magnet applications the main advantageous arguments are less the cost saving aspect but more the higher reliability, simplicity, N/sub 2/-availability, and ease of handling. (42 Refs)

Title: Superconductivity in power engineering. Status, concepts, new aspects
Original Title: Supraleitung in der Energietechnik. Stand, Konzepte, neue Aspekte
Original Series Title: VDI-Berichte
Corporate Source: Verein Deutscher Ingenieure (VDI) - Gesellschaft Energietechnik, Duesseldorf (Germany, F.R.)

Conference Title: Technical meeting on superconductivity in power engineering: Status, concepts, new aspects, with exhibition
Original Conference Title: Fachtagung Supraleitung in der Energietechnik: Stand, Konzepte, Neue Aspekte und Ausstellung
Conference Location: Karlsruhe (Germany, F.R.)
Conference Date: 14-15 Jun 1989
Publisher: Duesseldorf (Germany, F.R.) VDI-Verl.
v no. 733
Publication Date: 1989 (442 p)
Report Number(s): CONF-8906339--
Language: In German

Abstract: This proceedings volume presents 24 conference papers and 15 posters dealing with the following aspects: (1) Principles and elementary aspects of high-temperature superconductivity (3 plenary lectures); (2) Preparation, properties and materials requirements of metallic or oxide superconductors (critical current behaviour, soldered joints, structural studies); (3) Magnet technology (large magnets for thermonuclear fusion devices; magnets for particle accelerators and medical devices); (4) Magnetic levitation and superconductivity; (5) Cryogenics; (6) Energy storage systems using superconducting coils (SMES); (7) Superconducting power transmission cables, switches, transformers, and generator systems for power plant; (8) Supporting activities, industrial aspects, patents. There are thirty-eight records in the ENERGY database relating to individual conference papers. (MM).

Title: Application of superconductors to motors, generators, and transmission lines
Author: Kirtley, James L.; Edeskuty, Frederick J.
Corporate Source: MIT, Lab for Electromagn & Electron Syst, Cambridge, MA, USA
Source: Proceedings of the IEEE v 77 n 8 Aug 1989 p 1143-1154
Publication Year: 1989
Language: English
Document Type: JA; (Journal Article)
Treatment: X; (Experimental); A; (Applications)
Journal Announcement: 9002

Abstract: Two specific applications of superconductors are considered: electric machinery (motors and generators) and transmission lines. Development work carried out with respect to both types of equipment indicates that the use of superconductors is feasible, even if only liquid-helium-cooled superconductors are considered. The high-T_c superconductors will have a beneficial impact on motors, generators, and transmission lines only if conductors with sufficient mechanical properties and current-carrying capabilities can be developed. 35 Refs.

Title: Applications of superconductivity
Author(s): Huang, C.Y.
Author Affiliation: Lockheed Missiles & Space Co. Inc., Res. & Dev. Div., Palo Alto, CA, USA
Conference Title: High Temperature Superconductivity and Other Related Topics Proceedings of the 1st Asia-Pacific Conference on Condensed Matter Physics p.106-15
Editor(s): Baaquie, B.E.; Chew, C.K.; Lai, C.H.; Oh, C.H.; PHUA, K.K.
Publisher: World Scientific, Singapore
Publication Date: 1989
Country of Publication: Singapore xiii+314 pp.
Conference Sponsor: Int. Centre Theor. Phys.; Nat. Univ. Singapore; et al
Conference Date: 27 June-3 July 1988
Conference Location: Singapore

Language: English
Document Type: Conference Paper (PA)
Treatment: Applications (A); General, Review (G)

Abstract: The author has reviewed some large-scale applications involving electric power transmission lines, superconducting magnetic energy storage, magnets, and electrical machinery. He has also discussed some small-scale applications including short and long interconnects, digital circuits, superconducting transistors, magnetometers, and magnetic field sensors. Comparison with the use of high-temperature superconductors is also made. (22 Refs)

Title: Applicability of superconductivity in the electric power system: a Canadian perspective
Author(s): Chu, F.Y.; Roberge, R.
Author Affiliation: Ontario Hydro Res. Div., Toronto, Ont., Canada
Conference Title: Advances in Superconductivity. Proceedings of the 1st International Symposium on Superconductivity p.25-31
Editor(s): Kitazawa, K.; Ishiguro, T.
Publisher: Springer-Verlag, Tokyo, Japan
Publication Date: 1989
Country of Publication: Japan xxiii+920 pp.
Conference Sponsor: Int. Superconductivity Technol. Center
Conference Date: 29-31 Aug. 1988
Conference Location: Nagoya, Japan
Language: English
Document Type: Conference Paper (PA)
Treatment: Applications (A); General, Review (G)

Abstract: The recent discovery of high temperature superconducting (HTSC) materials and the development of low loss (in alternating current application), low temperature multifilamentary superconductors have the potential to benefit the electric power companies. The potential benefits of these materials, and the public interest in HTSC, have motivated electrical utilities to examine the technologies closely. The authors present a Canadian view on perspective applications of superconductivity in a power system. (6 Refs)

Title: Superconductivity and its application in technology
Author(s): Iyengar, P.K.
Author Affiliation: BARC, Bombay, India
Journal: Indian Journal of Cryogenics vol.13, spec. issue. p.179-85
Publication Date: 1989
Country of Publication: India
Conference Title: National Workshop on High T/sub c/ Superconductors
Conference Sponsor: Indian Inst. Sci.; Dept. Sci. Technol.; et al
Conference Date: 27-31 March 1988
Conference Location: Bangalore, India
Language: English
Document Type: Conference Paper (PA); Journal Paper (JP)
Treatment: Applications (A); General, Review (G)

Abstract: The introduction of high temperature superconductors has triggered an unprecedented world wide activity. After the transistor and the chip, these are being spoken of as capable of ushering in the third industrial revolution. Transformation is forecast in a number of technologies

connected with computers, energy sector, electronics and electrical engineering, medical diagnostics, power generation, transportation etc. To understand and evaluate this euphoria, it is worthwhile looking at some of the applications, old and new. (8 Refs)

Title: An alternator using a high temperature superconductor for field excitation

Author(s): Richardson, K.; Evans, P.D.; Eastham, J.F.; Appleton, A.D.; Alford, N.McN.

Author Affiliation: NEI International Research & Development Co. Ltd., Newcastle upon Tyne, UK

Conference Title: Fourth International Conference on Electrical Machines and Drives (Conf. Publ. no.310) p.202-4

Publisher: IEE, London, UK

Publication Date: 1989

Country of Publication: UK xii+393 pp.

Conference Date: 13-15 Sept. 1989

Conference Location: London, UK

Language: English

Document Type: Conference Paper (PA)

Treatment: Experimental (X)

Abstract: The authors describe the construction and performance of an alternator using YBaCuO high temperature superconductor for field excitation. The excitation winding consist of 15 turns of superconducting wire encapsulated in wax. Tests are carried out at a generator speed of 1500 rev/min to give a 3-phase 50 Hz output. (9 Refs)

Title: International Symposium on New Developments in Applied Superconductivity

Editor(s): Murakami, Y.

Publisher: World Scientific, Singapore

Publication Date: 1989

Country of Publication: Singapore xix+808 pp.

Conference Date: 17-19 Oct. 1988

Conference Location: Osaka, Japan

Language: English

Document Type: Conference Proceedings (CP)

Abstract: The following topics were dealt with: new superconductors and proposals for their applications; formation of superconducting films; properties of superconductors; applications of superconductors; superconducting magnets and materials, composite materials; structural materials; superconducting magnet technology; energy applications; superconducting magnet energy storage; superconducting generators; AC applications; new applications; applications for accelerators and measurements, superconducting electronics.

Title: Superconductivity: electrical applications

Author(s): Ausloos, M.; Laurent, C.

Journal: Electricite no.189 p.3-11

Publication Date: Nov. 1989

Country of Publication: Belgium

Language: French

Document Type: Journal Paper (JP)

Treatment: General, Review (G)

Abstract: The effects on the superconductivity market of developments in magnetic resonance imaging and so-called high-temperature superconductors are reviewed, with applications of interest to electrical power engineers. The history of the subject is traced from its discovery in 1911, and values of critical temperature and field are tabulated for the principal superconducting materials of types I and II, with critical temperatures for seven ceramic compounds. Applications of intense magnetic fields in biomedical imaging, superconducting machines, levitation, separation, high-energy particle physics and nuclear fusion are considered. Energy storage and transport, lightweight power transformers, and microelectronic applications (Josephson junction voltage standards, logic devices and SQUIDs) are also covered. (27 Refs)

Title: New solutions using superconductors in electrical power engineering
Author(s): Lontay, E.P.
Journal: Elektrotechnika vol.82, no.11 p.435-7
Publication Date: Nov. 1989
Country of Publication: Hungary
Language: Hungarian
Document Type: Journal Paper (JP)
Treatment: Practical (P)

Abstract: The characteristics of new types of high-temperatures superconducting materials enable their direct use in peak load power storage plants. In the field of basic research the world-scale competition has the increase of the $T_c/J-B$ in view, while the applied research is in progress in the fields of storage magnets, generators, transformers, remote cables, cryoswitches and cryotechnical devices. Because of the loss-free operation it is possible to decrease the conventional dimensions in a scale of 1:100. (6 Refs)

Title: The impact of high- T_c superconductors-a world-wide review
Author(s): Steennis, E.F.
Author Affiliation: Electr. Res. Dept., NV KEMA, Arnhem, Netherlands
Journal: Kema Scientific & Technical Reports vol.7, no.4 p.227-35
Publication Date: Aug. 1989
Country of Publication: Netherlands
Language: English
Document Type: Journal Paper (JP)
Treatment: Applications (A); General, Review (G); Practical (P)

Abstract: A review is presented of international opinions on the impact of high- T_c superconductors in electrical-power engineering. The international opinions have been gathered from a meeting of the International Energy Agency and from literature. It is assumed for the purpose that the operation temperature will be 77 K, and that critical parameters other than the critical temperature will be met by wires and tapes, even though this is not yet the case. The devices considered are: generators, electromotors, transformers, energy-storage devices, power-transmission equipment, current limiters and switches, power-regulation devices, magnets and transportation (maglev). Several arguments are identified and compared with each other for their desirability and for the technical-economical barriers that their realisation will meet. Economic break-even points are indicated for some cases. It is stressed, however, that fixed local factors and choices of the dimensions of the components highly influence the considerations. This explains the variations in a number of conclusions, as drawn by different sources. (34 Refs)

Title: Inventory of possible electrical-power applications of high-T/sub c/ superconductors for the Dutch situation

Author(s): Barten, H.; Smit, J.J.; Steennis, E.F.

Author Affiliation: Chem. Res. Dept., NV KEMA, Arnhem, Netherlands

Journal: Kema Scientific & Technical Reports vol.7, no.4 p.201-26

Publication Date: Aug. 1989

Country of Publication: Netherlands

Language: English

Document Type: Journal Paper (JP)

Treatment: Applications (A); Bibliography (B); Practical (P)

Abstract: The impact of high-T/sub c/ superconductors based on the compound YBa/sub 2/Cu/sub 3/O/sub 7/ (with a transition temperature of 95 K) in electric power engineering is inventoried. It appears that no basically new applications will be developed but that there will be a gradual shift to realisation of systems now based on cooling with liquefied helium. Assuming that suitable conductors will become available at reasonable cost, and that the development of materials will continue in such a way that practical boundary conditions such as processability, stability and current density under the application of a magnetic field will be satisfied, the main conclusions regarding their application in The Netherlands are: (1) high-T/sub c/ superconductors may lead to major breakthroughs for transformers, generators, motors and magnets for separation purposes, and can in the long term make a positive contribution to the development of MHD generators and fusion reactors; (2) application for magnetic screening is very obvious; (3) economic reasons prohibit the application of superconductive cables, and high-voltage transmission lines are undesirable, primarily for technical reasons; (4) there is no need for large-scale power storage, power regulation or magnetic-levitation (MAGLEV) trains unless there is cooperation on a European level; small-scale energy storage cannot yet be assessed; (5) there exist several options in the instrumentation field, based on the possibility of detecting very small magnetic fields by means of superconductors; (6) several less familiar and new applications as main components include current limiters, switches and fuses, the application of which may lead to an entirely different philosophy of system handling. There are options in the field of testing equipment such as impulse-current and impulse-voltage generators. An important element in some of these applications is the superconductive switchable impedance, which can be designed with or without separation of the cryogenic and normal parts of the system by means of a transformer. Oxygen stoichiometry, thermal stability and attack by moisture and carbon dioxide affect YBa/sub 2/Cu/sub 3/O/sub 7/. Moreover, the brittleness of the ceramics emerges as a highly complicating characteristic for the manufacture of wires and tapes. (67 Refs)

Title: Superconducting generators for power stations

Author(s): Intichar, L.; Kulig, S.

Author Affiliation: Siemens AG, Mulheim, West Germany

Journal: ETZ vol.110, no.13 p.660-7

Publication Date: July 1989

Country of Publication: West Germany

Language: German

Document Type: Journal Paper (JP)

Treatment: Practical (P)

Abstract: The state of development of large turbogenerators with superconducting field windings provide a promising new alternative to the conventional technology, offering operational and cost advantages. The development programme of large superconducting turbogenerators by Siemens is outlined, based on design of a prototype 400 MVA generator now under construction. The prospects of application of high T/sub c/ superconductors in electric power generators are

considered, suggesting that the experience with the low temperature technology would be largely valid for the future use of the new materials. (8 Refs)

Title: The new superconductors: prospects for applications
Author(s): Wolsky, A.M.; Giese, R.F.; Daniels, J.
Author Affiliation: Argonne Nat. Lab., IL, USA
Journal: Scientific American vol.260, no.2 p.44-52
Publication Date: Feb. 1989
Country of Publication: USA
Language: English
Document Type: Journal Paper (JP)
Treatment: General, Review (G); Theoretical (T); Experimental (X)

Abstract: The authors consider the future prospects for superconducting devices. They discuss supermagnets, generators and power lines, electrical energy storage, levitating trains, industrial applications, superconducting computers and SQUIDs. The theoretical limits of superconducting properties are studied, along with possible improvements in materials processing techniques used for superconducting materials. (0 Refs)

Title: Perspectives of high temperature superconductors in power engineering
Author(s): Kubikova, M.
Journal: Elektrotechnicky Obzor vol.78, no.1 p.27-31
Publication Date: Jan. 1989
Country of Publication: Czechoslovakia
Language: Czech
Document Type: Journal Paper (JP)
Treatment: Applications (A)

Abstract: The author surveys the state of high-temperature superconductor developments in the late 1980s and considers the possible applications of these materials in the following types of power apparatus: electrical machines (power transformers; DC machines; AC generators and motors; special-purpose motors); switching devices; power cables; and magnets. The great potential perspectives of high-temperature superconductors operating at normal room temperature, with other parameters comparable to classical superconductors, are pointed out. (28 Refs)

Title: The superconductor generator presented by Siemens AG
Journal: Elektrische Maschinen vol.68, no.1 p.8-13
Publication Date: Jan. 1989
Country of Publication: West Germany
Language: German
Document Type: Journal Paper (JP)
Treatment: Practical (P)

Abstract: The main purpose of Siemens decision to build a high-power prototype of a superconducting generator is the avoidance of difficulties of scaling up a design of a small generator to be applied to a considerably larger unit. The firm carried out tests on components and subassemblies for the 400 MVA generator and checked various superconducting materials, including the recently developed 'high-temperature' superconductors, to provide the basis for the design of the 850 MVA unit. The size of the stator for the 400 MVA set provides the basis for the larger unit which is expected to be offered to a client in 1995. The costs of investment and various problems in the design are discussed. (0 Refs)

Title: Application of superconductors-high T/sub c/ and otherwise-to electric power generators
 Author(s): Kirtly, J.L., Jr.
 Author Affiliation: MIT, Cambridge, MA, USA
 Conference Title: Superconductivity and Its Applications. Proceedings of the Second Annual Conference on Superconductivity and Applications p. 466-77
 Editor(s): Kwok, H.S.; Shaw, D.T.
 Publisher: Elsevier, New York, NY, USA
 Publication Date: 1988
 Country of Publication: USA xv+496 pp.
 Conference Date: 18-20 April 1988
 Conference Location: Buffalo, NY, USA
 Language: English
 Document Type: Conference Paper (PA)
 Treatment: Applications (A); Practical (P)

Abstract: Because superconducting magnets are capable of making large magnetic fluxes over large volumes of space with no dissipation and without the need for iron magnetic circuits, they appear to offer distinct advantages for use in electric machinery. In addition to eliminating the field winding losses, superconductors help improve efficiency by increasing flux density thus shortening the armature conductor length per unit of flux linked. The elimination of iron allows for innovations in generator design and reduces reactance thus improving dynamic performance. The basic feasibility of using metallic superconductors, operating at liquid helium temperature, has been demonstrated by investigators at several different organizations. While there is not yet agreement on exactly how a superconducting generator would be built, it is generally agreed that machines using liquid helium temperature conductors will be economically viable in at least some range of ratings. The use of higher transition temperature superconductors will make superconducting generators even more attractive if such conductors can provide satisfactory performance, measured by current density and magnetic field. Recent studies point out that even substantial improvements in operating temperature will not justify large reductions in current density. (2 Refs)

Title: Properties required for superconductive wires if they are applicable to energy systems and the present situation of the technologies necessary for making superconductive wires
 Author(s): Tomiyama, Sakutaro
 Title: Assessing the impact of high-temperature superconductivity on electric power
 Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power
 Conference Location: Tokyo (Japan)
 Conference Date: 1-2 Sep 1988
 Publisher: Paris (FR) International Energy Agency
 Publication Date: 1988 p 137-143 (284 p)
 Report Number(s): CONF-8809518--
 Language: In English

Abstract: The effort of application of high temperature superconductors for electric machines are in progress but investigators have not yet acquired enough information to evaluate their roles in the said field. Though their known thermal Properties give some insight about the design of future nitrogen cooled machine, the approach is a limited one because of the lack of crucial knowledge on electro-magnetic properties. Some already discovered. Peculiarities of the new materials sees to urge us to adopt completely different criterions on evaluation. The remarkable recent improvement of AC characteristics of superconducting wires was a chief impetus for the renewed effort to apply superconducting machineries to power industry, where the application for generators was the primary target. The paper describes the technology of generators with superconductors.

Title: Current situation of R D on warm superconductivity carried out by Engineering Research Association for Superconductive Generation Equipment and Materials, Japan (Super-GH)

Author(s): Uyeda, Kiyotaka

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 150-159 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: Super-GH is carrying on studies of NbTi metal superconductive wires and Nb₃Sn inter-metallic compound to be applied for superconductivity generators, and is also engaged in the research and development of oxide superconductive wires promising as advanced-superconductive materials. As for the sequence of research and development, in the initial two or three years, emphasis will be placed on the studies concerning the processes for synthesizing and preparing various materials of vapor, liquid and solid phases. Then, research and development will be concentrated on selected excellent processes for preparing superconductive wires, to enhance the properties of superconductive materials. After 4 years in the program during the progress of research and development, intermediate evaluation will be made, and it is planned to perform research and development for processing oxide superconductors into long wires, aiming at the application to superconductivity applied electric power apparatuses such as superconducting generators. A survey was carried out on the methods for measuring the critical temperature and critical current as the critical properties of oxide superconducting materials, prior to round robin tests. To establish a standard for evaluating oxide based superconductive wires, various measurement methods for TC, J_c, etc. have been examined. From the analytical results of the examination and experiments, problems in the present situation have been revealed, and the problems concerning evaluation tests have been identified. These are discussed.

Title: Superconductivity/power-sector assessment experts meeting - Specific findings

Author(s): Wolsky, A.M.; Daniels, E.J.; Giese, R.F. (Argonne National Lab., IL (USA))

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 259-265 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: The future applications of high temperature superconductors will be reviewed. Emphasis will be given to economic considerations, performance goals, and the research and development that remains to be done. Recent studies suggest that increasing current density to 10⁴-10⁵ amps per cm² in fields of 1-3 Tesla is more important than only raising {T_c}. The desirability of revising past designs of superconducting equipment to take better economic advantage of the hoped for properties of LN₂ superconductors will also be stressed. The possibility of building smaller devices (e.g., generators) than were discussed in past years will also be stressed because smaller devices will find a larger market. High temperature superconductors may offer capital savings as well as energy savings. This is crucial because their ultimate use will be determined by profitability.

Title: Presentation of activities by Germany

Author(s): Klose, W.

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 31-66 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: Applications of superconductivity may be classified in two categories: systems where superconductors are practically indispensable for achieving the system's objectives; and superconductor systems have to compete with highly developed conventional technologies. Systems with superconductors as indispensable components include systems where Cryogenic costs are a small fraction of total costs (e.g., fusion reactors and MHD generators) and systems where Cryogenic costs are a significant fracture of total overall costs (e.g., particle accelerators, storage rings, research magnets, and NMR-spectroscopy). The paper mostly discusses the application of superconductivity to developed conventional technologies: AC-power cables, transformers, energy storage systems, AC generators, and magnetic are separation.

Title: Activities within the field of superconductivity in Sweden

Author(s): Claeson, T. (Chalmers Univ. Technology, Gothenburg (Sweden))

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 220-224 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: The new oxide superconductors may have an impact on the power sector. However, the time scale of introducing new components or systems in the utilities is long and many basic materials problems remain to be solved. A persistence and continuously revised assessments as new progress is obtained are needed as well as a parallel development of materials and components. This paper reviews the conclusions to date on the application of uperconductivity and possible time frame to the following: fusion, MHD, and AC electric generators; cables; transformers; magnetic energy storage; power stabilization; electric motors; high speed trains; and magnetic are separation.

Title: High- Tc superconductors in electric power applications

Author(s): Steennis, E.F.

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 189-219 (284 p)
Report Number(s): CONF-8809518--
Language: In English

Abstract: This report describes the possible implications of the discovery of High-Temperature Superconductors in the Electric Power sector in The Netherlands. In particular the material $\text{YBa}_{2}\text{Cu}_{3}\text{O}_{7}$ is discussed. Assuming High-Tc superconducting wires and tapes become available for a reasonable price, the main consequences are as follows. (1) High-Tc superconductors may lead to important possibilities for transformers, generators, motors and magnets for separation. On the long term these superconductors may positively influence the development of MHD generators and fusion reactors. (2) The application of magnetic shielding is obvious. (3) In The Netherlands a large scale application like SMES or a MAGLEV-train is not attractive. Moreover there is no need for power regulation and stabilization. (4) High-Tc superconducting cables are not interesting from an economic point of view. (5) High-Tc superconducting overhead lines will not be accepted for practical reasons. (6) The introduction of rather specific components like current-limiters and switches can improve the dimensioning of the power transmission network. For instance it will lower the level of the short circuit current in a high extent. Such components are therefore very attractive but the technological and economical prospectives can hardly be given now. (7) High-Tc superconducting fuses for power applications are not attractive for practical reasons. (8) Test facilities, based on High-Tc superconductors, like impuls-current generators and compensation coils for cable testing, are very attractive. Here the application of a High-Tc superconductor offers new possibilities.

Title: The main actors in the power sector in Italy

Author(s): Vivaldi, F.; Dufour, A.

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy gency

Publication Date: 1988 p 119-123 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: The paper consists of a series of viewgraphs which review the following: organizations conducting research on superconductivity; power sector applications of low temperature superconductivity (turbogenerators; superconducting cables and magnets, and magnets for MHD conversion); research programs for high temperature superconductivity; superconductivity applications to power sector (power generation, power transmission, energy storage, electrical machinery, and magnets for physics research).

Title: Master plan for large-scale and energy-saving research and development of superconducting technology for application to power apparatuses

Author(s): Kurihara, S.

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 124-129 (284 p)

Report Number(s): CONF-8809518--
Language: In English

Abstract: It is desirable to apply superconducting technology to power generation, transmission, and conversion to achieve higher stability, current density, and efficiency in electric power systems. Research objectives are discussed for development of superconductors, superconducting generators, total systems, refrigeration systems, and evaluation techniques.

Title: IEA expert meeting: Assessment of superconductivity in the power sector

Author(s): Meyer, L.A.

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 183-188 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: In March 1988 the Government established a national research program on warm superconductors. The main items of the research program are: theory; new materials with higher TC; technology and classification; physics of superconducting phenomena and electronic structure, and investigation of applications. The implementation of item 5 will be divided into two categories: energy and magnet-related applications; and microelectronic applications and sensors. The general objective is to obtain an overview of the advantages of the use of nitrogen-cooled superconductors compared with other technologies in the categories mentioned above. The possible opportunities for Dutch industry will also be assessed. It is assumed that it will become possible to produce reliable layers, tapes, wires and coils on an industrial scale. Subjects that will be included in the studies relating to power and environmental applications are: transformers, generators, motors; magnetic shielding; superconducting magnet energy storage for peak-shaving (SMES); high-gradient magnetic separation for water purification (HGMS).

Title: Research schedule of Super-GM in 4 years from now

Author(s): Uyeda, Kiyothka

Title: Assessing the impact of high-temperature superconductivity on electric power (Engineering Research Association for Superconductive Generation equipment and Materials)

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 144-149 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: Super-GM was established in Osaka last September as one research association of Moonlight Project in AIST, MITI. Long term schedule of Super-GM can classify four items and interim evaluation will be done in 1991. Main research subjects of each items till this evaluation are as follows: Superconducting Materials (Both high TC and low TC materials are considered); Superconducting Generator (Two types of generator with different structure of damper and field

windings will be developed); Refrigerating System (Two type of compressors without oil seal will be developed one is screw type and another is turbo-type compressor); and Total System (Test method to prove the reliability of superconducting generator).

Title: 1987 report of the Committee for Study of Superconduction Technology in Japan

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 167-182 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: The superconductivity oriented cryogenic technology is going to plunge into the phase of practical use after studies made for the past more than 30 years. However, recent sudden progress of research about the findings of oxide based high temperature superconductors may bring about a remarkable revolution in the future technological system. For this reason, it is currently required to review the basic evaluation items concerned with refrigeration techniques, stabilization techniques, etc. in the superconducting technology, repercussive effect mainly on the electric power technology, scale merit in view of economic efficiency, and so on. Working groups were established for electric power systems, generators, transformers, power transmission (power cables), power storage and magnet application (various magnets using superconduction), discuss the following: Necessity and merits (introduction effect) of applying superconducting technology; Technical subjects and solutions in the application of superconducting technology; Technical requirements for superconduct or superconductor; Effect of introducing oxide based high temperature superconductive materials. For the subject of research and development of oxide based high temperature superconductive materials, a working group for conductor production techniques was established to discuss the subject. This report summarizes the results of discussion in the respective working groups.

Title: High T sub c materials in the electric network Why or why not

Author(s): Klein, K.W. (Office of Energy Storage and Distribution, US DOE, Washington, DC (US))

Title: Energy technology XV

Conference Title: 15. annual energy technology conference and exposition

Conference Location: Washington, DC (United States)

Conference Date: 17-19 Feb 1988

Publisher: Rockville, MD (USA) Government Institutes Inc.

Publication Date: 1988 p 844-852 (960 p)

Report Number(s): CONF-880212--

Language: In English

Availability: Government Institutes Inc., 966 Hungerford Dr. No. 24, Rockville, MD 20850 (USA)

Abstract: This paper reports on the new high temperature superconducting ceramics could revolutionize the design of some electrical power systems if major obstacles are cleared. The obstacles include improving the critical current density with applied magnetic fields, improving mechanical properties and chemical stability. For over a decade, the Office of Energy Storage and Distribution (OESD) has supported three applications of superconducting materials superconducting generator; superconducting transmission cable; and superconducting magnetic

energy storage (SMES). The future prospects for these and other power system applications depend, first and foremost, on the material properties of the superconductor. For most power applications, the critical current density is the crucial property. An understanding of the properties of the high temperature materials will suggest which applications may be the easiest to realize and which may have the greatest potential. This desired understanding can help formulate research goals and priorities.

Title: High T/sub c/ materials in the electric network: why or why not?

Author(s): Klein, K.W.

Author Affiliation: US DOE, Washington, DC, USA

Conference Title: Superconductivity and Its Applications. Proceedings of the Second Annual Conference on Superconductivity and Applications p. 17-24

Editor(s): Kwok, H.S.; Shaw, D.T.

Publisher: Elsevier, New York, NY, USA

Publication Date: 1988

Country of Publication: USA xv+496 pp.

Conference Date: 18-20 April 1988

Conference Location: Buffalo, NY, USA

Language: English

Document Type: Conference Paper (PA)

Treatment: Practical (P)

Abstract: The new high temperature superconducting ceramics could revolutionize the design of some electrical power systems if major obstacles are cleared. The obstacles include improving the critical current density with applied magnetic fields, improving mechanical properties and chemical stability. For over a decade, the Office of Energy Storage and Distribution (OESD) has supported three applications of superconducting materials: superconducting generators; superconducting transmission cables, and superconducting magnetic energy storage (SMES). The future prospects for these and other power system applications depend, first and foremost, on the material properties of the superconductor. For most power applications, the critical current density is the crucial property. An understanding of the properties of the high temperature materials will suggest which applications may be the easiest to realize and which may have the greatest potential. This desired understanding can help formulate research goals and priorities. (0 Refs)

Title: Applications of high temperature superconductivity

Author(s): Wolsky, A.M.; Daniels, E.J.; Giese, R.F.

Author Affiliation: Argonne Nat. Lab., IL, USA

Conference Title: Superconductivity and Its Applications. Proceedings of the Second Annual Conference on Superconductivity and Applications p. 450-6

Editor(s): Kwok, H.S.; Shaw, D.T.

Publisher: Elsevier, New York, NY, USA

Publication Date: 1988

Country of Publication: USA xv+496 pp.

Conference Date: 18-20 April 1988

Conference Location: Buffalo, NY, USA

Language: English

Document Type: Conference Paper (PA)

Treatment: Applications (A); Economic aspects (E); General, Review (G)

Abstract: The future applications of high temperature superconductors are reviewed. Emphasis is given to economic considerations, performance goals, and the research and development that remains to be done. Recent studies suggest that increasing current density to 10^4 - 10^5

amps per cm/sup 2/ in fields of 1-3 Tesla is more important than only raising T/sub c/. The desirability of revising past designs of superconducting equipment to take better economic advantage of the hoped for properties of LN/sub 2/ superconductors is also stressed. The possibility of building smaller devices (e.g. generators) than were discussed in past years is also stressed because smaller devices will find a larger market. High temperature superconductors may offer capital savings as well as energy savings. This is crucial because their ultimate use will be determined by profitability. (1 Refs)

Title: Planning assessment on the role of superconductors in the electric utility industry
Author: Holte, Kirby C.; Mavis, Steven E.
Corporate Source: Southern California Edison Co, CA, USA
Conference Title: Repowering America: Proceedings of the Energy Technology Conference
Conference Location: Washington, DC, USA
Conference Date: 1988 Feb 17-19
E.I. Conference No.: 11120
Source: Energy Technology: Proceedings of the Energy Technology Conference v 15.
Publ by Government Inst Inc, Rockville, MD, USA p 853-863
Publication Year: 1988
Language: English
Document Type: PA; (Conference Paper)
Journal Announcement: 8808

Abstract: Superconductors, with essentially zero losses for direct current and small losses for alternating current applications, offer the potential for system loss reduction while providing a wide range of new capabilities and options available to the electric utility planner. This paper reviews the current state of the art for superconducting cables and generators and suggests areas where electric utilities may benefit from new advancements with high temperature materials. 13 refs.

Title: Lightweight superconducting alternators
Author(s): Keim, T.A.; Goswami, D.Y.
Affiliation: General Electric Corporate Research and Development, Schenectady, NY (US)
Title: Proceedings of the 23rd intersociety energy conversion engineering conference
Series/Collection Title: Volume 2: Mechanical energy storage, thermal energy storage, fuel cells, battery energy storage-terrestrial applications, space battery energy storage, superconductivity
Conference Title: 23. intersociety energy conversion engineering conference
Conference Location: Denver, CO, USA
Conference Date: 31 Jul 1988
Publisher: American Society of Mechanical Engineers, New York, NY
Publication Date: 1988 p 519-524 v
Report Number(s): CONF-880702-
Note: Technical Paper 889418
Language: English

Abstract: One of the most efficient and most lightweight means of converting high-temperature heat energy to electricity is a turboalternator set. Turboalternators are potentially important components of burst-mod power systems, either chemical or nuclear powered. Also, they are probable key components in future electric propulsion systems. Existing examples of multimegawatt turbomachines have been optimized for a variety of aerospace uses, ranging from aircraft propulsion to rocket engine fuel pump drives. There is no corresponding history of multimegawatt alternators built to aerospace standards of mass, performance, and reliability. This paper discusses one of the few such development efforts presently in progress, and gives an indication of possible future potential. In large power ratings, superconducting generators offer

substantial power density, specific weight, and efficiency advantages over competing technologies. A program at GE has led to the construction of a lightweight high-voltage 20-MW generator with a superconducting field winding. The first part of this paper describes the design of the generator. The second projects the capabilities of the generator to other ratings.

Suprajohteiden energiasovellusten kartoitus. Esitutkimus.
(Survey of superconductors for energy applications. Preliminary study)
Eriksson, S. T.
Helsinki Univ. of Technology, Espoo (Finland).
Report No.: NEMO-3; ISBN 951-754-678-5
1988 47p
Languages: Finnish
Journal Announcement: GRAI9022; NSA1500
In Finnish.
NEMO-Research Programme
U.S. Sales Only. Portions of this document are illegible in microfiche products
Country of Publication: Finland

This report describes shortly the present level of superconductor technology and its applications in the field of energy technology. Superconducting magnetic energy storage is examined greater in detail. (ERA citation 15:035356)

Title: The future of superconductivity in the electric power industry
Author(s): Rabinowitz, M.
Journal: Transactions of the American Nuclear Society vol.56 p.24-5
Publication Date: 1988
Country of Publication: USA
Conference Title: 1988 Annual Meeting of the American Nuclear Society (papers in summary form only received)
Conference Date: 12-16 June 1988
Conference Location: San Diego, CA, USA
Language: English
Document Type: Conference Paper (PA); Journal Paper (JP)
Treatment: Theoretical (T)

Abstract: The author considers possible applications of high T_c superconductivity in the electric utility industry, discussing high temperature superconducting transmission lines in particular. He then uses the concept of the coherence length to derive theoretically a value for the highest possible T_c in any material. (2 Refs)

Title: High TC materials in the electric network why or why not?
Author: Klein, Kenneth W.
Corporate Source: US DOE
Conference Title: Repowering America: Proceedings of the Energy Technology Conference
Conference Location: Washington, DC, USA
Conference Date: 1988 Feb 17-19
E.I. Conference No.: 11120
Source: Energy Technology: Proceedings of the Energy Technology Conference v 15.
Publ by Government Inst Inc, Rockville, MD, USA p 844-852
Publication Year: 1988

Language: English
Document Type: PA; (Conference Paper)
Journal Announcement: 8808

Abstract: The new high temperature superconducting ceramics could revolutionize the design of some electrical power systems if major obstacles are cleared. The obstacles include improving the critical current density with applied magnetic fields, improving mechanical properties and chemical stability. For over a decade, the Office of Energy Storage and Distribution (OESD) has supported three applications of superconducting materials: superconducting generator; superconducting transmission cable; and superconducting magnetic energy storage (SEMS). The future prospects for these and other power system applications depend, first and foremost, on the material properties of the superconductor. For most power applications, the critical current density is the crucial property. An understanding of the properties of the high temperature materials will suggest which applications may be the easiest to realize and which may have the greatest potential. This desired understanding can help formulate research goals and priorities.

Title: A power engineering view of higher temperature superconductivity
Author(s): Appleton, A.D.
Conference Title: Proceedings of the Twelfth International Cryogenic Engineering Conference, ICEC 12 p.936-42
Editor(s): Scurlock, R.G.; Bailey, C.A.
Publisher: Butterworth, Guildford, UK
Publication Date: 1988
Country of Publication: UK xx+1034 pp.
Conference Sponsor: Air Products; BOC; BOC Cryoplants; British Cryogenics Council; British Gas; Butterworth Sci.; et al
Conference Date: 12-15 July 1988
Conference Location: Southampton, UK
Language: English
Document Type: Conference Paper (PA)
Treatment: General, Review (G)

Abstract: The search for new superconducting materials and for the improved fabrication of known materials is proceeding in many parts of the world. Engineering applications, and in particular power engineering applications, will form the major market for these materials. It is necessary for engineering design and development to proceed in step with the development of the materials for two reasons. Firstly because the engineer may be able to accept material in a form, other than wire, which could be easier to fabricate. Secondly because it is only by undertaking detailed design studies that the engineer can specify the performance which is required of the superconductor. (3 Refs)

Title: Superconductivity-state of the art
Author(s): Hingorani, N.G.
Author Affiliation: Div. of Electr. Syst., Electr. Power Res. Inst., Palo Alto, CA, USA
Conference Title: World Congress on Superconductivity p.119-25
Editor(s): Burnham, C.G.; Kane, R.D.
Publisher: World Scientific, Singapore
Publication Date: 1988
Country of Publication: Singapore xviii+683 pp.
Conference Sponsor: American Chem. Soc.; AIChE; APS; et al
Conference Date: 20-24 Feb. 1988
Conference Location: Houston, TX, USA

Language: English
Document Type: Conference Paper (PA)
Treatment: Applications (A); General, Review (G)

Abstract: The recent discovery of ceramics, which become superconductors at temperatures higher than liquid nitrogen, is very significant. If one thinks in terms of the business opportunities for future technologies, performance improvements, or new applications there certainly can be many significant opportunities. Possible applications for superconductivity in the electric power system will include: underground transmission, generators, motors, and energy storage (for electric power systems), system dampers (a few-second storage device for damping system oscillations), fault current limiters (for limiting high short-circuit currents), phase shifters (used to make the power flow through certain prescribed routes), transformers, static VAR compensators, power semiconductors, computers and sensors. (0 Refs)

Title: Superconductive electricity supply: no revolution yet!
Author(s): Runde, M.
Journal: Elektro no.16 p.12-13
Publication Date: 1988
Country of Publication: Norway
Language: Norwegian
Document Type: Journal Paper (JP)
Treatment: General, Review (G)

Abstract: The first superconductors capable of carrying currents suitable for electricity supply were available in 1960. Nearly 30 years later after heavy investment, superconductive commercial components suitable for electricity supply applications are still not marketable. The author notes that this should be remembered when considering new 'high temperature' superconductors for use in electricity supplies. (0 Refs)

Title: Applications of high-temperature superconductors to the power sector in developing countries
Author(s): Parikh, J.K.; Pai, M.G.
Author Affiliation: Indira Gandhi Inst. of Dev. Res., Bombay, India
Journal: Journal of Superconductivity vol.1, no.4 p.395-406
Publication Date: Dec. 1988
Country of Publication: USA
Language: English
Document Type: Journal Paper (JP)
Treatment: General, Review (G); Practical (P)

Abstract: Developing countries imported power equipment worth US\$25 billion in 1986, and their power requirements are expected to rise well in the 21st century. Therefore, a global view needs to be taken while according priorities for superconductivity research to the power sector. The scale of the power applications, feasibility of which is earlier established for low temperature superconductors, may have to be reduced if they have to be relevant for the developing countries (e.g. superconducting power generators of 100-500 MW, storage of 500-2000 MWh, and transmission lines of about 100-400 kVA). Fortunately, due to the easier availability of coolant (LN) and ceramics, there could be greater efforts in R&D and, therefore, faster progress. (13 Refs)

Title: Application of high temperature superconductive oxides to rotors
Author(s): Maki, Naoki
Affiliation: Hitachi, Ltd., Tokyo, Japan
Title: 1988 joint convention record of institutes of electrical and information engineers, Japan (part 1)
Corporate Source: Institute of Electrical and Information Engineers (Japan)
Conference Title: Joint convention record of institutes of electrical and information engineers
Conference Location: Niigata, Japan
Conference Date: 3 Oct 1988
Publication Date: 5 Sep 1988 p 49-52
Report Number(s): IEIE-8801; CONF-8810337-Pt.1
Order Number: DE88757165
Language: Japanese
Availability: NTIS (US Sales Only).

Abstract: Superconducting rotors with superconducting field winding has advantages such as miniaturization, weight reduction, improvement of efficiency, and improvement of line stability. Therefore, application of recently discovered high temperature superconducting oxides (high T_c material) to rotors is considered. This paper describes the effect of applying high temperature superconducting oxides to rotors. Rotors handled in this study are those which are used in the following machines: turbine-driven synchronous generators for thermal or atomic power generation, radiofrequency generators for aircraft or spacecraft, single-pole pulse generators, car motors, motors for electric car or ships, industrial motors, linear motors, and solenoid actuated craft. The effect of application to large equipment is also discussed; basic design specification is defined, cost of conventional generator is compared to that of superconducting generator, and advantage of superconducting generator is revealed. Further technological subject in this field for the future is also suggested. (3 figs, 4 tabs, 1 ref)

Superconductivity and Its Applications: State-of-the-Art and Future Perspectives
Spadoni, M.
ENEA, Frascati (Italy). Centro Ricerche Energia.
Report No.: ENEA-RT-FUS-87-34
Sep 88 21p
Languages: Italian
Journal Announcement: GRAI8914; NSA1400
In Italian. Submitted to Nuovo Saggiatore
U.S. Sales Only. Paper copy only, copy does not permit microfiche production.
Country of Publication: Italy

This paper, after a short introduction to superconductivity and to multifilament superconducting composites aims to review the state-of-the-art and future perspectives of some of the applications of superconducting materials. The main interest is focussed upon large scale applications, for instance, magnets for accelerators or fusion reactors, superconducting systems for NMR tomography etc. A short paragraph is dedicated to applications for high sensitivity instrumentation. The paper then concludes by giving some considerations about the potential impacts of the newly discovered high critical temperature materials. (ERA citation 14:017988)

Superconductivity Applications on an Electric Power System: A System Engineering Study
Myers, W. E. ; Taylor, C. W. ; Pachot, J. J. ; Hartmann, D. P. ; Fuller, N. E.
Bonneville Power Administration, Portland, OR
Sponsor: Department of Energy, Washington, DC
Report No.: DOE/BP-1038

Aug 88 74p
Languages: English
Journal Announcement: GRAI8914; NSA1400
Portions of this document are illegible in microfiche products.
Country of Publication: United States

The recent discoveries in superconductivity have raised both questions and exciting expectations about applications in the electric power industry. This report addresses these questions in general and for the Bonneville Power Administration and the Pacific Northwest power system in particular. During early discussions, we decided that an important part of the report would be a description of modern conventional power equipment that are candidates for replacement by superconducting equipment. Also, power system characteristics and requirements would be analyzed. The developments and promises of high temperature superconductors would be evaluated to formulate a BPA role or strategy in developing, demonstrating, and applying superconducting power equipment. 101 refs., 13 figs., 10 tabs. (ERA citation 14:006248)

Title: Do high temperature superconductors make true promises?
Author(s): Emous, K.
Journal: Elektrotechnik vol.66, no.7 p.619-25
Publication Date: July 1988
Country of Publication: Netherlands
Language: Dutch
Document Type: Journal Paper (JP)
Treatment: Applications (A); General, Review (G)

Abstract: Gives an account of the research into superconductivity in various countries. Development is in progress on generators making use of the new high temperature superconductors. (6 Refs)

Title: Applications of ceramic high-temperature superconductors in electric power engineering
Author(s): Barten, H.; Smit, J.J.; Steennis, E.F.
Journal: Elektrotechnik vol.66, no.6 p.543-5
Publication Date: June 1988
Country of Publication: Netherlands
Language: Dutch
Document Type: Journal Paper (JP)
Treatment: Applications (A); Practical (P)

Abstract: Discusses the application of the new (nitrogen cooled) superconductors in power systems, specifically in the Netherlands. They could be suitable for use in transformers, motors, generators, industrial magnets, in the further development of MHD generators and fusion reactors, but not in high-voltage transmission systems. (1 Refs)

Title: Superconductivity: obstacles persist on the path of no resistance
Author(s): Rosen, J.
Journal: Mechanical Engineering vol.110, no.6 p.70-7
Publication Date: June 1988
Country of Publication: USA
Language: English
Document Type: Journal Paper (JP)
Treatment: Applications (A); Economic aspects (E); General, Review (G)

Abstract: These remarkable materials can conduct DC electricity-sometimes in enormous currents-with no resistance. They can cause a locomotive to levitate. They have been tested in noteworthy projects. However, they must still overcome several economic as well as technical constraints. (0 Refs)

Title: Application of superconductivity to electric power technology

Author(s): Tanaka, Toshikatsu

Affiliation: Central Research Inst. of Electric Power Industry, Tokyo, Japan

Source: Nippon Kikai Gakkaishi (Japan) v 91:835

Publication Date: 5 Jun 1988 p 46-50

Language: Japanese

Abstract: Application of the superconductivity to the electric power technology is described. Whereas the cooling efficiency of liquid He is lower than 0.2%, that of liquid nitrogen is 10%, or more than 50 times larger than liquid He. As the evaporation potential heat is 63 times, the thermal conductivity is 7.2 times larger, the insulation breakdown strength is high and the price is one-fiftieth lower, reducing the economic scale greatly. The capacity of superconducting generators that are competitive with conventional machines are 1000 MVA with the liquid He and 500 MVA when the superconductivity at high temperature is possible with the liquid nitrogen. For the transformers, the AC wire of high temperature superconducting material is required but the research on it is not yet started. While the loss of superconducting power cable is low and it is suitable for large capacity DC power transmission, it is advantageous even with 2 million KVA if the liquid nitrogen cooling is possible. The superconducting magnetic energy storage (SMES) is useful in the system power pooling and storage, and it is competitive with the pumped storage power generation at 4 million KWh with He and 1 million KWh is allowable if the liquid nitrogen can be used. The impact of high temperature superconducting material to the power technology is high and the superconducting cable and SMES are promising. (3 figs, 3 tabs, 3 refs)

Research and Development of Superconductivity in the USA

Clarke, J.

Lawrence Berkeley Lab., CA

Sponsor: Department of Energy, Washington, DC

Report No.: LBL-25360; CONF-8805148-1

May 88 22p

Languages: English

Document Type: Conference proceeding

Journal Announcement: GRAI8902; NSA1300

25. anniversary meeting of the Metal Mining Agency, Tokyo, Japan, 27 May 1988

Portions are illegible in microfiche products.

Country of Publication: United States

Contract No.: AC03-76SF00098

In this paper, the author focuses his attention on the present and potential applications of superconductors -- both the classic low T_c superconductors such as niobium and its alloys and the new high- T_c materials. This discussion falls naturally into two broad areas: large scale applications such as magnets and power generators, and small scale applications such as ultrasensitive detectors of electromagnetic radiation and of tiny magnetic fields;. (ERA citation 13:038728)

Title: Fabrication of 91K superconducting coils
 Author(s): Jin, S.; Sherwood, R.C.; Van Dover, R.B.; Tiefel, T.H.; Johnson, D.W. Jr.; Gubser, D.U.; Schluter, M.
 Affiliation: AT and T Bell Labs., Murray Hill, NJ
 Title: Proceedings of symposium S at the 1987 Spring meeting of the MRS on high temperature superconductors (Extended Abstracts)
 Conference Title: Spring meeting of the Materials Research Society
 Conference Location: Anaheim, CA, USA
 Conference Date: 21 Apr 1987
 Publisher: Materials Research Society, Pittsburgh, PA
 Publication Date: 1987 p 219-222
 Report Number(s): CONF-870438-
 Language: English

Abstract: The recent discovery of high temperature superconductivity in La(Ba,Sr)-Cu oxides and Ba-Y-Cu oxides has stimulated worldwide research activity. The excitement in the scientific and engineering community is created by this advance in superconductivity due in part to the potentially immense technological impact of the superconducting materials that do not require liquid He refrigeration. Applications currently considered in this report include power transmission lines, rotating machinery, superconducting magnets for fusion reactors, MHD generators, particle accelerators, and junction devices.

Title: High temperature superconductors in electric power equipment?
 Author: De Doncker, R.; Novotny, D. W.
 Corporate Source: Univ of Wisconsin-Madison, Madison, WI, USA
 Source: Electric Machines and Power Systems v 13 n 5 1987 p 329-345
 Publication Year: 1987
 Language: ENGLISH
 Document Type: JA; (Journal Article)
 Treatment: A; (Applications) J
 Journal Announcement: 8803

Abstract: The recent discovery of new, high temperature superconductors has created a renewed interest in potential applications of superconductivity. Developments with the new materials have come at such a rapid pace that news articles often imply major new applications are near at the hand. One of the areas often mentioned is electrical equipment such as motors, generators, transmission lines, etc. The purpose of this paper is to explore the possible future applications of superconductivity in such equipment and what this might imply with regard to such issues as control requirements, system protection and even the basic structure of electric power systems. After a brief introduction to the properties of superconductors, a discussion of some basic technology issues affecting all types of superconducting electrical apparatus is presented. The overall intent is to discuss some of the basic technological properties of superconducting electrical equipment and what these properties suggest in terms of future developments in this area. (Edited author abstract) Refs.

Title: The impact of high T/sub c/ superconductors upon applications in electrical power equipment
 Author(s): Appleton, A.D.
 Author Affiliation: NEI Int. Res. & Dev. Co. Ltd., Newcastle upon Tyne, UK
 Conference Title: Commission of the European Communities European Workshop on High T/sub c/ Superconductors and Potential Applications. Proceedings p.145-76
 Publisher: Comm. Eur. Communities, Brussels, Belgium
 Publication Date: 1987

Country of Publication: Belgium 465 pp.
Conference Date: 1-3 July 1987
Conference Location: Genova, Italy
Language: English
Document Type: Conference Paper (PA)
Treatment: Applications (A); General, Review (G)

Abstract: The author discusses the impact which the high T_c superconductors may have upon applications in electrical power equipment. Topics covered include: DC motors, DC and AC generators, fault current limiters, power cables, energy storage, high speed transportation, transformers and magnetic separation. (0 Refs)

Title: Discovery of superconducting material and the future prospect
Author(s): Fueki, Kazuo
Affiliation: The Univ. of Tokyo, Faculty of Engineering, Tokyo, Japan
Source: Enerugi Rebyu (Japan) v 8:1
Publication Date: 20 Dec 1987 p 2-7
Language: Japanese

Abstract: Discovery of high temperature oxide superconducting material above 90K which was achieved in USA in Feb, 1987 rapidly made a break-through for the commercialization of the superconductivity. Features of superconducting materials in the electrical properties are zero-resistance and a permanent current. Magnetically it is a perfect dia-magnetism. For its commercialization, high critical temperature, large critical magnetic field or high critical current density are required. Discovery of high temperature oxide superconducting material has expanded its areas of application far more than before. Promising fields of application are as follows. Utilization of powerful, compact, low power consuming magnet: pollution treatment, nuclear fusion, MHD, power storage, NMR-CT, magnetic levitation train, electromagnetic propelled ship, etc.. Utilization of low loss: generator, power transmission, motor, etc.. Other applications: ultra high speed computer, Josephson element, gyroscope, brain wave meter, mechanical clutch, magnetic shield room, etc.. (7 figs)

Title: Impact of high T_c oxide superconductors
Author(s): Fueki, Kazuo
Affiliation: The Univ. of Tokyo, Faculty of Engineering, Tokyo, Japan
Source: Kagaku To Kogyo (Tokyo) (Japan) v 40:12
Publication Date: 1 Dec 1987 p 60-63
Language: Japanese

Abstract: Superconductivity has three characteristics: perfect conductivity, perfect diamagnetism, and macro-quantum effect. To produce superconductivity, it is necessary to put the substance under the critical temperature, critical magnetic field, and critical current density. These conditions are related mutually. Since 1911 when superconductivity was first discovered, the best record of the critical temperature was no more than 23K. After the first generation of 40K high T_c oxide superconductors in 1986, 90K superconductors which can be cooled by liquid nitrogen were discovered in 1987. Practical applications of superconductivity lie in large electric power engineering, transportation, and electronics. Applications to large power engineering include accelerators, electric energy storage, large electric generators, among others. Applications to transportation include linear motor cars, electromagnetically propelled ships, among others. Applications to electronics include high-speed computers. The important subject to be solved in 1987 is to find techniques for processing superconducting substances into usable materials. (2 figs, 3 refs)

Title: The promise and limitations of the new superconductors

Author(s): Rabinowitz, M.

Author Affiliation: Div. of Electr. Syst., Electric Power Res. Inst., Palo Alto, CA, USA

Journal: Transmission and Distribution vol.39, no.11 p.86-8, 90

Publication Date: Nov. 1987

Country of Publication: USA

Language: English

Document Type: Journal Paper (JP)

Treatment: General, Review (G)

Abstract: The momentous achievement of higher-temperature superconductivity has the potential of leading to practical developments which are likely to dramatically change (if not revolutionize) the electric utility, electrical manufacturing, electronics, and possibly even the transportation industries. These new developments may have an impact on society as important as the discovery of the transistor and the laser. Specific applications include transmission lines, supercomputers, generators, motors, transformers, magnetic energy storage, circuit breakers, fault-current limiters, electronics, medical diagnostics, levitated trains and high-energy physics. (5 Refs)

Title: Superconducting generator

Author(s): Aiyama, Y.

Journal: Solid State Physics vol.22, no.11 p.915-23

Publication Date: Nov. 1987

Country of Publication: Japan

Language: Japanese

Document Type: Journal Paper (JP)

Treatment: Practical (P)

Abstract: On the basis of characteristics of superconductors for commercial use, the designs, problems and R&D programmes for superconducting turbo-generators are outlined. The specific role of high current-density of the superconducting windings is stressed. (0 Refs)

Title: Application of high temperature superconducting materials

Author(s): Tanaka, Toshikatsu

Affiliation: Central Research Inst. of Electric Power Industry, Tokyo, Japan

Source: Kagaku Kogaku (Japan) v 51:11

Publication Date: 5 Nov 1987 p 35-39

Language: Japanese

Abstract: As for superconducting materials, there are still many problems such as their natures, etc. to be clarified. However, because of such merits that a large amount of electric current can be transferred with an extremely small loss and a strong magnetic field can be generated, the development of the application researches is in progress. In this article, the application to the electric power fields is explained. In the field of superconducting generators, many countries are conducting its research and development and in Japan, in accordance with the Moonlight Project, its research and development are planned to be conducted for 8 years from 1988 and the stage of a 70MVA model machine has already been over. Currently, wire rods of NbTi or Nb/sub 3/Sn as well as a cooling device are the subjects for study. Concerning superconducting transformers, it has been experimentally calculated that in comparison with the conventional transformers, the loss will be decreased by half and the weight be decreased down to 50-60%, but the increase of the critical electric current density is considered to be solved first. With respect to superconducting

cables, studies are being made on liquid nitrogen cooled cables in addition to liquid helium cooled ones. In the field of superconducting energy storage, the conceptual design of a 5 million KWh SMES was completed in 1985 as a commissioned project of NEDO. (6 figs, 3 tabs, 7 refs)

Title: The advances of high T/sub c/ superconductors and their impact on the application of superconductivity in the electric industry

Author(s): Bogner, G.; Lambrecht, D.; Sabrie, J.-L.

Journal: Electra no.114 p.96-107

Publication Date: Oct. 1987

Country of Publication: France

Language: French; English

Document Type: Journal Paper (JP)

Treatment: Applications (A); General, Review (G)

Abstract: The CIGRE Working Group 11.05 has the task of studying non-conventional generators, in particular superconducting (SC) generators and inquiring into superconducting materials with respect to potential application in the field of power engineering. This report gives information on the state-of-the-art in the development of high T/sub c/ superconductors with regard to their: (i) properties, characteristics and producibility; (ii) possible future applications in new fields of industry; and (iii) influence on products and current developments of applied superconductivity such as SC magnets, SC generators etc. (0 Refs)

Assessment of Potential Advantages of High T sub c-Superconductors for Technical Application of Superconductivity

Schauer, F. ; Juengst, K. P. ; Komarek, P. ; Maurer, W. Kernforschungszentrum Karlsruhe G.m.b.H. (Germany, F.R.). Inst. fuer Technische Physik.

Report No.: KFK-4308

Sep 87 28p

Languages: English

Journal Announcement: GRAI8908; NSA1300

U.S. Sales Only

Country of Publication: Germany, Federal Republic of

A first assessment of the technical and economical consequences of liquid nitrogen cooling of new superconductors is given. For the investigation the applications of superconductivity are classified in two categories: First, systems where superconductors are practically indispensable for achieving the system's objectives; second, superconductor applications in competition with highly developed conventional technologies. Further development of those superconducting systems in the first category for which the cost of cryogenic equipment is a smaller fraction of the total system cost (e.g. fusion reactor or MHD generator) will hardly be affected. However, for systems like particle accelerators, research magnets, and NMR spectroscopy and imaging systems, the cryogenic equipment expenditures are significant and LN2 cooling leads here to a reduction of investment and operating costs, to simplified handling and maintenance, to better reliability and availability, and will thereby improve the acceptance and further spread of these systems. In the second category each application of superconductivity has to be compared with its conventional counterpart, separately. Here, electronic components, power switches, resistive current limiters, and especially the power transmission cables are those applications which look most promising. For magnet applications the main advantageous arguments are less the cost saving aspect but more the higher reliability, simplicity, N2-availability, and ease of handling. (ERA citation 13:012069)

Applications of High Temperature Superconductors

Holzrichter, J. F. ; Struble, G. L. ; McMahan, A. K. ; Mapoles, E. R. ; Fluss, M. J.
Lawrence Livermore National Lab., CA

Sponsor: Department of Energy, Washington, DC

Report No.: UCRL-53855

9 Jan 87 31p

Languages: English

Journal Announcement: GRAI8823; NSA0000

Portions of this document are illegible in microfiche products

Country of Publication: United States

Contract No.: W-7405-ENG-48

The applications of high temperature superconductors to technologies of interest to the Lawrence Livermore National Laboratory are discussed. They include high field, large bore magnets, motors and generators, magnetic fusion, inductive energy storage, rf accelerators, computers, transmission lines, and sensors. Basic principles of superconductivity and the special properties (and limitations) of high temperature superconductors that make them attractive for technology applications are described.

VII. ASSESSMENTS BEARING UPON MOTORS

The following pages provide citations and abstracts for 23 reports, each bearing upon the use of ceramic superconductors in motors. Some reports describe more than one topic; in that case the report is listed in this section and in other appropriate sections. The most recent reports are from 1991 and the earliest is from 1987.

Motors

Title: Self energized air core superconducting (SEAC) motor
Author(s): Hilal, M.A.; Lloyd, J.D.; Crapo, A.D.; Huang, X.
Author Affiliation: Appl. Superconductivity Center, Wisconsin Univ., Madison, WI, USA
Journal: IEEE Transactions on Magnetics vol.27, no.2, pt.3 p.2240-3
Publication Date: March 1991
Country of Publication: USA
U.S. Copyright Clearance Center Code: 0018-9464/91/0300-2240\$01.00
Conference Title: 1990 Applied Superconductivity Conference
Conference Sponsor: IEEE
Conference Date: 24-28 Sept. 1990
Conference Location: Snowmass, CO, USA
Language: English
Document Type: Conference Paper (PA); Journal Paper (JP)
Treatment: Practical (P)

Abstract: The SEAC motor described utilizes superconductive windings both for the stator and the rotor and operates the same way as a conventional motor by supplying power to the stator. The rotor of a simple SEAC motor has a small and a large winding and two switches. The axes of the two rotor windings are normal to each other. The rotor is initially stationary, and the windings are exposed to the rotating stator field. Flux pumping is employed to charge the rotor windings. As the field rotates by 180 degrees from being parallel to the axis of the small winding of the rotor, a switch connected in series with the windings automatically opens, allowing the magnetic flux to penetrate the winding. The switch is closed during most of the other half of the cycle. The flux trapped in the small winding is partially transferred to the larger rotor winding by opening another switch, which results in series connection of the two windings. This results in charging the large winding and in accelerating the rotor to reach the rotating field angular velocity. The rotor synchronously rotates with the field when steady-state operation is achieved. The use of a high-temperature superconductor allows the persistent operation of the rotor windings after reaching steady state. (2 Refs)

Title: Homopolar DC motor and trapped flux brushless DC motor using high temperature superconductor materials
Author(s): Crapo, A.D.; Lloyd, J.D.
Author Affiliation: Emerson Electr. Co., St. Louis, MO, USA
Journal: IEEE Transactions on Magnetics vol.27, no.2, pt.3 p.2244-7
Publication Date: March 1991
Country of Publication: USA
U.S. Copyright Clearance Center Code: 0018-9464/91/0300-2244\$01.00
Conference Title: 1990 Applied Superconductivity Conference
Conference Sponsor: IEEE
Conference Date: 24-28 Sept. 1990
Conference Location: Snowmass, CO, USA
Language: English
Document Type: Conference Paper (PA); Journal Paper (JP)
Treatment: Practical (P)

Abstract: Two motors have been designed and built for use with high-temperature-superconductor (HTSC) materials. They are a homopolar DC motor that uses HTSC field windings and a brushless DC motor that uses bulk HTSC materials to trap flux in steel rotor poles. The HTSC

field windings of the homopolar DC motor are designed to operate at 1000 A/cm² in a 0.010-T (100-G) field. In order to maximize torque in the homopolar DC motor, an iron magnetic circuit with small air gaps gives maximum flux for minimum Ampere turns in the field. A copper field winding version of the homopolar DC motor has been tested while waiting for 575 Ampere turn HTSC coils. The trapped flux brushless DC motor has been built and is ready to test melt textured bulk HTSC rings that are currently being prepared. The stator of the trapped flux motor will impress a magnetic field in the steel rotor poles with warm HTSC bulk rings. The rings are then cooled to 77 K to trap the flux in the rotor. The motor can then operate as a brushless DC motor. (4 Refs)

Title: Test results of motors with a superconducting rotor
Author(s): Takahashi, M.; Arai, K.; Satoh, M.; Watanabe, M.; Takahashi, N.; Takahashi, R.
Author Affiliation: Res. Lab., Hitachi Ltd., Ibaraki, Japan
Conference Title: 11th International Conference on Magnet Technology (MT-11) p.580-5 vol.1
Editor(s): Sekiguchi, T.; Shimamoto, S.
Publisher: Elsevier Applied Science, London, UK
Publication Date: 1990
Country of Publication: UK 2 vol. xxxvi+1540 pp.
Conference Date: 28 Aug.-1 Sept. 1989
Conference Location: Tsukuba, Japan
Language: English
Document Type: Conference Paper (PA)
Treatment: Practical (P); Experimental (X)

Abstract: Experimental studies of two-pole, three-phase superconducting motors using Y-Ba-Cu-O (high-T_c) and Nb/₃Sn rotors were carried out. The former high-T_c rotor shapes were cylindrical, cylindrical with axial slits, or reluctance types. The rotor outer diameters were 38mm and their lengths were 30-32mm. Each high-T_c rotor started to rotate by itself and kept a speed with large slip at superconducting conditions in liquid nitrogen. For example, the cylindrical rotor rotated at 46 r.p.m. when the motor was excited by 5 Hz sinusoidal alternating current of 1.5 VA input. The cylindrical Nb/₃Sn rotor was confirmed as able to rotate not only at asynchronous speed, but also synchronous speed. Further, once the rotor reached the synchronous speed, it kept constant even if the stator voltage was decreased. These results indicated that the superconducting motor can be driven by AC magnetizing loss of the superconductor. (2 Refs)

Title: Application of high temperature superconducting materials to electric motors
Author: Edmonds, J. S.; Jordan, H. E.; Edick, J. D.; Schiferl, R. F.
Corporate Source: Electric Power Research Inst, Palo Alto, CA, USA
Source: Energy Engineering: Journal of the Association of Energy v 87 n 4 1990 p 64-79
Publication Year: 1990
Language: English
Document Type: JA; (Journal Article)
Treatment: A; (Applications); G; (General Review); X; (Experimental)
Journal Announcement: 9102

Abstract: Since the discovery of high temperature superconducting (HTSC) materials was reported in 1987, speculation on potential applications for this new science has ranged across diverse fields of engineering. In the electric power field, underground dc and ac transmission lines and ac generators are frequently mentioned candidates. This paper reports on progress made in a joint project conducted by the Electric Power Research Institute and Reliance Electric Company to study the possible application of HTSC materials to electric motors. Specific applications are identified which can be beneficially served by motors constructed with HTSC materials. Design aspects,

both electrical and mechanical, of motors tailored to utilize HTSC materials are discussed. A design study of a 10,000 hp motor has been conducted. The results are reported along with a discussion of the uncertainties remaining to be resolved before a viable 10,000 hp motor can be constructed. Two different types of laboratory models that are being used to examine critical design issues are described. Finally, this paper describes the operation of an HTSC dc motor. Measured data from the experiment demonstrates that the yttrium barium copper oxide field winding is indeed operating in the superconducting state when the motor is running. (Author abstract)

Title: Superconducting synchronous induction motor performance

Author: Tubbs, S. P.

Corporate Source: Univ of Pittsburgh, Pittsburgh, PA, USA

Source: IEE Proceedings, Part B: Electric Power Applications v 137 n 2 Mar 1990 p 120-124

Publication Year: 1990

Language: English

Document Type: JA; (Journal Article)

Treatment: T; (Theoretical)

Journal Announcement: 9006

Abstract: A method is presented for determining the steady state running currents, torques, speeds, power factors and efficiencies of a superconducting synchronous/induction motor. Also, a method is presented for determining the current and magnetic flux densities that a superconductor must be able to withstand to successfully function in a superconducting synchronous/induction motor. The methods are applied to a hypothetical superconducting synchronous/induction motor. The hypothetical motor's design is a modification of that of an 11.2 kW squirrel cage induction motor. Hypothetically, the inner 5/6ths of the induction motor's rotor conductors were replaced with high T_c (critical temperature) superconductor and liquid nitrogen cooling tubes were put next to the superconductor. Computations for this superconducting motor show that its superconductors must be able to withstand AC current densities of 1.4 multiplied by 10^{*7} A/m² peak and AC magnetic flux densities of 0.2 T peak. The major components of the current and magnetic flux density waveforms' frequencies are 120 Hz and 240 Hz. It is concluded that due to required superconductor qualities and cooling expenses superconducting synchronous/induction motors are presently impractical. (Author abstract) 8 Refs.

Title: Superconductivity rolls toward industry, but where are the motors?

Author(s): Rughe, T.

Journal: Power Transmission Design vol.32, no.11 p.45-7

Publication Date: Nov. 1990

Country of Publication: USA

Language: English

Document Type: Journal Paper (JP)

Treatment: Practical (P)

Abstract: In 1986, the first high temperature superconductors (HTSC) proved possible. Many applications were foreseen, and electric motors were predicted to use HTSCs. However superconducting motors never made a big breakthrough. The author finds that HTSCs are, as yet, not suitable for use in motors although, in time, they will become reality. (0 Refs)

Title: Composite ceramic superconducting wires for electric-motor applications. Quarterly report No. 9, 1 July-30 September 1990

Author(s)/Editor(s): Hodge, J.D.

Corporate Source: CPS Superconductor Corp., Milford, MA (USA)

Publication Date: 30 Sep 1990 (57 p)
Report Number(s): AD-A-228359/6/XAB CPSS--0990-1
Contract Number (Non-DOE): N00014-88-C-0512; DARPA Order-9525
Language: In English
Availability: NTIS

Abstract: A scaled-up process for producing sintered, silver-coated YBCO mono filament wire has been developed and is currently able to produce 30 meters of wire/day. Efforts aimed at improving the electrical performance of this wire are well underway. Two approaches are being used: (1) Continuously melt-texturing sintered YBCO wire/fiber to produce a macro-crystalline, strong-linked wire, and (2) Adapt the TBCO process to the production of BiSCCO wire which can be subsequently mechanically textured by rolling the wire into ribbon. Work has also proceeded on the fabrication of a brushless DC trapped flux motor in which melt-textured YBCO rings are used as permanent magnet replicas. This motor design holds the potential for a high power HTSC motor which can be fabricated using current HTSC technology.

Title: Composite ceramic superconducting wires for electric-motor applications. Quarterly technical report No. 6, 1 October-31 December 1989
Author(s)/Editor(s): Halloran, J.W.
Corporate Source: Ceramics Process Systems Corp., Milford, MA (USA)
Publication Date: 31 Jan 1990 (93 p)
Report Number(s): AD-A-219131/0/XAB CPS--90-001
Language: In English
Availability: NTIS

Abstract: This report describes progress on developing $\text{YBa}_{\text{sub } 2}\text{Cu}_{\text{sub } 3}\text{O}_{\text{sub } 7-X}$ (Yttrium Barium Copper Oxide-X) wire for an High Temperature Superconductor motor. The wire development activity includes synthesis of Y-123 powder, spinning polymer-containing green fiber, heat treating the fiber to produce metallized superconducting filaments, and characterizing the electrical properties of the filaments. Green fiber is produced in lengths up to 1.5 kilometers. The green clad fiber is converted to silver-clad superconducting wire by a sintering operation. The sintered wire has a Amperes per centimeters squared (77 deg) up to 2800 Angstrom per centimeters in self field, dropping to low values in magnetic fields. Directional solidification efforts are underway to improve the critical current density. The construction of the first prototype HTSC homopolar motor is in progress. The design specifies a 575 ampere-turn HTSC coil. The current collection system has been tested in liquid nitrogen. Motor performance has been predicted based on actual $J_c(B)$ behavior of wire samples. Motor power and losses have been calculated. The efficiency of this initial machine is limited by the magnetic fields obtainable from present HTSC wire coils.

Composite Ceramic Superconducting Wires for Electric Motor Applications (Quarterly technical rept. no. 6, 1 Oct-31 Dec 89)
Halloran, J. W.
Ceramics Process Systems Corp., Milford, MA.
Report No.: CPS-90-001
31 Jan 90 93p
Languages: English
Journal Announcement: GRAI9014
Country of Publication: United States
Contract No.: N00014-88-C-0512; DARPA Order-9525

This report describes progress on developing YBa₂Cu₃O_{7-X} (Yttrium Barium Copper Oxide-X) wire for an High Temperature Superconductor motor. The wire development activity includes synthesis of Y-123 powder, spinning polymer-containing 'green fiber', heat treating the fiber to produce metallized superconducting filaments, and characterizing the electrical properties of the filaments. Green fiber is produced in lengths up to 1.5 kilometers. The green clad fiber is converted to silver-clad superconducting wire by a sintering operation. The sintered wire has a Amperes per centimeters squared (77 deg) up to 2800 Angstrom per centimeters in self field, dropping to low values in magnetic fields. Directional solidification efforts are underway to improve the critical current density. The construction of the first prototype HTSC homopolar motor is in progress. The design specifies a 575 ampere-turn HTSC coil. The current collection system has been tested in liquid nitrogen. Motor performance has been predicted based on actual J_c(B) behavior of wire samples. Motor power and losses have been calculated. The efficiency of this initial machine is limited by the magnetic fields obtainable from present HTSC wire coils. Polymers; Green clad fibers; Superconductor; Ceramic; Motor; Wires; Composite materials. (jg)

Title: Novel synchronous machines: linear and disc
Author(s): Eastham, J.F.
Author Affiliation: Sch. of Elect. Eng., Bath Univ., UK
Journal: IEE Proceedings B (Electric Power Applications) vol.137, no.1 p.49-58
Publication Date: Jan. 1990
Country of Publication: UK
U.S. Copyright Clearance Center Code: 0143-7038/90/\$3.00+0.00
Language: English
Document Type: Journal Paper (JP)
Treatment: Practical (P)

Abstract: The author considers some of the developments that have taken place over the last few years in the field of synchronous machines of unusual geometry. Linear synchronous motors are a comparatively new development; they have the virtue of considerable higher force production but require a variable frequency supply. However, in small sizes, power integrated circuits have become available that can be used to power the machines as brushless DC drives. A tubular version using permanent magnet excitation is described. The development of disc brushless alternators is also described. In these machines the excitation winding is located on the same side of the air-gap as the AC winding. A demonstration of the use of the new 'high'-temperature superconductors, which uses a double disc form of these machines, is outlined. (35 Refs)

Title: Feasibility study of electric motors constructed with high temperature superconducting materials
Author(s): Jordan, H.E.
Author Affiliation: Reliance Electr. Co., Cleveland, OH, USA
Journal: Electric Machines and Power Systems vol.16, no.1 p.15-24
Publication Date: 1989
Country of Publication: USA
Language: English
Document Type: Journal Paper (JP)
Treatment: Practical (P)

Abstract: The potential application of high temperature superconducting (HTSC) materials to electric motors is discussed. The specific application area of motors in electric power generating stations has been selected and a feasible study has been initiated on the use of HTSC materials in the design of motors for this application. A progress report on this feasibility study is presented. Technical challenges in both the development of HTSC wire and the design of a motor to utilize

this wire are discussed. Finally, the results of design calculations comparing a superconducting motor with one of conventional design are presented assuming that success can be achieved in overcoming the technical problems which must be resolved to produce a high performance HTSC wire. (5 Refs)

Title: Fundamental properties of a new superconducting motor
Author(s): Takeoka, A.; Ishikawa, A.; Suzuki, M.; Kishi, Y.; Kuwano, Y.
Author Affiliation: Functional Mater. Dev. Center, Sanyo Electric Co. Ltd., Osaka, Japan
Conference Title: Advances in Superconductivity. Proceedings of the 1st International Symposium on Superconductivity p.695-700
Editor(s): Kitazawa, K.; Ishiguro, T.
Publisher: Springer-Verlag, Tokyo, Japan
Publication Date: 1989
Country of Publication: Japan xxiii+920 pp.
Conference Sponsor: Int. Superconductivity Technol. Center
Conference Date: 29-31 Aug. 1988
Conference Location: Nagoya, Japan
Language: English
Document Type: Conference Paper (PA)
Treatment: New Developments (N); Practical (P); Experimental (X)

Abstract: The authors developed a brand new superconducting motor using high-T/sub c/ ceramic superconductors for the first time. This motor, named the 'Meissner Motor', utilizes the repulsive force caused by the Meissner effect, which appears below T/sub c/ and disappears above that. The motor rotated at a maximum speed of 40 rpm and generated a torque below 0.66 gf-cm. Though the repulsive force to drive the motor increased with the decrease of temperature or the increase of the gradient magnetic field, it was only about 1.1 gf/g at 77 K in 3500 G/cm and differs a little with the processes of magnetization. The rotating speed of the motor is limited by heating ability and the torque is limited by cooling ability. (2 Refs)

Title: Magnetic field optimization by means of superconducting screens for energy transformation
Original Title: Magnetfeldkonditionierung durch supraleitende Blenden fuer die Energiewandlung
Author(s): Weh, H.; May, H.
Title: Superconductivity in power engineering. Status, concepts, new aspects
Original Title: Supraleitung in der Energietechnik. Stand, Konzepte, neue Aspekte
Original Series Title: VDI-Berichte
Corporate Source: Verein Deutscher Ingenieure (VDI) - Gesellschaft Energietechnik, Duesseldorf (Germany, F.R.)
Conference Title: Technical meeting on superconductivity in power engineering: Status, concepts, new aspects, with exhibition
Original Conference Title: Fachtagung Supraleitung in der Energietechnik: Stand, Konzepte, Neue Aspekte und Ausstellung
Conference Location: Karlsruhe (Germany, F.R.)
Conference Date: 14-15 Jun 1989
Publisher: Duesseldorf (Germany, F.R.) VDI-Verl.
v no. 733
Publication Date: 1989 p 137-152 (442 p)
Report Number(s): CONF-8906339--
Language: In German

Abstract: Energy transformation and the generation of mechanical forces by magnetic fields can be made more efficient by enhancing the local change of magnetic energy in the direction of movement. High-T_c superconducting screens can be used to influence the field distribution, and thus the generation of the forces wanted. The magnetic circuits thus are more efficiently used, and by means of magnetic circuits with high-T_c superconducting screens, the required permanent forces can be generated in the magnetic levitation and guidance systems. Similar enhancements can be achieved in the reluctance device using the edge effect. High-T_c superconducting screens and coils are the components that significantly improve the force density in transverse flux motors. Assessments show that the introduction of high-energy permanent magnets will allow designs of smaller dimensions and mass. (orig.).

Title: Conception and operation of a Meissner-Ochsenfeld effect motor with high T_c superconductors

Author(s): Bochenek, E.; Fischer, R.; Voigt, H.

Author Affiliation: AEG Res. Inst., Frankfurt, West Germany

Journal: Journal of the Less-Common Metals vol.151 p.473-80

Publication Date: 15 May 1989

Country of Publication: Switzerland

U.S. Copyright Clearance Center Code: 0022-5088/89/\$3.50

Conference Title: Symposium on High Temperature Superconductors -Preparation and Applications

Conference Sponsor: Bull S.A.; AEG-Res. Centre

Conference Date: 8-10 Nov. 1988

Conference Location: Strasbourg, France

Language: English

Document Type: Conference Paper (PA); Journal Paper (JP)

Treatment: Practical (P); Experimental (X)

Abstract: Utilizing the Meissner-Ochsenfeld effect, the authors designed and built a small motor with high T_c superconductors cooled by liquid nitrogen. The rotor is an epoxy resin disc whose rim carries 20 ceramic Y-Ba-CuO pellets. They pass the air gap of a permanent magnet system in an open liquid nitrogen Dewar vessel. When in motion, the pellets, one after another, turn superconductive and experience a repulsive force in the divergent magnetic field at the end of the air gap. In their subsequent passage through the ambient air, they gain a temperature greater than T_c so that they can enter the magnetic field and the liquid nitrogen bath anew. The repulsive force is caused by the diamagnetism in the Meissner state and gives rise to a torque exerted on the rotor. The design and operation are discussed as well as some details of the mechanical and magnetic components of the motor which in principle is a heat engine. (3 Refs)

Title: Meissner motor using high-T_c ceramic superconductors

Author(s): Takeoka, A.; Ishikawa, A.; Suzuki, M.; Niki, K.; Kuwano, Y.

Author Affiliation: Sanyo Electr. Co. Ltd., Osaka, Japan

Journal: IEEE Transactions on Magnetism vol.25, no.2 p.2511-14

Publication Date: March 1989

Country of Publication: USA

U.S. Copyright Clearance Center Code: 0018-9464/89/0300-2511\$01.00

Conference Title: 1988 Applied Superconductivity Conference

Conference Sponsor: IEEE

Conference Date: 21-25 Aug. 1988

Conference Location: San Francisco, CA, USA

Language: English
Document Type: Conference Paper (PA); Journal Paper (JP)
Treatment: Practical (P)

Abstract: The authors developed a superconducting motor using high- T_c ceramic superconductors. This motor, which utilizes the repulsive force caused by the Meissner effect that appears below T_c , is called the Meissner motor. The motor rotated at a maximum speed of 40 rpm. Though the repulsive force to drive the motor increased with the decrease of temperature or the increase of the gradient magnetic field, it was only about 1.1 gf/g at 77 K in 3500 G/cm. The motor has a maximum torque of 5.0 gf-cm theoretically, but actually had a torque below 0.66 gf-cm, because it took some time to be cooled below T_c . The rotating speed of the motor was limited by heating ability, and its torque was limited by cooling ability. (2 Refs)

Title: Meissner motor using high- T_c ceramic superconductors
Author(s): Takeoka, A.; Ishikawa, A.; Suzuki, M.; Niki, K.; Kuwano, Y.
Affiliation: 9305050
Conference Title: Applied superconductivity conference
Conference Location: San Francisco, CA, USA
Conference Date: 21-25 Aug 1988
Source: IEEE Trans. Magn. (United States) v 25:2.
Publication Date: Mar 1989 p 2511-2514
Report Number(s): CONF-880812-
Language: English

Abstract: The authors developed a brand new superconducting motor using high- T_c ceramic superconductors for the first time. This motor utilizes the repulsive force caused by the Meissner effect, which appears below T_c and disappears above that, and is therefore referred to as the Meissner Motor. The motor rotated at a maximum speed of 40 rpm. Though the repulsive force to drive the motor increased with the decrease of temperature or the increase of the gradient magnetic field, it was only about 1.1 gf/g at 77 K in 3500 G/cm. The motor has a maximum torque of 5.0 gf-cm theoretically, but actually had a torque below 0.66 gf-cm, because it took some time to be cooled below T_c . The rotating speed of the motor was limited by heating ability and its torque was limited by cooling ability.

Title: Meissner motor developed high- T_c ceramic superconductors
Author(s): Ishikawa, Akira; Suzuki, Masaharu; Takeoka, Akio
Affiliation: Sanyo Electric Co. Ltd., Osaka (Japan)
Source: Sanyo Tech. Rev. (Japan) v 20:3
Publication Date: 10 Nov 1988 p 43-49
Language: English

Abstract: Trial assembling of Meissner motor was achieved by using Y-Ba-Cu-O oxide which material was superconductive at liquid nitrogen temperature, and fundamental property of Meissner effect, determining factors of theoretical magnitude of torque and revolution speed, were studied. Principle of Meissner motor, its structure, preparation method of superconductor, were explained, and as the index of fundamental properties of the motor, revolution speed and torque were taken. Immersed depth of armature into liquid nitrogen and revolving speed were correlated as graph. It was indicated that, by the correlation, heating calorie affected the depth of immersion at maximum revolution. As the cause of this phenomenon, it was considered that heating calorie and the depth of immersion affected on the temperature of armature. Regarding the relation between revolution speed and torque, correlation graph was shown between no-load revolution

speed and starting torque at various heater temperature. Repulsion force induced by Meissner effect was also correlated by temperature and magnetic field as graph with explanation. 2 references, 14 figures, 2 tables.

Title: Applications of superconductors to electric motors

Author(s): McConnell, B.W.

Author Affiliation: Oak Ridge Nat. Lab., TN, USA

Conference Title: Superconductivity and Its Applications. Proceedings of the Second Annual Conference on Superconductivity and Applications p. 457-65

Editor(s): Kwok, H.S.; Shaw, D.T.

Publisher: Elsevier, New York, NY, USA

Publication Date: 1988

Country of Publication: USA xv+496 pp.

Conference Date: 18-20 April 1988

Conference Location: Buffalo, NY, USA

Language: English

Document Type: Conference Paper (PA)

Treatment: Applications (A); General, Review (G); Practical (P)

Abstract: The author reviews previous experience in applying superconductors to electric motors and examines the difficulties encountered. While motors and generators have a common basis, several significant differences exist. The application of high temperature superconductors to the major electric motor types is discussed and expected difficulties are presented. The limitations imposed by various motor designs are reflected in a statement of the desired material properties for high temperature superconductor electric motor applications. (23 Refs)

Title: Meissner motor developed using high-T/sub c/ ceramic superconductors

Author(s): Ishikawa, A.; Suzuki, M.; Takeoka, A.

Journal: Sanyo Technical Review vol.20, no.3 p.43-49

Publication Date: Nov. 1988

Country of Publication: Japan

Language: Japanese

Document Type: Journal Paper (JP)

Treatment: Experimental (X)

Abstract: The authors have developed a new superconducting motor, called 'Meissner Motor', which uses high-T/sub c/ ceramic superconductors. The motor axle is driven by utilizing the repelling force which results from the combination of the Meissner effect and the wheel's temperature difference. The repelling force that drives the motor increases as the temperature decreases, or the gradient of the magnetic field increases. Even so, it only reaches about 1.1 gf/g at 77 K in 3500 G/cm. The motor rotates at 40 r.p.m. with a torque below 0.66 gf-cm. (2 Refs)

Title: Fundamental characteristics of a new superconducting motor called the 'Meissner motor'

Author(s): Takeoka, A.; Ishikawa, A.; Suzuki, M.; Kishi, Y.; Kuwano, Y.

Author Affiliation: Functional Mater. Res. Center, Sanyo Electr. Co. Ltd., Osaka, Japan

Journal: Japanese Journal of Applied Physics, Part 1 (Regular Papers & Short Notes) vol.27, no.10 p.1875-80

Publication Date: Oct. 1988

Country of Publication: Japan

Language: English

Document Type: Journal Paper (JP)

Treatment: Applications (A); New Developments (N); Practical (P)

Abstract: The authors developed a brand new superconducting motor using high- T_c ceramic superconductors for the first time. This motor, called the 'Meissner Motor', utilizes the repulsive force caused by the Meissner effect, which appears below T_c and disappears above that. The motor rotated at a maximum speed of 40 r.p.m. Though the repulsive force to drive the motor increased with a decrease in temperature or an increase in the gradient magnetic field, it was only about 1.1 gf/g at 77 K in 3500 G/cm. This motor would have a maximum torque of 5.0 gf-cm theoretically, but actually had a torque of about 0.66 gf-cm, because it took some time to be cooled below T_c . Furthermore, the shortage of heating power was found to limit the rotating speed of the motor.

Title: The potential for high temperature superconducting AC and DC motors

Author(s): Lipo, T.A.

Author Affiliation: Dept. of Electr. Eng., Wisconsin Univ., Madison, WI, USA

Journal: Electric Machines and Power Systems vol.13, no.6 p.373-85

Publication Date: 1987

Country of Publication: USA

U.S. Copyright Clearance Center Code: 0731-356X/87/\$2.25+.00

Language: English

Document Type: Journal Paper (JP)

Treatment: Practical (P)

Abstract: The prospect of using superconductivity (SC) to power electrical machines has been a tantalizing but elusive goal ever since its discovery by Onnes in 1911. However, recent developments which have raised the critical temperature above liquid nitrogen (77 K) has removed the major obstacle to practical application of SC to rotating machinery, namely the liquid helium refrigerant system. The author addresses the potential for utilizing high temperature superconductivity (HTSC) in rotating (as opposed to linear) electrical motors and discusses several approaches to their implementation. Although SC at liquid nitrogen temperature is assumed, the implications of SC at room temperature is not considered. (10 Refs)

Title: Discovery of superconducting material and the future prospect

Author(s): Fueki, Kazuo

Affiliation: The Univ. of Tokyo, Faculty of Engineering, Tokyo, Japan

Source: Enerugi Rebyu (Japan) v 8:1

Publication Date: 20 Dec 1987 p 2-7

Language: Japanese

Abstract: Discovery of high temperature oxide superconducting material above 90K which was achieved in USA in Feb, 1987 rapidly made a break-through for the commercialization of the superconductivity. Features of superconducting materials in the electrical properties are zero-resistance and a permanent current. Magnetically it is a perfect dia-magnetism. For its commercialization, high critical temperature, large critical magnetic field or high critical current density are required. Discovery of high temperature oxide superconducting material has expanded its areas of application far more than before. Promising fields of application are as follows. Utilization of powerful, compact, low power consuming magnet: pollution treatment, nuclear fusion, MHD, power storage, NMR-CT, magnetic levitation train, electromagnetic propelled ship.

etc.. Utilization of low loss: generator, power transmission, motor, etc.. Other applications: ultra high speed computer, Josephson element, gyroscope, brain wave meter, mechanical clutch, magnetic shield room, etc.. (7 figs)

Title: Impact of high T_c oxide superconductors

Author(s): Fueki, Kazuo

Affiliation: The Univ. of Tokyo, Faculty of Engineering, Tokyo, Japan

Source: Kagaku To Kogyo (Tokyo) (Japan) v 40:12

Publication Date: 1 Dec 1987 p 60-63

Language: Japanese

Abstract: Superconductivity has three characteristics: perfect conductivity, perfect diamagnetism, and macro-quantum effect. To produce superconductivity, it is necessary to put the substance under the critical temperature, critical magnetic field, and critical current density. These conditions are related mutually. Since 1911 when superconductivity was first discovered, the best record of the critical temperature was no more than 23K. After the first generation of 40K high T_c oxide superconductors in 1986, 90K superconductors which can be cooled by liquid nitrogen were discovered in 1987. Practical applications of superconductivity lie in large electric power engineering, transportation, and electronics. Applications to large power engineering include accelerators, electric energy storage, large electric generators, among others. Applications to transportation include linear motor cars, electromagnetically propelled ships, among others. Applications to electronics include high-speed computers. The important subject to be solved in 1987 is to find techniques for processing superconducting substances into usable materials. (2 figs, 3 refs)

VIII. ASSESSMENTS BEARING UPON SMES

The following pages provide citations and abstracts for 43 reports, each bearing upon the use of ceramic superconductors in Superconducting Magnetic Energy Storage, SMES. Some reports describe more than one topic; in that case the report is listed in this section and in other appropriate sections. The most recent reports are from 1992 and the earliest is from 1987.

Superconducting Magnetic Energy Storage

Title: Superconducting magnetic energy storage: Technical considerations and relative capital cost using high-temperature superconductors

Author(s)/Editor(s): Loyd, R.J.; Bulc, A.M.; Majumdar, D. (Bechtel National, Inc., San Francisco, CA (United States))

Corporate Source: Electric Power Research Inst., Palo Alto, CA (United States) Bechtel National, Inc., San Francisco, CA (United States)

Sponsoring Organization: EPRI Electric Power Research Inst., Palo Alto, CA (United States)

Publication Date: Apr 1992 (137 p)

Report Number(s): EPRI-TR-100557

Language: In English

Availability: Research Reports Center, PO Box 50490, Palo Alto, CA 94303

Abstract: Superconducting magnetic energy storage plants could significantly benefit from using high-temperature superconductors. Benefits would include greatly lowered operation and maintenance expenses and modestly reduced capital costs. The project team compared present HTSC capabilities to the minimum requirements for SMES superconductors. Next, they projected potential cost reductions, assuming one-for-one replacement of conventional low-temperature superconductors with HTSC at equal installed cost. The estimated capital-cost savings from substituting HTSC for conventional superconductors in large-scale SMES plants ranged from 7% for 5000 MWh to 10% for 20 MWh. In addition, HTSC used in SMES plants would provide six design benefits -- better stability, lower refrigeration needs, lower thermal shielding needs, easier cooldown, no helium use, and possibly no vacuum system. Partially offsetting these is the need for more support structure, caused by the lower strength of materials at 77 K versus 4 K, and loss of the cryopumping ability of 4 K surfaces. To realize these benefits, the HTSC primary SMES coil conductor must be robust enough to be formed into a coil, and it must superconduct in a magnetic field of at least 3 tesla at a current density of at least 12,000 A/cm².

Superconducting Magnetic Energy Storage: Technical Considerations and Relative Capital Cost Using High-Temperature Superconductors

Report Number: EPRI TR-100557 0156P

Contract/Grant No.: RP2988-02

Document Type: Final Report

Publication Year: 1992 04

EPRI Division Name: Generation and Storage

Performing Org.: Bechtel National, Inc.

General Note: EPRI Members Technical reports are available from your company libraries, your manager, EPRI Technology Transfer, or the EPRI Distribution Center, 207 Coggins Drive, P.O. Box 23205, Pleasant Hill, CA 94523, (510) 934-4212. Nonmembers can order this report in print or microfiche from the EPRI Distribution Center, (510) 934-4212. Payment must accompany order. Price: \$200.00 (California residents add sales tax). Nonmember domestic electric utilities, please call (415) 855-2514. Electric Power Research Institute and EPRI are registered service marks of Electric Power Research Institute, Inc. 1992 Electric Power Research Institute, P.O. Box 10412, Palo Alto, CA 94303. All rights reserved. Printed on recycled paper.

Superconducting magnetic energy storage plants could significantly benefit from using high-temperature superconductors. Benefits would include greatly lowered operation and maintenance expenses and modestly reduced capital costs.

BACKGROUND: Large-scale (more than 1000 MWh) superconducting magnetic energy storage (SMES) has the potential to become a widespread method for storing energy. Its attractions include

high (more than 90%) efficiency and instantaneous (half-cycle) response to load. Conventional superconductors require very low operating temperatures of less than about 4 K, obtainable only with helium refrigeration. However, using high-temperature superconductors (HTSC) could raise operating temperature to that of boiling liquid nitrogen (77 K), a much more economical range.

OBJECTIVE: o To evaluate the prospects and potential impacts of HTSC on SMES technology. o To offer design approaches for accommodating HTSC in SMES coils and define threshold technical requirements for such use. o To quantify potential capital-cost reductions that could result from incorporating HTSC in large SMES plants.

APPROACH: The project team compared present HTSC capabilities to the minimum requirements for SMES superconductors. Next, they projected potential cost reductions, assuming one-for-one replacement of conventional low-temperature superconductors with HTSC at equal installed cost.

RESULTS: The estimated capital-cost savings from substituting HTSC for conventional superconductors in large-scale SMES plants ranged from 7% for 5000 MWh to 10% for 20 MWh. In addition, HTSC use in SMES plants would provide six design benefits--better stability, lower refrigeration needs, lower thermal shielding needs, easier cooldown, no helium use, and possibly no vacuum system. Partially offsetting these is the need for more support structure, caused by the lower strength of materials at 77 K versus 4 K, and loss of the cryopumping ability of 4 K surfaces. To realize these benefits, the HTSC primary SMES coil conductor must be robust enough to be formed into a coil, and it must superconduct in a magnetic field of at least 3 tesla at a current density of at least 12,000 A/cm². EPRI PERSPECTIVE: At present, HTSC cannot be economically made into wire for SMES coils to operate at 77 K. Many researchers today strive for that goal (for example, EPRI projects RP3149-1, RP7911-5, and RP7911-13)--and prospects appear good. Still, near-term success is not ensured. Meanwhile, a clearly desirable near-term use exists for HTSC in current leads for the temperature transition between 77 K and 4 K in conventional SMES plants--such as the SMES Engineering Test Model being developed in this project and in RP2988-1. The potential benefits of this application are significant but small compared with those that would result from the availability of useful 77 K HTSC wire. Because they can operate much closer to ambient temperature than conventional SMES plants, HTSC-based plants should be more reliable and simpler to construct and operate. In addition, unlike conventional SMES plants, they will not need to use costly helium for cooling. Nevertheless, these promises should not hinder present-day efforts to develop conventional SMES plants. The two technologies share many engineering challenges that must be overcome before commercial large-scale SMES plants are realized. Therefore, present efforts will benefit the near-term technology while accelerating HTSC SMES availability.

Title: Conceptual design study of superconducting magnetic energy storage using high temperature superconductors

Author(s)/Editor(s): Schoenung, S.M.; Meier, W.R. (Schafer (W.J.) Associates, Inc., Pleasanton, CA (United States)); Fagaly, R.L.; Heiberger, M.; Stephens, R.B.; Leuer, J.A.; Guzman, R.A.; Johnson, E.R. (General Atomics, San Diego, CA (United States)); Purcell, J.; Creedon, L. (Advanced CryoMagnetics, Inc., San Diego, CA (United States)); Hull, J.R. (Argonne National Lab., IL (United States))

Corporate Source: Schafer (W.J.) Associates, Inc., Pleasanton, CA (United States)

Sponsoring Organization: DOE USDOE, Washington, DC (United States)

Publication Date: Feb 1992 (177 p)

Report Number(s): DOE/CE/34019-1

Order Number: DE92007811

Contract Number (DOE): AC02-90CE34019

Language: In English

Availability: OSTI; NTIS; GPO Dep.

Abstract: Since the discovery of high critical temperature superconductors (HTS), many predictions have been made for savings in the cost or performance of superconducting technologies for electric utility systems, such as superconducting magnetic energy storage (SMES). The higher operating temperature of HTS materials could mean the use of less expensive cryogenics, such as liquid nitrogen, higher refrigeration efficiencies, greater reliability, and easier acceptance within the utility community. While all of these developments may occur, the significance of the improvements depends on the application and other characteristics of the system. Also, today's HTS materials have some negative features, including lower critical current density and greater brittleness, compared to conventional metallic superconductors. A conceptual design for SMES using HTS has been analyzed to determine configuration parameters, refrigeration requirements, and estimated costs of major components. The study covered the energy storage range from 2 to 200 MWh at power levels from 4 to 400 MW. This range includes utility applications from transient and power stabilization to spinning reserve and load leveling. The present assessment has been carried out for cold-supported modular torus and for comparison, a cold-supported modular solenoid. The toroidal configuration was chosen for analysis because it has minimal magnetic field, which could be an advantage in locating a small unit near a utility or customer load. The comparison shows that for all cases, the solenoid is comparable in price or less expensive. However, the solenoid has a varying external magnetic field which must be accommodated. The modular approach was selected primarily as a way to wind the coil and keep the brittle oxide superconductor under compression at all operating conditions to avoid breakage.

Title: Superconductive magnetic energy storage (SMES) Electrical and design considerations
Author(s): Boom, R.W.; Eyssa, Y.M. (Wisconsin Univ., Madison, WI (United States). Applied Superconductivity Center)
Title: Environmental issues and waste management in energy and minerals production
Author(s)/Editor(s): Yegulalp, T.M.; Kim, K. (Columbia Univ., New York, NY (United States). Henry Krumb School of Mines)
Conference Title: 1. international conference on environmental issues and waste management in energy and minerals production
Conference Location: Secaucus, NJ (United States)
Conference Date: 27-29 Aug 1990
Publisher: Columbus, OH (United States) Battelle Press
Publication Date: 1992 p 360-372 (602 p)
Report Number(s): CONF-9008109--
Language: In English
Availability: Battelle Press, 505 King Avenue, Columbus, OH 43201 (United States)

Abstract: SMES for electric utilities is potentially the largest application for superconductors in the foreseeable future. Energy storage solenoids with NbTi conductors at 1.8 K are feasible today and, with a decade, high- T_c superconductors storage solenoids could become feasible. Technical feasibility is assessed for NbTi solenoids. Technical feasibility includes: superfluid helium cooled, 200 kA NbTi/Aluminum conductors wound into two or four layer solenoids mounted in surface trenches in the ground and 93% efficient storage for load-leveling electric utility usage. In this paper examples are given for simulated hour by hour utility usage. Some extrapolations are presented for high- T_c solenoids.

Title: Using SMES as a multi-purpose interface in power generation, transmission and distribution systems
Author(s): Tam, K.S.; Zhang, X.; Yarali, A. (Virginia Polytechnic Inst. and State Univ., Blacksburg, VA (United States). Dept. of Electrical Engineering)
Title: Proceedings of the 26th intersociety energy conversion engineering conference

Conference Title: 26. intersociety energy conversion engineering (IECE) conference
Conference Location: Boston, MA (United States)
Conference Date: 3-9 Aug 1991
Publisher: La Grange Park, IL (United States) American Nuclear Society
Publication Date: 1991 p 544-549 (575 p)
Report Number(s): CONF-910801--
Language: In English
Availability: American Nuclear Society, 555 North Kensington Ave., La Grange Park, IL 60525 (United States)

Abstract: This paper presents a new SMES schemes, the MSMES system, which significantly broadens the ways in which SMES can be applied to electric power systems. On the generation side, the SMES system can convert low-quality power into high-quality power and enhances the utilization of all energy sources available to the power systems. Acting both as an energy storage device and a power flow control device, a MSMES system can act as a hub in a power transmission system. The use of multiple MSMES systems can provide many new solutions to the problems facing the transmission networks of the United States today. On the distribution side, MSMES systems can be used as advanced power distribution centers that supply high-quality power to the customers while providing desirable load shapes to the power systems. In addition to these functions, a MSMES unit can also perform functions such as damping of power oscillation, stability and dynamic performance improvement and other recognized benefits of the conventional SMES system. Functioning as a multi-purpose power processing units, the MSMES systems improve the economics of SMES system. Functioning as a multi-purpose power processing units, the MSMES systems improve the economics of SMES technology and expand its potential market.

Title: Small magnetic energy storage systems using high temperature superconductors
Author: Kumar, B.; Gist, T. E.; Fingers, R. T.; Flake, R. A.
Corporate Source: Univ of Dayton Research Inst, Dayton, OH, USA
Conference Title: Proceedings of the 26th Intersociety Energy Conversion Engineering Conference - IECEC '91
Conference Location: Boston, MA, USA
Conference Date: 1991 Aug 4-9
Sponsor: SAE; ANS; AIChE; IEEE; ASME; et al
E.I. Conference No.: 15187
Source: Proceedings of the Intersociety Energy Conversion Engineering Conference v 4
Publ by IEEE, IEEE Service Center, Piscataway, NJ, USA. p 538-543
Publication Year: 1991
Language: English
Document Type: PA; (Conference Paper)
Treatment: X; (Experimental) J
Journal Announcement: 9202

Abstract: Magnetic energy storage for power systems has been considered for commercial utility power, air and ground mobile power sources, and spacecraft applications. Even at the current technology limits of energy storage (100 KJ/Kg), superconducting magnetic energy storage inductors do not offer a strong advantage over state-of-the-art batteries. The commercial utility application does not have a weight and volume limitation, and is under intense study in several countries for diurnal cycle energy storage and high power delivery. The advent of high temperature superconductors has reduced one of the penalties of superconducting magnetic energy storage in that refrigeration and cryocontainers become greatly simplified. Still, structural and current density issues that limit the energy density and size of superconducting inductors do not change. Cold weather starting of aircraft engines is an application where these limitations are not as significant,

and where current systems lack performance. The very cold environments make it difficult to achieve high power densities in state-of-the-art batteries and hydraulically activated starters. The same cold environments make it possible to cool superconducting systems for weeks using a single charge of liquid nitrogen. At the same time, the ground carts can handle the size and weight of superconducting magnetic storage (SMES) devices. (Author abstract) 12 Refs.

Design and fabrication issues for small-scale SMES

Hull, J. R. ; Schoenung, S. M. ; Palmer, D. N. ; Davis, M. K.

Argonne National Lab., IL.

Sponsor: Department of Energy, Washington, DC.

Report No.: ANL/CP-73359; CONF-910635-1

1991 21p

Languages: English

Document Type: Conference proceeding

Journal Announcement: GRAI9122; ERA9148

Cryogenic engineering conference and international cryogenic materials conference, Huntsville, AL (USA), 11-14 Jun 1991

Sponsored by Department of Energy, Washington, DC

Country of Publication: United States

Contract No.: W-31109-ENG-38

Coil-scaling and structural-force calculations for small-scale solenoidal and toroidal superconducting magnetic energy storage (SMES) systems are presented. The efficiency of the refrigeration system is estimated as a function of mechanical support, insulation, and power-lead thermal losses. Required high-temperature superconductor (HTS) properties are compared to properties of presently available materials or those expected to evolve in the near term. Potential applications are described for small-scale SMES, and these applications will significantly increase when HTSs can be used. 28 refs., 6 figs., 1 tab.

Survey of domestic research on superconducting magnetic energy storage

Dresner, L.

Oak Ridge National Lab., TN

Sponsor: Department of Energy, Washington, DC

Report No.: ORNL/HTSPC-1

Sep 91 31p

Languages: English

Journal Announcement: GRAI9211; ERA9222

Sponsored by Department of Energy, Washington, DC

Country of Publication: United States

Contract No.: AC05-84OR21400

This report documents the results of a survey of domestic research on superconducting magnetic energy storage (SMES) undertaken with the support of the Oak Ridge National Laboratory (ORNL) Superconductivity Pilot Center. Each survey entry includes the following: Name, address, and other telephone and facsimile numbers of the principal investigator and other staff members; funding for fiscal year 1991, 1992, 1993; brief descriptions of the program, the technical progress to date, and the expected technical progress; a note on any other collaboration. Included with the survey are recommendations intended to help DOE decide how best to support SMES research and development (R&D). To summarize, I would say that important elements of a well-rounded SMES research program for DOE are as follows. (1) Construction of a large ETM. (2) Development of SMES as an enabling technology for solar and wind generation, especially in conjunction with the ETM program, if possible. (3) Development of small SMES units for electric

networks, for rapid transit, and as noninterruptible power supplies (uses (2), (3), and (4) above). In this connection, lightweight, fiber-reinforced polymer structures, which would be especially advantageous for space and transportation applications, should be developed. (4) Continued study of the potential impacts of high-temperature superconductors on SMES, with construction as soon as feasible of small SMES units using high-temperature superconductors (HTSs).

Title: Applications of superconducting magnetic energy storage in electrical power systems

Author(s): Banerjee, S.; Saha, T.N.

Author Affiliation: Dept. of Electr. Eng., Indian Inst. of Technol., Kharagpur, India

Journal: Bulletin of Materials Science vol.14, no.4 p.1135-40

Publication Date: Aug. 1991

Country of Publication: India

Conference Title: International Conference on Superconductivity

Conference Sponsor: Council Sci. Res.; Dept. Atomic Energy; et al

Conference Date: 10-14 Jan. 1990

Conference Location: Bangalore, India

Language: English

Document Type: Conference Paper (PA); Journal Paper (JP)

Treatment: Applications (A)

Abstract: Fast-acting energy storage devices can effectively damp electromechanical oscillations in a power system, because they provide storage capacity in addition to the kinetic energy of the generator rotor, which can share the sudden changes in power requirement. The authors explore the means of reducing the inductor size for this application so that the use of high-T/sub c/ superconducting materials becomes feasible. (7 Refs)

Title: Superconductor stability '90: a review

Author(s): Dresner, L.

Author Affiliation: Oak Ridge Nat. Lab., TN, USA

Journal: Cryogenics vol.31, no.7 p.489-98

Publication Date: July 1991

Country of Publication: UK

U.S. Copyright Clearance Center Code: 0011-2275/91/070489-10\$3.00

Conference Title: Superconductor Stability Symposium

Conference Date: 13-15 Nov. 1990

Conference Location: Yokohama, Japan

Language: English

Document Type: Conference Paper (PA); Journal Paper (JP)

Treatment: General, Review (G)

Abstract: This paper reviews some recent developments in the field of stability of superconductors. The main topics dealt with are: hydrodynamic phenomena in cable-in-conduit superconductors, namely, multiple stability, quench pressure, thermal expulsion and thermal hydraulic quenchback; traveling normal zones in large, composite conductors, such as those intended for SMES; and the stability of vapour cooled leads made of high temperature superconductors. (31 Refs)

Title: Superconductive magnetic energy storage for electric utilities-a review of the 20 year Wisconsin program

Author(s): Boom, R.W.

Author Affiliation: Appl. Superconductivity Center, Wisconsin Univ., Madison, WI, USA

Conference Title: Proceedings of the 34th International Power Sources Symposium (Cat. No.90CH2863-9) p.1-4
Publisher: IEEE, New York, NY, USA
Publication Date: 1990
Country of Publication: USA 413 pp.
U.S. Copyright Clearance Center Code: 90CH2863-9/90/0000-0001\$01.00
Conference Sponsor: IEEE; U.S. Army Electron. Res. & Dev. Command
Conference Date: 25-28 June 1990
Conference Location: Cherry Hill, NJ, USA
Language: English
Document Type: Conference Paper (PA)
Treatment: General, Review (G)

Abstract: The University of Wisconsin's experience as a superconductivity engineering research center since the invention of the superconducting magnetic energy storage (SMES) system is described. The SMES used today consists of a superconductive storage coil charged and discharged by a Graetz bridge. The topics discussed are the following: the electrical use of SMES; configurations; structure and conductor requirements; the status of present SMES design; rippled design; nonrippled design; conductor stability; SMES coil protection systems; and the use of high-temperature superconductors in SMES systems. (15 Refs)

Title: Applicability of high-T/sub c/ superconductors as opening switch materials for superconducting magnetic energy storage systems
Author(s): Byrne, D.P.; Smith, C.; Iverson, M.; Kwor, R.; Kalkur, T.S.
Author Affiliation: Kaman Sci. Corp., Colorado Springs, CO, USA
Conference Title: Proceedings of the 34th International Power Sources Symposium (Cat. No.90CH2863-9) p.13-16
Publisher: IEEE, New York, NY, USA
Publication Date: 1990
Country of Publication: USA 413 pp.
U.S. Copyright Clearance Center Code: 90CH2863-9/90/0000-0013\$01.00
Conference Sponsor: IEEE; U.S. Army Electron. Res. & Dev. Command
Conference Date: 25-28 June 1990
Conference Location: Cherry Hill, NJ, USA
Language: English
Document Type: Conference Paper (PA)
Treatment: Practical (P); Experimental (X)

Abstract: The authors briefly review past efforts to develop superconducting opening switches, and report on the initial phase of an analytical and experimental program designed to assess the potential of the high-transition temperature (T/sub c/) materials as opening switches. The experimental assessment program, which used BiSrCaCuO films, and the ionized-cluster beam (ICB) film deposition process are outlined. (19 Refs)

Parametric design studies of toroidal magnetic energy storage units
Herring, J. S.
EG and G Idaho, Inc., Idaho Falls
Sponsor: Department of Energy, Washington, DC
Report No.: EGG-M-89521; CONF-900801-15
1990 7p
Languages: English
Document Type: Conference proceeding

Journal Announcement: GRAI9022; ERA9043

Intersociety energy conversion engineering conference (25th), Reno, NV (USA), 12-17 Aug 1990.

Sponsored by Department of Energy, Washington, DC

Portions of this document are illegible in microfiche products

Country of Publication: United States

Contract No.: AC07-76ID01570

Superconducting magnetic energy storage (SMES) units have a number of advantages as storage devices. Electrical current is the input, output and stored medium, allowing for completely solid-state energy conversion. The magnets themselves have no moving parts. The round-trip efficiency is higher than those for batteries, compressed air or pumped hydro. Output power can be very high, allowing complete discharge of the unit within a few seconds. Finally, the unit can be designed for a very large number of cycles, limited basically by fatigue in the structural components. A small systems code has been written to produce and evaluate self-consistent designs for toroidal superconducting energy storage units. The units can use either low temperature or high temperature superconductors. The coils have 'D' shape where the conductor and its stabilizer/structure is loaded only in tension and the centering forces are borne by a bucking cylinder. The coils are convectively cooled from a cryogenic reservoir in the bore of the coils. The coils are suspended in a cylindrical metal shell which protects the magnet during rail, automotive or shipboard use. It is important to note that the storage unit does not rely on its surroundings for structural support, other than normal gravity and inertial loads. This paper presents designs for toroidal energy storage units produced by the systems code. A wide range of several parameters have been considered, resulting in units storing from 1 MJ to 72 GJ. Maximum fields range from 5 T to 20 T. The masses and volumes of the coils, bucking cylinder, coolant, insulation and outer shell are calculated. For unattended use, the allowable operating time using only the boiloff of the cryogenic fluid for refrigeration is calculated. For larger units, the coils have been divided into modules suitable for normal truck or rail transport. 8 refs., 5 tabs.

Title: Application of superconductors in power transmission and storage

Author(s): Raychaudhuri, A.K.

Author Affiliation: Indian Inst. of Sci., Bangalore, India

Journal: Indian Journal of Cryogenics vol.13, spec. issue. p.186-7

Publication Date: 1989

Country of Publication: India

Conference Title: National Workshop on High T/sub c/ Superconductors

Conference Sponsor: Indian Inst. Sci.; Dept. Sci. Technol.; et al

Conference Date: 27-31 March 1988

Conference Location: Bangalore, India

Language: English

Document Type: Conference Paper (PA); Journal Paper (JP)

Treatment: Applications (A); General, Review (G); Practical (P)

Abstract: Discovery of high transition temperature superconductors has created a unique challenge for the electrical power industry. It holds the promise of a new technology which becomes economically viable only in the area of large scale power generation and distribution. The author points out certain areas where large scale application of 'conventional' superconductors (those needing liquid helium) have gone beyond the stage of conceptual design and have entered the domain of prototype design with commercial viability. The large scale application of superconductors in power industry depends on two basic properties: (1) its ability to carry a very high current with no loss or very little loss. (2) its ability to produce medium to high magnetic field. The first property is used in power transmission while the second is used in power generation and storage. (0 Refs)

Title: U.S. program to develop superconducting magnetic energy storage
Author: Schoenung, Susan M.; Hassenzahl, William V.; Filios, Paul G.
Corporate Source: W.J. Schafer Assoc Inc, Pleasanton, CA, USA
Conference Title: Proceedings of the 23rd Intersociety Energy Conversion Engineering Conference
Conference Location: Denver, CO, USA
Conference Date: 1988 Jul 31-Aug 5 E.I
Conference No.: 12772
Source: Proceedings of the Intersociety Energy Conversion Engineering Conference v 2 (of 4)
Publ by IEEE, IEEE Service Center, Piscataway, NJ, USA. p 537-540
Publication Year: 1989
Language: English
Document Type: PA; (Conference Paper)
Treatment: A; (Applications)
Journal Announcement: 9002

Abstract: The US program to develop superconducting magnetic energy storage (SMES) is designed to answer questions of technical and economic viability by the mid-1990s, thereby paving the way to commercialization. The authors present a brief description of SMES technology and a review of the programmatic aspects of the ongoing program, including Electric Power Research Institute and US Department of Defense objectives, critical issues, and program milestones. The potential impact of high-temperature superconductors on SMES is discussed. 21 Refs.

Title: Superconductive magnetic energy storage (SMES) for electric utilities
Author(s): Pfotenhauer, J.M.; Boom, R.W.
Author Affiliation: Appl. Superconductivity Center, Wisconsin Univ., Madison, WI, USA
Conference Title: Advances in Superconductivity. Proceedings of the 1st International Symposium on Superconductivity p.33-8
Editor(s): Kitazawa, K.; Ishiguro, T.
Publisher: Springer-Verlag, Tokyo, Japan
Publication Date: 1989
Country of Publication: Japan xxiii+920 pp.
Conference Sponsor: Int. Superconductivity Technol. Center
Conference Date: 29-31 Aug. 1988
Conference Location: Nagoya, Japan
Language: English
Document Type: Conference Paper (PA)
Treatment: Applications (A); General, Review (G)

Abstract: SMES system designs, component developments, and utility usage studies at Wisconsin are reviewed. The SMES design criteria for superfluid helium cooled NbTi solenoids is outlined and compared to the probable design criteria for the future potential use of high T/sub c/ ceramic conductor solenoids cooled by liquid nitrogen. (16 Refs)

Title: Conceptual design studies of 5 GWh superconducting magnetic energy storage system
Author(s): Maekawa, T.; Kuwahara, H.; Fukatsu, T.; Kase, K.; Iwamoto, M.; Yamada, T.; Ogino, O.
Author Affiliation: Tokyo Electr. Power Co. Inc., Japan
Conference Title: International Symposium on New Developments in Applied Superconductivity p.598-603
Editor(s): Murakami, Y.
Publisher: World Scientific, Singapore
Publication Date: 1989

Country of Publication: Singapore xix+808 pp.
Conference Date: 17-19 Oct. 1988
Conference Location: Osaka, Japan
Language: English
Document Type: Conference Paper (PA)
Treatment: Practical (P)

Abstract: On the assumption that high T_c superconductors will be realized, the conceptual design studies of a 5 GWh superconducting magnetic energy storage system were made for the following four levels of superconducting temperature to survey the future feasibility; liquid helium temperature, liquid hydrogen temperature, liquid nitrogen temperature, and room temperature. (4 Refs)

Title: Design study of large scale SMES
Author(s): Shintomi, T.
Author Affiliation: Nat. Lab. for High Energy Phys., Ibaraki, Japan
Conference Title: International Symposium on New Developments in Applied Superconductivity p.592-7
Editor(s): Murakami, Y.
Publisher: World Scientific, Singapore
Publication Date: 1989
Country of Publication: Singapore xix+808 pp.
Conference Date: 17-19 Oct. 1988
Conference Location: Osaka, Japan
Language: English
Document Type: Conference Paper (PA)
Treatment: Practical (P)

Abstract: The appropriate size of commercial SMES is estimated as 5 GWh in capacity and 1 GW in output power from the electricity demand in the year 2000. The diameter of a superconducting coil in this scale is 400-1500 m depending on designs. By the optimization of the coil configuration and taking Japanese situations into consideration, a compact coil configuration whose diameter is 500 m is selected using Nb₃Sn. The cost is also estimated and expected to be economical by comparison of the break even capital cost of a 5 GWh SMES unit. The possibility of application of high T_c materials has been also considered. (5 Refs)

Title: Superconductivity in power engineering. Status, concepts, new aspects
Original Title: Supraleitung in der Energietechnik. Stand, Konzepte, neue Aspekte
Original Series Title: VDI-Berichte
Corporate Source: Verein Deutscher Ingenieure (VDI) - Gesellschaft Energietechnik, Duesseldorf (Germany, F.R.)
Conference Title: Technical meeting on superconductivity in power engineering: Status, concepts, new aspects, with exhibition
Original Conference Title: Fachtagung Supraleitung in der Energietechnik: Stand, Konzepte, Neue Aspekte und Ausstellung
Conference Location: Karlsruhe (Germany, F.R.)
Conference Date: 14-15 Jun 1989
Publisher: Duesseldorf (Germany, F.R.) VDI-Verl.
v no. 733
Publication Date: 1989 (442 p)
Report Number(s): CONF-8906339--
Language: In German

Abstract: This proceedings volume presents 24 conference papers and 15 posters dealing with the following aspects: (1) Principles and elementary aspects of high-temperature superconductivity (3 plenary lectures); (2) Preparation, properties and materials requirements of metallic or oxide superconductors (critical current behaviour, soldered joints, structural studies); (3) Magnet technology (large magnets for thermonuclear fusion devices; magnets for particle accelerators and medical devices); (4) Magnetic levitation and superconductivity; (5) Cryogenics; (6) Energy storage systems using superconducting coils (SMES); (7) Superconducting power transmission cables, switches, transformers, and generator systems for power plant; (8) Supporting activities, industrial aspects, patents. There are thirty-eight records in the ENERGY database relating to individual conference papers. (MM).

Title: Development of superconducting generators for power plant

Original Title: Entwicklung supraleitender Kraftwerksgeneratoren

Author(s): Intichar, L.; Lambrecht, D.

Title: Superconductivity in power engineering. Status, concepts, new aspects

Original Title: Supraleitung in der Energietechnik. Stand, Konzepte, neue Aspekte

Original Series Title: VDI-Berichte

Corporate Source: Verein Deutscher Ingenieure (VDI) - Gesellschaft Energietechnik, Duesseldorf (Germany, F.R.)

Conference Title: Technical meeting on superconductivity in power engineering: Status, concepts, new aspects, with exhibition

Original Conference Title: Fachtagung Supraleitung in der Energietechnik: Stand, Konzepte, Neue Aspekte und Ausstellung

Conference Location: Karlsruhe (Germany, F.R.)

Conference Date: 14-15 Jun 1989

Publisher: Duesseldorf (Germany, F.R.) VDI-Verl.

v no. 733

Publication Date: 1989 p 121-135 (442 p)

Report Number(s): CONF-8906339--

Language: In German

Abstract: Turbogenerators with a superconducting magnetic field already at today's level of technical development represent for large-system applications an interesting alternative to conventional generators. An experimental system is being installed within the framework of a development programme. The superconductors intended for use in generators will have to satisfy special requirements, and the same applies to the novel high-Tc superconductors. If the ongoing development work will have achieved the technical maturity, also smaller size superconducting turbogenerator systems will be of interest from an economic point of view. (orig.).

Title: Possible effects of high-temperature superconductivity on inductive energy accumulators

Original Title: Moegliche Auswirkungen der Hochtemperatursupraleitung auf induktive Energiespeicher

Author(s): Vollmar, H.E.; Altpeter, R. (Siemens AG, Erlangen (Germany, F.R.))

Title: Magnetic materials, varistors and superconductors: Applications and development trends. Proceedings

Original Title: Magnetische Werkstoffe, Varistoren und Supraleiter: Anwendungen und Entwicklungstendenzen. Vortraege

Original Series Title: ETG-Fachbericht

Corporate Source: Energietechnische Gesellschaft im VDE, Frankfurt am Main (Germany, F.R.)

Conference Title: ETC technical meeting on magnetic materials, varistors and superconductors: applications and development trends

Original Conference Title: ETG-Fachtagung ueber Magnetische Werkstoffe, Varistoren und Supraleiter: Anwendungen und Entwicklungstendenzen
 Conference Location: Baden-Baden (Germany, F.R.)
 Conference Date: 27-28 Sep 1989
 Publisher: Berlin (Germany, F.R.) VDE-Verl.
 v no. 29
 Publication Date: 1989 p 167-171 (171 p)
 Report Number(s): CONF-8909323--
 Language: In German

Abstract: The introduction of nitrogen cooling which is economical for high-temperature superconductors is nearly cost-neutral for large-capacity stores which are drafted for smoothing the daily load curves in the GWh range with an energy efficiency of up to 95%. The advantages of nitrogen cooling for which the cost advantage of the overall system amounts to 8% according to calculations are compensated by the increased demand for a mechanical and electric stabilization of the superconductors. The increase of efficiency by 2%, shorter cooling-off periods and the possibility of realizing week-supply stores with an efficiency of more than 90% constitute the lasting advantages of nitrogen cooling. Presently available current density measurements carried out on thin films show that high-temperature superconductors are of interest for inductive energy stores both at 77 K and 4.2 K. If the current densities measured at 4.2 K can also be realized in technical conductors at comparable costs, the cost advantages of the superconductor of a large-capacity stores amount to more than the factor 10 and those of the overall system to more than 10%. (orig./MM).

Title: Conceptual designs of large superconducting magnetic energy storage systems
 Original Title: Konzepte fuer magnetische Grossspeicher
 Author(s): Vollmar, H.E.; Altpeter, R.
 Title: Superconductivity in power engineering. Status, concepts, new aspects
 Original Title: Supraleitung in der Energietechnik. Stand, Konzepte, neue Aspekte
 Original Series Title: VDI-Berichte
 Corporate Source: Verein Deutscher Ingenieure (VDI) - Gesellschaft Energietechnik, Duesseldorf (Germany, F.R.)
 Conference Title: Technical meeting on superconductivity in power engineering: Status, concepts, new aspects, with exhibition
 Original Conference Title: Fachtagung Supraleitung in der Energietechnik: Stand, Konzepte, Neue Aspekte und Ausstellung
 Conference Location: Karlsruhe (Germany, F.R.)
 Conference Date: 14-15 Jun 1989
 Publisher: Duesseldorf (Germany, F.R.) VDI-Verl.
 v no. 733
 Publication Date: 1989 p 173-187 (442 p)
 Report Number(s): CONF-8906339--
 Language: In German

Abstract: There are conceptual designs of inductive, large magnetic energy storage systems intended for use as a day storage device for load management, offering stored energy in the GWh range, with an efficiency of 90%. The USA developed the trench design, and Japan the tunnel design, and both concepts use solid bedrock as the supporting material. The candidate superconductor materials are NbTi or Nb₃Sn. In case of the trench design, the overground magnetic stray fields are spreading wider than in case of the other design, and are practically unshieldable. Reducing the thermal losses would mean that high-T_c superconductors would permit even higher efficiencies, which would allow smaller devices, and week storage devices. (orig.).

Title: Superconductive energy storage (SMES) for electric utility use
 Author(s): Boom, R.W.; Abdelsalam, M.K.; Eyssa, Y.M.; Huang, X.
 Author Affiliation: Wisconsin Univ., Madison, WI, USA
 Conference Title: Proceedings of the Taiwan International Symposium on Superconductivity. Superconductivity and Applications p.173-87
 Editor(s): Wu, P.T.; Ku, H.C.; Lee, W.H.; Liu, R.S.
 Publisher: World Scientific, Singapore
 Publication Date: 1989
 Country of Publication: Singapore xii+460 pp.
 Conference Sponsor: Minist. Econ. Affairs. China; Acad. Sinica; Nat. Sci. Council; Chinese Soc. Mater. Sci.; et al
 Conference Date: 17-19 April 1989
 Conference Location: Hsinchu, Taiwan
 Language: English
 Document Type: Conference Paper (PA)
 Treatment: Applications (A); Practical (P)

Abstract: SMES for electric utilities is potentially the largest application for superconductors in the foreseeable future. Energy storage solenoids with NbTi conductors at 1.8 K are feasible today and, within a decade, high-T/sub c/ superconductor storage solenoids could become feasible. Technical feasibility is assessed for NbTi solenoids. Technical feasibility covers: superfluid helium cooled, 200 ka NbTi/Aluminum conductors wound into one or two layer solenoids mounted in surface trenches in the ground and covers electric utility uses: such as 95% efficient storage for load-leveling. Examples are given for simulated hour by hour utility usage. Some extrapolations are presented for High-T/sub c/ solenoids. (7 Refs)

Title: Downsized superconducting magnetic energy storage systems
 Author(s): Palmer, D.N.
 Author Affiliation: Combustion Eng. Inc., Windsor, CT, USA
 Conference Title: Proceedings of the 24th Intersociety Energy Conversion Engineering Conference IECEC-89 (Cat. No.89CH2781-3) p.453-8 vol.1
 Publisher: IEEE, New York, NY, USA
 Publication Date: 1989
 Country of Publication: USA 6 vol. 2999 pp.
 U.S. Copyright Clearance Center Code: CH2781-3/89/0000-0453\$01.00
 Conference Sponsor: IEEE; AIChE; ANSD; SAE; AIAA; ASME
 Conference Date: 6-11 Aug. 1989
 Conference Location: Washington, DC, USA
 Language: English
 Document Type: Conference Paper (PA)
 Treatment: Applications (A); Bibliography (B); Practical (P)

Abstract: Scaled-down superconductive magnetic energy storage systems (DSMES) and superconductive magnetic energy power sources (SMEPS) are proposed for residential, commercial/retail, industrial off-peak and critical services, telephone and other communication systems, computer operations, power back-up/energy stores, power sources for space stations, and in-field military logistics/communication systems. Advances in high-T/sub c/ superconducting materials technology are analyzed. DSMES/SMEPS concepts are presented, and design, materials, and systems requirements are discussed. Problems are identified, and possible solutions are offered. Comparisons are made with mechanical and primary and secondary energy storage and conversion systems. (53 Refs)

Title: Survey and study of superconducting magnetic energy storage system (Part 2)
 Author(s): Shimizu, Masayuki (Kansai Electric Power Co. Inc., Osaka (Japan))
 Source: Soken Hokoku (Japan) v 42
 Publication Date: 25 Mar 1989 p 108-129
 Language: In Japanese

Abstract: With regard to superconducting magnetic energy storage (SMES), technical trend and adaptability, etc. were surveyed and examined in FY 1987 as continuation of the same in FY 1986 and the basic design of a 100kWh class toroidal SMES, the conceptual design of SMES's of medium and small capacity to which a high temperature superconductor was applied and a study on operation and control of SMES were carried out. This article is a report of its essentials. Those which are to be solved as the elemental technical issues of a large capacity SMES are studies respectively concerning optimization of the superconducting coil structure, thermal stabilization, strength property of component materials and junctions, and permanent current switch and current lead. For the development of a large capacity SMES, construction of a 100kWh class experimental device, a prototype plant, a demonstration plant and a commercial plant (1-5GWh) is necessary following in the above order. Concerning middle and small capacity SMES's, those for household (3.75kWh) and those for distributing substations (35MWh) are under study. The above survey and study revealed the features, etc. of SMES. 2 refs., 38 figs., 16 tabs.

Title: Superconducting magnetic energy storage
 Author(s): Hassenzahl, W.
 Author Affiliation: Lawrence Berkeley Lab., California Univ., Berkeley, CA, USA
 Journal: IEEE Transactions on Magnetics vol.25, no.2 p.750-8
 Publication Date: March 1989
 Country of Publication: USA
 U.S. Copyright Clearance Center Code: 0018-9464/89/0300-0750\$01.00
 Conference Title: 1988 Applied Superconductivity Conference
 Conference Sponsor: IEEE
 Conference Date: 21-25 Aug. 1988
 Conference Location: San Francisco, CA, USA
 Language: English
 Document Type: Conference Paper (PA); Journal Paper (JP)
 Treatment: General, Review (G); Experimental (X)

Abstract: The author presents the rationale for energy storage on utility systems, describes the general technology of SMES (superconducting magnetic energy storage), and explains the chronological development of technology. The present ETM (Engineering Test Model) program is outlined. The impact of high-T/sub c/ materials on SMES is discussed. It is concluded that SMES is marginally competitive with other storage technologies and is likely to remain so. (69 Refs)

Title: Economic potential of applying HiT/sub c/ superconductors to magnetic energy storage
 Author(s): Eriksson, J.-T.; Korpijarvi, J.
 Author Affiliation: Lab. of Electr. & Magnetism, Tampere Univ. of Technol., Finland
 Journal: IEEE Transactions on Magnetics vol.25, no.2 p.1807-10
 Publication Date: March 1989
 Country of Publication: USA
 U.S. Copyright Clearance Center Code: 0018-9464/89/0300-1807\$01.00
 Conference Title: 1988 Applied Superconductivity Conference
 Conference Sponsor: IEEE
 Conference Date: 21-25 Aug. 1988
 Conference Location: San Francisco, CA, USA

Language: English

Document Type: Conference Paper (PA); Journal Paper (JP)

Treatment: Economic aspects (E); Experimental (X)

Abstract: The authors verify the technical and economic specifications of SMES (superconducting magnetic energy storage) units of arbitrary sizes, i.e. to provide models for further, energy-management-related simulations. The weekly energy efficiency is based on a five/seven days discharge duty cycle (51 out of 52 weeks a year). The efficiency includes thermal heat leak through walls and reinforcement, current lead losses, power equipment losses, and nitrogen production losses. Superconductor AC losses and losses due to eddy currents in massive aluminum parts are the only major sources that the authors have not tried to estimate so far. The cost distribution of the 500-MWh facility is presented. (8 Refs)

Title: Economic potential of applying HiTc superconductors to magnetic energy storage

Author(s): Eriksson, J.T.; Korpijarvi, J.

Affiliation: 6064320

Conference Title: Applied superconductivity conference

Conference Location: San Francisco, CA, USA

Conference Date: 21-25 Aug 1988

Source: IEEE Trans. Magn. (United States) v 25:2

Publication Date: Mar 1989 p 1807-1810

Report Number(s): CONF-880812-

Language: English

Abstract: Energy management has become a major part of electrical power engineering. However, current tariff policies aim at forcing the industrial consumers to continuously consider their grid loading. Load leveling based on energy storage offers peak energy to a price competitive with other peak shaving systems. Superconducting magnetic energy storage (SMES) combines excellent efficiency with an acceptable cost level. The impact of high temperature superconductors is a notable decrease in running costs due to cheaper coolant and lower service requirements.

Title: High- Tc superconductors in electric power applications

Author(s): Steennis, E.F.

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 189-219 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: This report describes the possible implications of the discovery of High-Temperature Superconductors in the Electric Power sector in The Netherlands. In particular the material $\text{YBa}_{2}\text{Cu}_{3}\text{O}_{7}$ is discussed. Assuming High-Tc superconducting wires and tapes become available for a reasonable price, the main consequences are as follows. (1) High-Tc superconductors may lead to important possibilities for transformers, generators, motors and magnets for separation. On the long term these superconductors may positively influence the development of MHD generators and fusion reactors. (2) The application of magnetic shielding is obvious. (3) In The Netherlands a large scale application like SMES or a MAGLEV-train is not attractive. Moreover there is no need for power regulation and stabilization. (4) High-Tc

superconducting cables are not interesting from an economic point of view. (5) High-Tc superconducting overhead lines will not be accepted for practical reasons. (6) The introduction of rather specific components like current-limiters and switches can improve the dimensioning of the power transmission network. For instance it will lower the level of the short circuit current in a high extent. Such components are therefore very attractive but the technological and economical prospectives can hardly be given now. (7) High-Tc superconducting fuses for power applications are not attractive for practical reasons. (8) Test facilities, based on High-Tc superconductors, like impuls-current generators and compensation coils for cable testing, are very attractive. Here the application of a High-Tc superconductor offers new possibilities.

Title: IEA expert meeting: Assessment of superconductivity in the power sector

Author(s): Meyer, L.A.

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 183-188 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: In March 1988 the Government established a national research program on warm superconductors. The main items of the research program are: theory; new materials with higher TC; technology and classification; physics of superconducting phenomena and electronic structure, and investigation of applications. The implementation of item 5 will be divided into two categories: energy and magnet-related applications; and microelectronic applications and sensors. The general objective is to obtain an overview of the advantages of the use of nitrogen-cooled superconductors compared with other technologies in the categories mentioned above. The possible opportunities for Dutch industry will also be assessed. It is assumed that it will become possible to produce reliable layers, tapes, wires and coils on an industrial scale. Subjects that will be included in the studies relating to power and environmental applications are: transformers, generators, motors; magnetic shielding; superconducting magnet energy storage for peak-shaving (S' ES); high-gradient magnetic separation for water purification (HGMS).

Title: High T sub c materials in the electric network Why or why not

Author(s): Klein, K.W. (Office of Energy Storage and Distribution, US DOE, Washington, DC (US))

Title: Energy technology XV

Conference Title: 15. annual energy technology conference and exposition

Conference Location: Washington, DC (United States)

Conference Date: 17-19 Feb 1988

Publisher: Rockville, MD (USA) Government Institutes Inc.

Publication Date: 1988 p 844-852 (960 p)

Report Number(s): CONF-880212--

Language: In English

Availability: Government Institutes Inc., 966 Hungerford Dr. No. 24, Rockville, MD 20850 (USA)

Abstract: This paper reports on the new high temperature superconducting ceramics could revolutionize the design of some electrical power systems if major obstacles are cleared. The obstacles include improving the critical current density with applied magnetic fields, improving

mechanical properties and chemical stability. For over a decade, the Office of Energy Storage and Distribution (OESD) has supported three applications of superconducting materials: superconducting generator; superconducting transmission cable; and superconducting magnetic energy storage (SMES). The future prospects for these and other power system applications depend, first and foremost, on the material properties of the superconductor. For most power applications, the critical current density is the crucial property. An understanding of the properties of the high temperature materials will suggest which applications may be the easiest to realize and which may have the greatest potential. This desired understanding can help formulate research goals and priorities.

Title: Economic potential of applying high critical temperature superconductors to magnetic energy storage

Author(s): Eriksson, J.; Korpijaervi, J. (Tampere Univ. of Technology (Finland))

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 280-283 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: Energy management has become a major part of electrical power engineering. However, current tariff policies aim at forcing the industrial consumers to continuously consider their grid loading. Load leveling based on energy storage offers peak energy to a price competitive with other peak shaving systems. Superconducting magnetic energy storage (SMES) combines excellent efficiency with an acceptable cost level. The impact of high temperature superconductors is a notable decrease in running costs due to cheaper coolant and lower service requirements. One objective of our current activities is to establish a scheme of evaluating the capitalized energy price of a storage system of given capacity. The first results of the general estimation software are presented in this paper. This tool offers a possibility to take forth the primary parameters of SMES plants of arbitrary sizes. So far the input cost parameters are approximative and they will be adjusted continuously to more accurate figures.

Title: Superconductor projects with power utilities in Denmark

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 26-30 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: The Danish Power Utilities ELSAM and ELKRAFT support two projects on superconducting cables using high T_c ceramic materials. The aim is to develop and test bulk cables and thin film for high current purpose. The methods considered are: drawing in silvertubes, extrusion process of cables, silver superconducting alloy, melt spinning, oxidation of treads of metal alloy, coating of ceramic treads and sputtering on continuous tape. Both projects are

described. It is anticipated that the two projects will be followed by additional projects in which the high $\{T_c\}$ superconducting cables can be tested by using them in components such as a transmission cable, a fault current limiter, or a Superconducting Magnetic Energy Storage System.

Title: Survey of superconductors for energy applications
Original Title: Suprajohteiden energiasovellusten kartoitus Esitutkimus
Author(s)/Editor(s): Eriksson, S.T. (Tampereen Teknillinen Korkeakoulu, Tampere (Finland).
Teoreettisen saehkoetekniikan laitos)
Corporate Source: Helsinki Univ. of Technology, Espoo (Finland)
Publication Date: 1988 (47 p)
Report Number(s): NEMO-3
Order Number: DE90796181
Note: NEMO-Research Programme
Language: In Finnish
Availability: NTIS (US Sales Only),

Abstract: This report describes shortly the present level of superconductor technology and its applications in the field of energy technology. Superconducting magnetic energy storage is examined greater in detail.

Title: The potential impact of development high T_c superconductors on superconductive magnetic energy storage (SMES)
Author(s): Eyssa, Y.M.; Abdelsalam, M.K.; Boom, R.W.; McIntosh, G.E.
Author Affiliation: Wisconsin-Madison Univ., WI, USA
Conference Title: Advances in Cryogenic Engineering. Vol.33. Proceedings of the 1987 Cryogenic Engineering Conference p.69-76
Editor(s): Fast, R.W.
Publisher: Plenum, New York, NY, USA
Publication Date: 1988
Country of Publication: USA xxi+1178 pp.
Conference Sponsor: Air Products & Chem.; Alabama Cryogenic Eng.; Astronautics Corp. America; et al
Conference Date: 14-18 June 1987
Conference Location: St. Charles, IL, USA
Language: English
Document Type: Conference Paper (PA)
Treatment: Economic aspects (E); General, Review (G); Practical (P)

Abstract: The discovery of superconductivity with $T_c > 77$ K (liquid nitrogen boiling temperature) is potentially of great importance for large scale electric utility applications such as the transmission and storage of electrical energy. Superconducting magnetic energy storage (SMES) is already a promising technology for electric utility load leveling. Therefore, it is useful to assess SMES with oxide superconductors cooled by inexpensive and plentiful liquid nitrogen (LN_2) instead of NbTi cooled by the more expensive liquid helium. Liquid nitrogen cooling will significantly reduce the refrigeration energy requirements, and, especially, would help make small size SMES units more economic. The paper presents the impact of LN_2 on efficiency, design and economics of SMES. (13 Refs)

Title: US program to develop superconducting magnetic energy storage
Author(s): Schoenung, S.M.; Hassenzahl, W.V.; Filios, P.G.
Author Affiliation: W.J. Schafer Assoc. Inc., Pleasanton, CA, USA
VIII-19

Conference Title: Proceedings of the 23rd Intersociety Energy Conversion Engineering Conference
p.537-40 vol.2

Editor(s): Goswami, D.Y.

Publisher: ASME, New York, NY, USA

Publication Date: 1988

Country of Publication: USA 4 vol. (xvii+619+xvi+551+xviii+797+xv+493+113) pp.

Conference Sponsor: IEEE; ASME; AIChE; ANS; SAE; ACS; AIAA

Conference Date: 31 July-5 Aug. 1988

Conference Location: Denver, CO, USA

Language: English

Document Type: Conference Paper (PA)

Treatment: Practical (P)

Abstract: The US program to develop superconducting magnetic energy storage (SMES) is designed to answer questions of technical and economic viability by the mid-1990s, thereby paving the way to commercialization. The authors present a brief description of SMES technology and a review of the programmatic aspects of the ongoing program, including Electric Power Research Institute and US Department of Defense objectives, critical issues, and program milestones. The potential impact of high-temperature superconductors on SMES is discussed. (21 Refs)

Title: Japanese activities on energy storage by superconductivities (SMES)

Author(s): Masuda, M.; Shintomi, T.

Author Affiliation: Res. Association of SMES, Tsukuba, Japan

Conference Title: Superconductivity and Its Applications. Proceedings of the Second Annual Conference on Superconductivity and Applications p. 439-49

Editor(s): Kok, H.S.; Shaw, D.T.

Publisher: Elsevier, New York, NY, USA

Publication Date: 1988

Country of Publication: USA xv+496 pp.

Conference Date: 18-20 April 1988

Conference Location: Buffalo, NY, USA

Language: English

Document Type: Conference Paper (PA)

Treatment: Practical (P)

Abstract: The Japanese Research Association of SMES has undertaken 5 activities. They have almost finished the conceptual design and economic evaluation of 5 GWh SMES. They are proposing a 50 MJ testing plant to the government. The unfinished activities are the design of the 20 to the MWh, the feasibility check of high T_c SMES and the safety analysis. (7 Refs)

Title: Superconductive magnetic energy storage (SMES) system studies for electrical utility usage at Wisconsin

Author(s): Boom, R.W.; Eyssa, Y.M.; Abdelsalam, M.K.; Huang, X.

Author Affiliation: Appl. Supercond. Center, Wisconsin Univ., Madison, WI, USA

Conference Title: Superconductivity and Its Applications. Proceedings of the Second Annual Conference on Superconductivity and Applications p. 417-31

Editor(s): Kwok, H.S.; Shaw, D.T.

Publisher: Elsevier, New York, NY, USA

Publication Date: 1988

Country of Publication: USA xv+496 pp.

Conference Date: 18-20 April 1988

Conference Location: Buffalo, NY, USA

Language: English
Document Type: Conference Paper (PA)
Treatment: Practical(P)

Abstract: Two-layer low aspect ratio solenoids mounted in surface trenches are described for superconductive magnetic energy storage utility applications. Both rippled and nonrippled designs are included in the technical and cost estimation discussions. Open pool cooling in superfluid helium provides extended time cryogenic stability; axial structure also functions as a protective heat absorbing secondary during emergency discharge; structural properties of the rippled and nonrippled designs are emphasized; and problem areas are listed. The potential impact of high T_c oxide superconductors is a 10%-20% cost reduction for large SMES units (above 3000 MWh). The operational storage efficiency of smaller units would improve to better than 95% for $E > 10$ MWh. (17 Refs)

Title: Application of superconductivity to electric power technology

Author(s): Tanaka, Toshikatsu

Affiliation: Central Research Inst. of Electric Power Industry, Tokyo, Japan

Source: Nippon Kikai Gakkaishi (Japan) v 91:835.

Publication Date: 5 Jun 1988 p 46-50

Language: Japanese

Abstract: Application of the superconductivity to the electric power technology is described. Whereas the cooling efficiency of liquid He is lower than 0.2%, that of liquid nitrogen is 10%, or more than 50 times larger than liquid He. As the evaporation potential heat is 63 times, the thermal conductivity is 7.2 times larger, the insulation breakdown strength is high and the price is one-fiftieth lower, reducing the economic scale greatly. The capacity of superconducting generators that are competitive with conventional machines are 1000 MVA with the liquid He and 500 MVA when the superconductivity at high temperature is possible with the liquid nitrogen. For the transformers, the AC wire of high temperature superconducting material is required but the research on it is not yet started. While the loss of superconducting power cable is low and it is suitable for large capacity DC power transmission, it is advantageous even with 2 million KVA if the liquid nitrogen cooling is possible. The superconducting magnetic energy storage (SMES) is useful in the system power pooling and storage, and it is competitive with the pumped storage power generation at 4 million KWh with He and 1 million KWh is allowable if the liquid nitrogen can be used. The impact of high temperature superconducting material to the power technology is high and the superconducting cable and SMES are promising. (3 figs, 3 tabs, 3 refs)

Title: Force-free coil principles applied to high-temperature superconducting materials

Author(s): Furth, H.P.; Jardin, S.C.; Montgomery, D.B.

Author Affiliation: Princeton Plasma Phys. Lab., Princeton Univ., NJ, USA

Journal: IEEE Transactions on Magnetics vol.24, no.2, pt.1 p.1467-8

Publication Date: March 1988

Country of Publication: USA

U.S. Copyright Clearance Center Code: 0018-9464/88/0300-1467\$01.00

Conference Title: Tenth International Conference on Magnet Technology (MT-10)

Conference Sponsor: MIT; DOE; NSF; Lawrence Livermore Nat. Lab.; Oak Ridge Nat. Lab.; et al

Conference Date: 21-25 Sept. 1987

Conference Location: Boston, MA, USA

Language: English

Document Type: Conference Paper (PA); Journal Paper (JP)

Treatment: Theoretical (T)

Abstract: A brief outline is given of force-free magnetic-field configurations, in which the current flows parallel to the magnetic field vector, that have the potential to raise the critical magnetic field and current-density limits. The advantages of force-free cables and coils are enumerated. The resulting improved levels of critical current density are noted. The authors describe the parameters governing cable and coil designs giving large values of central magnetic-field strengths, relative to a supporting coil, to produce maximum magnetic-field strengths in small experimental volumes. (10 Refs)

Title: Design study of SMES system using high temperature superconductors

Author(s): Yoshihara, T.; Masuda, M.; Shintomi, T.; Hasegawa, J.

Author Affiliation: Kawasaki Heavy Ind. Ltd., Tokyo, Japan

Journal: IEEE Transactions on Magnetics vol.24, no.2, pt.1 p.891-4

Publication Date: March 1988

Country of Publication: USA

U.S. Copyright Clearance Center Code: 0018-9464/88/0300-0891\$01.00

Conference Title: Tenth International Conference on Magnet Technology (MT-10)

Conference Sponsor: MIT; DOE; NSF; Lawrence Livermore Nat. Lab.; Oak Ridge Nat. Lab.; et al

Conference Date: 21-25 Sept. 1987

Conference Location: Boston, MA, USA

Language: English

Document Type: Conference Paper (PA); Journal Paper (JP)

Treatment: Practical (P)

Abstract: Some design possibilities for high-T/sub c/ superconducting magnetic energy storage systems are proposed. Conventional SMES systems are reviewed and considerations for achieving high-T/sub c/ performance are discussed. A significant difference from conventional SMES is the use of liquid-nitrogen cooling systems which in turn influences the design with respect to cryogenic stability, support for the axial magnetic force, thermal insulation and the specifics of the refrigeration system. (1 Refs)

Title: Energy storage by superconducting coil

Author(s): Masuda, asami

Affiliation: National Lab. for High Energy Physics, Tsukuba, Japan

Source: Enerugi, Shigen (Japan) v 9:1

Publication Date: 5 Jan 1988 p 23-28

Language: Japanese

Abstract: Topics on the development of superconducting magnetic energy storage (SMES), application of ceramic high temperature superconducting materials, and the situation of the world are reported. The application of superconduction can be grouped into two categories, i.e. improvement of electrical equipment and materialization of matters which are impossible with the conventional technologies. The latter include nuclear fusion, MHD, Josephson element, etc., and SMES is the typical example. Factors which prevent the application is its poor economy if used for the same purposes as those for the conventional storage devices. Larger scale SMES has a problem of confining the electromagnetic force generated by the large scale superconductive coils. The cost of the materials for the structure alone will not economically pay, and plans were made to build them in subsurface rocks. SMES which can well meet the problem of momentary power failure is effective for use in intelligent buildings. SMES may be the only one available for such storage equipment as used in SDI which needs to release all the stored power in a short period time. Present situations in Japan and U.S. were introduced. (5 figs, 1 tab, 6 refs)

Title: Application of high temperature superconducting materials
Author(s): Tanaka, Toshikatsu
Affiliation: Central Research Inst. of Electric Power Industry, Tokyo, Japan
Source: Kagaku Kogaku (Japan) v 51:11
Publication Date: 5 Nov 1987 p 35-39
Language: Japanese

Abstract: As for superconducting materials, there are still many problems such as their natures, etc. to be clarified. However, because of such merits that a large amount of electric current can be transferred with an extremely small loss and a strong magnetic field can be generated, the development of the application researches is in progress. In this article, the application to the electric power fields is explained. In the field of superconducting generators, many countries are conducting its research and development and in Japan, in accordance with the Moonlight Project, its research and development are planned to be conducted for 8 years from 1988 and the stage of a 70MVA model machine has already been over. Currently, wire rods of NbTi or Nb/sub 3/Sn as well as a cooling device are the subjects for study. Concerning superconducting transformers, it has been experimentally calculated that in comparison with the conventional transformers, the loss will be decreased by half and the weight be decreased down to 50-60%, but the increase of the critical electric current density is considered to be solved first. With respect to superconducting cables, studies are being made on liquid nitrogen cooled cables in addition to liquid helium cooled ones. In the field of superconducting energy storage, the conceptual design of a 5 million KWh SMES was completed in 1985 as a commissioned project of NEDO. (6 figs, 3 tabs, 7 refs)

IX. ASSESSMENTS BEARING UPON TRANSFORMERS

The following pages provide citations and abstracts for 18 reports, each bearing upon the use of ceramic superconductors in transformers. Some reports describe more than one topic; in that case the report is listed in this section and in other appropriate sections. The most recent reports are from 1991 and the earliest is from 1987.

Transformers

Title: Tests on a 30 kVA class superconducting transformer
Author: Yoneda, E. S.; Tashiro, I.; Morohoshi, M.; Ito, D.
Corporate Source: Toshiba Corp, Kanagawa, Jpn
Source: Cryogenics v 31 n 7 Jul 1991 p 655-659
Publication Year: 1991
Language: English
Document Type: JA; (Journal Article)
Treatment: T; (Theoretical); X; (Experimental)
Journal Announcement: 9111

Abstract: To demonstrate the applicability of superconductors to electric power machines, the present authors made and tested a 30 kVA class single-phase superconducting transformer. The aim of the study was to determine the superconducting transformer properties. Therefore the superconducting transformer has a simple structure, i.e. the primary to secondary voltage ratio is 1:1 and the iron core is immersed in liquid helium. The core loss, evaluated from no-load tests, was 13 W and leakage impedance, obtained by short circuit tests, was 0.02 Ω in accordance with a calculated value. The superconducting transformer showed the limitation effect of fault currents. The authors succeeded in continuous operation with a 0.5 Ω load resistance. These results suggest that efficiency can be 98.5%, if the iron core is located outside the cryostat and if high T/c superconductors are used as current leads. Superconducting windings exhibit training quenches in general. The authors also developed a superconducting transformer quench detector with a third winding around the iron core. The quench detector revealed that the secondary winding quenches before the primary winding. (Author abstract) 8 Refs.

Title: High-temperature superconductors Their potential role in electric utility applications and what must be done to use them
Author(s): Giese, R.F.; Sheahen, T.P.; Wolsky, A.M. (Argonne National Lab., IL (United States)); Sharma, D.K. (Electric Power Research Inst., Palo Alto, CA (United States))
Sponsoring Organization: EPRI Electric Power Research Inst., Palo Alto, CA (United States)
Conference Title: 52. American power conference
Conference Location: Chicago, IL (United States)
Conference Date: 23-25 Apr 1990
Source: Proceedings of the American Power Conference (United States) v 52
Publication Date: 1990 p 776-782
Report Number(s): CONF-9004133--
Contract Number (Non-DOE): Agreement RP7911-1
Language: In English

Abstract: This paper describes a number of proposed applications of superconductivity for the electric utility sector. The current status of their development is summarized, and the potential impact of successful development of high-temperature superconductors (HTSCs) is discussed. Performance goals for development of HTSCs are presented and compared with the current status of development of HTSCs. Applications discussed include large-scale generators, motors, transmission lines, magnetic storage, transformers, power electronics, and fault-current limiters.

Title: Superconductivity in energy technologies. Assessment, concepts and new aspects
Corporate Source: Verein Deutscher Ingenieure (VDI) - Gesellschaft Energietechnik, Duesseldorf (Germany, F.R.)

Publisher: Duesseldorf (Germany, F.R.) VDI-Verl.
Publication Date: 1990 (274 p)
Language: In English

Abstract: Four years after the sensational discovery the purpose of this book is to show the current state of the art, the technical-physical concepts and new aspects of the technical application and use of superconductors, in the field of energy technologies. The book will focus primarily on the following topics: general introductions; materials: requirements, properties, manufacture, processing; cryotechnology; machines, cables, switches, transformers; energy storage; magnetic engineering for fusion, transport and mass separation; magnets for particle accelerators; promotional activities, economy, patents. This book has been written by and for scientists and engineers working in industry, large-scale research institutions, universities and other research and application fields to help further their knowledge in this field. Apart from the current state of the art, the book also describes future application and development possibilities for the superconductor in power engineering. (orig.).

Title: Superconductivity in electrical engineering
Original Title: Elektrotechnische Anwendungen der Supraleitung
Author(s): Zeller, H.R. (Asea Brown Boveri AG, Baden (Switzerland). Forschungszentrum)
Source: Bulletin des Schweizerischen Elektrotechnischen Vereins (und) des Verbandes Schweizerischer Elektrizitaetswerke (Switzerland) v 81:15
Publication Date: 4 Aug 1990 p 20-22
Language: In German

Abstract: The article discusses the applications of ceramic high-temperature superconductors, e.g. superconducting generators, transformers, transmission cables, current limiters, and magnetic separators. (MM).

Title: Magnetic materials, varistors and superconductors: Applications and development trends. Proceedings
Original Title: Magnetische Werkstoffe, Varistoren und Supraleiter: Anwendungen und Entwicklungstendenzen. Vortraege
Original Series Title: ETG-Fachbericht
Corporate Source: Energietechnische Gesellschaft im VDE, Frankfurt am Main (Germany, F.R.)
Conference Title: ETC technical meeting on magnetic materials, varistors and superconductors: applications and development trends
Original Conference Title: ETG-Fachtagung ueber Magnetische Werkstoffe, Varistoren und Supraleiter: Anwendungen und Entwicklungstendenzen
Conference Location: Baden-Baden (Germany, F.R.)
Conference Date: 27-28 Sep 1989
Publisher: Berlin (Germany, F.R.) VDE-Verl.
v no. 29
Publication Date: 1989 (171 p)
Report Number(s): CONF-8909323--
Language: In German

Abstract: This volume of proceedings deals with the following four main topics: 1. soft magnetic materials (for example magnetic properties or reduction of the remagnetization losses of electric sheets; new magnetic materials for transformers or chokes); 2. hard magnetic materials (permanent magnets); 3. varistors (production, properties, range of application) and 4. range of applications of superconductors (high-temperature superconduction transformers; interconnection

through a current-limiting choke with a high-temperature superconduction core; possible effects of high-temperature superconduction on inductive energy accumulators). 8 of the 22 contributions were separately recorded for the data base ENERGY. (MM).

Title: Problems of a transformer with high-temperature superconductors

Original Title: Probleme eines Transformators mit
Hochtemperatur-Supraleitern

Author(s): Mueller, W. (Siemens AG Unternehmensbereich KWU, Nuernberg (Germany, F.R.).
Transformatorenwerk)

Title: Magnetic materials, varistors and superconductors: Applications and development trends.
Proceedings

Original Title: Magnetische Werkstoffe, Varistoren und Supraleiter: Anwendungen und
Entwicklungstendenzen. Vortraege

Original Series Title: ETG-Fachbericht

Corporate Source: Energietechnische Gesellschaft im VDE, Frankfurt am Main (Germany, F.R.)

Conference Title: ETC technical meeting on magnetic materials, varistors and superconductors:
applications and development trends

Original Conference Title: ETG-Fachtagung ueber Magnetische Werkstoffe, Varistoren und
Supraleiter: Anwendungen und Entwicklungstendenzen

Conference Location: Baden-Baden (Germany, F.R.)

Conference Date: 27-28 Sep 1989

Publisher: Berlin (Germany, F.R.) VDE-Verl.

v no. 29

Publication Date: 1989 p 149-158 (171 p)

Report Number(s): CONF-8909323--

Language: In German

Abstract: Fundamental reflections are made on the demands which have to be made on the short-circuit current limitation in the network on the one hand and on the admissible magnetic boundary field strengths of high-temperature superconduction on the other hand. The aim to develop mechanically self-supporting windings led for conventional core-type transformer designs to the construction of concentric-lay winding arrangements with magnetic stray field strengths, which seem to be realizable with regard to material development. Due to the further aim of avoiding core losses, a design study on a coreless high-temperature superconduction transformer was drawn up the windings of which are united in a coaxial cable which is wound up to a toroidal coil. The factors of influence which are relevant for the rating, operating characteristics and the application of a transformer like this are discussed. (orig.).

Title: Design study for a high-temperature superconductor

Original Title: Entwurfstudie zu einem Hochtemperatur-Supraleiter

Author(s): Mueller, W. (Siemens AG Unternehmensbereich KWU, Nuernberg (Germany, F.R.).
Transformatorenwerk)

Title: Magnetic materials, varistors and superconductors: Applications and development trends.
Proceedings

Original Title: Magnetische Werkstoffe, Varistoren und Supraleiter: Anwendungen und
Entwicklungstendenzen. Vortraege

Original Series Title: ETG-Fachbericht

Corporate Source: Energietechnische Gesellschaft im VDE, Frankfurt am Main (Germany, F.R.)

Conference Title: ETC technical meeting on magnetic materials, varistors and superconductors:
applications and development trends

Original Conference Title: ETG-Fachtagung ueber Magnetische Werkstoffe, Varistoren und
Supraleiter: Anwendungen und Entwicklungstendenzen

Conference Location: Baden-Baden (Germany, F.R.)

Conference Date: 27-28 Sep 1989

Publisher: Berlin (Germany, F.R.) VDE-Verl.

v no. 29

Publication Date: 1989 p 159-160 (171 p)

Report Number(s): CONF-8909323--

Language: In German

Abstract: For linking practically loss-free transformation and reactive power compensation, a design study on a coreless high-temperature superconduction transformer is drawn up the windings of which are united in a coaxial cable which is wound up into a toroidal coil. The influencing parameters which are relevant for the rating, operating characteristics and the application of a transformer like this are discussed. (orig./MM).

Title: Design study of a high-Tc superconducting transformer

Original Title: Entwurfsstudie zu einem HTSL-Transformator

Author(s): Mueller, W.

Title: Superconductivity in power engineering. Status, concepts, new aspects

Original Title: Supraleitung in der Energietechnik. Stand, Konzepte, neue Aspekte

Original Series Title: VDI-Berichte

Corporate Source: Verein Deutscher Ingenieure (VDI) - Gesellschaft Energietechnik, Duesseldorf (Germany, F.R.)

Conference Title: Technical meeting on superconductivity in power engineering: Status, concepts, new aspects, with exhibition

Original Conference Title: Fachtagung Supraleitung in der Energietechnik: Stand, Konzepte, Neue Aspekte und Ausstellung

Conference Location: Karlsruhe (Germany, F.R.)

Conference Date: 14-15 Jun 1989

Publisher: Duesseldorf (Germany, F.R.) VDI-Verl.

v no. 733

Publication Date: 1989 p 423-429 (442 p)

Report Number(s): CONF-8906339--

Language: In German

Abstract: The design study compares the network operating conditions for conventional and for superconducting transformers. The results indicate that high-Tc superconducting transformers require short-circuit current limitation by way of high-Tc superconducting switches. This would permit the short-circuit voltage of the transformers to be indefinitely low. Another task investigated in the study is prevention of core losses, and a draft design is presented of a coreless high-Tc superconducting transformer, whose windings are placed in coaxial cable wound up to form a toroidal coil. The parameters are given that determine the dimensioning, operating behaviour, and applications of such a transformer. (orig.).

Title: Superconductivity in power engineering. Status, concepts, new aspects

Original Title: Supraleitung in der Energietechnik. Stand, Konzepte, neue Aspekte

Original Series Title: VDI-Berichte

Corporate Source: Verein Deutscher Ingenieure (VDI) - Gesellschaft Energietechnik, Duesseldorf (Germany, F.R.)

Conference Title: Technical meeting on superconductivity in power engineering: Status, concepts, new aspects, with exhibition

Original Conference Title: Fachtagung Supraleitung in der Energietechnik: Stand, Konzepte, Neue Aspekte und Ausstellung

Conference Location: Karlsruhe (Germany, F.R.)
Conference Date: 14-15 Jun 1989
Publisher: Duesseldorf (Germany, F.R.) VDI-Verl.
v no. 733
Publication Date: 1989 (442 p)
Report Number(s): CONF-8906339--
Language: In German

Abstract: This proceedings volume presents 24 conference papers and 15 posters dealing with the following aspects: (1) Principles and elementary aspects of high-temperature superconductivity (3 plenary lectures); (2) Preparation, properties and materials requirements of metallic or oxide superconductors (critical current behaviour, soldered joints, structural studies); (3) Magnet technology (large magnets for thermonuclear fusion devices; magnets for particle accelerators and medical devices); (4) Magnetic levitation and superconductivity; (5) Cryogenics; (6) Energy storage systems using superconducting coils (SMES); (7) Superconducting power transmission cables, switches, transformers, and generator systems for power plant; (8) Supporting activities, industrial aspects, patents. There are thirty-eight records in the ENERGY database relating to individual conference papers. (MM).

Title: Presentation of activities by Germany

Author(s): Klose, W.

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 31-66 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: Applications of superconductivity may be classified in two categories: systems where superconductors are practically indispensable for achieving the system's objectives; and superconductor systems have to compete with highly developed conventional technologies. Systems with superconductors as indispensable components include systems where Cryogenic costs are a small fraction of total costs (e.g., fusion reactors and MHD generators) and systems where Cryogenic costs are a significant fracture of total overall costs (e.g., particle accelerators, storage rings, research magnets, and NMR-spectroscopy). The paper mostly discusses the application of superconductivity to developed conventional technologies: AC-power cables, transformers, energy storage systems, AC generators, and magnetic are separation.

Title: Activities within the field of superconductivity in Sweden

Author(s): Claeson, T. (Chalmers Univ. Technology, Gothenburg (Sweden))

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 220-224 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: The new oxide superconductors may have an impact on the power sector. However, the time scale of introducing new components or systems in the utilities is long and many basic materials problems remain to be solved. A persistence and continuously revised assessments as new progress is obtained are needed as well as a parallel development of materials and components. This paper reviews the conclusions to date on the application of superconductivity and possible time frame to the following: fusion, MHD, and AC electric generators; cables; transformers; magnetic energy storage; power stabilization; electric motors; high speed trains; and magnetic separation.

Title: High- Tc superconductors in electric power applications

Author(s): Steennis, E.F.

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 189-219 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: This report describes the possible implications of the discovery of High-Temperature Superconductors in the Electric Power sector in The Netherlands. In particular the material $\text{YBa}_{2}\text{Cu}_{3}\text{O}_{7}$ is discussed. Assuming High-Tc superconducting wires and tapes become available for a reasonable price, the main consequences are as follows. (1) High-Tc superconductors may lead to important possibilities for transformers, generators, motors and magnets for separation. On the long term these superconductors may positively influence the development of MHD generators and fusion reactors. (2) The application of magnetic shielding is obvious. (3) In The Netherlands a large scale application like SMES or a MAGLEV-train is not attractive. Moreover there is no need for power regulation and stabilization. (4) High-Tc superconducting cables are not interesting from an economic point of view. (5) High-Tc superconducting overhead lines will not be accepted for practical reasons. (6) The introduction of rather specific components like current-limiters and switches can improve the dimensioning of the power transmission network. For instance it will lower the level of the short circuit current in a high extent. Such components are therefore very attractive but the technological and economical perspectives can hardly be given now. (7) High-Tc superconducting fuses for power applications are not attractive for practical reasons. (8) Test facilities, based on High-Tc superconductors, like impuls-current generators and compensation coils for cable testing, are very attractive. Here the application of a High-Tc superconductor offers new possibilities.

Title: IEA expert meeting: Assessment of superconductivity in the power sector

Author(s): Meyer, L.A.

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 183-188 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: In March 1988 the Government established a national research program on warm superconductors. The main items of the research program are: theory; new materials with higher TC; technology and classification; physics of superconducting phenomena and electronic structure, and investigation of applications. The implementation of item 5 will be divided into two categories: energy and magnet-related applications; and microelectronic applications and sensors. The general objective is to obtain an overview of the advantages of the use of nitrogen-cooled superconductors compared with other technologies in the categories mentioned above. The possible opportunities for Dutch industry will also be assessed. It is assumed that it will become possible to produce reliable layers, tapes, wires and coils on an industrial scale. Subjects that will be included in the studies relating to power and environmental applications are: transformers, generators, motors; magnetic shielding; superconducting magnet energy storage for peak-shaving (SMES); high-gradient magnetic separation for water purification (HGMS).

Title: 1987 report of the Committee for Study of Superconduction Technology in Japan

Title: Assessing the impact of high-temperature superconductivity on electric power

Conference Title: Experts' meeting on assessing the impact of high temperature superconductivity on electric power

Conference Location: Tokyo (Japan)

Conference Date: 1-2 Sep 1988

Publisher: Paris (FR) International Energy Agency

Publication Date: 1988 p 167-182 (284 p)

Report Number(s): CONF-8809518--

Language: In English

Abstract: The superconductivity oriented cryogenic technology is going to plunge into the phase of practical use after studies made for the past more than 30 years. However, recent sudden progress of research about the findings of oxide based high temperature superconductors may bring about a remarkable revolution in the future technological system. For this reason, it is currently required to review the basic evaluation items concerned with refrigeration techniques, stabilization techniques, etc. in the superconducting technology, repercussive effect mainly on the electric power technology, scale merit in view of economic efficiency, and so on. Working groups were established for electric power systems, generators, transformers, power transmission (power cables), power storage and magnet application (various magnets using superconduction), discuss the following: Necessity and merits (introduction effect) of applying superconducting technology; Technical subjects and solutions in the application of superconducting technology; Technical requirements for superconduct or superconductor; Effect of introducing oxide based high temperature superconductive materials. For the subject of research and development of oxide based high temperature superconductive materials, a working group for conductor production techniques was established to discuss the subject. This report summarizes the results of discussion in the respective working groups.

Title: Future view of electric power supply techniques. Transmission techniques

Author(s): Kaminosono, Hiroshi

Affiliation: Central Research Inst. of Electric Power Industry, Tokyo, Japan

Source: Denki Gakkai Zasshi (Japan) v 108:6

Publication Date: 20 Jun 1988 p 527-529

Language: Japanese

Abstract: Future trends of overhead, underground and superconducting transmission techniques are reviewed. As for the overhead transmission, the increasing of a transmission capacity and the improvement of a system stability are pointed out. As examples, 1,000kV transmission, DC transmission with no problem of a system stability, the thunderbolt-proof design especially on the

Japan Sea side of Japan, and the small scale transmission tower in an urban area are described. As for the underground transmission. 500kV transmission, and the high insulating resistant and high cooling rate

crosslinked-polyethylene-insulated(CV) cable capable of increasing a transmission capacity are described. As for the superconductive transmission, the effect of a expected practical high temperature superconductive cable is epoch-making, so it is pointed out that the superconducting cable system as low as 60kV is possible to meet the power demand sufficiently. In summary, there will be no big change of the transmission techniques in the near future, and the present techniques will be possible to meet various requirements sufficiently, however, there is also the great expectation for the practical superconducting cable. (1 fig, 1 photo)

Title: Application of superconductivity to electric power technology

Author(s): Tanaka, Toshikatsu

Affiliation: Central Research Inst. of Electric Power Industry, Tokyo, Japan

Source: Nippon Kikai Gakkaishi (Japan) v 91:835

Publication Date: 5 Jun 1988 p 46-50

Language: Japanese

Abstract: Application of the superconductivity to the electric power technology is described. Whereas the cooling efficiency of liquid He is lower than 0.2%, that of liquid nitrogen is 10%, or more than 50 times larger than liquid He. As the evaporation potential heat is 63 times, the thermal conductivity is 7.2 times larger, the insulation breakdown strength is high and the price is one-fiftieth lower, reducing the economic scale greatly. The capacity of superconducting generators that are competitive with conventional machines are 1000 MVA with the liquid He and 500 MVA when the superconductivity at high temperature is possible with the liquid nitrogen. For the transformers, the AC wire of high temperature superconducting material is required but the research on it is not yet started. While the loss of superconducting power cable is low and it is suitable for large capacity DC power transmission, it is advantageous even with 2 million KVA if the liquid nitrogen cooling is possible. The superconducting magnetic energy storage (SMES) is useful in the system power pooling and storage, and it is competitive with the pumped storage power generation at 4 million KWh with He and 1 million KWh is allowable if the liquid nitrogen can be used. The impact of high temperature superconducting material to the power technology is high and the superconducting cable and SMES are promising. (3 figs, 3 tabs, 3 refs)

Title: Superconductivity and its application on electric power technology

Author(s): Hasegawa, Jun

Affiliation: Hokkaido Univ., Faculty of Engineering, Sapporo, Japan

Source: Karyoku Hatsuden (Japan) v 39:2

Publication Date: 15 Feb 1988 p 9-17

Language: Japanese

Abstract: This report describes the following items. 1. Superconductivity phenomena (Temperature dependency of electric resistance of metals. Important properties of superconductivity (Perfect conductivity. Perfect anti-magnetism. Quantum effect). Second class superconductive material (Magnetic flux flow. Pin-stop effect. Critical current). High temperature superconductive material (Properties of ceramic superconductive material. Basic requirement of commercialization). 2. Application of superconductivity technology to power industry (Electric power, electronics and communication, transportation, etc.). Superconductive electric power transmission cable. Superconductive transformer. Superconductive energy storage. Fundamental conditions for the commercialization of the new superconductive material are the following three: Electric resistance

is really zero at the temperature below the critical temperature (liquid nitrogen). Critical current density reaches the level of 10^5 - 10^6 A/cm². Production cost of the superconductive wire reaches the same level as the present superconductive wire. (7 figs, 4 tabs, 7 refs)

Title: Application of high temperature superconducting materials

Author(s): Tanaka, Toshikatsu

Affiliation: Central Research Inst. of Electric Power Industry, Tokyo, Japan

Source: Kagaku Kogaku (Japan) v 51:11

Publication Date: 5 Nov 1987 p 35-39

Language: Japanese

Abstract: As for superconducting materials, there are still many problems such as their natures, etc. to be clarified. However, because of such merits that a large amount of electric current can be transferred with an extremely small loss and a strong magnetic field can be generated, the development of the application researches is in progress. In this article, the application to the electric power fields is explained. In the field of superconducting generators, many countries are conducting its research and development and in Japan, in accordance with the Moonlight Project, its research and development are planned to be conducted for 8 years from 1988 and the stage of a 70MVA model machine has already been over. Currently, wire rods of NbTi or Nb₃Sn as well as a cooling device are the subjects for study. Concerning superconducting transformers, it has been experimentally calculated that in comparison with the conventional transformers, the loss will be decreased by half and the weight be decreased down to 50-60%, but the increase of the critical electric current density is considered to be solved first. With respect to superconducting cables, studies are being made on liquid nitrogen cooled cables in addition to liquid helium cooled ones. In the field of superconducting energy storage, the conceptual design of a 5 million KWh SMES was completed in 1985 as a commissioned project of NEDO. (6 figs, 3 tabs, 7 refs)

END

**DATE
FILMED**

4 / 15 / 93