May 01 1992

FUNDAMENTAL MECHANISMS IN FLUE GAS CONDITIONING

QUARTERLY REPORT
January 1992 - March 1992

DOE/PC/90365--T6

DE92 015629

SRI-ENV-92-334-7375-Q3

Contract No. DE-AC22-91PC90365

April 27, 1992

Todd R. Snyder
Michael S. Robinson
P. Vann Bush

SOUTHERN RESEARCH INSTITUTE
2000 NINTH AVENUE SOUTH
P.O. Box 55305
BIRMINGHAM, ALABAMA 35255-5305

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Prepared for

Felixa Eskey, Project Manager
UNITED STATES DEPARTMENT OF ENERGY
Pittsburgh Energy Technology Center
Post Office Box 10940, MS 922-206
Pittsburgh, Pennsylvania 15236-0940

ENTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

TABLE OF CONTENTS

	<u>PAGE</u>
INTRODUCTION	1
INITIAL PREPARATION OF LABORATORY EQUIPMENT	1
Electrostatic Tensiometer.....	1
Specific Surface Area Analyzer	3
Solvent Leaching Device	4
Karl Fischer Titrator	5
PLANS FOR THE UPCOMING QUARTER.....	11
APPENDIX A DESCRIPTIONS OF PROPOSED EXPERIMENTS.....	A-1

INTRODUCTION

This project is divided into four tasks. The Management Plan was developed in task 1. Task 2, Evaluation of Mechanisms in FGD Sorbent and Ash Interactions, focuses on the characteristics of binary mixtures of these distinct powders. Task 3, Evaluation of Mechanisms in Conditioning Agents and Ash, is designed to examine the effects of various conditioning agents on fine ash particles to determine the mechanisms by which these agents alter the physical properties of the ash. Tasks 2 and 3 began with an extensive literature search and the assembly of existing theories. This phase of the project is now complete. During the past quarter, initial preparations of laboratory equipment for laboratory testing have been made. A plan for initial laboratory tests has been submitted to the Project Manager for review. Laboratory testing will commence once these laboratory plans have been formally approved. The results of the work performed under tasks 2 and 3 will be included in a Flue Gas Conditioning Model that will be issued under task 4. The Final Report for the project will also be prepared under task 4.

INITIAL PREPARATION OF LABORATORY EQUIPMENT

Several different pieces of equipment will be used in this project once suitable modifications are made in their design and operation. The following description identifies the equipment and the types of activities involved.

Electrostatic Tensiometer

The electrostatic tensiometer measures the tensile strength of powders by exposure of a sample of the powder to an electrostatic field generated in a parallel-plate electrode system. As the field between the electrodes is increased, a point is reached when the tensile strength bonding the powder particles to each other is overcome by the attractive force generated by the applied electric field acting on the charge induced on the surface of the particulate sample. At this point, the powder particles on the surface of the sample are lofted into the region between the electrodes. Visual observation of the region between the electrodes or monitoring of electrical current through the grounded electrode with an electrometer can be used to detect the movement of these particles. For this project, the electrostatic tensiometer should be invaluable for the measurement of the tensile strength of powders, ashes, and mixtures of ashes and sorbents. Planned improvements to the original design of the electrostatic tensiometer have been evaluated. Southern Research Institute (SRI) will pay for the fabrication of an improved tensiometer that will be available for use in this project. Fabrication should be complete by the end of May. Figure 1 shows the modified design of the tensiometer in the bell jar that will be used to maintain various environmental conditions during the tensile strength measurement. Evacuation of the bell jar should increase the field strength that can be applied, and consequently the range of tensile strengths that can be measured. This redesign should also provide a convenient chamber for gaseous compounds to be used to condition powder samples already placed on

Figure 1. Modified design of the electrostatic tensiometer.

the surface of the grounded electrode. An oven large enough to contain the complete bell jar assembly has been set up in the laboratory where these conditioning measurements will take place, and it will be useful for these tensile strength measurements, as well as for tests performed with other devices. Concentration, equilibration time, and temperature will then be available as test parameters for conditioning agents such as H_2O , SO_3 , and NH_3 .

Specific Surface Area Analyzer

SRI has a Micromeritics Accusorb 2100E, a device for determining the adsorption isotherm of solid samples using a variety of adsorbates. Our current interest focuses on the use of water vapor as an adsorbate, but we have the capacity to use other gases as well. The device had been out of commission for some time so most of our effort to date has been to examine the instrument and bring it back to working order. The vacuum system, pressure transducer and heaters have been thoroughly examined and shown to be in good working condition. To obtain data measuring the adsorption of water by fine powders, certain modifications have been made to this device which allow adsorption isotherm measurements to be performed at relatively high temperatures (60 to 70 °C). Once we have completed checking out this modified design, we expect to use it extensively because of the key role adsorbed water plays in determining particle properties.

Determination of the adsorption isotherm involves admitting an adsorbing gas, called the adsorbate, to a sample of material of known weight, called the adsorbent, which has been previously dried, weighed, and freed of adsorbed gases and vapors by heating and exposure to vacuum. Adsorbate is admitted in incremental amounts into a manifold of volume V_d and temperature T_d where its pressure P_1 is measured. The quantity of gas is established by the relationship $P_1 V_d = nRT_d$, where R is the gas constant. A valve connecting the manifold and the sample of adsorbent is then opened and the gas expands into the new space attaining a new pressure P_2 . Some of it is adsorbed by the tested sample which is at a controlled temperature T_s lower than T_d . The gas is now partly in the distributing manifold at the apparatus temperature, partly in the space about the sample at a lower temperature, partly in interconnecting tubing at an intermediate temperature T_i , and partly adsorbed. A material balance written to encompass the shift from the first condition to the second is

$$\frac{P_1 V_d}{T_d} = \frac{P_2 V_d}{T_d} + \frac{P_2 V_s}{T_s} + \frac{P_2 V_i}{T_i} + \frac{760}{273} V_a \quad (1)$$

in which V_s , V_i , and V_a are, respectively, the volume of the free space about the sample, the volume of the interconnecting tubing, and the volume of the gas removed by adsorption, with the volume of gas adsorbed expressed at standard conditions (760 mm Hg, and 0 °C).

When the process is repeated with a second quantity of gas, the pressure P_2 that was the final pressure before becomes the base, or equilibrium pressure P_e for the second step, and the material balance equation becomes

$$\frac{P_1 V_d}{T_d} + \frac{P_e V_s}{T_s} + \frac{P_e V_i}{T_i} = \frac{P_2 V_d}{T_d} + \frac{P_2 V_s}{T_s} + \frac{P_2 V_i}{T_i} + \frac{760}{273} V_a \quad (2)$$

A correction must be made for the nonideal behavior of some gases at low temperature. Sufficiently accurate allowance is obtained by multiplying the volume of gas in the sample space V_s by the factor $1 + \alpha P_e$, where α is the Perfect Gas Law correction factor. For water $\alpha = 2.4 \times 10^{-5} \text{ mm Hg}^{-1}$ and P_e is the equilibrium pressure. When this correction is included and allowance is made for the weight of the sample W_s , equation 2 becomes

$$\frac{V_a}{W_s} = \frac{273}{760 W_s} \left[\frac{V_d}{T_d} (P_1 - P_2) - \left[\frac{V_s}{T_s} + \frac{V_i}{T_i} \right] (P_2 - P_e) - \frac{V_s \alpha}{T_s} (P_2^2 - P_2 P_e) \right] \quad (3)$$

We would prefer to represent the quantity of water adsorbed as a mass fraction. To convert from volume of water at standard temperature and pressure (STP) to mass of water requires multiplication by 0.802, so the equation becomes

$$\frac{W_a}{W_s} = \frac{0.288}{W_s} \left[\frac{V_d}{T_d} (P_1 - P_2) - \left[\frac{V_s}{T_s} + \frac{V_i}{T_i} \right] (P_2 - P_e) - \frac{V_s \alpha}{T_s} (P_2^2 - P_2 P_e) \right] \quad (4)$$

in which W_a is the mass of water adsorbed.

When experimental values obtained from several gas additions are substituted into equation 4, a series of values for W_a at various final pressures P_2 can be derived. A plot of W_a/W_s versus P_2/P_s , where P_s is the saturation pressure taken at the temperature of the sample during the test, yields an adsorption isotherm.

Figure 2 is an adsorption isotherm for water vapor on a sample of Monticello ash. The abscissa in the figure indicates the pressure of water vapor around the sample as a fraction of the saturation pressure at the sample temperature; therefore, a value of 0.4 is equivalent to 40% relative humidity. At 40% relative humidity (RH) the mass fraction of water adsorbed as measured by the Accusorb was about 0.17%. This value compares well to the results obtained with the coulometric Karl Fischer titration when the laboratory RH was approximately 40%. The coulometer determined the mass fraction of water on this ash to be between 0.15 and 0.19 %.

Solvent Leaching Device

In the literature review we identified a technique that should be useful for the characterization of the soluble chemical compounds that reside on the surfaces of fine fly ash particles. The technique consists of the gradual leaching of surface compounds from a thin bed of ash by the passage of a leaching solution through the bed. Aliquots of filtrate are then analyzed for anionic and cationic species to provide profiles of dissolved species versus the amount of leaching solution that has passed through the sample. The leaching apparatus has been assembled and the techniques that will be used

Figure 2. Adsorption isotherm of water vapor on Monticello ash.

for the initial analyses have been established. Distilled, deionized water will be the first leaching solution that we will use. Additional details of the leaching procedures to be used in the initial tests are discussed in Appendix A under Experiment 3.4.

Karl Fischer Titrator

A Karl Fischer Titration system (Brinkmann Model 684/2) for determination of water content will be a vital component of our laboratory analyses. This system will allow determination of water content to be made on samples immediately following their conditioning. During the past quarter we have been exploring the capabilities and limitations of the system with the types of ashes that will be tested during the scope of the project.

The coulometric Karl Fischer titration is a variant of the classical Karl Fischer method for the determination of water. In the conventional method, methanolic solutions of iodine, sulfur dioxide and an organic base (RN) are used, with the organic base serving as a buffer. During the titration of a sample containing water, several reactions occur, which are summarized in the following equation:

The quantitative determination of water content is based on the relationship that a given amount of iodine leads to the conversion of an equivalent amount of water.

In the coulometric Karl Fischer titration the iodine needed is generated electrochemically within the titration vessel itself. The quantitative relationship existing between the electric charge passed through the electrolyte and the amount of iodine produced is used for the precise dosing of iodine. Since the coulometric Karl Fischer titration is an absolute method it does not require any calibration. The endpoint of the titration is determined by the voltametric method which applies an alternating current to a pair of indicator electrodes. The voltage difference thus generated decreases drastically if traces of iodine are present.

The 684 KF Coulometer is an automated instrument for the exact determination of small amounts of water in the range 10 μg to 10 mg. This device uses a titration cell without a diaphragm, thus requiring only a single reagent for the water determination. The 684 KF Coulometer consists of an electronic control and readout unit and a glass titration cell filled about one third full with Hydranal Coulomat AD reagent. The titration cell is shown in figure 3. One generating electrode for producing iodine electrochemically and one indicating electrode for detecting the endpoint of the titration pass through openings in the titration cell and are immersed in the titration reagent. These electrodes are connected to the control unit via coaxial cables. A third opening into the titration cell allows for connection to the oven for water determination on solid samples, to be described later. A fourth and final opening into the cell is closed with a screw cap with a septum through which liquid samples may be injected. All connections and openings can be sealed.

Figure 3. The Karl Fischer titration cell.

Figure 4. Arrangement of components of the Karl Fischer apparatus for titrating solid samples.

The water content of solid samples is determined using an oven, a pump and a drying column in addition to the titration cell and control unit described above. This method will be the one most commonly used during this project. The arrangement of this equipment is shown schematically in figure 4. The oven can heat samples up to 300 °C. A sample of powder is weighed and placed in a stainless steel boat which is then placed in the oven where the heat removes water from the powder. A stream of dry air, generated by the pump and drying chamber, flows over the sample carrying the released water through the inlet tube into the titration cell where a water determination is made. In the following experiments the metal boats were kept dry in a desiccating chamber to prevent any water on the surface of the boats from being included in the final result. Because of observed variances in the results obtained with this procedure, for future measurements we will probably determine the water content of the boat and use that value as a blank to be subtracted from the final result.

We have made preliminary water determinations on three types of fly ash using the titrator and oven assembly as described above. The ashes were selected to represent a wide range of particle surface area, type of source coal and combustion parameters. These ashes have been thoroughly characterized in earlier projects. Extraction time was varied to get some idea of the its effects on final results. No blank values were used. All other parameters are listed in the tables below.

The first ash tested was a sample of dust cake ash from the EPRI Scholz High-Sulfur Fabric Filter Pilot Plant (HSFP). The results are summarized below.

oven temperature, °C	extraction time, min	sample wt., mg	H ₂ O, mg	wt. %
150	20	52.6	0.36	0.68
150	20	160.6	1.06	0.66
150	30	125.4	2.09	1.67
150	30	78.2	1.15	1.47
150	30	182.6	3.08	1.69
210	20	181.7	4.07	2.24
210	20	121.8	2.32	1.90
210	20	48.8	0.97	1.99
210	20	129.4	2.35	1.82

Results obtained under each set of conditions are reproducible. Increasing the oven temperature increases the amount of water extracted, and increasing the extraction time also predictably increases the amount of water extracted. At a sufficiently long extraction time the amount of water should not increase with increasing extraction time; however, too long an extraction time may increase the error. For future measurements it will be necessary to determine the appropriate extraction time for various types of samples. Ideally the temperature should be set high enough to drive off all of the water within 20 to 30 minutes. Ultimately our test procedure may use higher oven temperatures than these initial tests, which may improve the accuracy of the results.

Results of tests performed on a sample of dust cake ash from Monticello are presented in the following table.

oven temperature, °C	extraction time, min	sample wt., mg	H ₂ O, mg	wt. %
150	30	882.5	1.30	0.15
150	30	215.3	0.33	0.15
150	45	249.3	0.47	0.19

These results are also reproducible, and an increase in extraction time results in an increase in water extracted.

Results of similar tests performed on a sample of AFBC dust cake ash are presented below.

oven temperature, °C	extraction time, min	sample wt., mg	H ₂ O, mg	wt. %
150	30	160.6	1.51	0.94
150	30	46.8	0.38	0.82
150	30	42.8	0.39	0.91

A sample of sodium tartrate-2-hydrate, $C_4H_4Na_2O_6 \cdot 2H_2O$, a powder, which under normal conditions is not hygroscopic and has a water content of 15.66 %, was also tested using method II. The tests were performed with an extraction time of 20 minutes, a delay of 20 seconds and at an oven temperature of 210°C. To obtain the results below, a blank value for the water content of the metal boat was first determined and then subtracted from the result obtained for the boat and sample. The results are summarized below.

sample wt., mg	water wt., mg	wt. %, g H ₂ O / g sample
18.3	2.584	14.12
56.6	7.866	13.89

An alternative method for water determination of solid samples involves removing the water with a suitable liquid solvent and performing a determination on the liquid. Determinations have been made of water content of the Scholz ash with methanol as the solvent. A sample of the powder to be titrated is weighed and placed in a small sample bottle. A known volume of methanol is added to the sample bottle, the bottle is sealed and the contents are well mixed. Another sample bottle containing only methanol is prepared at the same time to be a blank. After the solid has settled out of the first bottle the water determination can be made. First a sample of the methanol blank is titrated to determine the water content of the methanol. Next a sample of the methanol that has been mixed with the powder is titrated. From this result the blank is subtracted to determine the amount of water released from the

powder sample. The mass fraction of water in the original powder may be calculated from the weight of the sample and the volume of solvent used.

Three sample bottles of methanol-ash mixture and one sample bottle of methanol blank were prepared. Three runs were made with each methanol-ash mixture. A run consisted of one blank titration followed by a titration of a sample of each of the powder-methanol mixtures.

Sample	wt., mg	run 1, wt. %	run 2, wt. %	run 3, wt. %
A	320.6	1.48	1.50	1.75
B	90.3	2.21	1.42	2.16
C	363.1	1.55	1.48	1.98

Averaging the above results yields a wt. % of 1.73 with a standard deviation of 0.31. This result is approximately the same as was obtained for this same ash with the oven at 150 °C.

PLANS FOR THE UPCOMING QUARTER

A proposed plan of laboratory tests has been submitted to the Project Manager for review. The plan covers the first three to six months in what is scheduled to be a twelve month effort under tasks 2 and 3. Included in Appendix A are descriptions of each of the initial seven proposed sets of experiments. Table A-1 in this appendix identifies the particular analyses that will be performed under each set of experiments. The reasons for the choices listed in this table are given under the specific discussions of each set of experiments provided in the appendix. Table A-2 lists the primary methods, equipment, and basic limitations of the analyses that will be used in these experiments.

Once written approval is obtained from the Project Manager the following work will begin. The work planned under task 2 includes the selection and acquisition of particulate matter collected from a variety of sorbent injection applications. We have initially selected seven types of sorbent and ash mixtures for task 2 analyses. We have selected sorbents that should represent the extremes of important physical characteristics (size and surface area) and sorbent injection applications that are widely used or have a high potential for wide application. Particle size, degree of agglomeration, amount and distribution of surface area, and special chemical additives are the primary characteristics that we expect will determine the ease of final particle collection among the samples from low-temperature sorbent injection applications. We plan to obtain samples from three types of tests performed at the DOE Duct Injection Test Facility (DITF). Sorbent and ash mixtures from $\text{Ca}(\text{OH})_2$ slurry injection tests, injection tests of dry $\text{Ca}(\text{OH})_2$ (coplanar with water spray), and $\text{Ca}(\text{OH})_2$ slurry injection tests performed with CaCl_2 additive are available from work performed under Contract DE-AC22-88PC88851. These samples from the DITF have well-documented operating histories and are readily available and relatively fresh. The slurry injection samples should be highly agglomerated in comparison to the dry injection samples. The CaCl_2 addition apparently caused a high potential for water adsorption. Once specific samples are selected, we will determine if any of the tests we plan to perform on the samples have already been carried out under Contract No. DE-AC22-88PC88851. Some samples from the DITF have already been obtained for sedigraphic size analysis. The samples were collected at the inlet to the DITF precipitator on various stages of Brink impactor substrates. These tests will help determine if the techniques we have available can redisperse previously collected particles from a sorbent and ash mixture to their original size distribution as measured by an inertial impactor.

We also will include the particulate product of a conventional spray dryer application in E 2.1. The EPRI High Sulfur Test Center (HSTC) will be the source for this sample, which should have a larger median particle size than the dry duct injection sample from the DITF. A sample of ash and sorbent mixture from the application of ADVACATE (an advanced sorbent material prepared by reacting lime with fly ash) has also been selected for analysis under E 2.1. Samples from the ADVACATE process may be significantly compromised over time because of the extremely high surface area of this material. Although SRI has a selection of samples from ADVACATE tests on hand from past EPA

projects, we feel it will be best to obtain relatively fresh samples from the ADVACATE process that will be evaluated later this year during an upcoming project at TVA's Shawnee Plant.

In high-temperature sorbent injection applications the problems encountered with particle collection in ESPs result primarily from increased resistivity and mass loading (especially in the finer particle sizes). The increased surface areas and mass loadings from these processes would be expected to increase filtering pressure drop in fabric filters. The furnace injection of hydrated lime has generated higher SO₂ removal levels than the injection of limestone. Therefore, we intend to include ash and sorbent mixtures from the former application in E 2.1, E 2.2, and E 2.3. Lignosulfonate-modified sorbent has also shown promise due to its ability to generate small sorbent particles with high surface areas. The ash and sorbent mixtures produced from its application will also be included in these three experiments. SRI has both types of furnace sorbent injection samples available from previous projects. We also may be able to obtain some of these types of samples from the Edgewater facility, if their test schedule still includes these studies.

In the work planned for task 3 we plan to analyze ashes in some sets of experiments and a variety of powders (glass beads, silicon dioxide, alumina, aluminosilicate, and carbon) in other experiments. (A discussion of the ashes we plan to analyze can be found in Appendix A under Experiment 3.1.) According to the results of our literature survey and our prior laboratory experience, particle size, particle shape, bulk chemical composition, and chemical compounds residing on the particle surfaces have significant influences on overall bulk behavior. Powders such as the types listed above minimize variations in these factors. These powders present relatively simple surface morphology and surface chemistry in comparison to fly ash and sorbent particles. Because the surfaces of these powders can be simply described, the chemical adsorption properties and types of chemical reactions that will occur on the surfaces of these particles are fairly well understood. When available, we will use descriptions of the chemical reactivity of the surfaces of these powders found in existing literature to evaluate our analytical methods and the results of analyses performed on fly ashes. In some tests surface treatments of the powders may be used to minimize chemisorption of water. Tests performed with these powders should help us isolate the effects of adsorbed water and particle morphology on bulk behavior. Powders only are called for in E 3.3, and fly ashes only are called for in E 3.4. The intent of E 3.3 is to measure the differences in tensile and cohesive strength of fine particles due solely to the adsorption of water. Since we expect any water adsorbed on fly ash particles to dissolve a significant amount of surface salts, relatively "clean" particles or particles with well-characterized surface chemistry must be used to isolate the effects of adsorbed water. E 3.4 is specifically intended to determine the soluble components on the surfaces of fly ash particles and the degree to which the presence or absence of these compounds affect the bulk physical characteristics of the ash particles. Since the powders we plan to use for E 3.1, E 3.2, and E 3.3 will be chosen for the very reasons of their comparatively homogeneous and chemically simple surfaces and dependable sizes and shapes, they will not be included in E 3.4.

Some of the procedures we will be using (namely compacted and uncompacted bulk porosity tests) are similar to those performed in project DE-AC22-88PC88868; however, the modifications that permit testing to be performed at controlled relative humidity conditions will allow the study of this very important parameter. The array of experiments and the various tests we have planned should offer an informative study of the degree to which water adsorbs on fly ash particles, and on ash and sorbent mixtures. These tests will also permit us to identify some of the environmental conditions present in flue gas ducts, ESPs, and fabric filters that are capable of modifying particulate matter so that the collection process becomes more difficult. Since preparation and checkout of several of the devices mentioned above are nearing completion, the initial experiments discussed in Appendix A will commence during the next reporting quarter.

APPENDIX A

DESCRIPTIONS OF PROPOSED EXPERIMENTS

This appendix discusses the seven sets of experiments proposed for the initial period of testing. The initial laboratory work we have proposed will be preceded by the collection of samples of sorbents and ash mixtures, and ashes and powders for further testing. Each of the two tasks (Task 2 and Task 3) active during this period will include several groups of experiments. Each group of experiments has a title and a corresponding number. For example, E 2.1 represents the first group of experiments to be performed under Task 2. These titles and numbers will be used in the weekly test reports which will be issued during actual periods of laboratory testing. The literature reviews reported in Topical Reports 1 and 2 have emphasized the roles adsorbed water can have in controlling the bulk properties of powders. The series of experiments described in this appendix are directed at defining the extent to which water affects key properties of sorbent and ash particles. The experiments will require thorough characterization of the particle properties and the bulk properties of the particulate matter after exposure to controlled humidity conditions. We will determine the amount of adsorbed water in each case (each powder, and each relative humidity), and the effects of this adsorption. To accomplish this, a variety of particulate matter will be tested, and several standard and specialized techniques will be used. The following table specifies the tests that will be performed under each set of laboratory experiments.

Table A-1
Specific Tests Planned for Each Set of Experiments

ANALYTICAL METHOD	EXPERIMENT						
	2.1	2.2	2.3	3.1	3.2	3.3	3.4
volumetric size distribution (Coulter Counter)				X			
aerodynamic size distribution (Shimadzu sedigraph)	X			X			
compacted bulk porosity	X			X			X
uncompacted bulk porosity	X		X	X		X	X
specific surface area (BET analyzer)	X			X			X
tensile strength (electrostatic tensiometer)	X		X	X		X	X
scanning electron micrographs	X			X			X
drag-equivalent diameter			X	X		X	X
relative gas flow resistance			X	X		X	X
thermogravimetric analysis		X			X		
water content (Karl Fischer titrator)		X			X		
water adsorption isotherms		X			X		
time-resolved solvent leaching							X
mineral analyses, soluble sulfate, equilibrium pH							X
resistivity	X		X	X		X	X
true particle density (pycnometer)	X			X			

E 2.1 STANDARD CHARACTERIZATION OF MIXTURES OF SORBENTS AND ASHES

OBJECTIVE

The objective of E 2.1 is to describe the physical properties of the samples of sorbent and ash mixtures obtained for testing. Sorbent and ash mixtures from seven different types of sorbent injection applications have been selected for analysis. Samples from three types of tests performed at the Duct Injection Test Facility (DITF) will be obtained: sorbent and ash mixtures from $\text{Ca}(\text{OH})_2$ slurry injection tests, injection tests of dry $\text{Ca}(\text{OH})_2$ (coplanar with water spray), and $\text{Ca}(\text{OH})_2$ slurry injection tests performed with CaCl_2 additive. The particulate product of a conventional spray dryer application at the EPRI HSTC will also be included in E 2.1. A sorbent and ash mixture from the application of ADVACATE (an advanced sorbent material prepared by reacting lime with fly ash) has also been selected for analysis under E 2.1. A sample of the ash product collected from the furnace injection of hydrated lime and an ash and sorbent mixture produced from the furnace injection application of lignosulfonate-modified sorbent will also be included in these characterizations.

METHOD

Portions of the seven samples of sorbent and ash mixtures listed above will be dried and their physical characteristics will be measured in the laboratory. The tests that will be performed on these samples are listed in table A-1 under E 2.1. These tests were selected in order to develop a data base of the base line characteristics of these sorbent and ash mixtures that can be compared with the corresponding characteristics of the base line fly ashes (refer to E 3.1) from these same installations.

E 2.2 CHARACTERIZATION OF WATER ADSORPTION BY MIXTURES OF SORBENTS AND ASHES

OBJECTIVE

The objective of E 2.2 is to determine the effects relative humidity has on the amount of water adsorbed by different sorbent and ash mixtures.

METHOD

We will perform parametric tests of water adsorption by desiccated sorbent samples after conditioning them in environments having various relative humidities. The seven sorbent and ash mixtures analyzed in E 2.1 will be conditioned at relative humidities from 10 to 85%. Water content of the conditioned samples will be determined with Karl Fischer titration and/or thermogravimetric analyses. Adsorption isotherms may also be used to characterize the water uptake by these samples after they have been dried by exposure to near vacuum conditions.

E 2.3 CHARACTERIZATION OF WATER-CONDITIONED SORBENT AND ASH MIXTURES

OBJECTIVE

The objective of E 2.3 is to assess the physical properties of sorbent and ash mixtures that have been conditioned at various relative humidities.

METHOD

Sorbent and ash mixtures conditioned in Experiment 2.2 will be subjected to selected analyses. These analyses are listed in table A-1 and are limited to those tests which can be performed at the conditioning humidity. When proper equipment modifications and test procedures are completed, tensile strength, uncompacted and compacted bulk porosity, and relative gas flow resistance analyses should be able to be performed on these water-conditioned sorbent and ash mixtures.

E 3.1 STANDARD CHARACTERIZATION OF POWDERS AND ASH SAMPLES

OBJECTIVE

The objective of E 3.1 is to describe the physical properties of the samples of ashes and powders obtained for testing. Two groups of ashes have been selected for analysis. In order to properly evaluate the effects sorbent injection processes have on fine particle collection, we must analyze the fly ashes (unmodified by sorbent injection) from the installations where the samples described in E 2.1 will be obtained. Therefore we will obtain fly ash from Muskingum River Station No. 5 (where the DITF was located), Somerset (the location of the HSTC), Edgewater, and Shawnee Unit 9. The other group of fly ashes we will analyze have been selected for their direct application to task 3 objectives. The three fly ashes that we used in Contract DE-AC22-88PC88868 (hopper ashes from Monticello, Scholz and TVA's 160 MW AFBC) compose this group, and offer a range of characteristics and advantages for the purposes of this task. These ashes differ chemically and physically in several important ways. For example, weight percent amounts of soluble sulfate measured for the ashes are 0.16 % for the Monticello ash, 1.4 % for the Scholz ash, and 14.0 % for the AFBC ash. The Monticello ash particles are relatively smooth spheres; the Scholz ash particles are spherical, but covered with surface irregularities; and the AFBC ash particles have rough angular shapes. We will make use of the wide range of characteristics we measured for these ashes under our previous contract, although additional tests, not available during our earlier work, will be performed to more fully describe these ashes. The powders that will be tested are glass beads, silicon dioxide, alumina, aluminosilicate, and carbon. Selected analyses will be performed in order to develop a data base of the

base line characteristics of these ashes and powders that can be compared with the corresponding characteristics of these same ashes and powders after various conditioning processes.

METHOD

A dried sample of each of the ashes and powders will be characterized with the range of tests listed in table A-1 under E 3.1.

E 3.2 CHARACTERIZATION OF WATER ADSORPTION BY POWDERS AND FLY ASHES

OBJECTIVE

The objective of E 3.2 is to determine the effects relative humidity has on the amount of water adsorbed by different powders and fly ashes.

METHOD

We will perform parametric tests of water adsorption by desiccated fly ash and powder samples after conditioning them in an environmental chamber at different relative humidities for different lengths of time. Bulk samples will be conditioned within a range of relative humidities from 10 to 85%. Water content of the conditioned samples will be determined with Karl Fischer titration and/or thermogravimetric analyses. Adsorption isotherms may also be used to characterize the water uptake by these samples after they have been dried by exposure to near vacuum conditions.

E 3.3 CHARACTERIZATION OF WATER-CONDITIONED POWDERS

OBJECTIVE

The objective of E 3.3 is to assess the physical properties of powders conditioned at various relative humidities.

METHOD

A selection of the powder samples conditioned in Experiment 3.2 will be subjected to selected analyses. These analyses will be limited to those tests which can be performed at the conditioning humidity. With proper modifications and test procedures, tensile strength, uncompacted and compacted bulk porosity, and relative gas flow resistance analyses should be able to be performed on water-conditioned powders.

E 3.4 SOLVENT LEACHING STUDIES OF FLY ASHES

OBJECTIVE

The objective of E 3.4 is to assess the types and amounts of soluble compounds on the surfaces of fly ashes and correlate them with the physical characteristics of the fly ash samples.

METHOD

Fly ash samples selected from the ones analyzed in Experiment 3.1 will be washed using the solvent leaching technique. Distilled, deionized water will serve as the solvent for this set of experiments. Samples of extract and the washed, dried ashes will be chemically analyzed. The physical analyses specified in under E 3.4 in table A-1 will be used to assess the physical characteristics of the washed ash samples. The solvent leaching apparatus is shown in figure A-1. The technique that will be used in the initial set of tests will consist of the collection of filtrate from repeated filtering cycles. In each cycle, 10 ml of the distilled, deionized water will be added to a 5 gram ash sample located in the filtration cup. A constant vacuum will be applied to the capture vessel in order to draw the water through the ash sample. After most of the water has been filtered through the sample (complete drying of the sample will not be performed between filtration cycles), the filtrate captured in the capture vessel will be removed and placed in a small vial for chemical analysis. The weight of filtrate collected will be recorded for each filtration cycle. At this point another filtration cycle will be performed. Ten more ml of distilled, deionized water will be added to the filtration cup and the filtering and collection processes will be repeated. For these initial tests 30 cycles will be performed. After the last filtration cycle, the ash sample will be dried for later analyses. In order to conserve analysis time and project funds, initially only a few samples selected from this array of 30 filtrate samples will be chemically analyzed (more samples from early filtration cycles, with the frequency of analysis decreasing as the total number of filtrate samples increases). After examination of these data, it may be desirable to resolve the leaching process further with the analyses of more filtrate samples.

For each fly ash selected for these studies, ash samples leached by different amounts of water and subsequently dried will be subjected to various physical analyses. Measurements of ash characteristics such as bulk porosity and cohesivity should indicate whether the bulk properties of the ash samples have been significantly modified by the removal of surface compounds in the leaching process. Observed changes in bulk physical behavior will be correlated with the chemical analyses of these leached ash samples and the corresponding extract samples.

Figure A-1. Schematic diagram of the solvent leaching device.

Table A-2
Primary Methods and Equipment Used in Laboratory Analyses

test	equipment	data obtained	limitations
sedigraphic analysis	Shimadzu SA-CP4	aerodynamic size distribution	particle agglomeration can result in non-representative data; measurement performed in liquid environment
particle counting/sizing	Coulter Counter TA II	volumetric size distribution	conductive particles not properly counted; particle agglomeration can result in non-representative data; measurement performed in liquid environment
compacted bulk porosity	compacted bulk porosity tester	porosity of compacted sample	results dependent on design of device
uncompacted bulk porosity	uncompacted bulk porosity tester	porosity of uncompacted sample	testing at high temperature not possible
surface area analysis	Monosorb Surface Area Analyzer	specific surface area	removes adsorbed materials from sample prior to measurement
tensile strength	electrostatic tensiometer	tensile strength	some samples may have tensile strength greater than the upper limit of device
SEM photo micrographs	scanning electron microscope	visual record of particle appearance	adsorbed compounds may be removed during sample preparation
drag-equivalent diameter	permeability tester	calculated diameter based on bulk permeability	algorithm used in calculation tends to fail for highly irregular particles
relative gas flow resistance	permeability tester	flow resistance of bulk ash sample	final value is strongly dependent on laboratory measurements of bulk porosity
thermo-gravimetric analysis	Perkin-Elmer thermogravimetric system	reaction kinetics (decomposition, evaporation and dehydration) and quantification of component compounds	identification of volatilized compounds must be interpreted solely from temperatures of volatilization
water content	Karl Fischer titrator	water content of powder sample	measurement cannot be done in situ
water adsorption isotherms	modified Accusorb 2100 surface area analyzer	water adsorption isotherms	sample must be evacuated prior to measurement
solvent leaching	solvent leaching apparatus	amounts and types of soluble compounds on particle surfaces	technique does not reveal how compounds were distributed on particle surfaces

Table A-2 (continued)
Primary Methods and Equipment Used in Laboratory Analyses

test	equipment	data obtained	limitations
chemical analysis	various standard techniques	chemical constituents of sample	
true particle density	helium pycnometer	particle density	method cannot distinguish internal pore structure
resistivity	IEEE Standard Method 548-1984	resistivity at various temperatures and gas conditions	
cohesive strength	ring shear device	effective angle of internal friction	large sample needed; test often fails for powders with extremely low or high cohesivities; value returned is only a relative measure of cohesivity

**DATE
FILMED**
8/11/92