WSRC-TR-90-297

NRTSC
NUCLEAR REACTOR TECHNOLOGY
AND SCIENTIFIC COMPUTATIONS

WSRC-TR--90-297

DE92 016473

Keywords: LOCA
BOR
CHF
FLOW INSTABILITY

RETENTION: PERMANENT

CRITICAL HEAT FLUX CONCERNS DURING THE
FLOW INSTABILITY PHASE OF A DEGB LOCA (U)

By

M. A. SHADDAY JR.

ISSUED: AUGUST 1990

Derivative Classifier

J. P. Faraci 8/21/90

SRL SAVANNAH RIVER LABORATORY, AIKEN, SC 29808
Westinghouse Savannah River Company
Prepared for the U.S. Department of Energy under
Contract DE-AC09-88SR18035

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

JP

PROJECT: LOCA
DOCUMENT: WSRC-TR-90-297
TITLE: CRITICAL HEAT FLUX CONCERNS DURING THE FLOW
INSTABILITY PHASE OF A DEGB LOCA
QA TASK NUMBER: 90-023-1
REVISION NUMBER: 0

APPROVALS:

W. M. Massey 8/30/90
TECHNICAL REVIEWER DATE

J. D. Menna 8/31/90
RESEARCH SUPERVISOR DATE

A. J. Harrett 9/4/90
RESEARCH MANAGER DATE

TABLE OF CONTENTS

1. Summary	4
2. Introduction	4
3. Assessment of Critical Heat Flux (CHF) Correlations	5
4. Review of Reactor Data Analysis Program (RDAP) Data	9
5. Impact of Azimuthal Asymmetry of Assembly Power	15
6. Conclusions	24
7. References	25
8. Appendix A - Assembly Model	27
9. Appendix B - FI Criterion	44
10. Appendix C - Code TILT.FOR	47

1. Summary

Arguments are presented that support the proposal that a separate burnout risk analysis, for the FI phase of a LOCA, not be required for reactor restart. With expected reactor power limits, flow instability will occur before critical heat flux (CHF). Since FI power limits preclude the occurrence of flow instability in a bounding accident, a DEGB LOCA, the risk of CHF and attendant burnout is negligible. A review of RDAP data revealed that in the past reactor assemblies operated at flow and power conditions similar to those expected in a LOCA without burnout occurring. This is strong bounding empirical evidence, without the scaling concerns of laboratory experiments. A bounding analysis of the influences of assembly non-idealities on CHF, power tilts, and channel eccentricity, is included. The margin between operating heat fluxes, during the postulated LOCA, and CHF was quantified by scoping calculations. Based on measured azimuthal power variations, the local heat flux would have to be more than 20 standard deviations above the calculated mean heat flux for CHF to occur.

2. Introduction

Critical heat flux (CHF) is the heat flux required for the transition from nucleate to film boiling. Nucleate boiling enhances heat transfer from a surface and film boiling retards it. This is due to the insulating effect of the vapor film that blankets the surface in film boiling. In the subcooled boiling regime, the high heat flux required for the transition from nucleate to film boiling generally means that the surface temperature quickly exceeds safe material temperatures, once CHF is reached, and physical burnout takes place. The criterion for avoiding burnout is therefore to prevent the local heat flux from exceeding CHF.

At operating powers presently contemplated for the SRS reactors, 1250 to 1300 MW, subcooled CHF is very unlikely to occur during the flow instability (FI) phase of a DEGB LOCA. The onset of significant voiding (OSV), the criterion for FI, will be a precursor to CHF, and therefore a separate burnout risk analysis is not necessary. This conclusion is supported by the results of the three-part study described in this document. The CHF correlations, used in the assembly code FLOWTRAN, are applicable for flow conditions in Mk-22 assemblies predicted for the FI phase of a LOCA. Historically,

assemblies have operated, without burnout, with flow conditions more severe than those expected in the accident. The peak wall heat flux, with a worst case combination of azimuthal asymmetries in assembly power and tube eccentricities, is unlikely to exceed CHF. These arguments are supported in the following three sections of this document.

3. Assessment of CHF Correlations

The occurrence of CHF in reactor assemblies is predicted by empirical correlations, developed at SRL. They predict CHF for downflow forced convection, subcooled nucleate boiling. These correlations are equations 2.4-33 through 2.4-40 in reference [1], and they are used in the assembly code FLOWTRAN [1]. The development of the correlations is documented by references [2] through [4]. There are correlations for aluminum and stainless steel surfaces, cooled by either H₂O or D₂O. There are two correlations for each set of physical parameters. The second correlation applies to subcoolings less than 20 degrees Celsius.

Aluminum with H₂O flowing

$$\begin{aligned} q_{\text{crit}}'' &= 92700(1 + 0.145V)[1 + 0.031(T_{\text{sat}} - T_b)] \\ \text{or} \\ q_{\text{crit}}'' &= 356000(1 + 0.0515V) \end{aligned} \quad (1)$$

Aluminum with D₂O flowing

$$\begin{aligned} q_{\text{crit}}'' &= 107500(1 + 0.145V)[1 + 0.031(T_{\text{sat}} - T_b)] \\ \text{or} \\ q_{\text{crit}}'' &= 413400(1 + 0.0515V) \end{aligned} \quad (2)$$

Stainless steel with H₂O flowing

$$\begin{aligned} q_{\text{crit}}'' &= 75738(1 + 0.145V)[1 + 0.031(T_{\text{sat}} - T_b)] \\ \text{or} \\ q_{\text{crit}}'' &= 290860(1 + 0.0515V) \end{aligned} \quad (3)$$

Stainless steel with D₂O flowing

$$q_{\text{crit}}'' = 87775(1 + 0.145V)[1 + 0.031(T_{\text{sat}} - T_b)]$$

or

$$q_{\text{crit}}'' = 337547(1 + 0.0515V) \quad (4)$$

where:

q_{crit}''Critical heat flux, $\frac{\text{Btu}}{\text{hr ft}^2}$

VCoolant velocity, $\frac{\text{ft}}{\text{s}}$

T_{sat}Saturation temperature, °C

T_bFluid temperature, °C

The above correlations cover the following range of conditions:

- (1) Velocity: 5.5 to 42.5 ft/s
- (2) Subcooling: 20 to 107° C
- (3) Pressure: 40 to 80 psig
- (4) Equivalent diameter: 0.44 to 0.5 in
- (5) Channel width: 1.00 to 2.05 in
- (6) Channel width/channel thickness: 4 to 9.3
- (7) Ribs: nonconducting, fiber glass, rectangular geometry

Figure 1 shows the CHF for an aluminum surface with D₂O flowing, equation 2, as functions of the subcooling for fluid velocities of 20, 30, and 40 ft/s. CHF is independent of the subcooling for subcooling values less than 20° C, [2].

Figure 1. CHF for Aluminum and D₂O

The SRL CHF correlations were reanalyzed to address two concerns: (1) the validity of the assumption that CHF is solely a function of local conditions, and (2) their application outside of the parameter ranges investigated. The concern over the local conditions hypothesis cannot be addressed by looking at the experimental data, because the CHF tests were conducted with twenty-four inch long uniformly heated test sections. However it is generally accepted that under subcooled and low quality conditions, CHF is a local phenomenon, [5] and [12]. Subcooled critical heat flux is dependent on the bubble growth rate in the thin superheated boundary layer, adjacent to a heated wall. The free stream flow is essentially single-phase. For long tubes ($L/D > 20$) the structure of this boundary layer is a function of the local wall heat flux and local flow parameters. Weisman [5] developed a good mechanistic subcooled CHF model based on the "local conditions hypothesis". The SRL CHF correlations are not applicable to saturated boiling conditions, conditions where this hypothesis is not applicable.

The three main flow channels of a Mark 22 assembly have hydraulic diameters of .3190, .4751, and .3255 inches, [6]. The SRL tests with an annular geometry and ribs, that were used to develop the

presently used CHF correlations, had a hydraulic diameter range of .44 to .5 in, [4]. Only the middle channel in a Mark 22 assembly falls in this range. Since the correlations are empirical, extrapolation is questionable. Fortunately, earlier tests at SRL were run with a wider range of hydraulic diameters. Figure 2 shows the ratio of calculated to measured CHF for the Cu/Ni data in reference [7], as functions of the hydraulic diameter. The range covered was .238 to .467 in., and these tests were downflow through short uniformly heated annuli. The data appears to be independent of the hydraulic diameter, and it covers the hydraulic diameter range of the Mark 22 assembly. Data with a single type of heater material was chosen to isolate the hydraulic diameter dependence.

The SRL CHF correlations are valid for subcooled boiling, with flow conditions that are expected in Mark 22 assemblies. For SRS reactors at restart, burnout risk (BOR) need only to be considered for subcooled boiling. Transient Protection Limits and LOCA-FI Limits are set to prevent the bulk fluid from reaching saturation temperature.

4. Review of RDAP Data

Prior to late 1986, reactor powers were not determined by LOCA-FI limits, and they were significantly higher than reactor powers contemplated for restart. Reactor Data Analysis Program (RDAP) files were reviewed for Mark-22 assemblies that operated with flow rates in the range 200 to 250 gpm. The flowzone one assembly flow rate, with the K 14.1 charge, will be approximately 225 gpm when the SCRAM power drop occurs during a LOCA, and operating experience, without burnout, under similar flow conditions strongly supports the argument that burnout is not a significant risk during a LOCA. Three cases were found where flowzone 5 flow rates met this criteria: the C 3.1 subcycle with a zone averaged flow rate of 246 gpm, the C 3.2 subcycle with a zone averaged flow rate of 233 gpm, and the C 5.1 subcycle with a zone averaged flow rate of 217 gpm. There are fifty-four assemblies in flowzone five of C reactor. The operation of these assemblies at near LOCA flow and power conditions, without burnout, is strong empirical evidence that FI power limits preclude burnout as a significant risk. This data does not suffer from the non-prototypical ambiguities of laboratory experiments. The C 5.1 subcycle data was investigated in detail, because it had the lowest average flow rate.

Figure 3 shows the positions of the flowzone five assemblies for the C 5.1 subcycle. They are on the periphery of the reactor core, where powers are low, and consequently the assemblies were orificed to reduce their flow. The coolant temperature rises along the flow zone five assemblies were approximately the same as those for the higher power interior assemblies.

Figure 3. Reactor Core Facemap, showing Flowzone Five Assemblies for the C 5.1 Subcycle

The C 5.1 subcycle ran from October 1984 to May 1985, and the assembly powers for flow zone five varied during this time period, peaking at the middle of the subcycle. On February 28, 1985, the flow zone averaged assembly flow rate was 215.4 gpm, and the average assembly power was 3.23 MW. The assembly powers were distributed over the range 2.57 to 3.86 MW. The distribution is close to normal, with a standard deviation of .305 MW. Figure 4 is a histogram, showing the distribution of assembly powers.

HISTOGRAM, C 5.1, FLOW ZONE 5

Figure 4. Distribution of Assembly Powers for the C 5.1 Subcycle, Flow Zone Five.

A simple steady-state assembly model was used to analyze flow conditions and determine how close to CHF the C 5.1, flow zone five assemblies were operating. Inputs to the model are assembly power and flow rate, inlet moderator temperature, and the tank bottom pressure. The flow is partitioned between the channels in accordance with the hydraulics manual, [6], and the axial and radial power distributions are close to those utilized by FLOWTRAN. The model calculates the axial pressure, velocity, and bulk temperature distributions for each of the three main flow channels of a Mark 22 assembly. It also calculates the local value of CHF, for each heat transfer surface, and determines the ratio of the local surface heat flux to CHF. The model is described in detail in appendix A. This model was used in this analysis rather than the more sophisticated assembly model, FLOWTRAN, because it has a much quicker computational turn-around time, and it is adequate for the task. It was considerably easier to include azimuthal non-uniformities, such as power tilts and tube eccentricities, in this simple model than it would have been with FLOWTRAN. The code was benchmarked with FLOWTRAN.

RDAP data includes the zone averaged flow rate, the inlet temperature, the assembly power, and the four assembly effluent temperatures, one for each quadrant of the assembly. The bottom

end fitting is partitioned into quadrants, and monitor pin thermocouples measure the mixed temperature of the three main flow channels, for each of the quadrants. The differences in the temperature rises of the coolant, in each of the quadrants, are a measure of the azimuthal non-uniformity of assembly power. If the influence of the azimuthal non-uniformity in power on axial mass flux is neglected, the ratio of assembly quadrant power to mean quadrant power is directly proportional to the ratio of the quadrant moderator rise to the mean temperature rise:

$$\frac{\dot{Q}_{\text{quad}}}{\dot{Q}_{\text{avg}}} = \frac{\Delta T_{\text{quad}}}{\Delta T_{\text{avg}}} \quad (5)$$

The influence of the power tilt on CHF is illustrated by an assembly with the mean power for flowzone five. Assembly 10/18 operated at 3.23 MW with an inlet temperature of 35.8° C, and a flow rate of 215.4 gpm. The assemblies are identified by the X/Y grid numbers shown in figure 3. The tank bottom pressure is assumed to have been 28.5 psia. The four quadrant effluent temperatures were 93.7° C, 88.8° C, 81.3° C, and 85.5° C. The average effluent temperature was 87.325° C, and the average quadrant power was .8075 MW. The four quadrant powers, calculated from equation 5, were .9074 MW, .8306 MW, .7131 MW, and .7789 MW respectively. Figure 5 shows the axial variation in the ratio of the local wall heat flux to the CHF for the inner surface of channel #2, the channel in which the closest approach to CHF occurred. Ratios for the hot quadrant and an average quadrant are shown. The peak value of the CHF ratio for the hot quadrant is .332 while the peak value for the case with an azimuthally uniform power distribution is .284. The assumed axial power shape is a modified cosine. It is shown in figure A3, along with the measured axial power shape from RDAP data. The highest power assembly in flowzone five operated at 3.86 MW. Figure 6 shows the CHF ratio for the hot quadrant of this assembly, 13/15. The peak value of the CHF ratio is .405. The wall heat flux, used in the hot quadrant calculations, is an average value for the surface in that particular quadrant, and is therefore lower than the local peak value.

The onset of flow instability criterion used in the calculation of FI power limits is the Saha-Zuber criterion for the onset of significant voiding (OSV), [8], suitably modified to account for system

uncertainties. For flows with Peclet numbers greater than 70,000 (a condition generally satisfied in the three main flow channels of a Mark 22 assembly) the Saha-Zuber criterion is a Stanton number of .0065. Seventy percent of this Stanton number criterion, .00455, is the FI phase limit criterion used in FLOWTRAN. The effect of the FI power limits uncertainty analysis is to lower the onset Stanton number. This can be accomplished by multiplying .00455 with an appropriate coefficient, α . FI power limits occur when the maximum local Stanton number equals the onset Stanton number.

$$\frac{St_{max}}{\alpha \times .00455} \geq 1.0 \quad (6)$$

where

$$St = \frac{Q}{\rho V C_p (T_{sat} - T)} \quad (7)$$

Values of α for the November 1989 preliminary FI power limits were calculated, and the results were used to calculate the Stanton number ratio, equation 6. The procedure for calculating α is described in appendix B. The coefficient α in equation 6 is a device that permits the approximate FI power limits criterion to be applied in the assembly model described in appendix A. It is not part of the FI power limits uncertainty analysis. Figure 7 shows the C 5.1 flowzone 5 values of the Stanton number ratio over the subcycle from October 1984 to May 1985. Results for maximum, minimum, and mean values of assembly power are shown. The tank bottom pressure for these results is 28.5 psia. For part of the subcycle, the majority of the 54 assemblies were operating at conditions that exceed the K-14.1 FI power limits criterion, without experiencing burnout, and some assemblies exceeded this criterion for the whole subcycle. This is strong empirical evidence that present FI power limits preclude the occurrence of CHF during a LOCA transient. The RDAP data does not involve geometric scaling, and except for the pressure, the power and flow parameters are similar to those expected at the power trim point in a LOCA.

Figure 5. Axial Distributions of the CHF Ratio in the Hot Quadrant and an Azimuthally Uniform Assembly, Channel #2, Assembly Power = 3.23 MW.

Figure 6. Axial variation in the CHF Ratio for the Hot Quadrant, Channel #2, Assembly Power=3.86 MW

Figure 7. Ratio of St to Power Limits Criterion for Flowzone 5 Assemblies, C 5.1 Subcycle

5. Impact of Azimuthal Non-Uniformity of Assembly Power

FI power limits are calculated with the two-dimensional version of FLOWTRAN, and 3-D effects are accounted for by the uncertainty analysis. CHF is a localized phenomena that can occur at hot spots on the assembly channel walls. In order to assess the potential impact of assembly axial asymmetries, the observed azimuthal variations in heat flux, for operating assemblies, was investigated statistically, and the worst case combination of asymmetric factors was also considered.

The distribution of assembly power tilts for the C 5.1 subcycle was investigated. The power tilts were determined by ratioing the assembly quadrant moderator temperature change to the average temperature change for that particular assembly.

$$\text{Power Ratio} = \frac{\Delta T_{\text{quad}}}{\Delta T_{\text{avg}}} \quad (8)$$

Four power ratios were determined for each assembly, and all five hundred assemblies were considered. The quadrant temperature changes were determined from RDAP data for January 14, 1985. Figure 8 shows the frequency distribution of assembly quadrant power ratios for the C 5.1 subcycle. The range of calculated power ratios is .7934 to 1.2406. The mean value of the power ratio is 1.0000 and the standard deviation is .044876.

In figure 9, the power ratio data is plotted as a probability distribution function. The horizontal ordinate is departure from the mean in standard deviations. Also shown is a normal distribution. The agreement between the two distributions is not great, and this is due to the fact that the power ratio distributions differ for different flowzones. The largest power tilts occur near the edge of the reactor core. The four largest power tilts for the C 5.1 RDAP data are in flowzones five and six. The probability distribution function (PDF) in figure 9 is the sum of several distributions with different variances and shapes.

Frequency Distribution of Quad. Power Ratios

Figure 8. Frequency Distribution of Power Ratios For the C 5.1 Subcycle

PDF of Power Tilts for C-5.1 Subcycle

Figure 9. PDF of Power Ratios for C 5.1 RDAP Data

Figure 10 shows the PDF for flowzones one through three, along with a normal distribution. The agreement between the two PDF's is good. There are 386 assemblies in these three flowzones, and these are the flowzones where power limits are set. The outer flowzones have low power assemblies. The standard deviation for the power ratios in the interior flowzones is .023727. This is 53% of that for the entire core.

Figure 11 is the frequency distribution of power ratios for flowzone five. There are 54 assemblies in this flowzone, and they are all near the periphery of the core. Figure 3 is a reactor core face map that shows the positions of the flowzone five assemblies. The power ratio distribution has a standard deviation of .091443, and it is bimodal. This is due to the fact that these assemblies are near the core edge, and there is a systematic power tilt towards the core center. The standard deviation is twice that of the entire core and almost four times that of the interior flowzones, one through three.

The quadrant power ratio distributions from the C 5.1 subcycle will be used to predict the influence of azimuthal non-uniformities on CHF in K 14.1 assemblies. The assembly code described in appendix A was run with the November 1989 flowzone one FI power limits,

equation B2. Both axisymmetric and asymmetric cases were run, and the local values of the CHF ratio were calculated. Figures 12 and 13 show the maximum CHF ratios as functions of the plenum inlet temperature and the assembly power. The flow conditions are those expected at the point when the power is trimmed in a LOCA, 225 gpm assembly flow rate and 19.5 psia tank bottom pressure. The two azimuthally non-uniform cases shown are for power tilts that are four standard deviations from the mean. The standard deviations for the two cases are for the whole core and flowzones one through three. Plus or minus four standard deviations encompasses the variation in quadrant power ratios observed in the C 5.1 RDAP data, and therefore the plus four sigma CHF ratios should be bounding values. The FI power limits provide a considerable margin for the occurrence of CHF in an assembly.

Figure 10. PDF for Quadrant Power Ratios for Flowzones 1-3

Figure 11. Frequency Distribution for Power Ratios for Flowzone 5 of the C 5.1 Subcycle.

Influence of Azimuthal Non-Uniformities

Figure 12. Maximum Values of the CHF Ratio at the FI Power Limits, 225 gpm 19.5 psia (P_{tb}).

Figure 13. Maximum Values of the CHF Ratio at the FI Power Limits, 225 gpm & 19.5 psia Tank Bottom Pressure (P_{tb}).

Quadrant average heat fluxes were used to calculate the CHF ratios that are shown in figures 12 and 13. The CHF ratios at localized peak heat fluxes could be higher. In order to bound the effect of localized heating, the worst possible combination of asymmetric factors was analyzed. Two types of factors were considered; those that contribute to an azimuthally non-uniform power distribution, and geometric factors that locally restrict the flow. CHF ratios, for both axisymmetric and asymmetric cases, at the FI power limits are presented.

During fabrication of the fuel and target tubes, azimuthal variations in the uranium and lithium thicknesses can occur, and they will result in azimuthally non-uniform power distributions in the two fuel tubes of an assembly. The relative position of a control rod also influences azimuthal power distributions. POWCOMB.FOR [9], a computer code that calculates the 3-D multiplier for the FI uncertainty analysis, was modified to calculate the worst case alignment of asymmetric power factors. The modified code is TILT.FOR, and it is listed in appendix C. Figure 14 shows the

azimuthal variation in normalized power of the two fuel tubes, for this configuration. The peak powers are approximately 40% above nominal. The code also determines the average fuel tube power for a quadrant. The average inner and outer fuel tube power multipliers for the hot quadrant are 1.34769 and 1.34180 respectively. These are multipliers for the nominal values of tube powers.

Figure 14. Azimuthal Variation in Power for the Inner and Outer Fuel Slugs

Eccentric positioning of the fuel and target tubes can reduce the cross-sectional areas of subchannels and their flow rates. The maximum value of the CHF ratio normally occurs in the outer flow channel, channel #2, and this is the channel in which eccentricity is considered. The channel surface on which the closest approach to CHF occurs is a function of core exposure. At the beginning of a cycle, this is in channel #2. The nominal values for the inner and outer radii of the outer flow channel are 1.6 and 1.77 inches respectively. The nominal clearance between the rib tips and the opposite channel wall is .015 inches. The maximum eccentricity occurs when two of the ribs contact the opposite wall, as shown in figure 15. This results in a 11.1% reduction in the subchannel cross-sectional area, and it is

reasonable to assume a corresponding reduction in flow rate. There is an additional reduction in flow rate due to the fact that the subchannel pressure drop is essentially invariant with respect to eccentricity. With the assumption that the friction factor is unchanged, it can be easily shown that the ratio of the eccentric to symmetric velocities is approximately equal to the fourth root of the ratio of eccentric to symmetric subchannel cross-sectional areas. For channel #2, with a 11.1% reduction in area, the flow velocity is reduced by approximately 3%. The worst possible configuration, with respect to CHF, is when the peak power occurs in the smallest subchannel.

Figure 15. Maximum Eccentricity in the Outer Flow Channel

The assembly code described in appendix A was run with the November 1989 flowzone one FI power limits, equation B2. Both axisymmetric and asymmetric cases were run, and the local values of the CHF ratio were calculated. Figures 16 and 17 show the maximum CHF ratios as functions of the plenum inlet temperature and the assembly power. Axisymmetric and hot subchannel values are shown. The flow conditions are those expected at the point when the power is trimmed in a LOCA, 225 gpm assembly flow rate and 19.5 psia tank bottom pressure.

For the axisymmetric cases, the maximum values of the CHF ratio vary from .26 to .33. Over the same range of inlet temperatures or assembly powers, the asymmetric values vary from .43 to .62. The worst possible assembly configuration will not have any surface operating beyond CHF. There is considerable margin with respect to CHF, and this configuration is highly unlikely. The eccentricity is assumed to be in the same azimuthal direction along the whole length of the assembly. This assumption is conservative, but probably not realistic.

Influence of Azimuthal Non-Uniformities

Figure 16. Maximum Values of the CHF Ratio at the FI Power Limits, 225 gpm & 19.5 psia P_{tb} .

Influence of Azimuthal Non-Uniformities

Figure 17. Maximum values of the CHF Ratio at the FI Power Limits, 225 gpm & 19.5 psia P_{tb}.

The worst configuration, with an inlet temperature of 20° C and an assembly power of 3.653 MW, would have a worst quadrant power ratio of 1.507. This is 11.3 standard deviations out if the whole core variance is used, 21.4 standard deviations out if the variance for flowzones one through three is used, and 5.5 standard deviations out if the variance for flowzone five is used. The probability of such a configuration occurring in the interior flowzones is negligible. The probability of a worst case power tilt occurring is greater for assemblies on the edge of the reactor core, but these assemblies operate at power levels considerably lower than the power limits for the interior assemblies. The burnout risk for these assemblies is therefore negligible.

6. Conclusions

At the reactor powers that are contemplated for K Reactor restart, the probability of CHF occurring during the FI phase of a LOCA is negligible, and therefore a separate burnout risk analysis is not

necessary. The strongest argument in support of this recommendation is the C reactor RDAP data. Reactor assemblies operated for lengthy periods at flow and power conditions more severe than those expected during the FI phase of a LOCA, without experiencing burnout. The adverse consequences of burnout, if it were to occur in an isolated assembly during a LOCA, are also not catastrophic. Burnout would be confined to a hot spot in an assembly, and would not be self-propagating. Fission products from the area where burnout occurred would be released into the moderator. In view of the negligibly small probability of occurrence of CHF and limited adverse consequences, the suggestion that a separate burnout risk analysis is not necessary is reasonable. Some of the arguments are heuristic, but summed together they present a strong case.

REFERENCES

1. S. E. Aleman, M. V. Gregory, L. L. Hamm, L. D. Koffman, R. E. Pevey, W. H. Reed, and F. G. Smith, FLOWTRAN: An Algorithm for Describing the Thermal-Hydraulic Behavior of SRP Assemblies, DPSTM-140, September 1989.
2. D. H. Knoebel, Subcooled Burnout Correlation for Annuli ($T_{sub} < 200\text{ C}$), DPST-68-303, April 1968.
3. D. H. Knoebel, S. D. Harris, B. Crain Jr., R. M. Biderman, Forced-Convection Subcooled Critical Heat Flux, DP-1306, February 1973.
4. M. W. Hodges, Burnout Heat Flux with Rib Contact, DPST-73-206, March 1973.
5. J. Weisman, and B. S. Pei, "Prediction of Critical Heat Flux in Flow Boiling at Low Qualities", *Int. J. Heat Mass Transfer*, Vol 26, No. 10, 1463-1477 (1983).

6. L. D. Koffman, Analysis of CMX Hydraulic Data for the Mark 22, DPST-88-975, December 1988.
7. S. Mirshak, W. S. Durant, and R. H. Towell, Heat Flux at Burnout, DP-355, February 1959.
8. P. Saha, and N. Zuber, "Point of Net Vapor Generation and Vapor Void Fraction in Subcooled Boiling", *Proceedings of the Fifth International Heat Transfer Conference*, Vol 4, Sept. 1974.
9. B. J. Hardy, Documentation for Computer Code POWCOMP.FOR, Memo to N. H. Kuehn, NES-RFI-890133, November 1989.
10. A. K. Jain, "Accurate Explicit Equation for Friction Factor," *ASCE J. Hydraulics Div.*, **102**, 674-677 (1976).
11. W. M. Massey, D. P. Griggs, and S. D. Painter, Flow Instability Analysis of a Design Basis LOCA for the K-14.1 Subcycle, WSRC-RP-89-1287, December 1989.
12. A. E. Bergles, "Burnout in Boiling Heat Transfer. Part II: Subcooled and Low-Quality Forced-Convection Systems", *Nuclear Safety*, Vol 18, No. 2, 154-167 (1977).

Appendix A

Assembly Model

A simple steady-state reactor assembly model was written for this analysis. The model predicts steady-state flow conditions in the three main coolant channels of a Mark 22 assembly, and its purpose is to calculate local values of the critical heat flux in these channels. Inputs to the model are the assembly flow rate, assembly power, inlet temperature, and the tank bottom pressure. The flow is partitioned between the channels as prescribed by reference [6], an analysis of assembly hydraulic tests. The axial power distribution is the sum of a uniform distribution and a sinusoidal distribution, with 75% of the total power allocated to the sinusoidal distribution. The partitioning of power between the two fuel tubes and the radial split of heat flux between the two surfaces of a fuel tubes were determined from beginning of cycle FLOWTRAN results.

The governing equations solved in this model are the integral forms of the continuity, energy, and momentum equations for steady-flow of an incompressible fluid.

Continuity equation:

$$\int_A \rho \vec{V} \cdot d\vec{A} = 0 \quad (A1)$$

Momentum equation:

$$\sum \vec{F} = \int_A \rho \vec{V} (\vec{V} \cdot d\vec{A}) \quad (A2)$$

Energy equation:

$$\frac{\dot{Q}}{A} = \int_A \rho C_p T \vec{V} \cdot d\vec{A} \quad (A3)$$

Figure A1 is a schematic of the nodalization in a heated channel. Since the mass flow rate and wall heat flux are specified, the axial temperature distribution can be determined directly from the energy equation, by marching axially down the channel. In this simple form of the energy equation, axial conduction and kinetic energy effects

are neglected. The Peclet numbers for the channel flows are approximately 300,000.

$$\dot{m}C_p T_{i-1} + \dot{Q}_{i-1} A_{sw} = \dot{m}C_p T_i \quad (A4)$$

and

$$T_i = T_{i-1} + \frac{\dot{Q}_{i-1} A_{sw}}{\dot{m}C_p} \quad (A5)$$

Figure A1. Nodalization in a Heated Channel

With the axial temperature distribution, the local density can be calculated, $\rho = \rho(T)$. The axial velocity distribution can then be determined from the continuity equation.

$$u_i = \frac{\dot{m}}{\rho_i A} \quad (A6)$$

The pressure distribution is determined from the momentum equation. The tank bottom pressure is an input. This pressure was chosen over the plenum pressure because it is independent of flowrate. The tank bottom pressure is the sum of the gas space pressure and the hydrostatic pressure of the moderator. Channel

exit pressures are determined from the mechanical energy equation for the bottom end-fitting. Figure A2 shows a nodal control volume in a channel, and the associated external forces. The steady-state momentum equation equates the net external force to the net momentum rate leaving the control volume.

$$\sum \vec{F} = \dot{M}_{out} - \dot{M}_{in} \quad (A7)$$

Figure A2. Nodal Control Volume with Applied Forces

Substituting appropriate expressions for the forces, the momentum equation takes the following form:

$$A(P_{i-1} - P_i) - \frac{\dot{m}}{2} f \frac{\Delta x}{D_h} \left(\frac{u_i + u_{i-1}}{2} \right) + \frac{1}{2}(\rho_i + \rho_{i-1})A \Delta x g = \dot{m}(u_i - u_{i-1})$$

and

$$P_{i-1} = P_i + \frac{\dot{m}}{4A} f \frac{\Delta x}{D_h} (u_i + u_{i-1}) - (\rho_{i-1} + \rho_i) \frac{\Delta x g}{2} + \frac{\dot{m}}{A} (u_i - u_{i-1}) \quad (A8)$$

The channel pressure distribution is determined by marching backwards up the channel.

Polynomial approximations are used to determine the temperature dependence of the density and dynamic viscosity of D₂O. These correlations are valid over the range 280 to 480 K.

$$\begin{aligned}\rho(T) &= 933.56 + 1.4624 T - 2.9848 \times 10^{-3} T^2 \frac{\text{kg}}{\text{m}^3} \\ \mu(T) &= [1.4839 \times 10^5 - 1462.1 T + 5.4205 T^2 - 8.9307 \times 10^{-3} T^3 \\ &\quad + 5.5085 \times 10^{-6} T^4] \times 10^{-6} \text{ Pa-s}\end{aligned}\tag{A9}$$

The friction factor is calculated by an explicit approximation of the Colebrook formula, [10], for the turbulent regime, and a third order polynomial is used for the transition regime.

$$\begin{aligned}f &= \frac{64}{\text{Re}_D} \quad \text{Re}_D \leq 2300 \\ f &= .23158 - 2.0549 \times 10^{-4} \text{Re}_D + 6.6351 \times 10^{-8} \text{Re}_D^2 - 6.7336 \times 10^{-12} \text{Re}_D^3 \\ &\quad 2300 \leq \text{Re}_D \leq 4000 \\ f &= \left[1.14 - 2 \log_{10} \left(\frac{\epsilon}{D} + \frac{21.25}{\text{Re}_D^9} \right) \right]^{-2} \quad \text{Re}_D \geq 4000\end{aligned}\tag{A10}$$

The diameter in the Reynolds number is the channel hydraulic diameter, [6]. Values for the channel roughnesses were chosen so the channel pressure drops match those of FLOWTRAN.

The channel exit pressures are determined by applying the mechanical energy equation to the bottom end fitting. One equation calculates the pressure at the top of the end fitting, and three separate equations calculate the channel exit pressures. A loss coefficient accounts for irreversible losses through the end fitting, and its value is dependent on the number of shell holes. Form losses for the channel exits were determined from FLOWTRAN. The flow through the bottom end fitting is assumed to be adiabatic, and well mixed thermally. The mixed temperature includes the purge channel flows. Approximately 1.5% of the flow passes through the purge channels, and they receive approximately 0.6% of the heat.

The axial power distribution for the C 5.1 assemblies is modeled as the sum of a uniform and a sinusoidal distribution, with 75% of the power in the sinusoidal component.

$$\dot{Q}(z) = \dot{Q}_{avg} \left(.25 + \frac{3\pi}{8} \sin \frac{\pi z}{L} \right) \quad (A11)$$

Figure A3 shows a comparison between the assumed axial power distribution and the actual power distribution, from RDAP data, for gang III and the buckle zone of the C 5.1 subcycle. The assumed power distribution is a close approximation.

Figure A3. Comparison Between Assumed and Actual Axial Assembly Power Distributions, Gang III and the Buckle Zone, C 5.1 Charge.

The axial power distribution used by FLOWTRAN to calculate FI power limits is the worst expected in a flowzone. For a specified assembly power, the peak power is higher than the distribution shown in figure A3, and the peak is skewed further towards the bottom of the assembly. The functional form of the model of this distribution is the sum of four sine curves with different periods and

offset with respect to each other. The distributions are shown in figure A4.

$$\begin{aligned} \dot{Q}(z) = \dot{Q}_{avg} \{ & \alpha + (1-\alpha)A \left[\sin \frac{\pi x}{L} + \sin \frac{\pi}{.9} \left(\frac{x}{L} - .1 \right) \right]_{\frac{x}{L} \geq .1} \\ & + \sin \frac{\pi}{.8} \left(\frac{x}{L} - .2 \right) \Big|_{\frac{x}{L} \geq .2} + \sin \frac{\pi}{.7} \left(\frac{x}{L} - .3 \right) \Big|_{\frac{x}{L} \geq .3} \} \\ \alpha = .3381 \quad & A = \frac{\pi}{6.8} \end{aligned} \quad (A12)$$

Figure A4. Comparison Between Assumed and Actual K 14.1 Axial Power Distributions.

The radial power splits between the two fuel tubes and the two surfaces of a tube were determined from FLOWTRAN results. The assembly power of the case considered was 5.417 MW, and the rate of heat transfer to the three main flow channels was 995,316.6 W, 2,717,327.7 W, and 1,670,057.9 W respectively for the inner, middle, and outer flow channels. .625% of the power goes to the two purge channels, leaving 5.383 MW to be transferred to the three main flow channels. Heat is transferred to the three channels through four

surfaces, so an additional piece of information is required to calculate the four surface power fractions. The axial temperature distributions in the middle and outer flow channels are close to equal. If the heat generation rate in the outer fuel tube is assumed to be uniform, the two surface heat flux fractions can be calculated from the heat conduction equation. The channel heat transfer rates can be used to calculate the remaining radial power splits.

Figure A5 shows the procedure for calculating the surface power splits for the outer fuel tube, assuming the two wall temperatures are the same. From the radial temperature distribution, the adiabatic point, the point at which the radial temperature gradient is zero, is determined. Heat generated inside of this boundary is transferred through the inside surface, and heat generated on the other side is transferred through the outside surface.

Figure A5. Radial Temperature Profile in the Outer Fuel Tube

The governing equation for radial heat conduction, with uniform internal heat generation is:

$$\frac{d^2T}{dr^2} + \frac{1}{r} \frac{dT}{dr} + \frac{q^*}{kr} = 0$$

$$@ r = r_i \Rightarrow T = T_w$$

$$@ r = r_o \Rightarrow T = T_w \quad (A13)$$

The solution to this differential equation is:

$$T = T_w + \frac{q^*}{4k} \left[(r_o^2 - r_i^2) \frac{\ln \frac{r}{r_i}}{\ln \frac{r_o}{r_i}} - (r^2 - r_i^2) \right] \quad (A14)$$

and

$$\frac{dT}{dr} = \frac{q^*}{4k} \left[\frac{r_o^2 - r_i^2}{\ln \frac{r_o}{r_i}} \frac{1}{r} - 2r \right] \quad (A15)$$

The radial point where the temperature gradient is zero is:

$$r = \sqrt{\frac{(r_o^2 - r_i^2)}{2 \ln \frac{r_o}{r_i}}} \quad (A16)$$

The inner and outer radii of the outer fuel tube are 1.446 in and 1.6 in, respectively, and the radius of the adiabatic point is 1.522 in. The fractions of generated heat transferred through the two surfaces of the tube are the ratios of cross-sectional areas inside and outside of the adiabatic boundary to the total tube cross-sectional area. 48.3% of the heat generated in the outer fuel tube is transferred through the inner surface, and 51.7% is transferred through the outer surface. All of the heat transferred to the outer flow channel is assumed to come from the the outer fuel tube, and for the case with an assembly power of 5.417 MW, the power generated in the outer fuel tube is 3.2303 MW or 60.012% of the heat transfer rate to the three flow channels. 39.988% of the power is generated in the inner fuel tube, in this case 2.1524 MW. 46.24% of the heat generated in the inner tube is transferred to the inner flow channel, and 53.76% is transferred to the middle flow channel. These power fractions are assumed to be independent of axial position.

Figures A6 through A8 show the axial variations in temperature, pressure, and velocity for the three main flow channels, as predicted by the assembly model. Also shown are FLOWTRAN results. The boundary conditions are: 224.9258 gpm flow, 20° C inlet temperature, tank bottom pressure 19.70738 psia, and 5.4166 MW assembly power. These are flow conditions from 1.37 seconds into the FLOWTRAN LOCA transient. The steady-state results of the assembly model agree well with the FLOWTRAN transient results, at the approximate LOCA SCRAM. This supports the assumption that a steady-state assembly model can be utilized to obtain a snapshot of transient flow conditions.

Figure A6. Comparison Between FLOWTRAN and Assembly Model Results.

A printout of the code is included at the end of this appendix.

Axial Variation in Channel Velocity

Axial Variation in Channel Pressure

Figures A7 & A8. Comparison Between FLOWTRAN and Assembly Model Results

```

C      PROGRAM ASSEMBLY
C      THIS IS FILE ASSBE.FOR
C      *****
C      THIS PROGRAM CALCULATES THE PRESSURE AND TEMPERATURE
C      DISTRIBUTION IN THE THREE CHANNELS OF A MK-22 ASSY.
C      INPUTS ARE FLOWRATE, TANK BOTTOM PRESSURE, AND ASSY POWER.
C      THIS PROGRAM GIVES A QUICK LOOK AT ASSY FLOW CONDITIONS.
C      IT IS A STEADY-STATE MODEL. THE AXIAL POWER DISTRIBUTION
C      IS A MODIFIED COSINE, AND THE RADIAL DISTRIBUTION OF THE
C      POWER PER UNIT VOLUME IS ASSUMED TO BE UNIFORM.
C      *****
C
C      DIMENSION P(3,42),U(3,42),STNI(3,42),STNO(3,42)
C      DIMENSION T(3,42),RHO(3,42)
C      DIMENSION ZK(3,42),VIS(3,42),QI(3,42),QO(3,42)
C      DIMENSION D(3),DI(3),DO(3),A(3),ASWI(3),ASWO(3)
C      DIMENSION FLO(3),QI AVG(3),QO AVG(3),ZKCH(3)
C      DIMENSION CHFRTI(3,42),CHFERTO(3,42),ED(3),E(3)
C
C      DEN(T), VISC(T), AND FF#(RE) ARE RELATIONS FOR THE DENSITY
C      VISCOSITY, AND FRICTION FACTOR RESPECTIVELY.
C
C      DEN(T)=933.56+1.4624*T-2.9848E-3*(T**2)
C      VISC(T)=1.4839E5-1462.1*T+5.4205*(T**2)-8.9307E-3*(T**3)
C      $      +5.5085E-6*(T**4)
C      FF1(RE)=64.0/RE
C      FF2(RE)=.23158-2.0549E-4*RE+6.6351E-8*(RE**2)
C      $ -6.7336E-12*(RE**3)
C      FF3(ED,RE)=1.0/((1.14-2.0*A LOG10(ED+21.25/(RE**.9))**2)
C      OPEN (UNIT=10,FILE='ASSY-FLOW.DAT',STATUS='NEW')
C      OPEN (UNIT=11,FILE='ASSY-POWER.DAT',STATUS='NEW')
C      OPEN (UNIT=18,FILE='QCHF.DAT',STATUS='NEW')
C      OPEN (UNIT=12,FILE='ONSET.DAT',STATUS='NEW')
C
C      IMAX IS THE NUMBER OF AXIAL NODES, XL IS THE LENGTH OF THE
C      HEATED SECTION OF THE ASSEMBLY.
C
C      IMAX=42
C      IM=IMAX-1
C      IM2=IMAX-2
C      XL=4.12115
C
C      CHANNEL GEOMETRY IS SPECIFIED BY ITS INSIDE AND OUTSIDE DIAMETERS,
C      FLOW AREA, AND HYDRAULIC DIAMETER. THE THREE MAIN FLOW CHANNELS
C      ARE NUMBERED 2, 3, AND 4, WITH #4 AS THE INNER CHANNEL.
C
C      DI(2)=.08128
C      DO(2)=.089916
C      A(2)=1.1348364E-3
C      D(2)=.0081026
C      DI(3)=.0597662
C      DO(3)=.0734568
C      A(3)=1.390965E-3
C      D(3)=.01206754
C      DI(4)=.040386
C      DO(4)=.050673
C      A(4)=7.0451472E-4
C      D(4)=.00894588

```

```

C
C CHANNEL AREA REDUCTIONS ACCOUNT FOR ECCENTRICITY.
C
C      A(2)=.889*A(2)
C      A(3)=.9264*A(3)
C      A(4)=.9014*A(4)
C
C E IS THE WALL ROUGHNESS AND RIB IS THE WIDTH OF A RIB.
C ASWI(#) & ASWO(#) ARE INSIDE AND OUTSIDE HEATED WALL
C SURFACE AREAS OF THE NUMBERED CHANNELS.
C
      E(2)=4.5E-6
      E(3)=3.9E-6
      E(4)=4.5E-6
      RIB=.001524
      DX=XL/FLOAT(IMAX)
      DO 79 I=2,4
      ED(I)=E(I)/D(I)
79  CONTINUE
      PI=3.141592654
      DO 11 I=2,4
      ASWI(I)=(PI*DI(I)-4.0*RIB)*DX
      ASWO(I)=(PI*DO(I)-4.0*RIB)*DX
11  CONTINUE
C
C CP IS THE SPECIFIC HEAT OF D2O.
C
      G=9.80665
      CP=4186.8164
C
C THE ASSY. FLOW RATE IS A READ INPUT.
C
      WRITE (6,1)
1  FORMAT (' ENTER ASSY FLOWRATE (GPM) ')
      READ (5,2)FLOW
2  FORMAT (G18.9)
C
C TIN IS THE INLET TEMPERATURE AND PTKBOT IS THE
C TANK BOTTOM PRESSURE. QI(I,J) & QO(I,J) ARE THE WALL
C HEAT FLUX DISTRIBUTIONS.
C ZK(I,J) ARE LOSS COEFFICIENTS (IF NECESSARY).
C FLO(#) ARE THE CHANNEL MASS FLOW RATES, (KG/M3).
C FOR ECCENTRIC CHANNELS, THE FLOW RATES ARE MULTIPLIED BY
C THE AREA REDUCTION RATIO TO THE 1.25 POWER TO ACCOUNT
C FOR THE REDUCTION IN FLOW VELOCITY.
C
      WRITE (6,9000)
9000 FORMAT (' ENTER INLET TEMP (C) ',
      READ (5,9010)TIN
9010 FORMAT (G18.6)
      CCC1=.36579
      CCC2=-1.0558E-3
      CCC3=-2.0449E-5
      ALPST=CCC1+CCC2*TIN+CCC3*(TIN**2)
      TIN=TIN+273.16
      FLO(2)=.299601*FLOW
      FLO(2)=FLO(2)*6.30902E-5*DEN(TIN)
      FLO(3)=.476098*FLOW

```

```

FLO(3)=FLO(3)*6.30902E-5*DEN(TIN)
FLO(4)=.209297*FLOW
FLO(4)=FLO(4)*6.30902E-5*DEN(TIN)
C      FLO(2)=(.889**1.25)*FLO(2)
C      FLO(3)=(.9264**1.25)*FLO(3)
C      FLO(4)=(.9014**1.25)*FLO(4)
C
C PCIFLO & PCOFLO ARE FLOW RATES THROUGH THE TWO PURGE CHANNELS.
C PTKBOT IS THE TANK BOTTOM PRESSURE. DELZ & ZKBFLS ARE DELTA Z
C AND THE LOSS COEFFICIENT FOR THE BOTTOM END FITTING.
C AOUT IS THE ASSEMBLY CROSS-SECTION AREA AT THE TOP OF THE
C BOTTOM END FITTING.
C
      PCIFLO=.005176*FLOW*6.30902E-5*DEN(TIN)
      PCOFLO=.009828*FLOW*6.30902E-5*DEN(TIN)
      WRITE (6,9020)
9020  FORMAT (' ENTER TK BOT PRES (PSIA) ')
      READ (5,9030)PTKBOT
9030  FORMAT (G18.6)
      WRITE (10,1200)FLOW
      WRITE (10,1201)TIN
      WRITE (10,1202)PTKBOT
      PTKBOT=PTKBOT*6.894757E+3
      DELZ=.3048
C
C FOR: 36 SHELL HOLES ZKBFLS=10.8122
C      28 SHELL HOLES ZKBFLS=12.5844
C      20 SHELL HOLES ZKBFLS=15.19697
C
      ZKBFLS=10.8122
C      ZKBFLS=12.5844
C      ZKBFLS=15.19697
C
      AOUT=5.7316038E-3
      DO 15 J=1,IMAX
      DO 14 I=2,4
      QI(I,J)=0.0
      QO(I,J)=0.0
      ZK(I,J)=0.0
14    CONTINUE
15    CONTINUE
C
C AT THIS POINT ENTER THE WALL POWER DISTRIBUTION (W/M2).
C THE ASSY POWER IS A READ VARIABLE. THE SPLIT BETWEEN THE
C TWO FUEL SLUGS AND THE WALL HEAT FLUX SPLIT FOR A GIVEN SLUG
C ARE DETERMINED BY THE FOLLOWING SIX COEFFICIENTS.
C QIPCH & QOPCH ARE THE POWERS FOR THE TWO PURGE CHANNELS.
C
C      PARAMETER      0% BURNUP      55% BURNUP
C
C      PWOS           .60012         .540781
C      PWIS           .39988         .459219
C      POSOS          .517           .5124236
C      POSIS          .483           .4875764
C      PISOS          .5376          .52746
C      PISIS          .4624          .47254
C      QIPCH COF      .00115         .001911
C      QOPCH COF      .005096        .00475

```

```

C      PWOS=.60012
C      PWOS=PWOS*1.3418
C      PWIS=.39988
C      PWIS=PWIS*1.34769
      POSOS=.517
      POSIS=.483
      PISOS=.5376
      PISIS=.4624
      WRITE (6,5)
5      FORMAT (' ENTER ASSY POWER (MW) ')
      READ (5,6)QASSY
6      FORMAT (G18.6)
      WRITE (10,1203)QASSY
      QIPCH=.00115*QASSY
      QOPCH=.005096*QASSY
      QASSY=(QASSY-QIPCH-QOPCH)*1000000.0
      QIAVG(2)=(PWOS*POSOS*QASSY)/(FLOAT(IM2-1)*ASWI(2))
      QOAVG(2)=0.0
      QIAVG(3)=(PWIS*PISOS*QASSY)/(FLOAT(IM2-1)*ASWI(3))
      QOAVG(3)=(PWOS*POSI*QASSY)/(FLOAT(IM2-1)*ASWO(3))
      QIAVG(4)=0.0
      QOAVG(4)=(PWIS*PI*QASSY)/(FLOAT(IM2-1)*ASWO(4))
C
C      THE AXIAL POWER PROFILE IS CALCULATED IN THE FOLLOWING
C      LOOP. FOR K14.1 ASSEMBLIES THE PROFILE IS THE SUM OF
C      FOUR SINUSOIDAL FUNCTIONS, (INDENTED STATEMENTS). THE
C      C5.1 ASSEMBLIES USE THE SIMPLIER SINUSOIDAL FUNCTION.
C
      DO 25 J=2,IM2
      DO 24 I=2,4
      ALPHA=(FLOAT(J-2)+.5)/FLOAT(IM2-1)
      PI=3.14159265
      COFUP=.3381
      SINM=SIN(PI*ALPHA)
      IF (ALPHA .LT. .1)GO TO 18
      SINM=SINM+SIN((ALPHA-.1)*PI/.9)
      IF (ALPHA .LT. .2)GO TO 18
      SINM=SINM+SIN((ALPHA-.2)*PI/.8)
      IF (ALPHA .LT. .3)GO TO 18
      SINM=SINM+SIN((ALPHA-.3)*PI/.7)
18      PWCFF=COFUP+(1.0-COFUP)*(PI/6.8)*SINM
      QI(I,J)=QIAVG(I)*PWCFF
      QO(I,J)=QOAVG(I)*PWCFF
C      QI(I,J)=QIAVG(I)*(.25+(3.0*PI/8.0)*SIN(ALPHA*PI))
C      QO(I,J)=QOAVG(I)*(.25+(3.0*PI/8.0)*SIN(ALPHA*PI))
24      CONTINUE
25      CONTINUE
C *****
C      THIS IS THE START OF THE COMPUTATIONAL SECTION OF THE CODE.
C *****
      DO 52 K=2,4
      T(K,1)=TIN
      RHO(K,1)=DEN(T(K,1))
      VIS(K,1)=VISC(T(K,1))*1.0E-6
      U(K,1)=FLO(K)/(RHO(K,1)*A(K))
      DO 50 I=2,IMAX
      T(K,I)=T(K,I-1)+(QI(K,I-1)*ASWI(K)+QO(K,I-1)*ASWO(K))/

```



```

#      (FLO(K)*CP)
RHO(K,I)=DEN(T(K,I))
VIS(K,I)=VISC(T(K,I))*1.0E-6
U(K,I)=FLO(K)/(RHO(K,I)*A(K))
50  CONTINUE
52  CONTINUE
TPCHI=TIN+((QIPCH*1.E6)/(PCIFLO*CP))
TPCHO=TIN+((QOPCH*1.E6)/(PCOFLO*CP))
TOUT=(FLO(2)*T(2,IMAX)+FLO(3)*T(3,IMAX)+FLO(4)*T(4,IMAX)+
%      PCIFLO*TPCHI+PCOFLO*TPCHO)/
%      (FLO(2)+FLO(3)+FLO(4)+PCIFLO+PCOFLO)
VOUT=(FLO(2)+FLO(3)+FLO(4)+PCIFLO+PCOFLO)/(DEN(TOUT)*AOUT)
POUT=PTKBOT-DEN(TOUT)*(G*DELZ-(VOUT**2)*(ZKBFLS-.5))
C
C  DLZCHX IS THE ELEVATION DIFFERENCE BETWEEN THE START OF THE
C  BOTTOM END FITTING AND THE CHANNEL EXIT.  ZKCH(4) ARE CHANNEL
C  EXIT LOSS COEFFICIENTS.
C
DLZCHX=.0254+(DX/2.0)
ZKCH(2)=.02915
ZKCH(3)=1.357
ZKCH(4)=.2675
DO 62 K=2,4
P(K,IMAX)=DEN(T(K,IMAX))*((POUT/DEN(TOUT))-(G*DLZCHX
%      +((VOUT**2)*(.5+ZKCH(K)))-((U(K,IMAX)**2)/2.0))
DO 60 I=IM,1,-1
RE=((RHO(K,I+1)+RHO(K,I))*(U(K,I)+U(K,I+1))*D(K)*.5)/
#      (VIS(K,I+1)+VIS(K,I))
IF (RE .LE. 2300.0) THEN
FFAC=FF1(RE)
ELSE IF (RE .GE. 4000.0) THEN
FFAC=FF3(ED(K),RE)
ELSE
FFAC=FF2(RE)
END IF
P(K,I)=P(K,I+1)+(FLO(K)/(4.0*A(K)))*(ZK(K,I)+FFAC*(DX/D(K)))
#      * (U(K,I)+U(K,I+1))
#      - (RHO(K,I)+RHO(K,I+1))*(DX*G/2.0)+(FLO(K)/A(K))
#      * (U(K,I+1)-U(K,I))
60  CONTINUE
62  CONTINUE
C
C  AT THIS POINT THE VELOCITY, TEMPERATURE, AND PRESSURE
C  FIELDS HAVE BEEN CALCULATED FOR THE THREE HEATED CHANNELS.
C  THE LOCAL VALUE OF CHF AND THE CHF RATIO ARE CALCULATED.
C
C1=.37228924E3
C2=.88331901E2
C3=.10970751E2
C4=.97251708
C5=.51713769E-1
C6=.12129545E-2
DO 64 K=2,4
DO 63 I=1,IMAX
TSAT=C1+C2*ALOG(P(K,I)/21.671E6)+C3*((ALOG(P(K,I)/21.671E6))**2)
&      +C4*((ALOG(P(K,I)/21.671E6))**3)
&      +C5*((ALOG(P(K,I)/21.671E6))**4)
&      +C6*((ALOG(P(K,I)/21.671E6))**5)+273.15

```

```

      TSUB=TSAT-T(K,I)
      VEL=U(K,I)*3.28084
      QQ1=107500.0*(1.0+.145*VEL)*(1.0+.031*TSUB)
      QQ2=413400.0*(1.0+.0515*VEL)
      IF (QQ2 .LE. QQ1)GO TO 90
      QCRIT=QQ2
      GO TO 91
90    QCRIT=QQ1
91    CHFRTI(K,I)=(QI(K,I)*.17611)/QCRIT
C     CHFRTI(K,I)=CHFRTI(K,I)*(1.40004/1.34769)
      CHFERTO(K,I)=(QO(K,I)*.17611)/QCRIT
C     CHFERTO(K,I)=CHFERTO(K,I)*(1.40376/1.3418)
      DISTX=(FLOAT(I-1)+.5)*DX
      WRITE(10,1250)I,DISTX,CHFRTI(K,I),CHFERTO(K,I),K
      WRITE(18,1359)K,DISTX,QCRIT
C
C   THE LOCAL VALUE OF THE STANTON # IS CALCULATED
C
C     ALPST=1.0
C
      VEL=VEL/3.28084
      STNI(K,I)=QI(K,I)/(DEN(T(K,I))*VEL*CP*TSUB)
      STNO(K,I)=QO(K,I)/(DEN(T(K,I))*VEL*CP*TSUB)
      STNI(K,I)=STNI(K,I)/(ALPST*.00455)
      STNO(K,I)=STNO(K,I)/(ALPST*.00455)
      WRITE(11,1260)K,I,STNI(K,I),STNO(K,I)
63    CONTINUE
64    CONTINUE
      DO 67 K=2,4
      DO 66 I=1,IMAX
      WRITE(11,1260)K,I,QI(K,I),QO(K,I)
66    CONTINUE
67    CONTINUE
C
C   THE LOOP 71 AND THE TWO WRITE STATEMENTS TO THE SCREEN
C   SHOULD BE CHANGED TO BE CONSISTENT WITH THE EXPOSURE
C   OPTION.  ZERO BURNUP AND THE CRITICAL SURFACE IS THE
C   INSIDE OF CHANNEL #2, AND @ 55% BURNUP THE CRITICAL
C   SURFACE IS THE OUTSIDE OF CHANNEL #4.
C
      DO 71 I=1,IMAX
      K=2
      WRITE(12,1260)K,I,STNI(K,I),CHFRTI(K,I)
71    CONTINUE
      WRITE(6,2000)STNI(2,24),STNI(2,25),STNI(2,26),
      @          STNI(2,27),STNI(2,28),STNI(2,29)
2000  FORMAT(11H ST RATIO= ,6G12.6)
      WRITE(6,2005)CHFRTI(2,24),CHFRTI(2,25),CHFRTI(2,26),
      @          CHFRTI(2,27),CHFRTI(2,28),CHFRTI(2,29)
2005  FORMAT(12H CHF RATIO= ,6G12.6)
      WRITE(10,122)
122   FORMAT(' CHANNEL #4-DIST/V/P/T')
      DO 125 I=1,IMAX
      K=4
      DISTX=(FLOAT(I-1)+.5)*DX
      WRITE(10,1010)I,DISTX,U(K,I),P(K,I),T(K,I)
125   CONTINUE
      WRITE(10,132)

```

```

132  FORMAT(' CHANNEL #3-DIST/V/P/T')
      DO 135 I=1,IMAX
          K=3
          DISTX=(FLOAT(I-1)+.5)*DX
          WRITE(10,1010)I,DISTX,U(K,I),P(K,I),T(K,I)
135  CONTINUE
          WRITE(10,142)
142  FORMAT(' CHANNEL #2-DIST/V/P/T')
      DO 145 I=1,IMAX
          K=2
          DISTX=(FLOAT(I-1)+.5)*DX
          WRITE(10,1010)I,DISTX,U(K,I),P(K,I),T(K,I)
145  CONTINUE
          WRITE (10,1100)TOUT,VOUT,POUT
1010 FORMAT(I5,4G18.8)
1100 FORMAT(6H TOUT=,G15.6,6H VOUT=,G15.6,6H POUT=,G15.6)
1200 FORMAT(7H FLOW= ,G18.6,4H GPM)
1201 FORMAT(6H TIN= ,G18.6,2H K)
1202 FORMAT(14H PRES TK BOT= ,G18.6,5H PSIA)
1203 FORMAT(13H ASSY POWER= ,G18.6,3H MW)
C 1250 FORMAT(I5,3G15.6,7H CH # =,I3)
1250 FORMAT(I5,3G15.6,I6)
1359 FORMAT(I5,2G20.8)
1260 FORMAT(2I5,2G16.8)
      STOP
      END

```

Appendix B

FI Criterion

The onset of significant voiding (OSV) is always a precursor to flow instability, and it is therefore a conservative criterion for FI. The criterion for predicting OSV in an assembly is a modified form of the Saha-Zuber correlation, [8]. For flows with a Peclet number greater than 70,000, a local Stanton number of .0065 is a good predictor of OSV. Flows through the heated channels of a Mark 22 assembly generally have Peclet numbers greater than 70,000. Seventy percent of the Stanton number criterion, .00455, has been found to be a lower bound for OSV in SRS reactor assemblies, and this is the onset criterion for FI, that is used in power limits calculations. Because of the FI uncertainty analysis, this onset criterion, applied to the azimuthal average heat flux, is effectively lowered, and has the following form:

$$St_{OSV} = \alpha \times .00455 \quad (B1)$$

Values for the coefficient α were determined from the November 1989 preliminary FI power limits, [11]. The limits are assembly effluent temperature limits, as functions of the plenum inlet temperature. The effluent temperature limits are:

RECOMMENDED K-14.1 ASSEMBLY EFFLUENT TEMPERATURE LIMITS

FLOWZONE NUMBER	T _O °C	K ₁	K ₂
1	46.0	0.562	-0.000838
2	44.4	0.585	-0.000828
3	43.5	0.601	-0.000831
4	41.5	0.621	-0.000796
5	41.2	0.623	-0.000795

$$T_{eff} = T_O + K_1 * T_{in} + K_2 * (T_{in})^2$$

where: T_{eff} - Assembly effluent temperature (°C)

T_{in} - Plenum inlet temperature ($^{\circ}\text{C}$)

Note: This equation is valid only for plenum inlet temperatures ranging from 20° to 45°C .

Using a preincident of flow rate of 339 gpm, these limits can be converted to assembly power limits. Though second order, the limits are very close to linear over the inlet temperature range 20° to 45°C . For flowzone one, a first order approximation of the assembly FI power limit is:

$$\text{Power Limit (MW)} = 4.6288 - .049292*(T_{in}) \quad (\text{B2})$$

The assembly code described in appendix A was modified to calculate the local Stanton number distribution for each surface in the three heated channels.

$$\text{St} = \frac{\dot{Q}}{\rho V C_p (T_{sat} - T)} \quad (\text{B3})$$

The assembly flow rate and tank bottom pressure were assumed to be 225 gpm and 19.5 psia respectively, at the time in a LOCA transient when the power limit is reached. The K 14.1 charge axial power shape, figure A4, was also assumed. At this point the maximum Stanton number ratio, the ratio of the Stanton number to the OSV criterion, equation B1, has a value of one. The Stanton number modifier, α , can be calculated as a function of T_{in} , using the power limits of equation B2, and the maximum value of the local Stanton number. Figure B1 shows the distribution of α . Also shown is a second order polynomial curve fit:

$$\begin{aligned} \alpha &= C_1 + C_2 T_{in} + C_3 T_{in}^2 \\ C_1 &= .36579 \\ C_2 &= -1.0558 \times 10^{-3} \\ C_3 &= -2.0449 \times 10^{-5} \end{aligned} \quad (\text{B4})$$

Figure B1. Stanton Number Multiplier for OSV as a
Function of the Plenum Inlet Temperature

Inserting α into the assembly code allows the code to determine if FI power limits are exceeded. This occurs when the ratio of the maximum value of the Stanton number to the OSV Stanton number, equation B1, is greater than one. This feature of the code was utilized in analyzing the C reactor RDAP data. The coefficient α that is used in the FI power limits criterion, equation 6, is a device that allows the FI power limits to be calculated in the assembly code herein described. It was conceived for this analysis alone. It is not utilized in the FI power limits uncertainty methodology.

Appendix C

Code TILT.FOR

```
      PROGRAM TILT
C
C *****
C THIS PROGRAM CALCULATES THE RELATIVE AZIMUTHAL HEAT FLUX
C DISTRIBUTION FOR THE INNER AND OUTER FUEL SLUGS OF A
C MK-22 ASSEMBLY, WITH THE WORST POSSIBLE COMBINATION OF
C FACTORS CONTRIBUTING TO AN AZIMUTHAL POWER TILT. THIS
C PROGRAM IS DERIVED FROM POWCOMP40.FOR, RECD. FROM B. HARDY.
C *****
C
C ALITFI = INFLUENCE OF INNER LITHIUM CONCENTRATION ON INNER POWER
C ALITFO = INFLUENCE OF INNER LITHIUM CONCENTRATION ON OUTER POWER
C FITFI = INFLUENCE OF INNER FUEL CONCENTRATION ON INNER POWER
C FITFO = INFLUENCE OF INNER FUEL CONCENTRATION ON OUTER POWER
C FOTFI = INFLUENCE OF OUTER FUEL CONCENTRATION ON OUTER POWER
C FOTFO = INFLUENCE OF OUTER FUEL CONCENTRATION ON OUTER POWER
C ALOTFI = INFLUENCE OF OUTER LITHIUM CONCENTRATION ON INNER POWER
C ALOTFO = INFLUENCE OF OUTER LITHIUM CONCENTRATION ON OUTER POWER
C AZFI = INFLUENCE OF AZIMUTHAL FLUX TILT ON INNER POWER
C AZFO = INFLUENCE OF AZIMUTHAL FLUX TILT ON OUTER POWER
C
C THE ASSUMED FUNCTIONALITY OF THE EFFECTS IS SINUSOIDAL, EXCEPT
C FOR THE AZIMUTHAL FLUX TILT. IT IS DESCRIBED BY A HISTOGRAM;
C FACLIFI, FACFIFI, ...
C
      DIMENSION ALITFI(360),ALITFO(360),FITFI(360),FITFO(360),
@          FOTFI(360),FOTFO(360),ALOTFI(360),ALOTFO(360),
@          AZFI(360),AZFO(360),COMBI(360),COMBO(360),
@          POWFI(8),POWFO(8),POWF(4),PWF(4)
      DATA FACLIFI,FACFIFI,FACFIFO,FACFOFI,FACFOFO,FACLOFO,
@          FACLIFO,FACLOFI
      @/.08098,.70023,.06144,.10891,.69743,.04747,.0356,.08098/
      RAD=.0174533
      DO 1 I=1,360
        ALITFI(I)=1.+FACLIFI*.3*SIN(FLOAT(I)*RAD)
        ALITFO(I)=1.+FACLIFO*.3*SIN(FLOAT(I)*RAD)
        FITFI(I)=1.+FACFIFI*.3*SIN(FLOAT(I)*RAD)
        FITFO(I)=1.+FACFIFO*.3*SIN(FLOAT(I)*RAD)
        FOTFI(I)=1.+FACFOFI*.3*SIN(FLOAT(I)*RAD)
        FOTFO(I)=1.+FACFOFO*.3*SIN(FLOAT(I)*RAD)
        ALOTFI(I)=1.+FACLOFI*.3*SIN(FLOAT(I)*RAD)
1      ALOTFO(I)=1.+FACLOFO*.3*SIN(FLOAT(I)*RAD)
      DO 2 I=1,360
        IF(I .LE. 30)AZFI(I)=1.0903
        IF(I .LE. 60 .AND. I .GT. 30)AZFI(I)=1.0569
        IF(I .LE. 90 .AND. I .GT. 60)AZFI(I)=1.0057
        IF(I .LE. 120 .AND. I .GT. 90)AZFI(I)=.9753
        IF(I .LE. 150 .AND. I .GT. 120)AZFI(I)=.9418
        IF(I .LE. 180 .AND. I .GT. 150)AZFI(I)=.9358
        IF(I .LE. 210 .AND. I .GT. 180)AZFI(I)=.935
```

```

IF(I .LE. 240 .AND. I .GT. 210)AZFI(I)=.9431
IF(I .LE. 270 .AND. I .GT. 240)AZFI(I)=.9687
IF(I .LE. 300 .AND. I .GT. 270)AZFI(I)=1.014
IF(I .LE. 330 .AND. I .GT. 300)AZFI(I)=1.0484
IF(I .LE. 360 .AND. I .GT. 330)AZFI(I)=1.085
IF(I .LE. 30)AZFO(I)=1.1311
IF(I .LE. 60 .AND. I .GT. 30)AZFO(I)=1.0655
IF(I .LE. 90 .AND. I .GT. 60)AZFO(I)=1.0005
IF(I .LE. 120 .AND. I .GT. 90)AZFO(I)=.9539
IF(I .LE. 150 .AND. I .GT. 120)AZFO(I)=.9327
IF(I .LE. 180 .AND. I .GT. 150)AZFO(I)=.9293
IF(I .LE. 210 .AND. I .GT. 180)AZFO(I)=.9277
IF(I .LE. 240 .AND. I .GT. 210)AZFO(I)=.9324
IF(I .LE. 270 .AND. I .GT. 240)AZFO(I)=.9491
IF(I .LE. 300 .AND. I .GT. 270)AZFO(I)=.9976
IF(I .LE. 330 .AND. I .GT. 300)AZFO(I)=1.0623
IF(I .LE. 360 .AND. I .GT. 330)AZFO(I)=1.1178
2  CONTINUE
SUMI=0.0
SUMO=0.0
DO 3 I=1,360
J=90+I
IF(J .GT. 360)J=J-360
COMBI(I)=ALITFI(J)*FITFI(J)*FOTFI(J)*AZFI(I)*ALOTFI(J)
COMBO(I)=ALOTFO(J)*FITFO(J)*FOTFO(J)*AZFO(I)*ALITFO(J)
SUMI=COMBI(I)+SUMI
SUMO=COMBO(I)+SUMO
3  CONTINUE
DO 4 I=1,360
COMBI(I)=COMBI(I)*360.0/SUMI
COMBO(I)=COMBO(I)*360.0/SUMO
WRITE (6,1010)I,COMBI(I),COMBO(I)
4  CONTINUE
DO 25 I=1,8
POWFI(I)=0.0
POWFO(I)=0.0
25 CONTINUE
DO 5 I1=1,45
I2=I1+45
I3=I1+90
I4=I1+135
I5=I1+180
I6=I1+225
I7=I1+270
I8=I1+315
POWFI(1)=COMBI(I1)+POWFI(1)
POWFI(2)=COMBI(I2)+POWFI(2)
POWFI(3)=COMBI(I3)+POWFI(3)
POWFI(4)=COMBI(I4)+POWFI(4)
POWFI(5)=COMBI(I5)+POWFI(5)
POWFI(6)=COMBI(I6)+POWFI(6)
POWFI(7)=COMBI(I7)+POWFI(7)
POWFI(8)=COMBI(I8)+POWFI(8)
POWFO(1)=COMBO(I1)+POWFO(1)
POWFO(2)=COMBO(I2)+POWFO(2)
POWFO(3)=COMBO(I3)+POWFO(3)
POWFO(4)=COMBO(I4)+POWFO(4)
POWFO(5)=COMBO(I5)+POWFO(5)

```



```

        POWFO(6)=COMBO(I6)+POWFO(6)
        POWFO(7)=COMBO(I7)+POWFO(7)
        POWFO(8)=COMBO(I8)+POWFO(8)
5      CONTINUE
        POWF(1)=(POWFO(1)+POWFO(8))/90.0
        POWF(2)=(POWFO(2)+POWFO(3))/90.0
        POWF(3)=(POWFO(4)+POWFO(5))/90.0
        POWF(4)=(POWFO(6)+POWFO(7))/90.0
        PWF(1)=(POWFI(1)+POWFI(8))/90.0
        PWF(2)=(POWFI(2)+POWFI(3))/90.0
        PWF(3)=(POWFI(4)+POWFI(5))/90.0
        PWF(4)=(POWFI(6)+POWFI(7))/90.0
        DO 50 I=1,4
        WRITE (6,1000) PWF(I),POWF(I)
50     CONTINUE
1000  FORMAT (2G18.6)
1010  FORMAT(I5,2G18.6)
        STOP
        END

```

**DATE
FILMED
8/11/92**