**HIGH FLUX ISOTOPE REACTOR SYSTEM
RELAP5 INPUT MODEL**

D. G. Morris
Engineering Technology Division

M. W. Wendel
Computing Applications Division

Date Published: January 1993

Prepared by the
OAK RIDGE NATIONAL LABORATORY
Oak Ridge, TN 37831-6285
managed by
MARTIN MARIETTA ENERGY SYSTEMS, INC.
for the
U.S. DEPARTMENT OF ENERGY
under contract DE-AC05-84OR21400

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

CONTENTS

	<u>Page</u>
LIST OF FIGURES	vii
LIST OF TABLES	xi
NOMENCLATURE	xv
ABSTRACT	1
1. INTRODUCTION	1
2. FACILITY OVERVIEW	4
3. INPUT MODEL	10
3.1 OVERVIEW	10
3.2 VESSEL/CORE COMPONENT DESCRIPTIONS	15
3.2.1 Fuel Element	15
3.2.2 Fuel Labyrinth	30
3.2.3 Target	30
3.2.4 Control Cylinders	44
3.2.5 Beryllium Reflector	51
3.2.5.1 Hot removable reflector	51
3.2.5.2 Removable/semipermanent reflector	55
3.2.5.3 Permanent reflector	57
3.2.6 Core Bypass	63
3.2.7 Vessel/Pool Check Valve	65
3.2.8 Core Shrouds	65
3.2.9 Target Tower	69
3.2.10 Upper Plenum	69
3.2.11 Lower Plenum	74
3.2.12 Outlet	78
3.3 EXTRA-VESSEL COMPONENT DESCRIPTIONS	79
3.3.1 Piping	79
3.3.2 Heat Exchangers	83
3.3.3 Primary Coolant Pumps	88

	<u>Page</u>
3.3.4 Main and Standby Pressurizer Pumps	93
3.3.5 Auxiliary Pressurizer Pump	96
3.3.6 Letdown and Radiation Block Valves	96
3.3.7 Primary Coolant Head Tank	98
3.3.8 Secondary Coolant System	98
3.4 SYSTEM STIFFNESS	103
3.4.1 Mathematical Framework	103
3.4.2 Discussion of Terms	104
3.4.2.1 Term 1	104
3.4.2.2 Term 2	104
3.4.2.3 Term 3	111
3.4.2.4 Term 4	111
3.4.3 Combination of Terms	112
3.4.4 Inclusion in the Model	113
3.5 LOSS COEFFICIENTS	115
3.5.1 Strainer	116
3.5.2 Heat Exchanger Inlet and Outlet	118
3.5.3 Bends and Elbows	118
3.5.4 Wyes	119
3.5.5 Check Valves and Block Valves	120
3.5.6 Pressurizer Pump Discharge Line	121
3.5.7 Pressurizer Pump Suction Line	121
3.6 TRIPS	123
3.7 CONTROL VARIABLES	123
3.7.1 Primary Coolant Head Tank Level	123
3.7.2 Main Circulation Pumps	126
3.7.3 Main and Standby Pressurizer Pumps	138
3.7.4 Auxiliary Pressurizer Pump	138
3.7.5 Letdown Control and Radiation Block Valves	138

	<u>Page</u>
3.7.6 Secondary Coolant Flow	138
3.7.7 Secondary Coolant Pumps	138
3.7.8 Reactor Trip	138
3.7.9 Structural Elasticity	145
3.7.10 Emergency Depressurization	145
3.7.11 Cooling Tower Bypass	145
3.7.12 Leakage from the Primary Coolant System	145
3.7.13 Cooling Tower Heat Removal	148
3.7.14 Reactor Vessel Check Valve Flow	148
3.7.15 Additional Output	148
4. PREPROCESSING AND POSTPROCESSING	149
5. MODEL APPLICATION	150
5.1 STEADY STATE	150
5.2 COSTS AND RUN TIMES	153
REFERENCES	155
APPENDIX A. INPUT LISTING	167
APPENDIX B. MODELING CAVITATION OF THE HFIR PRIMARY	
COOLANT PUMPS	231
B.1. SUMMARY	231
B.2. PUMP CAVITATION MODEL	231
B.3. CALCULATION RESULTS	234
B.4. DAMAGE TO THE PUMP	235
B.4.1 Time of Exposure	236
B.4.2 Cavitation Erosion	237
B.4.3 Bearing Damage	240
B.4.4 Recommendation	240
B.5. CONCLUSIONS	240
REFERENCES	240
APPENDIX C. PREPROCESSING PROGRAM	243

	<u>Page</u>
APPENDIX D. POSTPROCESSING PROGRAM	257
APPENDIX E. ABBREVIATED MODEL FOR OPERATIONAL TRANSIENTS	263
E.1. COARSENING OF NODALIZATION	263
E.2. POINT KINETICS MODEL	265
E.2.1 Moderator Temperature Effects	265
E.2.2 Thermal Expansion Effects	270
E.2.3 Moderator Density Change in Control Region and Reflector	270
E.2.4 Control Cylinder Worth	270
E.2.5 Safety Rod Worth	270
E.2.6 Target Region Void Feedback	272
REFERENCES	273
APPENDIX F. INPUT LISTING FOR ABBREVIATED MODEL	275

LIST OF FIGURES

Figure	Page
1 Core	4
2 Fuel element	5
3 Vessel/core cross section	7
4 Reactor vessel and pools	8
5 Primary system	9
6 Schematic of the HFIR RELAP5 system model	11
7 Schematic of the HFIR RELAP5 vessel/core model	12
8 Reactor vessel coolant flow distribution	14
9 Heat load following shutdown	18
10 Cross section of fuel meat	20
11 HFIR fuel axial power distribution	26
12 Peaking factor as function of film coefficient with fuel meat thickness as parameter	29
13 Target assembly	32
14 Core cross section	33
15 HFIR target rod configuration	34
16 Schematic representation of control cylinders within HFIR core	45
17 Control cylinders	46
18 Reflector—plan at center line	52
19 Cross section through core and shrouds	66
20 Vertical section of HFIR lower plenum	75
21 Plan section of core support upper flange	77
22 Heat exchanger cells and pool structures	80
23 Primary coolant clean-up system	82
24 Heat exchanger flow path	84
25 Schematic of HFIR RELAP5 secondary system model	85
26 Heat exchanger discretization sensitivity	87
27 Homologous head curves for main circulation pumps	90
28 Homologous torque curves for main circulation pumps	90

Figure	Page
29 Comparison of RELAP5 simulated main circulating pump coastdown with experimental data	92
30 Comparison of RELAP5 simulated pressurizer pump coastdown with experimental data	94
31 Homologous head curves for main pressurizer pumps	95
32 Homologous torque curves for main pressurizer pumps	95
33 Relationship between PC head tank level and pressurizer pump suction pressure and percentage of tank volume containing water	99
34 HFIR secondary coolant system	100
35 Coastdown rate of secondary coolant pumps	101
36 Exaggerated deformation of pressurized HFIR reactor vessel without support constraint	107
37 Elasticity of HFIR reactor vessel without support constraint	108
38 Exaggerated deformation of pressurized HFIR reactor vessel with support constraint	109
39 Elasticity of HFIR reactor vessel with support constraint	110
40 Extraction of structural elasticity from experiments performed by Dixon	110
41 Water density dependence upon temperature according to RELAP5 water properties library	111
42 Water density dependence upon pressure according to the RELAP5 water properties library	112
43 Comparison of RELAP5 water density with ASME Steam Table values	113
44 Upper plenum pressure history during depressurization of system with and without elasticity model	114
45 Upper plenum history of change in pressure with respect to change in system volume during depressurization of system with and without the elasticity model	115
46 Measurements recorded for PdT103 from HFIR hourly checksheets	118
47 Loss coefficient configurations at wye junctions	120
48 Schematic of pressurizer pump suction line	122
49 Primary coolant head tank level control logic	134
50 Calculation of actual MCP speed during a pump coastdown	135
51 Calculation of head degradation factor for MCP cavitation	136

Figure	Page
52 Calculation of degraded pump speed for MCP cavitation	137
53 Main circulation pump control logic	139
54 Main and standby pressurizer pump control logic	140
55 Auxiliary pressurizer pump control logic	141
56 Letdown and radiation block valve control logic	142
57 Secondary coolant flow control logic	143
58 Secondary coolant pump control logic	144
59 Reactor trip control logic	146
60 Structural elasticity mass injection control logic	147
61 Pressures at steady state in RELAP5 model	151
62 Measurements recorded for PdT106 from HFIR hourly readings	153
B.1 Manufacturer's data for required suction head for HFIR primary coolant pumps	232
B.2 Nondimensionalized data for required suction head as function of pump flow	233
B.3 Normalized degraded pump head vs available suction head	234
B.4 Control of HFIR primary coolant pump speed	235
B.5 Flow delivered to reactor vessel during 2-in. break	236
B.6 Mass flow through PU-1D during 2-in. break	237
B.7 Closeup of mass flow through PU-1D during 2-in. break	238
B.8 Nondimensional suction head vs nondimensional flow rate during 2-in. break	239
E.1 Abbreviated model primary system nodal diagram	264
E.2 Abbreviated model core nodal diagram	266
E.3 Moderator temperature change contribution to reactivity change control logic	271
E.4 Inner fuel thermal expansion contribution to reactivity change control logic ...	272
E.5 Control logic for safety rod insertion after scram is initiated	272

LIST OF TABLES

Table	Page
1 HFIR core heat loads at nominal 85-MW power level	15
2 HFIR heat load after scram	16
3 Fuel plate meat composition	22
4 Fuel meat specific heat and volumetric heat capacity	23
5 Fuel meat thermal conductivity	24
6 Clad specific heats and volumetric heat capacity	24
7 Clad thermal conductivity	25
8 Oxide (boehmite) specific heat and volumetric heat capacity	25
9 Normalized HFIR fuel axial power peaking factors	27
10 Hot channel and local power peaking factors	28
11 Fuel internal source multipliers for HFIR RELAP5 model	31
12 Target pellet core composition per rod	37
13 Pellet core specific heat and volumetric heat capacity	38
14 Pellet aluminum jacket specific heat and volumetric heat capacity	38
15 Target pellet containment tube specific heat and volumetric heat capacity	42
16 Target pellet containment tube thermal conductivity	43
17 Target axial power peaking factors and RELAP5 internal source multipliers ...	44
18 Radial boundaries of regions comprising the control cylinders	48
19 Control cylinder core specific heat and volumetric heat capacity	49
20 Control cylinder clad volumetric heat capacity	49
21 Control cylinder clad thermal conductivity	49
22 Control cylinder axial power peaking factors and RELAP5 internal source multipliers	50
23 Radial boundaries of regions comprising the hot removable reflector cylinders	53
24 Beryllium specific heat and volumetric heat capacity	54
25 Beryllium thermal conductivity	54
26 Hot removable beryllium reflector axial power peaking factors and RELAP5 internal source multipliers	55

Table	Page
27 Removable/semipermanent beryllium reflector axial power peaking factors and RELAP5 internal source multipliers	57
28 Effective natural convection heat transfer coefficients at the beryllium reflector outside surface	62
29 Permanent beryllium reflector axial power peaking factors and RELAP5 internal source multipliers	63
30 Natural convection heat transfer coefficients at the outer shroud surface	68
31 Carbon steel specific heat and volumetric heat capacity	70
32 Carbon steel thermal conductivity	71
33 304L stainless steel specific heat and volumetric heat capacity	71
34 304L stainless steel thermal conductivity	71
35 347 stainless steel specific heat and volumetric heat capacity	72
36 347 stainless steel thermal conductivity	72
37 Natural convection heat transfer coefficients at the upper vessel sidewall and top head outside surfaces	74
38 Radial boundaries of the oxide regions and aluminum comprising the reflector container and pedestal assembly	78
39 Dimensions of steel pipe	79
40 Selected elevations in the primary coolant system	83
41 Measurements of secondary side pressure drop	88
42 Moments of inertia for the primary coolant pump and pump motors	88
43 Primary coolant pump performance data at 77°F taken from Byron Jackson report	89
44 Pony motor torque supplied to the pump shaft	91
45 Pump characteristic data for the main and standby pressurizer pumps at 2616 rpm	94
46 Auxiliary pressurizer flow rate as a function of pump head	96
47 Elasticity in the HFIR primary coolant containment	106
48 HFIR hourly checksheet data for strainer pressure drop (PdT103)	117
49 Loss coefficients for bends and elbows	119
50 Loss coefficients for diverging wye junctions	119
51 Loss coefficients for converging wye junctions	120

Table	Page
52 Loss coefficients for the block and check valves	121
53 Fittings in the pressurizer pump discharge line	121
54 Trips as defined in the RELAP5 system model of the HFIR primary coolant system	124
55 Control variables used in the model	127
56 HFIR hourly checksheet data for vessel pressure drop (PdT106)	152
B.1 CPU times required for 5.08-cm (2-in.) break simulations	238
E.1 Control variables used for specifying changes in HFIR fuel reactivity	267
E.2 Moderator temperature coefficients in fuel and flux trap regions	269
E.3 HFIR control plate worth	269
E.4 Safety rod worth	269
E.5 HFIR target region reactivity as a function of coolant void fraction	270

NOMENCLATURE

Symbol	Definition	Units
A	area	m^2
b	torque ratio	
c_1	integration constant	m
C	circumference	m
C_p	volumetric heat capacity	$J/m^3 \cdot ^\circ C$
C_v	valve friction loss coefficient	gal/min/psi ^{0.5}
d	diameter	m
D_{hy}	hydraulic diameter	m
g	flow ratio or acceleration of gravity	- or m/s^2
G	volumetric flow rate	m^3/s
h	head ratio	
h_t	head loss	m
H	pump head	m
k	thermal conductivity	$W/m \cdot ^\circ C$
K	loss coefficient	
K_f	spring constant	MPa/m^3
L	length	m
n	pump speed	1/s
Nu	Nusselt number	
P	perimeter or pressure	m or MPa
r	radius	m
Ra	Rayleigh number	
t	thickness	m
T	temperature	$^\circ C$
v	velocity or pump flow ratio	m/s or -
V	volume	m^3
w	width	m
y	relative valve stem position	
Greek		
α	thermal diffusivity or pump speed ratio	m^2/s or -
β	coefficient of thermal expansion	$1/^\circ C$
λ	thermal coefficient of linear expansion	$1/^\circ C$
μ	Poisson's ratio	
ν	kinematic viscosity	m^2/s
ρ	density	kg/m^3

HIGH FLUX ISOTOPE REACTOR SYSTEM RELAP5 INPUT MODELS

D. G. Morris
M. W. Wendel

ABSTRACT

A thermal-hydraulic computational model of the High Flux Isotope Reactor (HFIR) has been developed using the RELAP5 program. The purpose of the model is to provide a state-of-the art thermal-hydraulic simulation tool for analyzing selected hypothetical accident scenarios for a revised HFIR Safety Analysis Report (SAR). The model includes (1) a detailed representation of the reactor core and other vessel components, (2) three heat exchanger/pump cells, (3) pressurizing pumps and letdown valves, and (4) secondary coolant system (with less detail than the primary system). Data from HFIR operation, component tests, tests in facility mockups and the HFIR, HFIR specific experiments, and other pertinent experiments performed independent of HFIR were used to construct the model and validate it to the extent permitted by the data.

The detailed version of the model has been used to simulate loss-of-coolant accidents (LOCAs), while the abbreviated version has been developed for the operational transients that allow use of a less detailed nodalization. Analysis of station blackout with core long-term decay heat removal via natural convection has been performed using the core and vessel portions of the detailed model.

1. INTRODUCTION

The High Flux Isotope Reactor (HFIR) is a beryllium-reflected, light-water-cooled and -moderated, aluminum-clad fuel plate, flux-trap-type reactor that utilizes highly enriched ^{235}U . The HFIR is designed to produce a very high thermal neutron flux of about 5×10^{15} neutrons/cm²-s for the production of transuranium isotopes and the performance of various irradiation experiments. The HFIR is a member of a family of "high-performance" research reactors employing plate-type fuel including, for example, the Advanced Test Reactor (ATR) at Idaho National Engineering Laboratory (INEL) and the High Flux Beam Reactor (HFBR) at Brookhaven National Laboratory (BNL). In addition, there are foreign reactors with characteristics similar to the HFIR.

The HFIR was operated for ~20 years before its shutdown in November 1986 due to vessel embrittlement concerns. These concerns have been resolved through a fracture mechanics analysis coupled with an annual hydrotest. In support of the restart effort, a number of other safety studies have been completed, and others are still in progress. One of the ongoing studies, which is the subject of this report, involves upgrading the analytical thermal-hydraulic capabilities for the HFIR. In particular, the objective is to provide a state-of-the-art analytical capability for simulating the thermal-hydraulic response of the system to small- and large-break loss-of-coolant accidents (SBLOCAs and LBLOCAs), station blackout

(necessitating long-term decay heat removal), and a variety of operational transients. To this end, a model has been constructed of the HFIR primary coolant system and pertinent secondary system components and control systems using the RELAP5/MOD2.5 computer code.¹ This model provides a tool that meets current standards for performing required thermal-hydraulic analyses necessary to develop a revised Safety Analysis Report (SAR) for the HFIR.

RELAP5 is a one-dimensional (1-D), transient, two-phase flow code developed at INEL for the analysis of pressurized-water reactors in support of the United States Nuclear Regulatory Commission (NRC). The code is based on a nonhomogeneous and nonequilibrium model of two-phase flow. The development of RELAP5 has spanned ~10 years and has benefitted from extensive application and comparison to data in light-water systems.

RELAP5 was selected for use over other candidate codes including TRAC,² COBRA/TRAC,³ and RETRAN.⁴ TRAC and COBRA/TRAC, like RELAP5, were developed through the sponsorship of the NRC. RETRAN is an extension of RELAP4, a predecessor to RELAP5, which contains enhancements sponsored by the Electric Power Research Institute. RELAP5, as well as the other codes, offers an impressive technology base of light-water reactor thermal-hydraulic analysis capability that, although not developed for the analysis of plate-fueled reactor systems, can be refined for these systems. Efforts are in progress to refine and benchmark RELAP5 for plate-fueled reactor systems.⁵⁻⁷ INEL has developed "updates" to RELAP5 for low-pressure conditions that have been incorporated in version 3T of RELAP5/MOD2.5, which is used for HFIR analysis. Two other changes were made to the code for HFIR analysis, the first of which entailed the implementation of a model for the onset of flow excursion. Over selected parameter ranges the model replaces the standard RELAP5/MOD2.5 high-flow, critical heat flux (CHF) correlation. The implementation and performance of this model are discussed elsewhere.⁸ The second change corrects the inability of the code to accurately simulate fast reactivity transients typical of the HFIR.⁹ In addition to code changes, other unique features of HFIR requiring extension of the basic RELAP5 capability were accommodated through the HFIR input model using control variables. An assessment of the applicability of the resulting code/input model for analysis of HFIR postulated accident scenarios for the SAR has been performed, and they were determined to be adequate.⁸

The major difference between the codes is the dimensionality of the thermal-hydraulic equations used in each. While RELAP5 and RETRAN are primarily 1-D codes, TRAC and COBRA/TRAC provide three-dimensional (3-D) capability (although based on a number of significant simplifying assumptions) with COBRA/TRAC providing the more detailed treatment of the continuity, momentum, and energy equations. The selection of RELAP5 over the other codes was made for a number of reasons. Foremost, it is anticipated that for most HFIR accident sequences to be investigated, multidimensional flow phenomena can be reasonably accommodated with RELAP5 using approximations (e.g., RELAP5 cross-flow junction and user-specified natural convection coefficients) and/or conservative assumptions. For most sequences, forced flow will be maintained throughout the event, thus providing a primarily 1-D flow.

In general, neglecting multidimensional effects should lead to conservative results (i.e., higher predicted fuel temperatures). For example, fluid mixing, generally a multidimensional phenomenon, results in cooling hot fluid and/or its transport to a cooler region. In the core, conduction along the spanwise dimension of the fuel involute to the cooler side plates mitigates the peak fuel temperature. However, this effect is offset to an extent, depending

upon the nonuniformity of the flow field (e.g., temperature, velocity, and void fraction) along the span of the involute. If important multidimensional phenomena cannot be adequately accommodated with RELAP5 for a particular accident sequence, then supplemental analysis will be performed. In previous studies¹⁰ examining HFIR core natural convection decay heat removal, RELAP5 analysis was supplemented with 3-D, single-phase flow analysis using the TEMPEST¹¹ computer code.

Among the other factors that led to the selection of RELAP5 was the authors' familiarity with RELAP4 and RELAP5 gained in previous projects. In addition, it is well known that model input requirements and computer run times are significantly greater for multidimensional models. Thus, it was felt that the additional cost and time required for a HFIR multidimensional system thermal-hydraulic model was not warranted.

Previously developed thermal-hydraulic computer models of HFIR were used in the design of the core and, more recently, to study the response of the system to LBLOCAs and SBLOCAs. For the design of the core, a steady-state, integral thermal-hydraulics model¹² was developed that simultaneously accounts for nuclear, hydraulic, heat transfer, mechanical, and corrosion factors. Scoping analyses of LBLOCAs have been conducted^{13,14} using a simplified HFIR primary system model developed with MELCOR,¹⁵ a severe accident analysis code that has the capability to simulate two-phase flow, along with a more detailed core model developed with RELAP5. "Global system" results obtained with MELCOR were used to define thermal-hydraulic boundary conditions for the RELAP5 core model, which included core inlet and outlet conditions (e.g., flows, temperatures, and pressures) throughout the transient. More recently, MELCOR has been used in a stand-alone mode to evaluate the consequences of LBLOCAs, which, by definition, are those LOCAs that result in core damage. Reference 16 provides a representative analysis. Scoping analysis of SBLOCAs was performed with HFIRSYS,¹⁷ a transient system, thermal-hydraulic model using the Modular Modeling System.¹⁸ Because HFIRSYS was not designed to simulate two-phase flow, the code cannot predict the response of the system following incipience of boiling. However, it provides a lower bound on the break size that could result in core damage. Analysis with RELAP5 will permit an extension of the HFIRSYS analysis with consideration of the departure from nucleate boiling and flow instability.

In general, a best-estimate HFIR input model was developed for RELAP5, consistent with the intent of the code. However, in instances where a best-estimate approach was not suitable, conservative modeling assumptions were made. Such an approach was taken in situations where uncertainties in a best-estimate model would be large or where a best-estimate model was impractical to implement. The key parameters that have significant uncertainties and were accounted for in the model are fuel plate and element manufacturing variability (defects), power distribution, and preaccident operating conditions (reactor power level, core inlet temperature, core flow, and system pressure). Uncertainties were taken at "worst" case values and then assumed to occur simultaneously. This obviously leads to very conservative results.

The HFIR RELAP5 input model was configured in British units, consistent with the original design calculations and drawings for the system. At a later time, the model can be translated into SI units.

This report describes the development of the HFIR system thermal-hydraulic RELAP5 model. The following chapters include a brief description of the HFIR; a detailed account of the development of the model, containing results of some validation studies; and summary information regarding the application of the model. The appendixes contain a list of the input model, a description of the pump cavitation modeling scheme, pre- and postprocessing programs written for use with the model, and a discussion about an abbreviated version of the model developed for simulating operational transients.

2. FACILITY OVERVIEW

This section provides a brief description of the HFIR facility. A detailed description of the facility can be found elsewhere.^{19,20} Much of the following discussion has been adapted from Ref 19.

The reactor core, illustrated in Fig. 1, consists of a series of concentric annular regions, each ~2 ft (0.61 m) high. The target, containing ^{242}Pu and other transuranium isotopes, is positioned on the reactor vertical axis within a 5-in.-diam (12.7-cm) hole. The fuel region is composed of two concentric fuel elements as shown in Fig. 2. The inner element, which

Fig. 1. Core.

Fig. 2. Fuel element.

contains 171 curved fuel plates, has an inside diameter of 5.067 in. (12.87 cm) and an outside diameter of 10.59 in. (26.90 cm). The outer fuel element contains 369 curved fuel plates and has inner and outer diameters of 11.25 and 17.134 in. (28.58 and 43.52 cm), respectively. The fuel plates are 0.050 in. (0.127 cm) thick and are curved in the shape of an involute, thus providing a constant coolant channel width. The coolant channels are also 0.050 in. (0.127 cm) wide. The plates are of complex, sandwich-type construction composed of a U_3O_8 -Al cermet clad with type 6061 aluminum. To minimize the radial peak-to-average power density ratio, the fuel is nonuniformly loaded along the arc of the involute. A burnable poison is included in the inner fuel element to further flatten the neutron flux distribution and to reduce the negative reactivity requirements of the control plates. A typical core loading includes ~9.4 kg of ^{235}U and 2.8 g of ^{10}B . This provides a maximum of 11% available reactivity and an average core lifetime of about 23 days.

The control plates, in the form of two thin, poison-bearing, concentric cylinders, are located in an annular region between the outer fuel element and the beryllium reflector. The inner control cylinder has its poison arranged so that reactivity is increased by downward motion. This cylinder is used for shimming and regulation; it has no fast safety function. The outer control cylinder consists of four separate quadrants, each having an independent drive and safety release mechanism. Reactivity is increased as the outer plates are raised. All control plates have three regions of different poison content designed to minimize the axial peak-to-average power density ratio throughout the core lifetime.

The beryllium reflector is composed of a series of concentric cylinders with a total thickness of ~1 ft (0.305 m). This, in turn, is bounded by a water reflector of effectively infinite thickness. In the axial direction the reactor is reflected by water.

The reactor core assembly is contained in an 8-ft-diam (2.44-m) pressure vessel, which is located in an 18-ft-diam (5.49-m) cylindrical pool of water. A section through the vessel/core and pool assembly is shown in Fig. 3. The top of the pressure vessel is 17 ft (5.18 m) below the pool water level, with the reactor centerline 27.5 ft (8.38 m) below the pool level. Adjacent to, and connected with, the reactor pool is the clean pool where spent elements are stored, which is 20 ft (6.10 m) deep, 18 ft (5.49 m) wide, and 41.5 ft (12.6 m) long, as shown in Fig. 4. Underwater access is also provided to a small [8-ft-diam (2.44-m)] critical facility pool.

The primary coolant enters the pressure vessel through two 16-in.-diam (40.6-cm) pipes above the core, passes downward through the core, and exits through an 18-in.-diam (45.7-cm) pipe beneath the core. For simplicity, only one of the inlet lines is shown in Fig. 3. The design total flow rate is ~16,000 gal/min (1.01 m³/s), of which ~13,000 gal/min (0.82 m³/s) flows through the fuel region and the remainder through the target, reflector, and control regions.¹⁹ The system is designed to operate at 100 MW with an inlet pressure up to 1000 psi (6.88 MPa). However, concerns about radiation-induced embrittlement of the pressure vessel prompted a decision to limit operation to 85 MW with an inlet pressure of only 482.7 psi (3.33 MPa). Under these conditions the inlet temperature is 120°F (48.9°C), the corresponding exit temperature is 157°F (69.4°C), and the pressure drop through the core is ~105 psi (0.724 MPa).

From the reactor, the coolant flow is distributed to three of four identical heat-exchanger circulation-pump combinations, each located in a separate cell adjacent to the reactor and storage pools. Each cell also contains a letdown control valve, which controls the primary system pressure by extracting flow from the heat exchanger; two block valves for cell isolation; and a check valve to prevent any backflow through the pump. A secondary coolant system removes heat from the primary system and transfers it to the atmosphere by passing water over a four-cell induced-draft cooling tower. Figure 5 shows the arrangement of the reactor vessel, inlet and outlet piping, and one of the four heat exchangers cells; also shown is the injection point in the inlet coolant piping of the low-flow, high-head pressurizer pump that pressurizes the system.

After the reactor is shut down, the main coolant pumps can be operated at reduced flow, driven by small dc "pony" motors located directly above the main ac motors (Fig. 5). Any one of the three operating pony motors can supply sufficient forced convection cooling to remove decay heat from the core.²¹ The total primary system flow is 2500 gal/min (0.158 m³/s) with three pony motors, 2100 gal/min (0.132 m³/s) with two pony motors, or 1300 gal/min (0.082 m³/s) with only one pony motor operating. Each pony motor is powered by either one of two off-site ac power sources, either one of two on-site emergency diesel generators, or by its own bank of batteries. There are four banks of batteries, one for each pony motor. Each bank has an 8-h lifetime at rated conditions.²² Thus, the HFIR has four redundant pony motors, each of which has multiple redundant power sources. In addition, two small, seismically qualified, mobile diesel generators were recently obtained to allow pony motor operation for very long durations.

Fig. 3. Vessel/core cross section.

Fig. 4. Reactor vessel and pools.

UNCLASSIFIED
DATE 11-14-2007 BY 7000422

Fig. 5. Primary system.

3. INPUT MODEL

3.1 OVERVIEW

The RELAP5 nodal diagram of the HFIR primary coolant system model is shown in Fig. 6, and a listing of the input is given in Appendix A. The heat exchanger and vessel/core details are not shown in Fig. 6 but will be presented later. Each rectangular box and pump symbol in the nodal diagram represents a single control volume (node) in the RELAP5 model. The lines that link the boxes indicate only the connectivity of the model. Elbows, bends, wyes, expansions, and reductions occur at junctions between the volumes, as indicated in the figure. Three heat exchanger cells have been represented: cells 110, 111, and 113 containing heat exchangers D, C, and A. Also the piping that leads to and from heat exchanger cell 112 (containing heat exchanger B) has been included.

Except for the heat exchangers and vessel/core, the high-pressure side of the system was discretized as coarsely as possible while including all of the friction losses (i.e., elbows, wyes, expansions, and reductions) in the piping at the correct locations. A finer discretization was selected in the heat exchangers because the heat exchanger performance was found to be a strong function of the number of volumes used.

The dashed arrow in Fig. 6 between the time-dependent volumes (TDVs) 65 and 68 indicates that, although in reality the flow continues from the letdown valves to the pressurizing pumps, this is not a continuous flow path in the RELAP5 model. Rather, the level in the primary coolant (PC) head tank is monitored using the control systems capability of RELAP5, and the suction pressure (assigned to volume 68) is calculated based on that level.

RELAP5's explicit models for valves and pumps were used where convenient. Friction losses at junctions between volumes were specified through loss coefficients supplied to RELAP5 in addition to the RELAP5 calculated straight-pipe friction losses. Six break locations have been included in the model as shown in Fig. 6.

Although not indicated in Fig. 6, heat structures were attached to all volumes representing the primary coolant piping. This was done to account for the heat capacity of the pipes and, in some cases, to facilitate heat transfer to the reactor pool. Heat loss from piping to surrounding air is small and was neglected.

A schematic diagram of the HFIR vessel/core RELAP5 model is presented in Fig. 7. As shown, the model contains two target channels representing an unheated bypass region and a heated region containing the target rods (see Fig. 1). With reference to Fig. 2, the inner and outer fuel elements are each modeled in two lumped "average" regions and a single "hot" region. As described subsequently, the average regions in each element model are distinguished from each other by power density, one slightly above average and the other slightly below. The region between the fuel elements, the fuel assembly labyrinth, is modeled as an unheated flow channel. The model contains three annular flow passages providing cooling for two sets of heat structures representing the control cylinders and four radial subregions representing the beryllium reflector (see Figs. 1 and 3).

The lower end of the target, fuel, and labyrinth channels connects to a common cylindrical region. Similarly, the control cylinder and beryllium reflector regions connect to an annular region. Flow passages exist between these regions beneath the core, so in the model they are connected to each other. The target channels connect to a channel representing the portion of the target tower water contained within the inner shroud above the core (see Fig. 3). Similarly, the fuel channels connect to an annular region within the inner

ORNL-DWG 92-3195 ETD

Fig. 6. Schematic of the HFIR RELAP5 system model

ORNL-DWG 92-3196 ETD

Fig. 7. Schematic of the HFIR RELAP5 vessel/core model.

shroud. The control cylinder and beryllium reflector regions connect to an annular region formed by the inner and outer shrouds.

With reference to Fig. 3, the water outside of the core within the vessel is divided into three regions as indicated in Fig. 7. The region denoted as "U-bypass" is connected to components representing a check valve controlling flow from the reactor pool into the vessel. It also connects to components used to simulate the effect of the elasticity of the primary system pressure boundary (e.g., pipe and reactor vessel walls) on system depressurization, and to components representing the emergency depressurization system (EDS). As described in Sect. 3.4, accounting for the effect of structural elasticity is necessary because HFIR normally operates under single-phase, liquid conditions. The upper plenum region connects to heat structures representing the vessel sidewalls and lid, which in turn connect to a component representing the pool conditions. The upper plenum and outlet regions connect to the inlet and outlet piping, respectively.

Based on a review of the HFIR design information,^{19,20,23-25} operating data,²⁶ and discussions with HFIR staff, normal flow rates through the various regions of the core are presented in Fig. 8. HFIR design information suggests a total flow rate of 16,156 gal/min (1.02 m³/s) (at core inlet). During the operating history of HFIR, flow rates have been observed to vary over the range ~16,500 to 17,500 gal/min (1.04 to 1.10 m³/s), depending upon the system configuration. Based on typical measured pressure drops through the core (upon which fuel element flow-rate estimates can be made) and discussions with HFIR staff, a normal (steady-state) flow rate of 16,500 gal/min (1.04 m³/s) was selected for initializing the vessel/core portion of the model. The design data were normalized to this value, thus preserving the designed flow distribution. As indicated in Fig. 8, the bulk of the flow is through the fuel region, resulting in an average inlet flow velocity of ~52 ft/s (1.58 m/s).

The heat loads in the various regions of the core are provided in Table 1 for the nominal HFIR power level of 85 MW.²⁷ As indicated in Table 1, the total is ~1 MW above the nominal 85-MW power level. This results due to extra heat added to the target and control plate regions to account for limitations and uncertainties in calculated heat loads in these regions. The core heat load and its distribution were developed to be applicable throughout the fuel cycle and, as a result, tend to be conservative. The heat load following shutdown was assumed to be the maximum of the beginning-of-cycle (BOC) and end-of-cycle (EOC) values through time. Differences were accounted for between fission and decay heat loads in terms of their contribution to the total load after shutdown through time and distribution in the core. Heat deposited above and below the core and within its radial extent was assumed to be deposited in the core itself in the same relative portions as that calculated to be actually deposited. On the same relative basis, heat deposited outside the radial extent of the core was assumed to be deposited in the extra-fuel element regions of the core.

The total core post-shutdown heat load is shown in Table 2 and Fig. 9.²⁷ Time in both is the time after initiation of insertion of safety plates. The calculated heat loads are based on an assumed safety plate insertion time of 250 ms (Ref. 28). The HFIR technical specifications²⁹ indicate that the time-of-flight for the safety plate (measured from the initiation of the scram signal until the plate is seated) cannot exceed 450 ms. The time before the plates begin to move has been measured to be <24 ms (Ref. 30). This dead time consists of the magnet release time (cannot exceed 12 ms) and the mechanical response time, which is administratively controlled. In this model, the time-of-flight was assumed to be 450 ms, consisting of 200-ms dead time plus 250-ms insertion time (Fig. 9 and Table 2). This is conservative because it is known that the plates begin to move 176 ms sooner than has been assumed.

Fig. 8. Reactor vessel coolant flow distribution.

The increase (rather than the expected decrease) in the extra-fuel element heat load that occurs from 1680 to 1920 s (Table 2) is due to a redistribution of the decay heat load from that obtained in the base heat loads calculation through the first 1800 s following shutdown. During this time a greater percentage of the load remains in the fuel element than calculated.²⁷ There is a corresponding decrease in the extra-fuel element regions because the total deposited in the core is unchanged.

Table 1. HFIR core heat loads at nominal 85-MW power level

Region	Heat load (MW)
Fuel ^a	80.7
Target	0.888
Control cylinders	1.71
Removable beryllium reflector	0.327
Semipermanent beryllium reflector	1.21
Permanent beryllium reflector ^b	<u>1.08</u>
Total	85.9

^aIncludes fuel plates, side plates, and water in fuel channels.

^bIncludes permanent beryllium reflector, vertical experimental facilities, and horizontal beam tube aluminum liners.

3.2 VESSEL/CORE COMPONENT DESCRIPTIONS

The components that comprise the HFIR vessel/core RELAP5 input model are described in detail in this section. For each component a description is presented that includes the relevant assumptions, geometry, thermophysical properties, heat transfer characteristics, and nominal flow rates and power.

3.2.1 Fuel Element

As shown in Fig. 7 and described previously, the fuel element is divided into six regions. The two average inner fuel element lumps are each composed of 85 fuel plates and flow channels (Inner Fuel-1 and -2). The remaining fuel plate and flow channel, of the total 171 inner fuel element plates and channels, represent a hot fuel region (Hot Inner Fuel). Similarly, the two average outer fuel element lumps are each composed of 184 fuel plates and flow channels (Outer Fuel-1 and -2). The remaining fuel plate and flow channel, of the total 369 outer fuel element plates and channels, represent a hot fuel region (Hot Outer Fuel).

Table 2. HFIR heat load after scram

Time (s)	Heat loads (MW)		
	Fuel element	Extra-fuel element	Total
0.00	80.720	5.2173	85.9373
0.01	80.370	5.1954	85.5654
0.05	58.370	4.0134	62.3834
0.10	21.190	2.0232	23.2132
0.15	11.580	1.5092	13.0892
0.20	9.940	1.4115	11.3515
0.25	9.840	1.4078	11.2478
0.30	9.740	1.3932	11.1332
0.35	9.650	1.3895	11.0395
0.40	9.560	1.3846	10.9446
0.45	9.470	1.3700	10.8400
0.50	9.400	1.3663	10.7663
0.55	9.320	1.3639	10.6839
0.60	9.230	1.3504	10.5804
0.65	9.170	1.3468	10.5168
0.70	9.100	1.3443	10.4443
0.75	9.020	1.3297	10.3497
0.80	8.960	1.3272	10.2872
0.85	8.900	1.3248	10.2248
0.90	8.830	1.3126	10.1426
1.00	8.250	1.1880	9.4380
3.00	6.720	1.0464	7.7664
5.00	5.860	0.9634	6.8234
9.00	4.890	0.8645	5.7545
20.00	3.770	0.7350	4.5050
40.00	2.950	0.6264	3.5764
60.00	2.530	0.5678	3.0978
80.00	2.280	0.5275	2.8075
100.00	2.100	0.4982	2.5982
120.00	1.970	0.4750	2.4450
140.00	1.890	0.4567	2.3467
160.00	1.810	0.4444	2.2544
180.00	1.750	0.4298	2.1798
200.00	1.700	0.4200	2.1200
220.00	1.670	0.4127	2.0827
240.00	1.620	0.4017	2.0217
360.00	1.470	0.3675	1.8375
480.00	1.370	0.3419	1.7119
600.00	1.310	0.3260	1.6360
720.00	1.250	0.3101	1.5601

Table 2 (continued)

Time (s)	Heat loads (MW)		
	Fuel element	Extra-fuel element	Total
840.00	1.190	0.2967	1.4867
960.00	1.150	0.2869	1.4369
1,080.00	1.120	0.2796	1.3996
1,200.00	1.090	0.2723	1.3623
1,320.00	1.060	0.2637	1.3237
1,440.00	1.030	0.2564	1.2864
1,560.00	1.000	0.2503	1.2503
1,680.00	0.980	0.2442	1.2242
1,920.00	0.905	0.2747	1.1797
2,040.00	0.886	0.2698	1.1558
2,160.00	0.870	0.2650	1.1350
2,400.00	0.838	0.2552	1.0932
2,640.00	0.810	0.2466	1.0566
2,880.00	0.786	0.2393	1.0253
3,120.00	0.763	0.2320	0.9950
3,600.00	0.724	0.2198	0.9438
7,200.00	0.553	0.1685	0.7215
10,800.00	0.469	0.1429	0.6119
14,400.00	0.416	0.1270	0.5430
18,000.00	0.379	0.1153	0.4943
21,600.00	0.352	0.1071	0.4591
25,200.00	0.330	0.1004	0.4304
28,800.00	0.312	0.0949	0.4069
32,400.00	0.297	0.0904	0.3874
36,000.00	0.283	0.0861	0.3691
39,600.00	0.272	0.0828	0.3548
43,200.00	0.262	0.0797	0.3417
46,800.00	0.252	0.0767	0.3287
50,400.00	0.244	0.0742	0.3182
54,000.00	0.237	0.0720	0.3090
57,600.00	0.230	0.0700	0.3000
61,200.00	0.223	0.0678	0.2908
64,800.00	0.218	0.0663	0.2843
68,400.00	0.212	0.0645	0.2765
72,000.00	0.207	0.0630	0.2700
75,600.00	0.202	0.0614	0.2634

Fig. 9. Heat load following shutdown.

The average fuel element channels are assumed to have the nominal design gap width of 50 mils (1.27 mm) adjusted for the presence of the oxide film (boehmite). The oxide thickness is conservatively taken to be the EOC value, 0.689 mils (0.0175 mm).³¹ The hot fuel channels have a gap width of 35 mils (0.889 mm) based on analysis of steady-state operation, which accounts for fuel element manufacturing tolerances; fuel plate deflections; thermal expansion; and oxide buildup.³¹ This value is slightly less than that calculated at the location of the "limiting" incipient boiling heat flux at EOC during steady-state operation. Because channel gap width is narrowest at EOC, the value chosen is conservative. For the hot region fuel, an EOC oxide thickness of 1.21 mils (0.031 mm) was selected that conservatively reflects the effects of the narrow channel and higher than average power density on oxide buildup.³¹ The radial boundaries of the inner, r_i^i and r_o^i , and outer, r_i^o and r_o^o , fuel element involutes are^{32,33}

$$r_i^i = 0.2268 \text{ ft (0.06913 m)},$$

$$r_o^i = 0.4198 \text{ ft (0.1280 m)},$$

$$r_i^o = 0.4894 \text{ ft (0.1492 m)},$$

$$r_o^o = 0.6926 \text{ ft (0.2111 m)}.$$

Because the fuel element flow area and plate cross-sectional area are equal, the nominal flow areas per plate for the inner, $A_{f, nm}^i$, and outer, $A_{f, nm}^o$, fuel element regions are

$$A_{f, nm}^i = 0.00115 \text{ ft}^2 (1.07 \times 10^{-4} \text{ m}^2),$$

$$A_{f, nm}^o = 0.00102 \text{ ft}^2 (9.48 \times 10^{-5} \text{ m}^2).$$

With the nominal plate thickness [50 mils (1.27 mm)], the width of the flow channel and fuel plate in the spanwise direction can be calculated for the inner, w_s^i , and outer, w_s^o , fuel element regions:

$$w_s^i = 0.276 \text{ ft (0.0841 m)},$$

$$w_s^o = 0.245 \text{ ft (0.0747 m)}.$$

The corresponding widths of the fuel bearing regions, w_f^i and w_f^o , are³⁴

$$w_f^i = 0.256 \text{ ft (0.0780 m)},$$

$$w_f^o = 0.230 \text{ ft (0.0701 m)}.$$

The "true" fuel element channel flow area and hydraulic diameter can be determined after accounting for the fuel oxide film thickness. Formation of the oxide results in the consumption of aluminum producing a film 25.4% thicker than the thickness of metal consumed.³⁵ Thus, the fuel plate thickness in the average fuel element lumps, $t_{p,av}$, is

$$t_{p,av} = 50 + 2 \text{ (oxide thickness - Al consumed) mils,}$$

$$= 50 + 2 (0.689 - 0.689/1.254) \text{ mils,}$$

$$t_{p,av} = 50.3 \text{ mils (1.28 mm)}.$$

The flow area per plate, $A_{f,av}^i$ and $A_{f,av}^o$, and channel gap width, $t_{c,av}$ ($t_{c,av}^i = t_{c,av}^o$), in the inner and outer average fuel element regions are reduced proportionally with the increase in plate thickness:

$$t_{c,av} = 49.7 \text{ mils (1.26 mm)},$$

$$A_{f,av}^i = 0.00114 \text{ ft}^2 (1.06 \times 10^{-4} \text{ m}^2),$$

$$A_{f,av}^o = 0.00101 \text{ ft}^2 (9.38 \times 10^{-5} \text{ m}^2).$$

The hydraulic diameters of the inner, $D_{hy,av}^i$, and outer, $D_{hy,av}^o$, average fuel element regions are

$$D_{hy} = 4 A_f / \text{wetted perimeter,}$$

$$D_{hy,av}^i = 8.14 \times 10^{-3} \text{ ft (2.48} \times 10^{-3} \text{ m)},$$

$$D_{hy,av}^o = 8.11 \times 10^{-3} \text{ ft (2.47} \times 10^{-3} \text{ m)}.$$

Fuel element plates consist of three regions: fuel ("meat"), clad, and oxide. A cross section of the fuel meat is shown in Fig. 10. In the model, the fuel meat is homogenized over the 30-mil (0.76-mm) thickness. With reference to the axial plane (curved) of symmetry through a plate, the outer boundaries of the three regions of an average plate are

oxide, $x_{o,av}$

$$x_{o,av} = \frac{t_{p,av}}{2} = 2.09496 \times 10^{-3} \text{ ft (6.38538} \times 10^{-4} \text{ m)};$$

ORNL-DWG 63-3672R

Fig. 10. Cross section of fuel meat.

clad, $x_{c,av}$

$$\begin{aligned} x_{c,av} &= x_{o,av} - \text{oxide thickness,} \\ &= 2.09496 \times 10^{-3} - 0.689/(12 \times 1000) \text{ ft,} \\ x_{c,av} &= 2.03754 \times 10^{-3} \text{ ft } (6.21042 \times 10^{-4} \text{ m}); \end{aligned}$$

fuel, $x_{f,av}$

$$x_{f,av} = 15 \text{ mils} = 1.25 \times 10^{-3} \text{ ft } (3.81 \times 10^{-4} \text{ m}).$$

The hot channel fuel element flow areas, $A_{f,ht}^i$ and $A_{f,ht}^o$, and hydraulic diameters, $D_{hy,ht}^i$ and $D_{hy,ht}^o$, are

$$\begin{aligned} A_f &= t_c w_s, \\ A_{f,ht}^i &= (0.035/12) (0.276) \text{ ft}^2, \\ A_{f,ht}^i &= 8.05 \times 10^{-4} \text{ ft}^2 (7.48 \times 10^{-5} \text{ m}^2), \\ A_{f,ht}^o &= (0.035/12) (0.245) \text{ ft}^2, \\ A_{f,ht}^o &= 7.14 \times 10^{-4} \text{ ft}^2 (6.63 \times 10^{-5} \text{ m}^2), \\ D_{hy,ht}^i &= 5.77 \times 10^{-3} \text{ ft } (1.76 \times 10^{-3} \text{ m}), \\ D_{hy,ht}^o &= 5.76 \times 10^{-3} \text{ ft } (1.76 \times 10^{-3} \text{ m}). \end{aligned}$$

The thickness of the hot fuel plates $t_{p,ht}$ is based on the nominal value

$$\begin{aligned} t_{p,ht} &= 50 + 2 (1.21 - 1.21/1.254) \text{ mils,} \\ t_{p,ht} &= 50.5 \text{ mils } (1.28 \text{ mm}). \end{aligned}$$

Because fuel plate manufacturing specifications allow plates to be 50 ± 1 mils (1.27 ± 0.0254 mm) thick,³⁶ the modeled fuel plate heat-conduction resistance and heat capacity are slightly lower than actual. The heat-conduction resistance of the oxide film (a minimum thickness of 0.689 mil is used in the model) is at least 2 times that of the rest of the fuel plate. Thus, the error incurred in the total conduction resistance is $<1\%$. The use of a slightly low heat capacity is conservative (i.e., results in a higher fuel plate heat-up rate). The hot channel gap width used in the model does account for channel narrowing caused by a plate with the maximum thickness permitted in the specifications. The outer boundaries of the three regions comprising the hot fuel plates are

oxide, $x_{o,ht}$

$$x_{o,ht} = \frac{x_{p,ht}}{2} = 2.10376 \times 10^{-3} \text{ ft } (6.41226 \times 10^{-4} \text{ m});$$

clad, $x_{c,ht}$

$$\begin{aligned} x_{c,ht} &= x_{o,ht} - \text{oxide thickness,} \\ &= 2.10376 \times 10^{-3} - 1.21/(12 \times 1000) \text{ ft,} \end{aligned}$$

$$x_{c,ht} = 2.00293 \times 10^{-3} \text{ ft } (6.10493 \times 10^{-4} \text{ m});$$

fuel, $x_{f,ht}$

$$x_{f,ht} = 15 \text{ mils} = 1.25 \times 10^{-3} \text{ ft } (3.81 \times 10^{-4} \text{ m}).$$

The nominal length of the "active" (fueled) portion of the fuel plates is 20 in. (50.8 cm). There are 2-in. (5.08-cm) extensions above and below the fueled portion that are "inactive." That is, nominally no fuel is present in these extensions, but manufacturing specifications allow fuel to extend slightly into them. As explained subsequently, this can result in very high, local heat flux peaking and is therefore modeled. The total active fuel heat transfer area is 428.8 ft² (39.84 m²).²⁵ This area only encompasses the active length of the element and, in the spanwise dimension, the fuel bearing width. The active heat transfer areas of the inner, A_i^i , and outer A_o^o , fuel plates are

$$A_i^i = 0.853 \text{ ft}^2 (0.0792 \text{ m}^2),$$

$$A_o^o = 0.767 \text{ ft}^2 (0.0712 \text{ m}^2).$$

Conservatively, these areas are used in the model. In addition, the side plates are not modeled; thus heat transfer to them is neglected.

The composition of the meat region in the active portion of the fuel plates is provided in Table 3 on a per plate basis. The mass of the aluminum filler in the inner fuel element fuel plate was assumed to be the difference between the total mass and the mass of the other components. The former was determined by dividing the U₃O₈ mass by its mass fraction (i.e., 19.28 g/0.226 = 85.3 g).³⁴ Referring to Fig. 10, the meat exists in the center 30-mil (0.76-mm)

Table 3. Fuel plate meat composition³⁴

Material	Mass (g)	
	Inner element	Outer element
U ₃ O ₈	19.28	23.42
Al ^a	44.59	35.00
B ₄ C (filler)	0.1188	
Al ^a (filler)	<u>21.3</u>	<u>22.64</u>
Total	85.3	81.06

^aType 1100 aluminum.

width of the plate. The density of the meat can be calculated based on its volume. Consistent with the fuel plate heat transfer area and volume assumed in the model, the meat volume is calculated using the width of the fuel bearing region. The volumes of the meat in each plate in the inner V_m^i and outer V_m^o fuel element regions are

$$V_m^i = 1.07 \times 10^{-3} \text{ ft}^3 (3.03 \times 10^{-5} \text{ m}^3),$$

$$V_m^o = 9.58 \times 10^{-4} \text{ ft}^3 (2.71 \times 10^{-5} \text{ m}^3).$$

Thus, the densities of the meat in the inner ρ_m^i and outer ρ_m^o fuel element plates are

$$\rho_m^i = 176.1 \text{ lb}_m/\text{ft}^3 (2821 \text{ kg/m}^3),$$

$$\rho_m^o = 186.3 \text{ lb}_m/\text{ft}^3 (2984 \text{ kg/m}^3).$$

The temperature-dependent specific heat of the fuel meat region was calculated as a mass weighted average of those of aluminum and U_3O_8 . The effect of B_4C on specific heat in the inner fuel element meat is ignored because its mass fraction is small. Temperature-dependent thermophysical properties of the aluminum in the fuel meat, 1100 aluminum, could not be found. Because 1100 aluminum is +99% aluminum,³⁷ values for pure aluminum were used. Table 4 presents temperature-dependent specific heats for aluminum and U_3O_8 , the average fuel meat values for the inner and outer elements, and the volumetric heat capacity (product of specific heat and density) for the elements, which is the quantity needed for input to RELAP5.

Table 4. Fuel meat specific heat and volumetric heat capacity^{38,39}

Temperature (°F)	Specific heat (Btu/lb _m -°F)				Volumetric heat capacity (Btu/ft ³ -°F)	
	Al	U_3O_8	Inner element	Outer element	Inner element	Outer element
80	0.215	0.068	0.182	0.173	32.1	32.2
440	0.238	0.079	0.202	0.192	35.6	35.8
980	0.274	0.081	0.230	0.218	40.5	40.6
1205	0.305	0.079	0.254	0.240	44.7	44.7

The thermal conductivity of the "fuel section" in the fuel meat of both the inner and outer fuel element plates has been measured (see Fig. 10).⁴⁰ Data were collected using samples of hi-fired U_3O_8 -Al cermet, which contained 12.45 and 18.05% U_3O_8 by volume (30 and 40% by weight) for the inner and outer fuel element regions, respectively. Conservatively, these values are used for the entire fuel meat regions in the model. Thus, the thermal conductivity of the fuel meat in the inner and outer fuel element plates is provided in Table 5. Data at lower temperatures were used to develop linear models (of thermal conductivity as a function of temperature) using regression analyses that were in turn used

Table 5. Fuel meat thermal conductivity

Temperature (°F)	Thermal conductivity (Btu/s-ft-°F)	
	Inner element	Outer element
80.3	0.02844	0.02553
260.3	0.02819	0.02539
900	0.02792 ^a	0.02540 ^a
1204	0.02773 ^a	0.02535 ^a

^aExtrapolated.

to extrapolate values at higher temperatures. The fuel meat thermal conductivity does not appear to be very temperature sensitive.

Based on a description of the HFIR fuel plate fabrication procedures,⁴¹ the center 30 mils (0.76 mm) of the inactive portion of the fuel plates (described below) consists of 1100 and 6061-0 aluminum. The composition and thermophysical properties are assumed to be the same as those of the clad material.

The fuel plate cladding consists of 1-mil-thick (0.0254-mm) 1100 aluminum adjacent to the fuel meat and 9-mil-thick (0.229-mm) 6061-0 aluminum.^{34,42} As for 1100 aluminum, temperature-dependent specific heat data could not be located for 6061-0 aluminum, so values for 6061-T6 were used. Due to the similarity of the thermal properties of 1100 and 6061-0 aluminum and the thinness of the 1100 aluminum portion, a single set of composition-averaged properties was calculated for the clad. The density of 6061 aluminum at room temperature (RT) is 169 lb_m/ft³ (2710 kg/m³) (Ref. 43), the same as that for 1100 aluminum.³⁷ Clad specific heats and volumetric heat capacity are given in Table 6, where averaged values are mass (thickness) weighted.

Similarly, the clad thermal conductivity was composition averaged (values of pure aluminum used for 1100 aluminum). Thermal conductivities are presented in Table 7. The value for 6061-0 aluminum at 1204°F (651°C) was extrapolated based on a second-degree polynomial curve fit to data.

The oxide that forms on the fuel plates has been determined to be boehmite, which is the monohydrate of aluminum oxide (α Al₂O₃ · H₂O).^{35,44} The specific heat of boehmite could not be found; therefore values of aluminum oxide (Al₂O₃) were used.⁴⁵ The density

Table 6. Clad specific heats and volumetric heat capacity^{38,46}

Temperature (°F)	Specific heat (Btu/lb _m -°F)			Volumetric heat capacity (Btu/ft ³ -°F)
	Al	6061-T6 Al	<Clad>	
80	0.215	0.215	0.215	36.3
440	0.238	0.236	0.236	39.9
980	0.274	0.269	0.270	45.6
1160	0.297	0.280	0.282	47.7

Table 7. Clad thermal conductivity^{47,48}

Temperature (°F)	Thermal conductivity (Btu/s-ft-°F)		
	Al	6061-0 Al	<Clad>
82.4	0.0381	0.0281	0.0291
442.4	0.0381	0.0314	0.0321
802.4	0.0363	0.0311	0.0316
1204	0.0339	0.0269 ^a	0.0276 ^a

^aExtrapolated.

of boehmite at RT has been reported to be 189 lb_m/ft³ (3.02 g/cm³).³⁵ Specific heat and volumetric heat capacity of boehmite are presented in Table 8, based on property assumptions above. The thermal conductivity of boehmite has been reported to be 1.3 Btu/h-ft-°F (3.61×10^{-4} Btu/s-ft-°F or 2.25 W/m-K).^{35,44}

Table 8. Oxide (boehmite) specific heat and volumetric heat capacity

Temperature (°F)	Specific heat ^a (Btu/lb _m -°F)	Volumetric heat capacity (Btu/ft ³ -°F)
80	0.19	35.9
440	0.25	47.3
980	0.28	52.9
1205	0.29	54.8

^aValues of Al₂O₃ used for boehmite.

During HFIR normal operation the flow rate through the fuel element is estimated to be 13,277 gal/min (0.838 m³/s) or 1828 lb_m/s (829.2 kg/s). The roughness of aluminum oxidized under conditions representative of those in HFIR has been measured and found to range from 20 to 60 μin.⁴⁹ To provide a pressure drop through the fuel element that is representative (~100 psi or 0.689 MPa), a fuel roughness value of 20 μin. was used in the model. Because the fuel plates are "rounded" at the top, the smooth area change option in RELAP5 was used at the entrance to the fuel element (junction 4-01 through 4-06). The fuel plates are not "rounded" at the bottom, so the abrupt area change option was used at the exit (junctions 8-01, 8-02, and 8-05 through 8-08).

As shown previously in Table 1, the power absorbed in the fuel region is 80.7 MW during normal steady-state operation. In the RELAP5 model, all of this power is conservatively assumed to be absorbed in the fuel bearing region of the fuel plates. Because the power

density varies spatially within the fuel (among other reasons), the fuel element is modeled with average and hot fuel regions that are divided axially into subregions.

The average fuel regions are broken axially into seven subregions as shown in Fig. 7. The top and bottom subregions are 2 in. (5.08 cm) long and contain the inactive portions (extensions) of the fuel plates. The remaining five subregions, each 4 in. (10.16 cm) long, contain the active portion of the fuel plates. In each of the pairs of average fuel regions in the inner and outer fuel element model, one region has a power density 1% above average and the other 1% below. This variation is representative of total plate loading tolerances.⁵⁰ In addition, the multiple average regions give the model more "flexibility" to accommodate spatial variations in flow through the fuel element. The average axial power distributions in the inner and outer fuel elements are presented graphically in Fig. 11(a) and in tabular form in Table 9.²⁷ These are based on EOC decay heat load distributions that were chosen because they best represent averages spatially and temporally.

Fig. 11. HFIR fuel axial power distribution.

Table 9. Normalized HFIR fuel axial power peaking factors

Axial location	Peaking factors			
	Inner element		Outer element	
	Average fuel	Hot fuel	Average fuel	Hot fuel
Top-to-bottom				
1	0.0809	0.0163	0.0643	0.0144
2	0.8871	1.02	0.939	1.06
3	1.275	1.14	1.33	1.22
4	1.453	1.41	1.48	1.54
5	1.285	1.58	1.34	1.75
6	0.8871	1.64	0.935	1.81
7	0.0809	1.56	0.0624	1.71
8		1.37		1.48
9		1.08		1.15
10		0.953		0.970
11		0.0149		0.0133
Element entrance (local)		1.515		1.580
Element exit (local)		1.342		1.342

The hot fuel regions, each representing a single fuel plate and flow channel (one pair from the inner fuel element and one pair from the outer), simulate fuel plates with the highest power density and the narrowest channel gap. As shown in Fig. 7, these two regions have a finer axial discretization than the average regions. This allows a better representation of the axial power distribution and flow field. As in the average regions, the hot region top and bottom subregions are 2 in. (5.08 cm) long and contain the nominally inactive portions of the fuel plate. The remaining nine subregions, each 2.22 in. (5.64 cm) long, contain the active portion of the fuel plate. The axial power distributions in the two hot fuel regions are taken to be those at the radial position during the fuel cycle where the respective inner and outer fuel element plates are closest to their thermal limit during normal, steady-state operation.⁵¹ This occurs at BOC at radial positions referenced to the core centerline of 3.94 in. (10.0 cm) and 5.96 in. (15.15 cm) for the inner and outer fuel element plates, respectively.^{51,52} The axial power distributions in the hot fuel regions are presented in Fig. 11(b) and Table 9.²⁷ These are fission heat load distributions that are, as expected, more peaked than EOC decay heat load distributions at the same locations. "Localized" axial distribution power factors at the very entrance and exit of the hot regions at the same radial positions as above are also presented in Table 9.⁵² As explained subsequently, these distribution factors are used in the modeling of fuel plate heat flux peaking due to fuel extending beyond the nominal axial boundary of the active portion of the fuel plates. The power density in the hot channels is increased further above average due to uncertainty in the calculated power distribution (10%) plus an allowance for power tilt associated with experiments (9%);⁵³ the possible existence of a "hot streak" within the channel;⁵⁴ and, as

just mentioned, the possibility that fuel could extend beyond the nominal axial boundary of the fuel.⁵⁵

Conservatively, these effects are assumed to occur simultaneously within the hot fuel regions along the entire fuel plate. Table 10 lists the values of the hot fuel regions peaking factors. The hot fuel regions also include local hot spots that represent the effect of fuel plate nonbonds and fuel segregation.⁵⁶ The heat flux peaking effect of a fuel plate nonbond in the presence of a "worst-case" (i.e., at fuel manufacturing specification limits) fuel segregation defect depends upon the thickness of the fuel meat. A correlation was previously developed to describe nonbond (with fuel segregation) flux peaking in terms of the location of the defect along the span of the fuel plate for both inner and outer fuel element plates. The nonbond peaking factors, U_{20}^i and U_{20}^o , for the inner and outer fuel plates are⁵⁶

$$U_{20}^i = 1.33687 - 0.35423 s + 0.14503 s^2 - 0.01669 s^3,$$

and

$$U_{20}^o = 1.180171 - 0.278079 s + 0.151756 s^2 - 0.014261 s^3,$$

where s is the distance (inches) along the span of the fuel plate. Evaluating these equations at the limiting radial (span) positions⁵⁷ [inner fuel element plate radial and span positions

Table 10. Hot fuel regions and local power peaking factors

Peaking factors				
	<i>Hot fuel</i>			
Power distribution uncertainty	1.199			
Hot streak	1.10			
Fuel plate heated length uncertainty	<u>1.025</u>			
Total ^a	1.35			
	<i>Local</i>			
	Active		Entrance and exit	
	Inner element	Outer element	Inner element	Outer element
Power distribution uncertainty	1.199	1.199	1.199	1.199
Nonbond	1.08	1.16	1.08	1.16
Fuel segregation	1.3	1.3	1.3	1.3
Fuel beyond axial boundary			1.44	1.23
Total ^a	1.68	1.81	2.42	2.22

^aMultiplicative.

are 3.94 in. (10.0 cm) and 1.487 in. (3.78 cm), respectively], outer element plate radial and span positions are 5.96 in. (15.15 cm) and 0.0923 in. (0.234 cm), respectively. Note: the 0.0739-in. value given for " Δr_2 " for the outer fuel element plates is incorrect in Ref. 57; it should be 0.09157 in., that is, the radial difference between the first mesh point in the outer fuel element plates (15.15 cm or 5.9646 in.)⁵² and the outside radius of the inner side plate of the outer fuel element give U_{20} and U_{20}^* as 1.08 and 1.16, respectively. The heat flux peaking caused by combined nonbond and fuel segregation defects is also affected by the heat transfer coefficient. Values reported in Table 10 are based on a heat transfer coefficient of 15,000 Btu/h-ft²·°F (85 kW/m²·K), which is representative during LOCA. The variation in the peaking factor with the heat transfer coefficient for several fuel meat thicknesses is shown in Fig. 12.⁵⁸

Representation of the local hot spot is accomplished in the model with an additional heat structure with an area much smaller (~0.01 times) than the normal hot channel heat structure. This allows simulation of a local, high fuel plate heat flux coupled with fluid conditions dictated by the heat structures representing the "global" hot fuel plate characteristics. In the present RELAP5 model, there is a local hot spot in each axial segment of the hot fuel plates, including the nominally inactive portions (extensions). The latter segments (denoted "entrance and exit" in Table 10) represent hot spots in fuel extending beyond the nominal axial boundary of the active portion of the fuel plates.⁵⁹ The exit hot spots are the locations in the fuel elements at which the hot inner and outer fuel element plates are closest to their thermal limit during normal, steady-state operation.⁵¹ Table 10 lists the values of the local hot fuel regions power peaking factors, which, like the hot fuel region factors, are assumed to occur simultaneously.

Fig. 12. Peaking factor as function of film coefficient with fuel meat thickness as parameter.

RELAP5 heat structure internal source multipliers were calculated by distributing the total fuel element power to each heat structure according to surface area. Then, axial power factors presented in Table 9 were used, along with appropriate power peaking factors, to represent the spatial core power distribution. Table 11 presents the fuel internal source multipliers calculated and used in the RELAP5 model (these multipliers are referenced to the fuel element power).²⁷

3.2.2 Fuel Labyrinth

The fuel labyrinth, the flow passage between the inner and outer fuel elements, is modeled as a single volume (Fig. 7). The volume is not thermally connected to the fuel heat structures and therefore provides them no cooling. The flow passage is an annulus with the following dimensions:²⁵

$$\begin{aligned}\text{inside diameter} &= 10.590 \text{ in. (26.899 cm),} \\ \text{outside diameter} &= 11.250 \text{ in. (28.575 cm).}\end{aligned}$$

Thus, the flow area A_f and hydraulic diameter D_{hy} of the channel are

$$\begin{aligned}A_f &= 0.0786 \text{ ft}^2 (7.30 \times 10^{-3} \text{ m}^2), \\ D_{hy} &= 0.0550 \text{ ft (1.68} \times 10^{-2} \text{ m).}\end{aligned}$$

With reference to Fig. 2, the length of the fuel labyrinth is assumed to be 24 in. (61 cm), the same as the fuel.

The top portion of the labyrinth provides a large flow resistance, which only allows a flow rate of ~136 gal/min ($8.58 \times 10^{-3} \text{ m}^3/\text{s}$) or 18.7 lb_m/s (8.48 kg/s) during HFIR normal steady-state operation. This flow resistance is represented in RELAP5 using the abrupt area change model (at junction 4-07) with an orifice possessing an area ~21 times smaller (0.0037 ft^2 or $3.4 \times 10^{-4} \text{ m}^2$) than the labyrinth flow area. The annulus was assumed to have the same channel surface roughness as the fuel, 20 $\mu\text{in.}$ ($5.08 \times 10^{-4} \text{ mm}$). The abrupt area change model was also used at the outlet (at junction 8-09).

3.2.3 Target

As indicated previously, the target assembly is located inside the 5-in.-diam (12.7-cm) hole within the inner fuel element. Figure 13 provides a view of the details of the target assembly in a typical configuration, while Fig. 14 shows its position within the core. The configuration of the target assembly varies depending upon the needs of experimenters.⁶⁰ In Fig. 13, the assembly contains 30 target rods containing curium oxide-aluminum pellets and a hydraulic tube in the central target region, occupying the position otherwise filled by the central target rod. The hydraulic tube can contain up to nine 0.5-in.-diam (1.27-cm), 2 9/16-in.-long (6.51-cm) capsules. For the development of the target assembly model for RELAP5 it was assumed for simplicity that the target region contained 31 target rods, including one rod replacing the hydraulic tube. The design of the target rods is presented in Fig. 15.

With reference to Fig. 15, water flows in the annulus formed by the tube containing the heavy metal pellets and the outer target rod tube. In Fig. 7, hydrodynamic volumes 5-01 through 5-07 are used to model this "heated" target flow path. A second flow path exists

Table 11. Fuel internal source multipliers for HFIR RELAP5 model

Axial location	Internal source multiplier			
(Top-to-bottom)	<i>Average fuel</i>			
	Inner element-1 ^a	Inner element-2 ^b	Outer element-1 ^a	Outer element-2 ^b
	1.15 × 10 ⁻³	1.13 × 10 ⁻³	1.78 × 10 ⁻³	1.74 × 10 ⁻³
	2.53 × 10 ⁻²	2.48 × 10 ⁻²	5.19 × 10 ⁻²	5.09 × 10 ⁻²
	3.63 × 10 ⁻²	3.56 × 10 ⁻²	7.37 × 10 ⁻²	7.22 × 10 ⁻²
	4.14 × 10 ⁻²	4.06 × 10 ⁻²	8.19 × 10 ⁻²	8.03 × 10 ⁻²
	3.66 × 10 ⁻²	3.59 × 10 ⁻²	7.42 × 10 ⁻²	7.27 × 10 ⁻²
(Top-to-bottom)	<i>Hot fuel</i>			
	Inner element	Outer element	Inner element-local	Outer element-local
	3.66 × 10 ⁻⁶	2.90 × 10 ⁻⁶	7.29 × 10 ⁻⁶	6.27 × 10 ⁻⁶
	2.54 × 10 ⁻⁴	2.38 × 10 ⁻⁴	3.16 × 10 ⁻⁶	3.18 × 10 ⁻⁶
	2.84 × 10 ⁻⁴	2.74 × 10 ⁻⁴	3.53 × 10 ⁻⁶	3.66 × 10 ⁻⁶
	3.52 × 10 ⁻⁴	3.45 × 10 ⁻⁴	4.36 × 10 ⁻⁶	4.61 × 10 ⁻⁶
	3.94 × 10 ⁻⁴	3.92 × 10 ⁻⁴	4.89 × 10 ⁻⁶	5.24 × 10 ⁻⁶
(Top-to-bottom)	<i>Hot fuel</i>			
	Inner element	Outer element	Inner element-local	Outer element-local
	4.09 × 10 ⁻⁴	4.06 × 10 ⁻⁴	5.07 × 10 ⁻⁶	5.42 × 10 ⁻⁶
	3.88 × 10 ⁻⁴	3.83 × 10 ⁻⁴	4.83 × 10 ⁻⁶	5.12 × 10 ⁻⁶
	3.41 × 10 ⁻⁴	3.31 × 10 ⁻⁴	4.24 × 10 ⁻⁶	4.43 × 10 ⁻⁶
	2.69 × 10 ⁻⁴	2.57 × 10 ⁻⁴	3.34 × 10 ⁻⁶	3.45 × 10 ⁻⁶
	2.38 × 10 ⁻⁴	2.17 × 10 ⁻⁴	2.95 × 10 ⁻⁶	2.91 × 10 ⁻⁶
(Top-to-bottom)	<i>Hot fuel</i>			
	Inner element	Outer element	Inner element-local	Outer element-local
	3.34 × 10 ⁻⁶	2.69 × 10 ⁻⁶	6.46 × 10 ⁻⁶	5.33 × 10 ⁻⁶

^a1% above average.^b1% below average.

Fig. 13. Target assembly.

ORNL-DWG 82-3200 ETD

Fig. 14. Core cross section.

ORNL-DWG 65-1383
R-1

Fig. 15. HFIR target rod configuration.

through the target assembly around the target rods. This "unheated" region is modeled with hydrodynamic volume 6 in Fig. 7.

As in the fuel region, oxide is assumed to form on aluminum components in the target region, and its effect on conduction heat transfer is modeled. However, for the purposes of calculating the flow areas and hydraulic diameters in this region, the effect of the oxide is small and ignored. The inside and outside diameters of the target rod (heated) annular flow path formed by the pellet containment tube and the target rod shroud are⁶¹

$$\text{inside diameter} = 0.369 \text{ in. (0.937 cm),}$$

$$\text{outside diameter} = 0.594 \text{ in. (1.51 cm).}$$

Thus, the total target heated flow area A_f^h is

$$A_f^h = 31\pi (0.594^2 - 0.369^2)/(2 \times 12)^2 \text{ ft}^2,$$

$$A_f^h = 3.66 \times 10^{-2} \text{ ft}^2 (5.70 \times 10^{-3} \text{ m}^2).$$

The heated target region hydraulic diameter D_{hy}^h is

$$D_{hy}^u = \frac{4 \cdot 6.72 \times 10^{-2}}{(5.33 + 1.33)} \text{ ft} ,$$

$$D_{hy}^h = 1.87 \times 10^{-2} \text{ ft (5.70} \times 10^{-3} \text{ m).}$$

The flow area of the unheated target region is taken to be the area of the hole within the inner fuel element less the area occupied by the target rods. The diameter of the hole D_h and the outside diameter of the target rod shrouds OD_t are⁶²

$$D_h = 5.067 \text{ in. (12.9 cm),}$$

$$OD_t = 21/32 \text{ in.} = 0.0547 \text{ ft (0.0167 m).}$$

The unheated target region flow area A_f^u is then calculated as

$$A_f^u = \pi [5.067/(12 \times 2)]^2 - 31\pi (0.0547/2)^2 \text{ ft}^2,$$

$$A_f^u = 6.72 \times 10^{-2} \text{ ft}^2 (6.24 \times 10^{-3} \text{ m}^2).$$

The hydraulic diameter of the unheated region D_{hy}^u is calculated based on A_f^u and the wetted perimeter of the outside surface of the target rods P_r and the hole containing the target assembly P_h

$$D_{hy}^u = 4 A_f^u / (P_r + P_h) ,$$

where

$$P_r = 31\pi \times 0.0547 \text{ ft,}$$

$$P_h = \pi \times 5.067/12 \text{ ft.}$$

Thus,

$$D_{hy}^u = \frac{4 \cdot 6.72 \times 10^{-2}}{(5.33 + 1.33)} \text{ ft ,}$$

$$D_{hy}^u = 4.04 \times 10^{-2} \text{ ft } (1.23 \times 10^{-2} \text{ m}).$$

As indicated in Fig. 15, the diameter of the target pellets is 0.249 in. (0.632 cm). Curium oxide, in a matrix of aluminum, is contained within the 0.195-in. (0.495-cm) region.⁶¹ The curium oxide-aluminum core is jacketed in 0.027-in.-thick (0.0686-cm) 1100 aluminum around the circumference and 0.050-in.-thick (0.127-cm) pure aluminum powder compacted at the ends. The pellets are contained in a 59-mil-thick (1.50-mm) 8001 aluminum tube [outer radius r_{rod} of 0.1845 in. (0.4686 cm)] with discontinuous fins that position it inside the outer target rod tube also constructed of 8001 aluminum.⁶¹ As will be described subsequently, a small gas gap [0.5 mils (0.13 mm)] exists at RT between the pellets and containment tube and becomes even smaller at HFIR normal operating conditions.⁶³ As will be described subsequently, the gas gap is taken to be 0.1 mil (2.54×10^{-3} mm) in the model. Oxide is assumed to form on the aluminum tube containing the pellets. The thickness of the oxide is taken to be the same as that used for the average fuel plate, 0.689 mil (0.0175 mm). Thus, the outer radial boundaries of the regions comprising the pellet and containment tube are

oxide, r_o

$$\begin{aligned} r_o &= r_{rod} + (\text{oxide thickness} - \text{Al consumed}), \\ &= 0.015375 + (0.689 - 0.689/1.254)/(1000 \times 12) \text{ ft}, \\ r_o &= 0.0153866 \text{ ft } (4.68984 \times 10^{-3} \text{ m}); \end{aligned}$$

containment tube, r_c

$$\begin{aligned} r_c &= r_o - \text{oxide thickness}, \\ &= 0.0153866 - 0.689/(1000 \times 12) \text{ ft}, \\ r_c &= 0.0153292 \text{ ft } (4.67234 \times 10^{-3} \text{ m}); \end{aligned}$$

gas gap, r_g

$$r_g = 0.01038333 \text{ ft } (3.16484 \times 10^{-3} \text{ m});$$

1100 aluminum jacket, r_j

$$r_j = 0.010375 \text{ ft } (3.16230 \times 10^{-3} \text{ m});$$

curium oxide-aluminum pellet, r_p

$$r_p = 8.125 \times 10^{-3} \text{ ft } (2.477 \times 10^{-3} \text{ m}).$$

With reference to Figs. 14 and 15, the length of the target region is taken to be 24 in. (61.0 cm), the same as the fuel element. The active length of the target rods is taken to be 20 in. (50.8 cm), the nominal value, with the remaining length containing an aluminum support liner and a void space for fission gas release instead of the curium oxide pellets as shown in Fig. 15. The total surface area of the target tubes containing the pellets A^h , is

$$A_s^h = 31\pi \times 2 \times 0.0153866 \times 20/12 \text{ ft}^2,$$

$$A_s^h = 4.99 \text{ ft}^2 (0.464 \text{ m}^2).$$

Similarly, the total surface area of the unheated portion of the tubes A_s^u is

$$A_s^u = 31\pi \times 2 \times 0.0153866 \times 4/12 \text{ ft}^2,$$

$$A_s^u = 0.999 \text{ ft}^2 (0.0928 \text{ m}^2).$$

The curium oxide-aluminum pellet core is composed of 11.2 g of curium oxide as $\text{CmO}_{1.73}$, per rod, 20% "void," and the balance 1100 aluminum.⁶⁴ For modeling purposes, the 1100 aluminum jacket at the ends of each pellet within the core radius is taken to be part of the core. Table 12 presents the mass and volume of each component in the pellet region assumed to comprise the core. Calculations used the density of pure aluminum, $169 \text{ lb}_m/\text{ft}^3$ (2710 kg/m^3) (Ref. 37), and a CmO_2 density of $227 \text{ lb}_m/\text{ft}^3$ (3640 kg/m^3) (Ref. 65) for $\text{CmO}_{1.73}$.

Table 12. Target pellet core composition per rod

Component	Volume fraction ^a (%)	Mass (lb_m)
$\text{CmO}_{1.73}$	30	0.0247
1100 Al	50	0.0308
Void	20	
Total		0.0555

^aTotal volume of $3.64 \times 10^{-4} \text{ ft}^3$.

The temperature-dependent specific heat of the pellet core was calculated as a mass weighted average of those of pure aluminum and $\text{CmO}_{1.73}$. The specific heat of $\text{CmO}_{1.73}$ could not be found, so values of Cm_2O_3 are used that are expected to be representative of $\text{CmO}_{1.73}$ (Refs. 66 and 67). Table 13 presents the specific heats of aluminum and $\text{CmO}_{1.73}$ along with the mass weighted core average value and the volumetric heat capacity.

The thermal conductivity of the pellet core was taken to be a constant, due to the lack of temperature-dependent property data. However, based on the weak temperature dependence of the fuel meat thermal conductivity and the similarity of these materials, available data should be adequate. The thermal conductivity value selected for the pellet core is based on measurements of aluminum- U_3O_8 void material.⁶⁸ The data indicate that voids and U_3O_8 particles reduce the thermal conductivity of the cermet by roughly the same amount. Thus, for the pellet core composition of 30 and 20% by volume $\text{CmO}_{1.73}$ (assumed

to affect cermet thermal conductivity like U_3O_8) and void, respectively, the thermal conductivity of the core k_c is taken to be⁶⁸

$$k_c = 13.9 \text{ Btu/h-ft-}^\circ\text{F} = 0.00386 \text{ Btu/s-ft-}^\circ\text{F} \text{ (24.0 W/m-K)} .$$

Table 13. Pellet core specific heat and volumetric heat capacity

Temperature (°F)	Specific heat (Btu/lb _m -°F)			Volumetric heat capacity (Btu/ft ³ -°F)
	Al	CmO _{1.73}	Core ^a	Core ^b
80	0.215	0.0627 ^c	0.148 ^c	22.5 ^c
440	0.238	0.0688	0.164	24.9
980	0.274	0.0751	0.186	28.3
1205	0.305	0.0769	0.205	31.2

$$^a \langle C_p(\text{core}) \rangle = 0.56 C_p(\text{Al}) + 0.44 C_p(\text{CmO}_{1.73}).$$

$$^b \langle \rho \rangle = 152 \text{ lb}_m/\text{ft}^3.$$

^cExtrapolated values using equation fit to data in Ref. 66.

The volumetric heat capacity and thermal conductivity of the pellet aluminum jacket is taken to be that of pure aluminum. The former property values (presented in Table 14) are derived from specific heat values (also provided) and an aluminum density of 169 lb_m/ft³ (2710 kg/m³).³⁷ The latter property values were previously presented for the fuel plate cladding (Table 6).

Table 14. Pellet aluminum jacket specific heat and volumetric heat capacity³⁸

Temperature (°F)	Specific heat (Btu/lb _m -°F)	Volumetric heat capacity (Btu/ft ³ -°F)
80	0.215	36.3
440	0.238	40.2
980	0.274	46.3
1205	0.305	51.5

The target containment tube, containing helium at ~0.5 atm of pressure,⁶⁴ is collapsed on the pellets hydrostatically. Destructive tests indicate that the maximum initial RT clearance between the pellet and tube is 0.5 mil (0.0127 mm).⁶⁹ During irradiation in the

HFIR, temperature differences between the pellet and tube will cause the gap to close further. Based on the thermal expansion of the pellet/tube and fission gas release, an estimate of the gap resistance can be made. It is noted that due to the importance of pellet-to-tube contact in determining the gap resistance, the RELAP5 gap conductance model, which ignores this mechanism, could not be used.

The target tube gap resistance has been investigated in a previous study.⁶³ The analysis presented here is similar. Gap resistances have been calculated for aluminum in contact with uranium metal with helium in the gap and with a 50% helium plus 50% xenon and krypton mixture by volume.⁷⁰ At a mean contact pressure of 200 psi (1.38 MPa) and a temperature of 752°F (400°C), the gap thermal conductance coefficient h_c was calculated to be ~40,000 Btu/h-ft²-°F (0.227 MW/m²-K) for the case with helium in the gap and ~30,000 Btu/h-ft²-°F (0.170 MW/m²-K) with the helium, xenon, and krypton gas mixture in the gap. In a second study,⁷¹ gap resistances were measured between several metals, including aluminum. For rough aluminum surfaces [50 to 100 μin. (1.27×10^{-3} to 2.54×10^{-3} mm)] in contact with each other, h_c was found to be ~2000 to 3500 Btu/h-ft²-°F (11,357 to 19,874 W/m²-K) with a contact pressure of 200 psi (1.38 MPa), temperature of 500°F (260°C), and air in the gap. With a temperature of 300°F (149°C), h_c "decreased" to ~1400 to 4000 Btu/h-ft²-°F (7949 to 22,713 W/m²-K). Increasing the contact pressure to 500 psi (3.45 MPa) resulted in h_c increasing dramatically at a temperature of 300°F (148.9°C) (h_c ~ 3000 to 8500 Btu/h-ft²-°F or 17,035 to 48,265 W/m²-K) and even more so at 500°F (260°C) (h ~ 5500 to 11,000 Btu/h-ft²-°F or 31,230 to 62,461 W/m²-K). Similarly, in the former study,⁷⁰ the thermal conductance coefficient was calculated to increase significantly with increasing contact pressure.

The composition of the gas in the target rods can be estimated based on the initial pressure of the helium fill gas and the fission gas released during irradiation. It has been estimated that 215 cm³ (Ref. 62) of gas at STP will be produced during irradiation, of which 5% (10.75 cm³) or less will escape the pellets and enter the target tube plenum and gap.⁷² The gases released during irradiation and their volume fractions are xenon (91.6%), helium (6%), and krypton (2.4%). Based on the above information and the void volume in each target rod (6.5 cm³),⁶² the composition of the gas occupying the gap was determined to be 70% xenon, 28% helium, and 2% krypton. At 500°F (260°C), the thermal conductivity of the target gas mixture (~0.020 Btu/h-ft-°F or 0.035 W/m-K)⁷³ is similar to that of air (~0.025 Btu/h-ft-°F or 0.043 W/m-K).⁷⁴ Thus, the thermal conductance coefficient data described above are representative of those for the target gap.

Based on the above discussion, to achieve a reasonably high gap thermal conductance coefficient between the target pellet and tube, a contact pressure on the order of 200 psi (1.38 MPa) or higher is needed. Given a desired contact pressure (e.g., 500 psi or 3.45 MPa), the required temperature drop through the gap can be determined to provide the necessary pressure supporting thermal expansion. Based on analysis elsewhere,⁷⁵

$$t = C - (T_1 - T_2) \lambda R, \quad (1)$$

where

t = clearance (gap) at operating conditions, mils;

T_2 = average target tube temperature, °F;

T_1 = average pellet temperature, °F;

λ = aluminum linear thermal expansion coefficient, $14.2 \times 10^{-6}/^\circ\text{F}$ ($2.56 \times 10^{-5}/^\circ\text{C}$);³⁷

R = pellet radius, 124.5 mils (3.162 mm);

C = initial clearance, 0.5 mils (0.013 mm).

A second equation, which relates the contact pressure P to the interference I (the difference in diameters between the pellet and tube at temperature in an unconstrained state) is⁷⁶

$$I = \frac{4b^3 P(c^2 - a^2)}{E(c^2 - b^2)(b^2 - a^2)},$$

where

a = pellet inside radius = 0,

b = pellet (including jacket) outside radius = 0.010375 ft (0.31623 cm),

c = tube outside radius = 0.0153292 ft (0.467234 cm),

E = aluminum modulus of elasticity, 1×10^7 psi (68,948 MPa).³⁷

With $P = 500$ psi, the interference is found to be

$$I = \frac{4 \cdot (0.010375)^3 \cdot 500 \cdot (0.0153292)^2 \cdot 12 \cdot 1000}{1 \times 10^7 \cdot [(0.0153292)^2 - (0.010375)^2] \cdot (0.010375)^2} \text{ mils .}$$

$$I = 0.046 \text{ mils } (1.17 \times 10^{-3} \text{ mm}) .$$

By letting $t = -I = -0.046$ mils (-1.17×10^{-3} mm), the temperature difference between the pellet and tube, $T_1 - T_2$, can be calculated with Eq. (1):

$$T_1 - T_2 = (0.5 + 0.046)/(14.2 \times 10^{-6} \times 124.5) ^\circ\text{F},$$

$$T_1 - T_2 = 309^\circ\text{F} \approx 310^\circ\text{F} (172^\circ\text{C}).$$

Because $T_1 - T_2$ will be greater than the gap temperature drop, a gap drop of 310°F (172°C) will conservatively result in a contact pressure of 500 psi (3.45 MPa).

The analysis above neglects the effect of the difference between the gas pressure within the tube and the external tube pressure. The gas pressure P_g inside the tube can be estimated using the ideal gas law given the preoperation (cold) and operation (hot) gas volumes and temperatures, and preoperation pressure, that is,

$$P_g = P_i V_r T_r ,$$

where

P_i = preoperation pressure,

V_r = hot-to-cold volume ratio at STP,

T_r = hot-to-cold absolute temperature ratio.

As indicated previously, the preoperation gas volume at STP is 3.25 cm³, while the corresponding operation value is 14 cm³. Thus, $V_r = 4.31$. Assuming preoperation and operation gas temperatures of 80°F (300 K) and 600°F (589 K), respectively, gives $T_r = 1.96$. Thus, with a P_i of 0.5 atm (7.35 psi or 0.051 MPa),

$$P_g = 7.35 \times 4.31 \times 1.96 \text{ psi},$$

$$P_g = 62 \text{ psi (0.43 MPa)}.$$

Obviously, under normal operation the external tube pressure will be much higher than P_g ; however, under accident conditions the external pressure could drop to atmospheric pressure or lower (for a very brief duration). Assuming an external pressure of 14.7 psi (0.10 MPa) the difference is ~50 psi (0.35 MPa). The effect of this difference is very small because small variations ~310°F (172°C) produce large variations in the contact pressure.

During HFIR normal steady-state operation, the target heat load is ~0.888 MW (see Table 1). Applying this load to the total target rod surface area at the pellet-tube interface [$A^{p,i} = A_s^h \times r_j/r_o = 4.99 \text{ ft}^2 \times 0.010375/0.0153866 = 3.36 \text{ ft}^2 (0.312 \text{ m}^2)$], the peak heat flux q_p^h is found to be $1.09 \times 10^6 \text{ Btu/h-ft}^2 (3.44 \times 10^6 \text{ W/m}^2)$. An "implied" thermal conductance coefficient h_c^i can be calculated based on the gap temperature drop ΔT_g necessary to produce a 500-psi (3.45-MPa) contact pressure and the peak heat flux at the pellet/tube interface. That is,

$$h_c^i = q_p^h / \Delta T_g$$

$$= 1.09 \times 10^6 / 310 \text{ Btu/h-ft}^2\text{-}^\circ\text{F},$$

$$h_c^i = 3516 \text{ Btu/h-ft}^2\text{-}^\circ\text{F} (14,323 \text{ W/m}^2\text{-K}).$$

The value of h_c^i is at the low end of the range of measured values of h_c described previously at a contact pressure of 500 psi (3.45 MPa) and temperatures of 300 and 500°F (148.9 and 260°C).⁷¹ Conservatively, the value of h_c selected for use in the RELAP5 model is

$$h_c = 3500 \text{ Btu/h-ft}^2\text{-}^\circ\text{F} (19,873 \text{ W/m}^2\text{-K}).$$

Importantly, use of this value of h_c will lead to a conservative calculation of the gap temperature drop at the target hot spot (i.e., core axial centerline) and a representative value at other locations only when the heat flux is not too much below q_p^h . As the heat flux decreases further, this value becomes optimistic. In these cases, the analyst should simply add an additional temperature margin to the code predicted values to determine the pellet temperatures. A conservative temperature margin can be calculated as the difference between the code calculated gap temperature drop and that needed to provide a $h_c = 3500 \text{ Btu/h-ft}^2\text{-}^\circ\text{F} (19,873 \text{ W/m}^2\text{-K})$ [$\Delta T_g \sim 310^\circ\text{F} (172^\circ\text{C})$].

With the 0.1-mil (2.54×10^{-3} -mm) gap assumed for the RELAP5 model, the effective thermal conductivity k_{eff} of the gap is

$$k_{eff} = h_c \times 0.1 \text{ mil},$$

$$= 3500 \text{ Btu/h-ft}^2\text{-}^\circ\text{F} \times 0.1 \text{ mil},$$

$$k_{eff} = 8.11 \times 10^{-6} \text{ Btu/s-ft-}^\circ\text{F} (5.06 \times 10^{-3} \text{ W/m-K}).$$

As mentioned previously, the portion of the target tube without pellets contains a void space for fission gas release and an aluminum support liner. Because the thermal contact between the target tube and support liner may or may not be good, the liner is not included in the heat structure model of this portion of the target rod. Thus, the model includes only the tube and oxide, with outer radial boundaries as given previously for the region with pellets.

Thermophysical properties could not be found for the 8001 aluminum⁶² target pellet containment tube. The composition of the alloy, in percent, is 0.17 silicon, 0.45–0.7 iron, 0.15 copper, 0.9–1.3 nickel, 0.05 zinc, and the balance essentially aluminum.⁷⁷

The specific heat of 8001 aluminum was taken to be the mass weighted average of the values of its major constituents, aluminum (98.5%), nickel (1%), and iron (0.5%). The specific heats of the components are presented in Table 15 along with the composition average specific heat and volumetric heat capacity. The calculation of the latter assumed a material density of pure aluminum, 169 lb_m/ft³ (2710 kg/m³).³⁷

The thermal conductivity of the 8001 aluminum containment tube was taken to be that of an alloy with a composition as close as possible to 8001 aluminum. The composition of the alloy selected, in percent, is 0.43 iron, 0.10 silicon, 0.32 magnesium, and the balance aluminum. The thermal conductivity of this alloy is presented in Table 16.⁷⁸

The flow rate through the target region during HFIR normal operation varies from about 710 to 770 gal/min (0.045 to 0.049 m³/s), depending upon the target configuration as well as that of the remainder of the system.⁶⁰ When the target is configured with 30 target rods and the hydraulic tube, design information indicates that the flow rate is 752 gal/min (0.047 m³/s) with 649 gal/min (0.041 m³/s) through the heated flow path and 103 gal/min (6.5 × 10⁻³ m³/s) through unheated flow paths. Following normalization of these flows based on operation data, the flows through the target region are 663 and 105 gal/min (4.1 × 10⁻² and 6.62 × 10⁻³ m³/s) for the heated and unheated regions, respectively.

Table 15. Target pellet containment tube specific heat and volumetric heat capacity

Temperature (°F)	Specific heat (Btu/lb _m -°F)				Volumetric heat capacity (Btu/ft ³ -°F)
	Aluminum ^a	Iron ^b	Nickel ^c	Tube ^d	
80	0.215	0.104	0.107	0.213	36.0
440	0.238	0.128	0.125	0.236	39.9
674	0.252	0.141	0.160	0.251	42.4
710	0.255	0.142	0.130	0.253	42.8
980	0.274	0.161	0.126	0.272	46.0
1205	0.305	0.190	0.131	0.303	51.2

^aReference 38.

^bReference 79.

^cReference 80.

^d $\langle C_p(\text{tube}) \rangle = 0.985 C_p(\text{Al}) + 0.005 C_p(\text{Fe}) + 0.01 C_p(\text{Ni})$.

Table 16. Target pellet containment tube thermal conductivity

Temperature (°F)	Thermal conductivity (Btu/s-ft-°F)
80	0.0336 ^a
122	0.0336
302	0.0347
572	0.0356
1200	0.0383 ^a

^aValues extrapolated based on linear equation fit to data.

The roughness of the surfaces of the target region structures was assumed to be 20 μ in. (5.08×10^{-4} mm), the same as that used for the fuel. Calibration of the model to obtain the desired flows through the heated and unheated regions was achieved using the abrupt area change model at the channel entrances (junctions 17-01 and 17-02) and exits (junctions 8-03 and 8-04). At the channel exits, the model simulates the target grid orifices, which are positioned beneath the target assembly. The area used to model the orifices is approximately 3 times smaller than the heated channel flow area. An area approximately 19 times smaller (0.004789 ft^2 or $4.45 \times 10^{-4} \text{ m}^2$) than the unheated channel area is used at the channel exit and was found to provide the same pressure drop that exists at the heated channel exit (i.e., the pressure drop simulating that over the target grid orifices). In addition, an area approximately 14 times smaller (0.00349 ft^2 or $3.24 \times 10^{-4} \text{ m}^2$) than the unheated channel flow area was used at the channel entrance. This simulates pressure drops through various orifices controlling flow through the target "bypass" (unheated) region.

The power liberated in the target region during HFIR normal operation at 85 MW is 888 kW, as presented previously in Table 1. In the RELAP5 model, this power is assumed to be absorbed within the pellet core. Because the radial peak-to-average thermal neutron flux ratio in the target is small, ≤ 1.04 , radial power variations within this region are neglected.⁸¹

The average of the target BOC fission and EOC decay heat axial distributions was used in the model. The two distributions are similar. The average distribution over the active length derived from the base heat load calculations was scaled upward to account for the difference between the target configuration used in the calculations and that producing the highest heat loads. In addition, it was scaled upward to account for uncertainties in the calculations. A multiplicative factor of 2.22 was used that includes a 15% margin for uncertainty. The effect of this factor is to increase the target loads to 2.1 times that obtained in the base heat load calculations (i.e., 417 kW at 85 MW total core power).²⁷

As indicated in Fig. 7, the heated target region is broken axially into seven subregions. The top and bottom subregions are 2 in. (5.08 cm) long and contain the portions of the rod without pellets. The remaining five subregions, each 4 in. (10.2 cm) long, contain the pellets. Target rod RELAP5 internal source multipliers were calculated by distributing the total target region power to each heat structure according to surface area. Then, the axial power factors were used to scale the multipliers to represent the axial power variation. The target region

multipliers are referenced to the extra-fuel element power. Table 17 presents the target region axial power peaking factors and internal source multipliers.

Table 17. Target axial power peaking factors and RELAP5 internal source multipliers

Axial location (top-to-bottom)	Axial power peaking factor	Internal source multiplier
1	0.458	3.72×10^{-3}
2	1.87	3.04×10^{-2}
3	2.77	4.48×10^{-2}
4	3.10	5.02×10^{-2}
5	2.75	4.45×10^{-2}
6	1.84	2.98×10^{-2}
7	0.444	3.60×10^{-3}

3.2.4 Control cylinders

As shown in Fig. 7, the control cylinders and associated flow channels are modeled with two sets of heat structures (28-01 through 28-05 and 29-01 through 29-05) and three flow channels (hydrodynamic volumes 27, 28, and 29). The location of the control cylinders and annular cooling passages within the HFIR core are indicated in Fig. 16. As shown, the control cylinders are contained in an annular region between the outer fuel element and the beryllium reflector. With reference to Fig. 7, the outermost control region flow channel is connected to heat structures representing the innermost portion of the removable beryllium reflector (to be described in the following section).

The inner control cylinder, which is a single piece, performs shim and regulating functions. The outer cylinder is divided into quadrants, each performing shim and safety functions. The control cylinders are divided into three longitudinal sections, each of which has different neutron absorbing characteristics. The "black" region is the most absorbing followed in turn by the "gray" and "white" regions. The composition and location of these regions are provided in Fig. 17.

As assumed in calculating flow areas and hydraulic diameters for the target region, the presence of the oxide on aluminum structures in the control region is neglected due to its small effect on these parameters. However, also consistent with previous treatment, the effect of the oxide on control cylinder heat transfer is modeled.

The inside and outside radii of the annular region containing the control cylinders are²⁵

inside radius = 8.567 in. (21.76 cm),

outside radius = 9.436 in. (23.97 cm).

Fig. 16. Schematic representation of control cylinders within HFIR core.

Fig. 17. Control cylinders.

The inside r_i^j and outside r_o^j radii of the inner control cylinder and those of the outer control cylinder r_i^o and r_o^o are

$$r_i^j = 8.671 \text{ in. (22.02 cm),}$$

$$r_o^j = 8.921 \text{ in. (22.66 cm),}$$

$$r_i^o = 9.091 \text{ in. (23.09 cm),}$$

$$r_o^o = 9.341 \text{ in. (23.73 cm).}$$

For each outer control cylinder quadrant, r_i^j and r_o^j include a radial offset of 0.041 in. (0.104 cm) in the quadrant median axial centerline from the core centerline.⁸² The thickness of the inner, Δr_i , middle, Δr_m , and outer, Δr_o , annular flow passages are therefore

$$\Delta r_i = 0.104 \text{ in. (0.264 cm),}$$

$$\Delta r_m = 0.170 \text{ in. (0.432 cm),}$$

$$\Delta r_o = 0.095 \text{ in. (0.241 cm).}$$

The flow area A_f^i and hydraulic diameter D_{hy}^i of the inner annular region are calculated as follows:

$$A_f^i = \pi(8.671^2 - 8.567^2)/144 \text{ ft}^2,$$

$$A_f^i = 0.0391 \text{ ft}^2 (3.63 \times 10^{-3} \text{ m}^2),$$

$$D_{hy}^i = 4 A_f^i / \text{wetted perimeter},$$

$$= 4 \times 0.0391 / [2\pi (8.567 + 8.671)/12] \text{ ft},$$

$$D_{hy}^i = 0.0173 \text{ ft } (5.27 \times 10^{-3} \text{ m}).$$

Similarly, the flow areas A_f^m and A_f^o and hydraulic diameters D_{hy}^m and D_{hy}^o , of the middle and outer annular regions, respectively, were calculated to be

$$A_f^m = 0.0668 \text{ ft}^2 (6.21 \times 10^{-3} \text{ m}^2),$$

$$D_{hy}^m = 0.0283 \text{ ft } (8.63 \times 10^{-3} \text{ m}),$$

$$A_f^o = 0.0389 \text{ ft}^2 (3.61 \times 10^{-3} \text{ m}^2),$$

$$D_{hy}^o = 0.0158 \text{ ft } (4.82 \times 10^{-3} \text{ m}).$$

Because the reactor will generally be shut down following the initiation of accidents of interest, the RELAP5 input model is configured with the black region within the vertical boundaries of the core. In addition, it is assumed for simplicity that the black region extends the full 24-in. (61.0-cm) height of the core, when in fact the length of the black region is 22 in. (55.9 cm).⁸²

As indicated in Fig. 17, the black region contains a europium oxide (Eu_2O_3)-aluminum "core" clad in 6061-F aluminum. The core and clad thicknesses are 0.2 and 0.025 in. (0.508 and 0.064 cm), respectively.⁸¹ An oxide film is assumed to form on the control cylinder surfaces with a thickness of 0.689 mil (0.0175 mm), the same as that used for the average fuel

plates. The radial boundaries of the regions comprising the control cylinders are presented in Table 18.

Table 18. Radial boundaries of regions comprising the control cylinders

Region	Inner control cylinder radius (ft)		Outer control cylinder ^a radius (ft)	
	Inside	Outside	Inside	Outside
Oxide	0.722571	0.722628	0.754155	0.754212
Clad	0.722628	0.724667	0.754212	0.756250
Core	0.724667	0.741333	0.756250	0.772917
Clad	0.741333	0.743371	0.772917	0.774955
Oxide	0.743371	0.743428	0.774955	0.775012

^aBased on outer control cylinder inside and outside radii of curvature of 9.050 and 9.300 in., respectively.⁸²

The inside $A_{s,i}^i$ and outside $A_{s,o}^i$ surface areas of the inner control cylinder and those of the outer cylinder, $A_{s,i}^o$ and $A_{s,o}^o$, are

$$\begin{aligned}
 A_{s,i}^i &= 2 \pi r_i^i L \\
 &= 2 \pi \times 0.722571 \times 2 \text{ ft}^2, \\
 A_{s,i}^i &= 9.08 \text{ ft}^2 (0.844 \text{ m}^2), \\
 A_{s,o}^i &= 9.34 \text{ ft}^2 (0.868 \text{ m}^2), \\
 A_{s,i}^o &= 9.48 \text{ ft}^2 (0.881 \text{ m}^2), \\
 A_{s,o}^o &= 9.74 \text{ ft}^2 (0.905 \text{ m}^2).
 \end{aligned}$$

The core region of the control cylinders contains 59.14 wt % Eu_2O_3 and the balance 1100 aluminum.⁸² The density of the core region at RT is reported to be 4.25 g/cm^3 ($265.3 \text{ lb}_m/\text{ft}^3$).⁸² The temperature-dependent specific heat of the control cylinder core was calculated as a mass weighted average of those of pure aluminum and Eu_2O_3 (cubic crystal structure).⁸³ Table 19 presents the specific heats of aluminum and Eu_2O_3 along with the core average values and the core volumetric heat capacity. The core region thermal conductivity is reported to be $39 \text{ Btu/h-ft-}^\circ\text{F}$ ($0.0108 \text{ Btu/s-ft-}^\circ\text{F}$ or 67.5 W/m-K), presumably at RT;⁸² no temperature-dependent data could be located.

Thermophysical properties of the 6061-F aluminum control cylinder cladding could not be found. Therefore, properties of 6061-T6 aluminum were used. The specific heat of 6061-T6 aluminum was presented previously in Table 6 and was used, along with its density, $169 \text{ lb}_m/\text{ft}^3$ (2710 kg/m^3), to calculate the clad volumetric heat capacities presented in Table 20. The clad thermal conductivity is presented in Table 21.

Table 19. Control cylinder core specific heat and volumetric heat capacity

Temperature (°F)	Specific heat (Btu/lb _m -°F)		Core	Volumetric heat capacity (Btu/ft ³ -°F)
	Al ^a	Eu ₂ O ₃ ^b		
80	0.215	0.085	0.138	36.6
440	0.238	0.093	0.152	40.3
980	0.274	0.099	0.171	45.4
1205	0.305	0.101	0.184	48.8

^aReference 38.^bReference 84.

Table 20. Control cylinder clad volumetric heat capacity

Temperature (°F)	Volumetric heat capacity (Btu/ft ³ -°F) ^a
80	36.3
440	39.9
980	45.5
1160	47.3

^a6061-T6 aluminum values used.Table 21. Control cylinder clad thermal conductivity⁴⁸

Temperature (°F)	Thermal conductivity ^a (Btu/s-ft-°F)
82.4	0.0255
442.4	0.0299
802.4	0.0310
1204	0.0276 ^b

^a6061-T6 aluminum values used.^bExtrapolated.

Based on design information,⁸² the flow rate through the control region during HFIR normal operation is 1080 gal/min (0.06814 m³/s). A flow rate of 1103 gal/min (0.06959 m³/s) or 151.9 lb_m/s (68.90 kg/s) was calculated for the control region following normalization with operation data.

As shown in Fig. 17, the control cylinders possess numerous holes that make the calculation of flow/pressure drop difficult. Thus, an "effective" roughness of the control region surfaces was selected that provided the desired flow and pressure drop. On this basis, a surface roughness of 6.5×10^{-4} ft (1.98×10^{-4} m) is used in the model. Consistent with the flow geometry, the abrupt area change model was used at the entrances and exits to the control region.

The power liberated in the control cylinders during HFIR normal operation at 85 MW is estimated to be 1.71 MW, as presented previously in Table 1. In the RELAP5 model, the total heat load is assumed to be absorbed within the core of the control cylinders and along the modeled 2-ft (0.610-m) length, rather than their full length. With reference to Fig. 7, the control region is divided axially into five subregions. The center region is 4 in. (10.2 cm) long, and each of the remaining four subregions are 5 in. (12.7 cm) long. The axial power distribution in the control cylinders is based on the decay heat load distribution with an adjustment. This was done because control cylinder heating due to fission heat loads was calculated under normal operating conditions with the cylinders far from their shutdown position. Thus, the fission axial heat load distribution is not representative after shutdown. However, the extra fission heat absorbed in the black regions of the control cylinders compared to the white regions is not included in the decay heat axial distribution. Thus, based on a comparison of fission heat loads in these regions, the decay heat axial distribution was adjusted upward by 38% to account for this effect.²⁷ The resulting axial power factors are presented in Table 22. Also presented in Table 22 are the RELAP5 heat structure multipliers for the control cylinders. The multipliers were calculated by distributing the 1.71-MW control region heat load based on relative heat structure surface area and axial power factor. The control region multipliers are referenced to the extra-fuel element power.

Table 22. Control cylinder axial power peaking factors and RELAP5 internal source multipliers

Axial location (top-to-bottom)	Axial power peaking factor		Internal source multiplier	
	Inner	Outer	Inner	Outer
1	1.03	0.829	3.17×10^{-2}	2.47×10^{-2}
2	1.63	1.63	5.02×10^{-2}	4.86×10^{-2}
3	1.88	1.88	4.64×10^{-2}	4.47×10^{-2}
4	1.63	1.63	5.02×10^{-2}	4.86×10^{-2}
5	0.842	1.03	2.60×10^{-2}	3.07×10^{-2}

3.2.5 Beryllium Reflector

The beryllium reflector is shown in vertical cross section in Fig. 14 and in horizontal cross section at the core midplane in Fig. 18. It is evident in Fig. 18 that the reflector is composed of five concentric cylinders that are cooled by many small coolant passages (the small circles within and at interfaces between cylinders). The inner three reflector cylinders comprise the "removable" beryllium reflector. The fourth cylinder is referred to as the "semipermanent" reflector while the outermost and largest cylinder is the "permanent" reflector. Also noteworthy in Fig. 18 are the experimental facilities located in, or terminating in, the reflector. These include three horizontal beam tubes, four slant access tubes called engineering facilities, and 42 vertical holes. The latter are denoted by "VXF" and "RB" along with the facility number (Fig. 18 does not contain the recent modifications to the RB facilities).²⁴

As shown in Fig. 7, the beryllium reflector is divided into four subregions in the RELAP5 input model. With the exception of the engineering facilities, the experimental facilities are "homogenized" within these subregions. Because the engineering facilities are on the periphery of the reflector, flow through them is assumed to occur through the modeled bypass regions (U-bypass and L-bypass in Fig. 7). The innermost subregion (R-Be) consists of the inner beryllium cylinder in the removable reflector. This small region was created to simulate the portion of the reflector with the highest heat load per unit volume. The subregion adjacent to this region (S/R-Be) is composed of the remaining two removable reflector cylinders along with the semipermanent reflector cylinder. The last two subregions model the permanent reflector. This portion of the reflector was divided into two pieces to better represent the cooling characteristics of each. The inner region (I-P-Be) includes the portion up to and including half of the outermost ring of small holes. The outer region (O-P-Be) consists of the remaining portion and is cooled by water in the vessel adjacent to it in addition to the small coolant holes.

A detailed description of the four reflector subregions comprising the model is presented in the following three subsections. In the first, the innermost ("hot") removable reflector subregion is described. In the following two subsections, descriptions are provided of the subregion composed of the rest of the removable reflector and semipermanent reflector and the two subregions comprising the permanent reflector.

3.2.5.1 Hot removable reflector

The hot removable reflector subregion contains a beryllium cylinder with inner and outer radii of 9.498 and 9.889 in. (24.12 and 25.12 cm), respectively.²⁵ The inside surface of the cylinder is lined with 62-mil-thick (1.57-mm) aluminum. Cooling of this portion of the reflector is provided on the inside surface of the aluminum by water flowing between it and the outermost control cylinder (see Sect. 3.2.4). On the outside surface of the beryllium cylinder, cooling is provided by water flowing through 144 grooves [0.125 in. (0.318 cm) in diameter] on the surfaces comprising the interface between the two innermost reflector cylinders.⁸⁵ Consistent with the treatment of oxide in other regions, oxide is assumed to form on the inside surface of the aluminum liner, and its effect on conduction heat transfer is modeled.

Based on previous analysis,⁸⁵ the grooves are assumed to be 0.125-in.-diam (0.318-cm) holes. Thus, the flow area per hole A_f^h and the hydraulic diameter D_{hy} are

$$A_f^h = 8.52 \times 10^{-5} \text{ ft}^2 (7.92 \times 10^{-6} \text{ m}^2),$$

$$D_{hy} = 1.04 \times 10^{-2} \text{ ft} (3.17 \times 10^{-3} \text{ m}).$$

It was assumed that the flow through half of the holes between the two innermost reflector cylinders effectively cools each cylinder. Therefore, with 72 holes associated with the hot removable reflector region, the total flow area A_f' is

$$A_f' = 6.13 \times 10^{-3} \text{ ft}^2 (5.69 \times 10^{-4} \text{ m}^2).$$

The thickness of the oxide on the inner surface of the aluminum liner is assumed to be 0.689 mil (0.0175 mm) (the same as that in the target and control regions). Accounting for the presence of the oxide, the radial boundaries of the regions comprising the hot removable reflector cylinders are presented in Table 23.

Table 23. Radial boundaries of regions comprising the hot removable reflector cylinders

	Radii (ft)	
	Inside	Outside
Oxide	0.786322	0.786379
Aluminum	0.786379	0.7915
Beryllium	0.7915	0.8241

The heat transfer surface area A_s^h of half the holes along the 2-ft (0.610-m) length L of the reflector is

$$A_s^h = 72 \times 2\pi r L,$$

$$A_s^h = 4.71 \text{ ft}^2 (0.438 \text{ m}^2).$$

The total outside surface area A_s^c of the innermost reflector cylinder is

$$A_s^c = 2\pi r L,$$

$$A_s^c = 10.36 \text{ ft}^2 (0.9624 \text{ m}^2).$$

In modeling the heat transfer from the outside cylinder surface to the fluid, the surface area is conservatively taken to be the smaller of the two areas above. Thus, in using the RELAP5 1-D conduction model in cylindrical geometry the "effective" height of the reflector cylinder, h_{eff} is

$$h_{eff} = 2 \times 4.71/10.36 \text{ ft},$$

$$h_{eff} = 0.909 \text{ ft} (0.277 \text{ m}).$$

The reduction of the effective cylinder height results in a similar reduction in the area of the inside surface of the aluminum liner. In addition, the volume and mass of the cylinder are

effectively reduced by 55% as is the total heat capacity. On the other hand, the volumetric heat generation rate is increased by 55%. The mass and total heat capacity was not "corrected" in the model by using higher "effective" densities because the region comprises a small portion of the reflector, and thus it would not be expected to effect the rest of the system significantly. In light of the other effects of using a reduced cylinder effective height, the model should be conservative overall.

The reflector liner is constructed of 6061-T6 aluminum.⁸⁵ Thermophysical properties of this alloy have been previously presented in Tables 19 and 20. Similarly, properties of the oxide film were presented in Sect. 3.2.1. The density of beryllium at RT is reported to be 116 lb_m/ft³ (1858 kg/m³).⁸⁶ The specific heat and volumetric heat capacity of beryllium are presented in Table 24,⁸⁷ and its thermal conductivity is provided in Table 25.⁸⁸

Table 24. Beryllium specific heat
and volumetric heat capacity

Temperature (°F)	Specific heat (Btu/lb _m -°F)	Volumetric heat capacity (Btu/ft ³ -°F)
80	0.432	50.1
392	0.540	62.6
752	0.615	71.3
1292	0.692	80.3

Table 25. Beryllium thermal
conductivity

Temperature (°F)	Thermal conductivity (Btu/s-ft-°F)
80	0.0322
260	0.0258
620	0.0202
1160	0.0156

Based on previous design data and calculations, the total flow rate through the removable reflector was determined to be ~132 gal/min (8.33×10^{-3} m³/s) during HFIR normal operation.⁸⁵ These calculations indicated that the fluid velocity was 12.5 ft/s (3.81 m/s) through the total 272 removable reflector holes. The flow rate through the 72 holes associated with the hot removable reflector region can be calculated by scaling the total flow with the relative number of holes. Thus, the subregion flow rate G is

$$G = 132 \times 72/272 \text{ gal/min,}$$

$$G = 34.9 \text{ gal/min } (2.20 \times 10^{-3} \text{ m}^3/\text{s}).$$

After normalizing this value with operation data, the flow becomes 35.6 gal/min ($2.25 \times 10^{-3} \text{ m}^3/\text{s}$) or 4.91 lb_m/s (2.23 kg/s). To provide the desired flow rate at the measured pressure drop through the reflector [~ 10 psi (0.0689 MPa) in normal operation], the roughness of the channel surfaces was selected to be 2.1×10^{-4} ft (6.40×10^{-5} m). The effect of this "calibration" is to distribute the small pressure drop [~ 1 psi (6.89×10^{-3} MPa)] caused by orifices at the top of the removable reflector over the total length of the channel. The approach simplified the calibration with little loss of accuracy. The abrupt area change model is used at the entrance and exit to the hot removable reflector region based on the nominal channel area.

As indicated in Table 1, the power liberated in the hot removable reflector during HFIR normal operation at 85 MW is estimated to be 327 kW. The average of the region's BOC fission and EOC decay heat axial distributions was used in the model. The two distributions are similar.²⁷ In the radial direction, the heat is assumed to be absorbed uniformly. With reference to Fig. 7, the hot reflector region and the other reflector regions are divided into five subregions, with a discretization matching that of the control region. The center region is 4 in. (10.16 cm) long, with each of the remaining subregions 5 in. (12.7 cm) long. As described previously, the effective (modeled) heights of the reflector cylinder heat structures are $\sim 55\%$ shorter than actual. Based on the relative heat structure surface areas, the axial power factors, and the total 327-kW heat load, RELAP5 internal source multipliers were calculated. Multipliers are referenced to the extra-fuel element power and are presented in Table 26 along with the axial power factors.

Table 26. Hot removable beryllium reflector
axial power peaking factors and RELAP5
internal source multipliers

Axial location (top-to-bottom)	Axial power peaking factor	Internal source multiplier
1	0.709	1.13×10^{-2}
2	1.21	1.92×10^{-2}
3	1.35	1.73×10^{-2}
4	1.16	1.84×10^{-2}
5	0.654	1.04×10^{-2}

3.2.5.2 Removable/semipermanent reflector

The "removable/semipermanent" beryllium reflector subregion is 3.236 in. (8.219 cm) thick with inner and outer radial boundaries of 9.889 and 13.125 in. (25.12 and 33.338 cm), respectively. With reference to Fig. 18, cooling of this region of the reflector is provided by small coolant passages. Some of these passages are 0.125-in.-diam (0.318-cm) grooves, while others are narrow slots of differing dimensions.⁸⁵ For simplicity, it is assumed that all the flow is through 0.125-in.-diam (0.318-cm) holes. Thus, the region hydraulic diameter is 0.0104 ft (3.175×10^{-3} m). The total "effective" number of holes in this region was calculated based on a reported flow velocity of ~ 13 ft/s (3.96 m/s) and total flow rate of ~ 600 gal/min (~ 1.34

ft³/s or 0.038 m³/s) during normal HFIR operation.⁸⁵ It was assumed that half of the flow at the interface between the semipermanent and permanent reflector [28 gal/min (1.77 × 10⁻³ m³/s) total] contributes to the total region flow. The total number of 0.125-in.-diam (0.318-cm) holes N_h is calculated to be

$$\begin{aligned} N_h &= \text{flow}/(\text{velocity } A_f^h), \\ &= 1.34/(13 \times 8.52 \times 10^{-5}), \\ N_h &= 1.21 \times 10^3. \end{aligned}$$

The total flow area is 0.103 ft² (9.57 × 10⁻³ m²), and the total surface area A_f^h implied by N_h holes is

$$\begin{aligned} A_f^h &= \pi D L N_h, \\ &= \pi \times 0.0104 \times 2 \times 1.21 \times 10^3 \text{ ft}^2, \\ A_f^h &= 79.1 \text{ ft}^2 (7.35 \text{ m}^2). \end{aligned}$$

Due to the numerous cooling passages between the three beryllium cylinders, they are "decoupled" from a thermal-conduction standpoint. Conservatively, "slab" geometry was used to model the cylinders where the slab thickness was taken to be half that of the semipermanent reflector cylinder (the thickest region between coolant passages, 1.183 in.).²⁵ The half-thickness was used because one side of the slab is adiabatic, representing a plane of symmetry through its center (horizontally) and along its length. The area of the adiabatic slab surface was selected after considering the total volume of the beryllium cylinders within the region and the total surface area of the holes A_f^h . The total volume V of this region is

$$\begin{aligned} V &= \pi [(13.125/12)^2 - (9.889/12)^2] \times 2 \text{ ft}^3, \\ V &= 3.25 \text{ ft}^3 (0.0920 \text{ m}^3). \end{aligned}$$

The total surface area A_s^v of the slab, which is consistent with this volume, is

$$\begin{aligned} A_s^v &= 2 V/\text{slab thickness}, \\ &= 2 \times 3.25/1.183 \times 12 \text{ ft}^2, \\ A_s^v &= 65.9 \text{ ft}^2 (6.12 \text{ m}^2). \end{aligned}$$

Because $A_s^v < A_f^h$, a surface area of 65.9 ft² (6.12 m²) for the model was selected that is slightly conservative and provides the correct region volume.

As mentioned previously, during HFIR normal operation the flow rate through this region was found to be ~600 gal/min (0.038 m³/s). Following normalization with operation data, the flow becomes 613 gal/min (0.039 m³/s) or 84.4 lb_m/s (38.28 kg/s). The roughness of channel surfaces in this region is the same as that used in the hot removable reflector region, 2.1 × 10⁻⁴ ft (6.4 × 10⁻⁵ m). This value provides the desired region flow rate and pressure drop. The abrupt area change model is used at the entrance and exit to the region.

As indicated in Table 1, the power liberated in this region during HFIR normal operation at 85 MW is estimated to be 1.21 MW. The average of the region's BOC fission and EOC decay heat axial distributions was used in the model. The two distributions are similar.²⁷ The

region heat generation is assumed to be uniform in the radial direction. With reference to Fig. 7, the region is divided into five subregions with a discretization matching that of the control region and other reflector regions. RELAP5 internal source multipliers for this region were calculated based on relative heat structure surface areas, the axial power factors, and the total 1.21-MW heat load. The multipliers are referenced to the extra-fuel element power along with the axial power factors and are presented in Table 27.

Table 27. Removable/semipermanent beryllium reflector
axial power peaking factors and RELAP5
internal source multipliers

Axial location (top-to-bottom)	Axial power peaking factor	Internal source multiplier
1	0.715	4.22×10^{-2}
2	1.19	7.02×10^{-2}
3	1.34	6.32×10^{-2}
4	1.16	6.84×10^{-2}
5	0.675	3.98×10^{-2}

3.2.5.3 Permanent reflector

As indicated previously, this region is broken into two parts to more adequately represent their cooling characteristics, which are a little different. The total thickness of the permanent reflector cylinder is 8.375 in. (21.3 cm) with inner and outer radial boundaries r_i and r_o of 13.125 and 21.5 in. (33.3 and 54.6 cm), respectively. With reference to Fig. 18, the region is cooled by five concentric rings of 80 coolant holes [0.125-in.-diam (0.318-cm)] uniformly spaced within each ring except where altered by experimental facilities.²⁵ Additional cooling is provided in experimental facilities through narrow slots, beam tubes, and by portions of the coolant passages through the semipermanent/permanent reflector interface and control cylinder access plugs.⁸⁵ The inner permanent reflector region is bounded radially by the innermost and outermost [18.219-in. (46.276-cm)] rings of holes. It is assumed that the flow associated with these rings is split equally between the removable/semipermanent reflector and outer permanent reflector regions, respectively (i.e., the number of holes at each interface is split equally between adjacent regions). As mentioned previously, the outer permanent reflector region is also cooled by water outside of the reflector within the vessel.

As in the removable/semipermanent reflector region, it is assumed that all the flow through the permanent reflector is through 0.125-in.-diam (0.318-cm) holes. As before, the region hydraulic diameter is 0.0104 ft (3.17×10^{-3} m). The split of the total permanent reflector flow between the inner and outer regions was based simply on the ratio of the nominal number of cooling holes associated with each region (as per the above assumption regarding the "splitting" of holes between regions, there are 40 nominal holes associated with the outer region and 320 with the inner). The total "effective" number of holes in each subregion was "back-calculated" based on a reported flow velocity of ~15 ft/s (4.57 m/s) and

total flows of 423 gal/min (0.942 ft³/s, 59.1 lb_m/s, 0.027 m³/s) and 53 gal/min (0.12 ft³/s, 7.4 lb_m/s, 3.34 × 10⁻³ m³/s) for the inner and outer subregions, respectively.⁸⁵ The total effective number of 0.125-in.-diam (0.318-cm) holes, N_h^i and N_h^o , in the inner and outer subregions, respectively, are

$$N_h^i = 0.942 / (15 \times 8.52 \times 10^{-5}),$$

$$N_h^i = 737,$$

$$N_h^o = 0.12 / (15 \times 8.52 \times 10^{-5}),$$

$$N_h^o = 94.$$

The corresponding flow areas A_f^i and A_f^o are

$$A_f^i = 6.28 \times 10^{-2} \text{ ft}^2 (5.83 \times 10^{-3} \text{ m}^2),$$

$$A_f^o = 8.01 \times 10^{-3} \text{ ft}^2 (7.44 \times 10^{-4} \text{ m}^2).$$

The heat flow within the permanent reflector is 3-D in character. Simulating the heat flow with RELAP5's 1-D conduction model required simplifying assumptions. In the model, the total permanent reflector volume is divided into N_h^i and N_h^o subvolumes ("unit cells") in the inner and outer subregions, respectively. Each subvolume is assumed to be a beryllium cylinder with a 0.125-in.-diam (0.318-cm) [or 0.00521-ft-radius (0.159-cm)] coolant hole in the center. For the subvolumes in the inner reflector subregion, the outside surface is assumed to be adiabatic. In the outer subregion, the outside surface of the cylinder is cooled by water in the vessel. The total volumes of the inner V_i and outer V_o reflector subregions are

$$V_i = \pi[(18.219/12)^2 - (13.125/12)^2] \times 2 \text{ ft}^3,$$

$$V_i = 6.97 \text{ ft}^3 (0.197 \text{ m}^3),$$

$$V_o = \pi[(21.5/12)^2 - (18.219/12)^2] \times 2 \text{ ft}^3,$$

$$V_o = 5.69 \text{ ft}^3 (0.161 \text{ m}^3).$$

The corresponding horizontal cross-sectional areas A_c^i and A_c^o of the subvolumes in the inner and outer subregions, respectively, are

$$A_c^i = V_i / (2 N_h^i) \text{ ft}^2,$$

$$= 6.97 / (2 \times 737) \text{ ft}^2,$$

$$A_c^i = 4.73 \times 10^{-3} \text{ ft}^2 (4.39 \times 10^{-4} \text{ m}^2),$$

$$A_c^o = 5.69 / (2 \times 94) \text{ ft}^2,$$

$$A_c^o = 3.03 \times 10^{-2} \text{ ft}^2 (2.81 \times 10^{-3} \text{ m}^2).$$

After accounting for the area of the 0.125-in.-diam (0.318-cm) hole, the horizontal cross-sectional areas $A_{c,b}^i$ and $A_{c,b}^o$ of the beryllium in the subvolumes in the inner and outer subregions, respectively, are

$$\begin{aligned}
A_{c,b}^i &= A_c^i - A_f^h, \\
&= 4.73 \times 10^{-3} - 8.52 \times 10^{-5} \text{ ft}^2, \\
A_{c,b}^i &= 4.64 \times 10^{-3} \text{ ft}^2 (4.31 \times 10^{-4} \text{ m}^2), \\
A_{c,b}^o &= 3.03 \times 10^{-2} - 8.52 \times 10^{-5} \text{ ft}^2, \\
A_{c,b}^o &= 3.02 \times 10^{-2} \text{ ft}^2 (2.81 \times 10^{-3} \text{ m}^2).
\end{aligned}$$

The total volumes of beryllium V_b^i and V_b^o in the inner and outer reflector subregions, respectively, are

$$\begin{aligned}
V_b^i &= A_{c,b}^i N_h^i L, \\
&= 4.64 \times 10^{-3} \times 737 \times 2 \text{ ft}^3, \\
V_b^i &= 6.84 \text{ ft}^3 (0.194 \text{ m}^3), \\
V_b^o &= 3.02 \times 10^{-2} \times 94 \times 2 \text{ ft}^3, \\
V_b^o &= 5.68 \text{ ft}^3 (0.135 \text{ m}^3).
\end{aligned}$$

The sum lengths L_s^i and L_s^o of the cylinders in the inner and outer subregions, respectively, are

$$\begin{aligned}
L_s^i &= L N_h^i, \\
&= 2 \times 737 \text{ ft}, \\
L_s^i &= 1474 \text{ ft (449 m)}, \\
L_s^o &= 2 \times 94 \text{ ft}, \\
L_s^o &= 188 \text{ ft (57.3 m)}.
\end{aligned}$$

The outside radii r_c^i and r_c^o of the cylinders in the inner and outer subregions, respectively, are

$$\begin{aligned}
r_c^i &= (A_c^i/\pi)^{1/4}, \\
&= (4.73 \times 10^{-3}/\pi)^{1/4} \text{ ft}, \\
r_c^i &= 0.0388 \text{ ft (0.0118 m)}, \\
r_c^o &= (3.03 \times 10^{-2}/\pi)^{1/4} \text{ ft}, \\
r_c^o &= 0.0982 \text{ ft (0.0299 m)}.
\end{aligned}$$

As mentioned previously, heat transfer from the outside surfaces of the cylinders in the outer reflector subregion to the vessel water is modeled. The actual heat transfer surface area A_s^o is

$$\begin{aligned}
A_s^o &= 2\pi r_o L, \\
&= 2\pi \times 21.5/12 \times 2 \text{ ft}^2, \\
A_s^o &= 22.5 \text{ ft}^2 (2.09 \text{ m}^2).
\end{aligned}$$

However, the "implied" heat transfer surface area A_s^i in the model is

$$A_s^i = 2\pi r_c' L N_h.$$

Thus,

$$A_s^i = 2\pi \times (0.0982) \times 2 \times 94 \text{ ft}^2,$$

$$A_s^i = 116 \text{ ft}^2 (10.78 \text{ m}^2).$$

To properly calculate the heat transfer from the outside surfaces of the outer region reflector cylinder subvolumes, the heat transfer coefficient applied at the outside surfaces is reduced by the ratio of the actual to implied area,

$$A_s^a/A_s^i = 22.5/116,$$

$$A_s^a/A_s^i = 0.195.$$

The heat transfer coefficient applied to the outside surfaces was input directly to RELAP5. Since the cross-sectional flow area [$\sim 42 \text{ ft}^2$ (3.9 m^2)] of the upper bypass region is large relative to the total flow through the region [$\sim 82 \text{ gal/min}$ ($5.17 \times 10^{-3} \text{ m}^3/\text{s}$) during normal operation], the average velocity is very low [$\sim 0.004 \text{ ft/s}$ ($1.22 \times 10^{-3} \text{ m/s}$)] (see Figs. 3, 6, and 7). Thus natural convection will dictate flow and heat transfer in this region. Because the natural convective heat transfer coefficient is a nonlinear function of the temperature difference between the reflector surface and water, it could not be accommodated using a RELAP5 "general" table. Thus, the following approximate approach was taken.

The Rayleigh number Ra_{L_c} is given by⁸⁹

$$Ra_{L_c} = \frac{g L_c^3 \beta \Delta T}{\nu \alpha} = \frac{g \beta}{\nu^2} Pr L_c^3 \Delta T,$$

where

g = acceleration due to gravity,

L_c = characteristic dimension,

β = coefficient of thermal expansion,

ΔT = wall-to-fluid temperature difference,

ν = kinematic viscosity,

α = thermal diffusivity,

Pr = Prandtl number.

For the purposes of calculating water properties, a film temperature of 140°F (60°C) was selected. As will be shown in Sect. 5.1, this is lower than the value that exists during HFIR normal, steady-state operation at 85 MW. Because natural convection heat transfer increases due to property changes with increasing film temperature, the value chosen is conservative

in this case. During simulated accident sequences, the value will obviously change, and it may be necessary to revise property values (and heat transfer coefficients). Based on a film temperature of 140°F (60°C), the property values are^{74,90}

$$\nu = 5.14 \times 10^{-6} \text{ ft}^2/\text{s} \quad (4.78 \times 10^{-7} \text{ m}^2/\text{s}),$$

$$\alpha = 1.67 \times 10^{-6} \text{ ft}^2/\text{s} \quad (1.55 \times 10^{-7} \text{ m}^2/\text{s}),$$

$$\beta = 0.28 \times 10^{-3}/^\circ\text{F} \quad (5.04 \times 10^{-4}/^\circ\text{C}).$$

With $L_c = 2$ ft, the height of the reflector, the Rayleigh number is calculated to be

$$Ra_{L_c} = \frac{(32 \text{ ft/s}^2) (2 \text{ ft})^3 (0.28 \times 10^{-3}/^\circ\text{F})}{5.14 \times 10^{-6} \text{ ft}^2/\text{s} (1.67 \times 10^{-6} \text{ ft}^2/\text{s})} \Delta T,$$

$$Ra_{L_c} = 8.34 \times 10^9/^\circ\text{F} \Delta T.$$

A criterion for determining whether a vertical cylinder can be treated like a vertical flat plate is⁸⁹

$$D/L_c \geq 35/(Gr_{L_c})^{1/4},$$

where

D = diameter of the cylinder,

Gr = Grashof number ($= Ra_{L_c}/Pr$),

Pr = Prandtl number ($= 3.02$ at 140°F).⁷⁴

With $D = 3.58$ ft ($21.5 \times 2/12$ ft) and an assumed $\Delta T \approx 1^\circ\text{F}$ (or larger), the criterion is satisfied as shown below:

$$3.58/2 \geq 35/(8.34 \times 10^9/3.02)^{1/4},$$

$$1.79 \geq 0.15.$$

A turbulent natural convection flow will exist if $Ra_{L_c} > 10^9$, which implies for the case here that

$$\Delta T > 10^9/(8.34 \times 10^9) ^\circ\text{F},$$

$$\Delta T > 0.12^\circ\text{F} \quad (0.067^\circ\text{C}).$$

For turbulent flow, the vertical flat-plate average Nusselt number Nu_{av} is given by⁸⁹

$$Nu_{av} = 0.10 (Ra_{L_c})^{1/4},$$

where

$$Nu_{av} = \frac{hL_c}{k},$$

h = natural convection heat transfer coefficient,

k = thermal conductivity [= 0.376 Btu/h-ft-°F at 140°F (0.651 W/m-K at 60°C)].⁷⁴

The average heat transfer coefficient is therefore

$$h = 1.06 \times 10^{-2} \Delta T^{1/4} \text{ Btu/s-ft}^2\text{-°F},$$

with ΔT in °F. After accounting for the difference between the actual and modeled surface area, the "effective" heat transfer coefficient h_{eff} is

$$h_{eff} = 0.195 \times 1.06 \times 10^{-2} \Delta T^{1/4} \text{ Btu/s-ft}^2\text{-°F},$$

$$h_{eff} = 2.07 \times 10^{-3} \Delta T^{1/4} \text{ Btu/s-ft}^2\text{-°F}.$$

Because the volume of water in the upper bypass region is large relative to the amount of heat deposited in it, it is assumed that its temperature is constant at 120°F (48.9°C) for the purposes of evaluating h_{eff} . This simplification is necessary because the RELAP5 general table allows heat transfer coefficients to be input as a function of only one temperature. In the model, the heat transfer coefficient depends only on the temperature of the outer surface of the reflector. Table 28 presents effective coefficients calculated using Eq. (3). When ΔT is less than zero, indicating heat transfer from the vessel water to the reflector, the absolute value is used.

Table 28. Effective natural convection heat transfer coefficients at the beryllium reflector outside surface

Beryllium surface temperature (°F)	Heat transfer coefficient (Btu/s-ft ² -°F)
100	0.00562
115	0.00354
120	0.0
125	0.00354
140	0.00562
165	0.00736
200	0.00892
240	0.0102
280	0.0112
320	0.0121

The normal operation flows through the permanent reflector of 423 and 53 gal/min (2.67×10^{-2} and 3.34×10^{-3} m³/s) for the inner and outer subregions, respectively, were normalized with data. The flows were found to be 432 gal/min (0.027 m³/s) or 59 lb_m/s

(26.7 kg/s) and 54 gal/min (3.41×10^{-4} m³/s) or 7.4 lb_m/s (3.36 kg/s). The roughness of channel surfaces was selected to provide the desired flow and pressure drop. A value of 4.1×10^{-5} ft (1.25×10^{-5} m) was chosen. The abrupt area change model was used at the entrance and exit of both subregions.

The total power liberated in the permanent reflector during HFIR normal operation is estimated to be 1.08 MW, as indicated in Table 1. This includes heating in the permanent reflector and the experimental facilities and horizontal beam tube liners within it. The loads to the inner and outer subregions are 0.833 and 0.244 MW, respectively.²⁷ As was the case for the other reflector regions, the respective averages of the subregions' BOC fission and EOC decay heat axial distributions were used in the model. The BOC fission and EOC decay heat load axial distributions within each subregion are similar.²⁷ The radial load variation within each subregion was assumed to be uniform. With reference to Fig. 7, the subregions are each divided into five axial segments with discretizations matching that of the control region and other reflector regions. RELAP5 internal source multipliers for the heat structures within each subregion were calculated based on their heat load and their respective heat structure surface areas and axial power factors. The multipliers are referenced to the extra-fuel element power and are presented along with the axial power factors in Table 29.

Table 29. Permanent beryllium reflector axial power peaking factors and RELAP5 internal source multipliers

Axial location (top-to-bottom)	Axial power peaking factor		Internal source multipliers	
	Inner subregion	Outer subregion	Inner subregion	Outer subregion
1	0.765	0.807	3.11×10^{-2}	9.60×10^{-3}
2	1.15	1.12	4.67×10^{-2}	1.33×10^{-2}
3	1.27	1.22	4.13×10^{-2}	1.16×10^{-2}
4	1.13	1.11	4.59×10^{-2}	1.32×10^{-2}
5	0.743	0.791	3.02×10^{-2}	9.41×10^{-3}

3.2.6 Core Bypass

The water within the vessel surrounding the outer shroud above the core, the core, and the lower plenum beneath the core (see Fig. 3) is represented in the model in two regions, U-bypass and L-bypass (see Fig. 7). The U-bypass region includes the water within vertical boundaries corresponding to the bottom of the core and the top of the outer shroud. The L-bypass region includes the water surrounding the lower plenum. This subdivision permits the representation of thermal stratification within the water that occurs due to heating of the portion adjacent to the outer shroud and core, while the remainder remains relatively cool. As indicated previously for the permanent beryllium reflector, the current model assumes that for the purposes of calculating the natural convection heat transfer coefficients at the outside surfaces of the outer shroud and core, the temperature of the U-bypass water is constant at

120°F (48.9°C), the nominal reactor inlet temperature. Although the heat transfer is much less, the same assumption is used in heat transfer coefficient calculations for the outer surfaces of the lower plenum heat structures, which attach to the L-bypass region. Heat transfer from the U- and L-bypass regions through the vessel walls to the pool is conservatively neglected. Extension of the current model to better represent these aspects can be made when needed.

The height of the U-bypass region is 5.92 ft (1.8 m), of which 3.92 ft (1.19 m) is along the vertical extent of the outer shroud and 2 ft (0.610 m) is along the core.⁹¹ The inner radii of these subregions are 1.20 and 1.79 ft (0.366 and 0.546 m), respectively.⁹¹ The outer radius r_o of both subregions is 3.982 ft (1.19 m).⁹² With these dimensions, a region volume V and average flow area $\langle A_f \rangle$ was calculated as

$$\begin{aligned} V &= \pi(3.92^2 - 1.20^2) 3.92 + \pi(3.92^2 - 1.79^2) 2 \text{ ft}^3, \\ V &= 247.9 \text{ ft}^3 (7.02 \text{ m}^3), \\ \langle A_f \rangle &= V/\text{height}, \\ &= 247.9/5.92 \text{ ft}^2, \\ \langle A_f \rangle &= 41.88 \text{ ft}^2 (3.82 \text{ m}^2). \end{aligned}$$

The hydraulic diameter D_{hy} of the U-bypass region was calculated using an average value of the region inner radius (based on $\langle A_f \rangle$ and region outer radius, $\langle r_i \rangle = 1.43$ ft (0.436 m):

$$\begin{aligned} D_{hy} &= 4 \langle A_f \rangle / 2\pi(r_o + \langle r_i \rangle), \\ &= 4 \times 41.88 / 2\pi(3.92 + 1.43) \text{ ft}, \\ D_{hy} &= 4.98 \text{ ft (1.52 m)}. \end{aligned}$$

The height and inner radius r_i of the L-bypass region are 3.74 and 1.76 ft (1.14 and 0.536 m), respectively. Because the region outer radius varies continuously along its height, average flow areas were calculated at five elevations, which along with their respective heights, were used to estimate the total region volume. A value of 98 ft³ (2.77 m³) was determined.²⁷ As with the U-bypass region, the region average flow area $\langle A_f \rangle$ was calculated as

$$\begin{aligned} \langle A_f \rangle &= \text{volume/height}, \\ &= 98/3.74 \text{ ft}^2, \\ \langle A_f \rangle &= 26.2 \text{ ft}^2 (2.43 \text{ m}^2). \end{aligned}$$

The hydraulic diameter D_{hy} was calculated using an average value of the region outer radius $\langle r_o \rangle = 3.38$ ft (1.03 m):

$$\begin{aligned} D_{hy} &= 4 \langle A_f \rangle / 2\pi(\langle r_o \rangle + r_i), \\ &= 4 \times 26.2 / 2\pi(3.38 + 1.76) \text{ ft}, \\ D_{hy} &= 3.25 \text{ ft (0.988 m)}. \end{aligned}$$

As mentioned in Sect. 3.2.5, flow through the engineering facilities (denoted EF1-4 in Fig. 18) is assumed to occur through the bypass regions. In the model, flow passes through

junction 9-07 (see Fig. 7), a cross-flow junction, between the L-bypass and L-plenum-2 (outer lower plenum) regions. The junction area is taken to be the combined area of the four engineering facility cooling lines at their connection to the L-plenum-2 region. The inside diameter of each line at this location is 0.15 ft (Ref. 93), from which the combined area was determined to be 0.071 ft^2 ($6.6 \times 10^{-3} \text{ m}^2$). The roughness of the channel surfaces in the bypass region was taken to be $1.5 \times 10^{-4} \text{ ft}$ ($4.57 \times 10^{-5} \text{ m}$), which corresponds to commercial steel piping.⁹⁴

The total flow rate through the engineering facilities during normal reactor operation is estimated to be 80 gal/min ($5.05 \times 10^{-3} \text{ m}^3/\text{s}$).⁹⁵ After normalizing this value with operation data, the flow becomes 82 gal/min ($5.17 \times 10^{-3} \text{ m}^3/\text{s}$) or 11.2 lb/s (5.08 kg/s). To provide this flow rate through the bypass regions, a forward flow energy loss coefficient of 2700 was selected for junction 9-07 connecting the L-bypass and L-plenum-2 regions along with the junction smooth area change model. An equivalent reverse loss coefficient was also used.

The U-bypass region receives heat from the permanent reflector (O-P-Be in Fig. 7) and from the shroud region. Heat transfer modeling in the former case was described in Sect. 3.2.5.3; a similar discussion for the latter case will be presented in Sect. 3.2.8. Likewise, modeling of heat transfer from the L-plenum-2 region to the L-bypass region will be described in Sect. 3.2.11.

3.2.7 Vessel/Pool Check Valve

The vessel contains a check valve, which permits flow from the reactor pool into the vessel if the vessel pressure drops below the pool pressure head. The valve piping is connected at an elevation about 1.5 ft (0.457 m) below the bottom of the vessel inlet piping penetration⁹⁶ (see Fig. 3). The valve itself is located 10 in. (25.4 cm) above the top of the vessel lid and is a 2-in. (5.08-cm) swing check valve.⁹⁷ With the normal reactor pool depth of 36 ft (11 m), the pool pressure at the valve, which is 19 ft 10 in. (6.05 m) above the bottom, is 21.7 psia (0.150 MPa).

With reference to Fig. 7, the check valve is modeled using a time-dependent junction component. A time-dependent volume represents the reactor pool conditions [21.7 psia, 100°F (0.150 MPa, 37.78°C)]. Viscous losses in the 2-in. (5.08-cm) pipe joining the valve to the vessel are also included in the model. Flow through the valve is determined by a control system (see Sect. 3.7.14).

3.2.8 Core Shrouds

Two concentric shrouds are located above the core as shown in Fig. 19. They provide proper distribution of coolant flow and furnish support and alignment for various components above the core. The desired flow into the reflector and control regions is achieved with orifices in the shroud flange and between the shroud flange and inner shroud.²⁰

The region encompassed by the shrouds are modeled in two subregions as indicated in Fig. 7 (inner shroud and shroud). In addition to heat transport through the vertical flow path, heat transfer from the region between the shrouds (shroud in Fig. 7) to the U-bypass region is modeled. Hot water within the shroud is transferred through the 6061 aluminum outer shroud wall to the cooler water in the vessel bypass region. The roughness of surfaces in the inner shroud and shroud region was taken to be $1.5 \times 10^{-4} \text{ ft}$ ($4.57 \times 10^{-5} \text{ m}$).⁹⁴

The inner shroud region is an annular region formed by the target tower and inner shroud and extends 3.92 ft (1.19 m) above the core.⁹¹ The inner r_i and outer r_o radii of the annulus are⁹¹

$$r_i = 0.248 \text{ ft (0.076 m)},$$

$$r_o = 0.692 \text{ ft (0.211 m)}.$$

With these dimensions, the region flow area A_f , volume V , and hydraulic diameter D_{hy} were calculated to be

$$A_f = 1.31 \text{ ft}^2 (0.122 \text{ m}^2),$$

$$V = 5.1352 \text{ ft}^3 (0.145 \text{ m}^3),$$

$$D_{hy} = 0.89 \text{ ft (0.271 m)}.$$

The shroud region is an annular region formed by the inner and outer shrouds. The region also extends 3.92 ft (1.19 m), h , above the core.⁹¹ Neglecting the presence of the oxide on the aluminum outer shroud wall (the inner shroud is constructed of stainless steel), the inner and outer radii, r_i and r_o , respectively, of the annular flow passage are⁹¹

$$r_i = 0.715 \text{ ft (0.218 m)},$$

$$r_o = 1.14 \text{ ft (0.347 m)}.$$

With these dimensions, the regions flow area A_f , volume V , and hydraulic diameter D_{hy} were calculated to be

$$A_f = 2.48 \text{ ft}^2 (0.231 \text{ m}^2),$$

$$V = 9.7216 \text{ ft}^3 (0.275 \text{ m}^3),$$

$$D_{hy} = 0.85 \text{ ft (0.259 m)}.$$

The effect of the oxide on the outer shroud wall was included in the calculation of its inner and outer surface areas and thermal conduction resistance. As with other aluminum core components, the shroud oxide thickness was assumed to be 0.689 mil (0.0175 mm). The average thickness of the shroud wall was taken to be 0.7 in. (1.78 cm).⁹¹ Thus, the inner r_i^o and the outer r_o^o radii and of the outer shroud wall, accounting for oxide, are

$$r_i^o = 1.139988 \text{ ft (0.347468 m)},$$

$$r_o^o = 1.198345 \text{ ft (0.365260 m)}.$$

The thickness of the aluminum portion is then 0.69891 in. (1.7752 cm). The inner and outer surface areas A_s^i and A_s^o of the outer shroud wall are

$$A_s^i = 2\pi r_i^o h,$$

$$A_s^i = 2\pi \times 1.139988 \times 3.92 \text{ ft}^2,$$

$$A_s^i = 28.08 \text{ ft}^2 (2.51 \text{ m}^2),$$

$$A_s^o = 2\pi \times 1.198345 \times 3.92 \text{ ft}^2,$$

$$A_s^o = 29.52 \text{ ft}^2 (2.74 \text{ m}^2).$$

The thermophysical properties for shroud wall modeling have been presented in Tables 20 and 21 for 6061 aluminum and in Table 8 and Sect. 3.2.1 for oxide.

Following the approach taken for modeling beryllium reflector heat transfer to the U-bypass region, natural convection heat transfer was modeled at the interface between the outer shroud and U-bypass region. Heat transfer coefficients were input to RELAP5 as a function of the shroud surface temperature in a general table. Input values are presented in Table 30 and were obtained by dividing those in Table 27 [which are based on Eq. (3)] by

Table 30. Natural convection heat transfer coefficients at the outer shroud surface

Shroud surface temperature (°F)	Heat transfer coefficient (Btu/s-ft ² -°F)
100	0.0287
115	0.0181
120	0.0
125	0.0181
140	0.0287
165	0.0377
200	0.0457
240	0.0523
280	0.0575
320	0.0620

0.195. This adjustment removes the effective area scaling used in modeling heat transfer at the beryllium reflector outside surface, which is not appropriate for modeling heat transfer at the shroud surface. In this case the actual heat transfer area is used in the model. Note that because a turbulent natural convection flow exists, the heat transfer coefficient is not a function of the height of the heat transfer surface. Therefore, Eq. (3), which was derived for the beryllium reflector outside surface (height of 2 ft), is also valid for the outer shroud surface (height of 3.92 ft). Thus, the average heat transfer coefficient h is given by [see Eq. (3)]

$$h = 2.07 \times 10^{-3} \Delta T^{1/3} \text{ Btu/s-ft}^2\text{-°F}/0.195,$$

$$h = 1.06 \times 10^{-2} \Delta T^{1/3} \text{ Btu/s-ft}^2\text{-°F}.$$

Shroud orifices limit flow significantly to the control and reflector regions. The pressure drop through the orifices is on the order of 100 psi (0.689 MPa).^{24,98} This flow resistance is represented in RELAP5 using the abrupt area change model at junction 18-04 with an orifice possessing an area approximately 40 times smaller (0.064 ft² or 0.0059 m²) than the shroud flow area. A match to HFIR design flows was thereby achieved that, following normalization with normal operation data, provided a flow rate of 2238 gal/min (308 lb/s). The abrupt area change model was also used at the shroud outlet.

3.2.9 Target Tower

With reference to Figs. 3 and 7, the portion of the target tower contained within the inner core shroud is represented in the RELAP5 model by the "Target Tower" region (single-volume number 17). Only the flow within the tower is modeled. The height h and radius r of the cylindrical region are⁹¹

$$\begin{aligned} h &= 3.92 \text{ ft (1.19 m)}, \\ r &= 0.203 \text{ ft (0.062 m)}. \end{aligned}$$

The region flow area A_f , volume V , and hydraulic diameter D_{hy} are

$$\begin{aligned} A_f &= 0.129 \text{ ft}^2 (0.012 \text{ m}^2), \\ V &= 0.50568 \text{ ft}^3 (0.014 \text{ m}^3), \\ D_{hy} &= 0.405 \text{ ft (0.123 m)}. \end{aligned}$$

The roughness of the tower channel surface was taken to be 1.5×10^{-4} ft (4.57×10^{-5} m), corresponding to commercial steel piping.⁹⁴ The abrupt area change model was used at the entrance and exit of the channel.

3.2.10 Upper Plenum

The portion of the vessel and water that is above the top of the core shrouds is included in the "U-plenum" region in the model (see Figs. 3 and 7). The height h and radius r of the region is⁹²

$$\begin{aligned} h &= 4.37 \text{ ft (1.33 m)}, \\ r &= 3.92 \text{ ft (1.19 m)}. \end{aligned}$$

The region flow area A_f , volume V , and hydraulic diameter D_{hy} are

$$\begin{aligned} A_f &= 48.3 \text{ ft}^2 (4.49 \text{ m}^2), \\ V &= 211 \text{ ft}^3 (5.98 \text{ m}^3), \\ D_{hy} &= 7.83 \text{ ft (2.39 m)}. \end{aligned}$$

In the model the height of the region was changed so that the elevation change between the inlet and outlet piping could be accurately represented. Inlet and outlet piping connect to

the vessel with cross-flow junctions that are required to be attached at the vertical center of the connecting volume (i.e., U-plenum and outlet volumes in Fig. 7). To conserve region volume, the flow area was increased proportionally by the decrease in region height. The model height h^m and flow area A_f^m are

$$h^m = 1.99 \text{ ft (0.606 m)},$$

$$A_f^m = 106 \text{ ft}^2 (9.85 \text{ m}^2).$$

The vessel sidewall is nominally 3.123 in. (7.94 cm) thick and composed of ASTM A212 grade B plate [2 7/8 in. (7.30 cm) thick] clad on the inside with 304L stainless steel plate [0.125 in. (0.318 cm) thick] and on the outside with 347 stainless steel weld overlay [0.125 in. (0.318 cm) thick].^{99,100} The thickness of the 347 stainless steel weld overlay is not consistently given in Refs. 98 and 100 [0.125 in. (0.318 cm) and 0.10 in. (0.254 cm)]; conservatively (i.e., to provide the maximum heat conduction resistance), the larger value was selected for use in the model. The vessel top head is nominally 14.25 in. (36.2 cm) thick and composed of ASTM A105 grade II forgings [14 in. (35.6 cm) thick] clad overall with 347 stainless steel weld overlay [0.125 in. (0.318 cm) thick].^{100,101} Thermophysical property values of ASTM A212 grade B and A105 grade II carbon steel could not be found, so those of a similar alloy were used.¹⁰² The density of carbon steel with $\approx 0.5\%$ carbon was selected whose value at RT is 487 lb_m/ft³ (7801 kg/m³) (Ref. 74). The specific heat of a carbon steel with 0.77% carbon¹⁰³ [except for the value at 68°F (20°C), which is of $\approx 0.5\%$ carbon steel]⁷⁴ was used with the density value above to calculate the volumetric heat capacity of the vessel carbon steel. These values are presented in Table 31 for a range of temperatures. The vessel carbon steel thermal conductivity is taken to be that of carbon steel with 0.31% carbon,¹⁰⁴ values are listed in Table 32. The density of the 304L stainless steel vessel sidewall clad at RT is 501.3 lb_m/ft³ (8025 kg/m³).¹⁰⁵ The specific heat and volumetric heat capacity of 304L stainless steel are presented in Table 33,¹⁰⁶ while its thermal conductivity is provided in Table 34 (based on that of 304 stainless steel).¹⁰⁷ The density of the 347 stainless steel vessel clad at RT is 493.8 lb_m/ft³ (7910 kg/m³),¹⁰⁵ and its other relevant thermophysical property data are presented in Tables 35 and 36.

Table 31. Carbon steel specific heat and volumetric heat capacity

Temperature (°F)	Specific heat (Btu/lb _m ·°F)	Volumetric heat capacity (Btu/ft ³ ·°F)
68	0.111	54.3
176	0.120	58.7
428	0.132	64.5
986	0.163	79.7

Table 32. Carbon steel thermal conductivity

Temperature (°F)	Thermal conductivity (Btu/s-ft-°F)
86	0.0112
212	0.00919
439	0.00658
932	0.00339

Table 33. 304L stainless steel specific heat and volumetric heat capacity

Temperature (°F)	Specific heat (Btu/lb _m -°F)	Volumetric heat capacity (Btu/ft ³ -°F)
50	0.089 ^a	44.6 ^a
80	0.089 ^a	44.6 ^a
440	0.091	45.6
620	0.092	46.1
980	0.098	49.1

^aValues extrapolated.

Table 34. 304L stainless steel thermal conductivity

Temperature (°F)	Thermal conductivity (Btu/s-ft-°F)
50	0.00239
80	0.00244
440	0.00294
520	0.00317
980	0.00361

Table 35. 347 stainless steel specific heat and volumetric heat capacity (Ref. 106)

Temperature (°F)	Specific heat (Btu/lb _m -°F)	Volumetric heat capacity (Btu/ft ³ -°F)
80	0.109	53.8
440	0.120	59.3
620	0.125	61.7
980	0.135	66.7

Table 36. 347 stainless steel thermal conductivity (Ref. 108)

Temperature (°F)	Thermal conductivity (Btu/s-ft-°F)
80	0.00238
440	0.00286
620	0.00308
980	0.00353

For the calculation of heat transfer from upper plenum water to the reactor pool, conduction heat transfer through the vessel sidewall is modeled in cylindrical geometry. Conduction through the vessel top head is modeled in "slab" geometry. The inside and outside surface areas of the sidewall, A_s^i and A_s^o , respectively, and that of the top head A_h , are⁹²

$$A_s^i = 108 \text{ ft}^2 (10.03 \text{ m}^2),$$

$$A_s^o = 115 \text{ ft}^2 (10.68 \text{ m}^2),$$

$$A_h = 48.3 \text{ ft}^2 (4.49 \text{ m}^2).$$

The top head surface area only includes the portion bounded by the inside diameter of the vessel.

During normal HFIR operation, heat transfer from the upper plenum to the pool is small relative to the core power. However, after reactor shutdown or when operating at low power and the forced flow rate is low (i.e., pony motor driven) or there is no forced flow, heat transfer is more significant. In this case, even with pony motor forced flow, natural convection will dictate heat transfer along vessel walls [average forced flow velocity is only ≈ 0.06 ft/s (0.018 m/s) in upper plenum]. Depending upon the simulation, the upper plenum water temperature may increase significantly above normal [$\approx 120^\circ\text{F}$ (48.9°C)]. Because the heat transfer coefficient cannot be input in RELAP5 as a function of the water and vessel

wall temperatures, both of which may vary with time, a representative coefficient is used. For the sidewall a value of 0.028 Btu/s-ft²-°F (568 W/m²-K) was selected that corresponds to roughly a 20°F (11°C) water-to-wall temperature difference (see Sect. 3.2.5.3 and Table 30). The same approach is used to calculate natural convection heat transfer to the vessel top head. However, natural convection heat transfer is more effective to a cold horizontal surface facing downward than to a vertical surface. In the former case the average turbulent Nusselt number is given by⁸⁹

$$Nu_{av} = 0.15 Ra_{L_c}^{1/4}.$$

The leading coefficient (0.15) is 1.5 times that for vertical surfaces (see Sect. 3.2.5.3). Thus, the representative heat transfer coefficient selected for the inside surface of the vessel top head is 0.042 Btu/s-ft²-°F (150 Btu/h-ft²-°F, 852 W/m²-K). Obviously, depending upon the accident simulated, these values may require revision.

Modeling of natural convection heat transfer from the outer surface of the U-plenum region vessel walls to the reactor pool can be accomplished accurately when the pool temperature remains nearly constant through the duration of an accident simulation. Aside from long-duration simulations (or simulations of certain "catastrophic" events), the pool temperature should not vary significantly due to its large thermal capacity. In this case, the natural convection heat transfer coefficient can be input to RELAP5 in a general table as a function of the outer vessel wall temperature. Following the procedure used in Sect. 3.2.5.3 for reflector-to-bypass natural convection heat transfer, and accounting for the difference between horizontal and vertical surface heat transfer, vessel sidewall and top head convection coefficients were calculated. As before, a conservative film temperature was selected, 104°F (40°C) in this case. Corresponding property values are^{74,90}

$$\nu = 7.08 \times 10^{-6} \text{ ft}^2/\text{s} \text{ (} 6.58 \times 10^{-7} \text{ m}^2/\text{s)},$$

$$\alpha = 1.63 \times 10^{-6} \text{ ft}^2/\text{s} \text{ (} 1.51 \times 10^{-7} \text{ m}^2/\text{s)},$$

$$\beta = 0.19 \times 10^{-3}/^\circ\text{F} \text{ (} 3.4 \times 10^{-4}/^\circ\text{C)}.$$

With $L_c = 4.39$ ft, the vessel sidewall height over which heat transfer to the pool is modeled, Ra_{L_c} is calculated to be

$$Ra_{L_c} = 4.46 \times 10^{10} \Delta T^\circ\text{F}.$$

Using this and the following Nu_{av} for turbulent flow as before, that is,⁸⁹

$$Nu_{av} = 0.10 (Ra_{L_c})^{1/3},$$

where

$$Nu_{av} = \frac{hL_c}{K},$$

h = natural convection heat transfer coefficient,

k = thermal conductivity [=0.363 Btu/h-ft-°F at 140°F (0.628 W/m-k at 40°C)],⁷⁴

the average heat transfer coefficient for the vessel sidewall (outside surface) is

$$h = 8.15 \times 10^{-3} \Delta T^{0.4} \text{ Btu/s-ft}^2\text{-}^\circ\text{F}.$$

Note that ΔT is the difference between the sidewall outside surface temperature and the reactor pool temperature. For the vessel lid outside surface the heat transfer coefficient is simply 1.5 times that for the sidewall (for the same temperature difference) as indicated previously. Vessel sidewall and lid (outside surfaces) heat transfer coefficients are presented in Table 37 and are based upon a constant pool temperature of 100°F (37.8°C).

The inside surfaces of the U-plenum region are assumed to have a roughness of 1.5×10^{-4} (Ref. 94). The inlet piping connects to the U-plenum region with a cross-flow junction. The abrupt area change model is used at all connections to the U-plenum.

3.2.11 Lower Plenum

The region beneath the core that extends to the base of the fuel and reflector support is represented in the model in two regions, L-plenum-1 and L-plenum-2 (see Figs. 3, 7, and 20). The L-plenum-1 region is the cylindrical region bounded radially by the outer wall of the fuel grid support pedestal. L-plenum-2 is an annular region bounded at its inner radius by the fuel grid support pedestal and at its outer radius by the reflector container and pedestal assembly and the fuel and reflector support. L-plenum-1 connects to the fuel and target regions, while L-plenum-2 connects to the control and reflector regions. Two vertical slots in the fuel grid support pedestal permit flow between L-plenum-1 and L-plenum-2.

The height and diameter of the L-plenum-1 region are 3.74 and 1.26 ft (1.14 and 0.384 m), respectively.⁹¹ The region flow area A_f^l and hydraulic diameter D_{hy}^l are

$$A_f^l = 1.25 \text{ ft}^2 (0.116 \text{ m}^2),$$

$$D_{hy}^l = 1.26 \text{ ft (0.384 m)}.$$

Table 37. Natural convection heat transfer coefficients at the upper vessel sidewall and top head outside surfaces

Outside vessel surface temperature (°F)	Heat transfer coefficient (Btu/s-ft ² -°F)	
	Sidewall	Top head
100	0	0
105	0.0139	0.0209
120	0.0221	0.0332
140	0.0278	0.0418
160	0.0319	0.0479
180	0.0351	0.0527
200	0.0378	0.0567
212	0.0392	0.0588

ORNL-DWG 82-3203 ETD

Fig. 20. Vertical section of HFIR lower plenum.

The two fuel grid support pedestal slots are 180° apart and 0.5 in. (1.27 cm) wide and 34.4 in. (87.4 cm) long.¹⁰⁹ The total slot flow area is then 0.239 ft² (0.0222 m²). This flow path is represented in the model using a cross-flow junction (9-09 in Fig. 7). The flow resistance through the slot is modeled using a smooth area change at the junction along with a form loss coefficient. Conservatively (more loss), the form loss is assumed to consist of a "sudden contraction" (L-Plenum-1 or -2 into the slots) and a "sudden expansion" (slots into L-Plenum-1 or -2) with area ratios providing the maximum possible loss. That is, for the sudden contraction form loss K_c , the ratio of the "exit" (slots) to "entrance" (L-Plenum-1 or -2) areas A_s/A_L is taken to be 0, which gives for K_c (Ref. 110)

$$K_c = a \left[1 - (A_s/A_L)^2 \right],$$

where

$$a = 0.4 \text{ to } 0.5 \text{ (conservatively use 0.5),}$$

$$K_c = 0.5.$$

For the sudden expansion form loss K_e , the ratio of the entrance (slots) to exit (L-Plenum-1 or -2) areas A_s/A_L is taken to be 0, which gives for K_e (Ref. 110)

$$K_e = (1 - A_s/A_L)^2,$$

$$K_e = 1.0.$$

Thus, the total form loss is 1.5, which is used as the forward and reverse value in the RELAP5 input model.

The area A_{fj}^1 of the junction connecting the L-plenum-1 and outlet regions (see Figs. 7 and 21) was estimated by summing the available flow area indicated in the plan section of the core support upper flange. A_{fj}^1 was determined to be 0.77 ft² (0.072 m²).²⁷

The height and inner and outer radii of the L-plenum-2 region are 3.74, 0.671, and 1.70 ft (1.14, 0.205, and 0.518 m), respectively.⁹¹ The region flow area A_f^2 and hydraulic diameter D_{hy}^2 are

$$A_f^2 = 7.66 \text{ ft}^2 \text{ (0.712 m}^2\text{),}$$

$$D_{hy}^2 = 2.06 \text{ ft (0.628 m).}$$

The area A_{fj}^2 of the junction connecting the L-plenum-2 and outlet regions (see Figs. 7 and 21) was found by summing the flow areas of the eight large holes shown in the plan section of the core support flange. A_{fj}^2 was determined to be 0.543 ft² (0.050 m²).²⁷

The roughness of the channel surfaces in L-plenum-1 and L-plenum-2 regions was taken to be 1.5×10^{-4} ft (4.57×10^{-5} m), which corresponds to commercial steel piping.⁹⁴ The abrupt area change model is used at junctions connecting the L-plenum-1 and L-plenum-2 regions to regions above and below them.

As mentioned previously, heat transfer from the L-plenum-2 region to the L-bypass region is modeled. Heat flows through the reflector container and pedestal assembly and through the fuel and reflector support. The former is constructed of 6061 aluminum.¹¹¹ The cylindrical structure is 2.6 ft (0.792 m) high with an inside diameter of 3.37 ft (1.03 m) and a wall thickness of 1 in. (2.54 cm) over most of its height [2.2 ft (6.71 m)].⁹¹ Elsewhere,

the wall thickness is significantly greater. Conservatively, heat transfer is assumed to occur only over the thinner portion. The thickness of the oxide on the inner and outer surfaces of the structure is assumed to be 0.689 mil (0.018 mm), as was assumed for the target, control, and reflector regions. Accounting for the presence of the oxide, the radial boundaries of the oxide regions and aluminum are presented in Table 38. The fuel and reflector support is constructed of 304L stainless steel.^{93,112} As above, heat transfer through the cylindrical structure was assumed to occur only over the height where the wall thickness was at its minimum nominal value, 0.65 in. (1.65 cm). Thus, the height and inside diameter of the structure are taken to be 0.92 and 3.43 ft (0.280 and 1.05 m), respectively.⁹¹

The thermophysical properties used for reflector container and pedestal assembly modeling have been presented in Tables 20 and 21 for 6061 aluminum and in Table 8 and Sect. 3.2.1 for oxide. Properties of 304L stainless steel for fuel and reflector support modeling have been presented in Tables 32 and 33 and in Sect. 3.2.10.

Natural convection heat transfer was assumed to occur along the outer surfaces of the L-plenum-2 heat structures, as was assumed in modeling the outer core shroud wall transfer to the U-bypass region. The heat transfer coefficients input to RELAP5 as a function of the heat structure outer surface temperature are the same as those used for the core shroud presented previously in Table 30. (Note again that a turbulent natural convection flow exists, making differences in heat transfer surface heights irrelevant.)

Table 38. Radial boundaries of the oxide regions and aluminum comprising the reflector container and pedestal assembly

Region	Radii (ft)	
	Inside	Outside
Inside-surface oxide	1.684988	1.685045
Aluminum	1.685045	1.768288
Outside-surface oxide	1.768288	1.768345

3.2.12 Outlet

With reference to Figs. 3 and 7, the region beneath the lower plenum and connecting to the outlet pipe is represented in the RELAP5 model by the "outlet" region (branch volume No. 34). Only the flow within the region is modeled. The height and diameter are 3.69 and 2.74 ft (1.12 and 0.835 m),⁹¹ respectively. The region flow area A_f and hydraulic diameter D_{hy} are

$$A_f = 5.90 \text{ ft}^2 (0.548 \text{ m}^2),$$

$$D_{hy} = 2.74 \text{ ft} (0.835 \text{ m}).$$

The roughness of the outlet channel surfaces was taken to be 1.5×10^{-4} ft (4.57×10^{-5} m), corresponding to commercial steel piping.⁹⁴ The abrupt area change model was used at the entrance and exit to the region. The exit of the outlet region was connected to the outlet pipe with a cross-flow junction.

3.3 EXTRA-VESSEL COMPONENT DESCRIPTIONS

The assumptions and calculations,¹¹³ which were used to represent each component in the RELAP5 model for the primary coolant system outside of the vessel, are described in this section.

3.3.1 Piping

Lengths and elevations of the piping throughout the high pressure side of the primary coolant system were obtained from available drawings.¹¹⁴⁻¹¹⁸ Pipe diameters and thicknesses¹¹⁹ used in the model are given in Table 39.

Table 39. Dimensions of steel pipe

Schedule	Nominal diameter (in.)	Inside diameter (in.)	Thickness (in.)
40	2	2.067	0.154
40	3	3.068	0.216
40	4	4.026	0.237
40	10	10.020	0.365
40	14	13.126	0.437
40	16	15.000	0.500
40	18	16.876	0.562
40	20	18.814	0.593
80	10	9.564	0.593

The hot leg stretching from the vessel outlet down the pipe tunnel (Figs. 5 and 6) consists of 18-in. (45.7-cm) schedule 40 pipe. The cold leg stretching down the pipe tunnel to the strainer housing (Figs. 5 and 6) is 20-in. (50.8-cm) schedule 40 pipe. Pipes in the pipe tunnel are gently sloped (less than 1°) so that the ends nearer the vessel are lowest. The two inlet pipes that join the strainer to the vessel (Figs. 5 and 6) are 16-in. (40.6-cm) schedule 40 pipe.

The four heat exchanger cells (Fig. 22) are at the same elevation, and from inlet block valve to outlet block valve (Figs. 5 and 22), the cells are identical. Because only three of the four heat exchanger cells are valved into the system at a time, only three cells were modeled (cells 110, 111, and 113, or D, C, and A, respectively). The lines leading up to the block valves for cell 112 were also included in the model (pipes 375 and 352 in Fig. 6).

ORNL-LR-DWG 65339AR4

Fig. 22. Heat exchanger cells and pool structures.

A short segment of 10-in. (25.4-cm) schedule 80 pipe is used for the branch side of the wyes in the pipe tunnel to and from each heat exchanger cell (Fig. 22 and volumes 52-01, 75-04, 152-01, 175-04, 352-01, and 375-03 in Fig. 6). From the schedule 80 section to the inlet block valve in each heat exchanger cell, the pipe is 10-in. (25.4-cm) schedule 40. This same size pipe stretches from the inlet block valve to an expansion fitting just upstream of the heat exchanger inlet (Fig. 22). The piping gently slopes downward in both directions from the isolation block valves: to the heat exchangers in one direction and to the pipe tunnel in the other. Fourteen-inch (35.6-cm) schedule 40 pipe is used in the heat exchanger (Fig. 22 and volumes 57, 157, and 257 in Fig. 6) and between the heat exchanger and the main circulating pump (Fig. 22 and pipes 60, 160, and 260 in Fig. 6). The remainder of the piping in the cell, from the pump discharge to the schedule 80 section near the wye fitting, is 10-in. (25.4-cm) schedule 40 (Fig. 22).

The line extending from the pressurizer pumps to the pipe tunnel (Fig. 23 and volume 67 in Fig. 6) is 3-in. (7.62-cm) schedule 40 and 148 ft (45.1 m) long.^{114,120-122} The line from the primary coolant head tank to the pressurizer pumps (Fig. 23 and volume 72 in Fig. 6) is 4-in. (10.2-cm) schedule 40 and is 66.5 ft (20.3 m) long. The letdown lines extending from the heat exchangers to the letdown valves (Fig. 23) are 2-in. (5.08-cm) schedule 40 and are about 30 ft (9.14 m) long.

Heat structures were included in the model to represent the pipe walls. The material used for the piping heat structures was 304L stainless steel, the properties of which were given in Tables 33 and 34.

Convective heat transfer to air from pipes in the pipe tunnel, heat exchanger cells, and the pressurizer line was neglected (conservative for most transients). Although heat structure models are provided, an insulated boundary condition was chosen. Convective heat transfer from the primary coolant piping to the pool surrounding the reactor vessel was included. A correlation developed by Churchill and Chu¹⁵ was used to generate tables for the heat transfer coefficient as a function of temperature for the horizontal 16-in. (40.6-cm) inlet pipes, the portion of the horizontal 20-in. (50.8-cm) cold leg pipe that is submerged in the pool, and the portion of the 18-in. (45.7-cm) hot leg pipe that is submerged in the pool. A correlation from Kreith¹⁶ was used to generate tables for the natural convective heat transfer coefficient from the vertical strainer housing and the vertical portion of the 18-in. (45.7-cm) hot leg.

Some of the key elevations are listed in Table 40. The highest elevations in the lines leading toward and away from the heat exchangers are located at the isolation block valves. The highest elevation in the system is at the top of the strainer housing.

Because RELAP5 checks that the net elevation change around a closed loop is exactly zero, very small adjustments [no larger than 10^{-3} ft (3.05×10^{-3} m)] had to be made to the net elevation change of a few volumes in the system. The surface roughness⁹⁴ was assumed to be 1.5×10^{-4} ft (4.57×10^{-5} m) for each pipe volume in the system except for the heat exchanger tubing where a smoother surface [10^{-6} ft (3.05×10^{-7} m)] was assumed. The sensitivity of the flow rate to surface roughness was determined by assuming a surface roughness of 10^{-6} ft (3.05×10^{-7} m) everywhere. This resulted in increasing the primary coolant flow by only 75 gal/min (4.73×10^{-3} m³/s) (<0.5%). Loss coefficients for the piping that are used to calculate the pressure drop due to friction brought on by changing the flow cross section or direction (e.g., bends, wyes, expansions, and contractions) are discussed in Sect. 3.5.

ORNL-LR-DWG 77796R

Fig. 23. Primary coolant clean-up system.

Table 40. Selected elevations in the primary coolant system^{115,125}

Location	Elevation
Top of strainer housing ¹¹⁸	832 ft 7 7/16 in.
16-in. inlet pipes	826 ft
18-in. outlet from vessel	813 ft 6 in.
20-in. line into strainer	830 ft 2 in.
Heat exchanger inlet and outlet	827 ft 8 in.
Inlet isolation block valves	827 ft 8 1/8 in.
Outlet isolation block valves	830 ft 7 1/2 in.
Bottom of PC head tank ¹²⁶	835 ft
Suction and discharge of main and standby pressurizer pumps ¹¹⁶	819 ft 5 3/4 in.

3.3.2 Heat Exchangers

The original HFIR heat exchangers were replaced in 1985 by new, more efficient heat exchangers manufactured by Joseph Oat Corporation. This was done because of concern that the old exchangers might experience a multiple tube rupture. The new heat exchangers (Figs. 5 and 22) are ~30 ft (9.14 m) high and 4 ft (1.22 m) in diameter. The flow paths taken by the secondary and primary water are indicated in Fig. 24. In Fig. 25, the RELAP5 nodal diagram for the three active heat exchangers and the secondary flow system is shown. Each heat exchanger was modeled by combining pipe, single volume, single junction, and heat structure RELAP5 components in such a way that the resulting heat exchanger performance was consistent with the observed performance of the new heat exchangers. Although the original exchangers were designed for inlet conditions of 5000 gal/min (0.315 m³/s), 167°F (75°C) primary flow, and 6667 gal/min (0.421 m³/s), 85°F (29.4°C) secondary flow each, the new exchangers require only about 4000 gal/min (0.252 m³/s) of secondary flow each to remove the 85 MW generated at normal operation. See the discussion of the model of the secondary coolant system (Sect. 3.3.8) for the exact value of secondary coolant flow used in the model and an explanation of how it was calculated.

The RELAP5 1-D model is sufficient to accurately model the primary side flow because of the simple U-tube geometry. As shown in Fig. 25, the primary fluid in the tube bundle is represented with 20 volumes linked in series (e.g., pipes 100, 101, 104, and 105, each of which contains five volumes). This level of refinement was selected after determining the sensitivity of the exchangers to discretization by making some preliminary RELAP5 runs. Pressure

Fig. 24. Heat exchanger flow path.

losses due to the U-tube curvature have been neglected because of the large radius-of-curvature-to-diameter ratio. According to manufacturer's data,¹²⁷ the tube bundle consists of 1200 stainless steel tubes with an average tube length of 710.52 in. (18.05 m). Each tube has inner and outer diameters of 0.555 and 0.625 in. (1.41 and 1.59 cm), respectively. The heat exchanger is capped with a hemispherical shell. Half of the volume inside this shell lies on either side of the heat exchanger: one-quarter-sphere volume upstream (hot side) and one-quarter-sphere volume downstream (cold side). Each of these volumes is characterized in the

Fig. 25. Schematic of HFIR RELAP5 secondary system model.

RELAP5 model by a control volume (node) having the actual quarter-sphere volume of 7.8644 ft^3 (0.223 m^3) and a length equal to the spherical radius of 1.9583 ft (0.597 m). Letdown flow is extracted off of the cold quarter-sphere plenum at the outlet of each heat exchanger.

The secondary side flow pattern is much more complicated. As seen in Fig. 24, the flow enters the heat exchanger about halfway up the primary outlet side. It then splits; some of the flow goes up, and some down. Both streams weave through the baffle configuration and then recombine at the secondary outlet, which is located about halfway up the primary inlet side. Details of the complex flow pattern on the secondary side of the heat exchanger cannot be resolved using the 1-D RELAP5 program. To calculate the heat transfer through the heat exchanger, RELAP5 uses the Dittus-Boelter correlation^{1,20}

$$Nu_D = 0.023 Re_D^{0.8} Pr^{0.4},$$

where

$$Nu_D = \frac{hD_{hy}}{k},$$

$$Re_D = \frac{QD_{hy}}{\nu A}.$$

Here h is the local heat transfer coefficient, D_{hy} is the hydraulic diameter, A is the cross-sectional flow area, ν is the kinematic viscosity, k is the water thermal conductivity, and Q is the volumetric flow rate.

Two problems exist with using this correlation on the secondary side. First, it is based on experiments for fully developed turbulent flow in pipes. However, the actual secondary flow is an extremely complicated 3-D flow with many areas of recirculation. Second, much of the secondary flow is orientated across the U-tubes rather than parallel with them. A correlation for tube bundles in cross-flow given by Kreith²¹ indicates that Nu_D is proportional to $Re_D^{0.6}$ and $Pr^{0.3}$. Despite these two problems, Dittus-Boelter is used to predict the heat transfer to the secondary side. By calibrating the model so that the heat exchanger performs properly at the design conditions, it is assumed that the Dittus-Boelter correlation is adequate for all cases.

The secondary-side Reynolds number depends upon the flow rate, the hydraulic diameter, and the cross-sectional flow area. Although the flow rate for the secondary side is known, the appropriate cross-sectional area and hydraulic diameter are not clear. Once a cross-sectional area is selected, the hydraulic diameter can be chosen so that the appropriate amount of heat is transferred from the primary fluid to the secondary fluid. The secondary side cross-sectional flow area was selected to be the average of that within the tube bundle region and that between the bundle and the shell outside wall, or 1.373 ft^2 (0.1276 m^2).

An appropriate hydraulic diameter, which results in matching the current heat exchanger performance, can be determined for any nodalization. Ideally, the discretization should be made fine enough that the calibrated secondary-side hydraulic diameter is unaffected by further refinement in the streamwise direction. If the steady-state results are dependent upon the nodalization, subsequent transient results will be less dependable. The results from the calibration runs for the heat exchanger are shown in Fig. 26. At least 80 volumes per heat

Fig. 26. Heat exchanger discretization sensitivity.

exchanger are required for the results to be essentially independent of the node distribution. In the heat exchanger model there is a one-to-one correspondence between the primary side volumes, the heat structures representing the tubing, and the secondary side volumes. Therefore, for a model including 20 primary flow volumes (and heat structures), 10 secondary side volumes are used for both the upper and lower flow paths. For each additional node (volume) used in discretization of the primary side, six additional hydrodynamic volumes and three additional heat structures are required. Also, to keep the discretization symmetric within a heat exchanger, the discretization can only be increased in increments of four primary side volumes.

To maintain higher computational speed, only 20 volumes were used. For 20 volumes, the hydraulic diameter that yielded the measured heat transfer rate (see Ref. 113) was 0.1960 ft.

Measurements for the secondary side pressure drop through the heat exchangers were recorded by D. M. McGinty¹³⁰ and are shown in Table 41. Only one new heat exchanger was installed when these measurements were taken in 1985. For the three lower flow rates only two cells were active (two pumps running). Three cells were active for the three higher flows.

These data are not consistent with current plant data¹³¹ that indicate a 12-psi (0.0827-MPa) pressure drop at a flow rate of 14,500 gal/min (0.915 m³/s). The reason for the inconsistency is unknown; however, the more recent plant data were used to determine an appropriate loss coefficient for the shell side of the heat exchanger. A total loss coefficient of 107.1 was calculated and distributed equally among the nine junctions on the secondary (shell) side flow path.

Table 41. Measurements of secondary side pressure drop

Total flow (gal/min)	Cell 110 (old) ΔP (psi)	Cell 111 (new) ΔP (psi)	Cell 113 (old) ΔP (psi)
10,000	7.62	<i>a</i>	8.12
11,000	9.12	<i>a</i>	9.62
12,000	10.88	<i>a</i>	11.38
15,000	7.62	8.12	8.25
16,500	9.00	9.50	9.62
18,000	10.75	11.25	11.38

^aHeat exchanger isolated when this measurement was taken.

3.3.3 Primary Coolant Pumps

The main circulation (or primary coolant) pumps PU-1A, PU-1B, PU-1C, and PU-1D (Fig. 5) were manufactured by the Byron Jackson Division of Borg Warner Corporation. They are constant speed, centrifugal, axial flow pumps. Piping connections to the pump are 14 in. (35.6 cm) in diameter on the suction side and 10 in. (25.4 cm) in diameter on the discharge side (Fig. 5). The moments of inertia¹³² for the pump, main motor, and pony motor are listed in Table 42.

Table 42. Moments of inertia for the primary coolant pump and pump motors

Component	Moment of inertia (lb _m -ft ²)
Main ac motor	421.0
Pony motor	9.5
Pump impeller	<u>37.5</u>
Total	468.0

The performance of the main circulation pumps is described in a Byron Jackson manufacturer's report.¹³³ Some of these data (for operation with the main ac motor) are given in Table 43.

Normally the main circulation pumps are driven by an 1800-rpm ac motor. If the ac motor fails or is tripped, back-up dc 270-rpm pony motors (see Sect. 2) should continue to drive the pumps. The main ac motors will be tripped if low system pressure (<264.7 psia) is detected or if a loss-of-offsite-power (LOOP) occurs. They may also be shut down because

Table 43. Primary coolant pump performance data
at 77°F taken from Byron Jackson report

Speed (rpm)	Flow (gal/min)	Head (ft)	Power (bhp)	Efficiency (%)
1780	9750	206.7	675	75.4
1780	9200	239.1	664	83.2
1780	8600	263.6	658	86.8
1780	8000	281.0	646	87.8
1782	7050	312.1	623	89.1
1784	6050	340.5	579	89.8
1786	5000	366.3	529	87.5
1786	3970	379.7	481	79.0
1788	3000	393.4	426	70.0
1790	2000	398.7	358	56.1
1792	1000	410.0	288	36.0
1793	0	413.3	275	0.0

excessive vibration (possibly caused by two-phase flow) is detected; however, this is not represented in the model.

The RELAP5 pump model consists of a hydrodynamic volume and two junctions.¹ The developed pump head is added into the momentum equations as a body force. This body force term is calculated based on the pump flow rate at the previous time step. For this reason, the pump head at any time is not necessarily consistent with the pump speed and flow at the same time. This may lead to numerical difficulties if the user is not careful. RELAP5 requires that the head and torque data be input in dimensionless, homologous form. Using the data in Table 43, the necessary homologous curves were generated.

The homologous curves for these data, assuming rated conditions of speed, 1786 rpm; flow, 5000 gal/min (0.315 m³/s); head, 366.3 ft (111.6 m) H₂O; and torque, 1361.2 ft-lb_t (1845.5 N-m), are plotted in Figs. 27 and 28. Figure 27 indicates that the dimensionless head curve, which was generated from the 1800-rpm data, is also adequate for 270-rpm pony motor operation. The dimensionless variables required to define the positive flow, positive speed homologous curves are as follows:

$$HAN = h/\alpha^2,$$

$$HVN = h/\nu^2,$$

$$BAN = b/\alpha^2,$$

where

$$h = \text{head}/h_r,$$

$$\nu = \text{flow}/q_r,$$

$$\alpha = \text{speed}/n_r,$$

$$b = \text{torque}/b_r,$$

Fig. 27. Homologous head curves for main circulation pumps.

Fig. 28. Homologous torque curves for main circulation pumps.

h_r = rated head,
 q_r = rated flow,
 n_r = rated speed,
 b_r = rated torque.

The term torque, as used above, refers to the fluid (hydraulic) torque, which can be calculated by dividing the power supplied to the pump by the pump speed and then multiplying that quotient by the pump efficiency.

Data for the pumps are available only for conditions of positive flow and speed. Although significant flow in the reverse direction through the pumps is prevented by check valves immediately downstream, for pump performance with negative flow or speed, data built into the RELAP5 program for a Bingham Pump Company pump¹ with a specific speed of 4200 rpm gal/min^{1/2}/ft^{3/4} were used. Nothing is known about the adequacy of the Bingham model in the HFIR model, so if reverse flow is important for a transient, the analyst should independently ensure that the results are valid, or at least conservative.

For some transients, the pump experiences conditions of two-phase flow. For such transients, RELAP5 requires specification of two parameters termed the head multiplier and head difference. These two parameters relate the single-phase pump performance to the two-phase pump performance. No two-phase data are available for the main circulation pumps, so available data for other centrifugal pumps¹ were used. If significant void exists in one of the pump volumes, it is again necessary that the analyst independently validate the model results. As discussed in detail in Sect. 3.7.2 and Appendix B, should the pump experience cavitation conditions, the pump head is degraded by artificially changing the pump speed.

In the model, the pumps are always controlled by a specified pump speed. When establishing a steady state, the pump speed is adjusted until the desired primary flow is obtained. During most transients the pump is either (1) running at full ac motor speed, (2) coasting down from ac motor speed to pony motor speed, or (3) running at pony motor speed (270 rpm). The actual pump speed is always calculated using RELAP5 control variables (see Sect. 3.7.2). During the pump coastdown, a torque balance is made on the pump shaft to calculate the pump speed according to the relation

$$I \frac{d\alpha}{dt} = T_m - T_f - T_h,$$

I = pump inertia (lb_m -ft²),

T_m = motor torque (ft-lb_t),

T_f = shaft friction torque (ft-lb_t),

T_h = hydraulic torque (ft-lb_t).

Manufacturer's data¹³² for the torque exerted by the pony motor as a function of shaft speed are given in Table 44.

Table 44. Pony motor torque supplied to the pump shaft¹³⁴

Speed (rpm)	Torque (ft-lb _t)
0 ^a	300.0
145	129.0
225	77.2
305	47.6
425	25.4
532	15.8
800 ^a	0.0

^aExtrapolated from data.

After the pumps were rebuilt, data were taken¹³⁵ for the simultaneous coastdown of three main circulation pumps. The total flow rate through the vessel was measured as the pumps coasted down. The pump shaft friction coefficients were adjusted in the model until the measured coastdown curve was closely matched (Fig. 29). The final expression for pump shaft friction torque T_f is

$$T_f = 20 + 50\alpha + 300\alpha^2 \text{ ft-lb}_f . \quad (22)$$

The hydraulic torque T_h is calculated as

$$T_h = \frac{HG}{n} ,$$

where H is the pump pressure head, G is the flow rate, and n is the pump speed.

By balancing the torques applied to the pump shaft, the actual pump speed is determined. However, if pump cavitation occurs, the actual pump speed is not always used for the pump model. Rather, the pump speed is modulated to appropriately degrade the pump head, as would occur when the pump cavitates. The pump cavitation model is discussed further in Sect. 3.7.2 and Appendix B.

Fig. 29. Comparison of RELAP5 simulated main circulating pump coastdown with experimental data.

3.3.4 Main and Standby Pressurizer Pumps

The main and standby multistage centrifugal pressurizer pumps (PU-4A and PU-4B) were supplied by Allis-Chalmers, along with an Instruction Book,²⁸ which contains head, braking horsepower, and efficiency correlations at various pump speeds. The speed of the operating pump is set manually by the operator to achieve the desired 120-gal/min ($7.57 \times 10^{-3} \text{ m}^3/\text{s}$) letdown flow. The pump speed can range from 0 to 3600 rpm, but for 85-MW reactor operation, it is set between 2200 and 2400 rpm. Normally, only one (either PU-4A or PU-4B) pressurizer pump is running. The pump, which is running during normal steady state, will be referred to as the main pressurizer pump. The standby pressurizer pump is interchangeable with the main pressurizer pump and operates with it in a parallel flow arrangement (Fig. 6). The automatic start feature of the standby pump is no longer used; the standby pump will only start on a manual signal. After the standby pressurizer pump start-up signal has been received, a delay of 10 s occurs before the pump ramps up to speed.²⁹ Currently this is modeled in RELAP5 by linearly increasing the speed from zero to the same speed at which the main pressurizer pump is running from 10 to 11 s after the start-up signal is received.

If any one of the following conditions exist, the main (and possible standby) pressurizer pumps are tripped:

1. the pressurizer pump discharge pressure exceeds 532.7 psia (3.67 MPa),
2. the pressurizer pump suction pressure remains below 15.2 psia (0.105 MPa) for at least 5 s,
3. the emergency depressurization valves are tripped open [based on a low primary coolant temperature ($<90^\circ\text{F}$)], or
4. the primary coolant head tank level falls below 25%.³⁰

As with the main circulation pumps, the rate of coastdown of the pressurizer pumps after shutdown depends upon shaft friction and the inertia of the rotating parts attached to the shaft. The pressurizer pump shaft is attached to an electromagnetic clutch with a relatively large moment of inertia. Although the inertia of the clutch and pump combination is not known for certain, an accurate enough value of $120 \text{ lb}_m\text{-ft}^2$ (5.06 kg-m^2) was calculated by Sozer³¹ based on a comparison with a measured coastdown rate. Sozer also calculated a shaft friction coefficient of 247.66 ft-lb_t (335.6 N-m) (appropriate conversions applied). This coefficient is used by RELAP5 as a multiplier on the square of the pump speed ratio to determine the frictional torque during coastdown. A sample calculation was performed for the coastdown of the pressurizer pump to verify that the inertia and friction coefficient values calculated by Sozer indeed bring about a close fit with the plant data.³² Results of this comparison are shown in Fig. 30. An additional coastdown simulation, which was performed for a different initial flow rate and pump head (same initial speed), showed that the fluid inertia was enough lower than the pump inertia that the coastdown was independent of the initial flow rate through the pump.

The performance data for a pump speed of 2616 rpm as extracted from the Instruction Book¹³⁶ are tabulated in Table 45. These data were fitted with polynomials. The rated conditions were then selected such that the homologous curves (see Sect. 3.3.3) pass through the point (1.,1.). Finally the homologous curves, shown in Figs. 31 and 32, were generated. The rated speed is 2616 rpm, the rated head selected is 1376.909 ft (419.682 m), the rated flow selected is 200 gal/min ($0.01262 \text{ m}^3/\text{s}$); and the rated torque is 139.75 ft-lb_t (189.47 N-m).

Fig. 30. Comparison of RELAP5 simulated pressurizer pump coastdown with experimental data.

Table 45. Pump characteristic data for the main and standby pressurizer pumps at 2616 rpm

Pump 69037				Pump 69038			
Flow rate (gal/min)	Head (ft H ₂ O)	Power (bhp)	Efficiency (%)	Flow rate (gal/min)	Head (ft H ₂ O)	Power (bhp)	Efficiency (%)
365	923.4	176	48.2	368	922.6	176	48.5
309	1085.5	171	49.5	322	1085.4	172	51.3
261	1245.5	164	49.9	273	1245	165	51.9
202	1384.4	147	48	206	1380.9	150	47.7
122	1452.9	120	37.4	145.5	1452.5	131	40.7
51.4	1476.6	90	21.1	44.5	1488	87	19.2
0	1482	84	0	0	1495	71	0

Fig. 31. Homologous head curves for main pressurizer pumps.

Fig. 32. Homologous torque curves for main pressurizer pumps.

3.3.5 Auxiliary Pressurizer Pump

The auxiliary pressurizer pump (PU-11) was supplied by Sunstrand Fluid Handling along with head, efficiency, and braking horsepower data at 3541 rpm.¹⁴¹ For pump head <133.9 psi (0.923 MPa) [153.9 psia (1.06 MPa) system pressure], this pump has a constant flow of 39 gal/min ($2.46 \times 10^{-3} \text{ m}^3/\text{s}$). The auxiliary pressurizer pump suction comes from the primary coolant head tank, so the suction pressure is nearly constant at 20 psia (0.138 MPa), varying only slightly as the level in the tank changes. It has been modeled using a time-dependent junction (specified flow rate) and is started only after the pressurizer flow into the cold leg drops below 75 gal/min ($4.73 \times 10^{-3} \text{ m}^3/\text{s}$). The flow rate is increased linearly from zero flow to the flow indicated by the pump data at 5 s after trip. The data have been digitized from the curve supplied by Sunstrand, and the flow rate as a function of pump head is shown in Table 46.

Table 46. Auxiliary pressurizer
flow rate as a function
of pump head

Pump head (psi)	Flow rate (lb/s)
216.0	0.0
214.0	2.77
204.0	4.16
198.7	4.42
185.8	4.71
172.8	4.92
133.9	5.38
0.0	5.38

3.3.6 Letdown and Radiation Block Valves

The pressure in the primary coolant system is controlled by opening or closing the letdown valves (PCV 127-4, -5, and -7), which are located in the 2-in. (5.08-cm) letdown lines branching off of the cold side of each heat exchanger (Fig. 23). The pressure is monitored upstream of the strainer (PT 127), and a signal is sent to a Foxboro Model 58 pneumatic three-mode proportional/integral/derivative (PID) controller (PRC-127). PID control action is defined as¹⁴²

$$m(t) = K_p e(t) + K_p T_d \frac{d}{dt} [e(t)] + \frac{K_p}{T_i} \int_0^t e(t) dt ,$$

where $m(t)$ is the control action (in this case stem position), $e(t)$ is the error signal (in this case difference between pressure and setpoint pressure), K_p is the proportional gain, T_d is the derivative time, and T_i is the integral (or reset) time.

The letdown valve receives the pressure signal from the controller in the range of 3 to 15 psi, so that for a signal change of 1 psi, the corresponding fractional change in valve stem position is 1/12 of the total valve stroke. The controller settings were read¹⁴³ on August 9, 1989, and reported to be

proportional band setting = 100% (gain = 1.0),

reset setting = 12 s,

derivative setting = 9 s.

These settings were made by trial and error while the system was operating. The gain of 1.0 indicated above is for the controller only. The actual gain is 0.08333 psi⁻¹ because of the signal conversion from the controller output to valve stem position at the valve. When these settings were substituted into the RELAP5 control systems, the letdown valve control became unstable. By trial and error, parameters for control of the stem position based on the raw error signal were determined to be 0.0005-psi⁻¹ (0.073-MPa⁻¹) gain, 0.857-s reset time, 1.15-s derivative constant, and 1-s lag time for the valve actuator. The valve is not allowed to open faster than 0.5848 s⁻¹ or close faster than 0.1163 s⁻¹. These rates are based on the maximum times that have been measured¹³⁷ for fully opening (17.1 s) or fully closing (8.6 s) the letdown control valves.

A RELAP5 servo-valve component is used to represent each letdown valve. Using the control systems model, the pressure in the upper plenum of the reactor vessel is monitored, and the letdown valve position is controlled. Equal percentage valve trim¹⁴⁴ with a maximum C_v of 8.7 gal/min/psi^{0.5} is assumed. The maximum C_v is the constant that relates flow through the valve G_{max} to the pressure drop across the valve ΔP when the valve is fully open by the relation,

$$G_{max} = C_v \Delta P^{1/2},$$

where G_{max} is in gal/min and ΔP is in psi.

For equal percentage valve trim, equal incremental changes in the stem position produce equal percentage changes in the flow for a constant pressure difference,¹⁴⁵ or, in equation form,

$$\frac{1}{G} dG = dy,$$

where G is the flow at stem position y . Integrating gives

$$y = \ln G + c_1,$$

and

$$g = \exp \frac{y - 1}{c_1},$$

where g is the ratio between the flow when the stem is at position y and the flow when the valve is completely open ($y = 1.0$). The constant c_1 for the letdown valves is unknown. For

a given pressure drop across the valve, C_v is proportional to the flow rate, hence the C_v dependence upon stem position, which must be supplied to RELAP5, can be calculated from the above equation. Until more information on the valve is obtained, it has been assumed that C_v is proportional to y^3 . This is a good approximation to equal percentage valve trim.

Two radiation block valves are in position immediately downstream of each letdown valve. If the system pressure falls below 407.7 ± 12 psia (2.81 MPa), the block valves immediately close. This is modeled as a part of the letdown control system in the RELAP5 input. For LOCA analyses, the HFIR RELAP5 model conservatively closes the letdown valves when the pressure falls below 395.7 psia (2.728 MPa).

3.3.7 Primary Coolant Head Tank

The primary coolant (PC) head tank (Fig. 23) has a capacity of 2500 gal (0.46 m³) and is 6 ft 6 in. (1.98 m) in diameter and 11 ft 8 in. (3.55 m) long.¹⁴⁶ This tank, located on the first floor, serves as the supply [via a 4-in. (10.16-cm) line] to the suction side of the pressurizer pumps (PU-4A, -4B, and -11) on the ground floor. The water that exits the high-pressure system through the letdown valves is eventually returned to the PC head tank after passing through the clean-up system. The mass of water passing through the letdown valves at a given time is assumed to be equal to the mass of water passing into the PC head tank from the clean-up system.

The level in the PC head tank must be monitored in the model to determine when the pressurizer pumps should be shut down and when the demineralized make-up flow should be supplied. If the level in the PC head tank drops below 25%, then the pressurizer pumps are shut down. If the level in the PC head tank is detected to be <70%, then a make-up flow of demineralized water is supplied to it by demineralized water pump PU-18A or PU-18E. During normal operation, this situation will occur due to leakage (Sect. 3.7.12) at the primary coolant pump seals, and the make-up flow will be more than enough to replenish the tank. In the model, if the level drops below 70%, then an assumed maximum make-up flow of 90 gal/min (5.68×10^{-3} m³/s) is supplied.¹⁴⁷ This is the maximum design flow through the demineralizer system.

There is an additional reason for keeping track of the level in the PC head tank. Once the system has been depressurized, the head across the pressurizer pump(s) is relatively small; thus, a small change in the suction pressure brought about by a change in the head tank level may significantly affect pressurizer pump performance.

The PC head tank is represented with an 80°F (26.7°C) time-dependent volume (volume 68) for which the pressure is calculated using the RELAP5 control systems model (see Sect. 3.7.1). The mass flows in and out of the tank are summed, and that sum is integrated over the time to determine the mass of water in the tank. The tank level can then be calculated knowing the tank geometry. The dependence of the level and the pressurizer pump suction pressure upon the fraction of the tank volume containing water is shown in Fig. 33. The initial level in the tank is assumed to be 70% (the lowest level allowed before the make-up flow is added). The pressure that is assigned to time-dependent volume 68 is equal to the tank overpressure (-50-in. H₂O vacuum)¹⁴⁸ plus the static head (0-6 ft or 0-1.83 m) of the tank water.

3.3.8 Secondary Coolant System

The HFIR secondary coolant system is shown in Fig. 34. Each of the three available main secondary coolant pumps (PU-6A, -6B, and -6C) have a capacity of 13,000 gal/min

Fig. 33. Relationship between PC head tank level and pressurizer pump suction pressure and percentage of tank volume containing water.

(0.82 m³/s) when operated at 1160 rpm and 120 ft (36.6 m) total developed head.¹⁴⁹ Only two of the pumps are operated at a given time.

When the reactor is shut down, or an emergency situation occurs, the auxiliary secondary coolant pump¹⁵⁰ (PU-14) with 6000-gal/min (0.379-m³/s) capacity at 100-ft total developed head and 1200 rpm circulates flow through the system. If the line power is lost, the auxiliary secondary pump is powered by diesel generators using a second motor winding (600 rpm) to supply 3000 gal/min (0.190 m³/s) of secondary coolant flow.

Before the new heat exchangers were installed, 20,000 gal/min (1.26 m³/s) of secondary flow was supplied to the primary coolant heat exchangers, and the remaining 6000 gal/min (0.379 m³/s) was diverted to other auxiliary equipment and the Transuranium Processing Facility (TRU).¹⁵⁰ However, because the new heat exchangers have been installed, between 11,400 and 14,500 gal/min (0.719 and 0.915 m³/s)^{131,151} has been required to remove the heat generated in the reactor. Much of the secondary flow is allowed to bypass the pool heat exchangers through HCV 438 and thus remains at the secondary coolant inlet temperature of 85°F (29.4°C). In this manner, when the flows recombine before entering the cooling tower, the cold bypass water keeps the cooling tower inlet temperature low enough to avoid cooling tower damage.

The cooling tower¹⁵² has been designed to cool 26,000 gal/min (1.64 m³/s) from 115 to 85°F (46.1 to 29.4°C) by transferring heat to a 77°F (25°C) wet-bulb-temperature environment. The cooling tower basin contains 400,000 gal (1514 m³) of water divided into four equal compartments.

The secondary coolant flow rate through the heat exchangers is automatically controlled with a Foxboro Model 58 controller by adjusting throttling valve FCV 377A in a 10-in.

Fig. 34. HFIR secondary coolant system.

(0.254-m) bypass pipe, which is in parallel with the main 36-in. (0.914-m) pipe. Throttling valve FCV 377 located in the 36-in. line is adjusted manually to keep the desired flow rate within the range of the valve in the 10-in. line. The 10-in. control valve is positioned to maintain the vessel inlet temperature at 120°F (48.9°C) using PID control (see Sect. 3.3.6).

When scram occurs, the two main secondary coolant pumps are tripped, and the cooling tower bypass valve FCV-362A opens (within 87 s)¹³⁷ to prevent overcooling of the primary coolant, and the auxiliary secondary coolant pump is started.

The representation of the secondary side of each heat exchanger has already been discussed (Sect. 3.3.2). The nodal diagram for the secondary coolant system was shown in Fig. 25. Five volumes are included in each of the pipe components numbered 100–107, 200–207, and 300–307.

It was desired to correctly model the heat removal and overall flow rates in the system, but some of the details (such as the distribution of flow through the TRU and auxiliary equipment) are unimportant and would require significant effort to include in the model. For this reason, a simplified representation of the secondary cooling system was used, and then a calibration of some of the pipe lengths was performed¹¹³ to match available flow rate and pressure data. The available data consist of heat exchanger flow rate, total flow rate (based on pump discharge pressure measurement and head/flow curve), and heat exchanger pressure drop. The time-dependent volume 123 is used to maintain the secondary coolant pump suction pressure at atmospheric pressure. (The pump suction is near the same level as the surface of the water in the cooling tower basins.) The two operating main secondary coolant pumps are represented with the RELAP5 Bingham pump model,¹ and the auxiliary secondary coolant pump is included separately. The same moment of inertia and friction coefficients were assumed for the main secondary coolant pumps as for the primary coolant pumps. The coastdown of the main secondary coolant pumps after a reactor trip is illustrated in Fig. 35

Fig. 35. Coastdown rate of secondary coolant pumps.

(data taken from Ref. 153). The data were taken with the old heat exchangers in place, and because the RELAP5 model is for the new system, the initial flow rate is lower. For LOCA transients the model of the secondary system is adequate because the critical time period for the fuel is early in the calculation before transient effects in the secondary system affect the primary coolant. If the model is used for a long running transient, with the secondary flows changing, more modeling may be necessary.

In the model, when power is supplied to the main secondary coolant pumps, they are controlled at a specified speed of 1186 rpm. A ramp time of 5 s is assumed for the auxiliary secondary pump to come to full speed, once the reactor is tripped. The auxiliary pump is always controlled by a specified speed, depending on the mode of operation.

Water passing through the cooling tower is represented in the model by pipe component 132, containing five volumes. Here the heat is removed from the secondary coolant across five heat structures to the cooling tower stream. The cooling tower stream is a separate flow system (Fig. 25) consisting of a 60°F mass source (time-dependent volume 401), a specified flow rate junction (time-dependent junction 402), a pipe used to remove heat from the secondary system (pipe 403), and a mass sink (time-dependent volume 405). The flow rate is controlled (see Sect. 3.7.13) so that the secondary coolant leaving the cooling tower is at 85°F.

The cooling tower bypass valve (component 136 in Fig. 25) is normally closed so all of the secondary flow passes through component 132. An additional valve is included (component 135) so that when the cooling tower bypass valve opens, the flow through the cooling tower is simultaneously stopped.

The secondary flow, which is diverted to the auxiliary equipment and the TRU, is represented by volume 131. Valve 228 is used to represent the flow bypassing the pool heat exchangers.

As shown in Fig. 25, the 10-in. bypass line containing FCV 377A has been represented in the model with a servo valve RELAP5 component inserted to regulate the flow. A control system has been implemented for controlling the stem position of this valve. The control system receives an error signal based on the inlet vessel water temperature. The 36-in. manual control valve has also been represented with a servo valve component. The value for the area should be set so that the secondary flow rate through the heat exchangers is between 11,400 and 14,500 gal/min. The abrupt area change model is used to characterize the pressure-flow performance of both flow-control valves 377 and 377A. The settings on the PID controller on August 9, 1989, were

proportional band setting = 10% (gain = 10.0),

reset setting = 30 s,

derivative setting = 6 s.

As for the letdown control system, using these settings in the model caused the calculation to enter into oscillation; the current values being used are

gain = 0.2,

reset time = 20 s,

derivative time = 2.5 s.

Although a substantial discrepancy exists, for LOCAs and most operational transient calculations, accurate modeling of the automatic control of the secondary coolant flow is not critical. For transients where it is important, the analyst should do further work in arriving at conservative settings.

As has been mentioned, the secondary piping components outside of the heat exchangers have been modeled using approximate dimensions. Although the total secondary flow rate is not directly measured, the outlet pressure of the secondary coolant pumps is indicated in the control room. On September 25, 1990, this reading indicated 65 psig.¹⁵⁴ From the pump curves for the secondary coolant pumps,¹⁵⁵ this indicates a total flow of about 18,000 gal/min. It has already been mentioned that the heat exchanger flow is normally somewhere between 11,400 and 14,500 gal/min. Another constraint on the secondary-side hydraulics is that FCV 377A controls only about 7% of the flow. The dimensions of pipes 137 and 131 (Fig. 25) and the position of manually controlled valve 377 were adjusted in the model until the above constraints were satisfied. The total heat transfer area of the heat exchanger was then calibrated so that during steady-state, 85-MW operations with FCV 377A at a stem position of 0.5, the primary coolant inlet temperature is 120°F (48.9°C).

3.4 SYSTEM STIFFNESS

The HFIR does not have a conventional pressurizer such as that found in other light-water reactors. Rather, it uses a high-head, low-flow pressurizing pump to pressurize the all-liquid system. The stiffness of the system depends upon both the compressibility of the water and the structural elasticity of the piping, vessel, and other components that contain the water. Because RELAP5 does not account for the stretching (or shrinkage) of the piping structures, a control systems model was developed to simulate the effect. The structural elasticity is only important when the system pressure changes drastically (such as the depressurization that immediately follows a significant break in the primary coolant containment). Once vapor is generated in the system, the structural elasticity is no longer important because the vapor is highly compressible.

3.4.1 Mathematical Framework

Pressure changes in the single-phase HFIR primary coolant system can be directly attributed to one of three causes: changes in the mass inventory of the system, changes in the total volume of the system (structural expansion or contraction), or changes in the temperature of the water. The relationship between the above effects can be expressed mathematically by considering contributions to changes in the total system inventory for a system with uniform temperature and pressure.

$$d(\text{mass}) = d(\rho V) = \frac{\partial}{\partial T} (\rho V) dT + \frac{\partial}{\partial P} (\rho V) dP \quad (3)$$

$$d(\text{mass}) = \left(\rho \frac{\partial V}{\partial T} + V \frac{\partial \rho}{\partial T} \right) dT + \left(\rho \frac{\partial V}{\partial P} + V \frac{\partial \rho}{\partial P} \right) dP$$

Considering a finite change in mass $\Delta(\rho V)$ that results in a corresponding change in temperature ΔT and in pressure ΔP , then rearranging gives

$$\Delta(\rho V) = \rho \frac{\partial V}{\partial T} \Delta T + \rho \frac{\partial V}{\partial P} \Delta P + V \frac{\partial \rho}{\partial T} \Delta T + V \frac{\partial \rho}{\partial P} \Delta P, \quad (4)$$

$$\Delta(\rho V) = \text{term 1} + \text{term 2} + \text{term 3} + \text{term 4}$$

where

- term 1 = expansion or contraction of the primary system pressure boundary due to the temperature change,
- term 2 = expansion or contraction of the primary system pressure boundary due to the pressure change,
- term 3 = density variation in the water due to the temperature change,
- term 4 = density variation in the water due to the pressure change.

3.4.2 Discussion of Terms

3.4.2.1 Term 1

The expansion or contraction of the pressure boundary due to temperature changes in the piping and vessel can be approximated by considering the system to be made up of unconstrained pipes. The linear expansion in the length of metal L with constant thermal expansion coefficient λ is given by

$$\frac{\partial L}{\partial T} = \lambda L. \quad (5)$$

If the length of pipe L and the inner circumference of the pipe C behave according to relation [Eq. (5)], then

$$\frac{\partial V}{\partial T} = \frac{\partial}{\partial T} \left(\frac{C^2 l}{4\pi} \right) = \frac{Cl}{2\pi} \frac{\partial C}{\partial T} + \frac{C^2 \partial l}{4\pi \partial T} = \frac{3}{4} \frac{\lambda C^2 l}{\pi} = 3\lambda V. \quad (6)$$

Dixon¹⁵³ determined that the high-pressure side of the primary coolant system, with three heat exchanger cells considered and only an orifice in the reactor vessel, contains about 12,500 gal [1671 ft³ (47.32 m³)]. The pipes are stainless steel [$\lambda = 9.6 \times 10^{-6} \text{ }^\circ\text{F}^{-1}$ ($1.728 \times 10^{-5} \text{ }^\circ\text{C}^{-1}$)].¹⁵⁶ The model, based on the dimensions in the available drawings, includes 11,600 gal (43.91 m³) with the target, core, and reflectors in place. Applying Eq. (6) gives a volume sensitivity with respect to a temperature of 0.04458 ft³/°F (0.00227 m³/°C).

3.4.2.2 Term 2

The structural elasticity of any component is here defined as the quantity

$$\frac{1}{V} \frac{\partial V}{\partial P},$$

where V is the fluid volume within that component, and P is the fluid (internal) pressure.

The structural expansion or contraction due to pressure change in the pipes can also be estimated assuming that the system consists of unconstrained pipes. The radial deflection of a thin-walled cylinder pressurized from the inside is¹⁵⁷

$$\Delta r = \frac{Pr^2}{Et},$$

where P is the gage pressure in the pipe, r is the pipe radius, E is the modulus of elasticity (30×10^6 psi for stainless steel),¹⁵⁸ and t is the wall thickness. The change in length Δl is

$$\Delta l = -\frac{Pr\mu l}{Et},$$

where μ is Poisson's ratio (0.3 for stainless steel).¹⁵⁸ Using the above expressions, the structural elasticity for an unconstrained pipe can be determined as follows. The unstressed volume V_o contained within a pipe is

$$V_o = l\pi r^2.$$

The volume V contained within a pipe with internal gage pressure P is

$$\begin{aligned} V &= \pi(l + \Delta l)(r + \Delta r)^2 \\ &= \pi \left(l - \frac{Pr\mu l}{Et} \right) \left(r + \frac{Pr^2}{Et} \right)^2. \end{aligned}$$

So the sensitivity of contained volume with respect to pressure can be calculated as

$$\frac{\partial V}{\partial P} = 2\pi \left(l - \frac{Pr\mu l}{Et} \right) \left(r + \frac{Pr^2}{Et} \right) \left(\frac{r^2}{Et} \right) + \pi \left(-\frac{\mu r l}{Et} \right) \left(r + \frac{Pr^2}{Et} \right)^2.$$

Dividing by the unstressed volume and simplifying gives

$$\frac{1}{V_o} \frac{\partial V}{\partial P} = \frac{r}{Et} \left\{ 2 + \frac{2Pr}{Et} - \mu \left[1 + \frac{4Pr}{Et} + 3 \left(\frac{Pr}{Et} \right)^2 \right] \right\}.$$

But $Pr/Et \ll 1$ for standard steel pipes with internal pressures < 1000 psi, and $V \approx V_o$, so,

$$\frac{1}{V} \frac{\partial V}{\partial P} = \frac{r}{Et} (2 - \mu) = \frac{d}{Et} \left(1 - \frac{\mu}{2} \right), \quad (7)$$

where $d = 2r$. The above equation was applied to pipes in the HFIR primary coolant system to estimate the change in volume with respect to pressure. It was also applied to the reactor vessel. Although the vessel is radially constrained at top and bottom, it will be shown that the elasticity predicted by this simple model is accurate enough. Table 47 shows how the

water volume is distributed throughout the primary system and gives the change in volume with respect to pressure (elasticity) for each part. Volumes listed in Table 47 for which no stiffness numbers are given were assumed to be structurally rigid. The table includes only those volumes in the high-pressure system (upstream of the letdown valves and downstream of the pressurizer pumps).

Table 47. Elasticity in the HFIR primary coolant containment

Component	Inside diameter (in.)	<i>t</i> (in.)	$\frac{1}{V} \frac{\partial V}{\partial P}$ (psi ⁻¹)	Volume (ft ³)	$\frac{\partial V}{\partial P}$ (ft ³ /psi)
Reactor vessel	94.0	3.125	9.1×10^{-7}	629.54	5.73×10^{-4}
HX tubing	0.555	0.035	4.8×10^{-7}	358.73	1.72×10^{-4}
Cold leg (20 in.)	18.814	0.593	9.6×10^{-7}	151.94	1.46×10^{-4}
Hot leg (18 in.)	16.876	0.562	9.1×10^{-7}	140.63	1.28×10^{-4}
10-in. pipes (sched. 40)	10.02	0.365	8.3×10^{-7}	111.50	0.93×10^{-4}
HX plena				47.19	
14-in. pipes	13.126	0.437	9.1×10^{-7}	38.13	0.35×10^{-4}
16-in. pipes	15.0	0.5	9.1×10^{-7}	35.19	0.32×10^{-4}
Strainer housing				10.45	
10-in. pipes (sched. 80)	9.564	0.593	4.6×10^{-7}	8.82	0.04×10^{-4}
Pzr. line				7.60	
Venturi				4.59	
PC pumps				2.82	
Letdown pipes				0.70	
Total				1547.83	1.183×10^{-3}

Based on the total fractional volume change of 0.001183 ft³/psi (0.00486 m³/MPa), the effective structural stiffness of the system is 113 psi/gal (206 MPa/m³).

It is important to adequately represent the vessel elasticity because the vessel contains about 40% of the water in the system. The vessel is capped by a 13-in.-thick (33.0-cm) lid, and necks down from the 94-in.-diam (239-cm) section through a hemispherical section to a 31-in.-diam (78.7-cm) section. Because the vessel shape (Fig. 3) is markedly different from that of an unconstrained pipe, two axisymmetric ADINA¹⁵⁹ simulations were run to

calculate the deformation (and fractional volume change) of the vessel as it is pressurized from atmospheric pressure to 1000 psi (6.89 MPa). ADINA is a finite-element stress analysis code.

The first simulation was run assuming that the vessel was constrained only at the lowermost point in the vertical direction. The exaggerated deformation resulting from this simulation is shown in Fig. 36. The fractional volume change with respect to pressure is essentially constant (Fig. 37). This quantity was calculated by numerically evaluating the volume contained within the vessel, based on the deformed geometry at each loading. For

ORNL-DWG 92-3216 ETD

Fig. 36. Exaggerated deformation of pressurized HFIR reactor vessel without support constraint.

Fig. 37. Elasticity of HFIR reactor vessel without support constraint.

the second simulation, the part of the vessel in contact with the vessel supports was constrained in both the vertical and horizontal directions. The results are shown in Figs. 38 and 39.

The elasticity of the vessel is only slightly greater than the Table 47 estimate. It is not intuitively clear whether the finite-element results should give a larger or smaller value for the vessel elasticity than the unconstrained pipe calculation. Although the additional radial constraints have been imposed with the finite-element model, the lid also allows vertical elongation of the vessel, whereas the unconstrained pipe estimate assumes shrinkage in the vertical direction. It is concluded from these results that the unconstrained pipe estimate for overall structural stiffness [112 psi/gal (204 MPa/m³)] is about right with regard to the vessel contribution.

If temperature effects are assumed to be small (as will be shown), then terms 1 and 3 can be neglected and Eq. (4) can be used to calculate the overall structural elasticity:

$$\frac{1}{V} \frac{\partial V}{\partial P} = \frac{1}{\rho V} \frac{\Delta(\rho V)}{\Delta P} - \frac{1}{\rho} \frac{\partial \rho}{\partial P} .$$

The measurements of ΔP (pressure change) and $\Delta(\rho V)$ (change in system inventory), taken by Dixon,¹⁵³ can be directly substituted into the above equation. Because Dixon's measurements were taken with all four heat exchanger cells open, the total volume within the system pressure boundary was larger than that for the normal system configuration during operation. This was accounted for, and Fig. 40 shows that the analytical results are consistent with those measurements taken by Dixon.

Fig. 38. Exaggerated deformation of pressurized HFIR reactor vessel with support constraint.

ORNL-DWG 92-3219 ETD

Fig. 39. Elasticity of HFIR reactor vessel with support constraint.

ORNL-DWG 92-3220 ETD

Fig. 40. Extraction of structural elasticity from experiments performed by Dixon.

3.4.2.3 Term 3

Sample calculations run with the RELAP5 computer program indicate that the total temperature change of the HFIR system during depressurization from 1000 to 25 psi (6.89 to 0.172 MPa) is about -0.3°F (-0.167°C). This result has been independently confirmed by Sozer.¹⁶⁰ The temperature- and pressure-dependent density was extracted from RELAP5 using sample calculations. The density dependence upon temperature and pressure is fitted with polynomials in Figs. 41 and 42. Using the curve fit shown in Fig. 41, the sensitivity of density with respect to temperature at 100°F is about $-0.0132 \text{ lb}_m/\text{ft}^3\text{-}^{\circ}\text{F}$.

3.4.2.4 Term 4

The compressibility of water is easily obtained from Fig. 42. Here, it can be seen that $\partial\rho/\partial P$ is about $1.89 \times 10^{-4} \text{ lb}_m/\text{ft}^3\text{-psi}$ at 90°F over the range of pressure from atmospheric to 1000 psi and $1.88 \times 10^{-4} \text{ lb}_m/\text{ft}^3\text{-psi}$ at 100°F over the same range of pressure. From this number, term 4 can be calculated.

One common way to characterize the stiffness of the system is to calculate K_f , which is a spring constant in psi/gal based solely on fluid compressibility. Using the total volume in the model [1551 ft^3 (43.9 m^3)], K_f is

$$K_f = \frac{\rho}{V \frac{d\rho}{dP}} = 28.4 \text{ psi/gal} \text{ (} 51.7 \text{ MPa/m}^3 \text{)} .$$

Fig. 41. Water density dependence upon temperature according to RELAP5 water properties library.

Fig. 42. Water density dependence upon pressure according to the RELAP5 water properties library.

To validate the density information for water that exists in RELAP5, a comparison was made to the ASME steam tables.¹⁶¹ Figure 43 shows the density as a function of pressure at 100°F as calculated by RELAP5. Data taken from the ASME Steam Tables is plotted on the same graph. The stair-step behavior of the ASME data is due to the limit of significant figures available. Excellent agreement is seen as RELAP5 data split right through the middle of the ASME data.

3.4.3 Combination of Terms

Assuming the primary coolant system, initially at 1000 psi and 100°F, depressurizes to 25 psi during which the adiabatic, uniform temperature change is -0.3°F , the terms in Eq. (2) can be calculated as

$$\text{term 1} = 61.5 \frac{\text{lb}_m}{\text{ft}^3} \times 0.0458 \frac{\text{ft}^3}{^\circ\text{F}} \times -0.3^\circ\text{F} = -0.823 \text{ lb}_m ,$$

$$\text{term 2} = 61.5 \frac{\text{lb}_m}{\text{ft}^3} \times 0.001183 \frac{\text{ft}^3}{\text{psi}} \times -975 \text{ psi} = -70.94 \text{ lb}_m ,$$

$$\text{term 3} = 1548 \text{ ft}^3 \times -0.0132 \frac{\text{lb}_m/\text{ft}^3}{^\circ\text{F}} \times -0.3^\circ\text{F} = 6.13 \text{ lb}_m ,$$

$$\text{term 4} = 1548 \text{ ft}^3 \times 0.000188 \text{ lb}_m/\text{ft}^3/\text{psi} \times -975 \text{ psi} = -283.7 \text{ lb}_m .$$

Fig. 43. Comparison of RELAP5 water density with ASME Steam Table values.

Thus, during the depressurization, 349 lb_m (42.1 gal at 100°F) is lost from the system; 0.2% is due to thermal contraction of the pipes, -1.8% to the water contracting, 20.3% to structural contraction due to internal pressure change, and 81.3% to isothermal compressibility of the water.

RELAP5 accounts for the water compressibility (term 4) and temperature change (term 3) in its normal solution process. The thermal expansion of the pipes (term 1) due to an adiabatic depressurization (or repressurization) is neglected. Furthermore, all dimensional changes due to thermal changes of the pipes are neglected for all transients. The structural elasticity of the system is significant and must be accounted for in the model.

3.4.4 Inclusion in the Model

RELAP5 does not automatically account for stretching of the system pressure boundary (pipes, vessel, and other components) as quantified in term 2 above. Rather, using the control systems, a method for representing the structural stiffness was devised whereby mass is added to or taken away from the system depending on whether the pressure is decreasing or increasing. Because the structural stiffness (the reciprocal of dV/dP) has been quantified (113 psi/gal), by monitoring the time rate of change in system pressure (dP/dt), the amount of volume per unit time that should be added to or taken away from the system to account for shrinkage or expansion of the pressure boundary can be calculated as $dP/dt \times dV/dP$.

Because different places in the system experience different pressure changes, it is possible that injecting (or ejecting) all of this mass compensation at a single point based upon the pressure monitored at a single point may not be sufficient to accurately represent the distributed pressure boundary changes. Concentrating the injection of mass might also lead to some instability in the model.

Initial testing of the single-monitor/single-injector model was done for a sudden depressurization from a zero velocity, pressurized state where the rate of mass loss from the

system was fixed. The pressure in the reactor vessel was monitored and mass added to or taken away from the system depending on the rate of pressure change. The mass injection (or ejection) occurred at the largest volume in the system (volume 33 in Fig. 7).

Depressurization of the system was simulated with and without the effects of structural elasticity by specifying a constant leakage rate. The results indicated that the single-monitor/single-injector model is adequate to represent the distributed effect of the structural elasticity because the results have the same qualitative behavior.

No instabilities were observed for these initial runs. However, the initial break simulations were run where the mass loss from the system varied with time. Instability was observed, and it was necessary to lag the response of the mass injection/ejection to the pressure change. The response follows the relation,

$$Q^* = \int_0^t \frac{Q - Q^*}{t_L} dt ,$$

where at time t , Q is the product $dP/dt \times dV/dP$ (calculated injection/ejection rate), Q^* is the adjusted rate of volumetric injection/ejection, and t_L is a characteristic lag time. For all of the transients that have been run to date, using 10^{-3} s for t_L has produced the best results.

Figures 44 and 45 show a comparison of depressurization (via a 1.5-in. break without the pumps and reactor operating) results with and without the single-monitor/single-injector structural elasticity model. The vessel upper plenum pressures are compared in Fig. 44, and the stiffness values based on the time rate of pressure change in the upper plenum during the depressurization are compared in Fig. 45. Although for single phase, the same behavior is seen with and without the structural elasticity model, it is expected that when some vapor exists in the system, the signal propagation rate will be greatly reduced. This could result in making the elasticity control system unstable. For SBLOCA transients, two-phase flow generally occurs first (if at all) during the initial depressurization. It is falling pressures (and

Fig. 44. Upper plenum pressure history during depressurization of system with and without elasticity model.

Fig. 45. Upper plenum history of change in pressure with respect to change in system volume during depressurization of system with and without the elasticity model.

not rising temperatures) that will bring about two-phase flow, which occurs first in the hot leg or at the suction to the main circulation pump(s). The elasticity control system must be engaged during the initial depressurization because this is the time when its effect will be significant. However, to disengage the elasticity control system before two-phase flow occurs, a cutoff value was set for the pressure at the suction side of main circulation pump PU-1D (generally the lowest pressure in the system). This cutoff value was chosen to be 20.0 psia, which is greater than the anticipated saturation pressure just after the initial depressurization.

The time-dependent junction 42 is assigned a mass flow rate, via control variables 372–376 (see Sect. 3.7.10), based on the pressure changes at volume 33. Junction 42 (Fig. 7) joins time-dependent volume 40 to volume 33. Volume 40 serves as the source or sink for mass injected or ejected from the system. The temperature of the water in volume 40 is equal to that in volume 33. Because the mass flow injection rate is specified, the pressure and associated density in volume 40 are unimportant.

3.5 LOSS COEFFICIENTS

RELAP5 contains a smooth area change (no irreversible losses unless specified by the code user) model and an abrupt area change model,¹⁶² which take into account form losses that occur at a transition to larger or smaller pipe size. The smooth area change model was invoked at the Venturi flowmeter (Fig. 5). The sudden change in diameter between the schedule 40 and schedule 80 10-in. pipes in cells 110 and 111 is modeled with the abrupt area change model. The abrupt area change model is also specified at the break junctions.

To include other head losses incurred due to flow through various fittings, including bends (elbows), valves, tees, wyes, and heat exchanger tube entrance and exit, empirical loss coefficients were supplied to the RELAP5 program. The loss coefficient K is the number of

velocity heads lost at a junction. One velocity head is defined as $v^2/2g$, so the loss coefficient is

$$K = \frac{h_l}{v^2/2g},$$

where v is the average fluid velocity at the junction, g is the acceleration of gravity, and h_l is the irreversible head loss. The values selected for junction loss coefficients in the RELAP5 model are discussed in this section. It has been assumed for all of the junctions that the loss coefficient K is independent of Reynolds number.

3.5.1 Strainer

The HFIR inlet piping strainer is described by Abbatiello and Fraas.¹⁶³ It consists of two layers: a steel plate with holes and a steel screen. Idel'Chik¹⁶⁴ gives correlations for the loss coefficients through the plate and the screen. The Idel'Chik correlations were developed for a flat screen and plate; however, it is here applied to the conical screen and plate. Also each correlation is for either a screen or plate by itself, whereas the two are abutted in the HFIR water strainer. The total surface area of the plate neglecting the holes was calculated to be 9.773 ft² (0.908 m²). The fraction of open area to closed area was calculated to be 0.403 in the plate and 0.1902 in the screen. Using the Idel'Chik correlations, this gives a loss coefficient of 2.80 for the plate and 19.2 for the screen. These loss coefficients are based on the average velocity corresponding to the total surface area of the strainer (9.773 ft²). The loss coefficient is assumed to be the same for flow in either direction through the strainer. Some selected hourly readings²⁶ since 1969 for the pressure drop across the strainer housing (PdT103) range from 11.2 to 13.1 psi (77.2 to 90.3 kPa). These data are shown in Table 48 and Fig. 46.

The two data points in Fig. 46 that indicate a pressure drop of <10 psi were taken in 1969, before the most recent strainer design was adopted (1972). One pressure tap for PdT103 is located 2 ft (0.61 m) upstream (in the 20-in. cold leg) of the strainer housing, and the downstream taps are located in a straight portion of the 16-in. inlet lines connecting to the reactor vessel.¹⁶⁵ The readings from PdT103 include not only the strainer pressure drop but also pressure losses into and out of the strainer housing, several feet of piping friction loss, pressure loss at the 45° bend in the 16-in. inlet piping, about 5 ft (1.52 m) of static head pressure recovery, and pressure recovery due to different velocities at the two tap locations. The head loss through the strainer itself was calculated by Abbatiello and Fraas¹⁶³ to be 0.5 psi; however, an incorrect amount (635 in.²) of open area in the screen was assumed in this calculation. The correct value is about 268 in.² (1729 cm²). This error resulted in underpredicting the velocity and pressure drop.

The pressure drop through the strainer screen and plate can be calculated as

$$\Delta P = K \frac{\rho G^2}{2g_c A^2},$$

where K is the total loss coefficient, ρ is the density (61.7 lb_m/ft³ at 120°F), G is the volumetric flow rate, g_c is 32.2 lb_m-ft/lb_f-s², and A is the area upon which the loss coefficients were based. This expression gives $\Delta P = 1.95$ psi due to the strainer alone, assuming the loss coefficients taken from Idel'Chik, and a flow rate of 16,000 gal/min.

Table 48. HFIR hourly checksheet data for strainer pressure drop (PdT103)

Date	Pressure drop	
	in. H ₂ O	psi
09-01-69	270	9.653
09-01-69	270	9.653
12-03-73	325	11.620
04-15-75	325	11.620
04-01-78	348	12.442
09-15-79	351	12.549
09-24-79	351	12.549
07-03-81	353	12.621
07-26-81	355	12.692
11-11-82	315	11.262
11-24-82	313	11.190
11-29-82	313	11.190
05-08-83	323	11.548
05-20-83	318	11.369
07-01-83	328	11.727
09-12-84	332	11.870
09-23-84	328	11.727
03-01-85	348	12.442
03-18-85	350	12.513
09-06-85	350	12.513
09-18-85	349	12.478
11-01-86	365	13.050
11-03-86	365	13.050

A cross-flow junction is used in the model to represent the juncture between the 20-in. cold leg (volume 80-04) and the top volume (81) of the strainer housing. At this junction a loss coefficient of 1.44 based on the Idel'Chik correlation¹⁶⁶ for a sharp elbow with a recess is used. This means the pressure drop at the entrance to the strainer housing is about 3.32 psi (0.0229 MPa). Because the stream is turned 90° in volume 81, RELAP5 forces the velocity in volume 81 to be zero so that the pressure is equal to the stagnation pressure. A tee junction exists at the exit of the strainer housing, branching into the 16-in. inlet pipes. From Miller,¹⁶⁷ the tee loss coefficient based on the 16-in. pipe area is about 1.95. This results in a pressure drop through the tee of 2.74 psi (0.0189 MPa). The pressure difference ΔP_{103} can be calculated then by adjusting the total head losses by the elevation and velocity differences,

$$\Delta P_{103} = 1.95 + 3.32 + 2.74 - \frac{\rho g}{g_c} (z_{upstream} - z_{downstream}) - \frac{\rho}{2g_c} (v_{upstream}^2 - v_{downstream}^2) + \text{line losses}$$

Fig. 46. Measurements recorded for PdT103 from HFIR hourly checksheets.

$$= 1.95 + 3.32 + 2.74 - 1.79 - 0.868 + \text{line losses}$$

$$= 5.35 \text{ psi} + \text{line losses} .$$

The steady-state value for PdT103 calculated in the model including line losses is 5.58 psi (0.0385 MPa). Although this is about half of what was measured, the flow is also low (16,171 gal/min). Still, increasing the flow to 17,000 gal/min would only result in an increase to 6.2 psi (0.0427 MPa) for PdT103. It was assumed that the cause for the discrepancy was that the loss coefficients calculated with the Idel'Chik correlations at the entrance and exit of the strainer housing were not accurate for this application. To be consistent with the measured data, both of these loss coefficients were set at 2.915, resulting in a pressure drop of 10.67 psi (0.0736 MPa).

3.5.2 Heat Exchanger Inlet and Outlet

Loss coefficients at the inlet and outlet of the tube bundle on the primary side of the heat exchanger were calculated based on correlations published in Idel'Chik.¹⁶⁸ A Reynolds number of 60,000 was calculated for steady-state flow through each tube. For the entrance into a thick-walled orifice, the loss coefficient is 1.455. For discharge from a conduit (heat exchanger tube), the loss coefficient is 2.0. For reverse flow through the exchanger, the loss coefficient at the inlet is the same as for forward flow at the outlet and vice versa.

3.5.3 Bends and Elbows

At many locations throughout the primary cooling system, bends and elbows of 45°, 90°, and 135° exist in the piping. The ratio between the radius of curvature and the nominal pipe diameter is 1.5 for the bends in the pipe, except for in the 16-in. inlet lines where the ratio is 1.0. The loss coefficients for all sizes of bends and elbows are given in Table 49.

Table 49. Loss coefficients for bends and elbows

Pipe size (in.)	Angle (deg)	Crane ^a	Miller ^b	Used
10	45	0.014	0.072	0.10
10	90	0.196	0.185	0.19
14	45	0.124	0.090	0.10
16	135	0.131	0.095	0.10
16	90	0.335	0.250	0.22
18	90	0.168	0.175	0.17
20	90	0.168	0.175	0.17

^aReference 169.^bReference 170.

3.5.4 Wyes

As flow diverges from the hot leg to the heat exchangers and converges into the cold leg from the heat exchanger, frictional losses occur at the wye junctions. Works by Idel'Chik¹⁷¹ and Miller¹⁷² both contain information regarding loss coefficients at wyes. The loss coefficients calculated from these two references and the actual values used in the model are tabulated in Tables 50 and 51, with reference to Fig. 47. Values are tabulated for both the 18-in. (45.7-cm) hot leg and the 20-in. (50.8-cm) cold leg. The G_1 , G_2 , and G_3 are the flows at the points 1, 2, and 3 in Fig. 47.

Because the correlations give loss coefficients based on the smaller of the two areas and, in the model, the main passage area was always used, the resulting coefficients were adjusted. The values used in the RELAP5 model are the "adjusted" values.

Table 50. Loss coefficients for diverging wye junctions

Pipe size (in.)	Configuration	G_1/G_2	Miller ^a	Idel'Chik ^b	Assumed	Adjusted
18	K_{31}	1/3	0.95	0.548	0.95	0.878
18	K_{32}	1/3	-0.025	0.044	0.0	0.0
18	K_{31}	1/2	1.20	1.10	1.10	1.02
18	K_{32}	1/2	0.025	0.0	0.0	0.0
18	K_{32}	0	0.040	0.0	0.0	0.0
20	K_{31}	1/3	1.10	0.756	1.0	0.6
20	K_{32}	1/3	-0.025	0.044	0.0	0.0
20	K_{31}	1/2	1.80	1.81	1.81	0.49
20	K_{32}	1/2	0.025	0.10	0.0	0.0
20	K_{32}	0	0.040	0.0	0.0	0.0

^aReference 172.^bReference 171.

Table 51. Loss coefficients for converging wye junctions

Pipe size (in.)	Configuration	G_1/G_2	Miller ^a	Idel'Chik ^b	Assumed	Adjusted
18	K_{13}	1/3	0.75	0.64	0.75	0.69
18	K_{23}	1/3	0.07	0.086	0.086	0.086
18	K_{13}	1/2	1.80	1.69	1.69	0.69
18	K_{23}	1/2	-0.20	-0.308	0.0	0.0
18	K_{23}	0	0.00	0.0	0.0	0.0
20	K_{13}	1/3	1.20	1.17	1.2	0.72
20	K_{23}	1/3	-0.02	-0.051	0.0	0.0
20	K_{13}	1/2	2.90	2.88	2.88	0.77
20	K_{23}	1/2	-0.40	-0.614	0.0	0.0
20	K_{23}	0	0.0	0.0	0.0	0.0

^aReference 172.^bReference 171.

ORNL-DWG 92-3227 ETD

Fig. 47. Loss coefficient configurations at wye junctions.

Some of the coefficients in Tables 50 and 51 are negative because momentum is transferred from one flow path to another; hence, flow along one of the paths actually experiences a head gain rather than a head loss at the wye. Flow along the other flow path, however, more than makes up for this by experiencing a head loss.

3.5.5 Check Valves and Block Valves

Loss coefficients for the isolation block valves at the inlet and outlet of each heat exchanger cell and that for the check valve immediately downstream of each main circulating pump (see Fig. 5) were taken from Crane¹⁷³ and Miller.¹⁷⁴ The loss coefficients are tabulated in Table 52.

Table 52. Loss coefficients for the block and check valves

Block valve	Crane ^a	Miller ^b	Used in model
Block valve	0.112	0.15	0.13
Check valve	0.65	0.5	0.65

^aReference 173.

^bReference 174.

3.5.6 Pressurizer Pump Discharge Line

The types of form losses in the 3-in. (7.62-cm) pressurizer pump discharge line are due to the fittings^{114,120-122} shown in Table 53. The equivalent L/d 's¹⁷⁵ and the K values, assuming a friction factor of 0.02, are also given. Here L is the equivalent length and d is the pipe diameter.

Table 53. Fittings in the pressurizer pump discharge line

Number of fittings	Type of fitting	L/d 's	K
15	90° elbows	450	9.0
3	45° elbows	36	0.72
5	Tees (flow through)	100	2.0
2	Swing check valves	270	5.4
1	Fully open globe valve	340	6.8
1	Half-open globe valve	340	6.8
1	Orifice flow meter	50	0.1

The pressure losses in the pressurizer pump discharge line become particularly important when the system has been depressurized and the pressurizer pump flow rate is high. The magnitude of these line losses then determines what the primary coolant system pressure will be and how quickly the PC head tank is emptied.

3.5.7 Pressurizer Pump Suction Line

If the suction pressure to the pressurizer pumps falls below 15.2 psia (0.107 MPa) and remains <16.7 psia for 5 s, then the pumps will be tripped to avoid cavitation. The losses in the 4-in. (10.2-cm) suction line, which extends 72.21 ft from the primary coolant (PC) head tank to the pumps, are important because they detract from the available suction head. Given the losses and the tank level, the maximum allowable pressurizer flow rate without

pump trip can be determined. A schematic with the associated measurements^{116,176-179} indicating the location of valves, bends, wyes, and tees is given in Fig. 48. The pressurizer pump suction pressure can be defined as

$$P_{suction} = P_{op} + \frac{\rho gh}{g_c} + \frac{\rho g \Delta z}{g_c} - \frac{\rho G^2}{2g_c A^2} \left(1 + \frac{fL}{d} \right),$$

ORNL-DWG 92-3228 ETD

Fig. 48. Schematic of pressurizer pump suction line.

where h is the height of water in the PC head tank, P_{op} is the overpressure in the primary coolant head tank, Δz is the elevation difference between the bottom of the PC head tank and the suction ports to the pressurizer pumps, L is effective pipe length including form losses, and G is the suction line flow rate. Solving the above equation for G gives

$$G = \sqrt{\frac{-g_c \frac{(P_{suction} - P_{op})}{\rho} + (h + \Delta z) g}{\frac{8}{\pi^2 d^4} \left(\frac{fL}{d} + 1 \right)}}.$$

The following values are assumed: the normal value for h (before pump trip on low PC head tank level) of 4.5 ft (0.508 m), the minimum allowable suction pressure of 15.2 psia (0.107 MPa), a density of 62 lb_m/ft³ (993 kg/m³), Δz of 15.52 ft (4.578 m), an inside diameter of 0.336 ft (0.102 m), and an overpressure in the head tank of 12.9 psia (0.0889 MPa).¹⁴⁸ Using loss coefficients from Ref. 175, the total loss coefficient through the 4-in. (10.16-cm) suction pipe is 9.6. Assuming a friction coefficient of 0.017, L/d is 637 ft. Substituting these values into the expression for G gives a maximum allowable pressurizer flow before pump trip of 0.7903 ft³/s (355 gal/min or 0.0224 m³/s).

3.6 TRIPS

Trips are set in the model to control the transient by starting and/or stopping various actions of system components. Table 54 lists the trip numbers and the purpose for each trip.

3.7 CONTROL VARIABLES

The control variables¹ are used in determining when and how events should happen during a transient; obtaining additional output from the run; and calculating pressures, flow rates, and valve positions to be supplied to certain preselected system components. Any dependent variable referenced by a control variable is in the SI units system, so when working in English units, conversion factors are included in the input. The control variables used in the HFIR model are described briefly in Table 55. The control variable types are explained in the RELAP5 documentation.¹⁸⁰

3.7.1 Primary Coolant Head Tank Level

Control variables (CVs) 1–7 are used to monitor the level in the primary coolant head tank. This is accomplished by summing the mass flows into the tank (CV 2) at each time step and integrating that sum to get the percentage of the tank volume occupied by water. The level indicator, which ranges from 0 to 6 ft, is 2 in. above the bottom of the tank. A logic diagram for this control system is shown in Fig. 49.

Table 54. Trips as defined in the RELAP5 system model of the HFIR primary coolant system

Trip No.	Trip is true if:
501	The current time is greater than or equal to the final time of the simulation.
503	Transient calculation is to begin (as opposed to establishing a new steady state).
505	Control variable 502 (pressurizer pump suction pressure) is low (less than control variable 692).
506	Control variable 500 (temperature of volume 80-01) is greater than control variable 674 (maximum allowable primary coolant temperature).
507	Control variable 206 (reactor temperature-trip indicator) is >0.5 .
508	Control variable 501 (pressure in volume 18-01, upper plenum) is less than control variable 675 (reactor trip pressure).
509	Control variable 204 (flux-to-flow ratio) is greater than control variable 676 (ratio at which reactor is tripped).
510	Control variable 208 (reactor trip indicator) is >0.5 .
511	Control variable 7 (PC head tank level) is less than control variable 677 (demineralizer flow trip level).
512	Control variable 7 (PC head tank level) is less than control variable 678 (pressurizer pump trip setpoint).
513	Control variable 502 (pressure in volume 47-01, pressurizer pump suction line) is less than control variable 679 (very low suction pressure). This trip is used by the control system for pressurizer pump trip.
514	Standby pressurizer pump trip on signal (currently disabled).
515	Control variable 503 (flow rate at junction 79-04, pressurizing flow) is less than control variable 681 (auxiliary pressurizer pump trip on setpoint).
516	Control variable 501 (pressure in volume 18-01, upper plenum) is less than control variable 682 (radiation block valve closure setpoint).
518	Control variable 505 (pressure in volume 48-01, main pressurizer pump discharge) is greater than control variable 684 (maximum pressure allowed before main pressurizer pump trips off).
519	Control variable 255 (EDS trip) is >0 .
521	Control variable 18 (duration in seconds of low suction pressure to pressurizer pumps) is ≥ 5 (if true, trip pressurizer pumps off).

Table 54 (continued)

Trip No.	Trip is true if:
525	The pressure in volume 60-03 (MCP suction) is <20 psia (disable structural elasticity control system).
526	Control variable 500 (temperature in volume 80-01) is less than control variable 685 (minimum allowable temperature before the emergency depressurization system trip).
528	Control variable 501 is less than control variable 686 (setpoint pressure for reset trip on EDS).
529	Time is greater than -1.0. This trip is always true.
530	Control variable 114 is <1 (MCP in cell D has cavitated).
531	Control variable 139 is <1 (MCP in cell C has cavitated).
532	Control variable 164 is <1 (MCP in cell A has cavitated).
533	Control variable 501 is less than control variable 683 (minimum allowable primary pressure before tripping MCPs).
536	Control variable 117 (v/α ratio for MCP in cell D) is >1.
537	Control variable 142 (v/α ratio for MCP in cell C) is >1.
538	Control variable 167 (v/α ratio for MCP in cell A) is >1.
551-599	These trips are used for transient definition.
600	Trip 501 is true (terminate the simulation).
602	Trip 515 and 503 are true (auxiliary pressurizer pump trip on).
603	Trip 526 is true and trip 528 is false (open EDS valves).
605	Trips 606 and 505 are true (low pressurizer pump suction pressure exists in conjunction with a previous very low pressure indication).
606	Trip 513 or 605 is true (pressurizer pump trip if this trip remains true for 5 s).
609	Trip 518 or trip 519 is true (signal to disengage pressurizer pumps based on EDS activation or high primary pressure).
610	Trip 609 or 553 is true (loss of ac power to pressurizer pumps).
611	Trip 555 or 610 is true (trip to check for pressurizer pump failure).
612	Trips 503 and 514 are true (trip to engage standby pressurizer pumps).
613	Trips 512 and 521 are false (trip pressurizer pumps because of low PC head tank level or low suction pressure).

Table 54 (continued)

Trip No.	Trip is true if:
614	Trip 613 is false or trip 611 is true (if true, begin using torque balance to determine the main pressurizer pump speed coastdown rate).
615	Trip 614 is false (stop using specified pump velocity table for the pressurizer pump).
622	Trip 579 is false and trip 516 is true (signal to close letdown block valves).
623	Trip 589 is false (auxiliary pressurizer pump is available) and trip 602 is true (trip auxiliary pressurizer pump on).
643	Trip 510 or 551 is true (initiate automatic scram).
644	Trips 571 and 518 are true (trip reactor at pressurizer pump trip for loss of instrument air case).
645	Trip 507 or 508 is true (temperature or pressure indicates a reactor trip should occur).
646	Trip 644 or 509 is true (reactor trip based on pressurizer pump trip initiator on loss of instrument air or FFR initiator).
647	Trip 646 or 645 is true (signal sent to initiate scram).
648	Trip 643 is true and trip 583 is false (scram initiated).
649	Trip 648 is true and trip 586 is false (trip off PU-6B).
650	Trip 649 is false (speed table trip on PU-6B).
651	Trip 649 or 568 is true (trip off PU-6A).
652	Trip 651 is false (speed table trip on PU-6A).
660	Trip 553 or 533 is true (trip MCPs).

3.7.2 Main Circulation Pumps

The main circulation pumps are controlled with trips 529–533, 536–538, and CVs 77–193. CVs 77–102 are used to calculate the actual pump speeds during or after coastdown (Fig. 50). CVs 74–76 and 103–180 are used to modulate the pump speed if the pumps are cavitating based on the Byron Jackson pump data (see Appendix B). This is accomplished by first calculating the degraded pump head based on data (Fig. 51) and then determining the degraded (modulated) pump speed (Fig. 52) corresponding to the degraded pump head. If a steady state is being established (trip 503 is false), then CVs 181–193 are used to control the pump speed so that the setpoint primary flow rate is reached. If a transient has begun, then the same set of control variables set the pump speed to (1) the latest steady-state value if the pump has not been tripped, (2) the actual speed of the pump during or after coastdown

Table 55. Control variables used in the model

No.	Type	Description
1	TRIPUNIT	Demineralized water flow rate into the PC head tank.
2	SUM	Net rate of mass change in the tank.
3	TRIPUNIT	On/off switch for adjustment of PC head level.
4	MULT	Product of variables 2 and 3.
5	INTEGRAL	Current percentage of tank volume occupied by water.
6	FUNCTION	Actual tank level based on variable 5.
7	SUM	Tank level indicated in control room.
8	TRIPUNIT	On/off switch for standby pressurizer pump.
9	TRIPDLAY	Most recent time standby pressurizer pump start-up signal was received.
10	SUM	Time elapsed since start-up signal was received.
11	MULT	Product of variables 8 and 10.
12	FUNCTION	Speed in rpm of the standby pressurizer pump.
15	TRIPDLAY	Most recent time low-pressurizer pump suction pressure was detected.
16	SUM	Time elapsed since low pressure was detected.
17	TRIPUNIT	On/off switch for low suction pressure.
18	MULT	Product of variables 16 and 17.
19	TRIPUNIT	Flag to disable/enable auxiliary pressurizer pump flow.
20	SUM	Auxiliary pressurizer pump head.
21	FUNCTION	Auxiliary pressurizer pump flow based on the existing pump head.
22	TRIPDLAY	Time that auxiliary pressurizer pump was tripped.
23	SUM	Time elapsed since auxiliary pressurizer pump was tripped.
24	FUNCTION	Start-up factor used to ramp the auxiliary pressurizer pump speed over a 5-s interval.
25	MULT	Adjusted auxiliary pressurizer pump speed; product of variables 21 and 24.
26	SUM	Current time step.
27	TRIPUNIT	Loss of instrument air flag (zero if loss of instrument air).
28	TRIPUNIT	Radiation block valve multiplier, set to zero if trip 622 is false.
29	TRIPDLAY	Last time trip 622 turned true.
30	SUM	Time elapsed since trip 622 last turned true.

Table 55 (continued)

No.	Type	Description
31	MULT	Product of CVs 28 and 30.
32	SUM	Letdown block valve factor to range from 0.0 to 1.0.
33	MULT	Product of CVs 27 and 32 (radiation block valve position).
34	SUM	LD control system error; system setpoint pressure less the current pressure at volume 79-01.
35	PROP-INT	Proportional/integral LD control signal.
36	DIFFREND	Derivative LD control signal.
37	SUM	PID control signal; sum of variables 37 and 38.
38	SUM	Unrestricted letdown control valve adjustment.
39	DIV	Letdown control valve stem speed.
40	MULT	Restricted letdown control valve adjustment.
41	SUM	New letdown control valve position.
42	MULT	Product of adjusted stem position and radiation block valve position.
43	MULT	Current problem time.
45	SUM	Gage pressure (psi) in volume 79-01.
46	POWERR	Exponential term of leakage correlation.
47	MULT	Product of CV 46 and density in 79-01 (mass flow leakage from system).
52	SUM	Secondary flow control system error; current 18-01 temperature less the setpoint temperature.
53	PROP-INT	Proportional/integral secondary control signal.
54	DIFFREND	Derivative secondary control signal.
55	SUM	PID control signal; sum of variables 53 and 54.
56	LAG	Time lag to actuate secondary flow control valve based on PID signal.
57	SUM	Adjusted secondary flow control valve position.
58	TRIPDLAY	Time that signal was received to start auxiliary secondary coolant pump.
59	SUM	Time elapsed since start signal for auxiliary secondary coolant pump was received.
60	FUNCTION	Factor used for accelerating the auxiliary secondary coolant pump.
61	TRIPUNIT	On/off switch for starting the auxiliary secondary coolant pump.
62	TRIPUNIT	On/off switch for using secondary motor winding on auxiliary secondary pump.

Table 55 (continued)

No.	Type	Description
63	SUM	Adjustment for speed of auxiliary secondary pump.
64	MULT	Auxiliary secondary coolant pump speed in rpm.
65	SUM	Requested valve position for heat exchanger bypass valve less flag for sudden valve closure.
66	LAG	Five-millisecond lag for closing heat exchanger bypass valve.
67	TRIPUNIT	Switch for sudden closure of FCV377.
68	TRIPDLAY	Last time trip 569 (closure of FCV377) turned true.
69	SUM	Time since trip 569 last turned true.
70	DIV	Factor for ramping FCV377 closed.
71	MULT	Adjustment for FCV377 valve position.
72	TRIPUNIT	Flag to indicate loss of instrument air.
73	SUM	Valve position for FCV377.
74	MULT	Velocity head (psi) at PU-1D suction volume.
75	MULT	Velocity head (psi) at PU-1C suction volume.
76	MULT	Velocity head (psi) at PU-1A suction volume.
77	TRIPUNIT	Flag-indicating MCPs have been tripped.
78	TRIPUNIT	Flag-indicating MCPs have not been tripped.
79	FUNCTION	Torque on PU-1D due to friction.
80	FUNCTION	Motor torque applied to PU-1D shaft.
81	MULT	Hydraulic power developed by PU-1D.
82	DIV	Hydraulic torque applied to PU-1D shaft.
83	SUM	Sum of PU-1D torques divided by the pump inertia.
84	MULT	Adjustment for rate of change of PU-1D pump speed.
85	INTEGRAL	Adjustment for PU-1D pump speed (rpm).
86	SUM	Actual speed of PU-1D.
87-94		Same as 79-86 except applied to PU-1C.
95-102		Same as 79-86 except applied to PU-1A.
103	SUM	Temperature in °C of volume 60-03.
104	SUM	Temperature in °F of volume 60-03.
105	FUNCTION	Saturation pressure at volume 60-03 based on properties in general Table 35.

Table 55 (continued)

No.	Type	Description
106	DIV	Flow rate in gal/min through pump PU-1D.
107	DIV	Nondimensional pump flow coefficient C_Q for PU-1D.
108	FUNCTION	Critical value of nondimensional pump NPSH coefficient C_{HS} for PU-1D.
109	MULT	Critical value of NPSH (ft) for PU-1D.
110	MULT	Critical value of NPSH (psi) for PU-1D.
111	MULT	Suction pressure (psia) to PU-1D.
112	SUM	Available NPSH to PU-1D (CV 111 + CV 74 - CV 105).
113	DIV	Ratio of available NPSH to critical NPSH.
114	FUNCTION	Head degradation factor (<1 , >0) for PU-1D.
115	MULT	Flow ratio for PU-1D (ν).
116	MULT	Speed ratio for PU-1D (α).
117	DIV	Quantity ν/α (see Sect. 3.3.3) for PU-1D.
118	DIV	Quantity α/ν (see Sect. 3.3.3) for PU-1D.
119	FUNCTION	Quantity HVN (see Sect. 3.3.3) for PU-1D.
120	TRIPUNIT	Flag to indicate if PU-1D is operating in the second portion (HVN) of the homologous data.
121	TRIPUNIT	Flag to indicate if PU-1D is operating in the first portion (HAN) of the homologous data.
122	MULT	Quantity HVN (see Sect. 3.3.3) for PU-1D after head degradation factor has been applied (if $\nu/\alpha < 1$).
123	MULT	Square of degraded pump speed (if $\nu/\alpha > 1$).
124	POWERR	Degraded pump speed (if $\nu/\alpha > 1$).
125	FUNCTION	Quantity α/ν (see Sect. 3.3.3) for PU-1D based on degraded pump head (CV 122).
126	MULT	Degraded pump speed (if $\nu/\alpha < 1$).
127	SUM	Degraded pump speed (less than actual pump speed only if pump is cavitating) for PU-1D.
128-152		Same as 103-127 except applied to PU-1C.
153-177		Same as 103-127 except applied to PU-1A.
178	LAG	Degraded pump speed for PU-1D after time lag has been applied.
179	LAG	Degraded pump speed for PU-1C after time lag has been applied.
180	LAG	Degraded pump speed for PU-1A after time lag has been applied.

Table 55 (continued)

No.	Type	Description
181	TRIPUNIT	Trip flag if the transient has not begun (establishing steady state).
182	SUM	Error in primary coolant flow.
183	MULT	Error used in adjusting MCP speed (nonzero only if establishing steady state).
184	PROPINT	Proportional/integral control of MCP speed (for steady state only).
185	DIFFREND	Differential control of MCP speed (for steady state only).
186	SUM	PID control signal for regulating MCP speed to reach a new steady-state value of primary flow.
187	MULT	Product of CVs 186 and 78 (nonzero only for steady state).
188	MULT	Product of CVs 178 and 77 (nonzero only for transient).
189	SUM	Sum of CVs 187 and 188 (speed used in table for PU-1D).
190	MULT	Product of CVs 179 and 77 (nonzero only for transient).
191	SUM	Sum of CVs 187 and 190 (speed used in table for PU-1C).
192	MULT	Product of CVs 180 and 77 (nonzero only for transient).
193	SUM	Sum of CVs 187 and 192 (speed used in table for PU-1A).
200	TRIPDLAY	Time since reactor trip was initiated.
201	FUNCTION	Flux ratio at current time.
202	DIV	Total flow in gallons per minute through reactor vessel measured at Venturi flowmeter.
203	MULT	Flow ratio at current time.
204	DIV	Flux-to-flow ratio.
205	TRIPUNIT	Flag for exceeding maximum primary coolant temperature.
206	DELAY	Time delay of 2 s for primary coolant temperature sensor to respond.
207	TRIPUNIT	Scram signal initiated if trip 647 is true.
208	DELAY	Delay scram by 0.05 s.
252	TRIPUNIT	Flag to indicate that the primary coolant temperature has fallen below the allowable limit.
253	TRIPUNIT	Flag to indicate loss of instrument air (EDS valves fail closed).
254	MULT	Flag to indicate signaled position of EDS valves.
255	DELAY	Time delay of 2 s for primary coolant temperature sensor to respond; trip indicator for emergency depressurization valves to open.
290	TRIPUNIT	Flag indicating that reactor has tripped.

Table 55 (continued)

No.	Type	Description
291	TRIPDLAY	Time that reactor trip occurred.
292	SUM	Time since reactor trip occurred.
293	MULT	Argument for function indicating cooling tower bypass valve stem position.
294	FUNCTION	Cooling tower bypass valve stem position.
295	SUM	One minus CV 294 used for control of cooling tower valve stem position.
300	SUM	Error in cooling tower outlet temperature.
301	MULT	Product of CV 181 and CV 300 (nonzero only for steady state).
302	PROP-INT	Proportional/integral control signal for maintaining cooling tower outlet temperature.
303	DIFFREND	Derivative control signal for maintaining cooling tower outlet temperature.
304	MULT	Product of CV 181 and CV 303 (nonzero only for steady state).
305	SUM	PID control signal for maintaining feedwater (cooling tower outlet) temperature.
319	SUM	Pressure drop across reactor check valve.
320	FUNCTION	Flow through reactor check valve based on pressure/flow characteristic of the valve.
321	LAG	Flow through reactor check valve after time lag has been applied.
372	DIFFREND	Time rate of change of pressure in volume 33-01.
373	MULT	Necessary volumetric injection/ejection to accommodate structural elasticity.
374	LAG	Adjusted injection/ejection mass flow for stability.
375	TRIPUNIT	Switch for elasticity system based on whether the MCP suction pressure (Volume 60-03) is <20 psia (trip 525).
376	MULT	Product of elasticity on/off switch (control variable 375) and calculated elasticity injection/ejection (control variable 374).
900	POWERR	Square root of the velocity through the outer fuel hot channel.
901	SUM	Subcooled margin at the exit of the outer fuel hot channel.
902	MULT	Costa flow excursion prediction (heat flux limit for hot channel).
903	DIV	Ratio of hot-spot heat flux to heat flux limit.
904	POWERR	Square root of velocity through the outer permanent beryllium reflector.
905	SUM	Subcooled margin at the exit of the outer permanent beryllium reflector.

Table 55 (continued)

No.	Type	Description
906	MULT	Costa flow excursion prediction for beryllium reflector.
907	DIV	Ratio of beryllium heat flux to heat flux limit.
909	DIV	Cooling tower flow rate (gal/min).
910	DIV	Cooling tower bypass flow rate (gal/min).
911	SUM	Total secondary flow (gal/min).
912	DIV	Secondary heat exchanger flow (gal/min).
913	DIV	Cooling tower heat removal flow rate (gal/min).
915	DIV	Total pressurizing flow (gal/min).
916	DIV	Reactor check valve flow (gal/min).
917	DIV	Flow out break number 1 (gal/min).
918	DIV	Flow out break number 2 (gal/min).
919	DIV	Flow out break number 3 (gal/min).
920	DIV	Flow out break number 4 (gal/min).
921	DIV	Flow out break number 5 (gal/min).
922	DIV	Flow out break number 6 (gal/min).
923	DIV	Structural elasticity model flow (gal/min).
924	DIV	Leakage model flow (gal/min).
925	SUM	Total letdown mass flow (kg/s).
926	DIV	Total letdown volumetric flow (gal/min).
930	SUM	$T_{sat} - T_{fuel}$ at outer fuel hot spot.
931	SUM	$T_{sat} - T_{fuel}$ at inner fuel hot spot.
994	SUM	PdT103 in psi.
995	SUM	PdT106 in psi.
996	SUM	Total heat transferred through heat exchanger in cell 110.
997	SUM	Total heat transferred through heat exchanger in cell 111.
998	SUM	Total heat transferred through heat exchanger in cell 113.
999	SUM	Total heat transferred through the three heat exchangers.

ORNL-DWG 92-3229 ETD

Fig. 49. Primary coolant head tank level control logic.

ORNL-DWG 92-3230 ETD

Fig. 50. Calculation of actual MCP speed during a pump coastdown.

Fig. 51. Calculation of L_{deg} degradation factor for MCP cavitation.

Fig. 52. Calculation of degraded pump speed for MCP cavitation.

as calculated by CVs 77–102, or (3) a modulated speed if pump cavitation is occurring (Fig. 53).

3.7.3 Main and Standby Pressurizer Pumps

CVs 8–12 are used to ramp up the standby pressurizer pump speed once the start-up signal has been received. CVs 15–18 are used to trip both the main and standby pressurizer pumps based on low suction pressure. This occurs if the flow rate gets so high that the static suction pressure falls below 15.2 psia (see Sect. 3.5.7) and remains below 16.7 psia for at least 5 s (Ref. 181). Pressurizer pumps also trip if the head tank level drops below 25%. A logic diagram for this control system is shown in Fig. 54.

3.7.4 Auxiliary Pressurizer Pump

CVs 19–25 are used to specify the auxiliary pressurizer pump flow rate based on its head/flow curve (see Sect. 3.3.5). Five seconds are assumed for the pump reaching full speed. The logic diagram is shown in Fig. 55.

3.7.5 Letdown Control and Radiation Block Valves

CVs 26–43 are used to control the operating pressure in the system. The stem position of the letdown valves is adjusted using PID control action to maintain pressure in volume 79–01 to the setpoint pressure (CV 670). The stem position is not allowed to change faster than the measured opening and closing valve speeds (Sect. 3.3.6). Also the valve is closed if the condition for radiation block valve closure is met. The logic diagram is shown in Fig. 56.

3.7.6 Secondary Coolant Flow

CVs 52–57 are used to control the secondary coolant flow rate. A PID controller is modeled for control of the normalized flow area of the secondary coolant 10-in. bypass valve (FCV 377A). The control logic diagram is shown in Fig. 57. Manual control of the FCV 377 flow area is accomplished using CVs 67–73.

3.7.7 Secondary Coolant Pumps

The main and auxiliary secondary coolant pump control logic is diagrammed in Fig. 58. The main pumps, which use trips and no CVs, are tripped whenever a reactor scram occurs or if the coupling between the motor and pump fails. Control variables 58–64 are used to linearly ramp the auxiliary pump speed starting at zero speed just after the reactor trip and ending at 1200 rpm (or 600 rpm if ac power is lost) 5 s after the reactor trip.

3.7.8 Reactor Trip

An automatic reactor trip will occur when the temperature of water entering the vessel exceeds a setpoint (nominally 130°F), when the primary pressure falls below a setpoint (nominally 370.7 psia), or when the flux-to-flow ratio exceeds a setpoint (nominally 1.25). Control variables 200–208 are used to monitor whether these setpoints have been exceeded

Fig. 53. Main circulation pump control logic.

ORNL-DWG 92-3236 ETD

Fig. 56. Letdown and radiation block valve control logic.

Fig. 57. Secondary coolant flow control logic.

Fig. 58. Secondary coolant pump control logic.

and, if so, to initiate a reactor trip. To account for instrument uncertainties, the pressure trip value was set at 370.7 psia (382.7–12 psia), and the flux-flow ratio was set at 1.2875 (1.25×1.03). A 2-s time delay is applied to the initiation of a reactor trip based on high primary temperature to include the time for the temperature sensor to respond to actual conditions. The pressure sensors are assumed to respond immediately. The control logic diagram is shown in Fig. 59.

3.7.9 Structural Elasticity

To represent the structural elasticity, CVs 372–376 are used to either inject or eject mass from the system based on whether the system pressure is decreasing or increasing. No adjustment is made if the elasticity control is disabled (trip 525). Also a time lag is introduced to keep the system stable. The logic diagram is shown in Fig. 60.

3.7.10 Emergency Depressurization

If the primary coolant temperature drops below 90°F, then the emergency depressurization system (EDS) is activated (trip 526). The EDS valves, which open when the system is activated, reclose if the primary pressure falls below 314.7 psia (2.17 MPa). The CVs 252–255 are used to control the EDS valves. The temperature sensor is assumed to lag the primary coolant temperature by 2 s. This is represented with a 2-s delay (CV 255) in the EDS control system. The value of CV 255 indicates the stem position of the EDS control valves (component 141), which are modeled as either fully open or fully closed. As presently installed in the model, the EDS system is based on preliminary design information. For transients where its performance is important, the analyst will have to enhance the model.

3.7.11 Cooling Tower Bypass

After the main secondary coolant pumps are tripped, the cooling tower bypass valve is opened to prevent overcooling the primary system. CVs 290–295 are used to represent this action. General Table 38 is used to determine the stem position of the cooling tower bypass valve.

3.7.12 Leakage from the Primary Coolant System

Control variables 43–45 are used to calculate the appropriate leakage rate from the primary coolant system. CV 45 is used by time-dependent junction 84 to drain flow from volume 79. Volume 79 was selected because it is a convenient location on the discharge side of all three pumps (where the actual leakage occurs). This is conservative for all transients except overpressurization transients, where the leakage should either be disabled or attached to the hot leg (pump suction side). W. E. Thomas assembled the following correlation (unpublished) based on some data taken by M. B. Farrar on September 9, 1986, for the leakage rate from the primary system:

$$G = 0.0784 P^{0.4416},$$

where G is the flow rate in gal/min and P is the system gage pressure (psig). Using the system stiffness of 22 psi/gal, this correlation gives a depressurization rate of 26 psi/min at

ORNL-DWG 92-3239 ETD

Fig. 59. Reactor trip control logic.

3.7.13 Cooling Tower Heat Removal

Although in actuality the secondary heat is lost to the outside environment through a fan-controlled cooling tower, in the model, the secondary heat loss occurs through a heat structure to a cold stream of water by forced convection. The flow rate of this stream is controlled using CVs 300–305 so that the temperature of the secondary coolant is 85°F leaving the cooling tower. This control is accomplished using PID control action as discussed in Sect. 3.3.6.

3.7.14 Reactor Vessel Check Valve Flow

CVs 319–321 are used to specify the flow through the reactor check valve, which is a function of the pressure difference between volume 21–05 and the vessel pool. A tabular function is input as a general table that gives the pressure-drop/flow relationship for the valve. Instead of forcing the flow through the valve to instantaneously adjust to the value from the tabular function, a time lag is introduced to avoid "fluttering." Fluttering occurs when the valve opens and closes alternately on each successive time step.

3.7.15 Additional Output

CVs 900–904 are used to predict flow excursion (using a correlation developed by Costa)¹⁸² in the inner fuel hot channel. Secondary flow rates are monitored in units of gallons per minute with CVs 909–913. Primary inventory gains and losses are monitored in units of gallons per minute with CVs 915–926. Margins to boiling (°F) are monitored at the two hot spots (one for each of the fuel elements) with CVs 930–931. The pressure drop across the strainer is calculated with CV 994. The pressure drop in the primary coolant across the reactor vessel, including the strainer pressure drop, is calculated with CV 995. The primary coolant heat losses in the heat exchangers are calculated with CVs 996–999.

4. PREPROCESSING AND POSTPROCESSING

Two FORTRAN programs were written to aid setting up RELAP5 input and post-processing RELAP5 results. The first program, a preprocessor, initializes the input with temperatures, pressures, and mass flows at the initial time. The user may opt to initialize the input at uniform temperature and pressure and zero mass flows; or the temperatures, pressures, and flows from a previous major edit in a normal RELAP5 output file may be read and automatically loaded into the input. The second option allows the user to initialize input at steady state, with the pumps at full speed and reactor at full power. The program does not initialize time-dependent volumes, time-dependent junctions, time-dependent tables, or trips; so it may be necessary for the user to initialize some of these components manually. This program is also useful for converting between MOD2 and MOD3 versions of the input. A listing of this preprocessor and user instructions are given in Appendix C.

The second program, a postprocessor, was written to translate information from a strip file into TECPLOT¹⁸³ readable format. A strip file is the formatted output of selected dependent variables, as a function of time, throughout the entire simulation. RELAP5 always writes this information in the SI units system to the restart/plot file. A strip data file is created on a subsequent RELAP5 run using the "strip" option on card 100.

5. MODEL APPLICATION

The intended use for the detailed model described in this report (input listing shown in Appendix A) is for analysis of SBLOCA transients in the HFIR primary coolant system.¹⁸⁴ By definition, a small break is one that does not result in fuel damage. Additional modeling capability has been included beyond the bare minimum necessary to simulate SBLOCA transients, and other applications of the model, especially the abbreviated version described in Appendix E (and listed in Appendix F), are expected. Already, the model has been used to perform unheated LBLOCA analysis for the purpose of benchmarking the MELCOR severe accident model of the HFIR.¹⁸⁵

When applying this model, either in the detailed or abbreviated form, to any transient other than a SBLOCA, it is very important to consider the adequacy of its capabilities regarding that application. It is likely that additional modeling capability will be necessary to produce meaningful simulations of these transients. For example, very simple representations for the EDS system, secondary coolant system, and low-pressure clean-up system are included in the model. In all probability, simulation of transients during which the performance of one of these systems is critical to the results will require modification of the baseline model.

In this section, the steady-state performance of the model at nominal conditions is described and compared with available plant data. In addition, computational performance statistics are supplied. The input listing in Appendix A has been initialized at pre-LOCA conditions, that is, those conditions that are considered conservative (e.g., low pressure and high temperature) for a LOCA transient.

5.1 STEADY STATE

The steady-state pressures as calculated by RELAP5/MOD2.5 (RELAP5/MOD3 yields almost identical results) for 85-MW operation are shown in Fig. 61 at the nominal primary flow rate of 16,500 gal/min. The calculated primary coolant flow rate using the actual pump speed is 15,850 gal/min. The calculated value for PdT106 (difference in pressure between volumes 80-03 and 51) at 15,850 gal/min is 142 psi. Some checksheet data²⁶ are listed in Table 56 and plotted in Fig. 62.

Some uncertainty in the flow rate data may exist because of the placement of the pressure tap in the cold leg. The tap is located in the diffusing portion of the Venturi flowmeter, where a complex flow pattern is likely.

As the resistance to flow through the vessel increases (due to a particular fuel element having slightly smaller flow area or corrosion), it is expected that the pressure drop across the core would increase and the flow through the vessel would decrease, assuming the pump performance and hot and cold leg piping remains unchanged. The calculated steady state does not lie within the spread of the data; however, it is only 4% less than the nominal flow of 16,500 gal/min. Table 56 shows some data taken from HFIR checksheets.

Some experimentation with the model was done to determine possible reasons for the discrepancy between the calculation and the data. At the time this testing was done, the predicted primary coolant flow rate was 16,124 gal/min, which is lower than the current estimate of 16,171 gal/min. The following reasons were suggested for the discrepancy between the calculated values for total flow rate and vessel pressure drop (PdT106) and those values recorded in the hourly checksheets:

ORNL-DWG 92-3241 ETD

Pressures in RELAP5 model at nominal conditions.

Core Inlet Pressure = 482.7

Total Venturi Flow = 16,500 gpm

Fig. 61. Pressures at steady state in RELAP5 model.

Table 56. HFIR hourly checksheet
data for vessel pressure
drop (PdT106)

Date	Flow rate (gal/min)	Pressure drop (psi)
09-01-69	16,490	138
09-01-69	16,605	138
12-03-73	17,238	136
04-15-75	17,195	136
04-01-78	17,205	141
09-15-79	17,064	140
09-24-79	17,030	140
07-03-81	16,900	135
07-26-81	16,950	135
11-11-82	17,074	134
11-24-82	17,010	135
11-29-82	17,100	134
05-08-83	17,292	135
05-20-83	17,240	134
07-01-83	17,305	132
09-12-84	17,000	133
09-23-84	16,767	133
03-01-85	16,999	135
03-18-85	17,011	135
09-06-85	17,037	132
09-18-85	16,989	131
11-01-86	17,003	126
11-03-86	17,015	126

1. The primary coolant pumps actually run at a speed higher than 1800 rpm (used in the model).
2. The pump performance curves, which were based on data taken for only one of the pumps, are not representative for all of the pumps.
3. The friction pressure drop on the pump side of PdT106 is being overestimated because either the surface roughness of 1.5×10^{-4} ft or the form loss coefficients at the junctions are too great.

No data were found for any of the main circulating pumps except the pump with factory No. 37172, impeller R-3341. However, it was found that increasing the pump speed by 50 rpm (to 1850 rpm), the vessel flow increased from 16,124 to 16,600 gal/min and the vessel pressure drop increased from 128.4 to 136.1 psi. When all of the form loss coefficients on the pump side of PdT106 were set to zero, the values changed to 16,810 gal/min and

Fig. 62. Measurements recorded for PdT106 from HFIR hourly readings.

139.6 psi. When a smooth pipe assumption was made (roughness of 10^{-6} ft), the vessel flow increased only slightly, to 16,200 gal/min.

Because changing the form loss coefficients enough to make the calculated results consistent with the data cannot be justified, and smoothing the pipes did not significantly improve the match, it was assumed that inaccuracy in the pump model was the primary cause of the discrepancy. It is not likely that the pump motors have consistently been running at 1850 rpm rather than 1800 rpm for 20 years, so the discrepancy is probably due to the inappropriateness of the characteristic pump curve to describe all four primary coolant pumps. If the Venturi is consistently indicating a flow rate higher than the true value, this could also explain the discrepancy.

Before the model is used for a specific transient, it is necessary to establish the appropriate steady-state operating condition. This is accomplished by controlling the pump speed until the setpoint for primary coolant flow is reached (see Sect. 3.7.2).

5.2 COSTS AND RUN TIMES

A material Courant limit is applied to each hydrodynamic volume in the system to keep the solution stable. This limit is 0.00323 to 0.00328 s (depending on the selected flow rate) for the detailed RELAP5 model during normal steady-state operation. The limiting volume in the system is 1-07, which is the most downstream volume in one of the average channels of the inner fuel. The limit outside of the vessel is a factor of 5 higher. The model currently runs at a time step of 0.003125 s at 85-MW steady conditions. Although the input shows a requested time step of 0.1 s, RELAP5 halves this value until a satisfactory time step has been

reached. To run one simulated second of real time during which the HFIR is running steadily at 85 MW, the model requires 175 s of cpu time on the IBM RS6000/Model 320 (AIX version 3.2, XLF version 2.1) using RELAP5/MOD2.5 version 3T.

During LOCAs for which the system depressurizes and the main circulating pumps are tripped, the Courant limit is relaxed because the coolant velocity decreases significantly. Unless voiding occurs in the coolant, or noncondensable air enters the system, these simulations run much more quickly because of the larger stability limit.

REFERENCES

1. V. H. Ransom et al., *RELAP5/MOD2 Code Manual, Volume 1: Code Structure, Systems, Models, and Solution Methods*, August 1985, and *Volume 2: Users Guide and Input Requirements*, NUREG/CR-4312 (EGG-2396), EG&G Idaho, Inc., December 1985.
2. *TRAC PF1/MOD1: An Advanced Best-Estimate Computer Program for Pressurized Water Reactor Thermal-Hydraulic Analysis*, NUREG/CR-3858, Safety Code Development Group, Los Alamos Natl. Lab., July 1986.
3. M. J. Thurgood et al., *COBRA/TRAC—A Thermal-Hydraulics Code for Transient Analysis of Nuclear Reactor Vessels and Primary Coolant Systems, Equations and Constitutive Models*, Vol. 1, NUREG/CR-3046 (PNL-4395), Pacific Northwest Laboratories, March 1983.
4. J. H. McFadden, R. E. Narum, and C. E. Peterson, *RETRAN-02—A Program for Transient Thermal-Hydraulic Analysis of Complex Fluid Flow Systems, Volume 1: Theory and Numerics* (Rev. 2), EPRI-NP-1850, Electric Power Research Institute, November 1984.
5. A. E. Ruggles, Oak Ridge National Laboratory, letters to C. D. Fletcher, Idaho National Engineering Laboratory, "Review of RELAP5/MOD2 Two-Phase Thermal-Hydraulic Models and Identification of Changes Needed for Applicability to Plate Fueled Reactor Cores," January 27, 1989, and March 3, 1989.
6. A. E. Ruggles and D. G. Morris, "Thermal-Hydraulic Simulation of Natural Convection Decay Heat Removal in the High Flux Isotope Reactor Using RELAP5 and TEMPEST, Part 2: Interpretation and Validation of Results," pp. 3-39-3-45 in *Proceedings of the First International RELAP5 User Seminar*, College Station, Texas, January 31-February 2, 1989, CONF-890173.
7. A. E. Ruggles and P. T. Williams, "RELAP5/MOD2 Benchmarking Study: Critical Heat Flux Under Low Flow Conditions," p. 204 in *Trans. of ANS 1990 Annual Meeting*, June 10-14, 1990.
8. H. A. Glovier, Oak Ridge National Laboratory, letter to H. Randall Fair, Department of Energy, "High Flux Isotope Reactor (HFIR) Key Milestone, Complete Thermal Hydraulic Analysis (HFIRMS-010), Action Step 11, Final Verification and Validation (V&V) Report," February 3, 1992.
9. J. D. Freels, Oak Ridge National Laboratory, letter to D. H. Cook et al., Oak Ridge National Laboratory, "Review Comments and Changes for the HFIR RELAP5 Point Kinetics Input Deck," January 20, 1992.
10. D. G. Morris et al., "Thermal-Hydraulic Simulation of Natural Convection Decay Heat Removal in the High Flux Isotope Reactor Using RELAP5 and TEMPEST, Part 1: Models and Simulation Results," pp. 3-32-3-38 in *Proceedings of the First International*

RELAP5 User Seminar, College Station, Texas, January 31–February 2, 1989, CONF-890173.

11. D. S. Trent, L. L. Eyler, and M. J. Budden, *A Computer Program for Three-Dimensional Time-Dependent Hydrothermal Analysis*, PNL-4348, Vol. 1, Rev. 3, Pacific Northwest Laboratories, April 1991.
12. H. A. McLain, *HFIR Fuel Element Steady State Heat Transfer Analysis*, ORNL/TM-1904, revised version, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., December 1967.
13. R. P. Taleyarkhan, Oak Ridge National Laboratory, letter to D. G. Morris, Oak Ridge National Laboratory, "Transmittal of Core Boundary Conditions for RELAP5 Evaluations," January 9, 1989.
14. P. T. Williams and D. G. Morris, Martin Marietta Energy Systems, Inc., letter to R. P. Taleyarkhan, Oak Ridge National Laboratory, "MELCOR/RELAP5 HFIR Core LBLOCA Study," July 12, 1989.
15. R. M. Summers et. al., *MELCOR 1.8.0: A Computer Code for Nuclear Reactor Severe Accident Source Term and Risk Assessment Analyses*, NUREG/CR-5531 (SAND90-0364, R3), Sandia Natl. Lab., January 1991.
16. R. H. Morris, "HFIR MELCOR Simulation for a Large Break LOCA in the Pipe Tunnel," HFIR Calculation C-HFIR-91-029, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., December 1991.
17. T. L. Wilson, *HFIR Systems Transient Model*, ORNL/RRD/INT-25, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., October 30, 1987.
18. *Modular Modeling System (MMS): A Code for the Dynamic Simulation of Fossil and Nuclear Power Plants*, Volumes 1–4, CS/NP-3016-CCM, Electric Power Research Institute, March 1983.
19. *The High Flux Isotope Reactor—A Functional Description*, Vol. 1A, Text, F. T. Binford, T. E. Cole, and E. N. Cramer, ed., May 1968, and Vol. 1B, Illustrations, F. T. Binford and E. N. Cramer, ed., ORNL-3572 (Rev. 2), Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., June 1968.
20. HFIR Staff, *Operating Manual for the High Flux Isotope Reactor*, ORNL/TM-1138/R1, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., September 1982.
21. Ref. 19, Vol. 1A, p. 6–14.
22. W. E. Sallee, Oak Ridge National Laboratory, letter to S. E. Burnette, Oak Ridge National Laboratory, "Engineering Report: Acceptance Test Results for Pony Motor Battery Systems PU-1E, PU-1F, PU-1G, and PU-1H, and Test Evaluations and Comments," February 7, 1990.

23. C. A. Sweet, *HFIR Design Data—No. 1*, Oak Ridge Natl. Lab. internal report, August 7, 1970.
24. B. H. Montgomery, K. R. Thoms, and C. D. West, "Appendix A: HFIR Model-E Removable Reflector Hydraulics," *Final Report of the HFIR Irradiation Facilities Improvement Project*, ORNL/TM-10505, pp. 149–167, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., September 1987.
25. *Summary of HFIR Design Parameters for 85 MW Operation*, ORNL/RRD/INT-55, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., March 1989.
26. HFIR Hourly Readings, Nov. 2, 1986, April 1, 1978, and Sept. 1, 1969.
27. D. G. Morris, Oak Ridge National Laboratory, letter to B. L. Lepard, Oak Ridge National Laboratory, "HFIR Vessel/Core RELAP5 Model Input Calculation Notes," February 28, 1992.
28. T. Sofu, University of Tennessee, letter to B. L. Lepard, Oak Ridge National Laboratory, "HFIR Safety System Response Time as Calculated in REACC," February 19, 1992.
29. Research Reactors Division Staff, *High Flux Isotope Reactor Technical Specifications*, ORNL/TM-5711/R2, pp. 3–5, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., rev. September 1990.
30. R. E. Hale, "Validation and Verification Report HFIR Time-of-Flight Measurement System," Research Reactors Division, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., to be published.
31. Ref. 12, pp. 77 and 81.
32. Eng. Dwg. D-42113, Rev. E, ORNL HFIR.
33. Eng. Dwg. D-42121, Rev. F, ORNL HFIR.
34. Ref. 23, pp. 94–121.
35. Ref. 12, pp. 21–23.
36. G. A. Bowden and R. W. Knight, *Specifications for High Flux Isotope Reactor Fuel Elements HFIR-FE-3*, ORNL/TM-9220, p. 10, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., August 1984.
37. *Metals Handbook, Vol. 1, Properties and Selection of Metals*, 8th ed., American Society for Metals, 1961, p. 936.
38. *Thermophysical Properties of High Temperature Solid Materials*, Y. S. Touloukian, ed., Purdue University, West Lafayette, Ind., 1967, Vol. 1, pp. 11–12.

39. Ref. 38, Vol. 4, pp. 499-500.
40. D. L. McElroy, Oak Ridge National Laboratory, letter to R. W. Knight, Oak Ridge National Laboratory, "Physical Properties of Al Cermets," January 5, 1970.
41. R. W. Knight, J. Binns, and G. M. Adamson, Jr., *Fabrication Procedures for Manufacturing High Flux Isotope Reactor Fuel Elements*, ORNL-4242, pp. 9-13, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., June 19, 1968.
42. N. Hilvety and T. G. Chapman, *HFIR Fuel Element Steady State Heat Transfer Analysis*, ORNL-TM-1903, p. 38, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., December 1967.
43. *Aerospace Structural Metals Handbook*, Vol. 3, AFML-TR-68-115, Mechanical Properties Data Center, Belfour Stulen, Inc., 1975, code 3206, p. 1.
44. J. C. Griess et al., *Effect of Heat Flux on the Corrosion of Aluminum by Water, Part III, Final Report on Tests Relative to the High Flux Isotope Reactor*, ORNL-3230, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., December 5, 1961.
45. Ref. 38, Vol. 4, pp. 8-10.
46. *Recommended Values of the Thermophysical Properties of Eight Alloys, Major Constituents and Their Oxides*, Y. S. Touloukian, ed., Purdue University, West Lafayette, Ind., February 1966, pp. 326-328.
47. Y. S. Touloukian et al., *Thermophysical Properties of Matter*, IFT/Plenum, Vol. 1, p. 9, 1970.
48. R. E. Pawel, Oak Ridge National Laboratory, personal communication to D. G. Morris, Oak Ridge National Laboratory, May 1989.
49. J. C. Griess et al., *Effect of Heat Flux on the Corrosion of Aluminum by Water, Part 1: Experimental Equipment and Preliminary Test Results*, ORNL-2939, p. 25, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., April 29, 1960.
50. Ref. 12, p. 62.
51. Ref. 12, pp. 72-73.
52. Ref. 12, p. 57.
53. W. E. Thomas, Oak Ridge National Laboratory, letter to R. D. Cheverton, Oak Ridge National Laboratory, "Reevaluation of Uncertainty Factor U_3 Based on Actual Scram Setpoint," June 7, 1989.
54. Ref. 12, p. 16.
55. Eng. Dwgs. D-42114 and D42122, ORNL HFIR.

56. Ref. 12, pp. 17-18.
57. Ref. 12, p. 64.
58. J. R. Kirkpatrick, Oak Ridge K-25 Site, letter to D. G. Morris, Oak Ridge National Laboratory, "HFIR Hot Side Peaking Factors as Functions of Meat Thickness and Film Coefficient," June 9, 1992.
59. Ref. 12, p. 63.
60. W. E. Thomas, Oak Ridge National Laboratory, personal communication to D. G. Morris, Oak Ridge National Laboratory, April 1988.
61. J. D. Sease, *The Fabrication of Target Elements for the High-Flux Isotope Reactor*, ORNL/TM-1712, Appendix A, pp. 29-31, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., March 1967.
62. Ref. 19, Vol. 1A, pp. 5-2-5-3.
63. T. G. Chapman, *HFIR Target Design Study*, ORNL/TM-1084, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., Sept. 3, 1965.
64. J. E. Bigelow, Oak Ridge National Laboratory, personal communication to D. G. Morris, Oak Ridge National Laboratory, May 1989.
65. C. W. Alexander, Oak Ridge National Laboratory, personal communication to D. G. Morris, Oak Ridge National Laboratory, December 1987.
66. R. E. Hale, Oak Ridge National Laboratory, letter to B. L. Lepard, Oak Ridge National Laboratory, "Specific Heat of $\text{CmO}_{1.73}$," April 7, 1991.
67. R. L. Gibby, C. E. McNeilly, and T. D. Chikalla, "The Thermal Diffusivity, Thermal Conductivity, and Transformation Temperatures of Curium Sesquioxide," *J. Nucl. Mat.*, 34, 299-306 (1970).
68. R. K. Williams and R. S. Graves, Oak Ridge National Laboratory, letter to G. L. Copeland, Oak Ridge National Laboratory, "Thermal Conductivity Measurements on 6061 Al Clad, U_3O_8 -Al Fuel Plates," January 14, 1980.
69. Ref. 63, p. 10.
70. H. French and W. M. Rohsenow, "Prediction of Thermal Conductance of Metallic Surfaces in Contact," *J. Heat Transfer*, 15-24 (February 1963).
71. N. D. Weills and E. A. Ryder, "Thermal Resistance Measurements of Joints Formed Between Stationary Metal Surfaces," *Trans. ASME* 71, 259-267 (1949).

72. A. L. Lotts et al., *Analysis of Failure of HFIR Target Elements Irradiated in SRL and in HFIR—An Interim Status Report*, ORNL/TM-2236, p. 35, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., February 1972.
73. M. W. Wendel, Oak Ridge K-25 Site, letter to D. G. Morris, Oak Ridge National Laboratory, "Calculation of Effective Gap Thermal Conductivity with RELAP5," June 5, 1991.
74. B. V. Karlekar and R. M. Desmond, *Engineering Heat Transfer*, West Publishing Company, 1977, pp. 547–576.
75. Ref. 63, p. 6.
76. A. Higdon et al., *Mechanics of Materials*, 3rd ed., John Wiley and Sons, New York, 1976, pp. 157–166.
77. *Woldman's Engineering Alloys*, 6th ed., R. C. Gibbons, ed., American Society for Metals, 1979, p. 1767.
78. Ref. 47, Vol. 1, curve 4, pp. 905–907.
79. Ref. 47, Vol. 4, curve 8, pp. 102–109.
80. Ref. 47, Vol. 4, curves 3 and 10, pp. 146–152.
81. R. D. Cheverton and T. M. Sims, *HFIR Core Nuclear Design*, ORNL-4621, pp. 22–28, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., July 1971.
82. Ref. 23, pp. 76–93.
83. G. A. Bowden, G. R. Hicks, and R. W. Knight, *Fabrication Procedures for HFIR Control Plates*, ORNL/TM-9365, p. 11, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., October 1984.
84. Ref. 38, Vol. 4, pp. 170–171.
85. Ref. 23, Vol. 1, pp. 7–75.
86. Ref. 38, Vol. 1, pp. 48–49.
87. Ref. 47, Vol. 4, curve 9, pp. 16–20.
88. Ref. 47, Vol. 1, p. 24.
89. Ref. 74, pp. 415–462.
90. C. A. Meyer et al., *ASME Steam Tables*, 4th ed., American Society of Mechanical Engineers, 1979.

91. Ref. 19, Vol. IB, p. 55.
92. Eng. Dwg. M-11506-OH-507, ORNL HFIR.
93. Eng. Dwg. E-42328, ORNL HFIR.
94. F. M. White, *Fluid Mechanics*, McGraw-Hill Book Company, New York, 1979, p. 332.
95. Ref. 23, p. 124.
96. Eng. Dwg. D-49852, ORNL HFIR.
97. Vendor Dwg., William Powell Co., C51089, ORNL HFIR.
98. Ref. 21, pp. 122–123.
99. Ref. 20, pp. 2–25.
100. Ref. 19, Vol. 1A, pp. B-1–B-2.
101. Ref. 19, Vol. 1B, p. 69.
102. Ref. 37, pp. 264 and 586.
103. Ref. 47, Vol. 4, curve 5, pp. 619–622.
104. Ref. 47, Vol. 1, curve 139, pp. 1113–1123.
105. Ref. 38, Vol. 3, pp. 145–146.
106. Ref. 38, Vol. 3, pp. 161–163.
107. Ref. 47, Vol. 1, curve A, pp. 1174–1175.
108. Ref. 47, Vol. 1, curve B, pp. 1174–1175.
109. Eng. Dwg. E-42350, Rev. 1, ORNL HFIR.
110. M. M. El-Wakil, *Nuclear Heat Transport*, Intext Educational Publishers, New York, 1971, pp. 347–351.
111. Ref. 19, Vol. 1A, p. 5-5.
112. Eng. Dwg. E-42359, Rev. C, ORNL HFIR.
113. M. W. Wendel, Research Reactors Division Calculation, C-HFIR-91-006 (HFIR RELAP5 extra-vessel input calculation papers), Martin Marietta Energy Systems, Inc., Oak Ridge K-25 Site, 1990.

114. Eng. Dwg. 1546-01-M5506, ORNL HFIR.
115. Eng. Dwg. 1546-01-M5507, ORNL HFIR.
116. Eng. Dwg. 1546-01-M5515, ORNL HFIR.
117. Southwest Fabrication and Welding Co. Dwg. S.O. 9614, Isometric 1, ORNL HFIR.
118. Southwest Fabrication and Welding Co. Dwg. S.O. 9614, Isometric 2, ORNL HFIR.
119. T. Baumeister and L. S. Marks, *Standard Handbook for Mechanical Engineers*, McGraw-Hill Book Company, New York, 7th ed., 1958, pp. 8-202.
120. Eng. Dwg. 1546-01-5509, ORNL HFIR.
121. Eng. Dwg. E-49866, ORNL HFIR.
122. Eng. Dwg. 1546-01-5512, ORNL HFIR.
123. S. W. Churchill and H. H. S. Chu, "Correlating Equations for Laminar and Turbulent Free Convection from a Horizontal Cylinder," *Int. J. Heat Mass Transfer* 18, 1049-1053 (1975).
124. F. Kreith, *Principles of Heat Transfer*, Intext Educational Publishers, New York, 3rd ed., 1973, pp. 395-396.
125. Eng. Dwg. 1546-M-5508, ORNL HFIR.
126. ACME Copper Smithing and Machine Company, Dwg. 5942, ORNL HFIR.
127. *Design Report on High Flux Isotope Reactor Primary Heat Exchangers*, TM Report 743, Joseph Oat Corporation, June 1985.
128. F. W. Dittus and L. M. K. Boelter, "Heat Transfer in Automobile Radiators of the Tubular Type," University of California Publications, Vol. 2, 1930, pp. 443-461.
129. Ref. 124, p. 481.
130. D. M. McGinty, "Hydraulic Vibration Analysis and Thermal Performance Tests of New Primary Heat Exchanger," Oak Ridge National Laboratory Equipment Maintenance Standards, Reactor Operations Section, High Flux Isotope Reactor, Standard No. 3070, May 1985.
131. Internal correspondence to M. W. Wendel, Oak Ridge K-25 Site, from B. L. Lepard, Jr., Oak Ridge National Laboratory, "High Flux Isotope Reactor Secondary Heat Exchanger Flow Rate and Pressure Drop," May 30, 1991.

132. Intra-Laboratory Correspondence to T. E. Cole, Oak Ridge National Laboratory, from H. A. McLain, Oak Ridge National Laboratory, *Revised Flow Coast-down Times in the HFIR Primary Coolant System Following an Electrical Failure of All Three Pumps Neglecting the Effects of the Pony Motor*, September 25, 1962.
133. *Report of Test from the Byron Jackson Hydraulic Test Facilities*, Byron Jackson Order No. 371720, January 1963.
134. Ideal Electric Co. test data supplied to HFIR with pony motors.
135. Eng. Dwg. SK-GJJ-880830-4, ORNL HFIR.
136. *Allis-Chalmers Instruction Book*, Allis Chalmers Order No. 1-0832-80435, March 14, 1963.
137. T. D. Radcliff and B. L. Lepard, Jr., *Description of Reactor Transients to be Analyzed for the Completion of the Accident Analyses in Chapter 15 of the High Flux Isotope Reactor Safety Analysis Report (SAR)*, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., 1991.
138. Ref. 20, pp. 3-112.
139. A. Sozer, Oak Ridge National Laboratory, "Main Pressurizer Pump Coastdown Prediction and Comparison to HFIR Test Data," internal correspondence, March 16, 1989.
140. Letter from A. Sozer, Oak Ridge National Laboratory, to D. H. Cook, Oak Ridge National Laboratory, "HFIR Pump Manufacturer and Coastdown Curves," June 21, 1989.
141. Y. Sunstrand Fluid Handling Certified Test Curve, HFIR files, Reactor Research Division, Martin Marietta Energy Systems, Inc., June 17, 1987.
142. K. Ogata, *Modern Control Engineering*, Prentice-Hall, Englewood Cliffs, N.J., 1970, p. 158.
143. D. S. Asquith, Oak Ridge National Laboratory, personal communication to M. W. Wendel, Oak Ridge Gaseous Diffusion Plant, August 1989.
144. S. J. Ball, Oak Ridge National Laboratory, *Results of Loss of Pressure Accident Study for HFIR*, internal memorandum to N. Hilvety, January 12, 1962.
145. J. W. Hutchinson, ed., *ISM Handbook of Control Valves*, 2nd ed., 1976, p. 9.
146. Ref. 19, Vol. 1A, p. 6-6.
147. Ref. 19, Vol. 1A, pp. 10-7-10-8.

148. B. L. Lepard, Jr., Oak Ridge National Laboratory, "High Flux Isotope Reactor Hot-Off-Gas System Pressure," internal memorandum to M. W. Wendel, Oak Ridge K-25 Site, May 30, 1991.
149. Ref. 19, p. B-6.
150. Ref. 19, p. 6-8.
151. HFIR hourly readings, Dec. 1-4, 1990.
152. Ref. 20, p. 6-29.
153. G. J. Dixon, *Preliminary HFIR Hydraulic Tests*, ORNL 64-12-43, Oak Ridge Natl. Lab., 1963.
154. B. L. Corbett, Oak Ridge National Laboratory, personal communication to M. W. Wendel, Oak Ridge Gaseous Diffusion Plant, September 25, 1990.
155. Ref. 20, pp. 6-35.
156. *CRC Handbook of Chemistry and Physics*, R. C. Weast, ed., 55th ed., CRC Press, Cleveland, Ohio, 1974, p. D-150.
157. R. J. Roark and W. C. Young, *Formulas for Stress and Strain*, 5th ed., McGraw-Hill, New York, 1975, p. 448.
158. Ref. 156, pp. 5-6.
159. *ADINA: A Finite Element Program for Automatic Dynamic Incremental Nonlinear Analysis*, Report AE-81-1, ADINA Engineering, September 1981.
160. A. Sozer, "Calculation of HFIR System Elasticity Constant and Structural Elasticity Coefficient from HFIR Hydraulic Test Data," Oak Ridge Natl. Lab., internal memorandum, April 11, 1989.
161. C. A. Meyer et al., *Thermodynamic and Transport Properties of Steam*, The American Society of Mechanical Engineers, New York, 1967.
162. J. A. Trapp and V. H. Ransom, *RELAP5 Hydrodynamic Model Progress Summary—Abrupt Area Changes and Parallel Branching*, PG-R-77-92, EG&G Idaho, Inc., November 1977.
163. A. A. Abbatiello and A. P. Fraas, "The HFIR Water Strainer," ORNL TM-3460, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., March 1972.
164. I. E. Idel'Chik, *Handbook of Hydraulic Resistance Coefficients of Local Resistance and of Friction*, AEC-TR-6630, published pursuant to an agreement with the U.S. Atomic Energy Commission and the National Science Foundation, Washington, D.C., 1960,

pp. 326-327. (Distributed by NTIS, Springfield, Va., published by the Israel Program for Scientific Translations, Jerusalem, 1966.)

165. Eng. Dwg. 1546-01-I-4024, Rev. B, ORNL HFIR.
166. Ref. 164, p. 215.
167. D. S. Miller, *Internal Flow Systems*, BHRA Fluid Engineering, 1978, p. 237.
168. Ref. 164, pp. 144 and 417.
169. *Flow of Fluids Through Valves, Fittings, and Pipe*, Crane Co., Technical Paper No. 410, Eighteenth Printing, 1979, p. A-29.
170. Ref. 167, p. 141.
171. Ref. 164, pp. 263 and 280.
172. Ref. 167, p. 224.
173. *Flow of Fluids Through Valves, Fittings, and Pipe*, Crane Co., Technical Paper No. 410, Eighteenth Printing, 1979, p. A-27.
174. Ref. 167, pp. 270-275.
175. S. Levy, *Fluid Flow Technology of Nuclear Reactor Safety, Vol. 2. Reactor Materials and Engineering*, MIT Press, 1973, p. 283.
176. Eng. Dwg. 1546-M-5512, Rev. A, ORNL HFIR.
177. Eng. Dwg. 1546-M-5513, Rev. C, ORNL HFIR.
178. Eng. Dwg. 1546-M-5516, Rev. B, ORNL HFIR.
179. Eng. Dwg. 1546-M-5534, Rev. B, ORNL HFIR.
180. Ref. 1, Vol. 2, pp. 323-334.
181. Eng. Dwg. 1546-01-E-2119, ORNL HFIR.
182. A. E. Ruggles, Oak Ridge National Laboratory, letter to D. L. Selby, Oak Ridge National Laboratory, "Preferred Correlation for Flow Excursion in the ANSR," July 30, 1990.
183. *TECPLOT User's Manual*, Ver. 4.0, Amtec Engineering, Inc., Bellevue, Wash., June 1990.

184. M. W. Wendel and P. T. Williams, Oak Ridge K-25 Site, RRD technical calculations (HFIR small break LOCA analysis), C-HFIR-91-014 thru C-HFIR-91-020, April 4, 1992.
185. M. W. Wendel, Oak Ridge K-25 Site, "RELAP5 Simulation of an Unheated 10-in. Double-Ended Pipe Break at the Discharge of a Main Circulating Pump," C-HFIR-91-005, June 6, 1991.

Appendix A
INPUT LISTING

508 cntrlvar 501 lt cntrlvar 675 0. l
 * signal for reactor flux-to-flow ratio trip initiated
 509 cntrlvar 204 gt cntrlvar 676 0. l
 * automatic trip of the reactor
 510 cntrlvar 208 gt null 0 0.5 n
 * demineralizer supply to pc head tank trip on
 511 cntrlvar 7 lt cntrlvar 677 0. n
 * trip off pressurizer pumps if level in pc head tank < 25%
 512 cntrlvar 7 lt cntrlvar 678 0. l
 * detect very low suction pressure to pressurizer pumps
 513 cntrlvar 502 lt cntrlvar 679 0. n
 * trip on standby pressurizer pump
 514 time 0 gt null 0 1.06 l * standby pwr pump on
 514 cntrlvar 501 lt cntrlvar 680 0. l * standby pwr pump on
 * check for low pressurizing flow for start-up of auxiliary pwr pump
 515 cntrlvar 503 lt cntrlvar 681 0. l
 * let-down radiation block valve closure
 516 cntrlvar 501 lt cntrlvar 682 0. n
 * trip off pwr pumps on high system pressure
 518 cntrlvar 505 gt cntrlvar 684 0. l
 * trip pressurizer pumps if eds is activated
 519 cntrlvar 255 gt null 0 0. l
 * trip pressurizer pumps if suction pressure is low for 5 seconds
 521 cntrlvar 18 ge null 0 5. l
 525 p 060030000 lt null 0 20.0 l * structural elasticity model off
 * water coolant temperature low enough to trip open eds
 526 cntrlvar 500 lt cntrlvar 685 0. l
 528 cntrlvar 501 lt cntrlvar 686 0. l * reset eds valves
 *
 * main circulation pump trip logic
 *
 529 time 0 gt null 0 -1. l * use speed table for mcps
 530 cntrlvar 114 lt null 0 1. n * mcp d cavitated
 531 cntrlvar 139 lt null 0 1. n * mcp c cavitated
 532 cntrlvar 164 lt null 0 1. n * mcp a cavitated
 533 cntrlvar 501 lt cntrlvar 683 0. l * mcp trip on low pressure
 536 cntrlvar 117 gt null 0 1. n * v/alpha range pump pu-1d
 537 cntrlvar 142 gt null 0 1. n * v/alpha range pump pu-1c
 538 cntrlvar 167 gt null 0 1. n * v/alpha range pump pu-1a
 *
 * trips on setpoints and failures
 *
 551 time 0 gt cntrlvar 601 0. l * reactor trip
 552 time 0 gt cntrlvar 602 0. l
 553 time 0 gt cntrlvar 603 0. l * loss of offsite ac power
 554 time 0 gt cntrlvar 604 0. l
 555 time 0 gt cntrlvar 605 0. l * pressurizer pump failure
 556 time 0 gt cntrlvar 606 0. l
 557 time 0 gt cntrlvar 607 0. l
 558 time 0 gt cntrlvar 608 0. l
 559 time 0 gt cntrlvar 609 0. l
 560 time 0 gt cntrlvar 610 0. l
 561 time 0 gt cntrlvar 611 0. l
 562 time 0 gt cntrlvar 612 0. l
 563 time 0 gt cntrlvar 613 0. l
 564 time 0 gt cntrlvar 614 0. l
 565 time 0 gt cntrlvar 615 0. l
 566 time 0 gt cntrlvar 616 0. l
 567 time 0 gt cntrlvar 617 0. l
 568 time 0 gt cntrlvar 618 0. l
 569 time 0 gt cntrlvar 619 0. l
 570 time 0 gt cntrlvar 620 0. l
 571 time 0 gt cntrlvar 621 0. l
 572 time 0 gt cntrlvar 622 0. l
 573 time 0 gt cntrlvar 623 0. l
 574 time 0 gt cntrlvar 624 0. l
 575 time 0 gt cntrlvar 625 0. l
 576 time 0 gt cntrlvar 626 0. l
 577 time 0 gt cntrlvar 627 0. l
 578 time 0 gt cntrlvar 628 0. l
 579 time 0 gt cntrlvar 629 0. l
 580 time 0 gt cntrlvar 630 0. l
 581 time 0 gt cntrlvar 631 0. l
 582 time 0 gt cntrlvar 632 0. l
 583 time 0 gt cntrlvar 633 0. l
 584 time 0 gt cntrlvar 634 0. l
 585 time 0 gt cntrlvar 635 0. l
 586 time 0 gt cntrlvar 636 0. l
 587 time 0 gt cntrlvar 637 0. l
 588 time 0 gt cntrlvar 638 0. l
 589 time 0 gt cntrlvar 639 0. l
 590 time 0 gt cntrlvar 641 0. l
 594 time 0 gt cntrlvar 650 0. l
 595 time 0 gt cntrlvar 651 0. l
 596 time 0 gt cntrlvar 652 0. l
 597 time 0 gt cntrlvar 653 0. l
 598 time 0 gt cntrlvar 654 0. l
 599 time 0 gt cntrlvar 655 0. l
 *
 600 501
 *
 * logical trips
 *
 * check for aux pwr pump trip conditions
 602 515 and 503 l
 603 526 and -528 n * eds valves open
 * logic for low suction pressure trip on pressurizer pumps
 605 606 and 505 n
 606 513 or 605 n
 * has eds been activated or has the high pressure limit been exceeded?
 609 518 or 519 l
 * has ac power been lost?
 610 609 or 553 l
 * check for pressurizer pump failure
 *
 * sec pump coupling failure
 * fev377 closes
 *
 * loss of instrument air
 *
 * ld block valves fail to close
 *
 * failure of reactor trip
 *
 * secondary pump/bypass failure
 *
 * aux pressurizer pump fails
 * allow primary coolant leakage
 * pipe break at mcp outlet
 * pipe break at mcp inlet
 * pipe brk at ht exchngtr inlet
 * pipe break at vessel
 * pipe brk in pwr supply line
 * pipe brk at vessel outlet

```

611 555 or 610 l
* should standby pressurizer pump be on?
612 503 and 514 l
* should pressurizer pump motors be engaged?
613 -512 and -521 n 0.
* should power be supplied to main pwr. pumps? yes, if false. no, if
true.
* pressurizer pump trip (used on cards 0660301 and 0690301)
614 -613 or 611 l * pressurizer pump trip
* pressurizer pump speed table trip (cards 0666100 and 0696100)
615 -614 or -614 n 0.
622 -579 and 516 n * letdown block valves close
623 -589 and 602 l * auxiliary pwr pump on
* reactor trip logic
*
* initiate scram due to automatic controls
643 510 or 551 n
* trip reactor on loss of instr. air at pwr pump trip
644 571 and 518 l
* temperature or pressure trip
645 507 or 508 l
646 644 or 509 l
647 646 or 645 l * initiate scram
648 643 and -583 n * scram initiated
* secondary cooling system actions: bypass valve open, pumps trip
649 648 and -586 l * trip secondary pump pu-6b
650 -649 or -649 n 0.
651 649 or 568 l * trip secondary pump pu-6a
652 -651 or -651 n 0.
*
* mcp trip logic
*
660 553 or 533 l * main circulation pumps tripped
*
*****
*
* reactor contents
*
*****
*
*
1800000 u-plenum branch
180001 6 1
180101 106. 1.99 210.94 0.0 -90. -1.99 1.5e-4 7.83 0
180200 3 -42070e+03 126.150
181101 018010000 004000000 1.31 0.0 0.0 31100
181201 1.9153e+03 0.
182101 018010000 017000000 0.129 0.0 0.0 31100
0182201 1.0916e+02 0. 0.
0183101 018010000 033000000 41.9 0.0 0.0 31100
0183201 1.1552e+01 0. 0.
0184101 018010000 003000000 0.064 0.0 0.0 31100
0184201 3.2399e+02 0. 0.
0185101 091010000 018000000 0.0 0.0 0.0 31101
0185201 1.1800e+03 0. 0.
0186101 092010000 018000000 0.0 0.0 0.0 31101
0186201 1.1800e+03 0. 0.
*
0170000 target-t branch
0170001 2 1
0170101 0.129 3.92 0.50568 0.0 -90. -3.92 1.5e-4 0.405 0
0170200 3 -42013e+03 126.150
0171101 017010000 005000000 3.66e-2 0.0 0.0 31100
0171201 9.4253e+01 0. 0.
0172101 017010000 006000000 0.004789 0.0 0.0 31100
0172201 1.4910e+01 0. 0.
*
0040000 i-shrd branch
0040001 7 1
0040101 1.31 3.92 5.1352 0.0 -90. -3.92 1.5e-4 0.89 0
0040200 3 -41670e+03 126.150
0041101 004010000 001000000 0.097 0.0 0.0 31000
0041201 3.2462e+02 0. 0.
0042201 004010000 002000000 0.186 0.0 0.0 31000
0043101 004010000 010000000 8.05e-4 0.0 0.0 31000
0043201 2.2127e+00 0. 0.
0044101 004010000 014000000 0.097 0.0 0.0 31000
0044201 3.2457e+02 0. 0.
0045101 004010000 015000000 0.186 0.0 0.0 31000
0045201 6.2126e+02 0. 0.
0046101 004010000 016000000 7.14e-4 0.0 0.0 31000
0046201 1.9625e+00 0. 0.
0047101 004010000 019000000 0.0037 0.0 0.0 31100
0047201 1.9341e+01 0. 0.
*
0030000 shrd branch
0030001 7 1
0030101 2.48 3.92 9.7216 0.0 -90. -3.92 1.5e-4 0.85 0
0030200 3 -30897e+03 126.090
0031101 003010000 027000000 0.0391 0.0 0.0 31100
0031201 3.8016e+01 0. 0.
0032101 003010000 028000000 0.0668 0.0 0.0 31100
0032201 8.5511e+01 0. 0.
0033101 003010000 029000000 0.0389 0.0 0.0 31100
0033201 3.5760e+01 0. 0.
0034101 003010000 030000000 0.00613 0.0 0.0 31100
0034201 5.2811e+00 0. 0.
0035101 003010000 031000000 0.103 0.0 0.0 31100
0035201 8.8637e+01 0. 0.

```

```

0036101 003010000 032000000 0.0628 0.0 0.0 31100
0036201 6.2759e-01 0. 0.
0037101 003010000 036000000 0.00801 0.0 0.0 31100
0037201 8.0205e-00 0. 0.
* this volume should always be about 120 f (322.22 k)
*
0330000 u-byps branch
0330001 3 1
0330101 41.9 5.919 248.0061 0.0 -90. -5.919 1.5e-4 5.0 0
0330200 3 -42240e+03 120.000
0331101 033010000 035000000 26.2 0.0 0.0 31000
0331201 1.1581e+01 0. 0.
0332101 033010000 140000000 0.05134 2.05 2.05 31000
0332201 -6.0862e-09 0. 0.
0333101 033010000 021000000 0.023303 0. 0. 31100
0333201 -4.6698e-09 0. 0.
* break 4 orifice on reactor vessel
*
* for 0.5" break area= .0013635
* for 1.0" break area= .0054542
* for 1.5" break area= .0122718
* for 2.0" break area= .0218166
* for 2.5" break area= .0340885
* for 3.0" break area= .0490874
*
5080000 bk4-vlv valve
5080101 033010000 509000000 0.0122718 0. 0. 31100
5080201 1 0.0000e+00 0. 0.
5080300 trpvlv
5080301 597
*
* break 4 sink
*
5090000 h20-b4s tmpdvol
5090101 1. 1. 0. 0. 0. 1.d-6 1. 10
5090200 3 0
5090201 0.00 24.2 100.
*
* emergency depressurization system
*
* pipe from reactor to eds valve
*
1400000 edspipe pipe
1400001 3
1400101 0.05134 1 0.01414 2 0.00600 3
1400301 15.875 1 26.86 2 7.5 3
1400601 0. 3
1400801 1.5e-4 0.2557 1 1.5e-4 0.1342 2 1.5e-4 0.0874 3
1400901 0.7 0.7 1 4.05 4.05 2
1401001 0 3
1401101 31000 2
1401201 3 .42367e+03 119.97 0. 0. 0. 1
1401202 3 .42367e+03 119.97 0. 0. 0. 2
1401203 3 .42367e+03 119.97 0. 0. 0. 3
1401300 1
1401301 1.3513e-09 0. 0. 1
1401302 2.2508e-10 0. 0. 2
*
* servo valve for emergency depressurization
*
1410000 eds-vlv valve
1410101 140010000 142000000 0.00211 1. 1. 100
1410201 1 0.0000e+00 0. 0.
1410300 srvvlv
1410301 255
*
* 1/2-in line joining valve to hold-up tank
*
1420000 vlv-tank singlvol
1420101 0.00211 7.5 0. 0. 0. 1.5e-4 0.0518 0
1420200 3 .14700e+02 120.000
*
1430000 eds-ou-j singlvol
1430101 142010000 144000000 0.00211 1. 1. 31100
1430201 1 0.0000e+00 0. 0.
*
* 90-s hold-up tank for eds discharge
*
1440000 eds-sink tmpdvol
1440101 0.1 1.0 0. 0. 0. 1.d-6 0.1 10
1440200 3
1440201 0. 14.7 120.
*
* injection/ejection of mass to account for structural elasticity
*
0400000 elast8v tmpdvol
0400101 1. 1. 0. 0. 0. 1.d-6 1. 10
0400200 3 0 tempf 033010000
0400201 0. 20. 0. 1.e6 20. 1.e6
*
0420000 elast8j tmpdvol
0420101 040000000 033000000 1.
0420200 1 0 cntrlvtr 376
0420201 -1.e60 -1.e60 0. 0.
0420202 -1.e4 -1.e4 0. 0.
0420203 1.e4 1.e4 0. 0.
0420204 1.e60 1.e60 0. 0.
*
* pipe from reactor vessel to reactor
*
* check valve
*
0210000 rcvpipe pipe

```


0161210	3	.30793e+03	242.16	0.	0.	0.	0.	10
0161211	3	.29810e+03	242.50	0.	0.	0.	0.	11
0161300	1							
0161301	1	1.9625e+00	0.	0.	1			
0161302	1	1.9625e+00	0.	0.	2			
0161303	1	1.9625e+00	0.	0.	3			
0161304	1	1.9625e+00	0.	0.	4			
0161305	1	1.9625e+00	0.	0.	5			
0161306	1	1.9625e+00	0.	0.	6			
0161307	1	1.9625e+00	0.	0.	7			
0161308	1	1.9625e+00	0.	0.	8			
0161309	1	1.9625e+00	0.	0.	9			
0161310	1	1.9625e+00	0.	0.	10			
*								
0270000	i-cp pipe							
0270001	5							
0270101	0.0391	5						
0270301	0.4165	2 0.333 3 0.4165	5					
0270601	-90.	5						
0270801	6.5e-4	0.0173	5					
0271001	0 5							
0271101	31000	4						
0271201	3	.30641e+03	127.77	0.	0.	0.	1	
0271202	3	.30408e+03	130.43	0.	0.	0.	2	
0271203	3	.30198e+03	132.89	0.	0.	0.	3	
0271204	3	.29988e+03	135.55	0.	0.	0.	4	
0271205	3	.29755e+03	136.93	0.	0.	0.	5	
0271300	1							
0271301	3	.8016e+01	0.	0.	1			
0271302	3	.8016e+01	0.	0.	2			
0271303	3	.8016e+01	0.	0.	3			
0271304	3	.8016e+01	0.	0.	4			
*								
0280000	m-cp pipe							
0280001	5							
0280101	0.0668	5						
0280301	0.4165	2 0.333 3 0.4165	5					
0280601	-90.	5						
0280801	6.5e-4	0.0283	5					
0281001	0 5							
0281101	31000	4						
0281201	3	.30490e+03	127.52	0.	0.	0.	1	
0281202	3	.30292e+03	130.02	0.	0.	0.	2	
0281203	3	.30112e+03	132.34	0.	0.	0.	3	
0281204	3	.29933e+03	134.86	0.	0.	0.	4	
0281205	3	.29733e+03	136.32	0.	0.	0.	5	
0281300	1							
0281301	8.5511e+01	0.	0.	1				
0281302	8.5511e+01	0.	0.	2				
0281303	8.5511e+01	0.	0.	3				
0281304	8.5511e+01	0.	0.	4				
*								
0290000	o-cp pipe							
0290001	5							
0290101	0.0389	5						
0290301	0.4165	2 0.333 3 0.4165	5					
0290601	-90.	5						
0290801	6.5e-4	0.0158	5					
0291001	0 5							
0291101	31000	4						
0291201	3	.30662e+03	128.09	0.	0.	0.	1	
0291202	3	.30425e+03	131.88	0.	0.	0.	2	
0291203	3	.30211e+03	135.35	0.	0.	0.	3	
0291204	3	.29997e+03	139.12	0.	0.	0.	4	
0291205	3	.29758e+03	141.46	0.	0.	0.	5	
0291300	1							
0291301	3	.5760e+01	0.	0.	1			
0291302	3	.5760e+01	0.	0.	2			
0291303	3	.5760e+01	0.	0.	3			
0291304	3	.5760e+01	0.	0.	4			
*								
0300000	hot-be pipe							
0300001	5							
0300101	0.00613	5						
0300301	0.4165	2 0.333 3 0.4165	5					
0300601	-90.	5						
0300801	2.1e-4	0.0104	5					
0301001	0 5							
0301101	31000	4						
0301201	3	.30684e+03	131.05	0.	0.	0.	1	
0301202	3	.30441e+03	139.35	0.	0.	0.	2	
0301203	3	.30222e+03	146.70	0.	0.	0.	3	
0301204	3	.30004e+03	154.22	0.	0.	0.	4	
0301205	3	.29761e+03	157.99	0.	0.	0.	5	
0301300	1							
0301301	5.2811e+00	0.	0.	1				
0301302	5.2811e+00	0.	0.	2				
0301303	5.2811e+00	0.	0.	3				
0301304	5.2811e+00	0.	0.	4				
*								
0310000	r-sp-be pipe							
0310001	5							
0310101	0.103	5						
0310301	0.4165	2 0.333 3 0.4165	5					
0310601	-90.	5						
0310801	2.1e-4	0.0104	5					
0311001	0 5							
0311101	31000	4						
0311201	3	.30684e+03	128.09	0.	0.	0.	1	
0311202	3	.30441e+03	131.41	0.	0.	0.	2	
0311203	3	.30222e+03	134.40	0.	0.	0.	3	
0311204	3	.30004e+03	137.63	0.	0.	0.	4	
0311205	3	.29761e+03	139.51	0.	0.	0.	5	
0311300	1							

```

0311301 8.8637e+01 0. 0. 1
0311302 8.8637e+01 0. 0. 2
0311303 8.8637e+01 0. 0. 3
0311304 8.8637e+01 0. 0. 4
*
0320000 pm-be-1 pipe
0320001 5
0320101 0.0628 5
0320301 0.4165 2 0.333 3 0.4165 5
0320601 -90. 5
0320801 4.1e-5 0.0104 5
0321001 0 5
0321101 31000 4
0321201 3 .30628e+03 128.17 0. 0. 0. 1
0321202 3 .30397e+03 131.29 0. 0. 0. 2
0321203 3 .30189e+03 134.05 0. 0. 0. 3
0321204 3 .29982e+03 137.11 0. 0. 0. 4
0321205 3 .29753e+03 139.13 0. 0. 0. 5
0321300 1
0321301 6.2759e+01 0. 0. 1
0321302 6.2759e+01 0. 0. 2
0321303 6.2759e+01 0. 0. 3
0321304 6.2759e+01 0. 0. 4
*
0360000 pm-be-0 pipe
0360001 5
0360101 0.00801 5
0360301 0.4165 2 0.333 3 0.4165 5
0360601 -90. 5
0360801 4.1e-5 0.0104 5
0361001 0 5
0361101 31000 4
0361201 3 .30627e+03 130.35 0. 0. 0. 1
0361202 3 .30396e+03 136.11 0. 0. 0. 2
0361203 3 .30188e+03 141.04 0. 0. 0. 3
0361204 3 .29981e+03 146.52 0. 0. 0. 4
0361205 3 .29752e+03 150.26 0. 0. 0. 5
0361300 1
0361301 8.0205e+00 0. 0. 1
0361302 8.0205e+00 0. 0. 2
0361303 8.0205e+00 0. 0. 3
0361304 8.0205e+00 0. 0. 4
*
0080000 l-plm-1 branch
0080001 9 1
0080101 1.25 3.74 4.675 0.0 -90. -3.74 1.5e-4 1.26 0
0080200 3 .30129e+03 165.990
0081101 001010000 008000000 0.097 0.0 0.0 31100
0081201 3.2462e+02 0. 0.
0082101 002010000 008000000 0.186 0.0 0.0 31100
0082201 6.2136e+02 0. 0.
0083101 005010000 008000000 1.65e-2 0.0 0.0 31100

0083201 9.4253e+01 0. 0.
0084101 006010000 008000000 3.49e-3 0.0 0.0 31100
0084201 1.4910e+01 0. 0.
0085101 010010000 008000000 8.05e-4 0.0 0.0 31100
0085201 2.2127e+00 0. 0.
0086101 014010000 008000000 0.097 0.0 0.0 31100
0086201 3.2457e+02 0. 0.
0087101 015010000 008000000 0.186 0.0 0.0 31100
0087201 6.2126e+02 0. 0.
0088101 016010000 008000000 7.14e-4 0.0 0.0 31100
0088201 1.9625e+00 0. 0.
0089101 019010000 008000000 0.0786 0.0 0.0 31100
0089201 1.9341e+01 0. 0.
*
0090000 l-plm-2 branch
0090001 9 1
0090101 7.66 3.74 28.6484 0.0 -90. -3.74 1.5e-4 2.06 0
0090200 3 .29731e+03 151.240
0091101 027010000 009000000 0.0391 0.0 0.0 31100
0091201 3.8016e+01 0. 0.
0092101 028010000 009000000 0.0668 0.0 0.0 31100
0092201 8.5511e+01 0. 0.
0093101 029010000 009000000 0.0389 0.0 0.0 31100
0093201 3.5760e+01 0. 0.
0094101 030010000 009000000 0.00613 0.0 0.0 31100
0094201 5.2811e+00 0. 0.
0095101 031010000 009000000 0.103 0.0 0.0 31100
0095201 8.8637e+01 0. 0.
0096101 032010000 009000000 0.0628 0.0 0.0 31100
0096201 6.2759e+01 0. 0.
0097101 035000000 0.90000000 0.071 2700. 2700. 30003
0097201 1.1587e+01 0. 0.
0098101 036010000 009000000 0.00801 0.0 0.0 31100
0098201 8.0205e+00 0. 0.
0099101 009000000 008000000 0.239 1.5 1.5 30003
0099201 -2.9241e+02 0. 0.
*
* this volume should always be about 120 f (322.22 k)
*
0350000 l-byps branch
0350001 0 1
0350101 26.2 3.74 97.988 0.0 -90. -3.74 1.5e-4 3.25 0
0350200 3 .42447e+03 120.000
*
0340000 outlet branch
0340001 2 1
0340101 5.90 3.69 21.771 0.0 -90. -3.69 1.5e-4 2.74 0
0340200 3 .29315e+03 162.060
0341101 008010000 034000000 0.77 0.0 0.0 31100
0341201 1.7321e+03 0. 0.
0342101 009010000 034000000 0.543 0.0 0.0 31100
0342201 6.2798e+02 0. 0.

```



```

* 0410000 reactorj sngljun
0410101 034000000 05000000 0. 0. 0. 31002
0410201 1 2.3601e+03 0. 0.
* vessel lid heat structure
10181000 1 5 1 0 0.0 0
10181400 -1
10181401 122.77 122.16 114.45 106.92 106.32
10181100 0 1
10181101 1 0.01042 2 1.1771 1 1.1875
10181201 11 1 12 3 11 4
10181301 0 0 4
10181501 18010000 0 3600 0 48.3 1
10181601 39010000 0 4700 0 48.3 1
10181701 0 0 0 0 0 0 1
10181801 0 0 0 0 0 0 1
10181901 0 0 0 0 0 0 1
*
* upper vessel sidewall heat structure
10180000 1 5 2 0 3.92 0
10180400 -1
10180401 118.29 117.41 114.98 112.63 111.78
10180100 0 1
10180101 1 3.930 2 4.170 1 4.18
10180201 10 1 12 3 11 4
10180301 0 0 4
10180501 18010000 0 3400 1 4.39 1
10180601 39010000 0 4500 1 4.39 1
10180701 0 0 0 0 0 0 1
10180801 0 0 0 0 0 0 1
10180901 0 0 0 0 0 0 1
*
* outer shroud heat structure
10410000 1 5 2 0 1.139988 0
10410400 -1
10410401 125.31 125.30 125.20 125.11 125.09
10410100 0 1
10410101 1 1.140045 2 1.198288 1 1.198345
10410201 5 1 8 3 5 4
10410301 0 0 4
10410501 3010000 0 1 1 3.92 1
10410601 33010000 0 4300 1 3.92 1
10410701 0 0 0 0 0 0 1
10410801 0 0 0 0 0 0 1
10410901 0 0 0 0 0 0 1
*
* active target heat structure
10050000 5 7 2 0 0.0 0 1 8
10050400 -1
10050401 676.98 613.63 423.58 411.09 217.49 195.43 175.18
10050402 938.67 845.31 565.23 546.54 261.25 228.96 199.11
10050403 1037.80 933.15 619.31 598.23 278.54 242.46 209.02
10050404 936.29 843.56 565.36 546.80 263.41 231.35 201.70
10050405 672.28 610.18 423.87 411.63 221.86 200.25 180.40
10050100 0 1
10050101 2 0.008125 1 0.010375 1 0.01038333 1 0.0153292 1 0.0153866
10050201 4 2 14 3 13 4 9 5 6
10050301 1.0 2 0.0 6
10050501 0 0 0 0 0 5
10050601 5020000 010000 1 0 0.998 5
10050701 101 3.04e-2 0.0 0.0 1
10050702 101 4.48e-2 0.0 0.0 2
10050703 101 5.02e-2 0.0 0.0 3
10050704 101 4.45e-2 0.0 0.0 4
10050705 101 2.98e-2 0.0 0.0 5
10050901 0 0 0 0 0 0.5
*
* target void heat structure
10051000 2 3 2 0 0.010375 0
10051400 -1
10051401 145.41 142.94 137.99
10051402 153.47 151.08 146.29
10051100 0 1
10051101 1 0.0153292 1 0.0153866
10051201 9 1 5 2
10051301 1.0 1 0.0 2
10051501 0 0 1 5.167 2
10051601 5010000 060000 1 1 5.167 2
10051701 101 3.72e-3 0.0 0.0 1
10051702 101 3.60e-3 0.0 0.0 2
10051901 0 0 0 0 0 0 2
*
* i-active fuel-1 heat structure
10010000 5 5 1 0 0.0 0 1 8
10010400 -1
10010401 195.79 195.03 192.75 189.14 167.26
10010402 230.39 229.30 226.02 220.89 189.49
10010403 250.94 249.69 245.95 240.13 204.32
10010404 246.89 245.79 242.49 237.33 205.68
10010405 225.78 225.02 222.74 219.16 197.27
10010100 0 1
10010101 2 1.23e-3 1 2.03754e-3 1 2.09496e-3
10010201 2 2 1 3 5 4
10010301 1.0 2 0.0 4
10010501 0 0 0 0 14.5 5
10010601 1020000 010000 1 0 14.5 5
10010701 100 2.53e-2 0.0 0.0 1

```

```

10010702 100 3.63e-2 0.0 0.0 2
10010703 100 4.14e-2 0.0 0.0 3
10010704 100 3.66e-2 0.0 0.0 4
10010705 100 2.53e-2 0.0 0.0 5
10010901 0 0.0 0.0 0.0 5
*
* i-fuel-1 extension heat structure
*
10011000 2 5 1 0 0.0 0
10011400 -1
10011401 132.26 132.19 131.99 131.66 129.67
10011402 172.43 172.36 172.17 171.84 169.85
10011100 0 1
10011101 2 1.25e-3 1 2.03754e-3 1 2.09496e-3
10011201 1 3 5 4
10011301 1.0 2 0.0 4
10011501 0 0 0 7.25 2
10011601 1010000 060000 1 0 7.25 2
10011701 100 1.15e-3 0.0 0.0 1
10011702 100 1.15e-3 0.0 0.0 2
10011901 0 0.0 0.0 0.0 2
*
* i-active fuel-2 heat structure
*
10140000 5 5 1 0 0.0 0 1 8
10140400 -1
10140401 194.44 193.70 191.46 187.92 166.47
10140402 228.45 227.38 224.16 219.12 188.33
10140403 248.63 247.41 243.74 238.03 202.91
10140404 244.70 243.62 240.37 235.32 204.26
10140405 223.92 223.18 220.94 217.43 195.98
10140100 0 1
10140101 2 1.25e-3 1 2.03754e-3 1 2.09496e-3
10140201 2 2 1 3 5 4
10140301 1.0 2 0.0 4
10140501 0 0 0 14.5 5
10140601 1402000 010000 1 0 14.5 5
10140701 100 2.48e-2 0.0 0.0 1
10140702 100 3.56e-2 0.0 0.0 2
10140703 100 4.06e-2 0.0 0.0 3
10140704 100 3.59e-2 0.0 0.0 4
10140705 100 2.48e-2 0.0 0.0 5
10140901 0 0.0 0.0 0.0 5
*
* i-fuel-2 extension heat structure
*
10141000 2 5 1 0 0.0 0
10141400 -1
10141401 132.15 132.09 131.89 131.56 129.61
10141402 171.56 171.50 171.30 170.98 169.03
10141100 0 1
10141101 2 1.25e-3 1 2.03754e-3 1 2.09496e-3
10141201 1 3 5 4
10141301 1.0 2 0.0 4
10141501 0 0 0 0.0853 2
10141601 1001000 100000 1 0 0.0853 2
10141701 100 3.66e-6 0.0 0.0 1
10141702 100 3.34e-6 0.0 0.0 2
10141201 1 3 5 4
10141301 1.0 2 0.0 4
10141501 0 0 0 7.25 2
10141601 1401000 060000 1 0 7.25 2
10141701 100 1.13e-3 0.0 0.0 1
10141702 100 1.13e-3 0.0 0.0 2
10141901 0 0.0 0.0 0.0 2
*
* i-hot active fuel heat structure
*
10100000 9 5 1 0 0.0 0 1 8
10100400 -1
10100401 262.04 260.87 257.35 252.14 193.14
10100402 284.72 283.41 279.48 273.69 207.72
10100403 327.14 325.51 320.64 313.54 231.77
10100404 357.54 355.72 350.26 342.38 250.85
10100405 375.56 373.67 368.01 359.86 264.85
10100406 376.88 375.09 369.72 361.99 271.86
10100407 366.05 364.47 359.75 352.95 273.73
10100408 342.55 341.31 337.58 332.18 269.69
10100409 336.56 335.46 332.16 327.38 272.09
10100100 0 1
10100101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10100201 2 2 1 3 5 4
10100301 1.0 2 0.0 4
10100501 0 0 0 0.0948 9
10100601 1002000 010000 1 0 0.0948 9
10100701 100 2.54e-4 0.0 0.0 1
10100702 100 2.84e-4 0.0 0.0 2
10100703 100 3.52e-4 0.0 0.0 3
10100704 100 3.94e-4 0.0 0.0 4
10100705 100 4.09e-4 0.0 0.0 5
10100706 100 3.88e-4 0.0 0.0 6
10100707 100 3.41e-4 0.0 0.0 7
10100708 100 2.69e-4 0.0 0.0 8
10100709 100 2.38e-4 0.0 0.0 9
10100901 0 0.0 0.0 0.0 9
*
* i-hot fuel extension heat structure
*
10101000 2 5 1 0 0.0 0
10101400 -1
10101401 128.62 128.60 128.55 128.46 127.51
10101402 234.20 234.19 234.14 234.06 233.20
10101100 0 1
10101101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10101201 1 3 5 4
10101301 1.0 2 0.0 4
10101501 0 0 0 0.0853 2
10101601 1001000 100000 1 0 0.0853 2
10101701 100 3.66e-6 0.0 0.0 1
10101702 100 3.34e-6 0.0 0.0 2

```

```

10101901 0 0 0 0 0 0 0 2
* i-hot spot 1 (local) extension fuel heat structure
*
10102000 1 5 1 0 0 0 0 1 8
10102400 -1
10102401 535.39 531.64 520.39 504.53 316.32
10102100 0 1
10102101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10102201 2 2 1 3 5 4
10102301 1.0 2 0.0 4
10102501 0 0 0 0.000853 1
10102601 10010000 0 1 0 0.000853 1
10102701 100 7.29e-6 0.0 0.0 1
10102901 0 0 0 0.0 0.0 1
* i-hot spot 2 (local) active fuel heat structure
*
10103000 1 5 1 0 0 0 0 1 8
10103400 -1
10103401 292.81 291.35 286.98 280.55 207.14
10103100 0 1
10103101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10103201 2 2 1 3 5 4
10103301 1.0 2 0.0 4
10103501 0 0 0 0.000948 1
10103601 10020000 0 1 0 0.000948 1
10103701 100 3.16e-6 0.0 0.0 1
10103901 0 0 0 0.0 0.0 1
* i-hot spot 3 (local) active fuel heat structure
*
10104000 1 5 1 0 0 0 0 1 8
10104400 -1
10104401 318.35 316.72 311.83 304.70 222.69
10104100 0 1
10104101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10104201 2 2 1 3 5 4
10104301 1.0 2 0.0 4
10104501 0 0 0 0.000948 1
10104601 10030000 0 1 0 0.000948 1
10104701 100 3.53e-6 0.0 0.0 1
10104901 0 0 0 0.0 0.0 1
* i-hot spot 4 (local) active fuel heat structure
*
10105000 1 5 1 0 0 0 0 1 8
10105400 -1
10105401 367.23 365.21 359.17 350.47 249.18
10105100 0 1
10105101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10105201 2 2 1 3 5 4

10105301 1.0 2 0.0 4
10105501 0 0 0 0.000948 1
10105601 10040000 0 1 0 0.000948 1
10105701 100 4.36e-6 0.0 0.0 1
10105901 0 0 0 0.0 0.0 1
* i-hot spot 5 (local) active fuel heat structure
*
10106000 1 5 1 0 0 0 0 1 8
10106400 -1
10106401 401.92 399.66 392.89 383.21 269.61
10106100 0 1
10106101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10106201 2 2 1 3 5 4
10106301 1.0 2 0.0 4
10106501 0 0 0 0.000948 1
10106601 10050000 0 1 0 0.000948 1
10106701 100 4.89e-6 0.0 0.0 1
10106901 0 0 0 0.0 0.0 1
* i-hot spot 6 (local) active fuel heat structure
*
10107000 1 5 1 0 0 0 0 1 8
10107400 -1
10107401 420.45 418.10 411.07 401.09 283.31
10107100 0 1
10107101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10107201 2 2 1 3 5 4
10107301 1.0 2 0.0 4
10107501 0 0 0 0.000948 1
10107601 10060000 0 1 0 0.000948 1
10107701 100 5.07e-6 0.0 0.0 1
10107901 0 0 0 0.0 0.0 1
* i-hot spot 7 (local) active fuel heat structure
*
10108000 1 5 1 0 0 0 0 1 8
10108400 -1
10108401 419.67 417.44 410.74 401.23 289.02
10108100 0 1
10108101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10108201 2 2 1 3 5 4
10108301 1.0 2 0.0 4
10108501 0 0 0 0.000948 1
10108601 10070000 0 1 0 0.000948 1
10108701 100 4.83e-6 0.0 0.0 1
10108901 0 0 0 0.0 0.0 1
* i-hot spot 8 (local) active fuel heat structure
*
10109000 1 5 1 0 0 0 0 1 8
10109400 -1

```



```

10150601 15020000 010000 1 0 28.2 5
10150701 100 5.09e-2 0.0 0.0 1
10150702 100 7.22e-2 0.0 0.0 2
10150703 100 8.03e-2 0.0 0.0 3
10150704 100 7.27e-2 0.0 0.0 4
10150705 100 5.07e-2 0.0 0.0 5
10150901 0 0.0 0.0 0.0 5
* o-fuel-2 extension heat structure
*
10151000 2 5 1 0 0.0 0
10151400 -1
10151401 130.91 130.86 130.71 130.45 128.90
10151402 172.41 172.36 172.22 171.97 170.46
10151100 0 1
10151101 2 1.25e-3 1 2.03754e-3 1 2.09496e-3
10151201 1 3 5 4
10151301 1.0 2 0.0 4
10151501 0 0 0 14.1 2
10151601 15010000 060000 1 0 14.1 2
10151701 100 1.74e-3 0.0 0.0 1
10151702 100 1.69e-3 0.0 0.0 2
10151901 0 0.0 0.0 0.0 2
*
* o-hot active fuel heat structure
*
10160000 9 5 1 0 0.0 0 1 8
10160400 -1
10160401 268.31 266.96 262.89 257.47 195.95
10160402 296.56 295.00 290.32 284.12 213.30
10160403 345.10 343.14 337.24 329.53 240.36
10160404 381.34 379.11 372.41 363.73 262.41
10160405 400.66 398.35 391.41 382.47 277.53
10160406 401.21 399.03 392.48 384.05 285.05
10160407 386.52 384.64 378.98 371.67 286.11
10160408 359.18 357.72 353.33 347.61 281.18
10160409 347.57 346.34 342.63 337.79 281.70
10160100 0 1
10160101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10160201 3 2 1 3 5 4
10160301 1.0 2 0.0 4
10160501 0 0 0 0.0852 9
10160601 16020000 010000 1 0 0.0852 9
10160701 100 2.38e-4 0.0 0.0 1
10160702 100 2.74e-4 0.0 0.0 2
10160703 100 3.45e-4 0.0 0.0 3
10160704 100 3.92e-4 0.0 0.0 4
10160705 100 4.06e-4 0.0 0.0 5
10160706 100 3.83e-4 0.0 0.0 6
10160707 100 3.31e-4 0.0 0.0 7
10160708 100 2.57e-4 0.0 0.0 8
10160709 100 2.17e-4 0.0 0.0 9

10160901 0 0.0 0.0 0.0 9
* o-hot fuel extension heat structure
*
10161000 2 5 1 0 0.0 0
10161400 -1
10161401 128.35 128.33 128.29 128.21 127.38
10161402 243.94 243.92 243.88 243.81 243.04
10161100 0 1
10161101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10161201 1 3 5 4
10161301 1.0 2 0.0 4
10161501 0 0 0 0.0767 2
10161601 16010000 100000 1 0 0.0767 2
10161701 100 2.90e-6 0.0 0.0 1
10161702 100 2.69e-6 0.0 0.0 2
10161901 0 0.0 0.0 0.0 2
*
* o-hot spot 1 (local) extension fuel heat structure
*
10162000 1 5 1 0 0.0 0 1 8
10162400 -1
10162401 519.05 515.08 503.18 488.03 308.00
10162100 0 1
10162101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10162201 3 2 1 3 5 4
10162301 1.0 2 0.0 4
10162501 0 0 0 0.000767 1
10162601 16010000 0 1 0 0.000767 1
10162701 100 6.27e-6 0.0 0.0 1
10162901 0 0.0 0.0 0.0 1
*
* o-hot spot 2 (local) active fuel heat structure
*
10163000 1 5 1 0 0.0 0 1 8
10163400 -1
10163401 312.61 310.80 305.37 298.20 216.01
10163100 0 1
10163101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10163201 3 2 1 3 5 4
10163301 1.0 2 0.0 4
10163501 0 0 0 0.000852 1
10163601 16020000 0 1 0 0.000852 1
10163701 100 3.18e-6 0.0 0.0 1
10163901 0 0.0 0.0 0.0 1
*
* o-hot spot 3 (local) active fuel heat structure
*
10164000 1 5 1 0 0.0 0 1 8
10164400 -1
10164401 346.51 344.43 338.17 330.00 235.39
10164100 0 1

```

```

10164101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10164201 3 2 1 3 5 4
10164301 1.0 2 0.0 4
10164501 0 0 0 0.000852 1
10164601 16030000 0 1 0 0.000852 1
10164701 100 3.66e-6 0.0 0.0 1
10164901 0 0.0 0.0 0.0 1
*
* o-hot spot 4 (local) active fuel heat structure
*
10165000 1 5 1 0 0.0 1 8
10165400 -1
10165401 406.65 404.03 396.15 386.01 266.85
10165100 0 1
10165101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10165201 3 2 1 3 5 4
10165301 1.0 2 0.0 4
10165501 0 0 0 0.000852 1
10165601 16040000 0 1 0 0.000852 1
10165701 100 4.61e-6 0.0 0.0 1
10165901 0 0.0 0.0 0.0 1
*
* o-hot spot 5 (local) active fuel heat structure
*
10166000 1 5 1 0 0.0 1 8
10166400 -1
10166401 449.77 446.79 437.84 426.43 290.99
10166100 0 1
10166101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10166201 3 2 1 3 5 4
10166301 1.0 2 0.0 4
10166501 0 0 0 0.000852 1
10166601 16050000 0 1 0 0.000852 1
10166701 100 5.24e-6 0.0 0.0 1
10166901 0 0.0 0.0 0.0 1
*
* o-hot spot 6 (local) active fuel heat structure
*
10167000 1 5 1 0 0.0 1 8
10167400 -1
10167401 469.70 466.61 457.35 445.59 305.49
10167100 0 1
10167101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10167201 3 2 1 3 5 4
10167301 1.0 2 0.0 4
10167501 0 0 0 0.000852 1
10167601 16060000 0 1 0 0.000852 1
10167701 100 5.42e-6 0.0 0.0 1
10167901 0 0.0 0.0 0.0 1
*
* o-hot spot 7 (local) active fuel heat structure
*
10168000 1 5 1 0 0.0 1 8
10168400 -1
10168401 465.59 462.68 453.93 442.81 310.47
10168100 0 1
10168101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10168201 3 2 1 3 5 4
10168301 1.0 2 0.0 4
10168501 0 0 0 0.000852 1
10168601 16070000 0 1 0 0.000852 1
10168701 100 5.12e-6 0.0 0.0 1
10168901 0 0.0 0.0 0.0 1
*
* o-hot spot 8 (local) active fuel heat structure
*
10169000 1 5 1 0 0.0 1 8
10169400 -1
10169401 441.71 439.19 431.62 421.97 307.46
10169100 0 1
10169101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10169201 3 2 1 3 5 4
10169301 1.0 2 0.0 4
10169501 0 0 0 0.000852 1
10169601 16080000 0 1 0 0.000852 1
10169701 100 4.43e-6 0.0 0.0 1
10169901 0 0.0 0.0 0.0 1
*
* o-hot spot 9 (local) active fuel heat structure
*
10170000 1 5 1 0 0.0 1 8
10170400 -1
10170401 402.17 400.20 394.31 386.72 297.54
10170100 0 1
10170101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10170201 3 2 1 3 5 4
10170301 1.0 2 0.0 4
10170501 0 0 0 0.000852 1
10170601 16090000 0 1 0 0.000852 1
10170701 100 3.45e-6 0.0 0.0 1
10170901 0 0.0 0.0 0.0 1
*
* o-hot spot 10 (local) active fuel heat structure
*
10171000 1 5 1 0 0.0 1 8
10171400 -1
10171401 383.46 381.81 376.83 370.40 295.18
10171100 0 1
10171101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10171201 3 2 1 3 5 4
10171301 1.0 2 0.0 4
10171501 0 0 0 0.000852 1
10171601 16100000 0 1 0 0.000852 1
10171701 100 2.91e-6 0.0 0.0 1

```

```

10171901 0 0.0 0.0 0.0 1
*
* o-hot spot 11 (local) extension fuel heat structure
*
10172000 1 5 1 0 0.0 0 1 8
10172400 -1
10172401 529.55 526.17 516.06 503.17 350.13
10172100 0 1
10172101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10172201 3 2 1 3 5 4
10172301 1.0 2 0.0 4
10172501 0 0 0 0.000767 1
10172601 16110000 0 1 0 0.000767 1
10172701 100 5.33e-6 0.0 0.0 1
10172901 0 0.0 0.0 0.0 1
*
* i-control plate heat structure
*
10270000 5 7 2 0 0.722571 0
10270400 -1
10270401 154.72 160.03 162.61 175.07 160.92 158.19 152.61
10270402 172.66 181.07 185.12 204.86 182.46 178.19 169.35
10270403 181.22 190.94 195.61 218.41 192.52 187.60 177.39
10270404 176.87 185.28 189.32 209.01 186.58 182.31 173.47
10270405 158.15 162.49 164.61 174.75 163.08 160.84 156.25
10270100 0 1
10270101 1 0.722628 1 0.724667 2 0.741333 1 0.743371 1 0.743428
10270201 5 1 8 2 6 4 8 5 5 6
10270301 0 0 2 1.0 4 0.0 6
10270501 27010000 010000 1 1 0.4165 2
10270502 27030000 0 1 1 0.333 3
10270503 27040000 010000 1 1 0.4165 5
10270601 28010000 010000 1 1 0.4165 2
10270602 28030000 0 1 1 0.333 3
10270603 28040000 010000 1 1 0.4165 5
10270701 101 3.17e-2 0.0 0.0 1
10270702 101 5.02e-2 0.0 0.0 2
10270703 101 4.64e-2 0.0 0.0 3
10270704 101 5.02e-2 0.0 0.0 4
10270705 101 2.60e-2 0.0 0.0 5
10270801 0 0.0 0.0 0.0 5
10270901 0 0.0 0.0 0.0 5
*
* o-control plate heat structure
*
10280000 5 7 2 0 0.754155 0
10280400 -1
10280401 146.58 150.81 152.88 163.50 154.23 152.32 148.42
10280402 167.24 175.60 179.64 200.64 182.52 178.81 171.15
10280403 174.89 184.53 189.17 213.48 192.77 188.54 179.75
10280404 171.76 180.21 184.29 205.74 188.05 184.40 176.83
10280405 159.97 165.42 168.06 182.14 171.49 169.22 164.54

10280100 0 1
10280101 1 0.754212 1 0.75625 2 0.772917 1 0.774955 1 0.775012
10280201 5 1 8 2 6 4 8 5 5 6
10280301 0 0 2 1.0 4 0.0 6
10280501 28010000 010000 1 1 0.4165 2
10280502 28030000 0 1 1 0.333 3
10280503 28040000 010000 1 1 0.4165 5
10280601 29010000 010000 1 1 0.4165 2
10280602 29030000 0 1 1 0.333 3
10280603 29040000 010000 1 1 0.4165 5
10280701 101 2.47e-2 0.0 0.0 1
10280702 101 4.86e-2 0.0 0.0 2
10280703 101 4.47e-2 0.0 0.0 3
10280704 101 4.86e-2 0.0 0.0 4
10280705 101 3.07e-2 0.0 0.0 5
10280801 0 0.0 0.0 0.0 5
10280901 0 0.0 0.0 0.0 5
*
* hot rem be reflector heat structure
*
10290000 5 5 2 0 0.786322 0
10290400 -1
10290401 146.64 150.20 154.57 160.09 152.03
10290402 163.45 169.61 177.09 187.12 173.38
10290403 170.91 177.94 186.45 198.30 183.18
10290404 170.42 176.70 184.31 195.38 183.41
10290405 161.11 165.09 169.94 177.58 172.42
10290100 0 1
10290101 1 0.786379 1 0.7915 2 0.8241
10290201 5 1 8 2 7 4
10290301 0 0 2 1.0 4
10290501 29010000 010000 1 1 0.189 2
10290502 29030000 0 1 1 0.152 3
10290503 29040000 010000 1 1 0.189 5
10290601 30010000 010000 1 1 0.189 2
10290602 30030000 0 1 1 0.152 3
10290603 30040000 010000 1 1 0.189 5
10290701 101 1.13e-2 0.0 0.0 1
10290702 101 1.92e-2 0.0 0.0 2
10290703 101 1.73e-2 0.0 0.0 3
10290704 101 1.84e-2 0.0 0.0 4
10290705 101 1.04e-2 0.0 0.0 5
10290801 0 0.0 0.0 0.0 5
10290901 0 0.0 0.0 0.0 5
*
* rem/semi perm be reflector heat structure
*
10310000 5 4 1 0 0.0 0
10310400 -1
10310401 148.88 147.70 144.16 138.31
10310402 166.05 164.05 158.06 148.19
10310403 173.52 171.04 164.25 153.06

```

```

10310404 171.09 169.13 163.26 153.58
10310405 158.81 157.68 154.31 148.72
10310100 0 1
10310101 3 0 0.0493
10310201 7 3
10310301 1.0 3
10310501 0 0 0 13.73 2
10310502 0 0 0 10.98 3
10310503 0 0 0 13.73 5
10310601 31010000 010000 1 0 13.73 2
10310602 31030000 0 1 0 10.98 3
10310603 31040000 010000 1 0 13.73 5
10310701 101 4.22e-2 0 0 0 0 1
10310702 101 7.02e-2 0 0 0 0 2
10310703 101 6.32e-2 0 0 0 0 3
10310704 101 6.84e-2 0 0 0 0 4
10310705 101 3.98e-2 0 0 0 0 5
10310801 0 0 0 0 0 0 5
10310901 0 0 0 0 0 0 5
* i-perm be reflector heat structure
*
10320000 5 6 2 0 0.00521 0
10320400 -1
10320401 137.30 138.99 139.84 140.31 140.55 140.62
10320402 144.82 147.39 148.68 149.39 149.76 149.87
10320403 148.84 151.70 153.12 153.92 154.33 154.45
10320404 150.11 152.65 153.92 154.63 154.99 155.10
10320405 147.61 149.28 150.11 150.57 150.81 150.88
10320100 0 1
10320101 5 0.0388
10320201 7 5
10320301 1.0 5
10320501 32010000 010000 1 1 307.1 2
10320502 32030000 0 1 1 245.7 3
10320503 32040000 010000 1 1 307.1 5
10320601 0 0 1 307.1 2
10320602 0 0 1 245.7 3
10320603 0 0 1 307.1 5
10320701 101 3.11e-2 0 0 0 0 1
10320702 101 4.67e-2 0 0 0 0 2
10320703 101 4.13e-2 0 0 0 0 3
10320704 101 4.59e-2 0 0 0 0 4
10320705 101 3.02e-2 0 0 0 0 5
10320801 0 0 0 0 0 0 5
10320901 0 0 0 0 0 0 5
* o-perm be reflector heat structure
*
10360000 5 6 2 0 0.00521 0
10360400 -1
10360401 148.92 154.76 157.05 158.18 158.67 158.70

```

```

10360402 160.65 168.67 171.80 173.35 173.99 174.00
10360403 166.88 175.55 178.93 180.59 181.27 181.25
10360404 168.95 176.65 179.64 181.09 181.67 181.61
10360405 165.36 170.58 172.59 173.55 173.90 173.82
10360100 0 1
10360101 5 0.0982
10360201 7 5
10360301 1.0 5
10360501 36010000 010000 1 1 39.2 2
10360502 36030000 0 1 1 31.3 3
10360503 36040000 010000 1 1 39.2 5
10360601 33010000 0 4200 1 39.2 2
10360602 33010000 0 4200 1 31.3 3
10360603 33010000 0 4200 1 39.2 5
10360701 101 9.60e-3 0 0 0 0 1
10360702 101 1.33e-2 0 0 0 0 2
10360703 101 1.16e-2 0 0 0 0 3
10360704 101 1.32e-2 0 0 0 0 4
10360705 101 9.41e-3 0 0 0 0 5
10360801 0 0 0 0 0 0 5
10360901 0 0 0 0 0 0 5
*
* 6061-al lower plenum-2 heat structure
*
10090000 1 5 2 0 1.684988 0
10090400 -1
10090401 141.80 141.71 140.79 139.89 139.81
10090100 0 1
10090101 1 1.685045 2 1.768288 1 1.768345
10090201 5 1 8 3 5 4
10090301 0.0 4
10090501 9010000 0 1 1 2.6 1
10090601 35010000 0 4300 1 2.6 1
10090701 0 0 0 0 0 0 1
10090801 0 0 0 0 0 0 1
10090901 0 0 0 0 0 0 1
*
* 3041-ss lower plenum-2 heat structure
*
10091000 1 4 2 0 1.715 0
10091400 -1
10091401 144.56 141.63 138.73 135.85
10091100 0 1
10091101 3 1.769
10091201 10 3
10091301 0.0 3
10091501 9010000 0 1 1 0.92 1
10091601 35010000 0 4300 1 0.92 1
10091701 0 0 0 0 0 0 1
10091801 0 0 0 0 0 0 1
10091901 0 0 0 0 0 0 1
*

```



```
*****
*
* primary piping
*
*
*
*
*****
* * 18" pipe exiting reactor vessel
*
0500000 pipeta pipe
0500001 3
0500101 1.553 3
0500301 4.146 1 16.402 2 3. 3
0500601 0.17468 1 90. 2 0. 3
0500701 0.0091 1 13.8402 2 0. 3
0500801 1.5e-4 1.40633 3
0500901 .17 .17 2
0501001 0 3
0501101 31000 2
0501201 3 .28898e+03 162.05 0. 0. 0. 1
0501202 3 .28497e+03 161.96 0. 0. 0. 2
0501203 3 .28098e+03 161.95 0. 0. 0. 3
0501300 1
0501301 2.3601e+03 0. 0. 1
0501302 2.3601e+03 0. 0. 2
*
* wye on 18" line to cell 110 (d)
*
0510000 wye-1a branch
0510001 3 1
0510101 1.553 27.8385 0. 0. 0.17468 0.0849 1.5e-4 1.40633 0
0510200 3 .28039e+03 161.950
0511101 050010000 051000000 1.533 0.0 0.0 1000
0511201 2.3601e+03 0. 0.
0512101 051010000 052000000 0.4989 0.878 0.69 1000
0512201 7.8003e+02 0. 0.
0513101 051010000 053000000 1.533 0.0 0.086 1000
0513201 1.5800e+03 0. 0.
*
* break 6 reactor vessel outlet
*
* for 0.5" break area= .0013635
* for 1.0" break area= .0054542
* for 1.5" break area= .0122718
* for 2.0" break area= .0218166
* for 2.5" break area= .0340885
* for 3.0" break area= .0490874
*
5120000 bk6-vlv valve
5120101 050010002 513000000 0.0122718 0. 0. 31100
*****
```

```

0770200 3 .43908e+03 127.410
0771101 275010000 077000000 1.9305 0. 0. 1000
0771201 8.0848e+02 0. 0.
0772101 375010000 077000000 0.4989 0. 0. 1000
0772201 -3.9467e-05 0. 0.
*
* wye on 20" line from cell 111 (c)
*
0760000 wye-1b branch
0760001 2 1
0760101 1.9305 16. 0. 0. -.190327 -.05315 1.5e-4 1.56783 0
0760200 3 .43819e+03 126.670
0761101 175010000 076000000 0.4989 0.77 0.49 1000
0761201 7.6054e+02 0. 0.
0762101 077010000 076000000 0. 0. 0. 1000
0762201 8.0848e+02 0. 0.
*
* wye on 20" line from cell 110 (d)
*
0790000 wye-2b branch
0790001 4 1
0790101 1.9305 7.3073 0. 0. -.190327 -.0242 1.5e-4 1.56783 0
0790200 3 .43664e+03 126.200
0791101 075010000 079000000 0.4989 0.72 0.60 1000
0791201 7.7452e+02 0. 0.
0792101 076010000 079000000 1.9305 0. 0. 1000
0792201 1.5690e+03 0. 0.
0793101 079010000 080000000 1.9305 0.17 0.17 1000
0793201 2.3600e+03 0. 0.
0794101 089010000 079000000 0. 0. 0.0 1101
0794201 1.6650e+01 0. 0.
*
* break 5 orifice pressurizing line
*
* for 0.5" break area= .0013635
* for 1.0" break area= .0054542
* for 1.5" break area= .0122718
* for 2.0" break area= .0218166
* for 2.5" break area= .0340885
* for 3.0" break area= .0490874
*
5100000 bk5-vlv valve
5100101 079010000 511000000 0.0122718 0. 0. 31100
5100201 1 0.0000e+00 0. 0.
5100300 trpvlv
5100301 598
*
* break 5 sink
*
5110000 air-b5s tmdpvov
5110101 1. 1. 0. 0. 0. 0. 1.d-6 1. 10
5110200 4 0

```

```

5110201 0.00 14.7 75. 1. 1.e6 14.7 75. 1.
*
* leakage from the system
*
0840000 leaktdj tmdplun
0840101 079010000 083000000 0.
0840200 1 590 cntrlvar 47
0840201 -2. 0. 0. 0.
0840202 0. 0. 0. 0.
0840203 1.e6 1.e6 0. 0.
*
* leakage time-dependent volume (sink)
*
0830000 leaktdv tmdpvov
0830101 1. 10. 10. 0.0 0.0 0.0 1.5e-4 1. 10
0830200 3
0830201 0.0 25. 100.
*
* 20" pipe between the wye from cell 110 and the strainer
* this section of pipe includes the venturi meter
*
0800000 pipe1b pipe
0800001 4
0800101 1.9305 1 0.85836 2 1.9305 4
0800301 22.2916 1 5.34375 2 9.9375 3 3. 4
0800601 -.178377 1 -.167710 2 -.167710 3 0. 4
0800701 -.0671 1 -.01564 2 -.03787 3 0. 4
0800801 1.5e-4 1.56783 1 1.5e-4 1.04542 2 1.5e-4 1.56783 4
0800901 0.1 0.1 2 0. 0. 3
0801001 0 4
0801101 01000 3
0801201 3 .43586e+03 126.20 0. 0. 0. 1
0801202 3 .42325e+03 126.20 0. 0. 0. 2
0801203 3 .43199e+03 126.20 0. 0. 0. 3
0801204 3 .43186e+03 126.20 0. 0. 0. 4
0801300 1
0801301 2.3600e+03 0. 0. 1
0801302 2.3600e+03 0. 0. 2
0801303 2.3600e+03 0. 0. 3
*
* junction at strainer inlet: sharp 90 degree turn with a recess
*
0820000 jtostr sngljun
0820101 080010000 081000000 1.9305 2.915 2.915 31001
0820201 1 2.3600e+03 0. 0.
*
* top volume in strainer housing
* note: fluid in the strainer housing has been apportioned into top
* and bottom volumes separated by the strainer
*
0810000 strtov snglvov
0810101 1.9305 2.5 0. 0. -.90. -2.5 1.5e-4 1.56783 0

```

```

0810200 3 .42681e+03 126.190
*
* bottom volume in the strainer housing
*
0900000 strbot branch
0900001 3 1
0900101 1.9305 2.91767 0. 0. -90. -2.91767 1.5e-4 1.56783 0
0900200 3 .42303e+03 126.190
*
* both the perforated plate and screen loss coefficients are
* based on total surface area of the strainer.
*
0901101 081010000 0900000000 9.773 22. 22. 31000
0901201 2.3600e+03 0. 0.
0902101 090010000 0910000000 1.2272 2.915 2.915 31000
0902201 1.1800e+03 0. 0.
0903101 090010000 0920000000 1.2272 2.915 2.915 31000
0903201 1.1800e+03 0. 0.
*
* horizontal inlet pipes to reactor vessel
*
0910000 tore-1 pipe
0910001 3
0910101 1.2272 3
0910301 3.9890 1 4.833 2 5.5166 3
0910601 0. 3
0910801 1.5e-4 1.25 3
0910901 .1 .1 1 .25 .25 2
0911001 0 3
0911101 01000 2
0911201 3 .41988e+03 126.18 0. 0. 0. 1
0911202 3 .41963e+03 126.17 0. 0. 0. 2
0911203 3 .41913e+03 126.16 0. 0. 0. 3
0911300 1
0911301 1.1800e+03 0. 0. 1
0911302 1.1800e+03 0. 0. 2
*
0920000 tore-2 pipe
0920001 3
0920101 1.2272 3
0920301 3.9890 1 4.833 2 5.5166 3
0920601 . 3
0920801 1.5e-4 1.25 3
0920901 .1 .1 1 .25 .25 2
0921001 0 3
0921101 01000 2
0921201 3 .41988e+03 126.18 0. 0. 0. 1
0921202 3 .41963e+03 126.17 0. 0. 0. 2
0921203 3 .41913e+03 126.16 0. 0. 0. 3
0921300 1
0921301 1.1800e+03 0. 0. 1
0921302 1.1800e+03 0. 0. 2
*
*****
*
* heat exchanger cell 110 (d)
*
*****
*
* 10" pipe from the tunnel to the 14" expansion
* initial leg of this pipe is schedule 80
*
0520000 toexd pipe
0520001 4
0520101 .4989 1 .5476 4
0520301 3.5282 1 9.9791 2 8.2917 3 10.3017 4
0520601 .12687 1 .28392 2 1.28263 3 -.05784 4
0520701 .0078125 1 .04945 2 .18564 3 -.0104 4
0520801 1.5e-4 0.797 1 1.5e-4 0.835 4
0520901 0.1 0.1 1 0.19 0.19 2 .13 .13 3
0521001 0 4
0521101 01100 1
0521102 01000 3
0521201 3 .27602e+03 161.95 0. 0. 0. 1
0521202 3 .27583e+03 161.95 0. 0. 0. 2
0521203 3 .27454e+03 161.95 0. 0. 0. 3
0521204 3 .27346e+03 161.96 0. 0. 0. 4
0521300 1
0521301 7.8003e+02 0. 0. 1
0521302 7.8003e+02 0. 0. 2
0521303 7.8003e+02 0. 0. 3
*
0580000 j52-57 sngl jun
0580101 052010000 0570000000 0.5476 0.0876 0.0734 1000
0580201 1 7.8003e+02 0. 0.
*
* 14 in. inlet pipe to heat exchanger
*
0570000 ldoffd branch
0570001 1 1
0570101 .93943 3.1772 0. 0. 0. 0. 1.5e-4 1.09367 0
0570200 3 .27518e+03 161.960
0571101 057010000 1130000000 0.93943 0. 0. 31100
0571201 7.8003e+02 0. 0.
*
* break 3 orifice upstream of heat exchanger in cell d
*
* for 0.5" break area= .0013635
* for 1.0" break area= .0054542
* for 1.5" break area= .0122718
* for 2.0" break area= .0218166

```

```

* for 2.5" break area= .0340885
* for 3.0" break area= .0490874
*
5060000 bk3-vlv valve
5060101 057010000 507000000 0.0122718 0. 0. 31100
5060201 1 0.0000e+00 0. 0.
5060300 trpvlv
5060301 596
*
* break 3 sink
*
5070000 air-b3s tmpdvol
5070101 1. 1. 0. 0. 0. 1.d-6 1. 10
5070200 4 0
5070201 0.00 14.7 75. 1. 1.e6 14.7 75. 1.
*
* inlet plenum to exchanger in cell 110
*
1130000 hxdpln snglvol
1130101 4.016 1.9583 0. 0. -90. -1.9583 1.5e-4 2.3931 0
1130200 3 .27600e+03 161.960
*
* inlet to exchanger tubing in cell 110
*
0970000 hxdin snglvol
0970101 113010000 100000000 2.016 1.455 2.0 31000
0970201 1 7.8003e+02 0. 0.
*
* heat exchanger d
*
* pipes 100, 101, 104, and 105 are linked in series making
* up the primary flow side of the exchanger
*
1000000 prim-d1 pipe
1000001 5
1000101 2.016 5
1000301 2.96055 5
1000601 -90. 5
1000801 5.e-6 .04625 5
1001001 0 5
1001101 31000 4
1001201 3 .27626e+03 158.86 0. 0. 0. 1
1001202 3 .27711e+03 156.57 0. 0. 0. 2
1001203 3 .27796e+03 154.89 0. 0. 0. 3
1001204 3 .27881e+03 153.67 0. 0. 0. 4
1001205 3 .27967e+03 152.78 0. 0. 0. 5
1001300 1
1001301 7.8003e+02 0. 0. 1
1001302 7.8003e+02 0. 0. 2
1001303 7.8003e+02 0. 0. 3
1001304 7.8003e+02 0. 0. 4
*
1160000 pd1-d2 snglvol
1160101 100010000 101000000 2.016 0 0 31000
1160201 1 7.8003e+02 0. 0.
*
1010000 prim-d2 pipe
1010001 5
1010101 2.016 5
1010301 2.96055 5
1010601 -90. 5
1010801 5.e-6 .04625 5
1011001 0 5
1011101 31000 4
1011201 3 .28052e+03 151.93 0. 0. 0. 1
1011202 3 .28137e+03 150.93 0. 0. 0. 2
1011203 3 .28223e+03 149.77 0. 0. 0. 3
1011204 3 .28308e+03 148.43 0. 0. 0. 4
1011205 3 .28393e+03 146.86 0. 0. 0. 5
1011300 1
1011301 7.8003e+02 0. 0. 1
1011302 7.8003e+02 0. 0. 2
1011303 7.8003e+02 0. 0. 3
1011304 7.8003e+02 0. 0. 4
*
1170000 pd2-d3 snglvol
1170101 101010000 104000000 2.016 0 0 31000
1170201 1 7.8003e+02 0. 0.
*
1040000 prim-d3 pipe
1040001 5
1040101 2.016 5
1040301 2.96055 5
1040601 90. 5
1040801 5.e-6 .04625 5
1041001 0 5
1041101 31000 4
1041201 3 .28352e+03 145.05 0. 0. 0. 1
1041202 3 .28185e+03 142.97 0. 0. 0. 2
1041203 3 .28018e+03 140.58 0. 0. 0. 3
1041204 3 .27850e+03 137.86 0. 0. 0. 4
1041205 3 .27683e+03 134.79 0. 0. 0. 5
1041300 1
1041301 7.8003e+02 0. 0. 1
1041302 7.8003e+02 0. 0. 2
1041303 7.8003e+02 0. 0. 3
1041304 7.8003e+02 0. 0. 4
*
1180000 pd2-d3 snglvol
1180101 104010000 105000000 2.016 0. 0. 31000
1180201 1 7.8003e+02 0. 0.
*
1050000 prim-d4 pipe
1050001 5

```

```

1050101 2.016 5
1050301 2.96055 5
1050601 90. 5
1050801 5.e-6 .04625 5
1051001 0 5
1051101 31000 4
1051201 3 .27515e+03 131.93 0. 0. 0. 1
1051202 3 .27347e+03 129.75 0. 0. 0. 2
1051203 3 .27178e+03 128.11 0. 0. 0. 3
1051204 3 .27010e+03 126.88 0. 0. 0. 4
1051205 3 .26841e+03 125.96 0. 0. 0. 5
1051300 1
1051301 7.8003e+02 0. 0. 1
1051302 7.8003e+02 0. 0. 2
1051303 7.8003e+02 0. 0. 3
1051304 7.8003e+02 0. 0. 4
*
* heat structures connecting the secondary and primary sides
* of the exchanger d (cell 110)
*
11002000 5 3 2 0 .023125 0 0 0
11002400 -1
11002401 150.39 147.78 145.32
11002402 150.26 148.33 146.51
11002403 150.24 148.82 147.49
11002404 150.25 149.22 148.25
11002405 150.29 149.54 148.83
11002100 0 1
11002101 2 .02604
11002201 10 2
11002301 0. 2
11002501 100010000 010000 1 1 3555.62 5
11002601 102010000 010000 1 1 3555.62 5
11002701 0 0 0 0 0 0 5
11002801 0 0 0 0 0 0 5
11002901 0 0 0 0 0 0 5
*
11012000 5 3 2 0 .023125 0 0 0
11012400 -1
11012401 149.54 148.83 148.15
11012402 148.14 147.30 146.51
11012403 146.50 145.52 144.60
11012404 144.60 143.46 142.39
11012405 142.39 141.07 139.82
11012100 0 1
11012101 2 .02604
11012201 10 2
11012301 0. 2
11012501 101010000 010000 1 1 3555.62 5
11012601 103050000 -010000 1 1 3555.62 5
11012701 0 0 0 0 0 0 5
11012801 0 0 0 0 0 0 5
*
11012901 0 0 0 0 0 0 5
*
11012000 5 3 2 0 .023125 0 0 0
11012400 -1
11012401 139.85 138.32 136.88
11012402 136.94 135.17 133.51
11012403 133.61 131.59 129.68
11012404 129.84 127.53 125.35
11012405 125.62 123.01 120.54
11012100 0 1
11012101 2 .02604
11012201 10 2
11012301 0. 2
11012501 104010000 010000 1 1 3555.62 5
11012601 106050000 -010000 1 1 3555.62 5
11012701 0 0 0 0 0 0 5
11012801 0 0 0 0 0 0 5
11012901 0 0 0 0 0 0 5
*
11032000 5 3 2 0 .023125 0 0 0
11032400 -1
11032401 123.29 120.85 118.55
11032402 123.12 121.26 119.51
11032403 123.07 121.67 120.35
11032404 123.08 122.03 121.04
11032405 123.11 122.33 121.59
11032100 0 1
11032101 2 .02604
11032201 10 2
11032301 0. 2
11032501 105010000 010000 1 1 3555.62 5
11032601 107010000 010000 1 1 3555.62 5
11032701 0 0 0 0 0 0 5
11032801 0 0 0 0 0 0 5
11032901 0 0 0 0 0 0 5
*
* outlet from tubing in heat exchanger 1d
*
0980000 hxdou snljun
0980101 105010000 11400000 2.016 2.0 1.455 31000
0980201 1 7.8003e+02 0. 0.
*
* outlet plenum from exchanger in cell 110
*
1140000 hxdplou branch
1140001 1 1
1140101 4.016 1.9583 0. 0. 90. 1.9583 1.5e-4 2.3931 0
1140200 3 .26682e+03 125.960
1141101 114010000 06200000 0.0233 0.5 1. 31002
1141201 5.5071e+00 0. 0.
*
* outlet from exchanger in cell 110

```

```

*
1150000 hxdou sngljun
1150101 1140100n0 060000000 0.93943 0. 0. 31100
1150201 1 7.7452e+02 0. 0.
*
* 14" pipe between the heat exchanger and the main circulating pump
*
0600000 diocmp pipe
0600001 3
0600101 .93943 3
0600301 2.4480 1 3.9477 2 3.9573 3
0600601 0. 2 90. 3
0600701 0. 2 2.9584 3
0600801 1.5e-4 1.09367 3
0600901 0.1 0.1 1 0.18 0.18 2
0601001 0 3
0601101 01000 2
0601201 3 .26483e+03 125.96 0. 0. 0. 1
0601202 3 .26466e+03 125.96 0. 0. 0. 2
0601203 3 .26375e+03 125.96 0. 0. 0. 3
0601300 1
0601301 7.7452e+02 0. 0. 1
0601302 7.7452e+02 0. 0. 2
*
* break 2 orifice on suction side of mcp d
*
* for 0.5" break area= .0013635
* for 1.0" break area= .0054542
* for 1.5" break area= .0122718
* for 2.0" break area= .0218166
* for 2.5" break area= .0340885
* for 3.0" break area= .0490874
*
5040000 bk2-vlv valve
5040101 060010000 505000000 0.0122718 0. 0. 31100
5040201 1 0.0000e+00 0. 0.
5040300 trpvlv
5040301 595
*
* break 2 sink
*
5050000 air-b2s tmdpv0l
5050101 1. 1. 0. 0. 0. 1.d-6 1. 10
5050200 4 0
5050201 0.00 14.7 75. 1. 1.e6 14.7 75. 1.
*
* main circulation pump d
*
0700000 d-primy pump
0700101 0.9394 1. 0. 0. 0. 0.
0700108 060010000 0. 0. 0. 31000
0700109 073000000 0. 0. 0. 1000
0700200 3 .35466e+03 126.140
0700201 1 7.7452e+02 0. 0.
0700202 1 7.7452e+02 0. 0.
0700301 0 0 -1 -1 0 0
0700302 1786. 1.08359 5000. 366.3 1361.2 468. 62.2 0. 300. 20. 50. 0.
* han
0701100 1 1 0.000 1.12 0.199 1.112 0.399 1.084
0701102 0.599 1.072 0.794 1.037 1.000 1.00
* hvn
0701200 1 2 0. -0.3 0.511 0.148 0.542 0.193 0.579 0.243
0701201 0.623 0.300 0.708 0.429 0.826 0.635 1. 1.
* had homologous data taken from bingham pump in relap
0701300 1 3 -1. 2.5 -9 2.28 -.63 2. -.55 1.74
0701301 -.5 1.68 -.42 1.6 -.15 1.4 0. 1.12
* hvd homologous data taken from bingham pump in relap
0701400 1 4 -1. 2.5 -.9 2.28 -.63 2. -.55 1.74
0701401 -.5 1.68 -.42 1.6 -.15 1.4 0. 1.3
* ban
0701500 2 1 n.000 0.00 0.199 0.223 0.399 0.432
0701502 0.599 0.642 0.794 0.821 1.000 1.00
* lvn
0701600 2 2 0.511 0.290 0.542 0.353 0.579 0.417
0701601 0.623 0.479 0.708 0.603 0.826 0.768 1. 1.
* bad homologous data taken from bingham pump in relap
0701700 2 3 -1. 2.5 -.8 2. -.6 1.45 -.46 1.15
0701701 -.3 .95 -.13 .8 0. .8
* bvd homologous data taken from bingham pump in relap
0701800 2 4 -1. 2.5 -.65 2.15 -.4 1.79 -.30 1.61
0701801 -.13 1.5 0. 1.44
* multipliers
0703000 0.0 0.0 0.0 0.1 0.0 0.15 0.05 0.24 0.80
0703001 0.30 0.96 0.40 0.98 0.60 0.97 0.80 0.90
0703002 0.90 0.80 0.96 0.50 1.00 0.0
0703100 0.0 0.0 0.0 0.1 0.0 0.15 0.05 0.24 0.80
0703101 0.30 0.96 0.40 0.98 0.60 0.97 0.80 0.90
0703102 0.90 0.80 0.96 0.50 1.00 0.0
0706100 529 cntrlvar 189
0706101 0. 0.
0706102 1.e6 1.e6
*
* 10" pipe from the main circulation pump to the check valve
*
0730000 pudout branch
0730001 0 1
0730101 .5476 1.0 0. 0. 0. 1.5e-4 0.835 0
0730200 3 .44390e+03 126.180
*
* break 1 orifice on discharge side of mcp d
*
* for 0.5" break area= .0013635
* for 1.0" break area= .0054542
* for 1.5" break area= .0122718

```



```

* heat exchanger c
*
* pipes 200, 201, 204, and 205 are linked in series making
* up the primary flow side of the exchanger
*
2000000 prim-c1 pipe
2000001 5
200101 2.016 5
200301 2.96055 5
200601 -90. 5
200801 5.e-6 .04625 5
201001 0 5
201101 31000 4
201201 3 .27542e+03 158.81 0. 0. 0. 1
201202 3 .27629e+03 156.49 0. 0. 0. 2
201203 3 .27715e+03 154.79 0. 0. 0. 3
201204 3 .27802e+03 153.55 0. 0. 0. 4
201205 3 .27888e+03 152.65 0. 0. 0. 5
201300 1
201301 7.6604e+02 0. 0. 1
201302 7.6604e+02 0. 0. 2
201303 7.6604e+02 0. 0. 3
201304 7.6604e+02 0. 0. 4
*
2160000 pc1-c2 sngl jun
2160101 200010000 201000000 2.016 0. 0. 31000
2160201 1 7.6604e+02 0. 0.
*
2010000 prim-c2 pipe
2010001 5
2010101 2.016 5
2010301 2.96055 5
2010601 -90. 5
2010801 5.e-6 .04625 5
2011001 0 5
201101 31000 4
2011201 3 .27975e+03 151.79 0. 0. 0. 1
2011202 3 .28062e+03 150.78 0. 0. 0. 2
2011203 3 .28148e+03 149.60 0. 0. 0. 3
2011204 3 .28235e+03 148.24 0. 0. 0. 4
2011205 3 .28321e+03 146.66 0. 0. 0. 5
2011300 1
2011301 7.6604e+02 0. 0. 1
2011302 7.6604e+02 0. 0. 2
2011303 7.6604e+02 0. 0. 3
2011304 7.6604e+02 0. 0. 4
*
2170000 pc2-c3 sngl jun
2170101 201010000 204000000 2.016 0. 0. 31000
2170201 1 7.6604e+02 0. 0.
*
2040000 prim-c3 pipe
2040001 5
2040101 2.016 5
2040301 2.96055 5
2040601 90. 5
2040801 5.e-6 .04625 5
2041001 0 5
2041101 31000 4
2041201 3 .28282e+03 144.83 0. 0. 0. 1
2041202 3 .28116e+03 142.73 0. 0. 0. 2
2041203 3 .27950e+03 140.33 0. 0. 0. 3
2041204 3 .27784e+03 137.60 0. 0. 0. 4
2041205 3 .27618e+03 134.51 0. 0. 0. 5
2041300 1
2041301 7.6604e+02 0. 0. 1
2041302 7.6604e+02 0. 0. 2
2041303 7.6604e+02 0. 0. 3
2041304 7.6604e+02 0. 0. 4
*
2180000 cd2-c3 sngl jun
2180101 204010000 205000000 2.016 0. 0. 31000
2180201 1 7.6604e+02 0. 0.
*
2050000 prim-c4 pipe
2050001 5
2050101 2.016 5
2050301 2.96055 5
2050601 90. 5
2050801 5.e-6 .04625 5
2051001 0 5
2051101 31000 4
2051201 3 .27451e+03 131.64 0. 0. 0. 1
2051202 3 .27284e+03 129.45 0. 0. 0. 2
2051203 3 .27117e+03 127.80 0. 0. 0. 3
2051204 3 .26950e+03 126.57 0. 0. 0. 4
2051205 3 .26783e+03 125.65 0. 0. 0. 5
2051300 1
2051301 7.6604e+02 0. 0. 1
2051302 7.6604e+02 0. 0. 2
2051303 7.6604e+02 0. 0. 3
2051304 7.6604e+02 0. 0. 4
*
* heat structures connecting the secondary and primary sides
* of the exchanger c (cell 111)
*
12002000 5 3 2 0 .023125 0 0 0
12002400 -1
12002401 150.25 147.65 145.19
12002402 150.11 148.19 146.38
12002403 150.08 148.68 147.35
12002404 150.10 149.08 148.11
12002405 150.13 149.39 148.69

```



```

12022100 0 1
12022101 2 .02604
12022201 10 2
12022301 0. 2
12022501 200010000 010000 1 1 3555.62 5
12022601 202010000 010000 1 1 3555.62 5
12022701 0 0 0 0 0 0 5
12022801 0 0 0 0 0 0 5
12022901 0 0 0 0 0 0 5
*
12022000 5 3 2 0 .023125 0 0 0
12022400 -1
12022401 149.37 148.66 147.99
12022402 147.95 147.12 146.33
12022403 146.30 145.33 144.41
12022404 144.38 143.25 142.19
12022405 142.16 140.85 139.61
12022100 0 1
12022101 2 .02604
12022201 10 2
12022301 0. 2
12022501 201010000 010000 1 1 3555.62 5
12022601 203050000 -010000 1 1 3555.62 5
12022701 0 0 0 0 0 0 5
12022801 0 0 0 0 0 0 5
12022901 0 0 0 0 0 0 5
*
12022000 5 3 2 0 .023125 0 0 0
12022400 -1
12022401 139.60 138.09 136.66
12022402 136.67 134.93 133.28
12022403 133.33 131.33 129.44
12022404 129.55 127.27 125.12
12022405 125.32 122.74 120.30
12022100 0 1
12022101 2 .02604
12022201 10 2
12022301 0. 2
12022501 204010000 010000 1 1 3555.62 5
12022601 206050000 -010000 1 1 3555.62 5
12022701 0 0 0 0 0 0 5
12022801 0 0 0 0 0 0 5
12022901 0 0 0 0 0 0 5
*
12032000 5 3 2 0 .023125 0 0 0
12032400 -1
12032401 122.98 120.57 118.30
12032402 122.81 120.98 119.25
12032403 122.76 121.39 120.09
12032404 122.77 121.74 120.77
12032405 122.80 122.03 121.31
12032100 0 1

12032101 2 .02604
12032201 10 2
12032301 0. 2
12032501 205010000 010000 1 1 3555.62 5
12032601 207010000 010000 1 1 3555.62 5
12032701 0 0 0 0 0 0 5
12032801 0 0 0 0 0 0 5
12032901 0 0 0 0 0 0 5
*
* outlet from tubing in heat exchanger 1c
*
1980000 hxcou engl jun
1980101 205010000 214000000 2.016 2.0 1.455 31000
1980201 1 7.6604e+02 0. 0.
*
* outlet plenum from exchanger in cell 111
*
2140000 hxcplou branch
2140001 1 1
2140101 4.016 1.9583 0. 0. 90. 1.9583 1.5e-4 2.3931 0
2140200 3 .26626e+03 125.650
2141101 214010000 162000000 0.0233 0.5 1. 31002
2141201 5.5009e+00 0. 0.
*
* outlet from exchanger in cell 111
*
2150000 hxcou engl jun
2150101 214010000 160000000 0.93943 0. 0. 31100
2150201 1 7.6054e+02 0. 0.
*
* 14" pipe between the heat exchanger and the main circulating pump
*
1600000 ctomp pipe
1600001 3
1600101 .93943 3
1600301 2.4480 1 3.9477 2 3.9573 3
1600601 0. 2 90. 3
1600701 0. 2 2.9584 3
1600801 1.5e-4 1.09367 3
1600901 0.1 0.1 1 0.18 0.18 2
1601001 0 3
1601101 01000 2
1601201 3 .26432e+03 125.65 0. 0. 0. 1
1601202 3 .26415e+03 125.65 0. 0. 0. 2
1601203 3 .26325e+03 125.65 0. 0. 0. 3
1601300 1
1601301 7.6054e+02 0. 0. 1
1601302 7.6054e+02 0. 0. 2
*
* main circulation pump c
*
1700000 c-prime pump

```

```

1700101 0.9394 1. 0. 0. 0. 0. 0.
1700108 160010000 0. 0. 0. 0. 31000
1700109 173000000 0. 0. 0. 0. 1000
1700200 3 -.35446e+03 125.840
1700201 1 7.6054e+02 0. 0.
1700202 1 7.6054e+02 0. 0.
1700301 70 70 -1 -1 0 0 0
1700302 1786. 1.08359 5000. 366.3 1361.2 468. 62.2 0. 300. 20. 50. 0.
1706100 529 entrivar 191
1706101 0. 0.
1706102 1.e6 1.e6
*
* 10" pipe from the main circulation pump to the check valve
*
1730000 pucout pipe
1730001 1
1730101 .5476 1
1730301 1. 1
1730601 0. 1
1730801 1.5e-4 0.835 1
1731001 0 1
1731201 3 .44408e+03 125.88 0. 0. 0. 1
*
* check valve in the cell 111
*
1740000 c-check valve
1740101 173010000 175000000 0.5476 0.65 0. 31000
1740201 1 7.6054e+02 0. 0.
1740300 chkvlv
1740301 0 0. 0.
*
* pipe returning from check valve in cell 111 (c) to the pipe tunnel
*
1750000 ctotun pipe
1750001 4
1750101 0.5476 3 0.4989 4
1750301 2.29165 1 10.8385 2 5.22917 3 2.82843 4
1750601 0. 1 -0.27996 2 -1.4738 3 -1.47675 4
1750701 0. 1 -.05296 2 -.13454 3 -.07292 4
1750801 1.5e-4 0.835 3 1.5e-4 0.797 4
1750901 0.13 0.13 1 0.19 0.19 2 0.10 0.10 3
1751001 0 4
1751101 01000 2
1751102 01100 3
1751201 3 .44179e+03 125.88 0. 0. 0. 1
1751202 3 .44097e+03 125.88 0. 0. 0. 2
1751203 3 .43989e+03 125.88 0. 0. 0. 3
1751204 3 .43853e+03 125.88 0. 0. 0. 4
1751300 1
1751301 7.6054e+02 0. 0. 1
1751302 7.6054e+02 0. 0. 2
1751303 7.6054e+02 0. 0. 3
*****

1700101 0.9394 1. 0. 0. 0. 0. 0.
1700108 160010000 0. 0. 0. 0. 31000
1700109 173000000 0. 0. 0. 0. 1000
1700200 3 -.35446e+03 125.840
1700201 1 7.6054e+02 0. 0.
1700202 1 7.6054e+02 0. 0.
1700301 70 70 -1 -1 0 0 0
1700302 1786. 1.08359 5000. 366.3 1361.2 468. 62.2 0. 300. 20. 50. 0.
1706100 529 entrivar 191
1706101 0. 0.
1706102 1.e6 1.e6
*
* 10" pipe from the main circulation pump to the check valve
*
1730000 pucout pipe
1730001 1
1730101 .5476 1
1730301 1. 1
1730601 0. 1
1730801 1.5e-4 0.835 1
1731001 0 1
1731201 3 .44408e+03 125.88 0. 0. 0. 1
*
* check valve in the cell 111
*
1740000 c-check valve
1740101 173010000 175000000 0.5476 0.65 0. 31000
1740201 1 7.6054e+02 0. 0.
1740300 chkvlv
1740301 0 0. 0.
*
* pipe returning from check valve in cell 111 (c) to the pipe tunnel
*
1750000 ctotun pipe
1750001 4
1750101 0.5476 3 0.4989 4
1750301 2.29165 1 10.8385 2 5.22917 3 2.82843 4
1750601 0. 1 -0.27996 2 -1.4738 3 -1.47675 4
1750701 0. 1 -.05296 2 -.13454 3 -.07292 4
1750801 1.5e-4 0.835 3 1.5e-4 0.797 4
1750901 0.13 0.13 1 0.19 0.19 2 0.10 0.10 3
1751001 0 4
1751101 01000 2
1751102 01100 3
1751201 3 .44179e+03 125.88 0. 0. 0. 1
1751202 3 .44097e+03 125.88 0. 0. 0. 2
1751203 3 .43989e+03 125.88 0. 0. 0. 3
1751204 3 .43853e+03 125.88 0. 0. 0. 4
1751300 1
1751301 7.6054e+02 0. 0. 1
1751302 7.6054e+02 0. 0. 2
1751303 7.6054e+02 0. 0. 3
*****

*****
*
* heat exchanger cell 112 (b)
*
*****
*
* 10" pipe from the tunnel to the closed gate valve
*
* Initial leg of this pipe is schedule 80
*
3520000 toexb pipe
3520001 3
3520101 .4989 1 .5476 3
3520301 2.8284 1 7.4843 2 8.2917 3
3520601 .1580 1 .2885 2 .4111 3
3520701 .0078 1 .0377 2 .0595 3
3520801 1.5e-4 0.797 1 1.5e-4 0.835 3
3520901 0.10 0.10 1 0.19 0.19 2
3521001 0 3
3521101 01100 1
3521102 01000 2
3521201 3 .28341e+03 140.36 0. 0. 0. 1
3521202 3 .28340e+03 139.92 0. 0. 0. 2
3521203 3 .28338e+03 139.92 0. 0. 0. 3
3521300 1
3521301 -2.1178e-05 0. 0. 1
3521302 -8.8259e-06 0. 0. 2
*
* pipe returning from check valve in cell 112 (b) to the pipe tunnel
*
3750000 btotun pipe
3750001 3
3750101 0.5476 2 0.4989 3
3750301 10.8385 1 5.22917 2 2.82843 3
3750601 -0.27996 1 -1.4738 2 -0.421948 3
3750701 -.05296 1 -.13454 2 -.020833 3
3750801 1.5e-4 0.835 2 1.5e-4 0.797 3
3750901 0.19 0.19 1 0.10 0.10 2
3751001 0 3
3751101 01000 1
3751102 01100 2
3751201 3 .43930e+03 139.99 0. 0. 0. 1
3751202 3 .43934e+03 139.99 0. 0. 0. 2
3751203 3 .43937e+03 139.51 0. 0. 0. 3
3751300 1
3751301 -1.2138e-05 0. 0. 1
3751302 -2.6967e-05 0. 0. 2
*
*****

```

```

*
*
*      h e a t   e x c h a n g e r   c e l l   1 1 3   ( a )
*
*
*
*
*
*****
* 10" pipe from the tunnel to the 14" expansion
* initial leg of this pipe is schedule 80
*
2520000 toexa pipe
2520001 4
2520101 1.553 1 0.5476 4
2520301 3.125 1 22.3593 2 10.29165 3 10.3017 4
2520601 0.2187 1 .2150 2 0.0512 3 -.0578 4
2520701 0.0119 1 .0839 2 .0093 3 -.0104 4
2520801 1.5e-4 1.40633 1 1.5e-4 0.835 4
2520901 0.1154 0.2429 1 0.19 0.19 2 .13 .13 3
2521001 0 4
2521101 01000 3
2521201 3 .28287e+03 161.96 0. 0. 0. 1
2521202 3 .27823e+03 161.96 0. 0. 0. 2
2521203 3 .27638e+03 161.96 0. 0. 0. 3
2521204 3 .27518e+03 161.96 0. 0. 0. 4
2521300 1
2521301 8.1400e+02 0. 0. 1
2521302 8.1400e+02 0. 0. 2
2521303 8.1400e+02 0. 0. 3
*
2580000 1252-257 sngl jun
2580101 252010000 257000000 0.5476 0.0876 0.0734 1000
2580201 1 8.1400e+02 0. 0.
*
* 14 in. inlet line to exchanger
*
2570000 ldoffa branch
2570001 1 1
2570101 0.93943 3.1772 0. 0. 0. 0. 1.5e-4 1.09367 0
2570200 3 .27705e+03 161.960
2571101 257010000 313000000 0.93943 0. 0. 31100
2571201 8.1400e+02 0. 0.
*
* inlet plenum to exchanger in cell 110
*
3130000 hxaplin sngl vol
3130101 4.016 1.9583 0. 0. -90. -1.9583 1.5e-4 2.3931 0
3130200 3 .27791e+03 161.960
*
* inlet to exchanger tubing in cell 113
*
2970000 hxain sngl jun
2970101 313010000 300000000 2.016 1.455 2.0 31000
2970201 1 8.1400e+02 0. 0.
*
* heat exchanger a
*
* pipes 300, 301, 304, and 305 are linked in series making
* up the primary flow side of the exchanger
*
3000000 prim-a1 pipe
3000001 5
300101 2.016 5
3000301 2.96055 5
3000601 -90. 5
3000801 5.e-6 .04625 5
3001001 0 5
3001101 31000 4
3001201 3 .27810e+03 159.04 0. 0. 0. 1
3001202 3 .27892e+03 156.88 0. 0. 0. 2
3001203 3 .27974e+03 155.30 0. 0. 0. 3
3001204 3 .28056e+03 154.14 0. 0. 0. 4
3001205 3 .28138e+03 153.30 0. 0. 0. 5
3001300 1
3001301 8.1400e+02 0. 0. 1
3001302 8.1400e+02 0. 0. 2
3001303 8.1400e+02 0. 0. 3
3001304 8.1400e+02 0. 0. 4
*
3160000 pd1-a2 sngl jun
3160101 300010000 301000000 2.016 0. 0. 31000
3160201 1 8.1400e+02 0. 0.
*
3010000 prim-a2 pipe
3010001 5
3010101 2.016 5
3010301 2.96055 5
3010601 -90. 5
3010801 5.e-6 .04625 5
3011001 0 5
3011101 31000 4
3011201 3 .28220e+03 152.51 0. 0. 0. 1
3011202 3 .28302e+03 151.58 0. 0. 0. 2
3011203 3 .28384e+03 150.48 0. 0. 0. 3
3011204 3 .28466e+03 149.29 0. 0. 0. 4
3011205 3 .28548e+03 147.70 0. 0. 0. 5
3011300 1
3011301 8.1400e+02 0. 0. 1
3011302 8.1400e+02 0. 0. 2
3011303 8.1400e+02 0. 0. 3
3011304 8.1400e+02 0. 0. 4
*
3170000 pa2-a3 sngl jun
3170101 301010000 304000000 2.016 0. 0. 31000

```

```

3170201 1 8.1400e+02 0. 0.
*
3040000 prim-a3 pipe
3040001 5
3040101 2.016 5
3040301 2.96055 5
3040601 90. 5
3040801 5.e-6 .04625 5
3041001 0 5
3041101 31000 4
3041201 3 .28503e+03 145.95 0. 0. 0. 1
3041202 3 .28350e+03 143.93 0. 0. 0. 2
3041203 3 .28163e+03 141.60 0. 0. 0. 3
3041204 3 .27992e+03 138.94 0. 0. 0. 4
3041205 3 .27821e+03 135.91 0. 0. 0. 5
3041300 1
3041301 8.1400e+02 0. 0. 1
3041302 8.1400e+02 0. 0. 2
3041303 8.1400e+02 0. 0. 3
3041304 8.1400e+02 0. 0. 4
*
3180000 pa2-a3 sngl jun
3180101 304010000 305000000 2.016 0. 0. 0. 31000
3180201 1 8.1400e+02 0. 0.
*
3050000 prim-a4 pipe
3050001 5
3050101 2.016 5
3050301 2.96055 5
3050601 90. 5
3050801 5.e-6 .04625 5
3051001 0 5
3051101 31000 4
3051201 3 .27650e+03 133.08 0. 0. 0. 1
3051202 3 .27478e+03 130.93 0. 0. 0. 2
3051203 3 .27307e+03 129.31 0. 0. 0. 3
3051204 3 .27135e+03 128.09 0. 0. 0. 4
3051205 3 .26963e+03 127.18 0. 0. 0. 5
3051300 1
3051301 8.1400e+02 0. 0. 1
3051302 8.1400e+02 0. 0. 2
3051303 8.1400e+02 0. 0. 3
3051304 8.1400e+02 0. 0. 4
*
* heat structures connecting the secondary and primary sides
* * of the exchanger a (cell 113)
*
13002000 5 3 2 0 .023125 0 0 0
13002400 -1
13002401 150.98 148.41 145.99
13002402 150.88 148.98 147.19
13002403 150.87 149.48 148.17

13002404 150.90 149.89 148.94
13002405 150.95 150.21 149.51
13002100 0 1
13002101 2 .02604
13002201 10 2
13002301 0. 2
13002501 300010000 010000 1 1 3555.62 5
13002601 302010000 010000 1 1 3555.62 5
13002701 0 0.0 0.0 0.0 5
13002801 0 0.0 0.0 0.0 5
13002901 0 0.0 0.0 0.0 5
*
13012000 5 3 2 0 .023125 0 0 0
13012400 -1
13012401 150.27 149.57 148.91
13012402 148.93 148.11 147.33
13012403 147.36 146.40 145.49
13012404 145.53 144.40 143.33
13012405 143.39 142.07 140.82
13012100 0 1
13012101 2 .02604
13012201 10 2
13012301 0. 2
13012501 301010000 010000 1 1 3555.62 5
13012601 303050000 -010000 1 1 3555.62 5
13012701 0 0.0 0.0 0.0 5
13012801 0 0.0 0.0 0.0 5
13012901 0 0.0 0.0 0.0 5
*
13022000 5 3 2 0 .023125 0 0 0
13022400 -1
13022401 140.91 139.37 137.92
13022402 138.05 136.27 134.58
13022403 134.77 132.71 130.77
13022404 131.04 128.67 126.45
13022405 126.83 124.15 121.61
13022100 0 1
13022101 2 .02604
13022201 10 2
13022301 0. 2
13022501 304010000 010000 1 1 3555.62 5
13022601 306050000 -010000 1 1 3555.62 5
13022701 0 0.0 0.0 0.0 5
13022801 0 0.0 0.0 0.0 5
13022901 0 0.0 0.0 0.0 5
*
13032000 5 3 2 0 .023125 0 0 0
13032400 -1
13032401 124.51 122.00 119.63
13032402 124.35 122.44 120.63
13032403 124.31 122.87 121.51
13032404 124.33 123.25 122.23

```

```

13032405 124.37 123.56 122.80
13032100 0 1
13032101 2 .02604
13032201 10 2
13032301 0. 2
13032501 305010000 010000 1 1 3555.62 5
13032601 307010000 010000 1 1 3555.62 5
13032701 0 0.0 0.0 0.0 5
13032801 0 0.0 0.0 0.0 5
13032901 0 0.0 0.0 0.0 5
*
* outlet from tubing in heat exchanger 1a
*
29800000 hxaout sngljun
2980101 305010000 314000000 2.016 2.0 1.455 31000
2980201 1 8.1400e+02 0. 0.
*
* outlet plenum from exchanger in cell 113
*
31400000 hxaoplou branch
3140001 1 1
3140101 4.016 1.9583 0. 0. 90. 1.9583 1.5e-4 2.3931 0
3140200 3 .26799e+03 127.180
3141101 314010000 262000000 0.0233 0.5 1. 31002
3141201 5.5193e+00 0. 0.
*
* outlet from exchanger in cell 113
*
31500000 hxaou sngljun
3150101 314010000 260000000 0.93943 0. 0. 31100
3150201 1 8.0848e+02 0. 0.
*
* 14" pipe between the heat exchanger and the main circulating pump
*
26000000 atotun pipe
2600001 3
2600101 .93943 3
2600301 2.4480 1 3.9477 2 3.9573 3
2600601 0. 2 90. 3
2600701 0. 2 2.9584 3
2600801 1.5e-4 1.09367 3
2600901 0.10 0.10 1 0.18 0.18 2
2601001 0 3
2601101 01000 2
2601201 3 .26586e+03 127.18 0. 0. 0. 1
2601202 3 .26567e+03 127.18 0. 0. 0. 2
2601203 3 .26474e+03 127.18 0. 0. 0. 3
2601300 1
2601301 8.0848e+02 0. 0. 0. 1
2601302 8.0848e+02 0. 0. 0. 2
*
* main circulation pump a
13700000 a-primy pump
2700101 0.9394 1. 0. 0. 0. 0. 0
2700108 260010000 0. 0. 0. 31000
2700109 273000000 0. 0. 0. 1000
2700200 3 .35462e+03 127.360
2700201 1 8.0848e+02 0. 0.
2700202 1 8.0848e+02 0. 0.
2700301 70 70 -1 0 0 0
2700302 1786. 1.08359 5000. 366.3 1361.2 468. 62.2 0. 300. 20. 50. 0.
2706100 529 cntrlvar 193
2706101 0. 0.
2706102 1.e6 1.e6
*
* 10" pipe from the main circulation pump to the check valve
*
27300000 puaout pipe
2730001 1
2730101 .5476 1
2730301 1.0 1
2730601 0. 1
2730801 1.5e-4 0.835 1
2731001 0 1
2731201 3 .44261e+03 127.40 0. 0. 0. 1
*
* check valve in the cell 113
*
27400000 a-check valve
2740101 273010000 275000000 0.5476 0.65 0.0 31000
2740201 1 8.0848e+02 0. 0.
2740300 chkvlv
2740301 0 0 0. 0.
*
* pipe returning from check valve in cell 113 (a) to the pipe tunnel
*
27500000 atotun pipe
2750001 5
2750101 0.5476 4 1.93059 5
2750301 2.29165 1 9.6072 2 3.75638 3 17.7947 4 4.16667 5
2750601 0. 1 -.10583 2 -1.91406 3 -.162784 4 -.179078 5
2750701 0. 1 -.017745 2 -.124475 3 -.052028 4 -.013023 5
2750801 1.5e-4 0.835 4 1.5e-4 1.56783 5
2750901 0.13 0.13 1 .10 .10 3 0.2864 0.12304 4
2751001 0 5
2751101 01000 4
2751201 3 .44002e+03 127.40 0. 0. 0. 1
2751202 3 .43913e+03 127.40 0. 0. 0. 2
2751203 3 .43833e+03 127.40 0. 0. 0. 3
2751204 3 .43727e+03 127.40 0. 0. 0. 4
2751205 3 .43910e+03 127.40 0. 0. 0. 5
2751300 1
2751301 8.0848e+02 0. 0. 0. 1

```

```

*****
2751302      8.0848e+02 0. 0. 2
2751303      8.0848e+02 0. 0. 3
2751304      8.0848e+02 0. 0. 4
*****
*
*           l o w   p r e s s u r e   c l e a n - u p
*
*
*
*
*
*
*****
* * let-down line off of exchanger in cell 110
*
0620000 ldline-d pipe
0620001 2
0620101 0.0233 2
0620301 15.0 2
0620601 0. 2
0620701 0. 2
0620801 1.5e-4 0.17225 2
0620901 18.0 18.0 1
0621001 0 2
0621101 01000 1
0621201 3 .26657e+03 125.96 0. 0. 0. 1
0621202 3 .26458e+03 125.96 0. 0. 0. 2
0621300 1
0621301 5.5071e+00 0. 0. 1
*
* let-down valve, 41.67 gpm nominal clean-up flow
* taken from heat exchanger d (cell 110)
*
0630000 ld-servo valve
0630101 062010000 064000000 0.0233 0. 0. 31000
0630201 1 5.5070e+00 0. 0.
0630300 srwlv
0630301 42 13
0630400 1. 8.7
0630401 0. 0.
0630402 0.10 0.001
0630403 0.15 0.003375 0.003375
0630404 0.20 0.008 0.008
0630405 0.25 0.015625 0.015625
0630406 0.30 0.027 0.027
0630407 0.35 0.042875 0.042875
0630408 0.40 0.064 0.064
0630409 0.45 0.091125 0.091125
0630410 0.50 0.125 0.125
0630411 0.55 0.166375 0.166375
0630412 0.60 0.216 0.216
0630413 0.65 0.274625 0.274625
0630414 0.70 0.343 0.343
*****

```

```

1630413 0.65 0.274625 0.274625
1630414 0.70 0.343 0.343
1630415 0.75 0.421875 0.421875
1630416 0.78 0.474552 0.474552
1630417 0.80 0.512 0.512
1630418 0.82 0.551368 0.551368
1630419 0.84 0.592704 0.592704
1630420 0.86 0.636056 0.636056
1630421 0.88 0.681472 0.681472
1630422 0.90 0.729 0.729
1630423 0.92 0.778688 0.778688
1630424 0.94 0.830584 0.830584
1630425 0.96 0.884736 0.884736
1630426 0.98 0.941192 0.941192
1630427 1.00 1.000 1.000
*
* let-down line off of exchanger in cell 113
*
2620000 ldline-a pipe
2620001 2
2620101 0.0233 2
2620301 15.0 2
2620601 0. 2
2620701 0. 2
2620801 1.5e-4 0.17225 2
2620901 18.0 18.0 1
2621001 0 2
2621101 01000 1
2621201 3 .26774e+03 127.18 0. 0. 0. 1
2621202 3 .26574e+03 127.18 0. 0. 0. 2
2621300 1
2621301 5.5193e+00 0. 0. 1
*
* let-down valve, 41.67 gpm nominal clean-up flow
* taken from heat exchanger a (cell 113)
*
2630000 ld-servo valve
2630101 262010000 064000000 .0233 0. 0. 31000
2630201 1 5.5193e+00 0. 0.
2630300 srvtlv
2630301 42 13
2630400 1. 8.7
2630401 0. 0.
2630402 0.10 0.001 0.001
2630403 0.15 0.003375 0.003375
2630404 0.20 0.008 0.008
2630405 0.25 0.015625 0.015625
2630406 0.30 0.027 0.027
2630407 0.35 0.042875 0.042875
2630408 0.40 0.064 0.064
2630409 0.45 0.091125 0.091125
2630410 0.50 0.125 0.125

2630411 0.55 0.166375 0.166375
2630412 0.60 0.216 0.216
2630413 0.65 0.274625 0.274625
2630414 0.70 0.343 0.343
2630415 0.75 0.421875 0.421875
2630416 0.78 0.474552 0.474552
2630417 0.80 0.512 0.512
2630418 0.82 0.551368 0.551368
2630419 0.84 0.592704 0.592704
2630420 0.86 0.636056 0.636056
2630421 0.88 0.681472 0.681472
2630422 0.90 0.729 0.729
2630423 0.92 0.778688 0.778688
2630424 0.94 0.830584 0.830584
2630425 0.96 0.884736 0.884736
2630426 0.98 0.941192 0.941192
2630427 1.00 1.000 1.000
*
* collection of let-down valve flows
*
0640000 outflow branch
0640001 1 1
0640101 0.0233 10. 0. 0. 0. 1.5e-4 0.17225 0
0640200 3 .19681e+02 126.150
0641101 064010000 065000000 0.0233 0. 0. 31000
0641201 1.6527e+01 0. 0.
*
* sink for fluid exiting the high pressure primary system
* through the let-down valves
*
0650000 clean-up tmdpvcl
0650101 1. 1. 0. 0. 0. 1.d-6 1. 10
0650200 3 0
0650201 0.00 20.0 120. 1.e6 20.0 120.
*
* intake to pressurizer pumps
* from the primary coolant head tank
*
0680000 pcheado tmdpvcl
0680101 1. 1. 0. 0. 0. 0. 1.d-6 1. 10
0680200 3 0 cntrlvar 6
* table of level vs. piz suction pressure
0680201 .00 19.6041994 80. .34 19.7511205 80. .54 19.8389556 80.
0680202 .72 19.9135702 80. .87 19.9809366 80. 1.02 20.0435262 80.
0680203 1.15 20.1026618 80. 1.28 20.1591559 80. 1.41 20.2135575 80.
0680204 1.53 20.2662521 80. 1.65 20.3175343 80. 1.77 20.3676250 80.
0680205 1.88 20.4167063 80. 1.99 20.4649227 80. 2.10 20.5123961 80.
0680206 2.21 20.5592295 80. 2.32 20.6055127 80. 2.42 20.6513246 80.
0680207 2.53 20.6967323 80. 2.63 20.7418012 80. 2.74 20.7865863 80.
0680208 2.84 20.8311411 80. 2.94 20.8755151 80. 3.05 20.9197567 80.
0680209 3.15 20.9639099 80. 3.25 21.0080189 80. 3.35 21.0521279 80.
0680210 3.45 21.0962811 80. 3.56 21.1405226 80. 3.66 21.1848967 80.

```

```

0680211 3.76 21.2294515 80. 3.87 21.2742366 80. 3.97 21.3193055 80.
0680212 4.08 21.3647131 80. 4.18 21.4105251 80. 4.29 21.4568082 80.
0680213 4.40 21.5036417 80. 4.51 21.5511150 80. 4.62 21.5993314 80.
0680214 4.73 21.6484127 80. 4.85 21.6985034 80. 4.97 21.7497856 80.
0680215 5.09 21.8024803 80. 5.22 21.8568818 80. 5.35 21.9133760 80.
0680216 5.48 21.9725115 80. 5.63 22.0351011 80. 5.78 22.1024675 80.
0680217 5.96 22.1770821 80. 6.16 22.2649172 80. 6.50 22.4117527 80.
*
* tap on pc head tank which distributes flow to the three
* pressurizer pumps
*
0720000 outflow branch
0720001 1 1
0720101 0.08840 70. 0. 0. 0. 0. 0. 0. 1.5e-4 0.3355 0
0720200 3 .21449e+02 80.001
0721101 0.68000000 0.72000000 0.08840 0. 0. 0. 31000
0721201 1.6650e+01 0. 0.
*
0470000 p2r-suct branch
0470001 1 1
0470101 0.08840 2.21 0. 0. 0. 0. 0. 0. 1.5e-4 0.3355 0
0470200 3 .20394e+02 80.001
* include losses due to elbows, wyes, valves and tee
0471101 0.72010000 0.47000000 0.08840 9.6 9.6 31000
0471201 1.6650e+01 0. 0.
*
* main pressurizer pump
*
0660000 p2r-1 pump
0660101 1. 1.413 0. 0. 0. 0. 0. 0. 0. 31000
0660108 0.47010000 0.8840 0. 0. 0. 31000
0660109 0.48000000 0.8840 0. 0. 0. 31000
0660200 3 .23584e+03 83.064
0660201 1 1.6650e+01 0. 0.
0660202 1 1.6650e+01 0. 0.
0660301 69 -1 -3 -1 0 614 0
0660302 2616. .82993 200. 1376.906 139.751 120. 0. 0. 247.66 0. 0. 0.
* speed table trip
0666100 615
0666101 1. 2171.06
*
* single volume to connect main p2r pump to check valve
*
0480000 main-chk singlvol
0480101 0.05135 5. 0. 0. 0. 0. 0. 0. 1.5e-4 0.2557 0
0480200 3 .45071e+03 83.121
*
* check valve for main p2r pump
*
0490000 ma-check valve
0490101 0.48010000 0.67000000 .05135 5.4 5.4 31000
0490201 1 1.6650e+01 0. 0.

```

```

0490300 chkvlv
0490301 0 0 0. 0.
*
* standby pressurizer pump
*
0690000 p2r-2 pump
0690101 1. 1.413 0. 0. 0. 0. 0. 0. 0. 31000
0690108 0.47010000 0.8840 0. 0. 0. 31000
0690109 0.59000000 0.8840 0. 0. 0. 31000
0690200 3 .20757e+02 80.000
0690201 1 1.1666e-10 0. 0.
0690202 1 1.7936e-11 0. 0.
0690301 0 -1 -3 -1 0 614 0
0690302 2616. .00000 200. 1376.909 139.75 120. 0. 0. 247.66 0. 0. 0.
* han
0691100 1 1 .000 1.078 .040 1.079 .080 1.080
0691101 120 1.081 .160 1.082 .200 1.082
0691102 240 1.082 .280 1.082 .320 1.081
0691103 360 1.080 .400 1.078 .440 1.076
0691104 480 1.074 .520 1.071 .560 1.068
0691105 600 1.064 .640 1.060 .680 1.056
0691106 720 1.050 .760 1.045 .800 1.039
0691107 840 1.032 .880 1.025 .920 1.017
0691108 960 1.009 1.000 1.000
* hvn
0691200 1 2 .368 -.012 .373 -.006 .379 .000
0691201 385 .006 .391 .013 .397 .020
0691202 403 .027 .410 .034 .417 .041
0691203 424 .049 .431 .058 .439 .066
0691204 446 .075 .455 .085 .463 .095
0691205 472 .105 .481 .116 .490 .128
0691206 500 .140 .510 .152 .521 .166
0691207 532 .180 .543 .195 .556 .211
0691208 568 .228 .581 .247 .595 .266
0691209 610 .287 .625 .309 .641 .333
0691210 658 .358 .676 .386 .694 .415
0691211 714 .448 .735 .483 .758 .521
0691212 781 .562 .806 .608 .833 .657
0691213 862 .712 .893 .773 .926 .841
0691214 962 .916 1.000 1.000
* had homologous data taken from bingham pump in relap
0691300 1 3 -1. 2.5 -.9 2.28 -.63 2. -.55 1.74
0691301 -.5 1.68 -.42 1.6 -.15 1.4 0. 1.078
* hvd homologous data taken from bingham pump in relap
0691400 1 4 -1. 2.5 -.9 2.28 -.63 2. -.55 1.74
0691401 -.5 1.68 -.42 1.6 -.15 1.4 0. 1.30
* ban
0691500 2 1 .000 -.001 .040 .041 .080 .085
0691501 120 .128 .160 .171 .200 .215
0691502 240 .259 .280 .302 .320 .346
0691503 360 .389 .400 .432 .440 .475
0691504 480 .517 .520 .559 .560 .600

```



```

*
0691505 .600 .641 .640 .681 .680 .721
0691506 .720 .759 .760 .797 .800 .833
0691507 .840 .869 .880 .904 .920 .937
0691508 .960 .969 1.000 1.000
* bvn
0691600 2 2 .368 .009 .373 .023 .379 .036
0691601 .385 .050 .391 .064 .397 .078
0691602 .403 .092 .410 .106 .417 .121
0691603 .424 .136 .431 .151 .439 .166
0691604 .446 .182 .455 .198 .463 .215
0691605 .472 .231 .481 .248 .490 .266
0691606 .500 .284 .510 .302 .521 .321
0691607 .532 .340 .543 .359 .556 .380
0691608 .568 .401 .581 .422 .595 .444
0691609 .610 .467 .625 .491 .641 .515
0691610 .658 .540 .676 .567 .694 .594
0691611 .714 .623 .735 .652 .758 .683
0691612 .781 .716 .806 .750 .833 .786
0691613 .862 .824 .893 .864 .926 .907
0691614 .962 .952 1.000 1.000
* bad homologous data taken from bingham pump in relap
0691700 2 3 -1.2 5 -.8 2. -.6 1.45 -.46 1.15
0691701 -.3 .95 -.13 .8 0. .8
0691800 2 4 -1.2 5 -.65 2.15 -.4 1.79 -.30 1.61
0691801 -.13 1.5 0. 1.44
* speed table trip
0696100 615 cntrlvar 12
0696101 0. 0. 1.e6 1.e6
*
* single volume to connect standby pump to check valve
*
0590000 stby-chk snglvol
0590101 0.05135 5. 0. 0. 0. 0. 1.5e-4 0.2557 0
0590200 3 .20757e+02 80.000
*
* check valve for standby pump
*
0560000 sb-check valve
0560101 059010000 067000000 .05135 5.4 5.4 31000
0560201 1 0.0000e+00 0. 0.
0560300 chkvlv
0560301 0 1 0. 0.
*
* auxiliary pressurizer pump
*
0710000 auxpmp tmdpjvn
0710101 047010000 067000000 0.
0710200 1 623 cntrlvar 25
0710201 -2. 0. 0. 0.
0710202 0. 0. 0. 0.
0710203 1.e6 1.e6 0.

```

```

1230201 40.00 14.7 40.00
1230202 100. 14.7 100.
1230203 1000. 14.7 1000.
*
* cooling tower water basins (400,000 gal) - 53,480 ft**3
*
1080000 sec-in1 branch
1080001 2 1
1080101 106.96 500. 0 0 0 1.5e-4 0.29 0
1080200 3 .14699e+02 88.200
1081101 123000000 108000000 1. 0. 0. 1000
1081201 -1.2529e-03 0. 0.
1082101 132010000 108000000 13.0045 0. 0. 1000
1082201 2.5504e+03 0. 0.
*
* auxiliary secondary pump (pu-14)
*
1240000 pu-14 pump
1240101 1. 3. 0. 0. 0. 0. 0.
1240108 108010000 0. 0. 0. 1000
1240109 133000000 0. 0. 0. 1000
1240200 3 .14700e+02 85.000
1240201 1 -1.1320e-08 0. 0.
1240202 1 -9.9308e-09 0. 0.
1240301 -1 -1 -3 -1 0 0 0
1240302 1200. .00000 6000. 100.0 508. 200. 62.2 80. 300. 20. 50. 0.
1246100 0 cntlvar 64
1246101 0. 0.
1246102 5000. 5000.
*
* single volume to connect pu-14 to check valve
*
1330000 pu14-vol snglvol
1330101 1. 10. 0. 0. 0. 0. 1.5e-4 1.596 0
1330200 3 .14700e+02 85.000
*
* check valve for pu-14
*
1340000 pu14-chk valve
1340101 133010000 119000000 0. 0. 0. 31000
1340201 1 0.0000e+00 0. 0.
1340300 chkvlv
1340301 0 1 0. 0.
*
* secondary coolant pump pu-6a
*
1250000 pu-6a pump
1250101 1. 3. 0. 0. 0. 0. 0.
1250108 108010000 0. 0. 0. 1000
1250109 126000000 0. 0. 0. 1000
1250200 3 .41923e+02 88.252
1250201 1 1.2752e+03 0. 0.
*
1250202 1 1.2752e+03 0. 0.
1250301 -1 -1 -3 -1 0 649 0
1250302 1160. 1.00000 13000. 120.0 1528. 468. 62.2 0. 300. 20. 50. 0.
2256100 650
2256101 0. 1160.
2256102 1.e6 1160.
*
* single volume to connect pumps to check valve
*
2260000 pu6b-vol snglvol
2260101 1. 10. 0. 0. 0. 0. 1.5e-4 1.596 0
2260200 3 .71863e+02 88.262
*
* check valve for pu-6b
*
2270000 pu6b-chk valve
2270101 226010000 119000000 0. 0. 0. 31000
2270201 1 1.2752e+03 0. 0.
2270300 chkvlv
2270301 0 0 0. 0.
*
* manually-set control valve in 36" pipe
*
1250202 1 1.2752e+03 0. 0.
1250301 -1 -1 -3 -1 0 651 0
1250302 1160. 1.00000 13000. 120.0 1528. 468. 62.2 0. 300. 20. 50. 0.
1256100 652
1256101 0. 1160.
1256102 1.e6 1160.
*
* single volume to connect pumps to check valve
*
1260000 pu6a-vol snglvol
1260101 1. 10. 0. 0. 0. 0. 1.5e-4 1.596 0
1260200 3 .71863e+02 88.262
*
* check valve for pu-6a
*
1270000 pu6a-chk valve
1270101 126010000 119000000 0. 0. 0. 31000
1270201 1 1.2752e+03 0. 0.
1270300 chkvlv
1270301 0 0 0. 0.
*
* secondary coolant pump 6b
*
2250000 pu-6b pump
2250101 1. 3. 0. 0. 0. 0. 0.
2250108 108010000 0. 0. 0. 0
2250109 226000000 0. 0. 0. 0
2250200 3 .41923e+02 88.252
2250201 1 1.2752e+03 0. 0.
2250202 1 1.2752e+03 0. 0.
2250301 -1 -1 -3 -1 0 649 0
2250302 1160. 1.00000 13000. 120.0 1528. 468. 62.2 0. 300. 20. 50. 0.
2256100 650
2256101 0. 1160.
2256102 1.e6 1160.
*
* single volume to connect pumps to check valve
*
2260000 pu6b-vol snglvol
2260101 1. 10. 0. 0. 0. 0. 1.5e-4 1.596 0
2260200 3 .71863e+02 88.262
*
* check valve for pu-6b
*
2270000 pu6b-chk valve
2270101 226010000 119000000 0. 0. 0. 31000
2270201 1 1.2752e+03 0. 0.
2270300 chkvlv
2270301 0 0 0. 0.
*
* manually-set control valve in 36" pipe
*

```

```

1110000 cv377 valve
1110101 119010000 211000000 6.07 0. 0. 100
1110201 1 1.4849e+03 0. 0.
1110300 srwlv
1110301 73
*
1190000 sec-in1 branch
1190001 1
1190101 9.19 200.0 0 0 0 1.5e-4 3.42 0
1190200 3 .74405e+02 88.264
1192101 119010000 138000000 0. 0. 0. 1100
1192201 1.0204e+03 0. 0.
*
* servo valve for secondary coolant control
*
1100000 cv377a valve
1100101 119010000 211000000 0.5454 0. 0. 1100
1100201 1 4.5086e+01 0. 0.
1100300 srwlv
1100301 57
*
2110000 sec-in2 branch
2110001 3 1
2110101 7.0685 200.0 0 0 0 1.5e-4 3.0 0
2110200 3 .50145e+02 88.259
21110101 211010000 109000000 1.9306 0. 0. 1100
2111201 5.1227e+02 0. 0.
2112101 211010000 209000000 1.9306 0. 0. 1100
2112201 5.0887e+02 0. 0.
2113101 211010000 309000000 1.9306 0. 0. 1100
2113201 5.0884e+02 0. 0.
*
* servo valve for heat exchanger bypass
*
2280000 hxbypass valve
2280101 138010000 137000000 0.7854 6.00 6.00 1100
2280201 1 9.9383e+02 0. 0.
2280300 srwlv
2280301 66
*
* secondary bypass to auxiliaries in water wing and tru
*
1310000 sec-byps branch
1310001 1
1310101 0.0785 500. 0. 0. 0. 0. 1.5e-4 0.10 0
1310200 3 .58035e+02 88.352
13110101 131010000 137000000 0.0785 5. 5. 1100
1311201 2.6566e+01 0. 0.
*
* secondary side piping: heat exchanger d
* note: two parallel paths of piping make up the secondary side
*
1110000 cv377 valve
1110101 119010000 211000000 6.07 0. 0. 100
1110201 1 1.4849e+03 0. 0.
1110300 srwlv
1110301 73
*
1190000 sec-in1 branch
1190001 1
1190101 9.19 200.0 0 0 0 1.5e-4 3.42 0
1190200 3 .74405e+02 88.264
1192101 119010000 138000000 0. 0. 0. 1100
1192201 1.0204e+03 0. 0.
*
* servo valve for secondary coolant control
*
1100000 cv377a valve
1100101 119010000 211000000 0.5454 0. 0. 1100
1100201 1 4.5086e+01 0. 0.
1100300 srwlv
1100301 57
*
2110000 sec-in2 branch
2110001 3 1
2110101 7.0685 200.0 0 0 0 1.5e-4 3.0 0
2110200 3 .50145e+02 88.259
21110101 211010000 109000000 1.9306 0. 0. 1100
2111201 5.1227e+02 0. 0.
2112101 211010000 209000000 1.9306 0. 0. 1100
2112201 5.0887e+02 0. 0.
2113101 211010000 309000000 1.9306 0. 0. 1100
2113201 5.0884e+02 0. 0.
*
* servo valve for heat exchanger bypass
*
2280000 hxbypass valve
2280101 138010000 137000000 0.7854 6.00 6.00 1100
2280201 1 9.9383e+02 0. 0.
2280300 srwlv
2280301 66
*
* secondary bypass to auxiliaries in water wing and tru
*
1310000 sec-byps branch
1310001 1
1310101 0.0785 500. 0. 0. 0. 0. 1.5e-4 0.10 0
1310200 3 .58035e+02 88.352
13110101 131010000 137000000 0.0785 5. 5. 1100
1311201 2.6566e+01 0. 0.
*
* secondary side piping: heat exchanger d
* note: two parallel paths of piping make up the secondary side
*
1200000 sdi-d2 snaljun
1200101 107010000 102000000 1.373 11.900 11.900 1000
1200201 1 2.5538e+02 0. 0.
*
1020000 sec-d1 pipe
1020001 5
1020101 1.373 5
1020301 0. 5
1020401 9.9189 5
1020601 -90. 5
1020701 -2.96055 5
1020801 1.5e-6 0.1960 5
1020901 11.900 11.900 4
1021001 0 5
1021101 01000 4
1021201 3 .40480e+02 124.73 0. 0. 0. 1
1021202 3 .40972e+02 131.73 0. 0. 0. 2
1021203 3 .41460e+02 136.87 0. 0. 0. 3
1021204 3 .41945e+02 140.62 0. 0. 0. 4
1021205 3 .42429e+02 143.34 0. 0. 0. 5
1021300 1
1021301 2.5538e+02 0. 0. 1
1021302 2.5538e+02 0. 0. 2
1021303 2.5538e+02 0. 0. 3
1021304 2.5538e+02 0. 0. 4
*
* the lower path consists of pipes 106 and 103 in series
*
1070000 sec-d1 pipe
1070001 5
1070101 1.373 5
1070301 0. 5
1070401 9.9189 5
1070601 90. 5
1070701 2.96055 5
1070801 1.5e-6 0.1960 5
1070901 11.900 11.900 4
1071001 0 5
1071101 01000 4
1071201 3 .49439e+02 97.00 0. 0. 0. 1
1071202 3 .47391e+02 103.66 0. 0. 0. 2
1071203 3 .45345e+02 108.67 0. 0. 0. 3
1071204 3 .43300e+02 112.43 0. 0. 0. 4
1071205 3 .41256e+02 115.24 0. 0. 0. 5
1071300 1
1071301 2.5538e+02 0. 0. 1
1071302 2.5538e+02 0. 0. 2
1071303 2.5538e+02 0. 0. 3
1071304 2.5538e+02 0. 0. 4
*
1200000 sdi-d2 snaljun
1200101 107010000 102000000 1.373 11.900 11.900 1000
1200201 1 2.5538e+02 0. 0.
*
1020000 sec-d1 pipe
1020001 5
1020101 1.373 5
1020301 0. 5
1020401 9.9189 5
1020601 -90. 5
1020701 -2.96055 5
1020801 1.5e-6 0.1960 5
1020901 11.900 11.900 4
1021001 0 5
1021101 01000 4
1021201 3 .40480e+02 124.73 0. 0. 0. 1
1021202 3 .40972e+02 131.73 0. 0. 0. 2
1021203 3 .41460e+02 136.87 0. 0. 0. 3
1021204 3 .41945e+02 140.62 0. 0. 0. 4
1021205 3 .42429e+02 143.34 0. 0. 0. 5
1021300 1
1021301 2.5538e+02 0. 0. 1
1021302 2.5538e+02 0. 0. 2
1021303 2.5538e+02 0. 0. 3
1021304 2.5538e+02 0. 0. 4
*
* the lower path consists of pipes 106 and 103 in series
*

```

```

1060000 sec-d3 pipe
1060001 5
1060101 1.373 5
1060301 0. 5
1060401 9.9189 5
1060601 -90. 5
1060701 -2.96055 5
1060801 1.5e-6 0.1960 5
1060901 11.900 11.900 4
1061001 0 5
1061101 01000 4
1061201 3 .50713e+02 97.59 0. 0. 0. 1
1061202 3 .51206e+02 105.85 0. 0. 0. 2
1061203 3 .51696e+02 113.11 0. 0. 0. 3
1061204 3 .52183e+02 119.44 0. 0. 0. 4
1061205 3 .52668e+02 124.94 0. 0. 0. 5
1061300 1
1061301 2.5689e+02 0. 0. 1
1061302 2.5689e+02 0. 0. 2
1061303 2.5689e+02 0. 0. 3
1061304 2.5689e+02 0. 0. 4
*
1210000 sd3-d4 sngljun
1210101 106010000 103000000 1.373 11.900 11.900 1000
1210201 1 2.5689e+02 0. 0.
*
1030000 sec-d4 pipe
1030001 5
1030101 1.373 5
1030301 0. 5
1030401 9.9189 5
1030601 90. 5
1030701 2.96055 5
1030801 1.5e-6 0.1960 5
1030901 11.900 11.900 4
1031001 0 5
1031101 01000 4
1031201 3 .51885e+02 129.70 0. 0. 0. 1
1031202 3 .49835e+02 133.80 0. 0. 0. 2
1031203 3 .47786e+02 137.32 0. 0. 0. 3
1031204 3 .45738e+02 140.34 0. 0. 0. 4
1031205 3 .43690e+02 142.93 0. 0. 0. 5
1031300 1
1031301 2.5689e+02 0. 0. 1
1031302 2.5689e+02 0. 0. 2
1031303 2.5689e+02 0. 0. 3
1031304 2.5689e+02 0. 0. 4
*
* inlet volume to the secondary side
*
1090000 sdinbr branch
1090001 2 1
1090101 1.9306 20. 0 0 0 1.5e-4 1.5678 0
1090200 3 .50045e+02 88.259
1091101 109010000 107000000 1.9306 0. 0. 1000
1091201 2.5538e+02 0. 0.
1092101 109010000 106000000 1.9306 0. 0. 1000
1092201 2.5689e+02 0. 0.
*
* outlet volume from the secondary side
*
1120000 sdoubr branch
1120001 2 1
1120101 1.9306 20. 0 0 0 1.5e-4 1.5678 0
1120200 3 .42968e+02 143.130
1121101 103010000 112000000 1.9306 0. 0. 1000
1121201 2.5689e+02 0. 0.
1122101 102010000 112000000 1.9306 0. 0. 1000
1122201 2.5538e+02 0. 0.
*
* secondary side piping: heat exchanger c
* note: two parallel paths of piping make up the secondary side
* the upper path consists of pipes 207 and 202 in series
*
2070000 sec-c1 pipe
2070001 5
2070101 1.373 5
2070301 0. 5
2070401 9.9189 5
2070601 90. 5
2070701 2.96055 5
2070801 1.5e-4 .1960 5
2070901 11.900 11.900 4
2071001 0 5
2071101 01000 4
2071201 3 .49436e+02 96.94 0. 0. 0. 1
2071202 3 .47390e+02 103.54 0. 0. 0. 2
2071203 3 .45345e+02 108.51 0. 0. 0. 3
2071204 3 .43300e+02 112.24 0. 0. 0. 4
2071205 3 .41257e+02 115.02 0. 0. 0. 5
2071300 1
2071301 2.5369e+02 0. 0. 1
2071302 2.5369e+02 0. 0. 2
2071303 2.5369e+02 0. 0. 3
2071304 2.5369e+02 0. 0. 4
*
2200000 sc1-c2 sngljun
2200101 207010000 202000000 1.373 11.900 11.900 1000
2200201 1 2.5369e+02 0. 0.
*
2020000 sec-c1 pipe
2020001 5
2020101 1.373 5

```

```

2020301 0. 5
2020401 9.9189 5
2020601 -90. 5
2020701 -2.96055 5
2020801 1.5e-4 .1960 5
2020901 11.900 11.900 4
2021001 0 5
2021101 01000 4
2021201 3 .40482e+02 124.54 0. 0. 0. 1
2021202 3 .40974e+02 131.57 0. 0. 0. 2
2021203 3 .41463e+02 136.72 0. 0. 0. 3
2021204 3 .41950e+02 140.47 0. 0. 0. 4
2021205 3 .42434e+02 143.19 0. 0. 0. 5
2021300 1
2021301 2.5369e+02 0. 0. 1
2021302 2.5369e+02 0. 0. 2
2021303 2.5369e+02 0. 0. 3
2021304 2.5369e+02 0. 0. 4
*
* the lower path consists of pipes 206 and 203 in series
*
2060000 sec-c3 pipe
2060001 5
2060101 1.373 5
2060301 0. 5
2060401 9.9189 5
2060601 -90. 5
2060701 -2.96055 5
2060801 1.5e-4 .1960 5
2060901 11.900 11.900 4
2061001 0 5
2061101 01000 4
2061201 3 .50710e+02 97.53 0. 0. 0. 1
2061202 3 .51204e+02 105.74 0. 0. 0. 2
2061203 3 .51695e+02 112.96 0. 0. 0. 3
2061204 3 .52184e+02 119.27 0. 0. 0. 4
2061205 3 .52670e+02 124.76 0. 0. 0. 5
2061300 1
2061301 2.5518e+02 0. 0. 1
2061302 2.5518e+02 0. 0. 2
2061303 2.5518e+02 0. 0. 3
2061304 2.5518e+02 0. 0. 4
*
2210000 sc3-c4 sngljun
2210101 206010000 203000000 1.373 11.900 11.900 1000
2210201 1 2.5518e+02 0. 0.
*
2030000 sec-c4 pipe
2030001 5
2030101 1.373 5
2030301 0. 5
2030401 9.9189 5

2030601 90. 5
2030701 2.96055 5
2030801 1.5e-4 .1960 5
2030901 11.900 11.900 4
2031001 0 5
2031101 01000 4
2031201 3 .51887e+02 129.51 0. 0. 0. 1
2031202 3 .49838e+02 133.61 0. 0. 0. 2
2031203 3 .47790e+02 137.13 0. 0. 0. 3
2031204 3 .45742e+02 140.16 0. 0. 0. 4
2031205 3 .43695e+02 142.75 0. 0. 0. 5
2031300 1
2031301 2.5518e+02 0. 0. 1
2031302 2.5518e+02 0. 0. 2
2031303 2.5518e+02 0. 0. 3
2031304 2.5518e+02 0. 0. 4
*
* inlet volume to the secondary side
*
2090000 scinbr branch
2090001 2 1
2090101 1.9306 20. 0 0 0 1.5e-4 1.5678 0
2090200 3 .50047e+02 88.259
2091101 209010000 207000000 1.9306 0. 0. 1000
2091201 2.5369e+02 0. 0.
2092101 209010000 206000000 1.9306 0. 0. 1000
2092201 2.5518e+02 0. 0.
*
* outlet volume to the secondary side
*
2120000 scoubr branch
2120001 2 1
2120101 1.9306 20. 0 0 0 1.5e-4 1.5678 0
2120200 3 .42969e+02 142.970
2121101 203010000 212000000 1.9306 0. 0. 1000
2121201 2.5518e+02 0. 0.
2122101 202010000 212000000 1.9306 0. 0. 1000
2122201 2.5369e+02 0. 0.
*
* secondary side piping
* note: two parallel paths of piping make up the secondary side
* the upper path consists of pipes 307 and 302 in series
*
3070000 sec-a1 pipe
3070001 5
3070101 1.373 5
3070301 0. 5
3070401 9.9189 5
3070601 90. 5
3070701 2.96055 5
3070801 1.5e-4 .1960 5

```

```

3070901 11.900 11.900 4
3071001 0 5
3071101 01000 4
3071201 3 .49436e+02 97.34 0. 0. 0. 1
3071202 3 .47390e+02 104.24 0. 0. 0. 2
3071203 3 .45345e+02 109.45 0. 0. 0. 3
3071204 3 .43302e+02 113.35 0. 0. 0. 4
3071205 3 .41258e+02 116.26 0. 0. 0. 5
3071300 1
3071301 2.5366e+02 0. 0. 1
3071302 2.5366e+02 0. 0. 2
3071303 2.5366e+02 0. 0. 3
3071304 2.5366e+02 0. 0. 4
*
3200000 sd1-a2 sngl jun
3200101 307010000 302000000 1.373 11.900 11.900 1000
3200201 1 2.5366e+02 0. 0.
*
3020000 sec-a1 pipe
3020001 5
3020101 1.373 5
3020301 0. 5
3020401 9.9189 5
3020601 -90. 5
3020701 -2.96055 5
3020801 1.5e-4 .1960 5
3020901 11.900 11.900 4
3021001 0 5
3021101 01000 4
3021201 3 .40484e+02 125.67 0. 0. 0. 1
3021202 3 .40975e+02 132.61 0. 0. 0. 2
3021203 3 .41464e+02 137.70 0. 0. 0. 3
3021204 3 .41950e+02 141.41 0. 0. 0. 4
3021205 3 .42434e+02 146.11 0. 0. 0. 5
3021300 1
3021301 2.5366e+02 0. 0. 1
3021302 2.5366e+02 0. 0. 2
3021303 2.5366e+02 0. 0. 3
3021304 2.5366e+02 0. 0. 4
*
* the upper path consists of pipes 306 and 303 in series
*
3060000 sec-a3 pipe
3060001 5
3060101 1.373 5
3060301 0. 5
3060401 9.9189 5
3060601 -90. 5
3060701 -2.96055 5
3060801 1.5e-4 .1960 5
3060901 11.900 11.900 4
3061001 0 5

3061101 01000 4
3061201 3 .50710e+02 97.92 0. 0. 0. 1
3061202 3 .51204e+02 106.43 0. 0. 0. 2
3061203 3 .51695e+02 113.87 0. 0. 0. 3
3061204 3 .52183e+02 120.32 0. 0. 0. 4
3061205 3 .52668e+02 125.89 0. 0. 0. 5
3061300 1
3061301 2.5518e+02 0. 0. 1
3061302 2.5518e+02 0. 0. 2
3061303 2.5518e+02 0. 0. 3
3061304 2.5518e+02 0. 0. 4
*
3210000 sd3-a4 sngl jun
3210101 306010000 303000000 1.373 11.900 11.900 1000
3210201 1 2.5518e+02 0. 0.
*
3030000 sec-a4 pipe
3030001 5
3030101 1.373 5
3030301 0. 5
3030401 9.9189 5
3030601 90. 5
3030701 2.96055 5
3030801 1.5e-4 .1960 5
3030901 11.900 11.900 4
3031001 0 5
3031101 01000 4
3031201 3 .51886e+02 130.68 0. 0. 0. 1
3031202 3 .49837e+02 134.78 0. 0. 0. 2
3031203 3 .47789e+02 138.29 0. 0. 0. 3
3031204 3 .45741e+02 141.27 0. 0. 0. 4
3031205 3 .43694e+02 143.81 0. 0. 0. 5
3031300 1
3031301 2.5518e+02 0. 0. 1
3031302 2.5518e+02 0. 0. 2
3031303 2.5518e+02 0. 0. 3
3031304 2.5518e+02 0. 0. 4
*
* inlet volume to the secondary side
*
3090000 saibr branch
3090001 2 1
3090101 1.9306 20. 0 0 0 1.5e-4 1.5678 0
3090200 3 .50047e+02 88.259
3091101 309010000 307000000 1.9306 0. 0. 1000
3091201 2.5366e+02 0. 0.
3092101 309010000 306000000 1.9306 0. 0. 1000
3092201 2.5518e+02 0. 0.
*
* outlet volume to the secondary side
*
3120000 saoub branch

```

```

3120001 2 1
3120101 1.9306 20. 0 0 0 1.5e-4 1.5678 0
3120200 3 .42969e+02 143.960
3121101 303010000 312000000 1.9306 0. 0. 1000
3121201 2.5518e+02 0. 0.
3122101 302010000 312000000 1.9306 0. 0. 1000
3122201 2.5366e+02 0. 0.
*
* heat exchanger manifold
*
2100000 sec-ou branch
2100001 4 1
2100101 7.0685 200.0 0 0 0 1.5e-4 3.0 0
2100200 3 .42955e+02 143.360
2101101 112010000 210000000 1.9306 0. 0. 1100
2101201 5.1227e+02 0. 0.
2102101 212010000 210000000 1.9306 0. 0. 1100
2102201 5.0887e+02 0. 0.
2103101 312010000 210000000 1.9306 0. 0. 1100
2103201 5.0884e+02 0. 0.
2104101 210010000 137000000 1.9306 0. 0. 1000
2104201 1.5300e+03 0. 0.
*
1380000 tru-in branch
1380001 1 1
1380101 1.553 300.0 0 0 0 1.5e-4 1.40633 0
1380200 3 .72310e+02 88.271
1381101 138010000 131000000 0.0 0. 0. 1100
1381201 2.8566e+01 0. 0.
*
1370000 sec-tact anglvol
1370101 9.19 200.0 0 0 0 1.5e-4 3.42 0
1370200 3 .42831e+02 121.330
*
* servo valve to cooling tower
*
1350000 sec-inj valve
1350101 137010000 132000000 1. 0. 0. 1100
1350201 1 2.5504e+03 0. 0.
1350300 srwlv
1350301 294
*
* servo valve to cooling tower bypass
*
1360000 sec-inj valve
1360101 137010000 108000000 1. 30. 30. 1100
1360201 1 0.0000e+00 0. 0.
1360300 srwlv
1360301 295
*
1320000 cooltr pipe
1320001 5

```

```

1320101 13.0045 5
1320301 50. 5
1320601 0. 5
1320701 0. 5
1320801 1.5e-4 0.29 5
1320901 0. 0. 4
1321001 0 5
1321101 01000 4
1321201 3 .15892e+02 107.65 0. 0. 0. 1
1321202 3 .15622e+02 99.08 0. 0. 0. 2
1321203 3 .15349e+02 93.71 0. 0. 0. 3
1321204 3 .15074e+02 90.33 0. 0. 0. 4
1321205 3 .14799e+02 88.20 0. 0. 0. 5
1321300 1
1321301 2.5504e+03 0. 0. 1
1321302 2.5504e+03 0. 0. 2
1321303 2.5504e+03 0. 0. 3
1321304 2.5504e+03 0. 0. 4
*
* heat removal from secondary side:
* total left heat transfer area = 53,491.90 ft**2 (4969.397 m**2)
*
10132000 5 3 2 0 0.1 0 0 0
10132400 -1
10132401 92.34 86.83 81.56
10132402 89.10 85.65 82.35
10132403 87.26 85.10 83.03
10132404 86.20 84.83 83.53
10132405 85.56 84.70 83.88
10132100 0 1
10132101 2 0.11
10132201 10 2
10132501 0. 2
10132501 132010000 010000 1 1 20000. 5
10132601 403010000 010000 1 1 20000. 5
10132701 0 0.0 0.0 0.0 5
10132801 0 0. 0. 0. 5
10132901 0 0. 0. 0. 5
*
* cooling tower stream
*
4010000 ctsource tmdpvol
4010101 1. 1. 0. 0. 0. 1.d-6 1. 10
4010200 3 0
4010201 0. 200. 60.
*
4020000 ct|unct tmdp|un
4020101 401000000 403000000 1.
4020200 1 0 cntr|ver 305
4020201 0. 0. 0. 0.
4020202 100000. 100000. 0. 0.
*

```

```

4030000 cooltur pipe
4030001 5
4030101 13.0045 5
4030301 50. 5
4030601 0. 5
4030701 0. 5
4030801 1.5e-4 0.29 5
4030901 0. 0. 4
4031001 0 5
4031101 01000 4
4031201 3 .42540e+02 69.10 0. 0. 0. 1
4031202 3 .41939e+02 74.81 0. 0. 0. 2
4031203 3 .41343e+02 78.40 0. 0. 0. 3
4031204 3 .40749e+02 80.66 0. 0. 0. 4
4031205 3 .40157e+02 82.08 0. 0. 0. 5
4031300 1
4031301 3.8197e+03 0. 0. 1
4031302 3.8197e+03 0. 0. 2
4031303 3.8197e+03 0. 0. 3
4031304 3.8197e+03 0. 0. 4
*
4040000 ctsraj angljun
4040101 403010000 405000000 1. 0. 0. 1000
4040201 1 3.8197e+03 0. 0.
*
4050000 ctsink tndpvol
4050101 1. 1. 0. 0. 0. 0. 1.d-6 1. 10
4050200 3 0
4050201 0. 14.7 60.
*
*****
*
* heat structures on piping
*
*****
*
* heat structure between volume 50-01 and pool
*
15012000 1 3 2 0 .703167 0 0 0
15012400 -1
15012401 160.27 146.66 133.38
15012100 0 1
15012101 2 .75
15012201 10 2
15012301 0. 2
15012501 050010000 0 1 4.146 1
15012601 -5 0 4006 1 4.146 1
15012701 0 0 0 0 0 0 1
15012801 0 0 0 0 0 0 1
*
*****
*
* heat structure between volume 50-02 and pool
*
15012901 0 0 0 0 0 0 1
*
15022000 1 3 2 0 .703167 0 0 0
15022400 -1
15022401 158.73 133.95 109.63
15022100 0 1
15022101 2 .75
15022201 10 2
15022301 0. 2
15022501 050020000 0 1 16.402 1
15022601 -5 0 4007 1 16.402 1
15022701 0 0 0 0 0 0 1
15022801 0 0 0 0 0 0 1
15022901 0 0 0 0 0 0 1
*
* heat structure between volume 50-03 and pool
*
15032000 1 3 2 0 .703167 0 0 0
15032400 -1
15032401 160.17 146.59 133.34
15032100 0 1
15032101 2 .75
15032201 10 2
15032301 0. 2
15032501 050030000 0 1 1 3. 1
15032601 -5 0 4006 1 3. 1
15032701 0 0 0 0 0 0 1
15032801 0 0 0 0 0 0 1
15032901 0 0 0 0 0 0 1
*
* heat structure on volume 51-01
*
15042000 1 3 2 0 .703167 0 0 0
15042400 -1
15042401 161.95 161.96 161.96
15042100 0 1
15042101 2 .75
15042201 10 2
15042301 0. 2
15042501 051010000 0 1 1 27.8385 1
15042601 0 0 1 27.8385 1
15042701 0 0 0 0 0 0 1
15042801 0 0 0 0 0 0 1
15042901 0 0 0 0 0 0 1
*
* heat structure on volume 53-01
*
15052000 1 3 2 0 .703167 0 0 0
15052400 -1
15052401 161.96 161.96 161.96

```



```

15052100 0 1
15052101 2 .75
15052201 10 2
15052301 0. 2
15052501 053010000 0 1 1 5.7791 1
15052601 0 0 1 5.7791 1
15052701 0 0 0 0.0 1
15052801 0 0 0 0.0 1
15052901 0 0 0 0.0 1
*
* heat structure on volume 54-01
*
15062000 1 3 2 0 .703167 0 0 0
15062400 -1
15062401 161.96 161.96 161.96 161.96
15062100 0 1
15062101 2 .75
15062201 10 2
15062301 0. 2
15062501 054010000 0 1 1 14.2448 1
15062601 0 0 1 14.2448 1
15062701 0 0 0 0.0 1
15062801 0 0 0 0.0 1
15062901 0 0 0 0.0 1
*
* heat structure on volume 55-01
*
15072000 1 3 2 0 .703167 0 0 0
15072400 -1
15072401 161.96 161.96 161.96 161.96
15072100 0 1
15072101 2 .75
15072201 10 2
15072301 0. 2
15072501 055010000 0 1 1 16. 1
15072601 0 0 1 16. 1
15072701 0 0 0 0.0 1
15072801 0 0 0 0.0 1
15072901 0 0 0 0.0 1
*
* heat structure on volume 252-01
*
15082000 1 3 2 0 .703167 0 0 0
15082400 -1
15082401 161.96 161.96 161.96 161.96
15082100 0 1
15082101 2 .75
15082201 10 2
15082301 0. 2
15082501 252010000 0 1 1 3.125 1
15082601 0 0 1 3.125 1
15082701 0 0 0 0.0 0.0 1

15082801 0 0 0 0.0 0.0 1
15082901 0 0 0 0.0 0.0 1
*
* heat structure on volume 275-05
*
15092000 1 3 2 0 .783917 0 0 0
15092400 -1
15092401 127.41 127.41 127.41 127.41
15092100 0 1
15092101 2 .833333
15092201 10 2
15092301 0. 2
15092501 275050000 0 1 1 4.16667 1
15092601 0 0 1 4.16667 1
15092701 0 0 0 0.0 0.0 1
15092801 0 0 0 0.0 0.0 1
15092901 0 0 0 0.0 0.0 1
*
* heat structure on volume 77-01
*
15102000 1 3 2 0 .783917 0 0 0
15102400 -1
15102401 127.41 127.41 127.41 127.41
15102100 0 1
15102101 2 .833333
15102201 10 2
15102301 0. 2
15102501 077010000 0 1 1 16. 1
15102601 0 0 1 16. 1
15102701 0 0 0 0.0 0.0 1
15102801 0 0 0 0.0 0.0 1
15102901 0 0 0 0.0 0.0 1
*
* heat structure on volume 76-01
*
15112000 1 3 2 0 .783917 0 0 0
15112400 -1
15112401 126.67 126.67 126.67 126.67
15112100 0 1
15112101 2 .833333
15112201 10 2
15112301 0. 2
15112501 076010000 0 1 1 16. 1
15112601 0 0 1 16. 1
15112701 0 0 0 0.0 0.0 1
15112801 0 0 0 0.0 0.0 1
15112901 0 0 0 0.0 0.0 1
*
* heat structure on volume 79-01
*
15122000 1 3 2 0 .783917 0 0 0
15122400 -1

```

```

15122401 126.20 126.20 126.20 126.20
15122100 0 1
15122101 2 .833333
15122201 10 2
15122301 0. 2
15122501 079010000 0 1 1 7.3073 1
15122601 0 0 1 7.3073 1
15122701 0 0 0 0.0 1
15122801 0 0 0 0.0 1
15122901 0 0 0 0.0 1
*
* heat structure on volume 80-01
*
15132000 1 3 2 0 .783917 0 0 0
15132400 -1
15132401 126.20 126.20 126.20 126.20
15132100 0 1
15132101 2 .833333
15132201 10 2
15132301 0. 2
15132501 080010000 0 1 1 22.2916 1
15132601 0 0 1 22.2916 1
15132701 0 0 0 0.0 1
15132801 0 0 0 0.0 1
15132901 0 0 0 0.0 1
*
* heat structure on volume 80-02
*
15142000 1 3 2 0 .52271 0 0 0
15142400 -1
15142401 126.20 126.20 126.20 126.20
15142100 0 1
15142101 2 .572127
15142201 10 2
15142301 0. 2
15142501 080020000 0 1 1 5.34375 1
15142601 0 0 1 5.34375 1
15142701 0 0 0 0.0 1
15142801 0 0 0 0.0 1
15142901 0 0 0 0.0 1
*
* heat structure on volume 80-03
*
15152000 1 3 2 0 .783917 0 0 0
15152400 -1
15152401 126.20 126.20 126.20 126.20
15152100 0 1
15152101 2 .833333
15152201 10 2
15152301 0. 2
15152501 080030000 0 1 1 9.9375 1
15152601 0 0 1 9.9375 1

15152701 0 0 0 0.0 0.0 1
15152801 0 0 0 0.0 0.0 1
15152901 0 0 0 0.0 0.0 1
*
* heat structure on volume 80-04
*
15162000 1 3 2 0 .783917 0 0 0
15162400 -1
15162401 125.36 120.42 115.62
15162100 0 1
15162101 2 .833333
15162201 10 2
15162301 0. 2
15162501 080040000 0 1 1 3. 1
15162601 -5 0 4008 1 3. 1
15162701 0 0 0 0.0 0.0 1
15162801 0 0 0 0.0 0.0 1
15162901 0 0 0 0.0 0.0 1
*
* heat structure on volume 81-01
*
15172000 1 3 2 0 .783917 0 0 0
15172400 -1
15172401 124.87 117.11 109.54
15172100 0 1
15172101 2 .833333
15172201 10 2
15172301 0. 2
15172501 081010000 0 1 1 2.5 1
15172601 -5 0 4009 1 2.5 1
15172701 0 0 0 0.0 0.0 1
15172801 0 0 0 0.0 0.0 1
15172901 0 0 0 0.0 0.0 1
*
* heat structure on volume 90-01
*
15182000 1 3 2 0 .783917 0 0 0
15182400 -1
15182401 124.87 117.11 109.54
15182100 0 1
15182101 2 .833333
15182201 10 2
15182301 0. 2
15182501 090010000 0 1 1 2.91767 1
15182601 -5 0 4009 1 2.91767 1
15182701 0 0 0 0.0 0.0 1
15182801 0 0 0 0.0 0.0 1
15182901 0 0 0 0.0 0.0 1
*
* heat structure on volume 91-01,-02,-03
*
15192000 3 3 2 0 .625 0 0 0

```

```

15192400 -1
15192401 125.13 120.67 116.33
15192402 125.13 120.66 116.33
15192403 125.12 120.65 116.32
15192100 0 1
15192101 2 .666667
15192201 10 2
15192301 0. 2
15192501 091010000 0 1 1 3.9890 1
15192502 091020000 0 1 1 4.8333 2
15192503 091030000 0 1 1 5.5166 3
15192601 -5 0 4010 1 3.9890 1
15192602 -5 0 4010 1 4.8333 2
15192603 -5 0 4010 1 5.5166 3
15192701 0 0 0 0 0 0 3
15192801 0 0 0 0 0 0 3
15192901 0 0 0 0 0 0 3
*
* heat structure on volume 92-01,-02,-03
*
15202000 3 3 2 0 .625 0 0
15202400 -1
15202401 125.13 120.67 116.33
15202402 125.13 120.66 116.33
15202403 125.12 120.65 116.32
15202100 0 1
15202101 2 .666667
15202201 10 2
15202301 0. 2
15202501 092010000 0 1 1 3.9890 1
15202502 092020000 0 1 1 4.833 2
15202503 092030000 0 1 1 5.5166 3
15202601 -5 0 4010 1 3.9890 1
15202602 -5 0 4010 1 4.833 2
15202603 -5 0 4010 1 5.5166 3
15202701 0 0 0 0 0 0 3
15202801 0 0 0 0 0 0 3
15202901 0 0 0 0 0 0 3
*
* cell d piping heat structures
*
*
* heat structure on volume 52-01
*
15252000 1 3 2 0 .3985 0 0
15252400 -1
15252401 161.95 161.95 161.95
15252100 0 1
15252101 2 .447917
15252201 10 2
15252301 0. 2
15252501 052010000 0 1 1 3.5282 1
15252601 0 0 0 1 3.5282 1
15252701 0 0 0 0 0 0 1
15252801 0 0 0 0 0 0 1
15252901 0 0 0 0 0 0 1
*
* heat structure on volume 52-02,-03,-04
*
15262000 3 3 2 0 .4175 0 0
15262400 -1
15262401 161.95 161.95 161.95
15262402 161.96 161.96 161.96
15262403 161.96 161.96 161.96
15262100 0 1
15262101 2 .447917
15262201 10 2
15262301 0. 2
15262501 052020000 0 1 1 9.9791 1
15262502 052030000 0 1 1 8.2917 2
15262503 052040000 0 1 1 10.3017 3
15262601 0 0 0 1 9.9791 1
15262602 0 0 0 1 8.2917 2
15262603 0 0 0 1 10.3017 3
15262701 0 0 0 0 0 0 3
15262801 0 0 0 0 0 0 3
15262901 0 0 0 0 0 0 3
*
* heat structure on volume 57-01
*
15272000 1 3 2 0 .546836 0 0
15272400 -1
15272401 161.96 161.96 161.96
15272100 0 1
15272101 2 .583247
15272201 10 2
15272301 0. 2
15272501 57010000 0 1 1 3.1772 1
15272601 0 0 0 1 3.1772 1
15272701 0 0 0 0 0 0 1
15272801 0 0 0 0 0 0 1
15272901 0 0 0 0 0 0 1
*
* heat structure on volume 113-01,114-01
*
15502000 2 3 3 0 1.9583 0 0
15502400 -1
15502401 161.96 161.98 161.98
15502402 125.96 125.96 125.96
15502100 0 1
15502101 2 2.07913
15502201 10 2
15502301 0. 2
15502501 113010000 1000000 1 1 0.25 2

```

```

15502601 0 0 0 0.25 2
15502701 0 0 0 0.0 2
15502801 0 0 0 0.0 2
15502901 0 0 0 0.0 2
*
* heat structures on volume 60-01,-02,-03
*
15282000 3 3 2 0 .546836 0 0 0
15282400 -1
15282401 125.96 125.96 125.96
15282402 125.96 125.96 125.96
15282403 125.96 125.96 125.96
15282100 0 1
15282101 2 .583247
15282201 10 2
15282301 0. 2
15282501 060010000 0 1 1 2.4480 1
15282502 060020000 0 1 1 3.9477 2
15282503 060030000 0 1 1 3.9573 3
15282601 0 0 1 2.4480 1
15282602 0 0 1 3.9477 2
15282603 0 0 1 3.9573 3
15282701 0 0 0 0.0 3
15282801 0 0 0 0.0 3
15282901 0 0 0 0.0 3
*
* heat structure on volume 73-01
*
15292000 1 3 2 0 .4175 0 0 0
15292400 -1
15292401 126.18 126.18 126.18
15292100 0 1
15292101 2 .44792
15292201 10 2
15292301 0. 2
15292501 073010000 0 1 1 1.0 1
15292601 0 0 1 1. 1
15292701 0 0 0 0.0 1
15292801 0 0 0 0.0 1
15292901 0 0 0 0.0 1
*
* heat structure on volume 75-01,-02,-03
*
15302000 3 3 2 0 .4175 0 0 0
15302400 -1
15302401 126.18 126.18 126.18
15302402 126.18 126.18 126.18
15302403 126.18 126.18 126.18
15302100 0 1
15302101 2 .447917
15302201 10 2
15302301 0. 2
15302501 075010000 0 1 1 2.29165 1
15302502 075020000 0 1 1 10.8385 2
15302503 075030000 0 1 1 5.22917 3
15302601 0 0 1 2.29165 1
15302602 0 0 1 10.8385 2
15302603 0 0 1 5.22917 3
15302701 0 0 0 0.0 3
15302801 0 0 0 0.0 3
15302901 0 0 0 0.0 3
*
* heat structure on volume 75-04
*
15312000 1 3 2 0 .3985 0 0 0
15312400 -1
15312401 126.18 126.19 126.19
15312100 0 1
15312101 2 .447917
15312201 10 2
15312301 0. 2
15312501 075040000 0 1 1 2.82843 1
15312601 0 0 1 2.82843 1
15312701 0 0 0 0.0 1
15312801 0 0 0 0.0 1
15312901 0 0 0 0.0 1
*
* cell c piping heat structures
*
*
* heat structure on volume 152-01
*
15322000 1 3 2 0 .3985 0 0 0
15322400 -1
15322401 161.95 161.95 161.95
15322100 0 1
15322101 2 .447917
15322201 10 2
15322301 0. 2
15322501 152010000 0 1 1 2.8284 1
15322601 0 0 1 2.8284 1
15322701 0 0 0 0.0 1
15322801 0 0 0 0.0 1
15322901 0 0 0 0.0 1
*
* heat structure on volume 152-02,-03,-04
*
15332000 3 3 2 0 .4175 0 0 0
15332400 -1
15332401 161.95 161.95 161.95
15332402 161.95 161.95 161.95
15332403 161.95 161.95 161.95
15332100 0 1
15332101 2 .447917

```

```

15332201 10 2
15332301 0. 2
15332501 152020000 0 1 1 7.4843 1
15332502 152030000 0 1 1 8.2917 2
15332503 152040000 0 1 1 10.3017 3
15332601 0 0 1 7.4843 1
15332602 0 0 1 8.2917 2
15332603 0 0 1 10.3017 3
15332701 0 0 0 0.0 0.0 3
15332801 0 0 0 0.0 0.0 3
15332901 0 0 0 0.0 0.0 3
*
* heat structure on volume 157-01
*
15342000 1 3 2 0 .546836 0 0 0
15342400 -1
15342401 125.65 125.65 125.65
15342100 0 1
15342101 2 .583247
15342201 10 2
15342301 0. 2
15342501 214010000 0 1 1 3.1772 1
15342601 0 0 1 3.1772 1
15342701 0 0 0 0.0 0.0 1
15342801 0 0 0 0.0 0.0 1
15342901 0 0 0 0.0 0.0 1
*
* heat structure on volume 213-01,214-01
*
15512000 2 3 3 0 1.9583 0 0 0
15512400 -1
15512401 161.96 161.98 161.98
15512402 125.65 125.65 125.65
15512100 0 1
15512101 2 2.07913
15512201 10 2
15512301 0. 2
15512501 213010000 1000000 1 1 0.25 2
15512601 0 0 1 0.25 2
15512701 0 0 0 0.0 0.0 2
15512801 0 0 0 0.0 0.0 2
15512901 0 0 0 0.0 0.0 2
*
* heat structures on volume 160-01,-02,-03
*
15352000 3 3 2 0 .546836 0 0 0
15352400 -1
15352401 125.65 125.65 125.65
15352402 125.65 125.65 125.65
15352403 125.65 125.65 125.65
15352100 0 1
15352101 2 .583247

15352201 10 2
15352301 0. 2
15352501 160010000 0 1 1 2.4480 1
15352502 160020000 0 1 1 3.9477 2
15352503 160030000 0 1 1 3.9573 3
15352601 0 0 1 2.4480 1
15352602 0 0 1 3.9477 2
15352603 0 0 1 3.9573 3
15352701 0 0 0 0.0 0.0 3
15352801 0 0 0 0.0 0.0 3
15352901 0 0 0 0.0 0.0 3
*
* heat structure on volume 173-01
*
15362000 1 3 2 0 .4175 0 0 0
15362400 -1
15362401 125.88 125.88 125.88
15362100 0 1
15362101 2 .44792
15362201 10 2
15362301 0. 2
15362501 173010000 0 1 1 1.0 1
15362601 0 0 1 1. 1
15362701 0 0 0 0.0 0.0 1
15362801 0 0 0 0.0 0.0 1
15362901 0 0 0 0.0 0.0 1
*
* heat structure on volume 175-01,-02,-03
*
15372000 3 3 2 0 .4175 0 0 0
15372400 -1
15372401 125.88 125.88 125.88
15372402 125.88 125.88 125.88
15372403 125.88 125.88 125.88
15372100 0 1
15372101 2 .447917
15372201 10 2
15372301 0. 2
15372501 175010000 0 1 1 2.29165 1
15372502 175020000 0 1 1 10.8385 2
15372503 175030000 0 1 1 5.22917 3
15372601 0 0 1 2.29165 1
15372602 0 0 1 10.8385 2
15372603 0 0 1 5.22917 3
15372701 0 0 0 0.0 0.0 3
15372801 0 0 0 0.0 0.0 3
15372901 0 0 0 0.0 0.0 3
*
* heat structure on volume 175-04
*
15382000 1 3 2 0 .3985 0 0 0
15382400 -1

```

```

15382401 125.88 125.88 125.88 125.88
15382100 0 1
15382101 2 .447917
15382201 10 2
15382301 0. 2
15382501 175040000 0 1 1 2.82843 1
15382601 0 0 1 2.82843 1
15382701 0 0 0 0.0 1
15382801 0 0 0 0.0 1
15382901 0 0 0 0.0 1
*
* cell a piping heat structures
*
*
*
* heat structure on volume 252-01
*
15392000 1 3 2 0 .70315 0 0 0
15392400 -1
15392401 161.96 161.96 161.96 161.96
15392100 0 1
15392101 2 .74998
15392201 10 2
15392301 0. 2
15392501 252010000 0 1 1 3.125 1
15392601 0 0 1 3.125 1
15392701 0 0 0 0.0 1
15392801 0 0 0 0.0 1
15392901 0 0 0 0.0 1
*
* heat structure on volume 252-02, -03, -04
*
15402000 3 3 2 0 .4175 0 0 0
15402400 -1
15402401 161.96 161.96 161.96 161.96
15402402 161.96 161.96 161.96 161.96
15402403 161.96 161.96 161.96 161.96
15402100 0 1
15402101 2 .447917
15402201 10 2
15402301 0. 2
15402501 252020000 0 1 1 22.3593 1
15402502 252030000 0 1 1 10.29165 2
15402503 252040000 0 1 1 10.3017 3
15402601 0 0 1 22.3593 1
15402602 0 0 1 10.29165 2
15402603 0 0 1 10.3017 3
15402701 0 0 0 0.0 3
15402801 0 0 0 0.0 3
15402901 0 0 0 0.0 3
*
* heat structure on volume 257-01
*
15412000 1 3 2 0 .546836 0 0 0
15412400 -1
15412401 127.19 127.19 127.19 127.19
15412100 0 1
15412101 2 .583247
15412201 10 2
15412301 0. 2
15412501 314010000 0 1 1 3.1772 1
15412601 0 0 1 3.1772 1
15412701 0 0 0 0.0 1
15412801 0 0 0 0.0 1
15412901 0 0 0 0.0 1
*
* heat structure on volume 313-01,314-01
*
15522000 2 3 3 0 1.9583 0 0 0
15522400 -1
15522401 161.97 161.97 161.98 161.99
15522402 127.19 127.19 127.19 127.18
15522100 0 1
15522101 2 2.07913
15522201 10 2
15522301 0. 2
15522501 313010000 1000000 1 1 0.25 2
15522601 0 0 1 0.25 2
15522701 0 0 0 0.0 2
15522801 0 0 0 0.0 2
15522901 0 0 0 0.0 2
*
* heat structures on volume 260-01, -02, -03
*
15422000 3 3 2 0 .546836 0 0 0
15422400 -1
15422401 127.18 127.19 127.19 127.19
15422402 127.18 127.19 127.19 127.19
15422403 127.18 127.19 127.19 127.19
15422100 0 1
15422101 2 .583247
15422201 10 2
15422301 0. 2
15422501 260010000 0 1 1 2.4480 1
15422502 260020000 0 1 1 3.9477 2
15422503 260030000 0 1 1 3.9573 3
15422601 0 0 1 2.4480 1
15422602 0 0 1 3.9477 2
15422603 0 0 1 3.9573 3
15422701 0 0 0 0.0 3
15422801 0 0 0 0.0 3
15422901 0 0 0 0.0 3
*
* heat structure on volume 273-01
*

```

```

15432000 1 3 2 0 .4175 0 0 0
15432400 -1
15432401 127.40 127.40 127.40
15432100 0 1
15432101 2 .44792
15432201 10 2
15432301 0. 2
15432501 273010000 0 1 1 1.0 1
15432601 0 0 1 1. 1
15432701 0 0 0 0.0 1
15432801 0 0 0 0.0 1
15432901 0 0 0 0.0 1
*
* heat structure on volume 275-01,-02,-03,-04
*
15442000 4 3 2 0 .4175 0 0 0
15442400 -1
15442401 127.40 127.40 127.40
15442402 127.40 127.40 127.40
15442403 127.40 127.40 127.40
15442404 127.40 127.41 127.41
15442100 0 1
15442101 2 .447917
15442201 10 2
15442301 0. 2
15442501 275010000 0 1 1 2.29165 1
15442502 275020000 0 1 1 9.6072 2
15442503 275030000 0 1 1 3.75638 3
15442504 275040000 0 1 1 17.7947 4
15442601 0 0 1 2.29165 1
15442602 0 0 1 9.6072 2
15442603 0 0 1 3.75638 3
15442604 0 0 1 17.7947 4
15442701 0 0 0 0.0 4
15442801 0 0 0 0.0 4
15442901 0 0 0 0.0 4
*
* heat structure on volume 275-05
*
15452000 1 3 2 0 .7839 0 0 0
15452400 -1
15452401 127.41 127.41 127.41
15452100 0 1
15452101 2 .8333
15452201 10 2
15452301 0. 2
15452501 275050000 0 1 1 4.16667 1
15452601 0 0 1 4.16667 1
15452701 0 0 0 0.0 1
15452801 0 0 0 0.0 1
15452901 0 0 0 0.0 1
*
* heat structures in cell b
*
*
* heat structure on volume 352-01
*
15462000 1 3 2 0 .3985 0 0 0
15462400 -1
15462401 140.35 140.35 140.35
15462100 0 1
15462101 2 .447917
15462201 10 2
15462301 0. 2
15462501 352010000 0 1 1 2.8284 1
15462601 0 0 1 2.8284 1
15462701 0 0 0 0.0 1
15462801 0 0 0 0.0 1
15462901 0 0 0 0.0 1
*
* heat structure on volume 352-02,-03
*
15472000 2 3 2 0 .4175 0 0 0
15472400 -1
15472401 139.93 139.93 139.93
15472402 139.93 139.93 139.93
15472100 0 1
15472101 2 .447917
15472201 10 2
15472301 0. 2
15472501 352020000 0 1 1 7.4843 1
15472502 352030000 0 1 1 8.2917 2
15472601 0 0 1 7.4843 1
15472602 0 0 1 8.2917 2
15472701 0 0 0 0.0 2
15472801 0 0 0 0.0 2
15472901 0 0 0 0.0 2
*
* heat structure on volume 375-01,-02
*
15482000 2 3 2 0 .4175 0 0 0
15482400 -1
15482401 140.00 140.00 140.00
15482402 140.00 140.00 140.00
15482100 0 1
15482101 2 .447917
15482201 10 2
15482301 0. 2
15482501 375010000 0 1 1 10.8385 1
15482502 375020000 0 1 1 5.22917 2
15482601 0 0 1 10.8385 1
15482602 0 0 1 5.22917 2
15482701 0 0 0 0.0 2
15482801 0 0 0 0.0 2

```

```

15482901 0 0.0 0.0 0.0 2
*
* heat structure on volume 375-03
*
15492000 1 3 2 0 .3985 0 0 0
15492400 -1
15492401 139.52 139.52 139.52
15492100 0 1
15492101 2 .447917
15492201 10 2
15492301 0. 2
15492501 375030000 0 1 1 2.82843 1
15492601 0 0 0 1 2.82843 1
15492701 0 0.0 0.0 0.0 1
15492801 0 0.0 0.0 0.0 1
15492901 0 0.0 0.0 0.0 1
*
*****
*
* material properties
*
*****
*
* 6061/1100-al thermal properties(fuel clad)
*
20100100 tbl/fctn 1 1
20100101 82.4 0.0291 442.4 0.0321 802.4 0.0316 1204. 0.0276
20100151 80. 36.3 440. 39.9 980. 45.6 1160. 47.7
*
* al/u3o8 thermal properties(inner fuel)
*
20100200 tbl/fctn 1 1
20100201 80.3 0.02844 260.3 0.02819 900. 0.02792 1204. 0.02773
20100251 80. 32.1 440. 35.6 980. 40.5 1205. 44.7
*
* al/u3o8 thermal properties(outer fuel)
*
20100300 tbl/fctn 1 1
20100301 80.3 0.02553 260.3 0.02539 900. 0.02540 1204. 0.02535
20100351 80. 32.2 440. 35.8 980. 40.6 1205. 44.7
*
* al/cmo1.73 thermal properties(target)
*
20100400 tbl/fctn 1 1
20100401 0.00386
20100451 80. 22.5 440. 24.9 980. 28.3 1205. 31.2
*
* oxide thermal properties
*
20100500 tbl/fctn 1 1
20100501 0.000361
20100551 80. 35.9 440. 47.3 980. 52.9 1205. 54.8
*
* al/eu2o3 thermal properties(control cylinder)
*
20100600 tbl/fctn 1 1
20100601 0.0108
20100651 80. 36.6 440. 40.3 980. 45.4 1205. 48.8
*
* be thermal properties(reflector)
*
20100700 tbl/fctn 1 1
20100701 80. 0.0322 260. 0.0258 620. 0.0202 1160. 0.0156
20100751 80. 50.1 392. 62.6 752. 71.3 1292. 80.3
*
* 6061-t6-al thermal properties
*
20100800 tbl/fctn 1 1
20100801 82.4 0.0255 442.4 0.0299 802.4 0.0310 1204. 0.0276
20100851 80. 36.3 440. 39.9 980. 45.5 1160. 47.3
*
* x-8001-al thermal properties; nearest alloy with available properties
* used.(target pellet containment tube)
*
20100900 tbl/fctn 1 1
20100901 80. 0.0336 122. 0.0336 302. 0.0347 572. 0.0356 1200. 0.0383
20100951 80. 36.0 440. 39.9 674. 42.4 710. 42.8 980. 46.0 1205. 51.2
*
* 304l-ss thermal properties
*
20101000 tbl/fctn 1 1
20101001 50. 0.00239 80. 0.00244 440. 0.00294 620. 0.00317 980. 0.00361
20101051 50. 44.6 80. 44.6 440. 45.6 620. 46.1 980. 49.1
*
* 347-ss thermal properties
*
20101100 tbl/fctn 1 1
20101101 80. 0.00238 440. 0.00286 620. 0.00308 980. 0.00353
20101151 80. 53.8 440. 59.3 620. 61.7 980. 66.7
*
* carbon steel thermal properties
*
20101200 tbl/fctn 1 1
20101201 86. 0.0112 212. 0.00919 439. 0.00658 932. 0.00339
20101251 68. 54.3 176. 58.7 428. 64.5 986. 79.7
*
* target rod gap effective contact thermal conductivity
*
20101300 tbl/fctn 1 1
20101301 8.11e-6
20101351 0.0

```



```

*
* 1100-al thermal properties(target pellet jacket)
*
20101400 tbl/fctn 1 1
20101401 82.4 0.0381 442.4 0.0381 802.4 0.0363 1204. 0.0339
20101451 80. 36.3 440. 40.2 980. 46.3 1205. 51.5
*
*****
*
* c o n t r o l   s y s t e m s
*
*****
*
*****
*
* primary coolant head tank level
*
* demineralized water flow into pc head tank 90 gpm (80 deg. f)
20500100 demin tripunit 1.247000d+01 0.000000d+00 0
20500101 511
* sum mass flows into the primary coolant head tank.
* density is 62.2 lb/ft**3 (80 deg f). convert mflow's
* from kg/s to lb/s
*
* - cntrlvar 1 - demineralized water make-up flow
* - mflowj 63, 163, 263 - letdown valve flows
* - mflowj 66 - main pressurizer pump flow
* - mflowj 69 - standby pressurizer pump flow
* - mflowj 71 - auxiliary pressurizer pump flow
20500200 tankmdot sum 1.000000d+00 -1.223390d-01 1
20500201 0. 1.,cntrlvar,1 2.2046,mflowj,63000000
20500202 2.2046,mflowj,163000000 2.2046,mflowj,263000000
20500203 -2.2046,mflowj,66010000 -2.2046,mflowj,69010000
20500204 -2.2046,mflowj,71000000
* if transient has not yet begun, zero net mass flow into tank
20500300 transient tripunit 1.000000d+00 0.000000d+00 1
20500301 503
20500400 mdot mult 1.000000d+00 0.000000d+00 1
20500401 cntrlvar,2 cntrlvar,3
* integrate net mass flow into the pc head tank for %full
* density is 62.2 lb/ft**3, tank capacity is 2500 gallons
* initially tank level reading is 70% (52.4 in. actual level, 78.5% full)
* note: measured tank level 2.0 in. less than actual tank level and
ranges
* from 0-72 in. (0-6 ft). the actual tank id is 78 inches (6.5
ft).
20500500 tankvol integral 4.810000d-05 7.850010d-01 0
20500501 cntrlvar,4
20500600 tanklevl function 1.000000d+00 4.762010d+00 1
20500601 cntrlvar,5,11
20500700 tankmeas sum 1.000000d+00 4.595310d+00 1
20500701 -0.1667 1.,cntrlvar,6

*
* standby pressurizer pump speed
*
20500800 stb tripunit 1.000000d+00 0.000000d+00 1
20500801 612
20500900 stbsp tripdelay 1.000000d+00 -1.000000d+00 1
20500901 612
20501000 stbysum sum 1.000000d+00 7.079200d+01 1
20501001 0. -1.,cntrlvar,9 1.,time,0
20501100 stbmult mult 1.000000d+00 0.000000d+00 1
20501101 cntrlvar,8 cntrlvar,10
20501200 stbsp function 2.171060d+03 0.000000d+00 1
20501201 cntrlvar,11,4
*
* pressurizer pump shutdown due to low suction pressure
*
* determine if very low pwr pump suction was detected
20501500 lowptdlt tripdelay 1.000000d+00 -1.000000d+00 1
20501501 606
* determine the time since the suction pressure dropped below minimum
20501600 lowpsum sum 1.000000d+00 7.079200d+01 1
20501601 0. 1.,time,0 -1.,cntrlvar,15
* set to 1 if suction pressure is still low
20501700 lowptrip tripunit 1.000000d+00 0.000000d+00 1
20501701 606
* set to 1.0 if pwr pumps should be tripped because of low suction p
20501800 lowpsult mult 1.000000d+00 0.000000d+00 1
20501801 cntrlvar,16 cntrlvar,17
*
* determine auxiliary pressurizer pump flow
*
20501900 aux-tu tripunit 1.000000d+00 0.000000d+00 1
20501901 623
20502000 auxdp sum 1.450377d-04 4.278150d+02 1
20502001 0. 1.,p,67010000 -1.,p,47010000
20502100 auxflow function 1.000000d+00 0.000000d+00 1
20502101 cntrlvar,20,2
20502200 auxptrdlt tripdelay 1.000000d+00 -1.000000d+00 1
20502201 623
20502300 auxpsrch sum 1.000000d+00 7.079200d+01 1
20502301 0. -1.,cntrlvar,22 1.,time,0
20502400 auxpfac function 1.000000d+00 1.000000d+00 1
20502401 cntrlvar,23,3
20502500 auxpfow mult 1.000000d+00 0.000000d+00 1
20502501 cntrlvar,19 cntrlvar,21 cntrlvar,24
*
* let-down valve control
* gain = 0.0006 /psi
* reset time = 0.0006/0.0007 = 0.85714 s
* derivative time = 0.00069/0.0006 = 1.15 s
*
20502600 timestep sum 1.000000d+00 3.000000d-03 0

```

```

20502601 0. 1.,time,0 -1.0,ctrlvar,43
20502700 lcbvlnai tripunit 1.000000d+00 1.000000d+00 1
20502701 -571
20502800 lcblopr tripunit 1.000000d+00 0.000000d+00 1
20502801 622
20502900 lbw-tim tripdelay 1.000000d+00 -1.000000d+00 1
20502901 622
20503000 lbw-tims sum 1.000000d+00 7.079200d+01 1
20503001 0. 1.,time,0 -1.,ctrlvar,29
20503100 lbw-arg mult 1.00.,00d+00 0.000000d+00 1
20503101 ctrlvar,28 ctrlvar,30
20503200 lbw-fact sum 1. 1.000000d+00 1 3 0.00000d+00 1.00000d+00
20503201 1.0 -0.25,ctrlvar,31
20503300 lcbclose mult 1.000000d+00 1.000000d+00 1
20503301 ctrlvar,27 ctrlvar,32
* let-down control valve
20503400 lderorr sum 1.000000d+00 1.387925d-05 1
20503401 0. 1.450377e-4,p,79010000 -1.,ctrlvar,670
20503500 proint prop-int 1.000000d+00 6.305670d-01 0
20503501 0.00600 0.00070 ctrlvar 34
20503600 ldderiv diffrend 6.900000d-04 2.114756d-06 0
20503601 ctrlvar,34
20503700 pldctrl sum 1.000000d+00 6.305690d-01 1
20503701 0. 1.,ctrlvar,35 1.,ctrlvar,36
20503800 deltepo sum 1.000000d+00 4.198015d-06 1
20503801 0. 1.,ctrlvar,37 -1.,ctrlvar,41
20503900 speed div 1. 1.39934d-03 1 3 -1.16280d-01 5.84800d-02
20503901 ctrlvar,26 ctrlvar,38
20504000 deltepos mult 1.000000d+00 4.198015d-06 1
20504001 ctrlvar,39 ctrlvar,26
20504100 new-posi sum 1.000000d+00 6.305690d-01 1
20504101 0. 1.,ctrlvar,40 1.,ctrlvar,41
*
20504200 ldst-p mult 1. 6.30569d-01 1 3 0.00000d+00 1.00000d+00
20504201 ctrlvar,41 ctrlvar,33
20504300 old-time mult 1.000000d+00 6.979200d+01 1
20504301 time,0
* leakage from system
*
20504500 gage-pre sum 1.450377d-04 4.219400d+02 1 1 0.000000d+00
20504501 -1.0135d5 1.,p,79010000
20504600 prexon powerr 1.000000d+00 1.443150d+01 1
20504601 ctrlvar,45,0.4416
20504700 leakage mult 1.090300d-05 1.554990d-01 1
20504701 ctrlvar,46 rhof,79010000
*
* automatic control of fcv 377a
*
* gain = 0.2
* reset time = 0.2/0.01
* derivative constant = 0.2/0.5
20505200 seerror sum 1.000000d+00 3.958404d-04 0
20505201 -459.67 1.8,tempf,80010000 -1.,ctrlvar,671
20505300 sec-pi prop-int 1.000000d+00 3.560974d-02 0
20505301 0.2 0.010 ctrlvar 52
20505400 sec-d diffrend 5.000000d-01 -1.799679d-05 0
20505401 ctrlvar,52
20505500 sec-pid sum 1.000000d+00 3.559174d-02 1
20505501 0. 1.,ctrlvar,53 1.,ctrlvar,54
* add 2.s lag for valve actuator
20505600 sec-lag lag 1. 3.55897d-02 1 3 0.00000d+00 1.00000d+00
20505601 2.0 ctrlvar,55
* check for loss of instrument air
20505700 vpos377a sum 1. 3.55897d-02 1 3 0.00000d+00 1.00000d+00
20505701 0. 1.,ctrlvar,56 1.,ctrlvar,72
*
* control of auxiliary secondary coolant pump
*
20505800 sec-off tripdelay 1.000000d+00 -1.000000d+00 1
20505801 649
20505900 sec-srch sum 1.000000d+00 7.079200d+01 1
20505901 0. -1.,ctrlvar,58 1.,time,0
20506000 sec-fact function 1.000000d+00 1.000000d+00 1
20506001 ctrlvar,59,3
20506100 sec-tru tripunit 1.000000d+00 0.000000d+00 1
20506101 649
20506200 noac-tru tripunit 1.000000d+00 0.000000d+00 1
20506201 553
20506300 sec-fac2 sum 1.000000d+00 1.000000d+00 1
20506301 1. -0.5,ctrlvar,62
20506400 sec-mult mult 1.200000d+03 0.000000d+00 1
20506401 ctrlvar,61 ctrlvar,60 ctrlvar,63
*
* normalized area of heat exchanger bypass valve
*
20506500 hxbypass sum 1.000000d+00 5.000000d-01 0
20506501 0. 1.,ctrlvar,689 -1.,ctrlvar,72
* add 0.005 s lag for valve closing
20506600 sec-lag lag 1. 5.00000d-01 0 3 0.00000d+00 1.00000d+00
20506601 0.005 ctrlvar,65
*
* manual control of fcv 377
*
20506700 se-tu1 tripunit 1.000000d+00 0.000000d+00 0
20506701 569
20506800 se-td1 tripdelay 1.000000d+00 -1.000000d+00 0
20506801 569
20506900 se-sum1 sum 1.000000d+00 7.079200d+01 0
20506901 0. -1.,ctrlvar,68 1.,time,0
20507000 se-fact div 1. 1.00000d+00 0 3 0.00000d+00 1.00000d+00
20507001 ctrlvar,688 ctrlvar,69
20507100 se-adjst mult 1.000000d+00 0.000000d+00 0

```

```

20507101 cntrlvar,67 cntrlvar,70 cntrlvar,687
20507200 se-tu2 tripunit 1.000000d+00 0.000000d+00 0
20507201 571
20507300 cv377pos sum 1. 1.00000d-01 0 3 0.00000d+00 1.00000d+00
20507301 0. -1.,cntrlvar,71 1.,cntrlvar,687 1.,cntrlvar,72
*
* velocity head at mcp suction
*
20507400 mcpvq1d mult 7.251900d-05 1.189640d+00 1
20507401 rhoF,60030000 velFj,70010000 velFj,70010000
20507500 mcpvq1c mult 7.251900d-05 1.146990d+00 1
20507501 rhoF,160030000 velFj,170010000 velFj,170010000
20507600 mcpvq1e mult 7.251900d-05 1.296680d+00 1
20507601 rhoF,260030000 velFj,270010000 velFj,270010000
*
* pump speed calculations after pump trip
*
20507700 mcptrip tripunit 1.000000d+00 0.000000d+00 1
20507701 660
20507800 mcpntrip tripunit 1.000000d+00 1.000000d+00 1
20507801 -660
*==== pu-1d ====
20507900 frtrq-1d function 1.000000d+00 3.700000d+02 0
20507901 cntrlvar,116,43
20508000 motrq-1d function 1.000000d+00 0.000000d+00 0
20508001 cntrlvar,116,44
* water power = (flow)(pressure difference)
20508100 watpw-1d mult 2.088540d-02 3.312690d+05 0
20508101 cntrlvar,106 pmphed,70
* water torque = (water power)/(pump speed)
20508200 watrq-1d div 9.549300d+00 1.634600d+03 0
20508201 cntrlvar,86 cntrlvar,81
* sum of torques divided by pump inertia (rate of speed change)
* scaling factor = gc/inertia
20508300 torq-1d sum 6.880340d-02 -1.379230d+02 0
20508301 0. -1.,cntrlvar,79 1.,cntrlvar,80 -1.,cntrlvar,82
* do not adjust speed unless pumps have been tripped (convert to rpm)
20508400 adj-1d mult 9.549300d+00 0.000000d+00 0
20508401 cntrlvar,83 cntrlvar,77
* adjustment to pump speed
20508500 adjus-1d integral 1.000000d+00 0.000000d+00 0
20508501 cntrlvar,84
* actual pu-1d pump speed after pump trip
20508600 actspd1d sum 1.000000d+00 1.935260d+03 0 1 2.700000d+02
*==== pu-1c ====
20508700 frtrq-1c function 1.000000d+00 3.700000d+02 0
20508701 cntrlvar,141,43
20508800 motrq-1c function 1.000000d+00 0.000000d+00 0
20508801 cntrlvar,141,44
* water power = (flow)(pressure difference)
20508900 watpw-1c mult 2.088540d-02 3.263130d+05 0
20508901 cntrlvar,131 pmphed,170
* water torque = (water power)/(pump speed)
20509000 watrq-1c div 9.549300d+00 1.610150d+03 0
20509001 cntrlvar,94 cntrlvar,89
* sum of torques divided by pump inertia (rate of speed change)
20509100 torq-1c sum 6.880340d-02 -1.362410d+02 0
20509101 0. -1.,cntrlvar,87 1.,cntrlvar,88 -1.,cntrlvar,90
* do not adjust speed unless pumps have been tripped (convert to rpm)
20509200 adj-1c mult 9.549300d+00 0.000000d+00 0
20509201 cntrlvar,91 cntrlvar,77
* adjustment to pump speed
20509300 adjus-1c integral 1.000000d+00 0.000000d+00 0
20509301 cntrlvar,92
* actual pu-1c pump speed after pump trip
20509400 actspd1c sum 1.000000d+00 1.935260d+03 0 1 2.700000d+02
20509401 0. 1.,cntrlvar,186 1.,cntrlvar,93
*==== pu-1a ====
20509500 frtrq-1a function 1.000000d+00 3.700000d+02 0
20509501 cntrlvar,166,43
20509600 motrq-1a function 1.000000d+00 0.000000d+00 0
20509601 cntrlvar,166,44
* water power = (flow)(pressure difference)
20509700 watpw-1a mult 2.088540d-02 3.420030d+05 0
20509701 cntrlvar,156 pmphed,270
* water torque = (water power)/(pump speed)
20509800 watrq-1a div 9.549300d+00 1.687570d+03 0
20509801 cntrlvar,102 cntrlvar,97
* sum of torques divided by pump inertia (rate of speed change)
20509900 torq-1a sum 6.880340d-02 -1.415680d+02 0
20509901 0. -1.,cntrlvar,95 1.,cntrlvar,96 -1.,cntrlvar,98
* do not adjust speed unless pumps have been tripped (convert to rpm)
20510000 adj-1a mult 9.549300d+00 0.000000d+00 0
20510001 cntrlvar,99 cntrlvar,77
* adjustment to pump speed
20510100 adjus-1a integral 1.000000d+00 0.000000d+00 0
20510101 cntrlvar,100
* actual pu-1a pump speed after pump trip
20510200 actspd1a sum 1.000000d+00 1.935260d+03 0 1 2.700000d+02
20510201 0. 1.,cntrlvar,186 1.,cntrlvar,101
*
* pump cavitation prediction
*
*==== pu-1d ====
* saturation pressure for volume 60-03
20510300 tmp60dgc sum 1.000000d+00 5.219750d+01 1
20510301 -273.15 1.,tempf,60030000
20510400 tmp60dgc sum 1.000000d+00 1.259560d+02 1
20510401 32. 1.8,cntrlvar,103
20510500 satprs60 function 1.000000d+00 2.010440d+00 1
20510501 cntrlvar,104,35
* pump flow pu-1d (cubic feet per second)
20510600 flow60 div 3.531500d+01 1.255990d+01 1

```

20510601 rhojj,70010000 mflowj,70010000
 20510700 cq-pu1d div 2.185000d+00 1.418071d-02 1
 20510701 cntrlvar,86 cntrlvar,106
 20510800 chscr1d function 1.000000d+00 9.567414d-03 1
 20510801 cntrlvar,107,38
 20510900 npsch1d mult 9.104100d-04 3.262210d+01 1
 20510901 cntrlvar,108 cntrlvar,86 cntrlvar,86
 * critical npsch for pu-1d in psi
 20511000 npsic1d mult 4.335280d-04 1.397010d+01 1
 20511001 cntrlvar,109 rhojj,70010000
 * suction pressure to pu-1d in psi
 20511100 suct-1d mult 1.450377d-04 2.637460d+02 1
 20511101 p,60030000
 * actual npsch for pu-1d in psi
 20511200 npsch-1d sum 1.000000d+00 2.629250d+02 1
 20511201 0.1.,cntrlvar,111 -1.,cntrlvar,105 1.,cntrlvar,74
 * ratio of actual npsch to critical npsch
 20511300 npsch1d div 1.000000d+00 1.882060d+01 1
 20511301 cntrlvar,110 cntrlvar,112
 * head degradation factor
 20511400 degra1d function 1.000000d+00 1.000000d+00 1
 20511401 cntrlvar,113,39
 * determine nondimensional homologous variables
 20511500 v-1d mult 8.975290d-02 1.127290d+00 1
 20511501 cntrlvar,106
 20511600 alpha-1d mult 5.599100d-04 1.083570d+00 1
 20511601 cntrlvar,86
 20511700 v/alpha-1d div 1.000000d+00 1.040340d+00 1
 20511701 cntrlvar,116 cntrlvar,115
 20511800 alp/v-1d div 1.000000d+00 9.612210d-01 1
 20511801 cntrlvar,115 cntrlvar,116
 20511900 hvn-1d function 1.000000d+00 9.186530d-01 1
 20511901 cntrlvar,118,41
 20512000 v/a-tu1d tripunit 1.000000d+00 1.000000d+00 1
 20512001 536
 20512100 a/v-tu1d tripunit 1.000000d+00 0.000000d+00 1
 20512101 -536
 20512200 hvn-pu1d mult 1.000000d+00 9.186530d-01 1
 20512201 cntrlvar,119 cntrlvar,120 cntrlvar,114
 20512300 alpsq-1d mult 1.000000d+00 0.000000d+00 1
 20512301 cntrlvar,114 cntrlvar,86 cntrlvar,86 cntrlvar,121
 20512400 spdg1-1d powerr 1.000000d+00 0.000000d+00 1
 20512401 cntrlvar,123,0.5
 20512500 a/vdg-1d function 1.000000d+00 9.612210d-01 1
 20512501 cntrlvar,122,42
 20512600 spdg2-1d mult 1.786000d+03 1.935260d+03 1
 20512601 cntrlvar,125 cntrlvar,115 cntrlvar,120
 * degraded pump speed for pump pu-1d
 20512700 speed-1d sum 1.000000d+00 1.935260d+03 1
 20512701 0.1.,cntrlvar,124 1.,cntrlvar,126
 *==== pu-1c ====
 * saturation pressure for volume 160-03
 20512800 tm160dpc sum 1.000000d+00 5.202620d+01 1
 20512801 -273.15 1.,tempf,160030000
 20512900 tm160dgc sum 1.000000d+00 1.256470d+02 1
 20512901 32.1.8,cntrlvar,128
 20513000 satpr160 function 1.000000d+00 1.994080d+00 1
 20513001 cntrlvar,129,35
 * pump flow pu-1c (cubic feet per second)
 20513100 flow160 div 3.531500d+01 1.233220d+01 1
 20513101 rhojj,170010000 mflowj,170010000
 20513200 cq-pu1c div 2.185000d+00 1.392361d-02 1
 20513201 cntrlvar,94 cntrlvar,131
 20513300 chscr1c function 1.000000d+00 9.237752d-03 1
 20513301 cntrlvar,132,38
 20513400 npsch1c mult 9.104100d-04 3.149810d+01 1
 20513401 cntrlvar,133 cntrlvar,94 cntrlvar,94
 * critical npsch for pu-1c in psi
 20513500 npsic1c mult 4.335280d-04 1.348980d+01 1
 20513501 cntrlvar,134 rhojj,170010000
 * suction pressure to pu-1c in psi
 20513600 suct-1c mult 1.450377d-04 2.632520d+02 1
 20513601 p,160030000
 * actual npsch for pu-1c in psi
 20513700 npsch-1c sum 1.000000d+00 2.624050d+02 1
 20513701 0.1.,cntrlvar,136 -1.,cntrlvar,130 1.,cntrlvar,75
 * ratio of actual npsch to critical npsch
 20513800 npsch1c div 1.000000d+00 1.945210d+01 1
 20513801 cntrlvar,135 cntrlvar,137
 * head degradation factor
 20513900 degra1c function 1.000000d+00 1.000000d+00 1
 20513901 cntrlvar,138,39
 * determine nondimensional homologous variables
 20514000 v-1c mult 8.975290d-02 1.106850d+00 1
 20514001 cntrlvar,131
 20514100 alpha-1c mult 5.599100d-04 1.083570d+00 1
 20514101 cntrlvar,94
 20514200 v/alpha-1c div 1.000000d+00 1.021480d+00 1
 20514201 cntrlvar,141 cntrlvar,140
 20514300 alp/v-1c div 1.000000d+00 9.789700d-01 1
 20514301 cntrlvar,140 cntrlvar,141
 20514400 hvn-1c function 1.000000d+00 9.558860d-01 1
 20514401 cntrlvar,143,41
 20514500 v/a-tu1c tripunit 1.000000d+00 1.000000d+00 1
 20514501 537
 20514600 a/v-tu1c tripunit 1.000000d+00 0.006000d+00 1
 20514601 -537
 20514700 hvn-pu1c mult 1.000000d+00 9.558860d-01 1
 20514701 cntrlvar,144 cntrlvar,145 cntrlvar,139
 20514800 alpsq-1c mult 1.000000d+00 0.000000d+00 1
 20514801 cntrlvar,139 cntrlvar,94 cntrlvar,94 cntrlvar,146
 20514900 spdg1-1c powerr 1.000000d+00 0.000000d+00 1
 20514901 cntrlvar,148,0.5
 20515000 a/vdg-1c function 1.000000d+00 9.789700d-01 1

```

20515001 cntrlvar,147,42
20515100 spdg2-1c mult 1.786000d+03 1.935260d+03 1
20515101 cntrlvar,150 cntrlvar,160 cntrlvar,165
* degraded pump speed for pump pu-1c
20515200 speed-1c sum 1.000000d+00 1.935260d+03 1
20515201 0. 1.,cntrlvar,149 1.,cntrlvar,151
===== pu-1a =====
* saturation pressure for volume 260-03
20515300 tm260dgc sum 1.000000d+00 5.287940d+01 1
20515301 -273.15 1.,tempf,26030000
20515400 tm260dgc sum 1.000000d+00 1.271830d+02 1
20515401 32. 1.8,cntrlvar,153
20515500 satpr260 function 1.000000d+00 2.075530d+00 1
20515501 cntrlvar,154,35
* pump flow pu-1a (cubic feet per second)
20515600 flow260 div 3.531500d+01 1.311490d+01 1
20515601 rho fj,270010000 mflowj,270010000
20515700 eq-pu1a div 2.185000d+00 1.480734d+02 1
20515701 cntrlvar,102 cntrlvar,156
20515800 chacr1a function 1.000000d+00 1.037089d+02 1
20515801 cntrlvar,157,38
20515900 npahr1a mult 9.104100d-04 3.536170d+01 1
20515901 cntrlvar,158 cntrlvar,102 cntrlvar,102
* critical npeh for pu-1a in psi
20516000 npahr1a mult 6.335280d-04 1.513840d+01 1
20516001 cntrlvar,159 rho fj,270010000
* suction pressure to pu-1a in psi
20516100 suct-1a mult 1.450377d-04 2.647380d+02 1
20516101 p,26030000
* actual npeh for pu-1a in psi
20516200 npeh-1a sum 1.000000d+00 2.639590d+02 1
20516201 0. 1.,cntrlvar,161 -1.,cntrlvar,155 1.,cntrlvar,76
* ratio of actual npeh to critical npeh
20516300 npahr1a div 1.000000d+00 1.743640d+01 1
20516301 cntrlvar,160 cntrlvar,162
* head degradation factor
20516400 degra1a function 1.000000d+00 1.000000d+00 1
20516401 cntrlvar,163,39
* determine nondimensional homologous variables
20516500 v-1a mult 8.975290d-02 1.177180d+00
20516501 cntrlvar,156
20516600 alpha-1a mult 5.599100d-04 1.083570d+00 1
20516601 cntrlvar,102
20516700 v/atp-1a div 1.000000d+00 1.086320d+00 1
20516701 cntrlvar,166 cntrlvar,165
20516800 alp/v-1a div 1.000000d+00 9.205430d-01 1
20516801 cntrlvar,165 cntrlvar,166
20516900 hwn-1a function 1.000000d+00 8.333230d-01 1
20516901 cntrlvar,168,41
20517000 v/a-tu1a tripunit 1.000000d+00 1.000000d+00 1
20517001 538
20517100 a/v-tu1a tripunit 1.000000d+00 0.000000d+00 1
20517101 -538
20517200 hwn-pu1a mult 1.000000d+00 8.333230d-01 1
20517201 cntrlvar,169 cntrlvar,170 cntrlvar,164
20517300 alpeq-1a mult 1.000000d+00 0.000000d+00 1
20517301 cntrlvar,164 cntrlvar,102 cntrlvar,102 cntrlvar,171
20517400 spdg1-1a power 1.000000d+00 0.000000d+00 1
20517401 cntrlvar,173,0.5
20517500 a/vdg-1a function 1.000000d+00 9.205430d-01 1
20517501 cntrlvar,172,42
20517600 spdg2-1a mult 1.786000d+03 1.935260d+03 1
20517601 cntrlvar,175 cntrlvar,165 cntrlvar,170
* degraded pump speed for pump pu-1a
20517700 speed-1a sum 1.000000d+00 1.935260d+03 1
20517701 0. 1.,cntrlvar,174 1.,cntrlvar,176
* pu-1d speed after lag
20517800 speed1d lag 1.000000d+00 1.935260d+03 1
20517801 0.050 cntrlvar,127
* pu-1c speed after lag
20517900 speed1c lag 1.000000d+00 1.935260d+03 1
20517901 0.050 cntrlvar,152
* pu-1a speed after lag
20518000 speed1a lag 1.000000d+00 1.935260d+03 1
20518001 0.050 cntrlvar,177
* control mcp speed to reach new steady-state
*
20518100 tr-tu tripunit 1.000000d+00 1.000000d+00 1
20518101 -503
20518200 flerror sum 1.000000d+00 1.176113d-04 0
20518201 0. 1.,cntrlvar,690 -1.,cntrlvar,202
20518300 flerr mult 1.000000d+00 1.176113d-04 0
20518301 cntrlvar,181 cntrlvar,182
20518400 flo-pl prop-int 1.000000d+00 1.935260d+03 0
20518401 0.1 1. cntrlvar 183
20518500 flo-d diffrend 1.000000d-03 1.261082d-06 0
20518501 cntrlvar,183
20518600 flo-pid sum 1.000000d+00 1.935260d+03 1
20518601 0. 1.,cntrlvar,184 1.,cntrlvar,185
20518700 multemp1 mult 1.000000d+00 1.935260d+03 1
20518800 multempd mult 1.000000d+00 0.000000d+00 1
20518801 cntrlvar,178 cntrlvar,77
20518900 acpd-vel sum 1.000000d+00 1.935260d+03 1
20518901 0. 1.,cntrlvar,187 1.,cntrlvar,188
20519000 multempc mult 1.000000d+00 0.000000d+00 1
20519001 cntrlvar,179 cntrlvar,77
20519100 acpc-vel sum 1.000000d+00 1.935260d+03 1
20519101 0. 1.,cntrlvar,187 1.,cntrlvar,190
20519200 multempc mult 1.000000d+00 0.000000d+00 1
20519201 cntrlvar,180 cntrlvar,77
20519300 mcp-vel sum 1.000000d+00 1.935260d+03 1
20519301 0. 1.,cntrlvar,187 1.,cntrlvar,192

```

```

* reactor scram
20520000 rxtime tripdlay 1.000000d+00 -1.000000d+00 1
20520001 648
* flux ratio in fuel
20520100 fluxrat function 1.241310d-08 1.032630d+00 1
20520101 cntrlvar,200,100
* flow (gpm) into the vessel
20520200 flowgpm div 1.585040d+04 1.717000d+04 1
20520201 rhoj,80020000 mflowj,80020000
* flow ratio
20520300 flowrat mult 6.25000d-05 1.0000d+00 1 3 .1u 1.0000d+00
20520301 cntrlvar,202
* flux-to-flow ratio
20520400 ffr div 1.000000d+00 1.032630d+00 1
20520401 cntrlvar,203 cntrlvar,201
* maximum primary coolant temperature exceeded
20520500 maxttr tripunit 1.000000d+00 0.000000d+00 1
20520501 506
* delay for max. primary coolant temperature reactor trip of 2. s
20520600 scdly delay 1.000000d+00 0.000000d+00 1
20520601 cntrlvar 205 2. 100
* scram signal initiated
20520700 scram tripunit 1.000000d+00 0.000000d+00 1
20520701 647
* delay for scram of 0.200 s plus insertion time built in to
* power curve
20520800 scdly delay 1.000000d+00 0.000000d+00 1
20520801 cntrlvar 207 0.200 100
* emergency depressurization control
*
* minimum primary coolant temperature exceeded
20525200 lowtemp tripunit 1.000000d+00 0.000000d+00 1
20525201 603
20525301 -571
20525400 edsair tripunit 1.000000d+00 1.000000d+00 1
20525401 edspos mult 1.000000d+00 0.000000d+00 1
20525401 cntrlvar,252 cntrlvar,253
* delay for temperature sensor response of 2.0 s
* delay for min. primary coolant temperature eds trip of 0.33 s
20525500 scdly delay 1.000000d+00 0.000000d+00 1
20525501 cntrlvar 254 2.33 100
*
* cooling tower bypass control
*
20529000 ct-tripu tripunit 1.000000d+00 0.000000d+00 1
20529001 648
20529100 ct-tdely tripdlay 1.000000d+00 -1.000000d+00 1
20529101 648
20529200 timesinc sum 1.000000d+00 7.079200d+01 1
20529201 0. 1.,time,0 -1.,cntrlvar,291
20529300 ct-arg mult 1.000000d+00 0.000000d+00 1
20529301 cntrlvar,290 cntrlvar,292
20529400 ct-pos function 1.000000d+00 1.000000d+00 1
20529401 cntrlvar,293,37
20529500 ctbp-pos sum 1.000000d+00 0.000000d+00 1
20529501 1. -1.,cntrlvar,294
*
* cooling tower stream control (models fan control)
*
* pid control
20530000 ct-error sum 1.000000d+00 -3.121857d-03 0
20530001 0. 1.,cntrlvar,504 -1.,cntrlvar,672
20530100 ct-mult mult 1.000000d+00 -3.121857d-03 1
20530101 cntrlvar,300 cntrlvar,181
20530200 ct-pi prop-act 1.000000d+00 3.819390d+03 0
20530201 5. 5. cntrlvar,301
20530300 ct-d diffrend 2.250000d+03 2.879040d-01 0
20530301 cntrlvar,301
20530400 ct-d-mult mult 1.000000d+00 2.879040d-01 1
20530401 cntrlvar,303 cntrlvar,181
* add p-i component to d component of control
20530500 ct-pid sum 1.000000d+00 3.819670d+03 0
20530501 0. 1.,cntrlvar,302 1.,cntrlvar,304
*
* reactor vessel check valve flow
*
20531900 dclap sum 1.000000d+00 0.000000d+00 1 1 0.000000d+00
20531901 21.7 -1.450377d-4,p,21050000
20532000 revflo function 1.000000d+00 0.000000d+00 1
20532001 cntrlvar,319,12
20532100 revlag lag 1.000000d+00 0.000000d+00 1
20532101 1.2 cntrlvar,320
*
* structural elasticity mass injection
*
20537200 dphd8 diffrend 1.450377d-04 -5.277308d-05 0
20537201 p 033010000
* dvpd = 1.183e-3 ft**3/psi corresponding to 113 psi/gal
20537300 dhd8 mult -7.385000d-05 3.857020d-06 0
20537301 cntrlvar,372 rho,033010000
* mass injection/ejection adjusted by lag
20537400 elast lag 1.000000d+00 3.570348d-06 0
20537401 1.e-3 cntrlvar,373
* set to 1 if pressure in 60-03 is greater than 20 psia
20537500 elastrip tripunit 1.000000d+00 1.000000d+00 1
20537501 -525
* set final value of mass injection/ejection
20537600 elastcty mult 1.000000d+00 3.570348d-06 1
20537601 cntrlvar,374 cntrlvar,375
*
* cosmetics

```

```

*
* costa flow excursion prediction - outer fuel hot channel
*
20590000 sqrtvelr powerr 1.000000d+00 3.765800d+00 0
20590001 velr 16110000 0.5
20590100 subcoolr sum 1.000000d+00 9.681600d+01 0
20590101 0. 1.,sattemp,16110000 -1.,tempf,16110000
20590200 costaf mult 7.812500d+04 2.848359d+07 0
20590201 cntrlvar,900 cntrlvar,901
20590300 costaf ref div 1.000000d+00 2.184610d-01 0
20590301 cntrlvar,902 htrnr,17200101
*
* costa flow excursion prediction - o-perm be reflector
*
20590400 sqrtvelr powerr 1.000000d+00 2.231740d+00 0
20590401 velr 36050000 0.5
20590500 subcoolr sum 1.000000d+00 1.479600d+02 0
20590501 0. 1.,sattemp,36050000 -1.,tempf,36050000
20590600 costaf mult 5.555556d+04 1.834487d+07 0
20590601 cntrlvar,904 cntrlvar,905
20590700 costaf ref div 1.000000d+00 1.443255d-02 0
20590701 cntrlvar,906 htrnr,36000500
*
* secondary flows (gpm)
*
20590900 flow-ct div 1.585040d+04 1.855280d+04 1
20590901 rhoj,13500000 mflowj,13500000
20591000 flow-by div 1.585040d+04 0.000000d+00 1
20591001 rhoj,13600000 mflowj,13600000
20591100 sec-flow sum 1.000000d+00 1.855280d+04 1
20591101 0. 1.,cntrlvar,909 1.,cntrlvar,910
20591200 flow-hx div 1.585040d+04 1.119830d+04 1
20591201 rhoj,210040000 mflowj,210040000
20591300 fl-ctstr div 1.585040d+04 2.746980d+04 1
20591301 rhoj,402000000 mflowj,402000000
*
* primary flows (gpm)
*
20591500 flow-pzr div 1.585040d+04 1.200010d+02 1
20591501 rhoj,79040000 mflowj,79040000
20591600 flow-rv div 1.585040d+04 0.000000d+00 1
20591601 rhoj,38000000 mflowj,38000000
20591700 flow-br1 div 1.585040d+04 0.000000d+00 1
20591701 rhoj,50200000 mflowj,50200000
20591800 flow-br2 div 1.585040d+04 0.000000d+00 1
20591801 rhoj,504000000 mflowj,504000000
20591900 flow-br3 div 1.585040d+04 0.000000d+00 1
20591901 rhoj,506000000 mflowj,506000000
20592000 flow-br4 div 1.585040d+04 0.000000d+00 1
20592001 rhoj,508000000 mflowj,508000000
20592100 flow-br5 div 1.585040d+04 0.000000d+00 1
20592101 rhoj,510000000 mflowj,510000000
*
20592200 flow-br6 div 1.585040d+04 0.000000d+00 1
20592201 rhoj,512000000 mflowj,512000000
20592300 flow-ela div 1.585040d+04 6.315263d-06 1
20592301 rhoj,42000000 mflowj,42000000
20592400 flow-lee div 1.585040d+04 1.131260d+00 1
20592401 rhoj,84000000 mflowj,84000000
20592500 letdmfl sum 1.000000d+00 7.496600d+00 1
20592501 0. 1.,mflowj,63000000 1.,mflowj,163000000
20592502 1.,mflowj,263000000
20592600 flow-ldn div 1.585040d+04 1.202910d+02 1
20592601 rhoj,630000000 cntrlvar,925
*
* hot spot minimum margin to boiling
*
20593000 ohs-mmb sum 5.555560d-01 1.981160d+01 1
20593001 0. 1.,sattemp,10110000 -1.,httemp,11200105
20593100 ihs-mmb sum 5.555560d-01 2.056600d+01 1
20593101 0. 1.,sattemp,16110000 -1.,httemp,17200105
*
* pd103 - strainer pressure drop
*
20599400 pd103 sum 1.450377d-04 1.422680d+01 1
20599401 13789.5 1.,p,80040000 -1.,p,91020000
*
* static head difference of 4' 8" at 120 deg f
*
20599500 pd106 sum 1.450377d-04 1.528180d+02 1
20599501 8342.66 1.,p,80030000 -1.,p,51010000
*
* heat exchanger heat losses,
* each heat structure has a right-side area of
* 581.787 ft^2 (54.048 m^2)
*
20599600 hxcheat sum 5.404800d+01 2.961288d+07 1
20599601 0. 1.,htrnr,100200101 1.,htrnr,100200201
20599602 1.,htrnr,100200301 1.,htrnr,100200401
20599603 1.,htrnr,100200501 1.,htrnr,101200101
20599604 1.,htrnr,101200201 1.,htrnr,101200301
20599605 1.,htrnr,101200401 1.,htrnr,101200501
20599606 1.,htrnr,102200101 1.,htrnr,102200201
20599607 1.,htrnr,102200301 1.,htrnr,102200401
20599608 1.,htrnr,102200501 1.,htrnr,103200101
20599609 1.,htrnr,103200201 1.,htrnr,103200301
20599610 1.,htrnr,103200401 1.,htrnr,103200501
20599700 hxcheat sum 5.404800d+01 2.932976d+07 1
20599701 0. 1.,htrnr,200200101 1.,htrnr,200200201
20599702 1.,htrnr,200200301 1.,htrnr,200200401
20599703 1.,htrnr,200200501 1.,htrnr,201200101
20599704 1.,htrnr,201200201 1.,htrnr,201200301
20599705 1.,htrnr,201200401 1.,htrnr,201200501

```


20200807	130.0000000	.0401895	20201009	140.0000000	.0458254
20200808	135.0000000	.0429856	20201010	145.0000000	.0482660
20200809	140.0000000	.0455870	20201011	150.0000000	.0505579
20200810	145.0000000	.0480210	20201012	155.0000000	.0527149
20200811	150.0000000	.0503067	20201013	160.0000000	.0547476
20200812	155.0000000	.0524582	20201014	165.0000000	.0566636
20200813	160.0000000	.0544855	20201015	170.0000000	.0584691
20200814	165.0000000	.0563967	20201016	175.0000000	.0601684
20200815	170.0000000	.0581975	20201017	180.0000000	.0617649
20200816	175.0000000	.0598926	20201018	185.0000000	.0632612
20200817	180.0000000	.0614851	20201019	190.0000000	.0646569
20200818	185.0000000	.0629776	20201020	195.0000000	.0659590
20200819	190.0000000	.0643718	20201021	200.0000000	.0671620
20200820	195.0000000	.0656687	20201022	205.0000000	.0695209
20200821	200.0000000	.0668687	20201023	210.0000000	.0717838
20200822	205.0000000	.0692222	*		
20200823	210.0000000	.0714801	* pc head tank: level as a function of %full		
* 20" vertical pipe			*		
20200900 htc-temp			20201100 reac-t		
20200901	100.0000000	.0000000	20201101	.000	.020
20200902	105.0000000	.0615930	20201102	.060	.080
20200903	110.0000000	.0802674	20201103	.120	.140
20200904	115.0000000	.0946594	20201104	.180	.200
20200905	120.0000000	.1069813	20201105	.240	.260
20200906	125.0000000	.1180048	20201106	.300	.320
20200907	130.0000000	.1281059	20201107	.360	.380
20200908	135.0000000	.1374867	20201108	.420	.440
20200909	140.0000000	.1462789	20201109	.480	.500
20200910	145.0000000	.1545693	20201110	.540	.560
20200911	150.0000000	.1624189	20201111	.600	.620
20200912	155.0000000	.1698721	20201112	.660	.680
20200913	160.0000000	.1769619	20201113	.720	.740
20200914	165.0000000	.1837137	20201114	.780	.800
20200915	170.0000000	.1901467	20201115	.840	.860
20200916	175.0000000	.1962760	20201116	.900	.920
20200917	180.0000000	.2021128	20201117	.960	.980
20200918	185.0000000	.2076658	*		
20200919	190.0000000	.2129413	* reactor check valve delta p vs. flow		
20200920	195.0000000	.2179433	*		
20200921	200.0000000	.2226745	20201200 reac-t		
20200922	205.0000000	.2310102	20201201	0.0	0.1
20200923	210.0000000	.2390558	20201202	0.25	0.3
* 16" horizontal			20201203	0.45	0.5
20201000 htc-temp			20201204	0.8	0.9
20201001	100.0000000	.0000273	20201205	2.0	3.0
20201002	105.0000000	.0200361	20201206	6.0	7.0
20201003	110.0000000	.0258365	20201207	10.0	15.0
20201004	115.0000000	.0302656		50.18	62.49
20201005	120.0000000	.0340289	* letdown valve normalized area versus normalized stem position		
20201006	125.0000000	.0373722	*		
20201007	130.0000000	.0404128	20201300 normarea		
20201008	135.0000000	.0432168	20201301	.00000d+00	.16667d-01
					.36344d-02

20201302	.33333d-01	.10228d-01	.50000d-01	.18693d-01	20203522	220.	17.188
20201303	.66667d-01	.28631d-01	.83333d-01	.39802d-01	20203523	230.	20.78
20201304	.10000d-00	.52044d-01	.11667d+00	.65231d-01	20203524	240.	24.97
20201305	.13333d-00	.79263d-01	.15000d+00	.94060d-01	20203525	250.	29.82
20201306	.16667d+00	.10955d+00	.18333d+00	.12568d+00	20203526	260.	35.42
20201307	.20000d+00	.14238d+00	.21667d+00	.15961d+00	20203527	270.	41.85
20201308	.23333d+00	.17733d+00	.25000d+00	.19550d+00	20203528	280.	49.18
20201309	.26667d+00	.21408d+00	.28333d+00	.23303d+00	20203529	290.	57.53
20201310	.30000d+00	.25232d+00	.31667d+00	.27191d+00	20203530	300.	66.98
20201311	.33333d+00	.29179d+00	.35000d+00	.31192d+00	20203531	310.	77.64
20201312	.36667d+00	.33227d+00	.38333d+00	.35281d+00	20203532	320.	89.60
20201313	.40000d+00	.37353d+00	.41667d+00	.39439d+00	20203533	330.	103.00
20201314	.43333d+00	.41537d+00	.45000d+00	.43644d+00	20203534	340.	117.93
20201315	.46667d+00	.45759d+00	.48333d+00	.47878d+00	20203535	350.	134.53
20201316	.50000d+00	.50000d+00	.51667d+00	.52122d+00	20203536	360.	152.92
20201317	.53333d+00	.54241d+00	.55000d+00	.56356d+00	* valve position to cooling tower		
20201318	.56667d+00	.58463d+00	.58333d+00	.60561d+00	* non-dimensional limit for npsH on primary coolant pumps		
20201319	.60000d+00	.62647d+00	.61667d+00	.64719d+00	* primary coolant pump post-cavitation head degradation factor		
20201320	.63333d+00	.66773d+00	.65000d+00	.68808d+00	* main circulation pump homologous curve: hvm		
20201321	.66667d+00	.70821d+00	.68333d+00	.72809d+00	* main circulation pump homologous curve: hvm inverse		
20201322	.70000d+00	.74768d+00	.71667d+00	.76697d+00	* saturation table (pressure as a fcn. of temperature)		
20201323	.73333d+00	.78592d+00	.75000d+00	.80450d+00	* 20203500 reac-t		
20201324	.76667d+00	.82267d+00	.78333d+00	.84039d+00	20203503 40.		
20201325	.80000d+00	.85762d+00	.81667d+00	.87432d+00	20203505 50.		
20201326	.83333d+00	.89045d+00	.85000d+00	.90594d+00	20203506 60.		
20201327	.86667d+00	.92074d+00	.88333d+00	.93477d+00	20203507 70.		
20201328	.90000d+00	.94796d+00	.91667d+00	.96020d+00	20203508 80.		
20201329	.93333d+00	.97137d+00	.95000d+00	.98131d+00	20203509 90.		
20201330	.96667d+00	.98977d+00	.98333d+00	.99637d+00	20203510 100.		
20201331	.10000d+01	.10000d+00			20203511 110.		
					20203512 120.		
					20203513 130.		
					20203514 140.		
					20203515 150.		
					20203516 160.		
					20203517 170.		
					20203518 180.		
					20203519 190.		
					20203520 200.		
					20203521 210.		

20210072	54000.00	.002788	20210142	720.00	.002988
20210073	57600.00	.002706	20210143	840.00	.002859
20210074	61200.00	.002624	20210144	960.00	.002765
20210075	64800.00	.002565	20210145	1080.00	.002694
20210076	68400.00	.002494	20210146	1200.00	.002624
20210077	72000.00	.002435	20210147	1320.00	.002541
20210078	75600.00	.002376	20210148	1440.00	.002471
* power (mw) in target, control plate, and reflector regions			20210149	1560.00	.002412
* power (mw) in target, control plate, and reflector regions			20210150	1680.00	.002353
20210100	power 648 1.0 87.6		20210151	1920.00	.002647
20210101	-2.0 .050271		20210152	2040.00	.002600
20210102	-.5 .050271		20210153	2160.00	.002553
20210103	.00 .050271		20210154	2400.00	.002459
20210104	.01 .050059		20210155	2640.00	.002376
20210105	.05 .038671		20210156	2880.00	.002306
20210106	.10 .019494		20210157	3120.00	.002235
20210107	.15 .014541		20210158	3600.00	.002118
20210108	.20 .013600		20210159	7200.00	.001624
20210109	.25 .013565		20210160	10800.00	.001376
20210110	.30 .013424		20210161	14400.00	.001224
20210111	.35 .013388		20210162	18000.00	.001111
20210112	.40 .013341		20210163	21600.00	.001032
20210113	.45 .013200		20210164	25200.00	.000967
20210114	.50 .013165		20210165	28800.00	.000914
20210115	.55 .013141		20210166	32400.00	.000871
20210116	.60 .012976		20210167	36000.00	.000829
20210117	.65 .012976		20210168	39600.00	.000798
20210118	.70 .012953		20210169	43200.00	.000768
20210119	.75 .012812		20210170	46800.00	.000739
20210120	.80 .012788		20210171	50400.00	.000715
20210121	.85 .012765		20210172	54000.00	.000694
20210122	.90 .012647		20210173	57600.00	.000674
20210123	1.00 .011447		20210174	61200.00	.000653
20210124	3.00 .010082		20210175	64800.00	.000639
20210125	5.00 .009282		20210176	68400.00	.000621
20210126	9.00 .008329		20210177	72000.00	.000607
20210127	20.00 .007082		20210178	75600.00	.000592
20210128	40.00 .006035		* be h(temp)		
20210129	60.00 .005471		*		
20210130	80.00 .005082		20220000 htc-temp		
20210131	100.00 .004800		20220001 100. 0.00562 115. 0.00354 120. 0.0 125. 0.00354		
20210132	120.00 .004576		20220002 140. 0.00562 165. 0.00736 200. 0.00892 240. 0.0102		
20210133	140.00 .004400		20220003 280. 0.0112 320. 0.0121		
20210134	160.00 .004282		*		
20210135	180.00 .004141		* shroud, lower plenum-2 h(temp)		
20210136	200.00 .004047		*		
20210137	220.00 .003976		20230000 htc-temp		
20210138	240.00 .003871		20230001 100. 0.0287 115. 0.0181 120. 0.0 125. 0.0181		
20210139	360.00 .003541		20230002 140. 0.0287 165. 0.0377 200. 0.0457 240. 0.0523		
20210140	480.00 .003294		20230003 280. 0.0575 320. 0.0620		
20210141	600.00 .003141		*		

```

* vessel sidewall(inside) h(time)
*
20240000 htc-t
20240001 0.0 0.028 1.e6 0.028
*
* vessel sidewall(outside) h(temp)
*
20250000 htc-temp
20250001 100. 0.0 105. 0.0139 120. 0.0221 140. 0.0278
20250002 160. 0.0319 180. 0.0351 200. 0.0378 212. 0.0392
*
* vessel lid(inside) h(time)
*
20260000 htc-t
20260001 0.0 0.042 1.e6 0.042
*
* vessel lid(outside) h(temp)
*
20270000 htc-temp
20270001 100. 0.0 105. 0.0209 120. 0.0332 140. 0.0418
20270002 160. 0.0479 180. 0.0527 200. 0.0567 212. 0.0588
*
. end of case

```

Appendix B

MODELING CAVITATION OF THE HFIR PRIMARY COOLANT PUMPS

B.1 SUMMARY

Because the HFIR primary coolant system is typically all liquid, when the pressure boundary is ruptured, the system will depressurize rapidly. For a 5.08-cm-diam (2.0-in.) pipe break, the system will depressurize in about 1 s. Because of this rapid depressurization, the primary coolant pumps, which require about 10 s to completely coast down to pony motor speed, will cavitate as soon as the suction pressure falls below ~ 0.103 MPa (15 psia). As cavitation progresses, eventually the ability of the pump to deliver flow and head will be degraded. RELAP5/MOD2 does not contain a model for pump cavitation.

The objective of this effort was to represent the effects of pump cavitation within the context of the RELAP5 HFIR primary coolant system input model. Using the existing data available for the main circulating pumps, such a scheme was developed. The head degradation associated with pump cavitation was achieved in the model by modulating the pump speed value input to the RELAP5 pump model. The modulated pump speed is less than the noncavitation pump speed, thus producing the required head degradation.

The data used were taken during steady-state operation of the pumps; however, the pumps experience a harsh transient after a LOCA occurs. In particular, it is uncertain how long it takes for the developed pump head to respond to changes in the suction pressure once cavitation has occurred. The pump cannot respond instantaneously because a finite amount of time is required to (1) propagate pressure information through the pump and (2) condense, or "sweep away," bubbles that have formed near the tips of the impeller blades.

Because of this uncertainty, a time lag was applied to the modulated pump speed, and the time constant associated with that lag was varied from 0 (instantaneous response of pump head to suction pressure) to 50 ms. It was found that the flow delivered to the core was nearly the same for all values of the time constant. It is concluded that the use of the steady-state data in the RELAP5 model gives accurate results.

B.2 PUMP CAVITATION MODEL

The RELAP5 pump model consists of two junctions and one thermal-hydraulic control volume having a momentum equation that includes pump head as a body force. The pump model can be controlled by specifying a pump speed (allowed to vary with time) or by specifying torques to be applied to the pump shaft. In the pump-cavitation calculations, the pump speed is always specified directly. RELAP5 does not have a pump cavitation model. Although it does have a method for degrading pump performance, should the pumped fluid be two phase, this cannot be applied for two reasons:

1. To use the two-phase head multipliers, the void fraction in the pump would have to be known. Because pump cavitation occurs before the pressure in any RELAP5 volume reaches its saturation pressure, this void fraction calculation would have to be done outside of RELAP5.

2. Even if void fraction could be accurately and economically calculated, the behavior of a cavitating pump where bubbles are formed near the surface of the impeller is likely to be significantly different than the behavior of a pump that is working on a fluid that entered the pump saturated, even if the void fractions are identical.

Instead, a method similar to that used by C. B. Davis,¹ of INEL, was employed. After cavitation occurs, if the degraded value for pump head is known, the pump speed can be artificially modulated to force the pump head to the degraded value. Because pump cavitation during a LOCA at the HFIR will generally occur after the pump has been tripped and is coasting down to pony motor speed, this method requires that the true pump speed be independently tracked using the control variables.

The available data for onset of cavitation and pump performance after cavitation are shown in Fig. B.1. These data were taken from Byron Jackson (the pump manufacturer) data sheets.² From these constant flow curves, values for $NPSH_{crit}$ (that value of net positive suction head below which the pump performance begins to degrade) can be estimated. In addition, a plot was found in the HFIR files from Byron Jackson that appears to be a design curve of $NPSH_{required}$ for the pumps. $NPSH_{required}$ is the amount of NPSH required before the pump begins cavitating. Both sets of data were nondimensionalized according to White³ using the parameters C_{HS} and C_Q , defined as

$$C_{HS} = \frac{g(NPSH)}{n^2 D^2}$$

Fig. B.1. Manufacturer's data for required suction head for HFIR primary coolant pumps.

and

$$C_Q = \frac{Q}{nD^3},$$

where

- g = acceleration of gravity (32.2 ft/s²),
- $NPSH$ = net positive suction head (ft),
- n = pump speed (rad/s),
- D = diameter of pump impeller data sheets² = 1.635 ft,
- Q = flow rate through pump in ft³/s.

Although White uses pump speed in rpm, here we use rad/s for true nondimensionality. The resulting curves for $(C_{HS})_{crit}$ and $(C_{HS})_{required}$ as a function of C_Q are plotted in Fig. B.2. As expected, $(C_{HS})_{crit}$, which was estimated from the HFIR pump data and represents the onset of pump degradation, lies beneath the curve associated with onset of cavitation.

In the RELAP5 model, $(C_{HS})_{crit}$ as shown in Fig. B.2 was used to indicate the point at which pump performance begins to degrade. If the suction head falls low enough that C_{HS} is less than $(C_{HS})_{crit}$ then the pump head is degraded.

Fig. B.2. Nondimensionalized data for required suction head as function of pump flow.

The HFIR pump data shown in Fig. B.1 are also used to determine how the pump behaves after the head begins to degrade. The data in Fig. B.3 show the Fig. B.1 data with the pump head normalized to the predegradation value and the $NPSH$ normalized to the $NPSH_{crit}$ value. From this figure a relationship (FIT) was extracted for use in the model that dictated how the pump head degrades after C_{HS} becomes less than $(C_{HS})_{crit}$.

Figure B.4 shows a flow chart that indicates how the pump speed is controlled. Because the pump data are for steady state, a time lag has been applied to the pump speed. During a transient, the pump head will not respond instantaneously to changes in the pump suction pressure because of pressure wave transit time and because of time required to sweep bubbles away from the pump impeller. However, no transient data are available for pump performance during pump cavitation. It was hoped that the time lag would not significantly affect the flow delivered to the core, which is the important result.

B.3. CALCULATION RESULTS

Results were obtained for a 5.08-cm (2-in.) break at the outlet of one of the main circulating pumps. In Fig. B.5, the flow delivered to the core is plotted for various time lags applied to the modulated pump speed. In Figs. B.6 and B.7, the mass flow through one of the pumps is shown for the same simulations. The IBM/RS6000 computational time to simulate the first 11 s of the transient is shown for each simulation in Table B.1.

Fig. B.3. Normalized degraded pump head vs available suction head.

Actual Pump Speed Calculation **Modulated Pump Speed Calculation**

Fig. B.4. Control of HFIR primary coolant pump speed.

For longer time lags, fewer oscillations were calculated, and the calculation went smoother, requiring less CPU time.

The values for C_{HS} for the simulation with a 50-ms time lag are plotted in Fig. B.8.

B.4. DAMAGE TO THE PUMP

The main circulating pumps will cavitate for some of the LOCA transients that will be analyzed with the RELAP5 HFIR model. A model that is adequate for predicting pump

Fig. B.5. Flow delivered to reactor vessel during 2-in. break.

performance has been described in this appendix. The results should be realistic as long as the pump is not damaged enough to significantly affect pump performance. Two types of damage occur in pumps experiencing cavitation:

1. cavitation erosion at the impeller due to the implosion of collapsing voids on the impeller blades, and
2. metal-to-metal contact in the pump shaft journal bearing brought on by vibration and leading to pump lock-up (welding of the shaft to the bearing surface).

B.4.1 Time of Exposure

Pump cavitation will occur during a LOCA after the main circulating pumps have been tripped. The only power supplied to the pump shaft in such a scenario is from the pony motor. The pump shaft speed will decrease rapidly because of the resistance of the shaft friction torque and the hydraulic torque. The hydraulic torque during a period of cavitation is substantially less than what it is for fully liquid flow. If the hydraulic torque is completely neglected, then the rate of coastdown can be calculated as

$$\frac{d(\alpha)}{dt} = \frac{T_m - T_f}{I},$$

Fig. B.6. Mass flow through PU-1D during 2-in. break.

where I is the moment of inertia for the pump (19.7 kg/m^2 or $468 \text{ lb}_m\text{-ft}^2$), α is the pump speed ratio, T_f is the torque due to shaft friction (see Sect. 3.3.3), and T_m is the pony motor torque (Table 42). The above equation was solved numerically, and it was found that to coast down from full speed to pony motor speed (36.7 rad/s , or 350 rpm for no hydraulic torque) required 40 s . It is here demonstrated that once the pumps coast down to 36.7 rad/s (350 rpm), they are no longer cavitating.

As the pumps coast down, the developed head and flow rates also decrease. At design conditions (188 rad/s or 1800 rpm), the pumps each supply $0.315 \text{ m}^3/\text{s}$ (5000 gal/min) against a system head loss of 1.08 MPa (157 psi). At pony motor speed (28.3 rad/s or 270 rpm) the pumps each supply $0.0526 \text{ m}^3/\text{s}$ (833 gal/min) against a system head loss of about 0.0276 MPa (4 psi). Assuming that the system head loss varies with the square of the flow rate, a system loss coefficient can be calculated as

$$K_s = \frac{\Delta P}{Q^2}.$$

Because most of the pressure drop occurs across the reactor vessel, Q is the combined flow rate of the three pumps. At design conditions, $K_s = 1.21 \text{ MPa}/(\text{m}^3/\text{s})^2$ [7.0×10^{-7}

Fig. B.7. Closeup of mass flow through PU-1D during 2-in. break.

Table B.1. CPU times required for 5.08-cm (2-in.) break simulations

Time lag (ms)	CPU time (s)
0	13,217
2	7,013
5	3,552
50	2,100

psi/(gal/min)²], and at pony motor speed $K_p = 1.11 \text{ MPa}/(\text{m}^3/\text{s})^2$ [$6.4 \times 10^{-7} \text{ psi}/(\text{gal}/\text{min})^2$]. At 36.7 rad/s (350 rpm) the speed ratio is 0.194, so the maximum total developed pump is about 0.0414 MPa (6 psi). Using an average value of K_p , the above relation gives a flow rate of 0.0631 m³/s (1000 gal/min) per pump. At 36.7 rad/s (350 rpm) and 0.0631 m³/s (1000 gal/min), C_Q is 0.014 (see Sect. B.2). From Fig. B.2 the required C_{HS} is about 0.02, and using the definition of C_{HS} (Sect. B.2), the required NPSH for each pump is 0.00689 MPa (1 psi). If

Fig. B.8. Nondimensional suction head vs nondimensional flow rate during 2-in. break.

the break is at the outlet of the main circulating pumps (worst case) to the atmosphere, the suction pressure would be at least 0.0552 MPa (8 psia). Because the saturation pressure at 48.9°C (120°F) is <0.0138 MPa (2 psia), the available suction head at 37.6 rad/s (350 rpm) is at least 0.0414 MPa (6 psi), plenty to ensure that the pumps will recover from their cavitated state before they completely coast down.

Because the pumps will recover from their cavitated state by the time they slow to 37.6 rad/s (350 rpm), the time during which cavitation damage may occur will be no longer than 40 s, but probably much less. Results from preliminary calculations simulating a 5.08-cm (2-in.) break at the main circulating pump discharge, as shown in Figs. B.6–B.8, indicate cavitation lasts only 3 s.

B.4.2 Cavitation Erosion

Data for the erosion of metals are given in Refs. 4–7. In all of these references, the data indicate that to significantly erode a steel surface, hours of exposure to bubble collapse are required. Although these data are not directly applicable to the case of cavitation in large centrifugal pumps, there is practically no such information available.⁸ However, the large amount of erosion data that do exist and the wide margin between those exposure times

indicated by the data to cause significant mass loss and the exposure time typical for the HFIR main circulation pumps during a LOCA give a good basis for asserting that no significant erosion of the impeller will occur during a HFIR LOCA.

B.4.3 Bearing Damage

The more likely mechanism for cavitation-induced damage to the main circulating pumps is metal-to-metal contact in the water-lubricated shaft journal bearings. However, journal bearings are rugged in practice,⁹ and additional friction on the bearing would work to slow the pump down. Little information is available on failures of journal bearings because of their reliability. In the past, the HFIR primary coolant pumps have twice survived cavitation at full speed.

B.4.4 Recommendation

The only practical scenario where pump cavitation damage may lead to fuel damage is if all three pumps suddenly locked up, so that no flow could reach the core, because a single pony-motor-operated pump is enough to remove the core decay heat.

LOCA analysis using the input model will not include the effects of any cavitation damage that may occur. If the break is large enough to damage the fuel (cavitation damage not considered), based on preliminary calculations, it is expected that the fuel will be damaged before the pumps cavitate at all. However, for those breaks that are small enough that the reactor survives the initial depressurization, damage to the journal bearing may be a factor and will certainly lead to fuel damage should all three main circulating pump shafts lock up.

Because the pumps would be coasting down and in the past have survived cavitation at full speed, it is highly unlikely that all three would lock up during cavitation.

B.5. CONCLUSIONS

Because the flow delivered to the core was essentially the same for the range of time lags from 0 to 50 ms, the use of the steady-state data should be legitimate. The pump cavitation model as implemented in RELAP5 should provide realistic results, and the pump should not be significantly damaged during the transient.

B.6 REFERENCES

1. C. B. Davis, *Pump Cavitation in L-Reactor During a LOCA Initiated by a Large Break in a Plenum Inlet Line*, EGG-EAST-8148, Idaho National Engineering Laboratory, June 1988.
2. *Report of Test From the Byron Jackson Hydraulic Test Facilities*, Byron Jackson Order No. 371720, January 1963.
3. F. M. White, *Fluid Mechanics*, McGraw-Hill, New York, 1979, pp. 646–648.
4. M. A. Rayan, "Experimental Study of the Cavitation Erosion in Centrifugal Pump Impeller," Cavitation and Multiphase Flow Forum, *The Joint ASCE/ASME Mechanics Conference, Albuquerque, New Mexico, June 24–26, 1985*.

5. R. T. Knapp, J. W. Daily, and F. G. Hammitt, *Cavitation*, McGraw-Hill, New York, 1970, pp. 367, 410, 529, 530.
6. A. Thiruvengadam, "A Unified Theory of Cavitation Damage," *J. Basic Engineering* (September 1963).
7. M. S. Plesset and R. E. Devine, "Effect of Exposure Time on Cavitation Damage," *J. Basic Engineering* (December 1966).
8. Ref. 4, p. 515.
9. D. M. Smith, *Journal Bearings in Turbomachinery*, Chapman and Hall, London, 1969, pp. 135-139.

Appendix C

PREPROCESSING PROGRAM

The preprocessing program, which is useful for either (1) initializing a RELAP5/MOD2 or RELAP5/MOD3 input dataset at steady-state conditions or at uniform temperature and pressure, or (2) converting from a RELAP5/MOD2 dataset to a RELAP5/MOD3 dataset, is listed on the following pages. If the program is used for initializing a dataset at steady-state conditions, two files are read: a RELAP5 input file with all records correct except for initial conditions, and a file containing one major edit from the RELAP5 (MOD2 or MOD3) program.

The preprocessor will read the dependent variables (temperatures, pressures, flows, and control variables) from the file containing the major edit; it will read the model description from the RELAP5 input file; and finally, it will create a new input file containing the combined information that it has read.

RELAP5 Initialization Program

```

c
c This program reads a RELAP5/MOD2.5 generated MAJOR EDIT,
c and initializes an input file to contain the initial
c conditions read from the MAJOR EDIT.
c Also, a conversion to a MOD3 data set may be made.
c
c Written by M. W. Wendel (615-574-2825)
c
c MOD2.5 only!!!
c
      common /rinput/ strtmp,struct,p,t,flow,cntrl,d1,d2,pmpvel,acclev
      common /iinput/ istr,i1,j1
      common /ainput/ fin,fout
      character*5 format
      character*20 fin, fout, findat
      character*10 blank
      character*10 aread, a1, cmp10
      character*8 cmp,type
      character*80 arec,arecc,line
      character*132 arec1
      character*3 cnum
      character*5 zeros, chsnum
      logical long
      real ic
c
c ccccccccccccccccccccccccccccccccccccccccccccccccccccccccccccc
c Definition of arrays:
c
c   Pressures in 'p'
c   Temperatures in 't'
c   Mass flow rates in 'flow'
c   Control variables in 'cntrl'
c   Heat structures: temperatures in 'struct'; istr(i,j)
c       contains the address in struct where the temperatures
c       can be found for the ith heat structure and the jth
c       mesh point location
c ccccccccccccccccccccccccccccccccccccccccccccccccccccccccccccc
c
      dimension p(1000,20),t(1000,20),flow(1000,20),cntrl(1000),
&          strtmp(20),struct(10000),istr(10000,20)
      dimension d1(10),d2(10),i1(10),a1(10),j1(10)
      dimension pmpvel(1000),acclev(1000)
c
      data format /'(a )'/
      data zeros/'0000 '/, im /0/
      data z /0./, iunif /2/, pinit/475./, tinit /90./
      data ithree/3/, blank /'          '/
c
c Interact with user.
c
      write(*,('( Do you wish to input (1) Uniform initial conditions''
&,$)')
      write(*,('( or (2) Previous output, no convers
&ion'', $)')
      write(*,('( or (3) Previous output, convert fr
&om'', $)')
      write(*,('( MOD2.5 to MOD3:      '',$)')
      read(*, '(i1)') iflag

```

```

c      if(iflag.ne.1)then
c        write(*,(' Previous relap results file:    ','$'))
c        read(*,'(a)') fin
c      else
c        write(*,(' Initial pressure to be used:    ','$'))
c        read(*,'(e12.4)') pinit
c        write(*,(' Initial temperature to be used: ','$'))
c        read(*,'(e12.4)') tinit
c      endif
c      write(*,(' Input data file:                    ','$'))
c      read(*,'(a)') findat
c      write(*,(' Output data file:                    ','$'))
c      read(*,'(a)') fout
c
c      Open indicated files
c
c      open(unit=22,file=fout,status='unknown')
c      open(unit=21,file=findat,status='old')
c
c      ncvs = 0
c      if(iflag.eq.1)go to 305
c
c      Read mod2-formatted MAJOR EDIT for initial conditions
c
c      call mod25in(ncvs,nhs)
c
c      Initialize everything at uniform conditions
c
c      305 if(iflag.eq.1) then
c        do 315 i=1,1000
c          struct(i) = tinit
c          do 315 j=1,20
c            p(i,j) = pinit
c            t(i,j) = tinit
c          315 flow(i,j) = z
c        endif
c
c      Search for components in RELAP5 input file
c
c      1000 read(21,997,end=9000)arec
c      1001 if(arec(4:8).eq.zeros) then
c        write(22,997)arec
c        do 10 i=1,50
c          cmp = arec(10+i:17+i)
c          cnum = arec(1:3)
c          read(arec(1:3),970)num
c
c      c      PIPEs
c
c      if(cmp.eq.'pipe    ') then
c        ndhs = 0
c      310 read(21,997,end=9000)arec
c        if(arec(1:1).eq.'*' .or. arec(1:1).eq.' ') go to 310
c        do 311 l=1,20
c          if(arec(l+8:l+8).ne.' ') then
c            ist = l+8
c            go to 312
c          endif
c        311 continue
c      312 if(arec(ist+1:ist+1).eq.' ' .or.
c        2   arec(ist+1:ist+1).eq.',')then
c        read(arec(ist:ist),996)ni
c      else
c        read(arec(ist:ist+1),976)ni
c      endif
c      write(22,997)arec

```

```

11  continue
    read(21,997,end=9000)arec
    if(arec(1:1).eq.' ')go to 11
    if(arec(1:3).ne.cnum.and.arec(1:1).ne.'*') go to 1001
    icrd = 0
    if(arec(1:1).ne.'*')read(arec(4:7),985) icrd
    if(icrd.ge.801.and.icrd.le.899) then
c
c Read volume hydraulic diameters
c
        iptr = 8
        do 211 i211=1,10
            d1(i211+ndhs) = dread(iptr,arec)
            d2(i211+ndhs) = dread(iptr,arec)
            i1(i211+ndhs) = iread(iptr,arec)
            if(i1(i211+ndhs).eq.0) then
                ndhs = i211-1+ndhs
                write(22,997)arec
                go to 11
            endif
211  continue
        else if(icrd.eq.1201) then
c
c Write volume initial conditions
c
            do 111 k=1,ni
                if (k .lt. 10) then
                    write (line,972)arec(1:6),k,ithree,p(num,k),
&                        t(num,k),z,z,z,k
                else
                    write(line,982)arec(1:5),k,ithree,p(num,k),
&                        t(num,k),z,z,z,k
                endif
                call caselc (line)
                write(22,997)line
111  continue
            else if (icrd.eq.1301) then
c
c Write junction initial conditions
c
                write(22,973)arec(1:4),'1300 1'
                write(line,974)arec(1:3),'1301',flow(num,1),z,z,1
                call caselc( line )
                write(22,997)line
                if(ni.gt.1) then
                    do 112,k=2,ni-1
                        if(k.lt.10) then
                            write(line,975)arec(1:3),'130',k,flow(num,k),z,z,k
                        else
                            write(line,981)arec(1:3),'13',k,flow(num,k),z,z,k
                        endif
                        call caselc( line )
                        write(22,997)line
112  continue
                    endif
                else if (icrd.gt.1200.and.icrd.lt.1400) then
                    continue
                else
                    write(22,997)arec
                    endif
                go to 11

```

```

c
c BRANCH's
c
    else if(cmp.eq.'branch ') then
        cnum = arec(1:3)
        read(arec(1:3),970)num
12    read(21,997,end=9000)arec
        if(arec(1:1).eq.' ')go to 12
        if(arec(1:3).ne.cnum.and.arec(1:1).ne.'*') go to 1001
        if(arec(4:7).eq.'0200') then
            write(line,993)arec(1:7),ithree,p(num,1),t(num,1)
        else if(arec(5:7).eq.'201') then
            read(arec(4:4),996)k
            write(line,992)arec(1:8),flow(num,k),z,z
        else if(arec(5:7).eq.'001') then
            iptr = 8
            nj = iread(iptr,arec)
            write(line,991)arec(1:8),nj,'1'
        else
            write(line,997)arec
        endif
        call caselc( line )
        write(22,997)line
        go to 12

c
c SINGLE VOLUMES
c
    else if(cmp.eq.'snglvol ') then
        cnum = arec(1:3)
        read(arec(1:3),970)num
13    continue
        read(21,997,end=9000)arec
        if(arec(1:1).eq.' ')go to 13
        if(arec(1:3).ne.cnum.and.arec(1:1).ne.'*') go to 1001
        if(arec(4:7).eq.'0200') then
            write(line,993)arec(1:7),ithree,p(num,1),t(num,1)
            call caselc( line )
            write(22,997)line
        else
            write(22,997)arec
        endif
        go to 13

c
c ACCUMULATORS
c
    else if(cmp.eq.'accum ') then
        cnum = arec(1:3)
        read(arec(1:3),970)num
22    continue
        read(21,997,end=9000)arec
        if(arec(1:1).eq.' ')go to 22
        if(arec(1:3).ne.cnum.and.arec(1:1).ne.'*') go to 1001
        if(arec(4:7).eq.'0200') then
            write(line,980)arec(1:7),p(num,1),t(num,1)
            call caselc( line )
            write(22,997)line
        else if(arec(4:7).eq.'2200') then
            iptr = 8
            w1 = dread(iptr,arec)
            w2 = dread(iptr,arec)
            ip1 = iptr
            w3 = dread(iptr,arec)
            elev = dread(iptr,arec)
            tnkelv = acclev(num)-elev
            write(line,971)arec(1:7),z,tnkelv,arec(ip1:72)
            call caselc( line )
            write(22,997)line
        else
            write(22,997)arec
        endif
        go to 22

```

```

c
c SINGLE JUNCTIONS AND VALVES
c
      else if(cmp.eq.'sngljun '.or(cmp.eq.'valve  ') then
        cnum = arec(1:3)
        read(arec(1:3),970)num
23      continue
        read(21,997,end=9000)arec
        if(arec(1:1).eq.' ')go to 23
        if(arec(1:3).ne.cnum.and.arec(1:1).ne.'*') go to 1001
        if(arec(4:7).eq.'0201') then
          write(line,984)arec(1:7),'1',flow(num,1),z,z
          call caselc( line )
          write(22,997)line
        else
          write(22,997)arec
        endif
        go to 23

c
c PUMPS
c
      else if(cmp.eq.'pump  ') then
        cnum = arec(1:3)
        read(arec(1:3),970)num
15      read(21,997,end=9000)arec
        if(arec(1:1).eq.' ')go to 15
        if(arec(1:3).ne.cnum.and.arec(1:1).ne.'*') go to 1001

c
c Pump volume pressure and temperature
c
      if(arec(4:7).eq.'0200') then
        write(line,993)arec(1:7),ithree,p(num,1),t(num,1)
        call caselc( line )
        write(22,997)line

c
c Inlet junction initial flows
c
      else if (arec(4:7).eq.'0201') then
        write(line,984)arec(1:7),'1',flow(num,1),z,z
        call caselc( line )
        write(22,997)line

c
c Outlet junction initial flows
c
      else if (arec(4:7).eq.'0202') then
        write(line,984)arec(1:7),'1',flow(num,2),z,z
        call caselc( line )
        write(22,997)line

c
c Initial pump velocity
c
      else if (arec(4:7).eq.'0302') then
        iptr = 8
        w1 = dread(iptr,arec)
        w2 = dread(iptr,arec)
        rat = pmpvel(num)/w1

c
c Find the last non-blank character
c
      do 9 ichr=iptr,80
        if(arec(ichr:ichr).eq.' '.and.arec(ichr-1:ichr-1)
&         .ne.' ') nonbla=ichr
9      continue
      nchrs = nonbla-iptr+1
      if(nchrs.ge.10)write(format(3:4),'(i2)')nchrs
      if(nchrs.lt.10)write(format(3:3),'(i1)')nchrs
      write(arecc,'(8a10)')blank,blank,blank,blank,blank,blank,
&         blank,blank

```

```

        write(arecc(1:21),'(a8,f5.0,1x,f7.5)') arec(1:8),w1,rate
        write(arecc(22:22+nchrs-1),format)arec(iptr:nonbla)
        write(22,997)arecc
        format(3:4) = ' '
    else
        write(22,997)arec
    endif
    go to 15
endif
10 continue
c
c HEAT STRUCTURES
c
    else if(arec(1:1).eq.'1'.and.arec(6:8).eq.'000')then
c
c Store character heat structure number
c
        chsnum = arec(1:5)
        read(arec(2:5),985)num
c
c Search for nh, np, and ng
c Override the steady-state initialization flag
c
        ifound = 0
        nh = 0
        np = 0
        iss = 0
        j = 9
16    j=j+1
        if(arec(j:j).ne.' ') then
            if(arec(j+1:j+1).ne.' ') then
                if(arec(j+2:j+2).ne.' ') then
                    write(*,9999) arec
9999    format(' **** error ***** on following card'/a80)
                    stop
                endif
                read(arec(j:j+1),976)n1
                ifound = ifound+1
                j=j+2
            else
                read(arec(j:j),977)n1
                ifound = ifound+1
                j=j+1
            endif
        else
            go to 16
        endif
        if(j.gt.70) go to 114
        if(ifound.eq.1) nh = n1
        if(ifound.eq.2) np = n1
        if(ifound.eq.3) ng = n1
        if(ifound.eq.4) issold = n1
        if(ifound.eq.4) go to 114
        go to 16
c
c Write card 1 for the heat structure description
c
114    write(22,978)arec(1:9),nh,np,ng,iss,arec(j+1:72)
c
c Write heat structure initial temperature flag and temperatures
c
        write(22,988)arec(1:5),'400','-1'
        nmax = min(np,8)
        do 116 k=1,nh
            loc=istr(num,k)
            if(iflag.eq.1)loc=1
            if(k.gt.9) then
                write(line,990)arec(1:5),'4',k,(struct(loc-1+nn),
&                nn=1,nmax)

```

```

        else
            write(line,986)arec(1:5),'40',k,(struct(loc-1+nn),
&                nn=1,nmax)
        endif
        call caselc( line )
        write(22,997)line
        if(nmax.lt.np) then
            write(line,983)(struct(loc-1+nn),nn=nmax+1,np)
            call caselc( line )
            write(22,997)line
        endif
116 continue
14  read(21,997,end=9000)arec
    if(arec(1:1).eq.'+'.or.arec(1:1).eq.' ')go to 14
    if(arec(1:1).eq.'*')then
        write(22,997)arec
        go to 14
    endif
    read(arec(6:8),970)ntype
    if(ntype.gt.399.and.ntype.lt.500) then
        continue
    else if(ntype.gt.800.and.ntype.le.999) then
        if(iflag.eq.3) then
            write(22,969) arec(1:9),nh
        else if(iflag.eq.4) then
            write(22,968) arec(1:9),nh
        else
            write(22,997)arec
        endif
        else if(chsnum.ne.arec(1:5))then
            go to 1001
        else if(arec(1:1).eq.'1'.and.arec(6:6).eq.'4'.and.arec(8:8)
&            .ne.' ')then
            go to 14
        else
            write(22,997)arec
        endif
        go to 14
c
    else if(arec(1:3).eq.'205'.and.arec(7:9).eq.'00 ')then
        read(arec(4:6),'(i3)')icntrl
c
c CONTROL VARIABLES
c
        iptr = 9
        cmp10 = aread(iptr,arec,lngth)
        if(lngth.gt.8) then
            write(6,9991)arec
9991 format(' ERROR: The following card has too many characters
& for the CV name:'/a80/)
        endif
        long = .false.
        type = aread(iptr,arec,lngth)
        if(iptr.ge.24) long = .true.
        if(type.eq.'constant')then
            write(22,997)arec
            go to 1000
        endif
        sf = dread(iptr,arec)
        ic = dread(iptr,arec)
        iic = iread(iptr,arec)
        imm = iread(iptr,arec)
        if(imm.ne.0) then
            if(imm.eq.1.or.imm.eq.3) then
                xmin = dread(iptr,arec)
            endif
            if(imm.eq.2.or.imm.eq.3) then
                xmax = dread(iptr,arec)
            endif
        endif
    endif

```



```

c
c write control variable cards
c
      if(imm.eq.1) then
        write(line,994)arec(1:9),cmp10(1:8),type,sf,cntrl(icntrl),
&      iic,imm,xmin
      else if(imm.eq.2) then
        write(line,994)arec(1:9),cmp10(1:8),type,sf,cntrl(icntrl),
&      iic,imm,xmax
      else if(imm.eq.3) then
        if(sf.eq.1.) then
          write(line,2995)arec(1:9),cmp10(1:8),type,sf,cntrl(icntrl),
&      iic,imm,xmin,xmax
        else if(.not.long) then
          write(line,1995)arec(1:9),cmp10(1:8),type(1:5),sf,
&      cntrl(icntrl),iic,imm,xmin,xmax
        else
          write(line,995)arec(1:9),cmp10(1:8),type,sf,cntrl(icntrl),
&      iic,imm,xmin,xmax
        endif
      else
        write(line,989)arec(1:9),cmp10(1:8),type,sf,cntrl(icntrl),iic
      endif
      call caselc( line )
      write(22,997)line
      go to 1000
    else
      write(22,997)arec
    endif
    go to 1000
9000 continue
    ico = 0
    do 9010 i=1,1000
      do 9010 j=1,20
        if(p(i,j).eq.0)go to 9010
        ico = ico+1
9010 continue
      write(6,999)ico,nhs,ncvs
      close (21)
      close (22)
      close (23)
      stop
c
c Formats
c
2995 format(a9,a8,1x,a8,1x,f2.0,1x,1p,d12.5,1x,i1,1x,i1,1x,d12.5,
&1x,d12.5)
1995 format(a9,a8,1x,a5,1x,1p,d12.5,1x,d11.4,1x,i1,1x,i1,1x,
&0p,f7.2,1x,1p,d11.4)
999 format(' number of volumes =',i5/
&' number of heat structures =',i5/
&' number of control variables =',i5)
998 format(a132)
997 format(a80)
996 format(i1)
995 format(a9,a6,1x,a8,1x,1p,d11.4,1x,d11.4,1x,i1,1x,i1,1x,
&0p,f7.2,1x,1p,d11.4)
994 format(a9,a8,1x,a8,1x,1p,d13.6,1x,d13.6,1x,i1,1x,i1,1x,d13.6)
993 format(a7,1x,i1,1x,e11.5,1x,f8.3)
992 format(a7,1x,1p,e12.4,2(1x,f2.0))
991 format(a8,1x,i2,1x,a1)
990 format(a5,a2,i2,8(1x,f7.2))
989 format(a9,a8,1x,a8,1x,1p,d13.6,1x,d13.6,1x,i1)
988 format(a5,a3,1x,a2)
987 format(i1,1x,i1)
986 format(a5,a2,i1,8(1x,f7.2))
985 format(i4)
984 format(a7,1x,a1,1x,1p,e12.4,2(1x,f2.0))

```

```

983 format('+',6(f7.2,1x))
982 format(a5,i2,1x,i2,1x,e11.5,1x,f7.2,3(1x,f2.0),1x,i2)
981 format(a3,a2,i2,1x,1p,e12.4,2(1x,f2.0),1x,i2)
980 format(a7,1x,1x,e11.5,1x,f8.3)
979 format(1x,d13.7,1x)
978 format(a9,1x,4(i2,1x),a50)
977 format(i1)
976 format(i2)
975 format(a3,a3,i1,1x,1p,e12.4,2(1x,f2.0),1x,i2)
974 format(a3,a4,1x,1p,e12.4,2(1x,f2.0),1x,i2)
973 format(a3,a6)
972 format(a6,i1,1x,i2,1x,e11.5,1x,f7.2,3(1x,f2.0),1x,i2)
971 format(a7,1x,f2.0,1x,f7.4,a54)
970 format(i3)
969 format(a9,' 0. 10. 10. 0. 0. 0. 1.',1x,i2)
968 format(a9,' 0 0. 0. 0.',1x,i2)
967 format(a6,i1,1x,'1',a6,1x,i2)
966 format(a8,1x,a9)
965 format(a3,'140',i1,1x,d12.5,' 0. 1. 1. ',i3)
end

c
c Function to read integer data
c
      function iread(iptr,arec)
c
c Finds the first integer on the record after the iptr character
c
      character*80 arec
      character*4 format
      data format /'(' )'/
      do 10 i=iptr+1,80
        if(arec(i:i).ne.' ') then
          if(arec(i:i).eq.'**') then
            iread = 0
            return
          endif
          i1 = i
          go to 15
        endif
      10 continue
      iread = 0
      return
      15 do 20 i=i1+1,80
        if(arec(i:i).eq.' ') then
          length = i-i1
          iptr = i
          go to 25
        endif
      20 continue
      25 continue
      write(format(2:3),'(a1,i1)') 'i',length
      read(arec(i1:i1+length-1),format)iread
      return
      end

c
c Function to read a real number
c
      function dread(iptr,arec)
c
c Finds the first real number on the record after the iptr character
c
      character*80 arec
      character*7 format
      data format /'(' )'/
      do 10 i=iptr+1,80
        if(arec(i:i).ne.' ') then
          i1 = i
          go to 15
        endif

```

```

10 continue
   dread = 0.d0
   return
15 do 20 i=i1+1,80
   if(arec(i:i).eq.' ') then
      length = i-i1
      iptr = i
      go to 25
   endif
20 continue
25 write(format(2:6),'(a1,i2,a2)') 'g',length,'.0'
   read(arec(i1:i1+length-1),format)dread
   return
end

c
c Function to read alphanumeric data
c
c      function aread(iptr,arec,length)
c
c Finds the first alphanumeric on the record after the iptr character
c
c      character*10 aread
c      character*80 arec
c      character*5 format
c      format = '( )'
c      do 10 i=iptr+1,80
c         if(arec(i:i).ne.' ') then
c            i1 = i
c            go to 15
c         endif
10 continue
   return
15 do 20 i=i1+1,80
   if(arec(i:i).eq.' ') then
      length = i-i1
      iptr = i
      go to 25
   endif
20 continue
25 continue
   if(length.lt.10) then
      write(format(3:4),'(a1,i1)') 'a',length
   else
      write(format(2:4),'(a1,i2)') 'a',length
   endif
   read(arec(i1:i1+length-1),format)aread
   return
end

c
c Subroutine to read RELAP5/MOD2.5 input from file indicated by user
c
c      subroutine mod25in(ncvs,nhs)
c      common /rinput/ strtmp,struct,p,t,flow,cntrl,d1,d2,pmpvel,acclev
c      common /iinput/ istr,i1,j1
c      common /ainput/ fin,fout
c      character*10 fin, fout, findat, blank
c      character*10 a1
c      character*132 arec
c      character*8 cmp
c
c      dimension p(1000,20),t(1000,20),flow(1000,20),cntrl(1000)
c      dimension pmpvel(1000),acclev(1000)
c      dimension strtmp(20),struct(10000),istr(10000,20)
c      dimension d1(10),d2(10),i1(10),a1(10),j1(10)
c

```

```

c Open file containing the MAJOR EDIT
c
  open(unit=23,file=fin,status='unknown')
  ii = 1
  pmpv = 0.
10 read(23,997,end=200)arec
  call caselc(arec)
c
c Read pressures and temperatures
c
  if(arec(8:13).eq.'0000 ') then
    read(arec(1:71),999) i,j,p(i,j),t(i,j)
    if(pmpv.gt.0.d0)pmpvel(i)=pmpv
    if(accl.gt.0.d0)acclev(i)=accl
    pmpv = 0.
    accl = 0.
    if(i.eq.33) then
      t(i,j) = 120.
      write*,'('' volume 33 is set to 120 f'',$)'')
    endif
    if(i.eq.35) then
      t(i,j) = 120.
      write*,'('' volume 35 is set to 120 f'',$)'')
    endif
    else if(arec(4:6).eq.'rpm')then
      read(arec(9:17),'(f9.0)')pmpv
    else if(arec(2:12).eq.'liq. volume')then
      read(arec(74:82),'(f9.0)')accl
    else if(arec(14:19).eq.'solute') then
      go to 20
    endif
    go to 10
20 read(23,997,end=200)arec
  call caselc(arec)
  if(arec(2:8).eq.'system ')go to 30
  go to 20
c
c Read mass flows
c
30 read(23,997,end=200)arec
  call caselc(arec)
  if(arec(8:12).eq.'0000 ') then
    read(arec(1:74),971) i,j,flw
    if(j.eq.0)j=1
    flow(i,j)=flw
  else if(arec(14:19).eq.'voidfj') then
    go to 35
  endif
  go to 30
35 read(23,997,end=200)arec
  call caselc(arec)
  if( index(arec,'mesh point temp').ne.0) goto 40
  go to 35
c
c Read heat structure temperatures
c
40 read(23,997,end=200)arec
  call caselc(arec)
  if(arec(22:42).eq.'control variable edit') go to 50
  if(arec(6:6).eq.'-') then
    read(arec,990,end=90) i,j,(strtmp(k),k=1,10)
90 istr(i,j) = ii
    do 45 k=1,19
      if(strtmp(k).gt.1.d-7)then
        struct(ii) = strtmp(k)
        ii = ii+1
        nhs = nhs+1
      else

```

```

        go to 40
      endif
45  continue
    write(*,989) i,j
  endif
  go to 40
c
c Read control variable values
c
  50 read(23,997,end=200)arec
    call caselc(arec)
    if(arec(5:11).eq.'restart') go to 200
    if(arec(59:63).eq.' ') then
      read(arec(1:106),980)icntrl1,cntrl(icntrl1)
      ncvs = ncvs+1
    else
      read(arec(1:106),980)icntrl1,cntrl(icntrl1),
&      icntrl2,cntrl(icntrl2)
      ncvs = ncvs+2
    endif
    go to 50
200 return
c
c Formats
c
999 format(i4,1x,i2,6x,e11.5,15x,f7.2)
998 format(a80)
997 format(a132)
990 format(1x,i4,1x,i3,3x,f7.2,9(5x,f7.2))
989 format(' *** warning *** heat structure',i5,', segment','i5'/
&' *** warning *** has more than 19 nodes through the thickness')
980 format(i5,30x,g13.0,10x,i5,30x,g13.0)
971 format(i4,1x,i2,54x,e13.5)
970 format(i3)
end

c*****c
c***                                     ***c
c***      subroutine caselc                                     ***c
c***                                     ***c
c***      this subroutine takes the character:                 ***c
c***      string "line" and converts all upper case           ***c
c***      letters to lower case.                                ***c
c***                                     ***c
c*****c
c
  subroutine caselc(line)
    character*(*) line
    character*1 a1,z1
    data a1/'A'/,z1/'Z'/
    data inc/32/
c
    do 10 i=1,len(line)
      if( lge(line(i:i),a1) .and. lle(line(i:i),z1))
&      line(i:i) = char(ichar(line(i:i))+inc)
10  continue
c
    return
  end

```

Appendix D**POSTPROCESSING PROGRAM**

The postprocessing program is useful for plotting the dependent variables calculated by RELAP5 as a function of time with TECPLOT. This program, which reads a formatted "strip" file, displays a menu of the variables available on the strip file for plotting, and includes those selected variables in the TECPLOT data file, is given on the following pages.

Postprocessing Program Used for Data Selection and Filtering

[illegible]

c
c Read time-dependent data for requested variables

```
c
  do 20 i=1,10000
    n1 = 1
    n2 = 4
    n2 = min(nt,n2)
    read(21,982,end=30)(calc(j,i),j=n1,n2)
    n1 = 5
    do 25 ii=1,100
      if(n2.ge.nt) go to 21
      n2 = n1+4
      read(21,986,end=30)(calc(j,i),j=n1,n2)
      n1 = n1+5
    25 continue
  21 if(mod(i,100).eq.0)write(6,984)i
  20 continue
  30 ilst=i-1
    write(6,994)ilst
```

c
c Convert the units

```
c
  do 40 n=1,nt
    conv1 = 1.
    conv2 = 0.
    if(names(n).eq.'p      ')then
      tecnam(n) = 'p      '
      tecnam(n)(3:5) = nums(n)(2:4)
      conv1 = cpres
    else if(names(n).eq.'tempf  ') then
      tecnam(n) = 'tf      '
      tecnam(n)(3:5) = nums(n)(2:4)
      conv1 = ctemp1
      conv2 = ctemp2
    else if(names(n).eq.'httemp  ') then
      tecnam(n) = 'ht      '
      tecnam(n)(3:5) = nums(n)(3:5)
      conv1 = ctemp1
      conv2 = ctemp2
    else if(names(n).eq.'htvat  ') then
      tecnam(n) = 'ha      '
      tecnam(n)(3:5) = nums(n)(3:5)
      conv1 = ctemp1
      conv2 = ctemp2
    else if(names(n).eq.'tempg  ') then
      tecnam(n) = 'tg      '
      tecnam(n)(3:5) = nums(n)(2:4)
      conv1 = ctemp1
      conv2 = ctemp2
    else if(names(n).eq.'sattemp ') then
      tecnam(n) = 'st      '
      tecnam(n)(3:5) = nums(n)(2:4)
      conv1 = ctemp1
      conv2 = ctemp2
    else if(names(n).eq.'mflowj ') then
      tecnam(n) = 'mf      '
      tecnam(n)(3:5) = nums(n)(2:4)
      conv1 = cmass
    else if(names(n).eq.'htchf  ') then
      tecnam(n) = 'cf      '
      tecnam(n)(3:5) = nums(n)(3:5)
      conv1 = chtflx
    else if(names(n).eq.'htrnr  ') then
      tecnam(n) = 'hq      '
      tecnam(n)(3:5) = nums(n)(3:5)
      conv1 = chtflx
```



```

else if(names(n).eq.'Costa fl') then
  tecnam(n) = 'Co '
  tecnam(n)(3:5) = nums(n)(3:5)
  conv1 = chtflx
else if(names(n).eq.'rhofj ') then
  tecnam(n) = 'rj '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = cdens
else if(names(n).eq.'vapgen ') then
  tecnam(n) = 'vg '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = cdens
else if(names(n).eq.'rhog ') then
  tecnam(n) = 'rg '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = cdens
else if(names(n).eq.'rhof ') then
  tecnam(n) = 'rf '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = cdens
else if(names(n).eq.'rhogj ') then
  tecnam(n) = 'rj '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = cdens
else if(names(n).eq.'rho ') then
  tecnam(n) = 'r '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = cdens
else if(names(n).eq.'gammaw ') then
  tecnam(n) = 'ga '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = cdens
else if(names(n).eq.'hif ') then
  tecnam(n) = 'hf '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = chi
else if(names(n).eq.'hig ') then
  tecnam(n) = 'hg '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = chi
else if(names(n).eq.'pmphead ') then
  tecnam(n) = 'ph '
  tecnam(n)(3:5) = nums(n)(8:10)
  conv1 = cpres
else if(names(n).eq.'pmpvel ') then
  tecnam(n) = 'pv '
  tecnam(n)(3:5) = nums(n)(8:10)
  conv1 = cpmprv
else if(names(n).eq.'uf ') then
  tecnam(n) = 'uf '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = cu
else if(names(n).eq.'ug ') then
  tecnam(n) = 'ug '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = cu
else if(names(n).eq.'ufj ') then
  tecnam(n) = 'uj '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = cu
else if(names(n).eq.'ugj ') then
  tecnam(n) = 'uj '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = cu
else if(names(n).eq.'q ') then
  tecnam(n) = 'q '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = cpower

```

```

else if(names(n).eq.'qwg    ') then
  tecnam(n) = 'qw    '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = cpower
else if(names(n).eq.'velfj  ') then
  tecnam(n) = 'vj    '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = cvel
else if(names(n).eq.'velgj  ') then
  tecnam(n) = 'vj    '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = cvel
else if(names(n).eq.'velf   ') then
  tecnam(n) = 'vf    '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = cvel
else if(names(n).eq.'velg   ') then
  tecnam(n) = 'vg    '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = cvel
else if(names(n).eq.'sounde ') then
  tecnam(n) = 'so    '
  tecnam(n)(3:5) = nums(n)(2:4)
  conv1 = cvel
else if(names(n).eq.'voidg  ') then
  tecnam(n) = 'vd    '
  tecnam(n)(3:5) = nums(n)(2:4)
else if(names(n).eq.'voidf  ') then
  tecnam(n) = 'vl    '
  tecnam(n)(3:5) = nums(n)(2:4)
else if(names(n).eq.'quals  ') then
  tecnam(n) = 'qs    '
  tecnam(n)(3:5) = nums(n)(2:4)
else if(names(n).eq.'quale  ') then
  tecnam(n) = 'qe    '
  tecnam(n)(3:5) = nums(n)(2:4)
else if(names(n).eq.'quala  ') then
  tecnam(n) = 'qa    '
  tecnam(n)(3:5) = nums(n)(2:4)
else if(names(n).eq.'cpus   ') then
  tecnam(n) = 'cpu-s'
else if(names(n).eq.'acv    ') then
  tecnam(n) = 'ac    '
  tecnam(n)(3:5) = nums(n)(2:4)
else if(names(n).eq.'rktpow ') then
  tecnam(n) = 'rktpw'
else if(names(n).eq.'cntrlvar') then
  tecnam(n) = 'cv    '
  tecnam(n)(3:5) = nums(n)(8:10)
  if(nums(n)(8:10).eq.'904') then
    conv1 = chtflx
  endif
endif
endif
nn = nn+1
do 35 i=1,ilst
  calc1(nn,i) = conv1*calc(n,i)-conv2
35  continue
40 continue
c
c Write tecdat information
c
  tecnam(1) = ' time'
  write(22,992)title,tecnam(1)
  do 11 i=2,ntw
    write(22,997)tecnam(i)
11 continue
  ii = 0
  write(22,995)
  do 45 i=1,ilst

```

```

      ii = ii+1
      write(22,993)(calc1(j,i),j=1,ntw)
45 continue
c
c Formats
c
999 format(17x,i3)
998 format(10x,7(2x,a8))
997 format(12x,(' ',a5,' '))
995 format('ZONE T=" ", J=1, F=POINT')
994 format(' number of records found =',i5)
993 format(1x,1p,8(e12.5,2x))
992 format('TITLE=" ',a40,' ',/, 'VARIABLES=" ',a5,' '')
991 format(10x,7(1x,a9)/(8(1x,a9)))
990 format(a8)
989 format(6(1x,a10,2x))
988 format(8(2x,a8))
987 format(7x,i3)
986 format(5e15.6)
985 format(' Input title for this case.')
984 format(i5)
982 format(15x,4e15.6)
981 format(' *** WARNING *** The number of variables found in the',/,
- ' *** WARNING *** RELAP5 STRIP Data Set is ',i5,' (more than 50)',
-/, ' *** WARNING *** The first value (time) will be used.',
-/, ' *** WARNING *** Specify the number of the parameter to begin a
- ',/, ' *** WARNING *** block of the remaining 49 parameters')
980 format(i5)
979 format(a40)
978 format(a10)
977 format(i5)
      stop
      end

```

Appendix E

ABBREVIATED MODEL FOR OPERATIONAL TRANSIENTS

The model that has heretofore been discussed was developed primarily for simulating LOCAs, where detail (especially in the core region) is beneficial for resolving important flow and heat transfer characteristics. Usually for such transients the criteria for failure is either incipience of boiling or exceeding a critical heat flux limit (CHF) at the fuel/water interface. LOCAs, which result in complete depressurization because the pressurizer pump cannot respond quickly enough to recover system pressure, may involve two-phase flow in the reflector and control plate regions and in the piping between the reactor vessel and primary heat exchangers. Also, because the HFIR Final Safety Analysis Report will utilize a CHF (as opposed to incipient boiling) failure criteria, for some LOCAs, boiling will occur in the fuel regions. Much detail is necessary to accurately predict the system response for such transients.

Operational transients for which the system does not fully depressurize could be modeled with much less detail and, thus, less computational effort. For such transients an abbreviated version of the model has been assembled. Due to the coarse nodalization, it may not be clear from the results whether or not boiling (or voiding) would occur. However, the detailed model could be used to more accurately simulate the transient.

Another difference between the operational transient simulations and the LOCA simulations involves modeling reactor power fluctuation due to various feedback mechanisms. In a LOCA, the system immediately depressurizes so that the reactor is tripped very early in the transient, and the postshutdown heat curve is used to represent the decline in reactor power. However, the operational transient scenarios often involve longer simulation times before scram occurs, if it occurs at all. It is therefore necessary to represent changes in reactivity brought about by the changing temperatures of the structures and moderator in the core region. For this reason, the RELAP5 point (space-independent) kinetics model was invoked in the abbreviated model that will be used for simulating operational transients. Because RELAP5/MOD2.5 point kinetics capability has been found to be inadequate for the fast response of the HFIR system, a modification to the code has been made that requires changing the input model.¹

This appendix describes the changes that have been made to the detailed model to produce the abbreviated model. Details of the changes that have been made are elaborated in calculational notes.²

E.1. COARSENING OF NODALIZATION

Two parameters directly affect the cost of a RELAP5 simulation: number of nodes and time-step size.³ The cost is proportional to the number of nodes and inversely proportional to the time-step size. The time-step size is limited by the minimum material Courant limit in the model. The limiting nodes in the detailed model are in the core region because the velocities are high and the control volumes (nodes) are short. In an operational transient simulation, two-phase flow is generally not expected, so the level of discretization in the core can be realized.

To reduce the cost of running the model, the discretization was coarsened throughout the primary system, as shown in Fig. E.1. The input model is listed in Appendix F. The most

Fig. E.1. Abbreviated model primary system nodal diagram.

noticeable change is the combination of heat exchanger cells A and C into one loop. The flow areas, pump size, heat transfer areas, and volume in the combined loop were increased appropriately as indicated in the figure. The secondary side (except for the heat exchangers) and pressurizing system remained the same. In each heat exchanger, 8 nodes, instead of 20, were used to represent primary coolant in the tubing, and 8 were also used for the shell (secondary) side.

Within the core, the abbreviated discretization is shown in Fig. E.2. Here is where the greatest cost savings were made. Each channel and structure in the core/reflector were represented with only one axial node, whereas previously as many as 11 nodes were used. The heat source factors and heat structure areas used in the detailed model, which specify the power distribution in the core structures, were combined to get new factors for the single-node structures. The same number of parallel channels was used in the abbreviated model as in the detailed model.

In reducing the level of discretization, as junctions were eliminated from the model, it was often necessary to combine loss coefficients. This means that some form losses are calculated by RELAP5 at a position more remote from where they actually occur, but for most operational transients, the overall flows and important pressure drops should be as accurate as if the detailed model was used.

E.2 POINT KINETICS MODEL

The point kinetics model available in RELAP5 was used to model changes in the HFIR fuel reactivity. The option of fission product decay calculations was invoked using the 1979 ANS Standard for Decay Heat Power in Light Water Reactors.⁴ A total of 85 MW was specified as the nominal reactor power.

RELAP5 control variables (Table E.1) are used to calculate changes in reactivity of the HFIR fuel due to changes in (1) moderator temperature, (2) moderator density, (3) thermal expansion or contraction of the fuel plates, (4) position of control cylinders and safety rods, and (5) target region density. Insertion of the spring loaded safety rods (scram) is modeled with the control systems. R. B. Rothrock⁵ supplied the following reactivity constants that have been used in the RELAP5 HFIR point kinetics model:

1. effective total delayed neutron fraction, 0.0076;
2. prompt neutron lifetime, 35 μ s (BOL);
3. moderator temperature coefficients, Table E.2;
4. reactivity worth of the control cylinders and safety rods, Tables E.3 and E.4, and
5. uniform void coefficients: inner fuel element, -0.11% per 1% void; outer fuel element, -0.24% per 1% void.

Also, the target reactivity⁶ as a function of coolant void fraction is shown in Table E.5.

The four contributors to changes in reactivity are separated into sets of control variables. The value of the reactivity (in β) of any one of the four contributors is unimportant except that the sum be zero at steady state. Rather, it is the change in the reactivity that is important, and modeling that change accurately was the goal of the RELAP5 HFIR reactivity control systems model.

E.2.1 Moderator Temperature Effects

Increases in the water temperature within the target region lead to increases in the fuel reactivity; however, increases in the water temperature within the fuel region lead to decreases in the fuel reactivity. The RELAP5 control systems used to calculate these effects are diagrammed in Fig. E.3. The average moderator temperatures within the fuel and target regions are monitored, and the reactivity is adjusted as these average temperatures change.

Fig. E.2. Abbreviated model core nodal diagram.

Table E.1. Control variables used for specifying changes in HFIR fuel reactivity

Variable	Type	Description
776	CONSTANT	Steady-state average density in control plate region
777	SUM	Average coolant temperature in fuel channels
778	SUM	Moderator temperature coefficient for coolant in fuel channels
779	SUM	Change in average coolant temperature during last time step for fuel channels
780	SUM	Saved value of average coolant temperature in fuel channels (CV 777) for later use
781	MULT	Adjustment of reactivity due to temperature change of coolant in the fuel channels
782	SUM	New value of fuel moderator worth
783	SUM	Average coolant temperature in target channels
784	FUNCTION	Moderator temperature coefficient for coolant in target channels
785	SUM	Change in average coolant temperature during last time step for target channels
786	SUM	Saved value of the average coolant temperature in target channels (CV 783) for later use
787	MULT	Adjustment of reactivity due to temperature change of coolant in the target channels
788	SUM	New value of target moderator worth
789	SUM	Average inner fuel coolant temperature change
790	SUM	Saved value of the average inner fuel coolant temperature
791	SUM	Average inner fuel temperature change
792	SUM	Saved value of the average inner fuel temperature
793	SUM	Difference between fuel temperature change and coolant temperature change
794	MULT	Change in reactivity due to thermal expansion of the inner fuel element (\$)
795	SUM	New reactivity contribution based on thermal expansion of the inner fuel element (\$)
796	SUM	Average outer fuel coolant temperature change
797	SUM	Saved value of the average inner fuel coolant temperature

Table E.1 (continued)

Variable	Type	Description
798	SUM	Average outer fuel temperature change
799	SUM	Saved value of the average outer fuel temperature
800	SUM	Difference between fuel temperature change and coolant temperature change
801	MULT	Change in reactivity due to thermal expansion of the outer fuel element (\$)
802	SUM	New reactivity contribution based on the thermal expansion of the outer fuel element (\$)
803	SUM	Average change in density for coolant in control cylinder and reflector regions
804	SUM	Change in average density in control plate region
805	DIV	New worth contribution for density change of coolant in control cylinder and reflector regions (\$)
806	FUNCTION	Control plate worth (\$)
808	TRIPUNIT	Flag for initiating scram
809	TRIPDLAY	Time that scram was initiated
810	SUM	Time since scram was initiated
811	FUNCTION	Safety rod insertion (in.)
812	MULT	Safety rod insertion multiplied by initiating flag (CV 808)
813	SUM	New position of safety rods (in.)
814	FUNCTION	Safety rod worth (\$)
815	SUM	Average void fraction in target region
816	FUNCTION	Average reactivity based on CV815 and general Table 14
817	SUM	Total reactivity (\$)
819	CONSTANT	Control cylinder position (in.)
850	R - POW	Added input for modified version of RELAP5/MOD2.5

Table E.2. Moderator temperature coefficients in fuel and flux trap regions

Temperature (°F)	Fuel region (\$/°F)	Flux trap region (\$/°F)
80	-9.15×10^{-3}	7.46×10^{-3}
90	-9.86×10^{-3}	7.75×10^{-3}
100	-10.56×10^{-3}	8.03×10^{-3}
110	-11.27×10^{-3}	8.31×10^{-3}
120	-11.97×10^{-3}	8.59×10^{-3}
130	-12.68×10^{-3}	9.01×10^{-3}
140	-13.38×10^{-3}	9.58×10^{-3}
150	-14.08×10^{-3}	10.0×10^{-3}
160	-14.79×10^{-3}	10.56×10^{-3}

Table E.3. HFIR control plate worth

Insertion (in.)	Reactivity (\$)
0.0	0.0
0.543	-0.1071
1.086	-0.2476
1.629	-0.4284
2.172	-0.6551
2.715	-0.9317
3.258	-1.2611
3.801	-1.6456
4.344	-2.0871
4.887	-2.5867
5.43	-3.1457
5.973	-3.7647
6.516	-4.4442
7.059	-5.1844
7.602	-5.9847
8.145	-6.8439
8.688	-7.7598
9.231	-8.7286
9.774	-9.74488
10.317	-10.8008
10.860	-11.8859
19.86	-16.63
26.86	-16.63

Table E.4 Safety rod worth

Insertion (in.)	Reactivity
0.00	0.0000
0.543	-0.07833
1.086	-0.18291
1.629	-0.31909
2.172	-0.4911
2.715	-0.70237
3.258	-0.95569
3.801	-1.25346
4.344	-1.59773
4.887	-1.99024
5.430	-2.43236
5.973	-2.92495
6.516	-3.46822
7.059	-4.05143
7.602	-4.70255
8.145	-5.38790
8.688	-6.11166
9.231	-6.86532
9.774	-7.63706
10.371	-8.41110
10.860	-9.16695
18.86	-13.84
26.86	-13.84

Table E.5. HFIR target region reactivity as a function of coolant void fraction

Void	Δk	β
0.0	0.0	0.0
0.01	4.5×10^{-4}	6.34×10^{-2}
0.10	0.006	0.8451
0.20	0.010	1.408
0.30	0.013	1.831
0.40	0.0145	2.042
0.42	0.015	2.113
0.48	0.014	1.972

In calculating the average temperature of the target region, both the heated and unheated channels (Fig. 7) were included. The temperatures in the inner and outer average fuel channels were combined into a single average that was used for the average moderator temperature in the fuel region.

E.2.2 Thermal Expansion Effects

If the fuel plates heat up, they will also expand, the moderator volume contained within them is decreased, and the reactivity of the fuel increases by an amount proportional to the void coefficient. The RELAP5 control system diagrammed in Fig. E.4 shows how this effect for the inner fuel element is calculated in the model. The temperature change and, thus, thermal expansion/contraction of the fuel are assumed to occur uniformly. A similar control system is used to calculate the reactivity change due to thermal expansion/contraction of the outer fuel element. The coefficient of thermal expansion for the fuel plates was assumed to be that of Al6061 (Ref. 7) at 500 K: $27.5 \times 10^{-6} \text{ K}^{-1}$.

E.2.3 Moderator Density Change in Control Region and Reflector

Changes in reactivity due to moderator density changes in the control region and reflector are based on an assumed void coefficient of 0.028 β /1% void.⁸ The control plate and reflector region densities are area weighted, and a single void coefficient is applied to get the change in reactivity.

E.2.4 Control Cylinder Worth

The control cylinder position is specified in the input file, and the model determines control plate worth, using general Table 16.

E.2.5 Safety Rod Worth

The safety rod insertion at scram is calculated using a control system model (Fig. E.5). The rods are spring loaded, with the maximum acceleration of 4 g at the initial spring deflation of 0.5 ft (0.152 m). Once the spring is fully extended, the rods fall subject only to

Fig. E.3. Moderator temperature change contribution to reactivity change control logic.

Fig. E.4. Inner fuel thermal expansion contribution to reactivity change control logic.

Fig. E.5. Control logic for safety rod insertion after scram is initiated.

the acceleration of gravity. A curve was generated for the safety rod position as a function of time after insertion, and the total insertion time was found to be 0.25 s. Because the HFIR Technical Specifications allow an insertion time of 0.4 s, the curve was stretched out over 0.4 s. (For operational transients, if a shorter insertion time is conservative, then it must be assumed that the safety rods are instantaneously completely inserted.)

E.2.6 Target Region Void Feedback

Based on the average vapor void fraction in the target region and general Table 14, the reactivity of the moderator in the target region is calculated. General Table 14 is the same as Table E.5.

E.3 REFERENCES

1. J. D. Freels, "Documentation of a Modification of the RELAP5/MOD2.5/v3t Code for Performing HFIR Safety Analyses of Events Involving Reactivity Changes," RRD Calculation ID: HFIR-RRD-91-JDF-15-02, Martin Marietta Energy Systems, Inc., Oak Ridge Natl. Lab., February 1992.
2. M. W. Wendel, "HFIR RELAP5 Abbreviated Model Notes," Research Reactors Division Calculation, C-HFIR-92-004, Martin Marietta Energy Systems, Inc., October 1988–December 1990, February 28, 1992.
3. V. H. Ransom et al., *RELAP5 Code Manual*, Vol. 1, p. 11, Idaho National Engineering Laboratory, December 1985.
4. *American National Standard for Decay Heat Power in Light Water Reactors*, ANSI/ANS-5.1, 1979.
5. R. B. Rothrock, Oak Ridge National Laboratory, letter to B. L. Lepard, Oak Ridge National Laboratory, October 1990.
6. R. D. Cheverton and T. M. Sims, *HFIR Core Nuclear Design*, ORNL-4621, p. 72, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., July 1971.
7. Y. S. Touloukian et al., *Thermophysical Properties of Matter*, Vol. 12, p. 1028, IFI/Plenum, 1970.
8. R. D. Cheverton and T. M. Sims, *HFIR Core Nuclear Design*, ORNL-4621, Union Carbide Corp. Nuclear Div., Oak Ridge Natl. Lab., July 1971.

Appendix F

INPUT LISTING FOR ABBREVIATED MODEL


```

518 cntrlvar 505 gt cntrlvar 684 0. l
* trip pressurizer pumps if eds is activated
519 cntrlvar 255 gt null 0 0. l
* trip pressurizer pumps if suction pressure is low for 5 sec
521 cntrlvar 18 ge null 0 5. l
525 p 060010000 lt null 0 20.0 l * structural elast model off
* water coolant temperature low enough to trip open eds
526 cntrlvar 500 lt cntrlvar 685 0. l
528 cntrlvar 501 lt cntrlvar 686 0. l * reset eds valves
*
* main circulation pump trip logic
*
529 time 0 gt null 0 -1. l * use speed table for mcps
530 cntrlvar 114 lt null 0 1. n * mcp d cavitated
531 cntrlvar 139 lt null 0 1. n * mcp a/c cavitated
533 cntrlvar 501 lt cntrlvar 683 0. l * mcp trip on low pressure
534 pipvel 70 lt null 0 270. l * mcp d reached pony motor speed
535 pipvel 170 lt null 0 270. l * mcp a/c reached pony motor spd
536 cntrlvar 117 gt null 0 1. n * v/alpha range pump pu-1d
537 cntrlvar 142 gt null 0 1. n * v/alpha range pumps pu-1c,-1a
*
* trips on setpoints and failures
*
551 time 0 gt cntrlvar 601 0. l * reactor trip
552 time 0 gt cntrlvar 602 0. l
553 time 0 gt cntrlvar 603 0. l * loss of offsite ac power
554 time 0 gt cntrlvar 604 0. l
555 time 0 gt cntrlvar 605 0. l * pressurizer pump failure
556 time 0 gt cntrlvar 606 0. l
557 time 0 gt cntrlvar 607 0. l
558 time 0 gt cntrlvar 608 0. l
559 time 0 gt cntrlvar 609 0. l
560 time 0 gt cntrlvar 610 0. l
561 time 0 gt cntrlvar 611 0. l
562 time 0 gt cntrlvar 612 0. l
563 time 0 gt cntrlvar 613 0. l
564 time 0 gt cntrlvar 614 0. l
565 time 0 gt cntrlvar 615 0. l
566 time 0 gt cntrlvar 616 0. l
567 time 0 gt cntrlvar 617 0. l
568 time 0 gt cntrlvar 618 0. l
569 time 0 gt cntrlvar 619 0. l
570 time 0 gt cntrlvar 620 0. l
571 time 0 gt cntrlvar 621 0. l * loss of instrument air
572 time 0 gt cntrlvar 622 0. l
573 time 0 gt cntrlvar 623 0. l
574 time 0 gt cntrlvar 624 0. l
575 time 0 gt cntrlvar 625 0. l
576 time 0 gt cntrlvar 626 0. l
577 time 0 gt cntrlvar 627 0. l
578 time 0 gt cntrlvar 628 0. l
579 time 0 gt cntrlvar 629 0. l * ld block valves fail to close

580 time 0 gt cntrlvar 630 0. l
581 time 0 gt cntrlvar 631 0. l
582 time 0 gt cntrlvar 632 0. l
583 time 0 gt cntrlvar 633 0. l * failure of reactor trip
584 time 0 gt cntrlvar 634 0. l
585 time 0 gt cntrlvar 635 0. l
586 time 0 gt cntrlvar 636 0. l * secondary pump/bypass failure
587 time 0 gt cntrlvar 637 0. l
588 time 0 gt cntrlvar 638 0. l
589 time 0 gt cntrlvar 639 0. l * aux pressurizer pump fails
590 time 0 gt cntrlvar 641 0. l * allow primary coolant leakage
*
600 501
*
* logical trips
*
* check for aux pwr pump trip conditions
602 515 and 503 l
603 526 and -528 l * eds valves open
* logic for low suction pressure trip on pressurizer pumps
605 606 and 505 n
606 513 or 605 n
* has eds been activated or has is high press limit exceeded?
609 518 or 519 l
* has ac power been lost?
610 609 or 553 l
* check for pressurizer pump failure
611 555 or 610 l
* should standby pressurizer pump be on?
612 503 and 514 l
* should pressurizer pump motors be engaged?
613 -512 and -521 n 0.
* power supplied to main pwr pumps? yes, if false; no, if true
* pressurizer pump trip (used on cards 0660301 and 0690301)
614 -613 or 611 l * pressurizer pump trip
* pwr pump speed table trip (cards 0666100 and 0696100)
615 -614 or -614 n 0.
622 -579 and 516 n * letdown block valves close
623 -589 and 602 l * auxiliary pwr pump on
*
* reactor trip logic
*
* initiate scram due to automatic controls
643 510 or 551 n
* trip reactor on loss of instr. air at pwr pump trip
644 571 and 518 l
* temperature or pressure trip
645 507 or 508 l
646 644 or 509 l
647 646 or 645 l * initiate scram
648 643 and -583 n * scram initiated
* sec cooling system actions: bypass valve open, pumps trip

```

```

649 648 and -586 l * trip secondary pump pu-6b
650 -649 or -649 n 0.
651 649 or 568 l * trip secondary pump pu-6a
652 -651 or -651 n 0.
*
660 553 or 533 l * main circulation pumps tripped
*
*****
*
* reactor contents
*
*****
180000 u-plenum branch
180001 6 1
180101 106. 1.99 210.94 0.0 -90. -1.99 1.5e-4 7.83 0
180200 3 -.48270e+03 119.960
181101 018010000 004000000 1.31 0.0 0.0 31100
181201 1.8461e+03 0. 0.
182101 018010000 017000000 0.129 0.0 0.0 31100
182201 1.0452e+02 0. 0.
183201 018010000 033000000 41.9 0.0 0.0 31100
183301 1.1091e-01 0. 0.
184101 018010000 003000000 0.064 0.0 0.0 31100
184201 3.1028e+02 0. 0.
185101 091010000 018000000 0.0 0.0 0.0 31101
185201 1.1360e+03 0. 0.
186101 092010000 018000000 0.0 0.0 0.0 3110'
186201 1.1360e+03 0. 0.
*
170000 target-t branch
170001 2 1
170101 0.129 3.92 0.50568 0.0 -90. -3.92 1.5e-4 0.405 0
170200 3 -.48229e+03 119.960
171101 017010000 005000000 3.66e-2 0.0 0.0 31100
171201 9.0242e+01 0. 0.
172101 017010000 006000000 0.004789 0.0 0.0 31100
172201 1.4273e+01 0. 0.
*
0040000 i-shrd branch
0040001 7 1
0040101 1.31 3.92 5.1352 0.0 -90. -3.92 1.5e-4 0.89 0
0040200 3 -.47908e+03 119.960
0041101 004010000 001000000 0.097 0.0 0.0 31000
0041201 3.1281e+02 0. 0.
0042101 004010000 002000000 0.186 0.0 0.0 31000
0042201 5.9913e+02 0. 0.
0043101 004010000 010000000 8.05e-4 0.0 0.0 31000
0043201 2.1726e+00 0. 0.

0044101 004010000 014000000 0.097 0.0 0.0 31000
0044201 3.1269e+02 0. 0.
0045101 004010000 015000000 0.186 0.0 0.0 31000
0045201 5.9888e+02 0. 0.
0046101 004010000 016000000 7.14e-4 0.0 0.0 31000
0046201 1.9315e+00 0. 0.
0047101 004010000 019000000 0.0037 0.0 0.0 31100
0047201 1.8512e+01 0. 0.
*
0030000 shrd branch
0030001 7 1
0030101 2.48 3.92 9.7216 0.0 -90. -3.92 1.5e-4 0.85 0
0030200 3 -.38051e+03 119.910
0031101 003010000 027000000 0.0391 0.0 0.0 31100
0031201 3.6437e+01 0. 0.
0032101 003010000 028000000 0.0668 0.0 0.0 31100
0032201 8.1961e+01 0. 0.
0033101 003010000 029000000 0.0389 0.0 0.0 31100
0033201 3.4282e+01 0. 0.
0034101 003010000 030000000 0.00613 0.0 0.0 31100
0034201 5.0684e+00 0. 0.
0035101 003010000 031000000 0.103 0.0 0.0 31100
0035201 8.4842e+01 0. 0.
0036101 003010000 032000000 0.0628 0.0 0.0 31100
0036201 6.0001e+01 0. 0.
0037101 003010000 036000000 0.00801 0.0 0.0 31100
0037201 7.6862e+00 0. 0.
*
* this volume should always be about 120 f (322.22 k)
*
0030000 u-byps branch
0030001 3 1
0030101 41.9 5.92 248.0480 0.0 -90. -5.92 1.5e-4 5.0 0
0030200 3 -.48440e+03 120.000
0031101 003010000 035000000 26.2 0.0 0.0 31000
0031201 1.1086e+01 0. 0.
0032101 003010000 140000000 0.05134 2.05 2.05 31000
0032201 7.2271e-05 0. 0.
0033101 003010000 021000000 0.023303 0. 0. 31100
0033201 2.6655e-05 0. 0.
*
* emergency depressurization system
*
* pipe from reactor to eds valve
*
1400000 eds pipe
1400001 3
1400101 0.05134 1 0.01414 2 0.00600 3
1400301 15.875 1 26.86 2 7.5 3
1400601 0. 3
1400801 1.5e-4 0.2557 1 1.5e-4 0.1342 2 1.5e-4 0.0874 3
1400901 0.7 0.7 1 4.05 4.05 2

```

```

1401001 0 3
1401101 31000 2
1401201 3 .48567e+03 120.00 0. 0. 0. 1
1401202 3 .48567e+03 120.00 0. 0. 0. 2
1401203 3 .48567e+03 120.00 0. 0. 0. 3
1401300 1
1401301 2.3582e-05 0. 0. 1
1401302 2.4730e-06 0. 0. 2
*
* servo valve for emergency depressurization
*
1410000 eds-vlv valve
1410101 140010000 142000000 0.00211 1. 1. 100
1410201 1 0.0000e+00 0. 0.
1410300 srvtlv
1410301 255
*
* 1/2-in line joining valve to hold-up tank
*
1420000 vlv-tank snglvol
1420101 0.00211 7.5 0. 0. 0. 1.5e-4 0.0518 0
1420200 3 .14700e+02 120.000
*
1430000 eds-ou-j snglvol
1430101 142010000 144000000 0.00211 1. 1. 31100
1430201 1 0.0000e+00 0. 0.
*
* 90-s hold-up tank for eds discharge
*
1440000 eds-sink tmdpvol
1440101 0.1 1.0 0. 0. 0. 0. 1.d-6 0.1 10
1440200 3
1440201 0. 14.7 120.
*
* injection/ejection of mass to account for struct elasticity
*
0400000 elast8v tmdpvol
0400101 1. 1. 0. 0. 0. 0. 1.d-6 1. 10
0400200 3 0 tempf 033010000
0400201 0. 20. 0. 1.e6 20. 1.e6
*
0420000 elast8j tmdpvol
0420101 040000000 033000000 1.
0420200 1 0 cntrlvar 376
0420201 -1.e60 -1.e60 0. 0.
0420202 -1.e4 -1.e4 0. 0.
0420203 1.e4 1.e4 0. 0.
0420204 1.e60 1.e60 0. 0.
*
* pipe from reactor vessel to reactor
* check valve

```

```

0210000 rcvpipe pipe
0210001 5
0210101 0.05134 1 0.023303 5
0210301 1.2 1 9.876 2 1.925 3 3.25 4 1.25 5
0210601 0. 1 90. 2 7.4 3 90. 4 0. 5
0210701 0. 1 4.333 2 0.25 3 3.25 4 0. 5
0210801 1.5e-4 0.25567 1 1.5e-4 0.17225 5
0210901 0.19 0.19 1 0.27 0.27 3 0.9 0.9 4
0211001 0 5
0211101 01100 1 01000 4
0211201 3 .48567e+03 119.99 0. 0. 0. 1
0211202 3 .48474e+03 120.00 0. 0. 0. 2
0211203 3 .48375e+03 120.00 0. 0. 0. 3
0211204 3 .48300e+03 120.00 0. 0. 0. 4
0211205 3 .48230e+03 120.00 0. 0. 0. 5
0211300 1
0211301 2.2882e-05 0. 0. 1
0211302 8.9788e-06 0. 0. 2
0211303 6.2849e-06 0. 0. 3
0211304 1.7453e-06 0. 0. 4
*
* reactor check valve
*
0380000 rcv-chk tmdpvol
0380101 039000000 021010000 1.
0380200 1 0 cntrlvar 321
0380201 -1.e60 -1.e60 0. 0.
0380202 -1.e4 -1.e4 0. 0.
0380203 1.e4 1.e4 0. 0.
0380204 1.e60 1.e60 0. 0.
*
* vessel pool
*
0390000 chkval tmdpvol
0390101 0.218 1.0 0.218 0.0 0.0 0.0 1.5e-4 0.527 10
0390200 3
0390201 0.0 21.66 100.
*
0060000 c-target snglvol
0060101 6.72e-2 2.0 0.1344 0.0 -90. -2.0 1.7e-6 0.0404 0
0060200 3 .44767e+03 119.950
*
0050000 h-target snglvol
0050101 3.66e-2 2.0 0. 0.0 -90. -2.0 1.7e-6 0.0187 0
0050200 3 .45846e+03 129.340
*
0010000 i-fuel-1 snglvol
0010101 0.097 2.0 0. 0.0 -90. -2.0 1.7e-6 8.14e-3 0
0010200 3 .41488e+03 161.210
*
0140000 i-fuel-2 snglvol
0140101 0.097 2.0 0. 0.0 -90. -2.0 1.7e-6 8.14e-3 0

```

```

0140200 3 .41488e+03 160.430
*
0100000 i-f-hot snglvol
0100101 8.05e-4 2.0 0. 0.0 -90. -2.0 1.7e-6 5.77e-3 0
0100200 3 .41980e+03 223.790
*
0190000 f-laby snglvol
0190101 0.0786 2.0 0.0 1572 0.0 -90. -2.0 1.7e-6 0.0550 0
0190200 3 .37645e+03 119.910
*
0020000 o-fuel-1 snglvol
0020101 0.186 2.0 0. 0.0 -90. -2.0 1.7e-6 8.11e-3 0
0020200 3 .41493e+03 163.330
*
0150000 o-fuel-2 snglvol
0150101 0.186 2.0 0. 0.0 -90. -2.0 1.7e-6 8.11e-3 0
0150200 3 .41493e+03 162.500
*
0160000 o-f-hot snglvol
0160101 7.14e-4 2.0 0. 0.0 -90. -2.0 1.7e-6 5.76e-3 0
0160200 3 .41989e+03 233.130
*
0270000 i-cp snglvol
0270101 0.0391 2.0 0. 0.0 -90. -2.0 6.5e-4 0.0173 0
0270200 3 .37422e+03 130.880
*
0280000 m-cp snglvol
0280101 0.0668 2.0 0. 0.0 -90. -2.0 6.5e-4 0.0283 0
0280200 3 .37344e+03 130.350
*
0290000 o-cp snglvol
0290101 0.0389 2.0 0. 0.0 -90. -2.0 6.5e-4 0.0158 0
0290200 3 .37434e+03 135.520
*
0300000 hot-be snglvol
0300101 0.00613 2.0 0. 0.0 -90. -2.0 2.1e-4 0.0104 0
0300200 3 .37447e+03 150.870
*
0310000 r-sp-be snglvol
0310101 0.103 2.0 0. 0.0 -90. -2.0 2.1e-4 0.0104 0
0310200 3 .37446e+03 133.530
*
0320000 pm-be-i snglvol
0320101 0.0628 2.0 0. 0.0 -90. -2.0 4.1e-5 0.0104 0
0320200 3 .37417e+03 133.150
*
0360000 pm-be-o snglvol
0360101 0.00801 2.0 0. 0.0 -90. -2.0 4.1e-5 0.0104 0
0360200 3 .37417e+03 143.700
*
0080000 l-plm-1 branch
0080001 9 1
0080101 1.25 3.74 4.675 0.0 -90. -3.74 1.5e-4 1.26 0
0080200 3 .37375e+03 160.080
0081101 001010000 008000000 0.097 0.0 0.0 31100
0081201 3.1281e+02 0. 0.
0082101 002010000 008000000 0.186 0.0 0.0 31100
0082201 5.9913e+02 0. 0.
0083101 005010000 008000000 1.65e-2 0.0 0.0 31100
0083201 9.0242e+01 0. 0.
0084101 006010000 008000000 3.49e-3 0.0 0.0 31100
0084201 1.4273e+01 0. 0.
0085101 010010000 008000000 8.05e-4 0.0 0.0 31100
0085201 2.1726e+00 0. 0.
0086101 014010000 008000000 0.097 0.0 0.0 31100
0086201 3.1269e+02 0. 0.
0087101 015010000 008000000 0.186 0.0 0.0 31100
0087201 5.9888e+02 0. 0.
0088101 016010000 008000000 7.14e-4 0.0 0.0 31100
0088201 1.9315e+00 0. 0.
0089101 019010000 008000000 0.0786 0.0 0.0 31100
0089201 1.8512e+01 0. 0.
*
0090000 l-plm-2 branch
0090001 9 1
0090101 7.66 3.74 28.6484 0.0 -90. -3.74 1.5e-4 2.06 0
0090200 3 .37004e+03 145.450
0091101 027010000 009000000 0.0391 0.0 0.0 31100
0091201 3.6437e+01 0. 0.
0092101 028010000 009000000 0.0668 0.0 0.0 31100
0092201 8.1961e+01 0. 0.
0093101 029010000 009000000 0.0389 0.0 0.0 31100
0093201 3.4282e+01 0. 0.
0094101 030010000 009000000 0.00613 0.0 0.0 31100
0094201 5.0684e+00 0. 0.
0095101 031010000 009000000 0.103 0.0 0.0 31100
0095201 8.4842e+01 0. 0.
0096101 032010000 009000000 0.0628 0.0 0.0 31100
0096201 6.0001e+01 0. 0.
0097101 035000000 009000000 0.071 2700. 2700. 31003
0097201 1.1084e+01 0. 0.
0098101 036010000 009000000 0.00801 0.0 0.0 31100
0098201 7.6862e+00 0. 0.
0099101 009000000 008000000 0.239 1.5 1.5 31003
0099201 -2.8238e+02 0. 0.
*
* this volume should always be about 120 f (322.22 k)
*
0350000 l-byps branch
0350001 0 1
0350101 26.2 3.74 97.988 0.0 -90. -3.74 1.5e-4 3.25 0
0350200 3 .48647e+03 120.000
*
0340000 outlet branch

```

```

0340001 2 1
0340101 5.9032 3.688 21.771 0.0 -90. -3.688 1.5e-4 2.74 0
0340200 3 .36633e+03 156.190
0341101 008010000 034000000 0.77 0.0 0.0 31100
0341201 1.6683e+03 0. 0.
0342101 009010000 034000000 0.543 0.0 0.0 31100
0342201 6.0374e+02 0. 0.
*
0410000 reactoj srngljun
0410101 034000000 050000000 1.553 0.34 0.34 31002
0410201 1 2.2720e+03 0. 0.
*
* vessel lid heat structure
*
10181000 1 5 1 0 0 0 0
10181400 -1
10181401 117.43 116.98 111.22 105.52 105.06
10181100 0 1
10181101 1 0.01042 2 1.1771 1 1.1875
10181201 11 1 12 3 11 4
10181301 0 0 4
10181501 18010000 0 3600 0 48.3 1
10181601 39010000 0 4700 0 48.3 1
10181701 0 0 0 0 0 0 1
10181801 0 0 0 0 0 0 1
10181901 0 0 0 0 0 0 1
*
* upper vessel sidewall heat structure
*
10180000 1 5 2 0 3.92 0
10180400 -1
10180401 114.15 113.50 111.72 110.00 109.37
10180100 0 1
10180101 1 3.930 2 4.170 1 4.18
10180201 10 1 12 3 11 4
10180301 0 0 4
10180501 18010000 0 3400 1 4.39 1
10180601 39010000 0 4500 1 4.39 1
10180701 0 0 0 0 0 0 1
10180801 0 0 0 0 0 0 1
10180901 0 0 0 0 0 0 1
*
* outer shroud heat structure
*
10410000 1 5 2 0 1.139988 0
10410400 -1
10410401 119.92 119.92 119.92 119.92 119.92
10410100 0 1
10410101 1 1.140045 2 1.198288 1 1.198345
10410201 5 1 8 3 5 4
10410301 0 0 4
10410501 3010000 0 1 1 3.92 1

10410601 33010000 0 4300 1 3.92 1
10410701 0 0 0 0 0 0 1
10410801 0 0 0 0 0 0 1
10410901 0 0 0 0 0 0 1
*
* active target heat structure
*
10050000 1 7 2 0 0 0 1 8
10050400 -1
10050401 857.35 773.61 522.37 505.71 249.79 220.78 194.01
10050100 0 1
10050101 2 0.008125 1 0.010375 1 0.01038333 1 0.0153292 1 0.0153866
10050201 4 2 14 3 13 4 9 5 5 6
10050301 1.0 2 0 0 6
10050501 0 0 0 0 0 1
10050601 5010000 0 1 0 4.99 1
10050701 10850 1.041e-2 0 0 0 1
10050901 0 0 0 0 0 1
*
* i-active fuel-1 heat structure
*
10010000 1 5 1 0 0 0 1 8
10010400 -1
10010401 226.06 225.25 222.81 218.98 195.59
10010100 0 1
10010101 2 1.25e-3 1 2.03754e-3 1 2.09496e-3
10010201 2 2 1 3 5 4
10010301 1.0 2 0 0 4
10010501 0 0 0 0 87.0 1
10010601 1010000 0 1 0 87.0 1
10010701 10850 0.1568 0 0 0 0 1
10010901 0 0 0 0 0 1
*
* i-active fuel-2 heat structure
*
10140000 1 5 1 0 0 0 1 8
10140400 -1
10140401 224.11 223.32 220.92 217.17 194.23
10140100 0 1
10140101 2 1.25e-3 1 2.03754e-3 1 2.09496e-3
10140201 2 2 1 3 5 4
10140301 1.0 2 0 0 4
10140501 0 0 0 0 87.0 1
10140601 14010000 0 1 0 87.0 1
10140701 10850 0.1557 0 0 0 0 1
10140901 0 0 0 0 0 1
*
* i-hot active fuel heat structure
*
10100000 1 5 1 0 0 0 1 8
10100400 -1
10100401 341.60 340.38 336.73 331.43 270.16

```

```

10100100 0 1
10100101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10100201 2 2 1 3 5 4
10100301 1.0 2 0.0 4
10100501 0 0 0 1.0238 1
10100601 10010000 0 1 0 1.0238 1
10100701 10850 2.788e-3 0.0 0.0 1
10100901 0 0.0 0.0 1
*
* i-hot spot (local) active fuel heat structure
*
10102000 1 5 1 0 0.0 0 1 8
10102400 -1
10102401 574.58 570.94 560.02 544.61 361.98
10102100 0 1
10102101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10102201 2 2 1 3 5 4
10102301 1.0 2 0.0 4
10102501 0 0 0 0.000853 1
10102601 10010000 0 1 0 0.000853 1
10102701 10850 6.923e-6 0.0 0.0 1
10102901 0 0.0 0.0 0.0 1
*
* o-active fuel-1 heat structure
*
10020000 1 5 1 0 0.0 0 1 8
10020400 -1
10020401 230.63 229.69 226.88 222.92 198.69
10020100 0 1
10020101 2 1.25e-3 1 2.03754e-3 1 2.09496e-3
10020201 3 2 1 3 5 4
10020301 1.0 2 0.0 4
10020501 0 0 0 0.169.2 1
10020601 2010000 0 1 0 169.2 1
10020701 10850 0.3199 0.0 0.0 1
10020901 0 0.0 0.0 1
*
* o-active fuel-2 heat structure
*
10150000 1 5 1 0 0.0 0 1 8
10150400 -1
10150401 228.58 227.66 224.91 221.03 197.27
10150100 0 1
10150101 2 1.25e-3 1 2.03754e-3 1 2.09496e-3
10150201 3 2 1 3 5 4
10150301 1.0 2 0.0 4
10150501 0 0 0 0.169.2 1
10150601 15010000 0 1 0 169.2 1
10150701 10850 0.3136 0.0 0.0 1
10150901 0 0.0 0.0 1
*
* o-hot active fuel heat structure

```

```

*
10160000 1 5 1 0 0.0 0 1 8
10160400 -1
10160401 359.76 358.30 353.93 348.24 282.08
10160100 0 1
10160101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10160201 3 2 1 3 5 4
10160301 1.0 2 0.0 4
10160501 0 0 0 0.920 1
10160601 16010000 0 1 0 0.920 1
10160701 10850 2.705e-3 0.0 0.0 1
10160901 0 0.0 0.0 1
*
* o-hot spot 1 (local) extension fuel heat structure
*
10162000 1 5 1 0 0.0 0 1 8
10162400 -1
10162401 567.17 563.33 551.78 537.05 362.37
10162100 0 1
10162101 2 1.25e-3 1 2.00293e-3 1 2.10376e-3
10162201 3 2 1 3 5 4
10162301 1.0 2 0.0 4
10162501 0 0 0 0.000767 1
10162601 16010000 0 1 0 0.000767 1
10162701 10850 5.954e-6 0.0 0.0 1
10162901 0 0.0 0.0 0.0 1
*
* i-control plate heat structure
*
10270000 1 7 2 0 0.722571 0
10270400 -1
10270401 166.75 173.66 177.00 193.19 174.70 171.16 163.88
10270100 0 1
10270101 1 0.722628 1 0.724667 2 0.741333 1 0.743371 1 0.743428
10270201 5 1 8 2 6 4 8 5 6
10270301 0.0 2 1.0 4 0.0 6
10270501 27010000 0 1 1 2.0 1
10270601 28010000 0 1 1 2.0 1
10270701 10850 0.01028 0.0 0.0 1
10270801 0 0.0 0.0 1
10270901 0 0.0 0.0 1
*
* o-control plate heat structure
*
10280000 1 7 2 0 0.754155 0
10280400 -1
10280401 162.61 169.61 173.01 190.95 176.79 173.81 167.66
10280100 0 1
10280101 1 0.754212 1 0.75625 2 0.772917 1 0.774955 1 0.775012
10280201 5 1 8 2 6 4 8 5 6
10280301 0.0 2 1.0 4 0.0 6
10280501 28010000 0 1 1 2.0 1

```



```

* 18" pipe exiting reactor vessel
0500000 vessout singlvol
0500101 1.553 23.548 0. 0.0 90. 13.8493 1.5e-4 1.40633 0
0500200 3 .35791e+03 156.130
*
* wye on 18" line to cell 110 (d)
0510000 wye-1a branch
0510001 3 1
0510101 1.553 27.8385 0. 0. 0.17468 0.0849 1.5e-4 1.40633 0
0510200 3 .35406e+03 156.130
0511101 050010000 051000000 1.533 0.0 0.0 1000
0511201 2.2720e+03 0. 0.
0512101 051010000 052000000 0.4989 0.878 0.69 1000
0512201 7.7119e+02 0. 0.
0513101 051010000 053000000 1.533 0.0 0.086 1000
0513201 1.5008e+03 0. 0.
*
* 18" pipe between wyes to cells 110 and 111
0530000 pipe2a singlvol
0530101 1.553 5.7791 0. 0.0 0.22109 0.0223 1.5e-4 1.40633 0
0530200 3 .35581e+03 156.130
*
* wye on 18" line to cell 111 (c)
0540000 wye-2a branch
0540001 3 1
0540101 1.553 14.2448 0. 0. 0.21886 0.0544 1.5e-4 1.40633 0
0540200 3 .35535e+03 156.130
0541101 053010000 054000000 1.553 0.17 0.17 1000
0541201 1.5008e+03 0. 0.
0542101 054010000 152000000 0.9978 1.02 0.69 1000
0542201 1.5008e+03 0. 0.
0543101 054010000 055000000 1.553 0. 0. 1000
0543201 5.2562e-03 0. 0.
*
* remainder of hot-leg header and pipe to cell 112
0550000 hlend singlvol
0550101 1.553 25.5964 0. 0. .21886 0.0611 1.5e-4 1.40633 0
0550200 3 .35698e+03 157.810
*
* wye on 20" line from cell 111 (c)
0760000 wye-1b branch
0760001 2 1
0760101 1.9305 16. 0. 0. -.190327 -.05315 1.5e-4 1.56783 0
0760200 3 .49880e+03 120.050
0761101 175010000 076000000 0.9978 0.77 0.49 1000
0761201 1.4899e+03 0. 0.

0762101 077010000 076000000 0. 0. 0. 1000
0762201 -1.2737e-02 0. 0.
*
* remainder of cold-leg header and pipe from cell 112
0770000 clend singlvol
0770101 1.9305 25.4545 0. 0. -.190327 -.05315 1.5e-4 1.56783 0
0770200 3 .49992e+03 120.660
*
* wye on 20" line from cell 110 (d)
0790000 wye-2b branch
0790001 4 1
0790101 1.9305 7.3073 0. 0. -.190327 -.0242 1.5e-4 1.56783 0
0790200 3 .49734e+03 120.000
0791101 075010000 079000000 0.4989 0.72 0.60 1000
0791201 7.6574e+02 0. 0.
0792101 076010000 079000000 1.9305 0. 0. 1000
0792201 1.4898e+03 0. 0.
0793101 079010000 080000000 1.9305 0.17 0.17 1000
0793201 2.2720e+03 0. 0.
0794101 089010000 079000000 0. 0. 0.0 1101
0794201 1.6636e+01 0. 0.
*
* leakage from the system
0840000 leaktdj tmpbjun
0840101 079010000 083000000 0.
0840200 1.590 entrlvar 47
0840201 -2. 0. 0. 0.
0840202 0. 0. 0. 0.
0840203 1.e6 1.e6 0. 0.
*
* leakage time-dependent volume (sink)
0830000 leaktdv tmpdvpl
0830101 1. 10. 10. 0.0 0.0 0.0 1.5e-4 1. 10
0830200 3
0830201 0.0 25. 100.
*
* 20" pipe between the wye from cell 110 and the strainer
* this section of pipe includes the venturi meter
0800000 pipe1b pipe
0800001 4
0800101 1.9305 1 0.85836 2 1.9305 4
0800301 22.2916 1 5.34375 2 9.9375 3 3. 4
0800601 -.178377 1 -.167710 2 -.167710 3 0. 4
0800701 -.0671 1 -.01564 2 -.03787 3 0. 4
0800801 1.5e-4 1.56783 1 1.5e-4 1.04542 2 1.5e-4 1.56783 4
0800901 0.1 0.1 2 0. 0. 3
0801001 0 4

```

```

0801101 01000 3
0801201 3 .49662e+03 120.00 0. 0. 0. 1
0801202 3 .48494e+03 120.00 0. 0. 0. 2
0801203 3 .49302e+03 120.00 0. 0. 0. 3
0801204 3 .49290e+03 120.00 0. 0. 0. 4
0801300 1
0801301 2.2720e+03 0. 0. 1
0801302 2.2720e+03 0. 0. 2
0801303 2.2720e+03 0. 0. 3
*
* junction at strainer inlet: sharp 90 degree turn with a recess
*
0820000 jtostr sngljun
0820101 080010000 081000000 1.9305 2.915 2.915 31001
0820201 1 2.2720e+03 0. 0.
*
* top volume in strainer housing
* note: fluid in the strainer housing has been apportioned into top
* and bottom volumes separated by the strainer
*
0810000 strtot snglvol
0810101 1.9305 2.5 0. 0. -90. -2.5 1.5e-4 1.56783 0
0810200 3 .48822e+03 119.990
*
* bottom volume in the strainer housing
*
0900000 strtot branch
0900001 3 1
0900101 1.9305 2.91767 0. 0. -90. -2.91767 1.5e-4 1.56783 0
0900200 3 .48481e+03 119.990
*
* both the perforated plate and screen loss coefficients are
* based on total surface area of the strainer.
*
0901101 081010000 090000000 9.773 22. 22. 31000
0901201 2.2720e+03 0. 0.
0902101 090010000 091000000 1.2272 3.265 3.265 31000
0902201 1.1360e+03 0. 0.
0903101 090010000 092000000 1.2272 3.265 3.265 31000
0903201 1.1360e+03 0. 0.
*
* horizontal inlet pipes to reactor vessel
*
0910000 tore-1 snglvol
0910101 1.2272 14.3386 0. 0. 0. 0. 1.5e-4 1.25 0
0910200 3 .48133e+03 119.970
*
0920000 tore-2 snglvol
0920101 1.2272 14.3386 0. 0. 0. 0. 1.5e-4 1.25 0
0920200 3 .48133e+03 119.970
*
*****

```

```

*
*
* heat exchanger cell 110 (d)
*
*****
*
* 10" pipe from the tunnel to the 14" expansion
* initial leg of this pipe is schedule 80
*
0520000 toexd pipe
0520001 2
0520101 .5476 2
0520301 21.799 1 10.3017 2
0520601 1. 1 -.05784 2
0520701 .2429025 1 -.0104 2
0520801 1.5e-4 0.835 2
0520901 0.42 0.42 1
0521001 0 2
0521101 01000 1
0521201 3 .34975e+03 156.13 0. 0. 0. 1
0521202 3 .34727e+03 156.13 0. 0. 0. 2
0521300 1
0521301 7.7119e+02 0. 0. 1
*
0580000 j52-57 sngljun
0580101 52010000 570000000 0.5476 0.0876 0.0734 1000
0580201 1 7.7119e+02 0. 0.
*
* 14 in. inlet pipe to heat exchanger
*
0570000 ldoffd branch
0570001 1 1
0570101 .93943 3.1772 0. 0. 0. 0. 1.5e-4 1.09367 0
0570200 3 .34894e+03 156.130
0571101 057010000 113000000 0.93943 0. 0. 31100
0571201 7.7119e+02 0. 0.
*
* inlet plenum to exchanger in cell 110
*
1130000 hxdpln snglvol
1130101 4.016 1.9583 0. 0. -90. -1.9583 1.5e-4 2.3931 0
1130200 3 .34976e+03 156.130
*
* inlet to exchanger tubing in cell 110
*
0970000 hxdin sngljun
0970101 113010000 100000000 2.016 1.455 2.0 31000
0970201 1 7.7119e+02 0. 0.
*
* heat exchanger d

```

```

* pipes 100, 101, 104, and 105 are linked in series making
* up the primary flow side of the exchanger
*
1000000 prim-d1 pipe
1000001 2
1000101 2.016 2
1000301 7.4014 2
1000601 -90. 2
1000801 5.e-6 .04625 2
1001001 0 2
1001101 31000 1
1001201 3 .35068e+03 149.80 0. 0. 0. 1
1001202 3 .35283e+03 146.89 0. 0. 0. 2
1001300 1
1001301 7.7118e+02 0. 0. 1
*
1160000 pd1-d2 sngl jun
1160101 10010000 101000000 2.016 0 0 31000
1160201 1 7.7118e+02 0. 0.
*
1010000 prim-d2 pipe
1010001 2
1010101 2.016 2
1010301 7.4014 2
1010601 -90. 2
1010801 5.e-6 .04625 2
1011001 0 2
1011101 31000 1
1011201 3 .35498e+03 144.45 0. 0. 0. 1
1011202 3 .35714e+03 140.96 0. 0. 0. 2
1011300 1
1011301 7.7117e+02 0. 0. 1
*
1170000 pd2-d3 sngl jun
1170101 101010000 104000000 2.016 0 0 31000
1170201 1 7.7117e+02 0. 0.
*
1040000 prim-d3 pipe
1040001 2
1040101 2.016 2
1040301 7.4014 2
1040601 90. 2
1040801 5.e-6 .04625 2
1041001 0 2
1041101 31000 1
1041201 3 .35613e+03 136.03 0. 0. 0. 1
1041202 3 .35195e+03 129.18 0. 0. 0. 2
1041300 1
1041301 7.7116e+02 0. 0. 1
*
1180000 pd2-d3 sngl jun
1180101 104010000 105000000 2.016 0. 0. 31000
1180201 1 7.7116e+02 0. 0.
*
1050000 prim-d4 pipe
1050001 2
1050101 2.016 2
1050301 7.4014 2
1050601 90. 2
1050801 5.e-6 .04625 2
1051001 0 2
1051101 31000 1
1051201 3 .34776e+03 123.32 0. 0. 0. 1
1051202 3 .34356e+03 120.49 0. 0. 0. 2
1051300 1
1051301 7.7115e+02 0. 0. 1
*
* heat structures connecting the secondary and primary sides
* of the exchanger d (cell 110)
* right heat transfer area is 1454.37 ft**2 (135.111 m**2)
* for each heat structure
*
11002000 2 3 2 0 .023125 0 0 0
11002400 -1
11002401 142.67 140.55 138.56
11002402 143.58 142.61 141.70
11002100 0 1
11002101 2 .02604
11002201 10 2
11002301 0. 2
11002501 100010000 010000 1 1 8889.051 2
11002601 102010000 010000 1 1 8889.051 2
11002701 0 0. 0. 0. 0. 2
11002801 0 0. 0. 0. 2
11002901 0 0. 0. 0. 2
*
11012000 2 3 2 0 .023125 0 0 0
11012400 -1
11012401 141.63 140.82 140.05
11012402 136.89 135.72 134.62
11012100 0 1
11012101 2 .02604
11012201 10 2
11012301 0. 2
11012501 101010000 010000 1 1 8889.051 2
11012601 103020000 -010000 1 1 8889.051 2
11012701 0 0. 0. 0. 0. 2
11012801 0 0. 0. 0. 2
11012901 0 0. 0. 0. 2
*
11022000 2 3 2 0 .023125 0 0 0
11022400 -1
11022401 130.18 128.52 126.96

```

```

11022402 120.85 118.54 116.36
11022100 0 1
11022101 2 .02604
11022201 10 2
11022301 0. 2
11022501 104010000 010000 1 1 8889.051 2
11022601 106020000 -010000 1 1 8889.051 2
11022701 0 0 0 0 0 0 2
11022801 0 0 0 0 0 2
11022901 0 0 0 0 0 2
*
11032000 2 3 2 0 .023125 0 0 0
11032400 -1
11032401 116.01 114.02 112.15
11032402 116.92 115.96 115.06
11032100 0 1
11032201 10 2
11032301 0. 2
11032501 105010000 010000 1 1 8889.051 2
11032601 107010000 010000 1 1 8889.051 2
11032701 0 0 0 0 0 0 2
11032801 0 0 0 0 0 2
11032901 0 0 0 0 0 2
*
* outlet from tubing in exchanger in cell 110
*
09800000 hxdtpou sngljun
0980101 105010000 114000000 2.016 2.0 1.455 31000
0980201 1 7.7115e+02 0. 0.
*
* outlet plenum from exchanger in cell 110
*
1140000 hxdtpou branch
1140001 1
1140101 4.016 1.9583 0. 0. 90. 1.9583 1.5e-4 2.3931 0
1140200 3 .34072e+03 120.490
1141101 114010000 62000000 0.0233 0.5 1. 31002
1141201 5.3965e+00 0. 0.
*
* outlet from exchanger in cell 110
*
1150000 hxdtpou sngljun
1150101 114010000 060000000 0.9394 0. 0. 31100
1150201 1 7.6575e+02 0. 0.
*
* 14" pipe between the heat exchanger and the main circulating pump
*
0600000 hxdtpou in sngljun
0600101 .9394 10.353 0. 0. 90. 2.9584 1.5e-4 1.09367 0
0600200 3 .33806e+03 120.490
*
* main circulation pump d
*
0700000 d-primy pump
0700101 0.9394 1. 0. 0. 0. 0. 0
0700108 060010000 0.9394 0.28 0.28 31000
0700109 073000000 0.9394 0. 0. 1000
0700200 3 .42173e+03 120.660
0700201 1 7.6574e+02 0. 0.
0700202 1 7.6574e+02 0. 0.
0700301 0 0 -1 -1 0 0
0700302 1786. 1.04412 5000. 366.3 1361.2 468. 62.2 80. 300. 20. 50. 0.
* han
0701100 1 1 0.000 1.12 0.199 1.112 0.399 1.084
0701102 0.599 1.072 0.794 1.037 1.000 1.00
* hvn
0701200 1 2 0. -0.3 0.511 0.148 0.542 0.193 0.579 0.243
0701201 0.623 0.300 0.708 0.429 0.826 0.635 1. 1.
* had homologous data taken from bingham pump in relap
0701300 1 3 -1. 2.5 -9 2.28 -.63 2. -.55 1.74
0701301 -.5 1.68 -.42 1.6 -.15 1.4 0. 1.12
* hvd homologous data taken from bingham pump in relap
0701400 1 4 -1. 2.5 -9 2.28 -.63 2. -.55 1.74
0701401 -.5 1.68 -.42 1.6 -.15 1.4 0. 1.30
* ban
0701500 2 1 0.000 0.00 0.199 0.223 0.399 0.432
0701502 0.599 0.642 0.794 0.821 1.000 1.00
* bvn
0701600 2 2 0.511 0.290 0.542 0.353 0.579 0.417
0701601 0.623 0.479 0.708 0.603 0.826 0.768 1. 1.
* bad homologous data taken from bingham pump in relap
0701700 2 3 -1. 2.5 -.8 2. -.6 1.45 -.46 1.15
0701701 -.3 .95 -.13 .8 0. .8
* bvd homologous data taken from bingham pump in relap
0701800 2 4 -1. 2.5 -.65 2.15 -.4 1.79 -.30 1.61
0701801 -.13 1.5 0. 1.44
* multipliers
0703000 0.0 0.0 0.0 0.1 0.0 0.15 0.05 0.24 0.80
0703001 0.30 0.96 0.40 0.98 0.60 0.97 0.80 0.90
0703002 0.90 0.80 0.96 0.50 1.00 0.0
0703100 0.0 0.0 0.0 0.1 0.0 0.15 0.05 0.24 0.80
0703101 0.30 0.96 0.40 0.98 0.60 0.97 0.80 0.90
0703102 0.90 0.80 0.96 0.50 1.00 0.0
0706100 529 cntrlvar 189
0706101 0. 0.
0706102 1.e6 1.e6
*
* 10" pipe from the main circulation pump to the check valve
*
0730000 pddout branch
0730001 0 1
0730101 .5476 1.0 0. 0. 0. 0. 1.5e-4 0.835 0
0730200 3 .50416e+03 120.690

```

```

*
* check valve in the cell 110
*
0740000 d-check valve
0740101 073010000 075000000 .5476 0.65 0. 31000
0740201 1 7.6574e+02 0. 0.
0740300 chkvlv
0740301 0 0 0. 0.
*
* pipe returning from check valve in cell 110 (d) to the pipe tunnel
*
0750000 dtotun pipe
0750001 2
0750101 0.5476 2
0750301 2.29165 1 18.8961 2
0750601 0. 1 -1.5 2
0750701 0. 1 - .31357 2
0750801 1.5e-4 0.835 2
0750901 0.42 0.42 1
0751001 0 2
0751101 01000 1
0751201 3 .50184e+03 120.69 0. 0. 0. 1
0751202 3 .49982e+03 120.69 0. 0. 0. 2
0751300 1
0751301 7.6574e+02 0. 0. 1
*
*****
*
*
* h e a t e x c h a n g e r c e l l s 1 1 1 & 1 1 3
*
*****
*
* 10" pipe from the tunnel to the 14" expansion
* initial leg of this pipe is schedule 80
*
1520000 toexc pipe
1520001 2
1520101 1.0952 2
1520301 25.6277 1 10.3017 2
1520601 0.2900 1 -.05784 2
1520701 0.1662 1 -.0104 2
1520801 1.5e-4 0.835 2
1520901 0.42 0.42 1
1521001 0 2
1521101 01000 1
1521201 3 -.34872e+03 156.13 0. 0. 0. 1
1521202 3 .34627e+03 156.13 0. 0. 0. 2
1521300 1
1521301 1.5008e+03 0. 0. 1
*
*****
*
* check valve in the cell 110
*
1580000 j152-157 sngljun
1580101 152010000 157000000 1.0952 0.0876 0.0734 1000
1580201 1 1.5008e+03 0. 0.
*
* 14 in. inlet line to exchanger
*
1570000 ldoffc branch
1570001 1 1
1570101 1.87886 3.1772 0. 0. 0. 0. 1.5e-4 1.09367 0
1570200 3 -.34786e+03 156.130
1571101 157010000 213000000 1.87886 0. 0. 31100
1571201 1.5008e+03 0. 0.
*
* inlet plenum to exchanger in cell 110
*
2130000 hxcapli snglvol
2130101 8.032 1.9583 0. 0. -90. -1.9583 1.5e-4 2.3931 0
2130200 3 .34865e+03 156.130
*
* inlet to exchanger tubing in cell 111
*
1970000 hxcairn sngljun
1970101 213010000 200000000 4.032 1.455 2.0 31000
1970201 1 1.5008e+03 0. 0.
*
* heat exchangers c and a
*
* pipes 200, 201, 204, and 205 are linked in series making
* up the primary flow side of the exchangers a and c
*
2000000 prim-ca1 pipe
2000001 2
2000101 4.032 2
2000301 7.4014 2
2000601 -90. 2
2000801 5.e-6 .04625 2
2001001 0 2
2001101 31000 1
2001201 3 .34962e+03 149.60 0. 0. 0. 1
2001202 3 .35183e+03 146.60 0. 0. 0. 2
2001300 1
2001301 1.5008e+03 0. 0. 1
*
2160000 pc1-ca2 sngljun
2160101 200010000 201000000 4.032 0. 0. 31000
2160201 1 1.5008e+03 0. 0.
*
2010000 prim-ca2 pipe
2010001 2
2010101 4.032 2
2010301 7.4014 2

```

```

2010601 -90. 2
2010801 5.e-6 .04625 2
2011001 0 2
2011101 31000 1
2011201 3 .35403e+03 144.07 0. 0. 0. 1
2011202 3 .35623e+03 140.49 0. 0. 0. 2
2011300 1
2011301 1.5008e+03 0. 0. 1
*
2170000 pc2-ca3 sngl jun
2170101 201010000 204000000 4.032 0. 0. 31000
2170201 1 1.5007e+03 0. 0.
*
2040000 prim-ca3 pipe
2040001 2
2040101 4.032 2
2040301 7.4014 2
2040601 90. 2
2040801 5.e-6 .04625 2
2041001 0 2
2041101 31000 1
2041201 3 .35527e+03 135.48 0. 0. 0. 1
2041202 3 .35114e+03 128.58 0. 0. 0. 2
2041300 1
2041301 1.5007e+03 0. 0. 1
*
2180000 cd2-ca3 sngl jun
2180101 204010000 205000000 4.032 0. 0. 31000
2180201 1 1.5007e+03 0. 0.
*
2050000 prim-ca4 pipe
2050001 2
2050101 4.032 2
2050301 7.4014 2
2050601 90. 2
2050801 5.e-6 .04625 2
2051001 0 2
2051101 31000 1
2051201 3 .34700e+03 122.69 0. 0. 0. 1
2051202 3 .34285e+03 119.84 0. 0. 0. 2
2051300 1
2051301 1.5007e+03 0. 0. 1
*
* heat structures connecting the secondary and primary sides
* of exchangers c (cell 111) and a (cell 113)
* total right heat transfer area is 8900.000 ft**2 per heat structure
*
12002000 2 3 2 0 .023125 0 0 0
12002400 -1
12002401 142.28 140.15 138.15
12002402 143.20 142.22 141.30
12002100 0 1

12002101 2 .02604
12002201 10 2
12002301 0. 2
12002501 200010000 010000 1 1 17778.102 2
12002601 202010000 010000 1 1 17778.102 2
12002701 0 0. 0. 0. 0. 2
12002801 0 0. 0. 0. 2
12002901 0 0. 0. 0. 2
*
12012000 2 3 2 0 .023125 0 0 0
12012400 -1
12012401 141.17 140.35 139.57
12012402 136.34 135.17 134.07
12012100 0 1
12012101 2 .02604
12012201 10 2
12012301 0. 2
12012501 201010000 010000 1 1 17778.102 2
12012601 203020000 -010000 1 1 17778.102 2
12012701 0 0. 0. 0. 0. 2
12012801 0 0. 0. 0. 2
12012901 0 0. 0. 0. 2
*
12022000 2 3 2 0 .023125 0 0 0
12022400 -1
12022401 129.55 127.92 126.37
12022402 120.20 117.93 115.80
12022100 0 1
12022101 2 .02604
12022201 10 2
12022301 0. 2
12022501 204010000 010000 1 1 17778.102 2
12022601 206020000 -010000 1 1 17778.102 2
12022701 0 0. 0. 0. 0. 2
12022801 0 0. 0. 0. 2
12022901 0 0. 0. 0. 2
*
12032000 2 3 2 0 .023125 0 0 0
12032400 -1
12032401 115.35 113.41 111.58
12032402 116.25 115.32 114.43
12032100 0 1
12032101 2 .02604
12032201 10 2
12032301 0. 2
12032501 205010000 010000 1 1 17778.102 2
12032601 207010000 010000 1 1 17778.102 2
12032701 0 0. 0. 0. 0. 2
12032801 0 0. 0. 0. 2
12032901 0 0. 0. 0. 2
*
* outlet from heat exchanger in cell 111

```

```

* 1980000 hxcout sngljun
1980101 205010000 214000000 4.032 2.00 1.455 31000
1980201 1 1.5007e+03 0. 0.
*
* * outlet plenum from exchanger in cell 111
*
2140000 hxcplou branch
2140001 1 1
2140101 8.032 1.9583 0. 0. 90. 1.9583 1.5e-4 2.3931 0
2140200 3 .34005e+03 119.840
2141101 214010000 162000000 0.0466 0.5 1. 31002
2141201 1.0805e+01 0. 0.
*
* * outlet from exchanger in cell 111
*
2150000 hxcou sngljun
2150101 214010000 160000000 1.87886 0. 0. 31100
2150201 1 1.4899e+03 0. 0.
*
* * 14" pipe between the heat exchanger and the main circulating pump
*
1600000 catomp snglvol
1600101 1.87886 10.353 0. 0. 90. 2.9584 1.5e-4 1.09367 0
1600200 3 .33748e+03 119.840
*
* * main circulation pumps c and a
*
1700000 ca-primy pump
1700101 1.87886 1. 0. 0. 0. 0.
1700108 160010000 1.87886 .28 .28 31000
1700109 173000000 1.87886 0. 0. 1000
1700200 3 .42171e+03 120.010
1700201 1 1.4899e+03 0. 0.
1700202 1 1.4899e+03 0. 0.
1700301 70 70 -1 0 0 0
1700302 1786. 1.04412 10000. 366.3 2722.4 936. 62.2 160. 600. 40. 100.
0.
1706100 529 cntrlvar 191
1706101 0. 0.
1706102 1.e6 1.e6
*
* * 10" pipe from the main circulation pump to the check valve
*
1730000 pucacout snglvol
1730101 1.0952 1. 0. 0. 0. 0. 1.5e-4 0.835 0
1730200 3 .50480e+03 120.040
*
* * check valve in the cell 111
*
1740000 c-check valve
1740101 173010000 175000000 1.0952 0.65 0. 31000
1740201 1 1.4899e+03 0. 0.
1740300 chkvlv
1740301 0 0 0. 0.
*
* * pipe returning from cells a and c to the pipe tunnel
*
1750000 catotun pipe
1750001 2
1750101 1.0952 2
1750301 2.29165 1 25.0267 2
1750601 0. 1 -0.5204 2
1750701 0. 1 -.26047 2
1750801 1.5e-4 0.835 2
1750901 0.4682 0.3865 1
1751001 0 2
1751101 01000 1
1751201 3 .50260e+03 120.04 0. 0. 0. 1
1751202 3 .50035e+03 120.05 0. 0. 0. 2
1751300 1
1751301 1.4899e+03 0. 0. 1
*
*****
*
* * low pressure clean-up
*
*****
*
* * let-down line off of exchanger in cell 110
*
0620000 ldline-d pipe
0620001 2
0620101 0.0233 2
0620301 15.0 2
0620601 0. 2
0620701 0. 2
0620801 1.5e-4 0.17225 2
0620901 18.0 18.0 1
0621001 0 2
0621101 01000 1
0621201 3 .34099e+03 120.49 0. 0. 0. 1
0621202 3 .33995e+03 120.49 0. 0. 0. 2
0621300 1
0621301 5.3942e+00 0. 0. 1
*
* * let-down valve, 40 gpm nominal clean-up flow
* * taken from heat exchanger d (cell 110)
*
0630000 ld-servo valve
0630101 062010000 064000000 0.0233 0. 0. 31000

```

```

0630201 1 5.3881e+00 0. 0.
0630300 srvtlv
0630301 42 13
0630400 1. 8.7
0630401 0. 0.
0630402 0.10 0.001 0.001
0630403 0.15 0.003375 0.003375
0630404 0.20 0.008 0.008
0630405 0.25 0.015625 0.015625
0630406 0.30 0.027 0.027
0630407 0.35 0.042875 0.042875
0630408 0.40 0.064 0.064
0630409 0.45 0.091125 0.091125
0630410 0.50 0.125 0.125
0630411 0.55 0.166375 0.166375
0630412 0.60 0.216 0.216
0630413 0.65 0.274625 0.274625
0630414 0.70 0.343 0.343
0630415 0.75 0.421875 0.421875
0630416 0.78 0.474552 0.474552
0630417 0.80 0.512 0.512
0630418 0.82 0.551368 0.551368
0630419 0.84 0.592704 0.592704
0630420 0.86 0.636056 0.636056
0630421 0.88 0.681472 0.681472
0630422 0.90 0.729 0.729
0630423 0.92 0.778688 0.778688
0630424 0.94 0.830584 0.830584
0630425 0.96 0.884736 0.884736
0630426 0.98 0.941192 0.941192
0630427 1.00 1.000 1.000
*
* let-down line off of exchanger in cells 111 and 113
*
1620000 ldline-c pipe
1620001 2
1620101 0.0466 2
1620301 15.0 2
1620601 0. 2
1620701 0. 2
1620801 1.5e-4 0.17225 2
1620901 18.0 18.0 1
1621001 0 2
1621101 01000 1
1621201 3 .34026e+03 119.84 0. 0. 0. 1
1621202 3 .33910e+03 119.84 0. 0. 0. 2
1621300 1
1621301 1.0801e+01 0. 0. 1
*
* let-down valve, 40 gpm nominal clean-up flow
* taken from heat exchangers a and c
*
1630000 ld-servo valve
1630101 162010000 064000000 .0466 0. 0. 31000
1630201 1 1.0779e+01 0. 0.
1630300 srvtlv
1630301 42 13
1630400 1. 17.4
1630401 0. 0.
1630402 0.10 0.001 0.001
1630403 0.15 0.003375 0.003375
1630404 0.20 0.008 0.008
1630405 0.25 0.015625 0.015625
1630406 0.30 0.027 0.027
1630407 0.35 0.042875 0.042875
1630408 0.40 0.064 0.064
1630409 0.45 0.091125 0.091125
1630410 0.50 0.125 0.125
1630411 0.55 0.166375 0.166375
1630412 0.60 0.216 0.216
1630413 0.65 0.274625 0.274625
1630414 0.70 0.343 0.343
1630415 0.75 0.421875 0.421875
1630416 0.78 0.474552 0.474552
1630417 0.80 0.512 0.512
1630418 0.82 0.551368 0.551368
1630419 0.84 0.592704 0.592704
1630420 0.86 0.636056 0.636056
1630421 0.88 0.681472 0.681472
1630422 0.90 0.729 0.729
1630423 0.92 0.778688 0.778688
1630424 0.94 0.830584 0.830584
1630425 0.96 0.884736 0.884736
1630426 0.98 0.941192 0.941192
1630427 1.00 1.000 1.000
*
* collection of let-down valve flows
*
0640000 outflow branch
0640001 1 1
0640101 0.0233 10. 0. 0. 0. 1.5e-4 0.17225 0
0640200 3 .18750e+02 119.920
0641101 064010000 065000000 0.0233 0. 0. 31000
0641201 1.6181e+01 0. 0.
*
* sink for fluid exiting the high pressure primary system
* through the let-down valves
*
0650000 clean-up tmpdvol
0650101 1. 1. 0. 0. 0. 1.d-6 1. 10
0650200 3 0
0650201 0.00 20.0 120. 1.e6 20.0 120.
*
* intake to pressurizer pumps

```


* from the primary coolant head tank

0680000 pcheado tankvol
0680101 1. 1. 0. 0. 0. 1.d-6 1. 10
0680200 3 0 cntrlvtr 6

* table of level vs. ppr suction pressure

0680201	.00	19.6041994	80.	.34	19.7511205	80.	.54	19.8309556	80.
0680202	.72	19.9135702	80.	.87	19.9809366	80.	1.02	20.0435262	80.
0680203	1.15	20.1026618	80.	1.28	20.1591559	80.	1.41	20.2135575	80.
0680204	1.53	20.2662521	80.	1.65	20.3175343	80.	1.77	20.3676250	80.
0680205	1.88	20.4167063	80.	1.99	20.4649227	80.	2.10	20.5123961	80.
0680206	2.21	20.5592295	80.	2.32	20.6055127	80.	2.42	20.6513246	80.
0680207	2.53	20.6967323	80.	2.63	20.7418012	80.	2.74	20.7865863	80.
0680208	2.84	20.8311411	80.	2.94	20.8755151	80.	3.05	20.9197567	80.
0680209	3.15	20.9639099	80.	3.25	21.0080189	80.	3.35	21.0521279	80.
0680210	3.45	21.0962811	80.	3.56	21.1405226	80.	3.66	21.1848967	80.
0680211	3.76	21.2294515	80.	3.87	21.2742366	80.	3.97	21.3193055	80.
0680212	4.08	21.3647131	80.	4.18	21.4105251	80.	4.29	21.4568082	80.
0680213	4.40	21.5036417	80.	4.51	21.5511150	80.	4.62	21.5993314	80.
0680214	4.73	21.6484127	80.	4.85	21.6985034	80.	4.97	21.7497856	80.
0680215	5.09	21.8024803	80.	5.22	21.8568818	80.	5.35	21.9133760	80.
0680216	5.48	21.9725115	80.	5.63	22.0351011	80.	5.78	22.1024675	80.
0680217	5.96	22.1770821	80.	6.16	22.2649172	80.	6.50	22.4117527	80.

* tap on pc head tank which distributes flow to the three

* pressurizer pumps

0720000 outflow branch

0720001	1 1
0720101	0.08840 70. 0. 0. 0. 0. 1.5e-4 0.3355 0
0720200	3 .21450e+02 80.001
0721101	0.680000000 072000000 0.08840 0. 0. 31000
0721201	1.6637e+01 0. 0.

* 0470000 ppr-suct branch

0470001	1 1
0470101	0.08840 2.21 0. 0. 0. 0. 1.5e-4 0.3355 0
0470200	3 .20697e+02 80.001

* include losses due to elbows, wyes, valves and tee

0471101	072010000 047000000 0.08840 9.6 9.6 31000
0471201	1.6637e+01 0. 0.

* main pressurizer pump

0660000	ppr-1 pump
0660100	615
0660101	1. 1.413 0. 0. 0. 0. 0
0660108	047010000 0.8840 0. 0. 31000
0660109	048000000 0.8840 0. 0. 31000
0660200	3 .26618e+03 83.700
0660201	1 1.6637e+01 0. 0.
0660202	1 1.6637e+01 0. 0.

0660301 69 -1 -3 -1 0 614 0

0660302 2616. .08375 200. 1376.906 139.751 120. 0. 0. 247.66 0. 0. 0.

* speed table trip

0666100 615

0666101 0. 2311.9

* single volume to connect main ppr pump to check valve

0480000 main-chk anglvol

0480101 0.05135 5. 0. 0. 0. 0. 1.5e-4 0.2557 0

0480200 3 .51136e+03 83.766

* check valve for main ppr pump

0490000 ma-check valve

0490101 048010000 067000000 .05135 5.4 5.4 31000

0490201 1 1.6637e+01 0. 0.

0490300 chkvlv

0490301 0 0 0. 0.

* standby pressurizer pump

0690000 ppr-2 pump

0690101	0.08840 1. 0. 0. 0. 0
0690108	047010000 0.8840 0. 0. 31000
0690109	059000000 0.8840 0. 0. 31000
0690200	3 .20760e+02 135.850
0690201	1 7.5605e-06 0. 0.
0690202	1 5.5263e-06 0. 0.
0690301	0 -1 -3 -1 0 614 0
0690302	2616. .00000 200. 1376.909 139.75 120. 0. 0. 247.66 0. 0. 0.

* hwn

0691100	1 1 .000 1.078 .040 1.079 .080 1.080
0691101	.120 1.081 .160 1.082 .200 1.082
0691102	.240 1.082 .280 1.082 .320 1.081
0691103	.360 1.080 .400 1.078 .440 1.076
0691104	.480 1.074 .520 1.071 .560 1.068
0691105	.600 1.064 .640 1.060 .680 1.056
0691106	.720 1.050 .760 1.045 .800 1.039
0691107	.840 1.032 .880 1.025 .920 1.017
0691108	.960 1.009 1.000 1.000

* hvn

0691200	1 2 .368 -.012 .373 -.006 .379 .000
0691201	.385 .006 .391 .013 .397 .020
0691202	.403 .027 .410 .034 .417 .041
0691203	.424 .049 .431 .058 .439 .066
0691204	.446 .075 .455 .085 .463 .095
0691205	.472 .105 .481 .116 .490 .128
0691206	.500 .140 .510 .152 .521 .166
0691207	.532 .180 .543 .195 .556 .211
0691208	.568 .228 .581 .247 .595 .266
0691209	.610 .287 .625 .309 .641 .333

```

0691210 .658 .358 .676 .386 .694 .415
0691211 .714 .448 .735 .483 .758 .521
0691212 .781 .562 .806 .608 .833 .657
0691213 .862 .712 .893 .773 .923 .841
0691214 .962 .916 1.000 1.000
* had homologous data taken from bingham pump in relap
0691300 1 3 -1. 2.5 -9 2.28 -.63 2. -.55 1.74
0691301 -.5 1.68 -.42 1.6 -.15 1.4 0. 1.078
* hvd homologous data taken from bingham pump in relap
0691400 1 4 -1. 2.5 -9 2.28 -.63 2. -.55 1.74
0691401 -.5 1.68 -.42 1.6 -.15 1.4 0. 1.30
* ban
0691500 2 1 .000 -.001 .040 .041 .080 .085
0691501 .120 .128 .160 .171 .200 .215
0691502 .240 .259 .280 .302 .320 .346
0691503 .360 .389 .400 .432 .440 .475
0691504 .480 .517 .520 .559 .560 .600
0691505 .600 .641 .640 .681 .680 .721
0691506 .720 .759 .760 .797 .800 .833
0691507 .840 .869 .880 .904 .920 .937
0691508 .960 .969 1.000 1.000
* bvn
0691600 2 2 .368 .009 .373 .023 .379 .036
0691601 .385 .050 .391 .064 .397 .078
0691602 .403 .092 .410 .106 .417 .121
0691603 .424 .136 .431 .151 .439 .166
0691604 .446 .182 .455 .198 .463 .215
0691605 .472 .231 .481 .248 .490 .266
0691606 .500 .284 .510 .302 .521 .321
0691607 .532 .340 .543 .359 .556 .380
0691608 .568 .401 .581 .422 .595 .444
0691609 .610 .467 .625 .491 .641 .515
0691610 .658 .540 .676 .567 .694 .594
0691611 .714 .623 .735 .652 .758 .683
0691612 .781 .716 .806 .750 .833 .786
0691613 .862 .824 .893 .864 .926 .907
0691614 .962 .952 1.000 1.000
* bad homologous data taken from bingham pump in relap
0691700 2 3 -1. 2.5 -.8 2. -.6 1.45 -.46 1.15
0691701 -.3 .95 -.13 .8 0. .8
* bvd homologous data taken from bingham pump in relap
0691800 2 4 -1. 2.5 -.65 2.15 -.4 1.79 -.30 1.61
0691801 -.13 1.5 0. 1.44
* speed table trip
0696100 615 cntrlvar 12
0696101 0. 0. 1.e6 1.e6
*
* single volume to connect standby pump to check valve
0590000 stby-chk snglvol
0590101 0.05135 5. 0. 0. 0. 0. 1.5e-4 0.2557 0
0590200 3 .20760e+02 139.990

```

```

*
* check valve for standby pump
*
0560000 sb-check valve
0560101 059010000 067000000 .05135 5.4 5.4 31000
0560201 1 0.0000e+00 0. 0.
0560300 chkvlv
0560301 0 1 0. 0.
*
* auxiliary pressurizer pump
*
0710000 auxpmp tndpjun
0710101 047010000 067000000 0.
0710200 1 623 cntrlvar 25
0710201 -2. 0. 0. 0.
0710202 0. 0. 0. 0.
0710203 1.e6 1.e6 0. 0.
*
* return line from the clean-up system
*
0670000 clrtm1 pipe
0670001 3
0670101 0.05135 5
0670301 28.0 5
0670601 90. 5
0670701 2.2 5
0670801 1.5e-4 .2557 5
0670901 6.58 6.58 4
0671001 0 5
0671101 01000 4
0671201 3 .50918e+03 83.77 0. 0. 0. 1
0671202 3 .50683e+03 83.77 0. 0. 0. 2
0671203 3 .50421e+03 83.77 0. 0. 0. 3
0671204 3 .50160e+03 83.77 0. 0. 0. 4
0671205 3 .49898e+03 83.77 0. 0. 0. 5
0671300 1
0671301 1.6637e+01 0. 0. 1
0671302 1.6637e+01 0. 0. 2
0671303 1.6636e+01 0. 0. 3
0671304 1.6636e+01 0. 0. 4
*
* check valve for pressurizer line
*
0880000 pzzr-chk valve
0880101 067010000 089000000 .05135 5.4 5.4 31000
0880201 1 1.6636e+01 0. 0.
0880300 chkvlv
0880301 0 0 0. 0.
*
* pressurizer injection volume
*
0890000 pzzr-inj snglvol

```

```

0890101 0.05135 8.0 0. 0. 0. 0. 1.5e-4 0.2557 0
0890200 3 .49723e+03 83.770
*
*****
*
*
* secondary flow system
*
*
*
*****
*
* secondary side pressure control
*
1230000 sec-pres tmdpvol
1230101 1. 1. 0. 0. 0. 0. 1.d-6 1. 10
1230200 3 0 tempf 108010000
1230201 40.00 14.7 40.00
1230202 100. 14.7 100.
1230203 1000. 14.7 1000.
*
* cooling tower water basins (400,000 gal) - 53,480 ft**3
*
1080000 sec-in1 branch
1080001 2 1
1080101 106.96 500. 0 0 0 1.5e-4 0.29 0
1080200 3 .14699e+02 85.000
1081101 123000000 108000000 1. 0. 0. 1000
1081201 -3.3314e-04 0. 0.
1082101 132010000 108000000 13.0045 0. 0. 1000
1082201 2.5918e+03 0. 0.
*
* auxiliary secondary pump (pu-14)
*
1240000 pu-14 pump
1240101 1. 3. 0. 0. 0. 0. 0. 0
1240108 108010000 0. 0. 0. 1000
1240109 133000000 0. 0. 0. 1000
1240200 3 .14700e+02 85.000
1240201 1 8.8895e-14 0. 0.
1240202 1 6.8373e-14 0. 0.
1240301 -1 -1 -3 -1 0 0 0
1240302 1200. .00000 6000. 100.0 508. 200. 62.2 80. 300. 20. 50. 0.
1246100 0 cntrlvar 64
1246101 0. 0.
1246102 5000. 5000.
*
* single volume to connect pu-14 to check valve
*
1330000 pu14-vol snglvol
1330101 1. 10. 0. 0. 0. 0. 1.5e-4 1.596 0
1330200 3 .14700e+02 85.000
*****
*
* check valve for pu-14
*
1340000 pu14-chk valve
1340101 133010000 119000000 0. 0. 0. 31000
1340201 1 0.0000e+00 0. 0.
1340300 chkvlv
1340301 0 1 0. 0.
*
* secondary coolant pump pu-6a
*
1250000 pu-6a pump
1250101 1. 3. 0. 0. 0. 0. 0. 0
1250108 108010000 0. 0. 0. 1000
1250109 126000000 0. 0. 0. 1000
1250200 3 .41656e+02 85.050
1250201 1 1.2959e+03 0. 0.
1250202 1 1.2959e+03 0. 0.
1250301 -1 -1 -3 -1 0 651 0
1250302 1160. 1.00000 13000. 120.0 1528. 468. 62.2 0. 300. 20. 50. 0.
1256100 652
1256101 0. 1160.
1256102 1.e6 1160.
*
* single volume to connect pumps to check valve
*
1260000 pu6a-vol snglvol
1260101 1. 10. 0. 0. 0. 0. 1.5e-4 1.596 0
1260200 3 .71417e+02 85.059
*
* check valve for pu-6a
*
1270000 pu6a-chk valve
1270101 126010000 119000000 0. 0. 0. 31000
1270201 1 1.2959e+03 0. 0.
1270300 chkvlv
1270301 0 0 0. 0.
*
* secondary coolant pump 6b
*
1250000 pu-6b pump
1250101 1. 3. 0. 0. 0. 0. 0. 0
1250108 108010000 0. 0. 0. 0
1250109 226000000 0. 0. 0. 0
1250200 3 .41656e+02 85.050
1250201 1 1.2959e+03 0. 0.
1250202 1 1.2959e+03 0. 0.
1250301 -1 -1 -3 -1 0 649 0
1250302 1160. 1.00000 13000. 120.0 1528. 468. 62.2 0. 300. 20. 50. 0.
1256100 650
1256101 0. 1160.
1256102 1.e6 1160.

```

* single volume to connect pumps to check valve
 *
 2260000 pubb-vol snglv
 2260101 1. 10. 0. 0. 0. 1.5e-4 1.596 0
 2260200 3 .71417e+02 85.059
 *
 * check valve for pu-6b
 *
 2270000 pubb-chk valve
 2270101 226010000 119000000 0. 0. 0. 31000
 2270201 1 1.2959e+03 0. 0.
 2270300 chkv
 2270301 0 0. 0.
 *
 * manually-set control valve in 36" pipe
 *
 1110000 cv377 valve
 1110101 119010000 211000000 6.07 0. 0. 1100
 1110201 1 1.4236e+03 0. 0.
 1110300 srwlv
 1110301 73
 *
 1190000 sec-ini branch
 1190001 1 1
 1190101 9.19 200.0 0 0 0 1.5e-4 3.42 0
 1190200 3 .74040e+02 85.060
 1192101 119010000 138000000 0. 0. 0. 1100
 1192201 1.0017e+03 0. 0.
 *
 * servo valve for secondary coolant control
 *
 1100000 cv377a valve
 1100101 119010000 211000000 0.5454 0. 0. 1100
 1100201 1 1.6649e+02 0. 0.
 1100300 srwlv
 1100301 57
 *
 2110000 sec-in2 branch
 2110001 2 1
 2110101 7.0685 200.0 0 0 0 1.5e-4 3.0 0
 2110200 3 .51748e+02 85.054
 2111101 211010000 109000000 1.9306 0. 0. 1100
 2111201 5.3012e+02 0. 0.
 2112101 211010000 209000000 3.8612 0. 0. 1100
 2112201 1.0600e+03 0. 0.
 *
 * servo valve for heat exchanger bypass
 *
 2280000 hxbypass valve
 2280101 138010000 137000000 0.7854 6.00 6.00 1100
 2280201 1 9.7577e+02 0. 0.

2280300 srwlv
 2280301 66
 *
 * secondary bypass to auxiliaries in water wing and tru
 *
 1310000 sec-byps branch
 1310001 1 1
 1310101 0.0785 500. 0. 0. 0. 0. 1.5e-4 0.10 0
 1310200 3 .58324e+02 85.144
 1311101 131010000 137000000 0.0785 5. 5. 1100
 1311201 2.5933e+01 0. 0.
 *
 * secondary side piping: heat exchanger d
 * note: two parallel paths of piping make up the secondary side
 *
 * the upper path consists of pipes 107 and 102 in series
 *
 1070000 sec-d1 pipe
 1070001 2
 1070101 1.373 2
 1070301 0. 2
 1070401 13.526 2
 1070601 90. 2
 1070701 7.4014 2
 1070801 1.5e-4 0.0157 2
 1070901 0.000 0.000 1
 1071001 0 2
 1071101 01000 1
 1071201 3 .49131e+02 102.17 0. 0. 0. 1
 1071202 3 .43995e+02 110.43 0. 0. 0. 2
 1071300 1
 1071301 2.6418e+02 0. 0. 1
 *
 1200000 sdi-d2 snglv
 1200101 107010000 102000000 1.373 0.000 0.000 1000
 1200201 1 2.6418e+02 0. 0.
 *
 1020000 sec-d1 pipe
 1020001 2
 1020101 1.373 2
 1020301 0. 2
 1020401 13.526 2
 1020601 -90. 2
 1020701 -7.4014 2
 1020801 1.5e-4 0.0157 2
 1020901 0.000 0.000 1
 1021001 0 2
 1021101 01000 1
 1021201 3 .42061e+02 128.95 0. 0. 0. 1
 1021202 3 .43314e+02 137.44 0. 0. 0. 2
 1021300 1
 1021301 2.6418e+02 0. 0. 1

```

*
* the lower path consists of pipes 106 and 103 in series
*
1060000 sec-d3 pipe
1060001 2
1060101 1.373 2
1060301 0. 2
1060401 13.526 2
1060601 -90. 2
1060701 -7.4014 2
1060801 1.5e-4 0.0157 2
1060901 0.000 0.000 1
1061001 0 2
1061101 01000 1
1061201 3 .52306e+02 104.91 0. 0. 0. 1
1061202 3 .53520e+02 119.22 0. 0. 0. 2
1061300 1
1061301 2.6594e+02 0. 0. 1
*
1210000 sd3-d4 sngljun
1210101 106010000 103000000 1.373 0.000 0.000 1000
1210201 1 2.6594e+02 0. 0.
*
1030000 sec-d4 pipe
1030001 2
1030101 1.373 2
1030301 0. 2
1030401 13.526 2
1030601 90. 2
1030701 7.4014 2
1030801 1.5e-4 0.0157 2
1030901 0.000 0.000 1
1031001 0 2
1031101 01000 1
1031201 3 .51579e+02 129.36 0. 0. 0. 1
1031202 3 .46483e+02 136.47 0. 0. 0. 2
1031300 1
1031301 2.6594e+02 0. 0. 1
*
* inlet volume to the secondary side
*
1090000 sdinbr branch
1090001 2 1
1090101 1.9306 20. 0 0 0 1.5e-4 1.5678 0
1090200 3 .51642e+02 85.054
1091101 109010000 107000000 1.9306 0. 0. 1000
1091201 2.6418e+02 0. 0.
1092101 109010000 106000000 1.9306 0. 0. 1000
1092201 2.6594e+02 0. 0.
*
* outlet volume from the secondary side
*
1120000 sdoubr branch
1120001 2 1
1120101 1.9306 20. 0 0 0 1.5e-4 1.5678 0
1120200 3 .43866e+02 136.950
1121101 103010000 112000000 1.9306 0. 0. 1000
1121201 2.6594e+02 0. 0.
1122101 102010000 112000000 1.9306 0. 0. 1000
1122201 2.6418e+02 0. 0.
*
* secondary side piping: heat exchangers a and c
* note: two parallel paths of piping make up the secondary side
*
* the upper path consists of pipes 207 and 202 in series
*
2070000 sec-c1 pipe
2070001 2
2070101 2.746 2
2070301 0. 2
2070401 27.052 2
2070601 90. 2
2070701 7.4014 2
2070801 1.5e-4 .0157 2
2070901 0.000 0.000 1
2071001 0 2
2071101 01000 1
2071201 3 .49131e+02 101.80 0. 0. 0. 1
2071202 3 .43994e+02 109.88 0. 0. 0. 2
2071300 1
2071301 5.2825e+02 0. 0. 1
*
2200000 sc1-c2 sngljun
2200101 207010000 202000000 2.746 0.000 0.000 1000
2200201 1 5.2825e+02 0. 0.
*
2020000 sec-c1 pipe
2020001 2
2020101 2.746 2
2020301 0. 2
2020401 27.052 2
2020601 -90. 2
2020701 -7.4014 2
2020801 1.5e-4 .0157 2
2020901 0.000 0.000 1
2021001 0 2
2021101 01000 1
2021201 3 .42060e+02 128.48 0. 0. 0. 1
2021202 3 .43313e+02 137.02 0. 0. 0. 2
2021300 1
2021301 5.2825e+02 0. 0. 1
*
* the lower path consists of pipes 206 and 203 in series
*

```

```

2060000 sec-c3 pipe
2060001 2
2060101 2.746 2
2060301 0. 2
2060401 27.052 2
2060601 -90. 2
2060701 -7.4014 2
2060801 1.5e-4 .0157 2
2060901 0.000 0.000 1
2061001 0 2
2061101 01000 1
2061201 3 .52306e+02 104.54 0. 0. 0. 1
2061202 3 .53520e+02 118.70 0. 0. 0. 2
2061300 1
2061301 5.3175e+02 0. 0. 1
*
2210000 sc3-c4 sngl jun
2210101 206010000 203000000 2.746 0.000 0.000 1000
2210201 1 5.3175e+02 0. 0.
*
2030000 sec-c4 pipe
2030001 2
2030101 2.746 2
2030301 0. 2
2030401 27.052 2
2030601 90. 2
2030701 7.4014 2
2030801 1.5e-4 .0157 2
2030901 0.000 0.000 1
2031001 0 2
2031101 01000 1
2031201 3 .51579e+02 128.81 0. 0. 0. 1
2031202 3 .46484e+02 135.97 0. 0. 0. 2
2031300 1
2031301 5.3175e+02 0. 0. 1
*
* inlet volume to the secondary side
*
2090000 scinbr branch
2090001 2 1
2090101 3.8612 20. 0 0 0 1.5e-4 1.5678 0
2090200 3 .51642e+02 85.054
2091101 209010000 207000000 3.8612 0. 0. 1000
2091201 5.2825e+02 0. 0.
2092101 209010000 206000000 3.8612 0. 0. 1000
2092201 5.3175e+02 0. 0.
*
* outlet volume to the secondary side
*
2120000 scoubr branch
2120001 2 1
2120101 3.8612 20. 0 0 0 1.5e-4 1.5678 0

```

```

2120200 3 .43866e+02 136.490
2121101 203010000 212000000 3.8612 0. 0. 1000
2121201 5.3175e+02 0. 0.
2122101 202010000 212000000 3.8612 0. 0. 1000
2122201 5.2825e+02 0. 0.
*
* heat exchanger manifold
*
2100000 sec-ou branch
2100001 3 1
2100101 7.0685 200.0 0 0 0 1.5e-4 3.0 0
2100200 3 .43850e+02 136.640
2101101 112010000 210000000 1.9306 0. 0. 1100
2101201 5.3012e+02 0. 0.
2102101 212010000 210000000 3.8612 0. 0. 1100
2102201 1.0600e+03 0. 0.
2103101 210010000 137000000 1 .306 0. 0. 1000
2103201 1.5901e+03 0. 0.
*
1380000 tru-in branch
1380001 1 1
1380101 1.553 300.0 0 0 0 1.5e-4 1.40633 0
1380200 3 .72025e+02 85.046
1381101 138010000 131000000 0.0 0. 0. 1100
1381201 2.5933e+01 0. 0.
*
1370000 sec-toct sngl vol
1370101 9.19 200.0 0 0 0 1.5e-4 3.42 0
1370200 3 .43724e+02 116.720
*
* servo valve to cooling tower
*
1350000 sec-inj valve
1350101 137010000 132000000 1. 0. 0. 1100
1350201 1 2.5918e+03 0. 0.
1350300 srwlv
1350301 294
*
* servo valve to cooling tower bypass
*
1360000 sec-inj valve
1360101 137010000 108000000 1. 30. 30. 1100
1360201 1 0.0000e+00 0. 0.
1360300 srwlv
1360301 295
*
1320000 cooltrw pipe
1320001 5
1320101 13.0045 5
1320301 50. 5
1320601 0. 5
1320701 0. 5

```

```

1320801 1.5e-4 0.29 5
1320901 0. 0. 4
1321001 0 5
1321101 01000 4
1321201 3 .15934e+02 103.79 0. 0. 0. 1
1321202 3 .15654e+02 95.61 0. 0. 0. 2
1321203 3 .15372e+02 90.42 0. 0. 0. 3
1321204 3 .15083e+02 87.11 0. 0. 0. 4
1321205 3 .14803e+02 85.00 0. 0. 0. 5
1321300 1
1321301 2.5918e+03 0. 0. 1
1321302 2.5918e+03 0. 0. 2
1321303 2.5918e+03 0. 0. 3
1321304 2.5918e+03 0. 0. 4
*
* heat removal from secondary side:
* total left heat transfer area = 53,491.90 ft**2 (4969.397 m**2)
*
10132000 5 3 2 0 0.1 0 0 0
10132400 -1
10132401 89.00 83.70 78.64
10132402 85.87 82.51 79.31
10132403 84.06 81.92 79.89
10132404 82.98 81.62 80.32
10132405 82.33 81.46 80.63
10132100 0 1
10132101 2 0.11
10132201 10 2
10132301 0. 2
10132501 132010000 010000 1 1 20000. 5
10132601 403010000 010000 1 1 20000. 5
10132701 0 0. 0 0.0 0.0 5
10132801 0 0. 0. 5
10132901 0 0. 0. 5
*
* cooling tower stream
*
40100000 ctsource tmdpvol
4010101 1. 1. 0. 0. 0. 0. 1.d-6 1. 10
4010200 3 0
4010201 0. 200. 60.
*
4020000 ctiunct tmdpvol
4020101 401000000 403000000 1.
4020200 1 0 cntrlvar 305
4020201 0. 0. 0.
4020202 100000. 100000. 0. 0.
*
40300000 cooltwr pipe
4030001 5
4030101 13.0045 5
4030301 50. 5

4030601 0. 5
4030701 0. 5
4030801 1.5e-4 0.29 5
4030901 0. 0. 4
4031001 0 5
4031101 01000 4
4031201 3 .50416e+02 67.71 0. 0. 0. 1
4031202 3 .49655e+02 72.60 0. 0. 0. 2
4031203 3 .48898e+02 75.71 0. 0. 0. 3
4031204 3 .48144e+02 77.69 0. 0. 0. 4
4031205 3 .47392e+02 78.96 0. 0. 0. 5
4031300 1
4031301 4.3299e+03 0. 0. 1
4031302 4.3299e+03 0. 0. 2
4031303 4.3299e+03 0. 0. 3
4031304 4.3299e+03 0. 0. 4
*
4040000 ctstrsj sngljun
4040101 403010000 405000000 1. 0. 0. 1000
4040201 1 4.3299e+03 0. 0.
*
4050000 ctsink tmdpvol
4050101 1. 1. 0. 0. 0. 0. 1.d-6 1. 10
4050200 3 0
4050201 0. 14.7 60.
*
*****
*
* heat structures on piping
*
*****
*
* heat structure between volume 50-01 and pool
*
15012000 1 3 2 0 .703167 0 0 0
15012400 -1
15012401 154.47 142.40 130.64
15012100 0 1
15012101 2.75
15012201 10 2
15012301 0. 2
15012501 050010000 0 1 1 23.548 1
* use lowest heat transfer coefficient
* (horizontal orientation, general table 6)
* note: this is conservative only where a higher temperature is worse
15012601 -5 0 4006 1 23.548 1
15012701 0 0.0 0.0 0.0 1
15012801 0 0. 0. 0. 1
15012901 0 0. 0. 0. 1

```

```

*
* heat structure on volume 51-01
*
15042000 1 3 2 0 .703167 0 0 0
15042400 -1
15042401 156.13 156.13 156.13
15042100 0 1
15042101 2 .75
15042201 10 2
15042301 0. 2
15042501 051010000 0 1 1 27.8385 1
15042601 0 0 1 27.8385 1
15042701 0 0 0 0.0 0.0 1
15042801 0 0. 0. 1
15042901 0 0. 0. 1
*
* heat structure on volume 53-01
*
15052000 1 3 2 0 .703167 0 0 0
15052400 -1
15052401 156.13 156.13 156.13
15052100 0 1
15052101 2 .75
15052201 10 2
15052301 0. 2
15052501 053010000 0 1 1 5.7791 1
15052601 0 0 1 5.7791 1
15052701 0 0 0 0.0 0.0 1
15052801 0 0. 0. 1
15052901 0 0. 0. 1
*
* heat structure on volume 54-01
*
15062000 1 3 2 0 .703167 0 0 0
15062400 -1
15062401 156.13 156.13 156.13
15062100 0 1
15062101 2 .75
15062201 10 2
15062301 0. 2
15062501 054010000 0 1 1 14.2448 1
15062601 0 0 1 14.2448 1
15062701 0 0 0 0.0 0.0 1
15062801 0 0. 0. 1
15062901 0 0. 0. 1
*
* heat structure on volume 55-01
*
15072000 1 3 2 0 .7032 0 0 0
15072400 -1
15072401 157.83 157.83 157.83
15072100 0 1

```

```

15072101 2 .75
15072201 10 2
15072301 0. 2
15072501 055010000 0 1 1 26.97 1
15072601 0 0 1 26.97 1
15072701 0 0 0 0.0 0.0 1
15072801 0 0 0 0.0 0.0 1
15072901 0 0 0 0.0 0.0 1
*
* heat structure on volume 77-01
*
15102000 1 3 2 0 .7839 0 0 0
15102400 -1
15102401 120.69 120.70 120.70
15102100 0 1
15102101 2 .8333
15102201 10 2
15102301 0. 2
15102501 077010000 0 1 1 26.937 1
15102601 0 0 1 26.937 1
15102701 0 0 0 0.0 0.0 1
15102801 0 0 0 0.0 0.0 1
15102901 0 0 0 0.0 0.0 1
*
* heat structure on volume 76-01
*
15112000 1 3 2 0 .783917 0 0 0
15112400 -1
15112401 120.05 120.05 120.05
15112100 0 1
15112101 2 .833333
15112201 10 2
15112301 0. 2
15112501 076010000 0 1 1 16. 1
15112601 0 0 1 16. 1
15112701 0 0 0 0.0 0.0 1
15112801 0 0. 0. 1
15112901 0 0. 0. 1
*
* heat structure on volume 79-01
*
15122000 1 3 2 0 .783917 0 0 0
15122400 -1
15122401 120.00 120.00 120.00
15122100 0 1
15122101 2 .833333
15122201 10 2
15122301 0. 2
15122501 079010000 0 1 1 7.3073 1
15122601 0 0 1 7.3073 1
15122701 0 0 0 0.0 0.0 1

```



```

15122801 0 0. 0. 0. 1
15122901 0 0. 0. 0. 1
*
* heat structure on volume 80-01
*
15132000 1 3 2 0 .783917 0 0 0
15132400 -1
15132401 120.00 120.00 120.00
15132100 0 1
15132101 2 .833333
15132201 10 2
15132301 0. 2
15132501 080010000 0 1 1 22.2916 1
15132601 0 0 1 22.2916 1
15132701 0 0 0 0.0 0 1
15132801 0 0. 0. 0. 1
15132901 0 0. 0. 0. 1
*
* heat structure on volume 80-02
*
15142000 1 3 2 0 .52271 0 0 0
15142400 -1
15142401 120.00 120.00 120.00
15142100 0 1
15142101 2 .572127
15142201 10 2
15142301 0. 2
15142501 080020000 0 1 1 5.34375 1
15142601 0 0 1 5.34375 1
15142701 0 0 0 0.0 0 1
15142801 0 0. 0. 0. 1
15142901 0 0. 0. 0. 1
*
* heat structure on volume 80-03
*
15152000 1 3 2 0 .783917 0 0 0
15152400 -1
15152401 120.00 120.00 120.00
15152100 0 1
15152101 2 .833333
15152201 10 2
15152301 0. 2
15152501 080030000 0 1 1 9.9375 1
15152601 0 0 1 9.9375 1
15152701 0 0 0 0.0 0 1
15152801 0 0. 0. 0. 1
15152901 0 0. 0. 0. 1
*
* heat structure on volume 80-04
*
15162000 1 3 2 0 .783917 0 0 0
15162400 -1
15162401 119.36 115.81 112.35
15162100 0 1
15162101 2 .833333
15162201 10 2
15162301 0. 2
15162501 080040000 0 1 1 3. 1
15162601 -5 0 4008 1 3. 1
15162701 0 0.0 0.0 0.0 1
15162801 0 0. 0. 0. 1
15162901 0 0. 0. 0. 1
*
* heat structure on volume 81-01
*
15172000 1 3 2 0 .783917 0 0 0
15172400 -1
15172401 118.97 113.25 107.69
15172100 0 1
15172101 2 .833333
15172201 10 2
15172301 0. 2
15172501 081010000 0 1 1 2.5 1
15172601 -5 0 4009 1 2.5 1
15172701 0 0.0 0.0 0.0 1
15172801 0 0. 0. 0. 1
15172901 0 0. 0. 0. 1
*
* heat structure on volume 90-01
*
15182000 1 3 2 0 .783917 0 0 0
15182400 -1
15182401 118.96 113.25 107.69
15182100 0 1
15182101 2 .833333
15182201 10 2
15182301 0. 2
15182501 090010000 0 1 1 2.91767 1
15182601 -5 0 4009 1 2.91767 1
15182701 0 0.0 0.0 0.0 1
15182801 0 0. 0. 0. 1
15182901 0 0. 0. 0. 1
*
* heat structure on volume 91-01
*
15192000 1 3 2 0 .625 0 0 0
15192400 -1
15192401 119.18 115.98 112.87
15192100 0 1
15192101 2 .666667
15192201 10 2
15192301 0. 2
15192501 091010000 0 1 1 14.3386 1
15192601 -5 0 4010 1 14.3386 1

```

```

15192701 0 0.0 0.0 0.0 1
15192801 0 0.0 0.0 0.0 1
15192901 0 0.0 0.0 0.0 1
*
* heat structure on volume 92-01
*
15202000 1 3 2 0 .625 0 0 0
15202400 -1
15202401 156.13 156.13 156.13
15202401 119.18 115.98 112.87
15202100 0 1
15202101 2 .666667
15202201 10 2
15202301 0.2
15202501 092010000 0 1 1 14.3386 1
15202601 -5 0 4010 1 14.3386 1
15202701 0 0.0 0.0 0.0 1
15202801 0 0.0 0.0 0.0 1
15202901 0 0.0 0.0 0.0 1
*
* cell d piping heat structures
*
* heat structure on volumes 52-01, -02
*
15252000 2 3 2 0 .4175 0 0 0
15252400 -1
15252401 156.13 156.13 156.13
15252402 156.13 156.13 156.13
15252100 0 1
15252101 2 .447917
15252201 10 2
15252301 0.2
15252501 052010000 0 1 1 21.799 1
15252502 052020000 0 1 1 10.3017 2
15252601 0 0 1 21.799 1
15252602 0 0 1 10.3017 2
15252701 0 0.0 0.0 0.0 2
15252801 0 0.0 0.0 0.0 2
15252901 0 0.0 0.0 0.0 2
*
* heat structure on volume 57-01
*
15272000 1 3 2 0 .546836 0 0 0
15272400 -1
15272401 156.13 156.13 156.13
15272100 0 1
15272101 2 .583247
15272201 10 2
15272301 0.2
15272501 57010000 0 1 1 3.1772 1
15272601 0 0 1 3.1772 1
15272701 0 0.0 0.0 0.0 1
15272801 0 0.0 0.0 0.0 1
15192701 0 0.0 0.0 0.0 1
*
* heat structure on volume 113-01,114-01
*
15502000 2 3 3 0 1.9583 0 0 0
15502400 -1
15502401 156.13 156.13 156.13
15502402 120.49 120.49 120.49
15502100 0 1
15502101 2 2.07913
15502201 10 2
15502301 0.2
15502501 113010000 1000000 1 1 0.25 2
15502601 0 0 1 0.25 2
15502701 0 0.0 0.0 0.0 2
15502801 0 0.0 0.0 0.0 2
15502901 0 0.0 0.0 0.0 2
*
* heat structures on volume 60-01
*
15282000 1 3 2 0 .546836 0 0 0
15282400 -1
15282401 120.49 120.49 120.49
15282100 0 1
15282101 2 .583247
15282201 10 2
15282301 0.2
15282501 060010000 0 1 1 10.353 1
15282601 0 0 1 10.353 1
15282701 0 0.0 0.0 0.0 1
15282801 0 0.0 0.0 0.0 1
15282901 0 0.0 0.0 0.0 1
*
* heat structure on volume 73-01
*
15292000 1 3 2 0 .4175 0 0 0
15292400 -1
15292401 120.69 120.69 120.69
15292100 0 1
15292101 2 .44792
15292201 10 2
15292301 0.2
15292501 073010000 0 1 1 1.0 1
15292601 0 0 1 1.1
15292701 0 0.0 0.0 0.0 1
15292801 0 0.0 0.0 0.0 1
15292901 0 0.0 0.0 0.0 1
*
* heat structure on volume 75-01,-02
*
15302000 2 3 2 0 .4175 0 0 0
15302400 -1

```

```

15302401 120.69 120.69 120.69 120.69
15302402 120.69 120.69 120.69 120.69
15302100 0 1
15302101 2.447917
15302201 10 2
15302301 0. 2
15302501 075010000 0 1 1 2.29165 1
15302502 075020000 0 1 1 18.8961 2
15302601 0 0 1 2.29165 1
15302602 0 0 1 18.8961 2
15302701 0 0 0 0.0 0.0 2
15302801 0 0. 0. 2
15302901 0 0. 0. 2
*
* cells a and c piping heat structures
*
*
* heat structure on volume 152-01,-02
*
15322000 2 3 2 0 .4175 0 0 0
15322400 -1
15322401 156.13 156.13 156.13
15322402 156.13 156.13 156.13
15322100 0 1
15322101 2.447917
15322201 10 2
15322301 0. 2
15322501 152010000 0 1 1 51.2554 1
15322503 152020000 0 1 1 20.6034 2
15322601 0 0 1 51.2554 1
15322602 0 0 1 20.6034 2
15322701 0 0 0 0.0 0.0 2
15322801 0 0. 0. 2
15322901 0 0. 0. 2
*
* heat structure on volume 157-01
*
15342000 1 3 2 0 .546836 0 0 0
15342400 -1
15342401 119.84 119.84 119.84
15342100 0 1
15342101 2.583247
15342201 10 2
15342301 0. 2
15342501 214010000 0 1 1 6.3544 1
15342601 0 0 1 6.3544 1
15342701 0 0 0 0.0 0.0 1
15342801 0 0. 0. 1
15342901 0 0. 0. 1
*
* heat structure on volume 213-01,214-01
*
15512000 2 3 3 0 1.9583 0 0 0
15512400 -1
15512401 156.13 156.13 156.13
15512402 119.84 119.84 119.84
15512100 0 1
15512101 2.2.07913
15512201 10 2
15512301 0. 2
15512501 213010000 1000000 1 1 0.50 2
15512601 0 0 1 0.50 2
15512701 0 0 0 0.0 0.0 2
15512801 0 0. 0. 2
15512901 0 0. 0. 2
*
* heat structures on volume 160-01
*
15352000 1 3 2 0 .546836 0 0 0
15352400 -1
15352401 119.84 119.84 119.84
15352100 0 1
15352101 2.583247
15352201 10 2
15352301 0. 2
15352501 160010000 0 1 1 20.706 1
15352601 0 0 1 20.706 1
15352701 0 0 0 0.0 0.0 1
15352801 0 0. 0. 1
15352901 0 0. 0. 1
*
* heat structure on volume 173-01
*
15362000 1 3 2 0 .4175 0 0 0
15362400 -1
15362401 120.04 120.04 120.04 120.04
15362100 0 1
15362101 2.44792
15362201 10 2
15362301 0. 2
15362501 173010000 0 1 1 2.0 1
15362601 0 0 1 2. 1
15362701 0 0 0 0.0 0.0 1
15362801 0 0. 0. 1
15362901 0 0. 0. 1
*
* heat structure on volume 175-01,-02
*
15372000 2 3 2 0 .4175 0 0 0
15372400 -1
15372401 120.04 120.04 120.04 120.04
15372402 120.05 120.05 120.05 120.05
15372100 0 1
15372101 2.447917

```



```

* cooling tower heat structure properties (low heat capacity)
*
20101500 tbl/fctn 1 1
20101501 32. 0.00244 80. 0.00244 440. 0.00294 620. 0.00317
20101502 980. 0.00361
20101551 .01
*
*****
*
* control systems
*
*****
*
* primary coolant head tank level
*
* demineralized water flow into pc head tank 90 gpm (80 deg. f)
20500100 demin tripunit 1.247000d+01 0.000000d+00 0
20500101 511
* sum mass flows into the primary coolant head tank.
* density is 62.2 lb/ft**3 (80 deg f). convert mflowj's
* from kg/s to lb/s
* - cntrlvar 1 - demineralized water make-up flow
* - mflowj 63, 163 - letdown valve flows
* - mflowj 66 - main pressurizer pump flow
* - mflowj 69 - standby pressurizer pump flow
* - mflowj 71 - auxiliary pressurizer pump flow
20500200 tankmdot sum 1.000000d+00 -4.585480d-01 i
20500201 0. 1.,cntrlvar,1 2.2046,mflowj,63000000
20500202 2.2046,mflowj,163000000
20500203 -2.2046,mflowj,66010000 -2.2046,mflowj,69010000
20500204 -2.2046,mflowj,71000000
* if transient has not yet begun, zero net mass flow into tank
20500300 transient tripunit 1.000000d+00 0.000000d+00 1
20500301 503
20500400 mdot mult 1.000000d+00 0.000000d+00 1
20500401 cntrlvar,2 cntrlvar,3
* integrate net mass flow into the pc head tank for %full
* density is 62.2 lb/ft**3, tank capacity is 2500 gallons
* initially tank level reading is 70% (52.4 in. actual level, 78.5% full)
* note: measured tank level 2.0 in. less than actual tank level and
ranges
* from 0-72 in. (0-6 ft). the actual tank id is 78 inches (6.5
ft).
20500500 tankvol integral 4.810000d-05 7.850000d-01 0
20500501 cntrlvar,4
20500600 tanklev function 1.000000d+00 4.762000d+00 1
20500601 cntrlvar,5,11
20500700 tankmeas sum 1.000000d+00 4.595300d+00 1
20500701 -0.1667 1.,cntrlvar,6

* standby pressurizer pump speed
*
20500800 stb tripunit 1.000000d+00 0.000000d+00 1
20500801 612
20500900 stbsp tripdelay 1.000000d+00 -1.000000d+00 1
20500901 612
20501000 stbysum sum 1.000000d+00 3.020000d+02 1
20501001 0. -1.,cntrlvar,9 1.,time,0
20501100 stbysum mult 1.000000d+00 0.000000d+00 1
20501101 cntrlvar,8 cntrlvar,10
20501200 stbsp function 2.311900d+03 0.000000d+00 1
20501201 cntrlvar,11,4
*
* pressurizer pump shutdown due to low suction pressure
*
* determine if low pwr pump suction was detected
20501500 lowptdlt tripdelay 1.000000d+00 -1.000000d+00 1
20501501 606
* determine the time since the suction pressure dropped below minimum
20501600 lowsum sum 1.000000d+00 3.020000d+02 1
20501601 0. 1.,time,0 -1.,cntrlvar,15
* set to 1 if suction pressure is still low
20501700 lowtrip tripunit 1.000000d+00 0.000000d+00 1
20501701 606
* set to 1.0 if pwr pumps should be tripped because of low suction p
20501800 lowmult mult 1.000000d+00 0.000000d+00 1
20501801 cntrlvar,16 cntrlvar,17
*
* determine auxiliary pressurizer pump flow
*
20501900 aux-tu tripunit 1.000000d+00 0.000000d+00 1
20501901 623
20502000 auxdp sum 1.450377d-04 4.884810d+02 1
20502001 0. 1.,p,67010000 -1.,p,47010000
20502100 auxflow function 1.000000d+00 0.000000d+00 1
20502101 cntrlvar,20,2
20502200 auxptrdt tripdelay 1.000000d+00 -1.000000d+00 1
20502201 623
20502300 auxpsrch sum 1.000000d+00 3.020000d+02 1
20502301 0. -1.,cntrlvar,22 1.,time,0
20502400 auxpfac function 1.000000d+00 1.000000d+00 1
20502401 cntrlvar,23,3
20502500 auxpfow mult 1.000000d+00 0.000000d+00 1
20502501 cntrlvar,19 cntrlvar,21 cntrlvar,24
*
* let-down valve control
* gain = 0.0006 /psi
* reset time = 0.0006/0.0007 = 0.85714 s
* derivative time = 0.00069/0.0006 = 1.15 s
*
20502600 timestep sum 1.000000d+00 3.125000d-02 0

```

```

20502601 0. 1.,time,0 -1.0,ctrlvar,43
20502700 ldbvlnai tripunit 1.000000d+00 1.000000d+00 1
20502701 -571
20502800 ldblowpr tripunit 1.000000d+00 0.000000d+00 1
20502801 622
20502900 lbv-tim tripdelay 1.000000d+00 -1.000000d+00 1
20502901 622
20503000 lbv-tims sum 1.000000d+00 3.020000d+02 1
20503001 0. 1.,time,0 -1.,ctrlvar,29
20503100 lbv-arg mult 1.000000d+00 0.000000d+00 1
20503101 ctrlvar,28 ctrlvar,30
20503200 lbv-fact sum 1. 1.000000d+00 1 3 0.000000d+00 1.000000d+00
20503201 1.0 -0.25,ctrlvar,31
20503300 ldbclose mult 1.000000d+00 1.000000d+00 1
20503301 ctrlvar,27 ctrlvar,32
* let-down control valve
20503400 ldderror sum 1.000000d+00 2.282614d-02 1
20503401 0. 1.450377e-4,p,79010000 -1.,ctrlvar,670
20503500 proint prop-int 1.000000d+00 6.070600d-01 0
20503501 0.000600 0.00070 ctrlvar,34
20503600 ldderiv diffrend 6.900000d-04 1.013417d-03 0
20503601 ctrlvar,34
20503700 pidctrl sum 1.000000d+00 6.080730d-01 1
20503701 0. 1.,ctrlvar,35 1.,ctrlvar,36
20503800 deltepo sum 1.000000d+00 2.054371d-03 1
20503801 0. 1.,ctrlvar,37 -1.,ctrlvar,41
20503900 speed div 1. 5.84800d-02 1 3 -1.16280d-01 5.84800d-02
20503901 ctrlvar,26 ctrlvar,38
20504000 deltepos mult 1.000000d+00 1.827500d-03 1
20504001 ctrlvar,39 ctrlvar,26
20504100 new-posi sum 1.000000d+00 6.078460d-01 1
20504101 0. 1.,ctrlvar,40 1.,ctrlvar,41
*
20504200 ldst-pos mult 1. 6.07846d-01 1 3 0.000000d+00 1.000000d+00
20504201 ctrlvar,41 ctrlvar,33
20504300 old-time mult 1.000000d+00 3.010000d+02 1
20504301 time,0
*
* leakage from system
*
20504500 gage-pre sum 1.450377d-04 4.826430d+02 1 1 0.000000d+00
20504501 -1.0135d5 1.,p,79010000
20504600 prexpon powerr 1.000000d+00 1.531400d+01 1
20504601 ctrlvar,45,0.4416
20504700 leakage mult 1.090300d-05 1.653040d-01 1
20504701 ctrlvar,46 rhof,79010000
*
* automatic control of fcv 377a
*
* gain = 0.2
* reset time = 0.2/0.01
* derivative constant = 0.2/0.5

```

```

*
20505200 seerror sum 1.000000d+00 9.421295d-05 0
20505201 -459.67 1.8,tempf,80010000 -1.,ctrlvar,671
20505300 sec-pi prop-int 1.000000d+00 1.364240d-01 0
20505301 0.2 0.010 ctrlvar,52
20505400 sec-d diffrend 5.000000d-01 2.552759d-04 0
20505401 ctrlvar,52
20505500 sec-pid sum 1.000000d+00 1.366790d-01 1
20505501 0. 1.,ctrlvar,53 1.,ctrlvar,54
* add 2.s lag for valve actuator
20505600 sec-lag lag 1. 1.36421d-01 1 3 0.000000d+00 1.000000d+00
20505601 2.0 ctrlvar,55
* check for loss of instrument air
20505700 ypos377a sum 1. 1.36421d-01 1 3 0.000000d+00 1.000000d+00
20505701 0. 1.,ctrlvar,56 1.,ctrlvar,72
*
* control of auxiliary secondary coolant pump
*
20505800 sec-off tripdelay 1.000000d+00 -1.000000d+00 1
20505801 649
20505900 sec-arch sum 1.000000d+00 3.020000d+02 1
20505901 0. -1.,ctrlvar,58 1.,time,0
20506000 sec-faci function 1.000000d+00 1.000000d+00 1
20506001 ctrlvar,59,3
20506100 sec-tru tripunit 1.000000d+00 0.000000d+00 1
20506101 649
20506200 noac-tru tripunit 1.000000d+00 0.000000d+00 1
20506201 553
20506300 sec-fac2 sum 1.000000d+00 1.000000d+00 1
20506301 1. -0.5,ctrlvar,62
20506400 sec-mult mult 1.200000d+03 0.000000d+00 1
20506401 ctrlvar,61 ctrlvar,60 ctrlvar,63
*
* normalized area of heat exchanger bypass valve
*
20506500 hxbypass sum 1.000000d+00 5.000000d-01 0
20506501 0. 1.,ctrlvar,689 -1.,ctrlvar,72
* add 0.005 s lag for valve closing
20506600 sec-lag lag 1. 5.00000d-01 0 3 0.00000d+00 1.00000d+00
20506601 0.005 ctrlvar,65
*
* manual control of fcv 377
*
20506700 se-tu1 tripunit 1.000000d+00 0.000000d+00 0
20506701 569
20506800 se-td1 tripdelay 1.000000d+00 -1.000000d+00 0
20506801 569
20506900 se-sum1 sum 1.000000d+00 3.020000d+02 0
20506901 0. -1.,ctrlvar,68 1.,time,0
20507000 se-fact div 1. 1.00000d+00 0 3 0.00000d+00 1.00000d+00
20507001 ctrlvar,688 ctrlvar,69
20507100 se-adjst mult 1.000000d+00 0.000000d+00 0

```

```

20507101 cntrlvar,67 cntrlvar,70 cntrlvar,687
20507200 se-tu2 tripunit 1.000000d+00 0.000000d+00 0
20507201 571
20507300 cv377pos sum 1. 1.00000d-01 0 3 0.00000d+00 1.00000d+00
20507301 0. -1.,cntrlvar,71 1.,cntrlvar,687 1.,cntrlvar,72
* velocity head at mcp suction
*
20507400 mcpvseq1d mult 7.251990d-05 1.160930d+00 1
20507401 rho,60010000 vel,f,70010000 vel,f,70010000
20507500 mcpvseq1c mult 7.251990d-05 1.096460d+00 1
20507501 rho,160010000 vel,f,170010000 vel,f,170010000
* pump speed calculations after pump trip
*
20507700 mcptrip tripunit 1.000000d+00 0.000000d+00 1
20507701 660
20507800 mcpntrip tripunit 1.000000d+00 1.000000d+00 1
20507801 -660
*==== pu-1d ====
20507900 frtrq-1d function 1.000000d+00 3.700000d+02 0
20507901 cntrlvar,116,43
20508000 motrq-1d function 1.000000d+00 0.000000d+00 0
20508001 cntrlvar,116,44
* water power = (flow)(pressure difference)
20508100 watpw-1d mult 2.088540d-02 3.024390d+05 0
20508101 cntrlvar,106 pmphed,70
* water torque = (water power)/(pump speed)
20508200 watrq-1d div 9.549300d+00 1.548680d+03 0
20508201 cntrlvar,86 cntrlvar,81
* sum of torques divided by pump inertia (rate of speed change)
* scaling factor = gc/inertia
20508300 torq-1d sum 6.880340d-02 -1.320110d+02 0
20508301 0. -1.,cntrlvar,79 1.,cntrlvar,80 -1.,cntrlvar,82
* do not adjust speed unless pumps have been tripped (convert to rpm)
20508400 adj-1d mult 9.549300d+00 0.000000d+00 0
20508401 cntrlvar,83 cntrlvar,77
* adjustment to pump speed
20508500 adjus-1d integral 1.000000d+00 0.000000d+00 0
20508501 cntrlvar,84
* actual pu-1d pump speed after pump trip
20508600 actcpd1d sum 1.000000d+00 1.864790d+03 0 1 2.700000d+02
20508601 0. 1.,cntrlvar,186 1.,cntrlvar,85
*==== pu-1c ====
20508700 frtrq-1c function 1.000000d+00 3.700000d+02 0
20508701 cntrlvar,141,43
20508800 motrq-1c function 1.000000d+00 0.000000d+00 0
20508801 cntrlvar,141,44
* water power = (flow)(pressure difference)
20508900 watpw-1c mult 2.088540d-02 5.920960d+05 0
20508901 cntrlvar,131 pmphed,170
* water torque = (water power)/(pump speed)
20508902 cntrlvar,106

20509000 watrq-1c div 9.549300d+00 3.031940d+03 0
20509001 cntrlvar,94 cntrlvar,89
* sum of torques divided by pump inertia (rate of speed change)
20509100 torq-1c sum 3.440170d-02 -1.297600d+02 0
20509101 0. -2.,cntrlvar,87 2.,cntrlvar,88 -1.,cntrlvar,90
* do not adjust speed unless pumps have been tripped (convert to rpm)
20509200 adj-1c mult 9.549300d+00 0.000000d+00 0
20509201 cntrlvar,91 cntrlvar,77
* adjustment to pump speed
20509300 adjus-1c integral 1.000000d+00 0.000000d+00 0
20509301 cntrlvar,92
* actual pu-1c pump speed after pump trip
20509400 actcpd1c sum 1.000000d+00 1.864790d+03 0 1 2.700000d+02
20509401 0. 1.,cntrlvar,186 1.,cntrlvar,93
* pump cavitation prediction
*
*==== pu-1d ====
* saturation pressure for volume 60-03
20510300 tps60dgc sum 1.000000d+00 4.916170d+01 1
20510301 -273.15 1.,tempf,60010000
20510400 tps60dgc sum 1.000000d+00 1.204910d+02 1
20510401 32. 1.f,cntrlvar,103
20510500 satps60 function 1.000000d+00 1.720560d+00 1
20510501 cntrlvar,104,35
* pump flow pu-1d (cubic feet per second)
20510600 flow60 div 3.531500d+01 1.239720d+01 1
20510601 rho,f,70010000 mflow,70010000
20510700 cq-pu1d div 2.185000d+00 1.452600d-02 1
20510701 cntrlvar,86 cntrlvar,106
20510800 chcr1d function 1.000000d+00 1.001015d-02 1
20510801 cntrlvar,107,38
20510900 rpschcr1d mult 9.104100d-04 3.169100d+01 1
20510901 cntrlvar,108 cntrlvar,86 cntrlvar,86
* critical rpsch for pu-1d in psi
20511000 rpschcr1d mult 4.335280d-04 1.359370d+01 1
20511001 cntrlvar,109 rho,f,70010000
* suction pressure to pu-1d in psi
20511100 suct-1d mult 1.450380d-04 3.380610d+02 1
20511101 p,60010000
* actual rpsch for pu-1d in psi
20511200 rpsch-1d sum 1.000000d+00 3.375010d+02 1
20511201 0. 1.,cntrlvar,111 -1.,cntrlvar,105 1.,cntrlvar,74
* ratio of actual rpsch to critical rpsch
20511300 rpschra1d div 1.000000d+00 2.482780d+01 1
20511301 cntrlvar,110 cntrlvar,112
* head degradation factor
20511400 degfac1d function 1.000000d+00 1.000000d+00 1
20511401 cntrlvar,113,39
* determine nondimensional homologous variables
20511500 v-1d mult 8.975290d-02 1.112690d+00 1
20511501 cntrlvar,106

```

```

20511600 alpha-1d mult 5.599100d+04 1.044110d+00 1
20511601 cntrlvar,86
20511700 v/alp-1d div 1.000000d+00 1.065680d+00 1
20511701 cntrlvar,116 cntrlvar,115
20511800 alp/v-1d div 1.000000d+00 9.383720d-01 1
20511801 cntrlvar,115 cntrlvar,116
20511900 hvn-1d function 1.000000d+00 8.707230d-01 1
20511901 cntrlvar,118,41
20512000 v/a-tu1d tripunit 1.000000d+00 1.000000d+00 1
20512001 536
20512100 a/v-tu1d tripunit 1.000000d+00 0.000000d+00 1
20512101 -536
20512200 hvn-pu1d mult 1.000000d+00 8.707230d-01 1
20512201 cntrlvar,119 cntrlvar,120 cntrlvar,114
20512300 alpsq-1d mult 1.000000d+00 0.000000d+00 1
20512301 cntrlvar,114 cntrlvar,86 cntrlvar,86 cntrlvar,121
20512400 spdgl-1d power 1.000000d+00 0.000000d+00 1
20512401 cntrlvar,123,0.5
20512500 a/vdg-1d function 1.000000d+00 9.383720d-01 1
20512501 cntrlvar,122,42
20512600 spdgl-1d mult 1.786000d+03 1.864790d+03 1
20512601 cntrlvar,125 cntrlvar,115 cntrlvar,120
* degraded pump speed for pump pu-1d
20512700 speed-1d sum 1.000000d+00 1.864790d+03 1
20512701 0. 1.,cntrlvar,124 1.,cntrlvar,126
* === pu-1c ===
* saturation pressure for volume 160-03
20512800 ta160dc sum 1.000000d+00 4.879890d+01 1
20512801 -273.15 1.,tempf,160010000
20512900 ta160dc sum 1.000000d+00 1.198380d+02 1
20512901 32. 1.8,cntrlvar,128
20513000 satpr160 function 1.000000d+00 1.687730d+00 1
20513001 cntrlvar,129,35
* pump flow pu-1c (cubic feet per second)
20513100 flow160 div 3.531500d+01 2.411690d+01 1
20513101 rhojf,170010000 mflowj,170010000
20513200 cq-pu1c div 2.185000d+00 2.825816d-02 1
20513201 cntrlvar,94 cntrlvar,131
20513300 chacr11c function 1.000000d+00 1.508000d-02 1
20513301 cntrlvar,132,38
20513400 npshcr1c mult 9.104100d-04 4.774160d+01 1
20513401 cntrlvar,133 cntrlvar,94 cntrlvar,94
* critical npsh for pu-1c in psi
20513500 npshcr1c mult 4.335280d-04 2.048180d+01 1
20513501 cntrlvar,134 rhojf,170010000
* suction pressure to pu-1c in psi
20513600 suet-1c mult 1.450380d-04 3.374780d+02 1
20513601 p,160010000
* actual npsh for pu-1c in psi
20513700 npsh-1c sum 1.000000d+00 3.368890d+02 1
20513701 0. 1.,cntrlvar,136 -1.,cntrlvar,130 1.,cntrlvar,75
* ratio of actual npsh to critical npsh
20513800 npshra1c div 1.000000d+00 1.644820d+01 1
20513801 cntrlvar,135 cntrlvar,137
* head degradation factor
20513900 degfac1c function 1.000000d+00 1.000000d+00 1
20513901 cntrlvar,138,39
* determine nondimensional homologous variables
20514000 v-1c mult 4.487650d-02 1.082280d+00 1
20514001 cntrlvar,131
20514100 alpha-1c mult 5.599100d-04 1.044110d+00 1
20514101 cntrlvar,94
20514200 v/alp-1c div 1.000000d+00 1.036560d+00 1
20514201 cntrlvar,141 cntrlvar,140
20514300 alp/v-1c div 1.000000d+00 9.647320d-01 1
20514301 cntrlvar,140 cntrlvar,141
20514400 hvn-1c function 1.000000d+00 9.260190d-01 1
20514401 cntrlvar,143,41
20514500 v/a-tu1c tripunit 1.000000d+00 1.000000d+00 1
20514501 537
20514600 a/v-tu1c tripunit 1.000000d+00 0.000000d+00 1
20514601 -537
20514700 hvn-pu1c mult 1.000000d+00 9.260190d-01 1
20514701 cntrlvar,144 cntrlvar,145 cntrlvar,139
20514800 alpsq-1c mult 1.000000d+00 0.000000d+00 1
20514801 cntrlvar,139 cntrlvar,94 cntrlvar,94 cntrlvar,146
20514900 spdgl-1c power 1.000000d+00 0.000000d+00 1
20514901 cntrlvar,148,0.5
20515000 a/vdg-1c function 1.000000d+00 9.647320d-01 1
20515001 cntrlvar,147,42
20515100 spdgl-1c mult 1.786000d+03 1.864790d+03 1
20515101 cntrlvar,150 cntrlvar,140 cntrlvar,145
* degraded pump speed for pump pu-1c
20515200 speed-1c sum 1.000000d+00 1.864790d+03 1
20515201 0. 1.,cntrlvar,149 1.,cntrlvar,151
* pu-1d speed after lag
20517800 speedgl1d lag 1.000000d+00 1.864830d+03 1
20517801 0.050 cntrlvar,127
* pu-1c speed after lag
20517900 speedgl1c lag 1.000000d+00 1.864830d+03 1
20517901 0.050 cntrlvar,152
* control mcp speed to reach new steady-state
20518100 tr-tu tripunit 1.000000d+00 1.000000d+00 1
20518101 -503
20518200 f1error sum 1.000000d+00 2.502960d-01 0
20518201 0. 1.,cntrlvar,690 -1.,cntrlvar,202
20518300 flerr mult 1.000000d+00 2.502960d-01 0
20518301 cntrlvar,181 cntrlvar,182
20518400 flo-pi prop-int 1.000000d+00 1.864850d+03 0
20518401 0.1 1. cntrlvar,183
20518500 flo-d diffrend 1.000000d-03 1.601910d-02 0
20518501 cntrlvar,183

```



```

20518600 flo-pid sum 1.000000d+00 1.864870d+03 1
20518601 0. 1.,cntrlvar,184 1.,cntrlvar,185
20518700 multcpj mult 1.000000d+00 1.864870d+03 1
20518701 cntrlvar,186 cntrlvar,78
20518800 multcpd mult 1.000000d+00 0.000000d+00 1
20518801 cntrlvar,178 cntrlvar,77
20518900 mcpd-vel sum 1.000000d+00 1.864870d+03 1
20518901 0. 1.,cntrlvar,187 1.,cntrlvar,188
20519000 multcpc mult 1.000000d+00 0.000000d+00 1
20519001 cntrlvar,179 cntrlvar,77
20519100 mcpc-vel sum 1.000000d+00 1.864870d+03 1
20519101 0. 1.,cntrlvar,187 1.,cntrlvar,190
* reactor scram
*
* flux ratio
20520100 fluxrat mult 1.176470d-08 9.999990d-01 1
20520101 cntrlvar,850
* flow (gpm) into the vessel
20520200 flowgpm div 1.585040d+04 1.650030d+04 1
20520201 rho fj,80020000 mflowj,80020000
* flow ratio
20520300 flowrat mult 6.25000d-05 1.0000d+00 1 3 .10 1.0000d+00
20520301 cntrlvar,202
* flux-to-flow ratio
20520400 ffr div 1.000000d+00 9.999990d-01 1
20520401 cntrlvar,203 cntrlvar,201
* maximum primary coolant temperature exceeded
20520500 maxtrr tripunit 1.000000d+00 0.000000d+00 1
20520501 506
* delay for max. primary coolant temperature reactor trip of 2. s
20520600 scdly delay 1.000000d+00 0.000000d+00 1
20520601 cntrlvar 205 5. 100
* scram signal initiated
20520700 scram tripunit 1.000000d+00 0.000000d+00 1
20520701 647
* delay for scram of 0.02 s
20520800 scdly delay 1.000000d+00 0.000000d+00 1
20520801 cntrlvar 207 0.02 100
*
* emergency depressurization control
*
* minimum primary coolant temperature exceeded
20525200 lowtemp tripunit 1.000000d+00 0.000000d+00 1
20525201 603
20525300 edsair tripunit 1.000000d+00 1.000000d+00 1
20525301 -571
20525400 edspos mult 1.000000d+00 0.000000d+00 1
20525401 cntrlvar,252 cntrlvar,253
* delay for temperature sensor response of 5.0 s
* delay for min. primary coolant temperature eds trip of 5. s
20525500 scdly delay 1.000000d+00 0.000000d+00 1

20525501 cntrlvar 254 10.0 100
*
* cooling tower bypass control
*
20529000 ct-tripu tripunit 1.000000d+00 0.000000d+00 1
20529001 648
20529100 ct-tdeley tripdelay 1.000000d+00 -1.000000d+00 1
20529101 648
20529200 timesinc sum 1.000000d+00 3.020000d+02 1
20529201 0. 1.,time,0 -1.,cntrlvar,291
20529300 ct-arg mult 1.000000d+00 0.000000d+00 1
20529301 cntrlvar,290 cntrlvar,292
20529400 ct-pos function 1.000000d+00 1.000000d+00 1
20529401 cntrlvar,293,37
20529500 ctbp-pos sum 1.000000d+00 0.000000d+00 1
20529501 1. -1.,cntrlvar,294
*
* cooling tower stream control (models fan control)
*
* pid control
20530000 ct-error sum 1.000000d+00 -1.439921d-04 0
20530001 0. 1.,cntrlvar,504 -1.,cntrlvar,672
20530100 ct-mul mult 1.000000d+00 -1.439921d-04 1
20530101 cntrlvar,300 cntrlvar,181
20530200 ct-pi prop-int 1.000000d+00 4.329910d+03 0
20530201 5. 5. cntrlvar 301
20530300 ct-d diffrend 2.250000d+03 -4.170317d-03 0
20530301 cntrlvar,301
20530400 ct-d-mul mult 1.000000d+00 -4.170317d-03 1
20530401 cntrlvar,303 cntrlvar,181
* add p-i component to d component of control
20530500 ct-pid sum 1.000000d+00 4.329910d+03 1
20530501 0. 1.,cntrlvar,302 1.,cntrlvar,304
*
* reactor vessel check valve flow
*
20531900 dcltap sum 1.000000d+00 0.000000d+00 1 1 0.000000d+00
20531901 21.7 -1.45036d-4,p,21050000
20532000 rcvflo function 1.000000d+00 0.000000d+00 1
20532001 cntrlvar,319,12
20532100 rcvlag lag 1.000000d+00 0.000000d+00 1
20532101 1.2 cntrlvar,320
*
* structural elasticity mass injection
*
20537200 dclt8 diffrend 1.450380d-04 3.404950d-01 0
20537201 p 033010000
* dclp = 1.183e-3 ft**3/psi corresponding to 113 psi/gal
20537300 dclt8 mult -7.365000d-05 -2.468834d-02 0
20537301 cntrlvar,372 rho,033010000
* mass injection/ejection adjusted by lag
20537400 elast lag 1.000000d+00 5.812831d-08 0

```

```

20537401 1.e-3 cntrlvar,373
* set to 1 if pressure in 60-03 is greater than 20 psia
20537500 elastrip tripunit 1.000000d+00 1.000000d+00 1
20537501 -525
* set final value of mass injection/ejection
20537600 elastcy mult 1.000000d+00 5.812831d-08 1
20537601 cntrlvar,374 cntrlvar,375
*
*****
*****
*
* start of reactivity feedback for point-kinetics
*
* -- modified by j.d. freels 1/92
*****
*****
*
*== start of reactivity feedback from moderator temperature change in
fuel ==
*
* average moderator temperature in fuel region (^ok)
20577700 avgfuel sum 2.500000d-01 3.337700d+02 1
20577701 0. 1. tempf 1010000 1. tempf 2010000 2. tempf 18010000
*
* curve fit of fuel region moderator reactivity as a function of
average
* moderator temperature in the fuel region \rho (mod_t)=f(mod_t)
* fig 9.2, p.70, ornl-4621, "fuel region with 300-g pu target"
* returns ($/^ok)
*
20577800 avgrctco sum 1.000000d+00 -2.403952d-02 1
20577801 0.05206 -2.28d-4 cntrlvar 777
*
* change in average moderator temperature between time steps
* \delta mod_t=mod_t^(n+1)-mod_t^n (^ok)
20577900 deltatmp sum 1.000000d+00 3.383991d-05 1
20577901 0. 1. cntrlvar 777 -1. cntrlvar 780
*
* save old average moderator temperature = mod_t^n (^ok)
20578000 tempsave sum 1.000000d+00 3.337700d+02 1
20578001 0. 1. cntrlvar 777
*
* calculate reactivity change from average moderator temperature change
* $ = $/^ok \times ^ok
20578100 modfupmp mult 1.000000d+00 -8.134952d-07 1
20578101 cntrlvar 778 cntrlvar 779

*
* sum the change in the reactivity to track the total reactivity from
* the average moderator temperature in the fuel region
*
20578200 modfurx sum 1.000000d+00 -8.022050d+00 1
20578201 0.0 1. cntrlvar 781 1. cntrlvar 782
*
*== end of reactivity feedback from moderator temperature change in fuel
*
*== start of reactivity feedback from moderator temperature change in
target==
*
* average moderator temperature in target region (^ok)
*
20578300 targtemp sum 5.000000d-01 3.229340d+02 1
20578301 0. .647 tempf 6010000 .353 tempf 5010000 1. tempf
18010000
*
* curve fit of target region moderator reactivity as a function of
average
* moderator temperature in the fuel region \rho (mod_t)=f(mod_t)
* fig 9.2, p.70, ornl-4621, "flux trap with 300-g pu target"
* returns ($/^ok)
*
20578400 tartrctco function 1.000000d+00 1.555758d-02 1
20578401 cntrlvar 783 15
*
* change in average moderator temperature between time steps
* \delta mod_t=mod_t^(n+1)-mod_t^n (^ok)
20578500 deltmpta sum 1.000000d+00 4.331002d-06 1
20578501 0. 1. cntrlvar 783 -1. cntrlvar 786
*
* save old average moderator temperature = mod_t^n (^ok)
*
20578600 tampsveta sum 1.000000d+00 3.229340d+02 1
20578601 0. 1. cntrlvar 783
*
* calculate reactivity change from average moderator temperature change
* $ = $/^ok \times ^ok
*
20578700 modtarct mult 1.000000d+00 6.737992d-08 1
20578701 cntrlvar 784 cntrlvar 785
*
* sum the change in the reactivity to track the total reactivity from
* the average moderator temperature in the target region
*
20578800 modtarct sum 1.000000d+00 5.022630d+00 1
20578801 0. 1. cntrlvar 787 1. cntrlvar 788
*
*== end of reactivity feedback from moderator temperature change in
target==

```

```

*== start of reactivity feedback from void created by displacement of
fuel==
*== region by water due to thermal expansion/contraction
==
*
*== start of dimensional changes in inner fuel ==
*
* calculate inner fuel region coolant temperature change from
* previous step \delta t_inner fuel coolant=t^(n+1)-t^n (^ok)
20578900 ifcooldt sum 1.000000d+00 6.47595d-05 1
20578901 0. 1. tempf 1010000 -1. cntrlvar 790
*
* calculate inner fuel region coolant temperature at previous step t^n
(^ok)
20579000 ifcoolts sum 1.000000d+00 3.449350d+02 1
20579001 0. 1. tempf 1010000
*
* calculate inner fuel region temperature change from
* previous step \delta t_inner fuel=t^(n+1)-t^n (^ok)
20579100 ifhstrdt sum 1.000000d+00 -1.527606d-06 1
20579101 0. 1. htvat 10001 -1. cntrlvar 792
*
* calculate inner fuel region temperature at previous step t^n (^ok)
20579200 ifhstrts sum 1.000000d+00 3.791910d+02 1
20579201 0. 1. htvat 10001
*
* calculate the difference between the fuel and coolant temperature
* change = \delta t_inner fuel-\delta t_inner fuel coolant (^ok)
20579300 ifdt-exp sum 1.000000d+00 -6.628356d-05 1
20579301 0. 1. cntrlvar 791 -1. cntrlvar 789
*
* calculate the change in reactivity between time steps
* reactivity coefficient=-9.075-6*(3)(27.5-6)(-.08)(.01)/(.0071)
($/void)
* coefficient -.08 (delta k/k)/(\delta t v/v) comes from ornl-4621, p. 72
20579400 ifrcexp mult -9.296000d-06 6.161719d-10 1
20579401 cntrlvar 793
*
* track the total reactivity change from inner fuel region dimensional
* changes, hence void created by displacement of fuel region by water
* due to thermal expansion/contraction ($/void)
20579500 ifrcdex sum 1.000000d+00 -3.184514d-04 1
20579501 0.0 1. cntrlvar 794 1. cntrlvar 795
*
*== end of dimensional changes in inner fuel ==

*== start of reactivity feedback from void created by displacement of
fuel==
*== region by water due to thermal expansion/contraction
==
*
*== start of dimensional changes in outer fuel ==
*
* calculate outer fuel region coolant temperature change from
* previous step \delta t_inner fuel coolant=t^(n+1)-t^n (^ok)
20579600 ofcooldt sum 1.000000d+00 6.539252d-05 1
20579601 0. 1. tempf 2010000 -1. cntrlvar 797
*
* calculate outer fuel region coolant temperature at previous step t^n
(^ok)
20579700 ofcoolts sum 1.000000d+00 3.461120d+02 1
20579701 0. 1. tempf 2010000
*
* calculate outer fuel region temperature change from
* previous step \delta t_outer fuel=t^(n+1)-t^n (^ok)
20579800 ofhstrdt sum 1.000000d+00 -1.525984d-06 1
20579801 0. 1. htvat 20001 -1. cntrlvar 799
*
* calculate outer fuel region temperature at previous step t^n (^ok)
20579900 ofhstrts sum 1.000000d+00 3.815350d+02 1
20579901 0. 1. htvat 20001
*
* calculate the difference between the fuel and coolant temperature
* change = \delta t_outer fuel-\delta t_outer fuel coolant (^ok)
20580000 ofdt-exp sum 1.000000d+00 -6.691851d-05 1
20580001 0. 1. cntrlvar 798 -1. cntrlvar 796
*
* calculate the change in reactivity between time steps
* reactivity coefficient=-1.97505-5*(3)(27.5-6)(-.17)(.01)/(.0071)
($/void)
* coefficient -.17 (delta k/k)/(\delta t v/v) comes from ornl-4621, p. 72
20580100 ofrcexp mult -1.975050d-05 1.321674d-09 1
20580101 cntrlvar 800
*
* track the total reactivity change from outer fuel region dimensional
* changes, hence void created by displacement of fuel region by water
* due to thermal expansion/contraction ($/void)
20580200 ifrcdex sum 1.000000d+00 9.784530d-03 1
20580201 0.108802d-05 1. cntrlvar 801 1. cntrlvar 802
*
*== end of dimensional changes in outer fuel ==
*
*== end of reactivity feedback from void created by displacement of fuel
==
*== region by water due to thermal expansion/contraction

```

```

**
**== start of reactivity feedback due to voids in the control plate and
**== reflector region simulated by moderator density changes
**
** calculate the average density in the control plate/reflector region
20580300 avedens sum 1.000000d+00 9.862500d+02 1
20580301 0.0 .1204 rho 27010000 -2057 rho 28010000
20580302 .1198 rho 29010000 .0189 rho 30010000
20580303 .3172 rho 31010000 .1934 rho 32010000
20580304 .0247 rho 36010000
**
** calculate the change in average density of the
** control plate/reflector region...note cntrlvar 776 is the average
density
** at steady state, moved to set points
** ...other weighting factors are fractions of flow area
** (kg/m^3)
20580400 deltdens sum 1.000000d+00 9.371630d-01 1
20580401 0.0 1.0 cntrlvar 803 -1.0 cntrlvar 776
**
** calculate the fractional change in average density of the
** control plate/reflector region ... note that cntrlvar 776 is the
average density at steady state (unitless) then multiply by the
** reactivity coefficient for this phenomena ($)
** coefficient 2.817 ($/void fraction)=(.02)(.01)(100.0)/.0071
** .02 comes from ornl-4621, p. 73
20580500 modeprct div 2.817000d+00 2.679340d-03 1
20580501 cntrlvar 776 cntrlvar 804
**
**== end of reactivity feedback due to voids in the control plate and
**== reflector
**== region simulated by moderator density changes
**
**== start of control plate worth as a function of control plate
position==
**== comes from figure 20, p. 41, ornl-3679
**
** table is built on inches inserted
20580600 cp-worth function 1.000000d+00 -7.206550d-00 1
20580601 cntrlvar 819 16
**
** initial control plate position for boc (inches inserted)
** comes from figure 2.1, page 2-4, ornl/tm-1168
** where inches inserted=26.86 - inches withdrawn
*20581900 shimpos constant 8.36 0.0 0
** (put this up in set points section)

```

```

**
**== end of control plate worth as a function of control plate position==
**
**== start of safety rod worth as a function of safety rod position==
**== comes from figure 20, p. 41, ornl-3679
**
** trip unit on scram trip #648 (unitless)
20580800 sr-tripu tripunit 1.000000d+00 0.000000d+00 1
20580801 648
**
** trip delay on scram trip #648 (sec)
20580900 sr-tdely tripdelay 1.000000d+00 -1.000000d+00 1
20580901 648
**
** sum time and trip delay = t - t(trip delay) (sec)
20581000 timesinc sum 1.000000d+00 3.020000d-02 1
20581001 0. 1. time 0 -1. cntrlvar 809
**
** table lookup of safety rod insertion as a function of time after scram
** (inches)
20581100 srdcypos function 1.000000d+00 2.686000d-01 1
20581101 cntrlvar 810 17
**
** if scram has occurred, return control rod inserted position
** if scram has not occurred, return zero (inches)
20581200 deltapos mult 1.000000d+00 0.000000d+00 1
20581201 cntrlvar 811 cntrlvar 808
**
** table lookup of safety rod reactivity ($) as a function of
** safety rod insertion (inches) note 4 safety rods are inserted
20581400 sr-worth function 1.000000d+00 0.000000d+00 1
20581401 cntrlvar 812 18
**
**== end of safety rod worth as a function of safety rod position==
**
**== start of reactivity feedback from voids in target region due to
**== bubble formation, based on figure 9.5, p. 72, ornl-4621
**== curve with 300-g pu target
**
** calculate the average void fraction of steam in the target region
** weighting is based on flow area fraction in target region
20581500 avetvoid sum 1.000000d+00 0.000000d+00 1
20581501 0.0 .3526 voidg 5010000 .6474 voidg 6010000
**
** table look up of reactivity vs. void fraction

```

```

*
20581600 avtreac function 1.000000d+00 0.000000d+00 1
20581601 cntrlvar 815 14
*
* reactivity ($) versus void fraction in the island
* from fig. 9.5, p. 72, orn1-4621
*
20201400 reac-t
* voidg ($)
20201401 0.0 0.0
20201402 0.01 6.34-2
20201403 0.10 .8451
20201404 0.20 1.408
20201405 0.30 1.831
20201406 0.40 2.042
20201407 0.42 2.113
20201408 0.48 1.972
*
**= end of reactivity feedback from voids in target region due to
**= bubble formation
*
**= total reactivity feedback in dollars ==
*
20581700 reactivity sum 1.000000d+00 -1.019380d+01 1
20581701 0.1. cntrlvar 782 * fuel moderator temperature
20581702 1. cntrlvar 788 * target moderator temperature
20581703 1. cntrlvar 795 * inner fuel void of fuel by coolant
20581704 1. cntrlvar 802 * outer fuel void of fuel by coolant
20581705 1. cntrlvar 805 * control and reflector void of metal by
coolant
20581706 1. cntrlvar 806 * control plates
20581707 1. cntrlvar 814 * safety rods
20581708 1. cntrlvar 816 * target region void of coolant by bubbles
*
* input added for point kinetics/reativity feedback
20585000 r_pow sum 1.000000d+03 8.500000d+07 0
20585001 0.0 1.0 cntrlvar 304
*****
* end of reactivity feedback for point-kinetics
*
*****
*****
* cosmetics
*
* costa flow excursion prediction
*
20590000 sqrtvel powerr 1.000000d+00 3.681150d+00 0
20590001 velf 10010000 0.5
20590100 temprat div 1.000000d+00 1.000000d+00 0
20590101 uf,10010000 ufj,8050000
20590200 tempjunk mult 1.000000d+00 3.795780d+02 0
20590201 cntrlvar,901 tempf,10010000
20590300 subcool sum 1.000000d+00 1.191280d+02 0
20590301 0.1.,sattemp,8010000 -1.,cntrlvar,902
20590400 costa mult 7.812500d+04 3.426012d+07 0
20590401 cntrlvar,900 cntrlvar,903
*
* secondary flows (gpm)
*
20590900 flow-ct div 1.585040d+04 1.883090d+04 1
20590901 rhofj,135000000 mflowj,135000000
20591000 flow-by div 1.585040d+04 0.000000d+00 1
20591001 rhofj,136000000 mflowj,136000000
20591100 sec-flow sum 1.000000d+00 1.883090d+04 1
20591101 0.1.,cntrlvar,909 1.,cntrlvar,910
20591200 flow-hx div 1.585040d+04 1.161320d+04 1
20591201 rhofj,210030000 mflowj,210030000
20591300 fl-ctstr div 1.585040d+04 3.112850d+04 1
20591301 rhofj,402000000 mflowj,402000000
*
* primary flows (gpm)
*
20591500 flow-pzr div 1.585040d+04 1.199090d+02 1
20591501 rhofj,79040000 mflowj,79040000
20591600 flow-rcv div 1.585040d+04 0.000000d+00 1
20591601 rhofj,38000000 mflowj,38000000
20592300 flow-ela div 1.585040d+04 4.250107d-07 1
20592301 rhofj,42000000 mflowj,42000000
20592400 flow-lea div 1.585040d+04 0.000000d+00 1
20592401 rhofj,84000000 mflowj,84000000
20592500 letdnfl sum 1.000000d+00 7.617720d+00 1
20592501 0.1.,mflowj,63000000 1.,mflowj,163000000
20592600 flow-lcn div 1.585040d+04 1.220350d+02 1
20592601 rhofj,63000000 cntrlvar,925
*
* hot spot minimum margin to boiling
*
20593000 ohs-rmb sum 5.555560d-01 2.709840d+01 1
20593001 0.1.,sattemp,10010000 -1.,http,10200105
20593100 ihs-rmb sum 5.555560d-01 5.171690d+01 1
20593101 0.1.,sattemp,16010000 -1.,http,16000105
*
* pd103 - strainer pressure drop
* static head difference of 4' 8" at 120 deg f
*
20599400 pd103 sum 1.450380d-04 1.357000d+01 1
20599401 13789.5 1.,p,80040000 -1.,p,91010000
*
* pd106 - vessel pressure drop
* static head difference of 2' 10" at 140 deg f
*
20599500 pd106 sum 1.450380d-04 1.401700d+02 1

```

```

20599501 8342.66 1.,p,80030000 -1.,p,51010000
* heat exchanger heat losses
*
20599600 hxcheat sum 1.351192d+02 2.895717d+07 1
20599601 0. 1.,htnr,100200101 1.,htnr,100200201
20599603 1.,htnr,101200101 1.,htnr,101200201
20599606 1.,htnr,102200101 1.,htnr,102200201
20599608 1.,htnr,103200101 1.,htnr,103200201
20599700 hxcheat sum 2.702383d+02 5.737634d+07 1
20599701 0. 1.,htnr,200200101 1.,htnr,200200201
20599703 1.,htnr,201200101 1.,htnr,201200201
20599706 1.,htnr,202200101 1.,htnr,202200201
20599708 1.,htnr,203200101 1.,htnr,203200201
20599900 hxheats sum 1.000000d+00 8.633351d+07 1
20599901 0. 1.,cntrlvar,996 1.,cntrlvar,997
*
*****
*
*
* g e n e r a l   t a b l e s
*
*****
* table for mcp speed in rpm
20200100 reac-t
20200101 0. 270. 0.4 270. 0.5 0. 2. 0.
* table for aux pcr pump mass flow as a fcn of pressure difference
20200200 reac-t
20200201 -100. 5.38 133.9 5.38 172.8 5.06 185.8 4.87 198.7 4.62
20200202 204. 4.16 214. 2.77 216. 0. 1.e6 0.
* ramp for pu-14 (aux. secondary coolant pump)
* and pu-11 (aux. pressurizer pump)
20200300 reac-t
20200301 0. 0. 5. 1. 1.e6 1.
* ramp for standby and auxiliary pressurizer pumps
20200400 reac-t
20200401 0. 0. 10. 0. 11. 1. 1.e6 1.
* temperature of the pool
20200500 temp
20200501 0. 100. 1.e6 100.
* heat transfer coefficient as a function of temperature
* for horizontal 18" pipe (churchill/chu)
20200600 htc-temp
20200601 100.0000000 .0000243
20200602 105.0000000 .0199535
20200603 110.0000000 .0257403
20200604 115.0000000 .0301613
20200605 120.0000000 .0339181
20200606 125.0000000 .0372559

20200607 130.0000000 .0402917
20200608 135.0000000 .0430915
20200609 140.0000000 .0456962
20200610 145.0000000 .0481332
20200611 150.0000000 .0504217
20200612 155.0000000 .0525758
20200613 160.0000000 .0546056
20200614 165.0000000 .0565190
20200615 170.0000000 .0583219
20200616 175.0000000 .0600189
20200617 180.0000000 .0616133
20200618 185.0000000 .0631075
20200619 190.0000000 .0645033
20200620 195.0000000 .0658017
20200621 200.0000000 .0670030
20200622 205.0000000 .0693590
20200623 210.0000000 .0716192
* for vertical 18" pipe (kreith)
20200700 htc-temp
20200701 100.0000000 .0000000
20200702 105.0000000 .2071920
20200703 110.0000000 .2700106
20200704 115.0000000 .3184238
20200705 120.0000000 .3598732
20200706 125.0000000 .3969620
20200707 130.0000000 .4309342
20200708 135.0000000 .4624901
20200709 140.0000000 .4920661
20200710 145.0000000 .5199542
20200711 150.0000000 .5463594
20200712 155.0000000 .5714309
20200713 160.0000000 .5952804
20200714 165.0000000 .6179926
20200715 170.0000000 .6396327
20200716 175.0000000 .6602508
20200717 180.0000000 .6798853
20200718 185.0000000 .6985650
20200719 190.0000000 .7163109
20200720 195.0000000 .7331373
20200721 200.0000000 .7490524
20200722 205.0000000 .7770929
20200723 210.0000000 .8041575
* 20" horizontal pipe
20200800 htc-temp
20200801 100.0000000 .0000218
20200802 105.0000000 .0198820
20200803 110.0000000 .0256590
20200804 115.0000000 .0300732
20200805 120.0000000 .0338246
20200806 125.0000000 .0371577
20200807 130.0000000 .0401895
20200808 135.0000000 .0429856

```

20200809	140.0000000	.0455870	20201011	150.0000000	.0505579
20200810	145.0000000	.0480210	20201012	155.0000000	.0527149
20200811	150.0000000	.0503067	20201013	160.0000000	.0547476
20200812	155.0000000	.0524582	20201014	165.0000000	.0566636
20200813	160.0000000	.0544855	20201015	170.0000000	.0584691
20200814	165.0000000	.0563967	20201016	175.0000000	.0601684
20200815	170.0000000	.0581975	20201017	180.0000000	.0617649
20200816	175.0000000	.0598926	20201018	185.0000000	.0632612
20200817	180.0000000	.0614851	20201019	190.0000000	.0646589
20200818	185.0000000	.0629776	20201020	195.0000000	.0659590
20200819	190.0000000	.0643718	20201021	200.0000000	.0671620
20200820	195.0000000	.0656687	20201022	205.0000000	.0695209
20200821	200.0000000	.0668687	20201023	210.0000000	.0717838
20200822	205.0000000	.0692222	*		
20200823	210.0000000	.0714801	* pc head tank: level as a function of %full		
* 20" vertical pipe					
20200900 htc-temp			20201100 reac-t		
20200901	100.0000000	.0000000	20201101	.000	.020
20200902	105.0000000	.0615930	20201102	.060	.080
20200903	110.0000000	.0802674	20201103	.120	.140
20200904	115.0000000	.0946594	20201104	.180	.200
20200905	120.0000000	.1069813	20201105	.240	.260
20200906	125.0000000	.1180068	20201106	.300	.320
20200907	130.0000000	.1281059	20201107	.360	.380
20200908	135.0000000	.1374867	20201108	.420	.440
20200909	140.0000000	.1462789	20201109	.480	.500
20200910	145.0000000	.1545693	20201110	.540	.560
20200911	150.0000000	.1624189	20201111	.600	.620
20200912	155.0000000	.1698721	20201112	.660	.680
20200913	160.0000000	.1769619	20201113	.720	.740
20200914	165.0000000	.1837137	20201114	.780	.800
20200915	170.0000000	.1901467	20201115	.840	.860
20200916	175.0000000	.1962760	20201116	.900	.920
20200917	180.0000000	.2021128	20201117	.960	.980
20200918	185.0000000	.2076658	*		
20200919	190.0000000	.2129413	* reactor check valve pressure vs. flow		
20200920	195.0000000	.2179433			
20200921	200.0000000	.2226745	20201200 reac-t		
20200922	205.0000000	.2310102	20201201	0.0	0.1
20200923	210.0000000	.2390558	20201202	0.25	0.3
* 16" horizontal			20201203	0.45	0.5
20201000 htc-temp			20201204	0.8	0.9
20201001	100.0000000	.0000273	20201205	2.0	3.0
20201002	105.0000000	.0200381	20201206	6.0	7.0
20201003	110.0000000	.0258365	20201207	10.0	15.0
20201004	115.0000000	.0302656	*		
20201005	120.0000000	.0340289	* letdown valve normalized area versus normalized stem position		
20201006	125.0000000	.0373722			
20201007	130.0000000	.0404128	20201300 normarea		
20201008	135.0000000	.0432168	20201301	.00000d+00	.00000d+00
20201009	140.0000000	.0458254	20201302	.3333d-01	.10228d-01
20201010	145.0000000	.0482660	20201303	.66667d-01	.28631d-01
					.16667d-01
					.50000d-01
					.83333d-01
					.36344d-02
					.18693d-01
					.39802d-01

20201304	-1.0000d+00	.52044d-01	.11667d+00	.65231d-01	20201701	0.00	0.0000	0.04	0.2888	0.08	1.5140
20201305	.13333d+00	.79263d-01	.15000d+00	.94060d-01	20201702	0.12	3.5261	0.16	6.0808	0.20	8.9283
20201306	.16667d+00	.10955d+00	.18333d+00	.12568d+00	20201703	0.24	12.0224	0.28	15.3631	0.32	18.9503
20201307	.20000d+00	.14238d+00	.21667d+00	.15961d+00	20201704	0.36	22.7841	0.40	26.86		
20201308	.23333d+00	.17733d+00	.25000d+00	.19550d+00	*	* safety rod (includes 4)	worth as a function of insertion				
20201309	.26667d+00	.21408d+00	.28333d+00	.23303d+00	*						
20201310	.30000d+00	.25232d+00	.31667d+00	.27191d+00	20201800	react-t					
20201311	.33333d+00	.29179d+00	.35000d+00	.31192d+00	20201801	0.000	-0.00000	0.543	-0.07833	1.086	-0.18291
20201312	.36667d+00	.33227d+00	.38333d+00	.35281d+00	20201802	1.629	-0.31909	2.172	-0.49111	2.715	-0.70237
20201313	.40000d+00	.37353d+00	.41667d+00	.39439d+00	20201803	3.258	-0.95569	3.801	-1.25346	4.344	-1.59773
20201314	.43333d+00	.41537d+00	.45000d+00	.43644d+00	20201804	4.887	-1.99024	5.430	-2.43236	5.973	-2.92495
20201315	.46667d+00	.45759d+00	.48333d+00	.47878d+00	20201805	6.516	-3.46822	7.059	-4.06143	7.602	-4.70255
20201316	.50000d+00	.50000d+00	.51667d+00	.52122d+00	20201806	8.145	-5.38790	8.688	-6.11166	9.231	-6.86532
20201317	.53333d+00	.54241d+00	.55000d+00	.56356d+00	20201807	9.774	-7.63706	10.317	-8.41110	10.860	-9.16695
20201318	.56667d+00	.58463d+00	.58333d+00	.60561d+00	20201808	18.86	-13.84	26.86	-13.84		
20201319	.60000d+00	.62647d+00	.61667d+00	.64719d+00	*	* t. sofu data					
20201320	.63333d+00	.66773d+00	.65000d+00	.68808d+00	*	* safety rod (includes 4)	worth as a function of insertion				
20201321	.66667d+00	.70821d+00	.68333d+00	.72809d+00	*						
20201322	.70000d+00	.74768d+00	.71667d+00	.76697d+00	20201800	react-t					
20201323	.73333d+00	.78592d+00	.75000d+00	.80450d+00	*20201801	0.0000d+00	-0.0000d+00	0.1800d+00	-0.1801d-02		
20201324	.76667d+00	.82267d+00	.78333d+00	.84039d+00	*20201802	0.3600d+00	-0.7206d-02	0.5400d+00	-0.1621d-01		
20201325	.80000d+00	.85762d+00	.81667d+00	.87432d+00	*20201803	0.7200d+00	-0.2882d-01	0.9000d+00	-0.4504d-01		
20201326	.83333d+00	.89045d+00	.85000d+00	.90594d+00	*20201804	0.1080d+01	-0.6485d-01	0.1260d+01	-0.8827d-01		
20201327	.86667d+00	.92704d+00	.88333d+00	.93477d+00	*20201805	0.1440d+01	-0.1153d+00	0.1620d+01	-0.1459d+00		
20201328	.90000d+00	.94796d+00	.91667d+00	.96020d+00	*20201806	0.1800d+01	-0.1801d+00	0.1980d+01	-0.2180d+00		
20201329	.93333d+00	.97137d+00	.95000d+00	.98131d+00	*20201807	0.2160d+01	-0.2594d+00	0.2340d+01	-0.3044d+00		
20201330	.96667d+00	.98977d+00	.98333d+00	.99637d+00	*20201808	0.2520d+01	-0.3531d+00	0.2700d+01	-0.4053d+00		
20201331	.10000d+01	.10000d+00			*20201809	0.2880d+01	-0.4612d+00	0.3060d+01	-0.5206d+00		
* target moderator reactivity as a function of temperature					*20201810	0.3240d+01	-0.5837d+00	0.3420d+01	-0.6503d+00		
*					*20201811	0.3600d+01	-0.7206d+00	0.3780d+01	-0.7944d+00		
20201500	react-t				*20201812	0.3960d+01	-0.8719d+00	0.4140d+01	-0.9530d+00		
20201501	300.00	0.01343	305.56	0.01395	311.11	0.01445					
20201502	316.67	0.01496	322.22	0.01546	327.78	0.01622					
20201503	333.33	0.01724	338.89	0.01800	344.44	0.01901					
20201504	1000.00	0.01901									
* control plate worth as a function of insertion											
*											
20201600	react-t										
20201601	0.0000	-0.0000	0.5430	-0.1071	1.0860	-0.2476					
20201602	1.6290	-0.4284	2.1720	-0.6551	2.7150	-0.9317					
20201603	3.2580	-1.2611	3.8010	-1.6456	4.3440	-2.0871					
20201604	4.8870	-2.5867	5.4300	-3.1457	5.9730	-3.7647					
20201605	6.5160	-4.4442	7.0590	-5.1844	7.6020	-5.9847					
20201606	8.1450	-6.8439	8.6880	-7.7598	9.2310	-8.7286					
20201607	9.7740	-9.7448	10.317	-10.8008	10.860	-11.8859					
20201608	19.86	-16.63	26.86	-16.63							
* safety rod insertion as a function of time after scram											
*											
20201700	react-t										
20201701	0.00	0.0000	0.04	0.2888	0.08	1.5140					
20201702	0.12	3.5261	0.16	6.0808	0.20	8.9283					
20201703	0.24	12.0224	0.28	15.3631	0.32	18.9503					
20201704	0.36	22.7841	0.40	26.86							
*	* safety rod (includes 4)	worth as a function of insertion									
*											
20201800	react-t										
20201801	0.000	-0.00000	0.543	-0.07833	1.086	-0.18291					
20201802	1.629	-0.31909	2.172	-0.49111	2.715	-0.70237					
20201803	3.258	-0.95569	3.801	-1.25346	4.344	-1.59773					
20201804	4.887	-1.99024	5.430	-2.43236	5.973	-2.92495					
20201805	6.516	-3.46822	7.059	-4.06143	7.602	-4.70255					
20201806	8.145	-5.38790	8.688	-6.11166	9.231	-6.86532					
20201807	9.774	-7.63706	10.317	-8.41110	10.860	-9.16695					
20201808	18.86	-13.84	26.86	-13.84							
*	* t. sofu data										
*	* safety rod (includes 4)	worth as a function of insertion									
*											
20201800	react-t										
*20201801	0.0000d+00	-0.0000d+00	0.1800d+00	-0.1801d-02							
*20201802	0.3600d+00	-0.7206d-02	0.5400d+00	-0.1621d-01							
*20201803	0.7200d+00	-0.2882d-01	0.9000d+00	-0.4504d-01							
*20201804	0.1080d+01	-0.6485d-01	0.1260d+01	-0.8827d-01							
*20201805	0.1440d+01	-0.1153d+00	0.1620d+01	-0.1459d+00							
*20201806	0.1800d+01	-0.1801d+00	0.1980d+01	-0.2180d+00							
*20201807	0.2160d+01	-0.2594d+00	0.2340d+01	-0.3044d+00							
*20201808	0.2520d+01	-0.3531d+00	0.2700d+01	-0.4053d+00							
*20201809	0.2880d+01	-0.4612d+00	0.3060d+01	-0.5206d+00							
*20201810	0.3240d+01	-0.5837d+00	0.3420d+01	-0.6503d+00							
*20201811	0.3600d+01	-0.7206d+00	0.3780d+01	-0.7944d+00							
*20201812	0.3960d+01	-0.8719d+00	0.4140d+01	-0.9530d+00							
*20201813	0.4320d+01	-0.1038d+01	0.4500d+01	-0.1126d+01							
*20201814	0.4680d+01	-0.1218d+01	0.4860d+01	-0.1313d+01							
*20201815	0.5040d+01	-0.1412d+01	0.5220d+01	-0.1515d+01							
*20201816	0.5400d+01	-0.1621d+01	0.5580d+01	-0.1731d+01							
*20201817	0.5760d+01	-0.1845d+01	0.5940d+01	-0.1962d+01							
*20201818	0.6120d+01	-0.2082d+01	0.6300d+01	-0.2207d+01							
*20201819	0.6480d+01	-0.2335d+01	0.6660d+01	-0.2466d+01							
*20201820	0.6840d+01	-0.2601d+01	0.7020d+01	-0.2740d+01							
*20201821	0.7200d+01	-0.2882d+01	0.7380d+01	-0.3028d+01							
*20201822	0.7560d+01	-0.3178d+01	0.7740d+01	-0.3331d+01							
*20201823	0.7920d+01	-0.3488d+01	0.8100d+01	-0.3648d+01							
*20201824	0.8280d+01	-0.3812d+01	0.8460d+01	-0.3979d+01							
*20201825	0.8640d+01	-0.4151d+01	0.8820d+01	-0.4325d+01							
*20201826	0.9000d+01	-0.4504d+01	0.9180d+01	-0.4786d+01							
*20201827	0.9360d+01	-0.4866d+01	0.9540d+01	-0.5247d+01							
*20201828	0.9720d+01	-0.5148d+01	0.9890d+01	-0.5708d+01							
*20201829	0.1848d+02	-0.1396d+02	0.1860d+02	-0.1407d+02							
*20201830	0.1872d+02	-0.1418d+02	0.1894d+02	-0.1428d+02							
*20201831	0.1896d+02	-0.1438d+02	0.1908d+02	-0.1448d+02							

*20201832	0.1920d+02	-0.1458d+02	0.1932d+02	-0.1467d+02
*20201833	0.1944d+02	-0.1477d+02	0.1956d+02	-0.1486d+02
*20201834	0.1968d+02	-0.1494d+02	0.1980d+02	-0.1503d+02
*20201835	0.1992d+02	-0.1511d+02	0.2004d+02	-0.1519d+02
*20201836	0.2016d+02	-0.1527d+02	0.2028d+02	-0.1535d+02
*20201837	0.2040d+02	-0.1542d+02	0.2052d+02	-0.1549d+02
*20201838	0.2064d+02	-0.1556d+02	0.2076d+02	-0.1563d+02
*20201839	0.2088d+02	-0.1569d+02	0.2100d+02	-0.1575d+02
*20201840	0.2112d+02	-0.1581d+02	0.2124d+02	-0.1587d+02
*20201841	0.2136d+02	-0.1592d+02	0.2148d+02	-0.1597d+02
*20201842	0.2160d+02	-0.1602d+02	0.2172d+02	-0.1607d+02
*20201843	0.2184d+02	-0.1611d+02	0.2196d+02	-0.1615d+02
*20201844	0.2208d+02	-0.1619d+02	0.2220d+02	-0.1623d+02
*20201845	0.2232d+02	-0.1627d+02	0.2244d+02	-0.1630d+02
*20201846	0.2256d+02	-0.1633d+02	0.2268d+02	-0.1636d+02
*20201847	0.2280d+02	-0.1638d+02	0.2292d+02	-0.1640d+02
*20201848	0.2304d+02	-0.1642d+02	0.2316d+02	-0.1644d+02
*20201849	0.2328d+02	-0.1646d+02	0.2340d+02	-0.1647d+02
*20201850	0.2352d+02	-0.1648d+02	0.2364d+02	-0.1649d+02
*20201851	0.2376d+02	-0.1650d+02	0.2388d+02	-0.1650d+02
*20201852	30. -16.50			
* saturation table (pressure as a fcn. of temperature)				
20203500	0.12166			
20203503	0.17803			
20203505	0.2563			
20203506	0.3632			
20203507	0.5073			
20203508	0.6988			
20203509	0.9503			
20203510	1.2763			
20203511	1.6945			
20203512	2.225			
20203513	2.892			
20203514	3.722			
20203515	4.745			
20203516	5.996			
20203517	7.515			
20203518	9.343			
20203519	11.529			
20203520	14.125			
20203521	17.188			
20203522	20.78			
20203523	24.97			
20203524	29.82			
20203525	35.42			
20203526	41.85			
20203527	49.18			
20203528	57.53			
20203529	66.98			
20203530				
20203531	310.	77.64		
20203532	320.	89.60		
20203533	330.	103.00		
20203534	340.	117.93		
20203535	350.	134.53		
20203536	360.	152.92		
* valve position to cooling tower				
20203700	0.1.			
20203701	0.1.			
20203702	87. 0.			
20203703	1.d6 0.			
* non-dimensional limit for npsh on primary coolant pumps				
20203800	0.00544	0.00445		
20203801	0.01079	0.00781		
20203802	0.01359	0.00881		
20203803	0.01848	0.01508		
* primary coolant pump post-cavitation head degradation factor				
20203900	0.0	0.0		
20203901	0.7	0.0		
20203902	0.8	0.95		
20203903	1.0	1.0		
* main circulation pump homologous curve: hvm				
20204100	0.148	0.542	0.193	0.579
20204101	0.3	0.708	0.429	0.635
20204102	0.623	0.300	0.708	0.826
* main circulation pump homologous curve: hvm inverse				
20204200	0.3	0.148	0.511	0.193
20204201	0.3	0.148	0.511	0.193
20204202	0.300	0.623	0.429	0.708
* main circulation pump speed vs. frictional torque				
20204300	0.000	20.00	0.020	21.12
20204301	0.080	25.92	100	28.00
20204302	0.160	35.68	180	38.72
20204303	0.240	49.28	260	53.28
20204304	0.320	66.72	340	71.68
20204305	0.400	88.00	420	93.92
20204306	0.480	100.00	500	116.16

```

20204307 .480 113.12 .500 120.00 .520 127.12 .540 134.48
20204308 .560 142.08 .580 149.92 .600 158.00 .620 166.32
20204309 .640 174.88 .660 183.68 .680 192.72 .700 202.00
20204310 .720 211.52 .740 221.28 .760 231.28 .780 241.52
20204311 .800 252.00 .820 262.72 .840 273.68 .860 284.88
20204312 .880 296.32 .900 308.00 .920 319.92 .940 332.08
20204313 .960 344.48 .980 357.12 1.000 370.00
*
* main circulation pump
* relative speed vs. pony motor torque (ft-lbf)
*
20204400 reac-t
20204401 0.0000 300.
20204402 0.0812 129.
20204403 0.1260 77.2
20204404 0.1707 47.6
20204405 0.23796 25.4
20204406 0.29787 15.8
20204407 0.44793 0.0
20204408 1.00000 0.0
*
* be h(temp)
*
20220000 htc-temp
20220001 100. 0.00562 115. 0.00354 120. 0.0 125. 0.00354
20220002 140. 0.00562 165. 0.00736 200. 0.00892 240. 0.0102
20220003 280. 0.0112 320. 0.0121
*
* shroud, lower plenum-2 h(temp)
*
20230000 htc-temp
20230001 100. 0.0287 115. 0.0181 120. 0.0 125. 0.0181
20230002 140. 0.0287 165. 0.0377 200. 0.0457 240. 0.0523
20230003 280. 0.0575 320. 0.0620
*
* vessel sidewall(inside) h(time)
*
20240000 htc-t
20240001 0.0 0.028 1.e6 0.028
*
* vessel sidewall(outside) h(temp)
*
20250000 htc-temp
20250001 100. 0.0 105. 0.0139 120. 0.0221 140. 0.0278
20250002 160. 0.0319 180. 0.0351 200. 0.0378 212. 0.0392
*
* vessel lid(inside) h(time)
*
20260000 htc-t
20260001 0.0 0.042 1.e6 0.042
*
* vessel lid(outside) h(temp)
*
20270000 htc-temp
20270001 100. 0.0 105. 0.0209 120. 0.0332 140. 0.0418
20270002 160. 0.0479 180. 0.0527 200. 0.0567 212. 0.0588
*
. end of case

```

INTERNAL DISTRIBUTION

1. N. C. J. Chen	16-21. D. G. Morris
2. K. W. Childs	22. A. E. Ruggles
3. D. H. Cook	23. M. Siman-Tov
4. W. G. Craddick	24. C. C. Southmayd
5. J. S. Crowell	25. A. Sozer
6. R. D. Dabbs	26-31. M. W. Wendel
7. G. F. Flanagan	32. C. D. West
8. J. D. Freels	33. P. T. Williams
9. R. E. Hale	34. G. L. Yoder
10. R. M. Harrington	35. ORNL Patent Section
11. M. Ibn-Khayat	36. Central Research Library
12. J. E. Jones Jr.	37. Document Reference Section
13. B. L. Lepard	38-39. Laboratory Records Department
14. J. A. March-Leuba	40. Laboratory Records, RC
15. D. M. McGinty	

EXTERNAL DISTRIBUTION

41. C. D. Fletcher, Idaho National Engineering Laboratory, P.O. Box 1625, 2145 East 17th Street, Teton Village Complex, Idaho Falls, ID 83415-1575
42. Office of Assistant Manager for Energy Research and Development, DOE-Oak Ridge Field Office, P.O. Box 2001, Department of Energy, Oak Ridge, TN 37831-8600
- 43-52. Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831

END

**DATE
FILMED**

3 / 25 / 93